

# Lawrence Berkeley National Laboratory

## Lawrence Berkeley National Laboratory

### **Title**

Developing Information on Energy Savings and Associated Costs and Benefits of Energy Efficient Emerging Technologies Applicable in California

### **Permalink**

<https://escholarship.org/uc/item/38v358h9>

### **Author**

Xu, Tengfang

### **Publication Date**

2011-03-31

**Public Interest Energy Research (PIER) Program  
INTERIM/FINAL PROJECT REPORT**

**Developing Information on Energy  
Savings and Associated Costs and  
Benefits of Energy Efficient Emerging  
Technologies Applicable in California**

Prepared for: California Energy Commission

Prepared by: Lawrence Berkeley National Laboratory



DECEMBER 2010

BOA-99-205-P

**Prepared by:**

**Primary Author(s):**

Tengfang Xu  
Jan Willem Slaa  
Jayant Sathaye

Lawrence Berkeley National Laboratory  
1 Cyclotron Road  
Berkeley, CA 94720  
<http://www.lbl.gov>

**Contract Number: BOA-99-205-P**



**Prepared for:**

**California Energy Commission**

Anish Gautam  
**Contract Manager**

Pramod Kulkarni  
**Project Manager**

Virginia Lew  
**Office Manager**

**Energy Efficiency Research Office**  
Laurie Ten Hope

**Deputy Director**  
**Energy Research, Development and Demonstration**  
**Division**

Melissa Jones  
**Executive Director**

**DISCLAIMER**

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.

## **ACKNOWLEDGEMENTS**

This study is sponsored by the California Energy Commission's Public Interest Energy Research (PIER) program, and managed by CIEE, under the Contract No. DE-AC02-05CH11231 with the U.S. Department of Energy. This report benefits from the guidance and recommendations provided by Anish Gautam and Promod Kulkarni of California Energy Commission's Public Interest Energy Research (PIER) program. The authors would like to thank Dr. Wanfeng Zhang of Marvel Technologies, Inc. for his review comments on the report.

## PREFACE

The California Energy Commission's Public Interest Energy Research (PIER) Program supports public interest energy research and development that will help improve the quality of life in California by bringing environmentally safe, affordable, and reliable energy services and products to the marketplace.

The PIER Program conducts public interest research, development, and demonstration (RD&D) projects to benefit California.

The PIER Program strives to conduct the most promising public interest energy research by partnering with RD&D entities, including individuals, businesses, utilities, and public or private research institutions.

- PIER funding efforts are focused on the following RD&D program areas:
- Buildings End - Use Energy Efficiency
- Energy Innovations Small Grants
- Energy - Related Environmental Research
- Energy Systems Integration
- Environmentally Preferred Advanced Generation
- Industrial/Agricultural/Water End - Use Energy Efficiency
- Renewable Energy Technologies
- Transportation

*Developing Information on Energy Savings and Associated Costs and Benefits of Energy Efficient Emerging Technologies Applicable in California* is the report for the Industrial/Agricultural/Water End - Use Energy Efficiency project (contract number BOA-99-205-P, grant number LBL9005398) conducted by Lawrence Berkeley National Laboratory. The information from this project contributes to PIER's Industrial/Agricultural/Water End - Use Energy Efficiency Program.

For more information about the PIER Program, please visit the Energy Commission's website at [www.energy.ca.gov/research/](http://www.energy.ca.gov/research/) or contact the Energy Commission at 916 - 654 - 4878.

## ABSTRACT

Adoption of energy-efficient technologies and practices as one of the most important and cost-effective strategies to reduce energy consumption while maintaining economic growth. In this study, we performed technology reviews to identify new or under-utilized technologies that could offer savings potential from improving energy efficiency and additional benefits to California industries as well as in the U.S. industries, followed by detailed technology assessment on each targeted technology, with a focus on California applications. A total of eleven emerging or underutilized technologies applicable to California were selected and characterized with detailed information in this report. The outcomes essentially include a multi-page summary profile for each of the 11 emerging or underutilized technologies applicable to California industries.

This document may be revised as the Energy Commission deems necessary. Please check for the latest version at:

[www.energy.ca.gov/contracts/pier/contractors/](http://www.energy.ca.gov/contracts/pier/contractors/)

**Keywords:** California, emerging technology

Please use the following citation for this report:

Xu, Tengfang, Jan Willem Slaa, Jayant Sathaye. (Lawrence Berkeley National Laboratory). 2011. *Developing Information on Energy Savings and Associated Costs and Benefits of Energy Efficient Emerging Technologies Applicable in California*. California Energy Commission. Publication number: **BOA-99-205-P**.

# TABLE OF CONTENTS

<b>Acknowledgements</b> .....	<b>i</b>
<b>PREFACE</b> .....	<b>ii</b>
<b>ABSTRACT</b> .....	<b>iii</b>
<b>TABLE OF CONTENTS</b> .....	<b>iv</b>
<b>Table of Tables</b> .....	<b>v</b>
<b>EXECUTIVE SUMMARY</b> .....	<b>1</b>
<b>1 Introduction</b> .....	<b>2</b>
<b>2 Methodology</b> .....	<b>3</b>
2.1 Assessment on Significance of Technologies .....	4
2.1.1 Energy savings.....	4
2.1.2 Cost of emerging technologies .....	5
2.1.3 Other benefits .....	5
2.2 Detailed Technology Characterizations.....	6
2.2.1 Market information, new technology and reference technology in California .....	6
2.2.2 Analyses of energy savings, cost, other benefits in California .....	6
<b>3 Assessment on Significance of the Selected Emerging Technology</b> .....	<b>7</b>
3.1 Advanced Treatment Technologies – Ozonation of rinse water .....	8
3.2 High-efficient Submersible Mixers for Wastewater Pond Aeration .....	11
3.3 Computer picked bacteria for better biogas generation in wastewater sludge digestion .	
.....	14
3.4 Solar dish engine to offset wastewater peak energy demand .....	17
3.5 Vanadium Redox Flow Batteries for wastewater load management .....	19
3.6 Solar Thermal Cooling Systems .....	22
3.7 Motor Efficiency Improvement by Magnetically Coupled Adjustable Speed Drives	
(MC-ASD).....	25
3.8 Power Factor Correction Controllers for More Efficient Electricity Grids.....	28
3.9 Super Boiler.....	31
3.10 CO <sub>2</sub> as a refrigerant .....	34
3.11 Submerged Combustion Melting.....	36
<b>References</b> .....	<b>39</b>

## TABLE OF TABLES

Table 1. Significance ranking for each emerging technology by three criteria (i.e., energy savings, cost, other benefits).....	5
Table 2 Significance Assessment on 11 emerging technologies applicable to California .....	7
Table 3. Advanced wastewater treatment Data table .....	10
Table 4. High efficiency water mixer Data table.....	13
Table 5. CASCADE clean energy system Data table.....	16
Table 6. Solar Power Dish Engine for Wastewater Plant Electricity Data table.....	18
Table 7. Vanadium Redox Flow Batteries for Wastewater Treatment Plants Data table.....	21
Table 8. Solar Thermal Cooling Data Table.....	24
Table 9. Magnetically Coupled Adjustable Speed Drives Data table .....	27
Table 10. Power Factor Correction Controller implementation Data Table .....	30
Table 11. Super boiler Data table .....	33
Table 12. CO2 refrigeration Data table.....	36
Table 13. Submerged combustion melting Data table .....	38



## EXECUTIVE SUMMARY

Implementation and adoption of efficient end-use technologies have proven to be one of the key measures for reducing greenhouse gas (GHG) emissions throughout the industries. In many cases, implementing energy efficiency measures is among one of the most cost effective investments that the industry could make in improving efficiency and productivity while reducing carbon dioxide (CO<sub>2</sub>) emissions. Over the years, there have been incentives to use resources and energy in a cleaner and more efficient way to create industries that are sustainable and more productive. With the working of energy programs and policies on GHG inventory and regulation, understanding and managing the costs associated with mitigation measures for GHG reductions is very important for the industry and policy makers around the world and in California. Successful implementation of applicable emerging technologies not only may help advance productivities, improve environmental impacts, or enhance industrial competitiveness, but also can play a significant role in climate-mitigation efforts by saving energy and reducing the associated GHG emissions. Developing new information on costs and savings benefits of energy efficient emerging technologies applicable in California market is important for policy makers as well as the industries. Therefore, provision of timely evaluation and estimation of the costs and energy savings potential of emerging technologies applicable to California is the focus of this report.

The overall goal of the project is to identify and select a set of emerging and under-utilized energy-efficient technologies and practices as they are important to reduce energy consumption in industry while maintaining economic growth. Specifically, this report contains the results from performing Task 3 “Technology Characterization for California Industries” for the project titled “Research Opportunities in Emerging and Under-Utilized Energy-Efficient Industrial Technologies,” sponsored by California Energy Commission (CEC) and managed by California Institute for Energy and Environment (CIEE). The project purpose is to characterize energy savings, technology costs, market potential, and economic viability of newly selected technologies applicable to California.

In this report, LBNL first performed technology reviews to identify new or under-utilized technologies that could offer potential in improving energy efficiency and additional benefits to California industries as well as in the U.S. industries, followed by detailed technology assessment on each targeted technology, with a focus on California applications. A total of eleven emerging or underutilized technologies applicable to California were selected and characterized with detailed information in this report. The outcomes essentially include a multi-page summary profile for each of the 11 emerging or underutilized technologies applicable to California industries, based on the formats used in the technology characterization reports (Xu et al. 2010; Martin et al. 2000).

# 1 Introduction

The U.S. economy used 100 quadrillion Btu (106 EJ) of primary energy in 2008. The U.S. industries accounted for 32 percent of total domestic primary energy use that served the entire commercial, residential, industrial and transportation sectors. In California, a total of 7,707 TBtu (8.1 EJ) of primary energy was used in 2008, with the industrial sector using approximately 20% annually within the last decade (de la Rue du Can et al. 2010).

Implementation and adoption of efficient end-use technologies have proven to be one of the key measures for reducing greenhouse gas (GHG) emissions throughout the industries. In many cases, implementing energy efficiency measures is among one of the most cost effective investments that the industry could make in improving efficiency and productivity while reducing carbon dioxide (CO<sub>2</sub>) emissions. Over the years, there have been incentives to use resources and energy in a cleaner and more efficient way to create industries that are sustainable and more productive. With the working of energy programs and policies on GHG inventory and regulation, understanding and managing the costs associated with mitigation measures for GHG reductions is very important for the industry and policy makers around the world and in California. Successful implementation of applicable emerging technologies not only may help advance productivities, improve environmental impacts, or enhance industrial competitiveness, but also can play a significant role in climate-mitigation efforts by saving energy. Developing new information on costs and savings benefits of energy efficient emerging technologies applicable in California market is important for policy makers as well as the industries. Therefore, provision of timely evaluation and estimation of the costs and energy savings potential of emerging technologies applicable to California is the focus of this report.

## a) Project Purpose

The overall goal of the project is to identify and select emerging and under-utilized energy-efficient technologies and practices as they are important to reduce energy consumption in industry while maintaining economic growth in California. This report contains the results from performing Task 3 “Technology Characterization for California Industries” for the project titled “Research Opportunities in Emerging and Under-Utilized Energy-Efficient Industrial Technologies,” sponsored by California Energy Commission (CEC) and managed by California Institute for Energy and Environment (CIEE). The project purpose is to characterize energy savings, technology costs, market potential, and economic viability of a set of newly selected technologies applicable to California.

## b) Project Scope

In this project, we will first perform technology reviews to identify new or under-utilized technologies that could offer potential savings from improving energy efficiency and additional benefits to California industries as well as in the U.S. industries, followed by detailed technology assessment on each targeted technology, with a focus on California applications. A minimum of eight emerging technologies or underutilized technologies applicable to California will be identified and characterized with detailed information in this report. As a result, the report will also include a multi-page summary profile for each of the 11 emerging or underutilized technologies applicable to California industries, based on the formats used in the technology characterization reports (Xu et al. 2010; Martin et al. 2000).

## 2 Methodology

Based upon the recent reviews and assessments of emerging energy-efficient industrial technologies by Xu et al. (2010), we first identified a few underutilized or new technologies that can be applicable to California industries but have not been studied before. Through further reviews, we also identified additional emerging technologies for detailed characterizations. During the course of the project, we communicated with the various industries to identify and select emerging technologies applicable to California industries. In summary, the new technologies included in this study were identified and selected via various activities that are categorized as:

1. Literature research and technology reviews, and
2. Communications with professionals and stake holders, including California Energy Commission, utility companies, and various industries in California.

Specifically, we identified a number of underutilized or new technologies that were considered to have good potential in future perspective but had not been readily commercialized or were having low market penetration in the industries. In the project, we first performed technology and literature reviews to identify technologies, and collected relevant and updated information on energy efficiency, energy savings, market adoption, and costs of the selected emerging technologies applicable to various industries in California.

Using the data and information compiled, we then performed a technology screening to profile potential significance of each of the technologies that were initially identified, and selected a portion of them for detailed characterizations of costs and savings benefits. The initially identified technologies included:

- Novel materials for sludge dewatering
- Ozonation treatment
- Reuse wastewater by membrane filtration
- Biodiesel methanol strippers
- Wastewater pond mixers
- Improve bacteria mix for biogas generation
- Solar power dish engines
- Vanadium redox flow batteries
- Solar Thermal Cooling
- Power Factor Correction
- MagnaDrive

Based upon the overall score for each technology, we have eliminated three technologies that exhibited less significance. The following technologies had individual scores were 60 or higher, and were selected for detailed characterizations.

- Ozonation treatment
- Wastewater pond mixers
- Improve bacteria mix for biogas generation
- Solar power dish engines

- Vanadium redox flow batteries
- Solar Thermal Cooling
- Power Factor Correction
- MagnaDrive

Finally, we added three promising technologies that exhibited similar significance on the national level, and performed detailed characterizations of the following technologies applicable to California markets. Prior to this study, no detailed characterization of these four technologies has been performed.

- Super Boiler
- Submerged Combustion Melting (SCM)
- Carbon dioxide as a refrigerant.

## 2.1 Assessment on Significance of Technologies

For the screening evaluation, significance of technologies was assessed by their potential using the following criteria: energy savings, first costs, and other benefits, all being compared to existing technologies. Here we used a similar rating system to rate the significance of energy saving, cost, and other benefits, as was adopted in the previous study (Xu et al. 2010). The three levels of significance are defined to be “low, medium, or high,” while in the case of “other benefits,” an additional category, “none,” is included.

Each level of significance corresponds to a pre-defined criteria score as shown in Table 1. The following describes how the criteria scores are developed including assumptions.

### 2.1.1 Energy savings

First, the potential energy savings were identified by calculating the specific energy savings of an emerging technology when compared to that of the dominating technology (business as usual). Then, we extrapolated the difference to the total (potential) market size for California. The total potential energy savings percentage in the California industries can then be obtained by dividing this energy savings by the total industrial energy use in California, e.g., 45,176 GWh in 2010 ([EIA], 2010a).

There are various ways to obtain this percentage depending on the source of data and information available, based upon our literature research. For example, the savings can be quantified as an average saving in percentage (e.g. new method saves 20% energy), an average saving per product (e.g. 0.1 MBtu per short ton), or expected total savings for the whole sector in TBtu. In the first two scenarios mentioned, scaling up was then done by either looking at the total sector primary energy use, or the total production, respectively.

In this study, we evaluated the significance of energy savings potential for each emerging technology by its total potential energy savings percentage, which is defined as energy savings divided by the total California industrial energy use in 2009.

Based upon the comparison with the total California industrial electricity energy use in 2009, a total potential energy savings percentage above 0.1 percent for one technology is considered to have a “high” potential with a score of 40 points (shown in column 2 of Table 1), while a value lower than 0.01 percent is considered to have “low” potential, with a score of 10 points. A total potential energy savings percentage ranging between 0.01 and 0.1 percent is then considered to

have medium potential, corresponding to a score of 20 points. Overall, a higher savings score means greater significance in California.

**Table 1. Significance ranking for each emerging technology by three criteria (i.e., energy savings, cost, other benefits).**

Scoring Rating	Energy Savings	Cost	Other Benefits
High	40	10	30
Medium	20	20	20
Low	10	30	10
None	-	-	0

### 2.1.2 Cost of emerging technologies

Capital cost estimates of emerging technologies were based on descriptive information obtained from literature, mostly online sources, as actual costs are commonly unavailable in public domains.

As shown in column 3 of Table 1, an emerging technology is considered to have a “high” capital cost, corresponding to a score of 10 points, if its first cost is assessed as expensive as over 1.5 times the average cost of the conventional technology. On the other hand, a technology is considered to have a “low” capital cost, corresponding to a score of 30 points, if it is assessed to be significantly cheaper than the average cost of the conventional technology. If the technology first costs were comparable to a conventional technology or unclear, it would be assumed to be “medium,” corresponding to a score of 20 points. Overall, a higher cost score means a lower cost in California.

### 2.1.3 Other benefits

Other benefits of emerging technologies, which are not directly related to energy savings or first costs, are also important factors affecting the market adoption of the emerging technologies. In the assessments, we considered four different types of other benefits: productivity improvement, product quality improvement, safety improvement benefits, and environmental benefits.

As shown in column 4 of Table 1, if any of these “other benefits” becomes the compelling driver for the technology’s adoption in the market, we would assign a high score (compelling benefits, 30 points). Otherwise, the other benefits could either be deemed ‘significant’ (medium score, 20 points), or ‘somewhat significant’ (low score, 10 points). No point was given when there were no “other benefits” identified in this study. A higher benefit score means greater significance in California.

For each technology, we then summed the scores from each of the three criteria. The summed score can in turn yield a final score that indicates the overall significance of the technology. By definitions shown in Table 1, the final score of an emerging technology could range from as low as 20 (low energy savings, high cost, no other benefit) up to 100 points (high energy savings, low cost, compelling other benefits).

According to the total score calculated for each technology, we then ranked the eight emerging technologies applicable to waste water management, and three additional cross-cutting technologies selected in this study, with a higher score indicating a higher level of significance.

In addition, we also identified three emerging technologies from the recent screening results (Xu et al. 2010) for further characterizations. As a result, a total of 11 technologies applicable to California are included for detailed characterization in this study.

## **2.2 Detailed Technology Characterizations**

For the 11 technologies selected, we performed updated characterization, each with a one- to two-page summary of the technology profiles, including a complementary data table. In the data table, the following information is included:

- Market information
- Reference technology information
- New technology information
- Energy savings analysis
- Cost analysis
- Key non-energy factors
- Evaluation
- Data source information

### **2.2.1 Market information, new technology and reference technology in California**

In the profile table, market information includes types of technology application and energy used, and the industries to which the new technology is applicable. It also includes the estimated base-case information of the market in year 2015, such as production or the energy consumed in the relevant industries. Year 2015 was the same year used in the previous report for the sake of uniformity and the lack of proper forecasting tools. The reference technology information includes the reference technology application, throughput or production unit, and final and primary energy consumption per time (year, or hour), which provides a base case for the comparison with the new technology information. New technology information includes description of the new measure, electricity use, fuel use, and primary energy use. It also includes information on current status of market implementation, date of commercialization, and estimated life time of the new measure.

### **2.2.2 Analyses of energy savings, cost, other benefits in California**

The energy savings analysis is based upon the comparison of the new technology with its reference case. Estimates were made based on compiled source data from active literature research and technology information gathered in this study.

Normally, technology cost is quantified using either the cost of equipment installation or replacement, or incremental cost per energy unit compared to that of the reference technology. Sometimes, there was a lack of data for analyzing costs in which case no reasonable assessment could be made. In those cases, it will be noted as "N/A."

The other benefits (non-energy) are evaluated using results from the screening assessments and promotion information on implementing the new technology.

Most of the updated information comes from online literature research and reviews. Specifically, we used the Google search engine to gather information and data for the technologies and the industries in which they are applicable. In addition, scientific literature was searched by using ISI Web of Knowledge. In these searches, particular emphasis was

placed on available information from manufacturers and research institutes that addressed implementation issues instead of academic issues. Information was also obtained from governmental websites (e.g. U.S. Department of Energy, U.S. Environmental Protection Agency) and the specific industry’s professional associations. Finally, information from newspaper and magazine articles was used to understand other benefits of relevant technologies in screening assessments.

### 3 Assessment on Significance of the Selected Emerging Technology

In this study, 11 technologies applicable to California industries were first assessed using the criteria described in the “Methodology” section. Table 2 includes the screening assessment results – criteria ranking scores and the total score for each of the 11 technologies.

**Table 2 Significance Assessment on 11 emerging technologies applicable to California**

Measure / Technology	Sector	Energy Savings Estimation (GWh)	Energy savings (%)	Potential for Energy Savings	Costs compared to standard	Current Market Penetration	Other Benefits	Significance of Other Benefits	Energy Scoring	Cost Scoring	Other Benefits scoring	Total Initial Scoring
Novel materials for sludge dewatering	Wastewater	18	0.04%	medium	medium	none	P, E	somewhat	0.2	0.2	0.1	50
Ozonation treatment	Food	15	0.03%	medium	low	low	P,Q,E,S	compelling	0.2	0.3	0.3	80
Reuse wastewater by membrane filtration	Wastewater	42	0.09%	medium	medium	low	E	somewhat	0.2	0.2	0.1	50
Biodiesel methanol strippers	Refineries	0.1	0.00%	low	medium	none	Q,E	significant	0.1	0.2	0.2	50
Wastewater pond mixers	Wastewater	29	0.06%	medium	low	low	Q	somewhat	0.2	0.3	0.1	60
Improve bacteria mix for biogas	Wastewater	483	1.04%	high	medium	medium	P,Q,E	compelling	0.4	0.2	0.3	90
Solar power dish engines	cross-cutting	126	0.27%	high	high	low	E	significant	0.4	0.1	0.2	70
Vanadium redox flow batteries	cross-cutting	50	0.11%	high	high	low	E	somewhat	0.4	0.1	0.1	60
Solar Thermal Cooling	cross-cutting	681	1.46%	high	high	medium	E	compelling	0.4	0.1	0.3	80
Power Factor Correction	cross-cutting	400	0.86%	high	medium	low	P,Q	significant	0.4	0.2	0.2	80
MagnaDrive	cross-cutting	816	1.75%	high	medium	low	P	somewhat	0.4	0.2	0.1	70

Table 2 shows that five out of eight technologies sponsored by the California Energy Commission received total scores of 60 or above: Ozonation treatment, wastewater pond mixers, bacteria mix for biogas generation, solar power dish engines, and vanadium redox flow batteries. Based upon technical reviews, we also identified three emerging technologies that have significant potential, some of which have been implemented or demonstrated in other countries or states, while implementation of these are rather limited or non-existent in California. These technologies include: solar thermal cooling, power factor correction, and MagnaDrive (also in Table 2). In summary, eight technologies with total scores of 60 or above are selected for further characterizations. Three technologies (shaded in yellow color) with scores lower than 60 points were excluded for further characterization in this study.

Three additional technologies identified by Xu et al. 2010 from a recent study on the national level were then added due to their significance and applicability in California.

As a result, a total of 11 technologies are selected for detail characterizations in this study.

## Detailed Characterizations

The following 11 technologies had individual scores of 60 or higher, and were selected for detailed characterizations.

- Ozonation treatment
- Wastewater pond mixers
- Improve bacteria mix for biogas generation
- Solar power dish engines
- Vanadium redox flow batteries
- Solar Thermal Cooling
- Power Factor Correction
- MagnaDrive
- Super Boiler
- High-efficiency welding
- Submerged Combustion Melting (SCM)
- Carbon dioxide as a refrigerant

Detailed characterizations are included in the following.

### **3.1 Advanced Treatment Technologies – Ozonation of rinse water**

In many wastewater treatment facilities it is common to disinfect the effluent at the end of treatment. Although definition vary, disinfection is sometimes qualified as part of tertiary or advanced treatment and aims to kill of pathogens and microorganisms ([EPA], 2004). Food processing industry may use large amounts of water to wash, cook and transport fruits and vegetables. It is estimated that 70 thousand acre feet (86,000,000 m<sup>3</sup>) are used in the fruit and vegetable industry in California annually, which is about ten percent of its industrial total water use (Gleick et al., 2003). As water use and energy use are closely related (Klein et al., 2005), the Californian fruit and vegetable industry also uses significant amounts of energy. Indeed, it estimated this sector uses 600-800 GWh annually (Shoemaker, 2006). Reducing water use by extending water lifetime and quality may therefore lead to major energy savings.

The fruit and vegetable processing industry of California is the largest in the United States due to the size of the state's agricultural sector. In 2008, some 42 million short tons (38.1 Mt) of agricultural products were harvested in the state ([CDFA], 2010). Further processing steps depend on the large variety of fruit and vegetable end products (e.g. cans, frozen, fresh). For treatment of many fresh-cut fruits and vegetables a large quantity of water is necessary to rinse the product from dirt and other pollutants like pathogens or microorganisms, which could cause decay of the food product. In the data table we estimate that ten percent of the sector total water use is used for rinse water.

Currently, rinse water may act both as a conveyor to transport the fruits or vegetables to the next process, as well as for washing. To restrict microorganism growth, the washing water is mostly chilled, especially in the case of fresh cuts and antimicrobial chemicals like chlorine and organic acids may be added (Biswas, 2009). After a certain time period this rinse water needs to be refreshed and the residual water is mostly disposed at the sewage system for municipal wastewater treatment.



New advanced treatment technologies for disinfection have gained attention lately and can generally be classified in membrane filtration, UV radiation and advanced oxidation processes (AOPs) (Zhou & Smith, 2001). Advanced treatment is beneficial as it might enable the direct reuse of effluent water (Shon, Vigneswaran, & Snyder, 2006). Reclaiming wastewater for further use reduces the energy costs involved in transport and offsite treatment as well as decreasing the impact on natural water resources. In the fruit and vegetable processing industry an ideal solution would be to reuse the water for washing processes. Another way to use these advanced technologies in these industries could also be to treat water before use. Such would extend the period in which the water can be safely used and reduce chilling costs.

The most studied alternative to conventional disinfection technologies appears is ozonation. This is an advanced oxidation process which uses the reactive ozone gas to degrade organic compounds (Zhou & Smith, 2001). As ozone (O<sub>3</sub>) decomposes readily to oxygen, no harmful residues will result in ozonation processes, which is an advantage over chlorine use. Also, some microorganisms are better disabled by ozone than by chlorine (Olmez & Kretzschmar, 2009). A disadvantage of ozonation would be that it has to be generated onsite, because its reactivity makes it an explosive compound when used without proper handling. In recent years ozone has become more popular in the food industry (Hirneisen et al., 2010).

Ozone technology has been demonstrated at some food processing plants in California for the flour production and fresh cut vegetables processing (Biswas, 2009). Especially the latter case has gained some attention, because during implementation it was realized water use was reduced by about 60% due to fewer flume water changes (Strickland et al., 2007). The system still used some chlorine, but the whole system was a worthwhile investment with a payback period of less than two years. These values are used for the data table and because reduced water consumption results in less energy required for water chilling, it is assumed that energy reduction is comparable to the reduction in water use.

While there are significant benefits of using ozone instead of chlorine varying from quality to environmental benefits, barriers to further implementation still exist. There is a lack of information and communication with regard to the technology between suppliers and end-users (Biswas, 2009). Also, some health and safety fears remain. To address these issues, the California Energy Commission is currently funding a project at the Duda Farm Fresh Foods plant in Oxnard, California.

**Table 3. Advanced wastewater treatment Data table**

	Units		Notes
<b>Advanced Wastewater Treatment Technologies</b>			
<b>wastewater-2</b>			
Addition of ozone to flume and rinse water decreases microbial growth and energy use in water chilling			
<i>Market Information:</i>			
Industries		Fruit/vegetable processing	NAICS 31142
End-use(s)		Process Cooling	
Energy types		Electricity	
Market segment		Retrofit	
2015 basecase	GWh	800	Shoemaker 2006
<i>Reference technology</i>			
Description		Chlorination of flume and rinse water	
Throughput or annual operating hours	MG	2281	10% of sector total (Gleick 2003)
Electricity use	GWh	30	
Fuel use	TBtu	0.00	
Primary Energy use	TBtu	0.26	
<i>New Measure Information:</i>			
Description		Addition of ozone to flume and rinse water to increase time water can be used	
Electricity use	GWh	15	50% reduction (1:1 water use : chilling energy use)
Fuel use	TBtu	0.00	
Primary Energy use	TBtu	0.13	
Current status		Field Test	
Date of commercialization		2012	Author's Estimate
Estimated average measure lifetime	Years	30	Author's Estimate
<i>Savings Information:</i>			
Electricity savings	GWh/%	15.21	0%
Fuel savings	TBtu/%	0.00	0%
Primary energy savings	TBtu/%	0.13	50%
Penetration rate		Low	
Feasible applications	%	90%	Applicable to most plants
Other key assumptions for savings			
Electricity savings potential in 2015	GWh	15	
Fuel savings potential in 2015	TBtu	0	
Primary energy savings potential in 2015	TBtu	0.130	
<i>Cost Effectiveness</i>			
Investment cost	\$	200000	Demonstration in salad producing industry, Strickland
Type of cost		Full	
Change in annual costs (O&M/other benefits) \$		112300	
Cost of conserved energy (electricity)	\$/kWh	N/A	
Cost of conserved energy (fuel)	\$/Mbtu	N/A	
Cost of conserved energy (primary energy)	\$/Mbtu	1100611	
Simple payback period	Years	1.8	
Internal rate of return	%	55%	
<i>Key non energy factors</i>			
Productivity benefits		Significant	Less water per product, less maintenance
Product quality benefits		Somewhat	Fewer chlorine residues
Environmental benefits		Significant	Embedded energy savings in water chain
Other benefits		Somewhat	Lower health-risk employees
Current promotional activity	H,M,L	Low	
<i>Evaluation</i>			
Major market barriers		Lack of understanding	Grant Proposal (Biswas 2009)
Likelihood of success	H,M,L	Medium	Significant benefits
Recommended next steps		More research	On energy savings
Data quality assessment	E,G,F,P	Fair	
<i>Sources</i>			
2015 basecase			Shoemaker 2006
Basecase energy use			Gleick 2003, Grant Proposal (Biswas 2009)
New Measure energy savings			Grant Proposal (Biswas 2009)
Lifetime			Author's Estimate
Feasible applications			Grant Proposal (Biswas 2009)
Costs			Strickland 2006
Key non energy factors			Grant Proposal (Biswas 2009)
Principal contacts			
Additional notes and sources			

Advanced treatment technologies like ozonation might improve the energy efficiency of the Californian food processing industry. Water chilling is a significant energy cost of this industry and any technology which can reduce water use is likely to result in energy savings. Still, more research is needed on its actual potential and implementation issues. Ozone generation for example is an energy intensive process and might limit the potential of this technology.

However, if an advanced treatment technology will be able to show productivity improvements, water reductions and environmental benefits without rebound effects, its future may be large.

### **3.2 High-efficient Submersible Mixers for Wastewater Pond Aeration**

While most wastewater treatment occurs in larger plants, small scale onsite treatment is an alternative when discharge to sewers is expensive or not possible. One of the oldest onsite methods would be the stabilization pond ([EPA], 1983). These ponds treat wastewater in large basins or ponds (sometimes also called lagoons), which are designed for an average residence time of 1-4 weeks normally. If the wastewater load is not too high, facultative ponds without aeration equipment can be used. However, many wastewater streams require artificial oxygen addition (aeration) to keep the bacteria, which break down the pollutants, alive. California currently has at least 150 aerated wastewater stabilizations ponds out of some 400 in total (Nelson, 2005).

Single wastewater treatment ponds consume less energy than a large, modern treatment plant per volume of wastewater. Still, it is expected to use about 1000 kWh per million gallons per day (MGD). To a large extent this is due to the electricity required for operating the aerators. Most aerators function both as aerator and as mixer in the wastewater pond and this might result in suboptimal working conditions (Oppenheimer, 2009). At this time aerators are mainly found in two types: surface aerators and aspirating aerators. The first pumps water into the air, while the latter pumps air into the water. In both cases there are limitations to the water depth which can be fully aerated.

Improvement of aeration efficiency will lead to a reduction in electricity use. One of the approaches to achieve such improvement is by replacing traditional water aerators by submerged water circulators or mixers. Better mixing would yield a more dynamic water surface, which would enhance oxygen transfer to the water. Recently, PAX water has developed an efficient submerged water mixer and demonstrated excellent water mixing properties in water towers with large temperature variation over the year. The main reason for these results would be in the design of the impeller. Based on computational fluid dynamics studies, the design was optimized to obtain uniform flow patterns and eliminate water gradients. The technology has been demonstrated successfully at a wastewater pond of a Californian winery and is currently being extended (Oppenheimer, 2009).

Aspirating and surface aerators cost about \$ 5000-7000 per 5 or 10 HP unit. In the data table we assume the price for a high-efficient water mixer to be \$ 10,000 per unit. If the electricity savings are large however (e.g. 50%) payback periods may be as short as half a year<sup>1</sup>. In this respect, investment in this new technology seems very worthwhile.

Nevertheless, successful demonstration in different wastewater ponds with different wastewater properties has yet to be presented as the combination of mixing and aeration is a complex issue (Sardeing et al., 2005). Oxygen transfer rates might still be lower with water mixers, compared to aerators. The water mixer requires a minimum depth of 8 feet (2.4 m) for optimal working and in some ponds this might be a problem. Also, water circulation can have unforeseen side effects. A recent study showed improved bacterial growth (which was

---

<sup>1</sup> With an industrial electricity purchase price of \$ 0.12 per kWh in California.

beneficial in this case) due to wastewater circulation (McGarvey et al., 2009). Therefore, further studies would be helpful in establish the effects of the high efficient water mixer on wastewater ponds.

The large barrier to implementation however, might be the limited scale to which the technology is applicable. While 400 wastewater ponds can be found in California (Nelson, 2005) and this number might even be larger as there is no exact recording system in the state (Oppenheimer, 2009), the ponds are generally small and may treat less than a million gallon per day (in the data table we assume 1 MGD). Its potential for energy savings on a large scale is therefore limited. Still, the technology can be valuable for small scale wastewater producers with an onsite wastewater pond who would like to cut on their energy expenses.

**Table 4. High efficiency water mixer Data table**

	Units	Notes	
<b>High efficient wastewater pond mixer wastewater-5</b>			
<b>Improved design in wastewater pond mixer results in better aeration and mixer with lower electricity costs</b>			
<i>Market Information:</i>			
Industries			
End-use(s)		Utilities	
Energy types		Electricity	
Market segment		Replace on failure	
2015 basecase	MGD	400	
<i>Reference technology</i>			
Description	Energy use of aerated pond by surface or aspirating aerator		
Throughput or annual operating hours	MGD	1	
Electricity use	kWh	1,000	
Fuel use	MBtu	0	
Primary Energy use	MBtu	9	
<i>New Measure Information:</i>			
Description	Energy use of new PAX water mixer with improved design		
Electricity use	kWh	500	
Fuel use	MBtu	0	
Primary Energy use	MBtu	4	
Current status		Commercialized	
Date of commercialization		2007	For freshwater stratification applications
Estimated average measure lifetime	Years	20	
<i>Savings Information:</i>			
Electricity savings	kWh/%	500	50%
Fuel savings	MBtu/%	0	0%
Primary energy savings	MBtu/%	4	50%
Penetration rate		Low	
Feasible applications	%	40%	
Other key assumptions for savings			
Electricity savings potential in 2015	GWh	29	
Fuel savings potential in 2015	TBtu	0	
Primary energy savings potential in 2015	TBtu	0.25	
<i>Cost Effectiveness</i>			
Investment cost	\$	10000	
Type of cost		Full	
Change in annual costs (O&M/other benefits)	\$	21900	
Cost of conserved energy (electricity)	\$/kWh	20	
Cost of conserved energy (fuel)	\$/Mbtu	0	
Cost of conserved energy (primary energy)	\$/Mbtu	5509	
Simple payback period	Years	0.5	
Internal rate of return	%	219%	
<i>Key non energy factors</i>			
Productivity benefits		None	
Product quality benefits		Somewhat	Stratified effluent
Environmental benefits		None	
Other benefits		Somewhat	Less noise
Current promotional activity	H,M,L	High	
<i>Evaluation</i>			
Major market barriers		Limited market	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Demonstration no side-effects	
Data quality assessment	E,G,F,P	Fair	
<i>Sources:</i>			
2015 basecase			Nelson 2005
Basecase energy use			EPA 1983
New Measure energy savings			Proposal (Oppenheimer 2009)
Lifetime			Author's Estimate
Feasible applications			Nelson 2005
Costs			Proposal (Oppenheimer 2009)
Key non energy factors			Paxwater.com; Proposal (Oppenheimer 2009)
Principal contacts			
Additional notes and sources			

### **3.3 Computer picked bacteria for better biogas generation in wastewater sludge digestion**

Wastewater treatment uses significant amounts of energy and accounts for 1-2 percent of the total industrial electricity use of the United States (Appelbaum, 2002). In California it is estimated that public wastewater treatment facilities use 2012 GWh (Klein et al., 2005). As more stringent environmental regulations might increase the energy intensity of wastewater treatment, there is a need to make the wastewater sector more energy efficient. One of the technologies which can reduce the energy consumption of a plant significantly is by making use of the biosolid waste to generate biogas (mainly methane). This gas can be used to drive a turbine and generate online electricity for the plant operations. Biogas is formed by anaerobic bacteria and this anaerobic digestion process has been established in wastewater treatment facilities (Lettinga, 1995). Nevertheless, natural bacteria only convert the organic sludge materials partly (60%) to natural gas (Braaksma, 2010). Improvement of this process may increase the energy efficiency of the total plant.

Currently, wastewater sludge is thickened and pretreated before actual digestion takes place (Appels et al., 2008). In the digestion process four reaction steps can be described. First, suspended organics are hydrolyzed so that all organic materials are in solution. Further degradation (acidogenesis and acetogenesis steps) takes place which results in organic acids and gasses like hydrogen and carbon dioxide. These materials are then converted in the final step to methane and carbon dioxide. Currently, the rate determining step is the initial hydrolysis step. All these steps are facilitated by anaerobic bacteria (Angenent et al., 2004).

To improve the efficiency of the anaerobic digestion process several approaches have been examined. Sludge pre-treatment by radiation for example, to ease the hydrolysis step, or co-digestion which digests several substrates simultaneously. Another approach however, addresses the bacteria which perform the digestion processes. Choosing the appropriate bacteria might enhance sludge conversion to biogas. Cascade Clean Energy has been developing software which recognizes wastewater characteristics for a fit to certain bacteria and has demonstrated large conversion gains by adding the best bacteria mix in laboratory settings (Zhou, 2009).

A wastewater treatment facility could improve its energy efficiency to a large extent if methane production would be enlarged to a large extent and used to generate electricity or for heating purposes. For the data table we assume that a plant uses 2000 kWh per million gallons of treated wastewater on average (Water Environment Federation, 2009). With potential energy savings of 30 percent due to the enhanced bacteria mix and applicability to 80 percent of the plants (> 2 MGD) ([EPA], 2008), this could yield electricity savings close to 500 GWh in California.

However, the technology still has to be developed to a commercial scale. At the moment field tests of the technology are to be performed at the Dublin San Ramon Service District wastewater plant to show whether the technology can actually be implemented on a plant level (Zhou, 2009). In this test no genetically modified bacteria will be used, which might make the biogas increase more modest. Problems might arise in controlling the large scale bacteria mix.

The technology is expensive because of the significant costs associated with bacteria acquirement, but might still have a payback period of some three years with the significant

production increase on a bench scale level. Still, capital costs are large and before a smaller wastewater treatment plant would like to invest such a technology, it has to have some proven results.

There is a definite chance of success for this technology, as the lab results have been very promising and biogas production out of a waste stream has clear benefits. It reduces infrastructural needs for energy supply and will also reduce the sludge volume which will save sludge disposal costs. Nevertheless, the complex bacteria mixture might prove difficult to maintain at a larger scale. If scaling up problems can be overcome, the impact of this technology can be very large.

**Table 5. CASCADE clean energy system Data table**

	Units	Notes	
<b>CASCADE system for enhanced biogas generation wastewater-6</b>			
<b>Improving bacteria mix to enhance biogas generation in sludge generation, combined with biogas reactor for onsite electricity generation</b>			
<i>Market Information:</i>			
Industries			
End-use(s)		Utilities	
Energy types		Electricity	
Market segment		Retrofit	
2015 basecase	GWh	2012	
<i>Reference technology</i>			
Description	Activated sludge wastewater treatment plant without digestion		
Throughput or annual operating hours	MGD	1	
Electricity use	kWh	2,000	
Fuel use	MBtu	0	
Primary Energy use	MBtu	17	
<i>New Measure Information:</i>			
Description	Activated sludge wastewater treatment plant with CASCADE bioreactor		
Electricity use	kWh	1400	
Fuel use	MBtu	0	
Primary Energy use	MBtu	12	
Current status		Field test	
Date of commercialization		2012	Estimated
Estimated average measure lifetime	Years	20	
<i>Savings Information:</i>			
Electricity savings	kWh/%	600	30%
Fuel savings	MBtu/%	0	0%
Primary energy savings	MBtu/%	5	30%
Penetration rate		Low	
Feasible applications	%	80%	
Other key assumptions for savings			
Electricity savings potential in 2015	GWh	483	
Fuel savings potential in 2015	TBtu	0	
Primary energy savings potential in 2015	TBtu	4.12	
<i>Cost Effectiveness</i>			
Investment cost	\$	780000	
Type of cost		Full	
Change in annual costs (O&M/other benefits)	\$	260000	
Cost of conserved energy (electricity)	\$/kWh	1300	
Cost of conserved energy (fuel)	\$/Mbtu	0	
Cost of conserved energy (primary energy)	\$/Mbtu	32207	
Simple payback period	Years	3.0	
Internal rate of return	%	31%	
<i>Key non energy factors</i>			
Productivity benefits		Significant	More rapid biogas generation
Product quality benefits		Somewhat	Higher energy density
Environmental benefits		Significant	Lower sludge volume
Other benefits		None	
Current promotional activity	H,M,L	Low	
<i>Evaluation</i>			
Major market barriers		No large scale results	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Large field demonstration	
Data quality assessment	E,G,F,P	Fair	
<i>Sources:</i>			
2015 basecase		Klein 2005	
Basecase energy use		Water Environment Federation 2009	
New Measure energy savings		Proposal (Zhou 2009)	
Lifetime		Author's Estimate	
Feasible applications		EPA 2008	
Costs		Proposal (Zhou 2009)	
Key non energy factors		Proposal (Zhou 2009)	
Principal contacts			
Additional notes and sources			



### 3.4 Solar dish engine to offset wastewater peak energy demand

Renewable energy sources like the wind and the sun have received major attention in the last decades as potential new sources of electricity. Especially the sun emits enormous amounts of energy, but has a low energy density which makes it more difficult to generate electricity competitively to fossil fuel sources. The main approach to solar electricity has been by developing photovoltaic cells (Gratzel, 2001). Another method however, concentrates sunlight with mirrors or lenses to create high temperatures which may drive turbines or engines. Such solar thermal energy designs have been installed for larger plants, compared to average photovoltaic sizes, at sunny locations (Ridao et al., 2007).

One of the concentrated solar power designs makes use of a large dish and a Sterling engine at the focal point (solar power dish engine). A large number of these devices can produce a significant amount of energy during daylight hours when the dish is tracking the sun. Arguably, the potential for this sort of technology may be very large, but has met with unfortunate market conditions in the past (Mills, 2004). In the last ten years however, solar power dish engines have become commercially available and are being built on 'cloudless' locations, for example in the U.S. states of Nevada and California. The intermittency of the power generation remains a disadvantage, although heat may be stored more easily than electricity.

An interesting idea is to use the solar dish engines at locations where peak energy consumption takes place during the day. This is an example of a demand response technology which acts when electricity consumption is rising to 'shave' the peak energy demand. One of the applicable industrial areas for this idea is the wastewater industry. Currently, Californian public wastewater treatment facilities use 2012 GWh annually (Klein et al., 2005) and have a larger energy demand in the daytime (Lekov et al., 2009; Park & Bennett, 2010). Demonstration of this technology at a Californian wastewater treatment facility is planned in the coming years (Loge, 2009). The demonstration project will involve 1 MW of energy producing solar engine dishes and about 330 dishes need to be built to achieve this output.

Manufacturers of such dishes are Infinia and Tessera Solar, which are starting full scale production in 2010. The reason for the very recent scale up of production is the approval of the environmental reviews of large surface projects (Woody, 2010). Still they need federal loans, because the capital investments are very significant. For the wastewater demonstration project the costs are estimated at about nine million dollars (including labor), which would correspond to some \$ 27,000 per 3 kW dish. With a current industrial electricity price of \$ 0.12 per kWh this would not yet be economical.

In the data table we take a 4 million gallon per day wastewater treatment plant with the average energy consumption of 2000 kWh / MG (Water Environment Federation, 2009) and assume the plant saves on its utility bill by installing the solar dishes. The project developers expect that these can reduce the utility-supplied energy by about 25 percent (Loge, 2009). For the whole state of California, such reduction would save some 500 GWh of publicly supplied energy if fully applied. We assume the technology to be applicable to 25% of the plant's capacities as not all plants are large enough or have sufficient land available around the plant.

Despite these limitations, the technology might become more attractive with rising energy prices and would clearly aid in the state's goal to generate more renewable energy. Especially in

the dry and sunny southern part of California, this technology would be in place. However, the costs have yet to come down to be implemented to its fullest extent.

**Table 6. Solar Power Dish Engine for Wastewater Plant Electricity Data table**

	Units	Notes	
<b>Solar dish/engine for energy storage wastewater-7</b>			
Using solar energy to offset the peak energy demand of a wastewater plant			
<i>Market Information:</i>			
Industries		Utilities	
End-use(s)		Electricity	
Energy types		Retrofit	
Market segment		2012	
2015 basecase	GWh		
<i>Reference technology</i>			
Description	Wastewater treatment plant 2 MGD		
Throughput or annual operating hours	MGD	4	
Electricity use	kWh	8,000	
Fuel use	MBtu	0	
Primary Energy use	MBtu	68	
<i>New Measure Information:</i>			
Description	Wastewater treatment plant 4 MGD with 1 MW Solar power generation		
Electricity use	kWh	6000	
Fuel use	MBtu	0	
Primary Energy use	MBtu	51	
Current status		Commercialized	
Date of commercialization		2010	
Estimated average measure lifetime	Years	25	thepowerdish.com
<i>Savings Information:</i>			
Electricity savings	kWh/%	2000	25%
Fuel savings	MBtu/%	0	0%
Primary energy savings	MBtu/%	17	25%
Penetration rate		Low	
Feasible applications	%	25%	
Other key assumptions for savings			
Electricity savings potential in 2015	GWh	126	
Fuel savings potential in 2015	TBtu	0	
Primary energy savings potential in 2015	TBtu	1.07	
<i>Cost Effectiveness</i>			
Investment cost	\$	9000000	
Type of cost		Full	
Change in annual costs (O&M/other benefits)	\$	87600	
Cost of conserved energy (electricity)	\$/kWh	4500	
Cost of conserved energy (fuel)	\$/Mbtu	0	
Cost of conserved energy (primary energy)	\$/Mbtu	28915	
Simple payback period	Years	102.7	
Internal rate of return	%	N/A	
<i>Key non energy factors</i>			
Productivity benefits		None	
Product quality benefits		None	
Environmental benefits		Significant	No greenhouse gase emissions
Other benefits		Somewhat	Low maintenance costs, peak shaving
Current promotional activity	H,M,L	Low	
<i>Evaluation</i>			
Major market barriers		Not yet profitable	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Reduce costs	
Data quality assessment	E,G,F,P	Fair	
<i>Sources:</i>			
2015 basecase		Klein 2005	
Basecase energy use		Water Environment Federation 2009	
New Measure energy savings		Proposal (Loge 2009)	
Lifetime		thepowerdish.com	
Feasible applications		thepowerdish.com	
Costs		Proposal (Loge 2009)	
Key non energy factors		Proposal (Loge 2009)	
Principal contacts			
Additional notes and sources			

### 3.5 Vanadium Redox Flow Batteries for wastewater load management

One of the challenges encountered when handling fluctuating electric energy sources and/or demands, is to maintain a stable grid which provides sufficient electric energy regardless of weather or unexpected peaks. This issue is especially important with an increasing share of renewable energy supply in a state's or nation's total energy supply, as the amount of wind or sunshine will cause larger fluctuations in some climates. An ideal solution would be to store electric energy at the moment supply is significantly larger than demand. However, electricity storage is complex and very difficult to achieve on a large scale (Lee & Gushee, 2008). Batteries have yet to deal with cost, charging time and lifetime issues at this level. Still, there are examples of promising novel battery designs like the vanadium redox flow batteries.

The wastewater treatment industry is one of the areas in which electric energy storage would help making the sector more energy efficient. Wastewater load is not continuous and stable over the day and in the year, but has periods in which treatment is more intensive than at other moments (Park & Bennett, 2010). Limiting the purchase of more expensive electricity at peak moments by energy storage would reduce the costs of a wastewater treatment facility. Also, it might help in the possible implementation of onsite biogas generators as digested sludge gas would now harness energy which could be stored and used later (Appels et al., 2008). The plant's ability to practice facility load management and demand response opportunities would increase its efficiency and reduce its operating costs. Currently, it is estimated California's publicly owned wastewater treatment plants use 2012 GWh (Klein et al., 2005) and wastewater treatment can be a large expenditure on a municipality's budget (Elliott, 2005).

While rechargeable batteries are not suitable for large scale applications so far, they have certainly developed into commercial applications at a household level, for example as rechargeable alkaline batteries or in electronics. The most common rechargeable battery has been the lead-acid battery, which is found in virtually every car. Its costs are low, but lead is highly toxic and charge cycling is limited. Other rechargeable batteries make use of materials like lithium, nickel and sodium. They have varying energy densities, costs, cycle times and efficiencies.

A promise for larger applications is offered by vanadium redox flow batteries (VRBs), which have been developed since the 1980s (Skylas-Kazacos & Robins, 1988). VRBs have a strongly distinctive operation mode compared to the batteries mentioned above, because vanadium can act both as an anode and a cathode. As the electrolyte is a vanadium-sulphuric acid solution without solids, lifetime is very long (Blanc, 2009). Another advantage is that such a battery system can be monitored in real-time due to the accessibility of the fluid, so the amount of energy which is stored is clearer. The major disadvantage would be the low energy density, which would result in large installations. Also, the costs for implementing these systems are unsure. Some demonstration sites exist, but the technology has yet to reach full commercialization and market breakthrough.

Currently, a new demonstration is planned at the Californian wastewater treatment plant in Pleasanton (Dublin San Ramon Service District) (Toca, 2009). In this plant (molten carbonate) fuel cells have been installed, which would be more effective when an electric energy storage system would be in place. Such a system could be able to reduce purchase from the electricity grid by 25 percent. Especially, since the fuel cells are run on digested sludge biogas this could

reduce energy consumption of wastewater treatment facilities by roughly the same number (data table).

There appears to be enough potential in this technology to reduce energy demand, while enabling demand response and load management. The wastewater industry could benefit from this technology. However, a limiting factor is likely to be the amount of wastewater treatment plants to which the technology would be applicable. Not every plant in California currently has an anaerobic digestion system in place which would generate the electric energy onsite. Even fewer plants are likely to have fuel cells in place. Nevertheless, successful demonstration of the Dublin San Ramon project would create a significant incentive for other plants to follow this example of an energy efficient technology.

**Table 7. Vanadium Redox Flow Batteries for Wastewater Treatment Plants Data table**

	Units	Notes	
<b>Vanadium Redox Flow Batteries wastewater-8</b>			
<b>Using new battery technology to store and mitigate energy use of wastewater treatment plants</b>			
<i>Market Information:</i>			
Industries			
End-use(s)		Utilities	
Energy types		Electricity	
Market segment		Retrofit	
2015 basecase	GWh	2012	
<i>Reference technology</i>			
Description	Wastewater treatment plant		
Throughput or annual operating hours	MGD	1	
Electricity use	kWh	2,000	
Fuel use	MBtu	0	
Primary Energy use	MBtu	17	
<i>New Measure Information:</i>			
Description	Wastewater treatment plant with VRFB system		
Electricity use	kWh	1500	
Fuel use	MBtu	0	
Primary Energy use	MBtu	13	
Current status		Commercialized	
Date of commercialization		2010	
Estimated average measure lifetime	Years	11	
<i>Savings Information:</i>			
Electricity savings	kWh/%	500	25%
Fuel savings	MBtu/%	0	0%
Primary energy savings	MBtu/%	4	25%
Penetration rate		Low	
Feasible applications	%	10%	Estimated installations with digested gas & fuel cells
Other key assumptions for savings			
Electricity savings potential in 2015	GWh	50	
Fuel savings potential in 2015	TBtu	0	
Primary energy savings potential in 2015	TBtu	0.43	
<i>Cost Effectiveness</i>			
Investment cost	\$	2500000	
Type of cost		Full	
Change in annual costs (O&M/other benefits)	\$	125000	
Cost of conserved energy (electricity)	\$/kWh	5000	
Cost of conserved energy (fuel)	\$/Mbtu	0	
Cost of conserved energy (primary energy)	\$/Mbtu	47102	
Simple payback period	Years	20.0	
Internal rate of return	%	-11%	
<i>Key non energy factors</i>			
Productivity benefits		None	
Product quality benefits		None	
Environmental benefits		Somewhat	Might enable grid integration renewables
Other benefits		Significant	Demand response, load management
Current promotional activity	H,M,L	Medium	
<i>Evaluation</i>			
Major market barriers		Costs	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Diversification	
Data quality assessment	E,G,F,P	Fair	
<i>Sources:</i>			
2015 basecase			Klein 2005
Basecase energy use			Water Environment Federation 2009
New Measure energy savings			Proposal (Toca 2009)
Lifetime			Blanc 2009
Feasible applications			EPA 2008
Costs			Proposal (Toca 2009)
Key non energy factors			Proposal (Toca 2009)
Principal contacts			
Additional notes and sources			

### 3.6 Solar Thermal Cooling Systems

Solar thermal cooling technology is applicable for industrial process cooling (and heating) from renewable resource, i.e., solar energy. Applicable areas include a variety of food processing facilities, wineries, and grocery stores in which significantly improved energy efficiency of yearlong industrial cooling or refrigeration can be realized.

A typical solar thermal cooling system consists of solar heat collector, absorption chiller, hot-water storage tank, cooling tower, pumps, valves, and additional components. Different from a conventional chiller that uses grid-electricity to power the compressor in its refrigerating cycle to produce cooling, a solar thermal cooling system uses solar thermal collectors to produce heat that operates a conventional absorption or adsorption chiller that is thermally driven, and has no mechanically-moving components such as those seen in a traditional vapor compressor that demands high electric power. In addition, a compressor-based chiller typically uses HCFC or CFC refrigerant that is among the causes of depleted ozone and increases of greenhouse gas (GHG) emissions, while absorption chillers typically use ammonia or a salt solution such as lithium bromide (LiBr) solution, which is non-toxic and environmentally friendly. The technology inherits benign energy and environmental impacts when applied in the industries (Henning 2004, CEC 2002).

The absorption chillers are essentially thermally driven that take advantage of solar heat collected to change the solution phases within its cycles, and only require a much-smaller amount of electricity to power liquid-circulation pumps. The water heated by solar collectors is used to initiate a thermal dynamic process involving low-pressure chambers that cools water to around 44 degrees Fahrenheit. The chilled water is then brought to a series of copper pipes that efficiently cool air blown through the pipes and into the space or process. Among a variety of promising solar thermal cooling technologies, LiBr-based chillers present a wide range of applicability and products in terms of their cooling capacity, safety, and services worldwide. Relatively speaking, a LiBr-based cooling system driven by solar thermal energy can provide a workable balance between its promising high-performance, simplicity, and reliability. The decreasing costs of solar panels and increasingly gained experience in their applications have made solar thermal cooling system more affordable and attractive than it was before. Solar thermal cooling technology (i.e., LiBr-based chiller driven by solar thermal heat) has been in fact beyond the “proof-of-concept” stage with a convincing proof of performance at a laboratory or a pilot scale. It has gained more market acceptance in Europe and Japan than in the US. Some recent studies were mainly focused on system design and improvement. In fact, its commercial acceptance has been more benign and widely spread in Europe (e.g., 250+ installations) thanks to efforts within the European Union to combat global warming via reducing greenhouse gas emissions. For example, a number of applications of absorption chillers of various cooling capacity have performed with reliability and safety in buildings or processing. Unfortunately, its market acceptance and applications in California industrial sectors has been at most minimal due to a combination of technical and institutional barriers. Successful demonstrations of applying such systems (e.g., medium-size systems – e.g., absorption chiller with 10-ton or more cooling capacity) in the U.S. in pilot industrial plants (food or beverage) would be highly useful to diffuse the barriers due to lack of information and proof.

Based upon technology reviews and available data, we have concluded that it provides significant energy savings potential (approximately 56%) over conventional compressor-based

chillers, while cost of saving was conservatively estimated as \$7.9/kWh. The technology would also offer significant environment benefits. Current penetration rate is essentially zero in California but this could change dramatically if programs or policies become supportive to promote its application in California. We estimate that 80% of the market for cooling requirements in food processing would be possible – corresponding to a potential energy savings of 681 GWh per year in California.

**Table 8. Solar Thermal Cooling Data Table**

	Units	Notes	
<b>Solar Thermal Cooling</b>			
<b>ET-Cal-JW8</b>			
Using thermal solar energy as driving heat source for chilling			
<i>Market Information:</i>			
Industries		Food	
End-use(s)		Process cooling	
Energy types		Electricity	
Market segment		New	
2015 basecase use	TBtu	13.0	
<i>Reference technology</i>			
Description		Conventional electric compression chiller	
Throughput or annual op. hrs.	h	8760	1 year
Electricity use	kWh	24811	Simulation of chiller in Athens
Fuel use	MBtu	0.0	
Primary energy use	MBtu	210.9	
<i>New Measure Information:</i>			
Description		Thermal chiller in combination with Advanced flat-plate collector field	
Electricity use	kWh	10997	Simulation of chiller in Athens
Fuel use	MBtu	0.0	
Primary Energy use	MBtu	93.5	
Current status		Commercial	
Date of commercialization		<1990	Henning 2004
Est. avg. measure life	Years	20	Henning 2004
<i>Savings Information:</i>			
Electricity savings	kWh/%	13814	56%
Fuel savings	MBtu/%	0.0	0%
Primary energy savings	MBtu/%	117.4	56%
Penetration rate		Low	
Feasible applications	%	80%	Author's Estimate
Other key assumptions			
Elec svgs potential in 2015	GWh	681	
Fuel svgs potential in 2015	TBtu	0	
Primary energy svgs potential in 2015	TBtu	5.79	
<i>Cost Effectiveness</i>			
Investment cost	\$	109472	Total investment cost EUR 84209 *1.3 (exchange rate)
Type of cost			
Change in other costs	\$	3310	Assuming elec price of \$ 0.12 per kWh + difference in annual O&M rate according to table 7.2 Henning 2004
Cost of saved energy (elec)	\$/kWh	7.9	
Cost of saved energy (fuel)	\$/Mbtu	N/A	
Cost of saved energy (primary)	\$/Mbtu	932	
Simple payback period	Years	33.1	
Internal rate of return	%	-4%	
<i>Key non energy factors</i>			
Productivity benefits		None	
Product quality benefits		None	
Environmental benefits		Low ODP/GWP	
Other benefits		Less toxic/not flammable	
Current promotional activity	H,M,L	Medium	
<i>Evaluation</i>			
Major market barriers		Variable energy source (at different locations)	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Large scale deployment	
Data quality assessment	E,G,F,P	Good	
<i>Sources:</i>			
2015 basecase			EIA 2009
Basecase energy use			Henning 2004
New measure energy savings			Henning 2004
Lifetime			Henning 2004
Feasible applications			Author's Estimate
Costs			Henning 2004
Key non energy factors			Kalogirou 2004
Principal contacts			
Additional notes and sources			



### **3.7 Motor Efficiency Improvement by Magnetically Coupled Adjustable Speed Drives (MC-ASD)**

One of the largest shares of industrial electric energy is used for electric motors. These motors drive pumps, fans, compressors and several other (supporting) manufacturing machines. The exact numbers among different countries vary, but can be found in the range from 30 to 70 percent of the total industrial (electric) power of a country (Saidur, 2010). In the United States industrial motor systems account for about 17 percent of the country's total electricity use (Lowe et al., 2010) and for the process manufacturing the share is as high as 71 percent ([DOE-OIT], 2000). According to the U.S. Energy Information Administration, the West Census Region uses 51.7 TWh for machine drives in its manufacturing sector ([EIA], 2009), of which 40 percent is estimated to be used in California.

Efficiency improvements in electric motor systems have large potential in California's total industrial sector due to the scale on which these motors are used, even when an improvement might be small. Modern motors do have a high efficiency ranging between 83 and 92 percent or sometimes even higher (Saidur, 2010). Still, energy is lost due to e.g. friction, harmonics and current flow through stators and rotors. Such energy losses are mostly in the form of thermal energy (heat) and can require additional cooling of the motor. Also, losses occur due to load mismatches when the load is much lower than the capacity of the motor.

While energy can be saved by straightforward ways like motor cleaning and switching it off when they are not used, more sophisticated methods have come up in the last decades. One of these approaches is by improving the match between motor operations and its varying load. This is done by using adjustable (also called variable) speed drives, which either continuously change the speed of the motor by varying electric frequencies (variable frequency drives or VFDs) or by relieving the load shaft speed (which can be done with magnetic coupling and varying the air gap). The latter technology has been developed by MagnaDrive (Bellevue, WA) and Coyote Electronics (Fort Worth, TX) (Chvala, Winiarski, & Mulkerin, 2002).

The MC-ASD technology works by varying the air gap between the magnets, which increases or decreases the difference between input and output speed (the slip). If the load decreases, the slip will be increased and the load on the motor will thereby also decrease. The MagnaDrive has been developed since 1999 and been marketed together with the Northwest Energy Efficiency Alliance (NEEA) to push the new technology to the market (Quantec LLC, 2003, 2005). Since that moment few online sources can be found, but the annual report of NEEA has reported 7,000 installations have been installed since commercialization with an estimated total power savings of 7 MW ([NEEA], 2009).

The advantages of the technology would be the energy savings due to decreasing motor load, simple installation and maintenance and the absence of possible harmonics. Still, a problem of the technology has been the total costs (Quantec LLC, 2005). It is therefore that MagnaDrive has focused on explaining the costs and energy savings over the whole lifetime of the technology ('total cost of ownership'). According to a more recent assessment the technology has comparable installation costs as VFDs, a 100-HP MagnaDrive motor should be installed for \$ 20,000 (Tredinnick, 2010). For lower power applications it might be more expensive to buy a MagnaDrive compared to a VFD. In the data table we use the data of the 2002 study performed for the U.S. Department of Energy (Chvala & Winiarski, 2002; Chvala et al., 2002).

Other disadvantages might be that the efficiency drops at lower speeds and industrial market penetration is still limited (Tredinnick, 2010). The MC-ASD technology has often been compared to VFDs and might be less favorable in several markets (Chvala et al., 2002). An argument against MC-ASD is that it still requires the motor to run at full speed, which diminishes potential energy savings ([Anon], 2007). However, the technology is successful implemented in the U.S. Navy and several wastewater treatment plants as they appear to be very suitable to larger pump and fan applications (Tredinnick, 2010).

Magnetic Coupling - Adjustable Speed Drives do have significant potential for reducing Californian energy consumption in less efficient motors as long as it is noted that they do not provide a silver bullet for all motor applications. The technology has developed into maturity over the last decade and appears to have undergone continuous growth, although market penetration might be lower than expected earlier (Quantec LLC, 2005). Nevertheless, it is a useful addition to possible energy efficiency gains in electric motors.

**Table 9. Magnetically Coupled Adjustable Speed Drives Data table**

	Units	Notes	
<b>MagnaDrive - Adjustable Speed Drive</b>			
<b>Other-1</b>			
Reduces energetic load by adjusting the speed of the load shaft without physical contact			
<i>Market Information:</i>			
Industries		Crosscutting	
End-use(s)		Motor and Drives	
Energy types		Electricity	
Market segment		Replace on failure	
2015 basecase	GWh	20680	40 percent of West Census Region Machine Drive
<i>Reference technology</i>			
Description	100 horsepower regular motor		
Throughput or annual operating hours	hours	7884	10% off-time in a year
Electricity use	kWh	109,000	
Fuel use	MBtu	0.00	
Primary Energy use	MBtu	930	Chvala 2002
<i>New Measure Information:</i>			
Description	100 horsepower motor with MagnaDrive ASD		
Electricity use	kWh	66,000	
Fuel use	MBtu	0.00	
Primary Energy use	MBtu	563	
Current status		Commercialized	
Date of commercialization		2003	Quantec 2005
Estimated average measure lifetime	Years	25	Tredinnick 2010
<i>Savings Information:</i>			
Electricity savings	kWh/%	43,000	39%
Fuel savings	TBtu/%	0.00	0%
Primary energy savings	TBtu/%	367	39%
Penetration rate		Low	
Feasible applications	%	10%	Limited
Other key assumptions for savings			
Electricity savings potential in 2015	GWh	816	
Fuel savings potential in 2015	TBtu	0	
Primary energy savings potential in 2015	TBtu	7.0	
<i>Cost Effectiveness</i>			
Investment cost	\$	20000	
Type of cost		Full	
Change in annual costs (O&M/other benefits)	\$	5160	Electricity price \$ 0.12 per kWh
Cost of conserved energy (electricity)	\$/kWh	N/A	
Cost of conserved energy (fuel)	\$/Mbtu	N/A	
Cost of conserved energy (primary energy)	\$/Mbtu	15	
Simple payback period	Years	3.9	
Internal rate of return	%	22%	
<i>Key non energy factors</i>			
Productivity benefits		None	
Product quality benefits		None	
Environmental benefits		None	
Other benefits		Significant	Avoids harmonics and mechanical wear
Current promotional activity	H,M,L	Low	
<i>Evaluation</i>			
Major market barriers		Costs	
Likelihood of success	H,M,L	Low	
Recommended next steps		Cost reduction	
Data quality assessment	E,G,F,P	Good	
<i>Sources:</i>			
2015 basecase		EIA 2009	
Basecase energy use		Chvala 2002	
New Measure energy savings		Chvala 2002	
Lifetime		Tredinnick 2010	
Feasible applications		Quantec 2005	
Costs		Tredinnick 2010	
Key non energy factors		Tredinnick 2010	
Principal contacts			
Additional notes and sources			

### 3.8 Power Factor Correction Controllers for More Efficient Electricity Grids

Because energy efficiency has become important in U.S. policy to improve its national energy security and cut on dependence from foreign fossil sources, large steps have been undertaken in optimizing energy use in appliances. However, the quality of electric power has been pursued to a small extent only. Many electric appliances use more power (volt amperes) than would be expected by just looking at the (real) power (watts) demand. This is a result from the sinusoidal wave character of AC Input to the appliances and also the nature of the load (capacitive or inductive). This can result in current waveform leading or lagging the voltage waveform. Therefore, one needs to distinguish between apparent or total power (in Volt Amperes), reactive power (in vars; reactive Volt Amperes) and the real power (in Watts). The ratio between the real and the apparent power is called the power factor and will only be optimal (i.e. has a value of 1) when there is no reactive power (and hence full overlap (in phase) for the AC Input voltage and current waveforms). This unity power factor holds good when the electric circuits contain only resistive elements and no inductive elements (Fairchild Semiconductor, 2004).

While low power factors do not influence the device itself, they do result in higher currents in the local distribution wirings and hence the total grid. This results in larger than required capacities for the generating stations because of increased energy losses in transmission lines. Up to a certain level transmission losses are unavoidable, but improved power factors could reduce the total energy requirement. In California about 20,000 GWh are lost in electricity transmission, which is close to 7 percent of the total in state electricity use ([EIA], 2010). For this reason, companies like Marvell Semiconductor have been urging policy makers to implement power factor correction controllers (PFCs) in electronic appliances as this will lead to significant energy generation savings (Sutardja, 2009). In addition lower power factors pollute the grid with harmonic currents which could affect sensitive appliances connected to the grid. Indeed, Europe has required harmonics reduction and power factor correction for larger electric appliances (over 75W) in an agency regulation from 2001 (Keyser, 2009).

Nevertheless, solid data on potential energy savings is hard to find in scientific journals, as well as in online sources. One argument for this lack of data is the misconception that actual savings might be very low as the U.S. National Institute of Standards and Technology has put forward (Misakian, Nelson, & Feero, 2009). This could be especially true for residential consumers where there is no real benefit, because they are only billed for real power (in Watts) by electricity companies and will not see a difference in their energy costs for that reason. For industrial and some commercial consumers it can be somewhat different, because these users are better targeted by electric utility companies. Many utilities have a certain penalty charge for bad power factors and hence these customers will have an incentive to improve their total power factor. The electronics company of Intel has included power factor considerations in one of their recent Energy Star whitebooks (Intel, 2009).

An example with real data on energy savings is found in a study funded by the New York State Energy Research and Development Authority (NYSERDA) where PFCs were implemented at a manufacturing plant. This led to a decrease in real power demand of some 2 percent (from 500 W to 490 W) (Ellenbogen, 2010).

This potential saving could be applied to the total transmission losses in California. But this is a very limited application because there are few incentives currently in place to apply PFCs at a larger scale than ten percent market penetration.

There are other reasons for implementing PFCs. For one, it stabilizes the power grid, which will result in less maintenance and less risk in cable failure (which happened in the New York neighborhood of Queens in 2006 for example). It might also be a necessity for future development of smart grids and distributed generation facilities (Ellenbogen, 2009). Renewable energy sources like wind and solar power, as well as LED lamps, appear to have lower power factors which need to be taken into account when implementing at a large scale (Eltawil & Zhao, 2010; Siano, Chen, Chen, & Piccolo, 2010).

In general, power factor corrections have not been understood correctly. A significant reason for this is the large confusion on what power factor correction controllers can and cannot actually achieve. PFCs decrease reactive and apparent power, which decreases the current in the grid. This does lead to diminished transmission power losses, but does not directly lead to load power reductions for (residential) end users. Still, there are good arguments to promote them, but these arguments apply largely to utilities and grid owners. Energy (and cost) savings might be found in commercial and industrial end users, but this will be dependent on the type of loads and the utility contracts. Therefore, the outlook for rapid adoption of PFCs remains mixed, until convincing energy generation savings are understood and incentives are provided for better power factor by the utility Companies and the Government. For example, improving the power factor from 0.7 to 0.98 would technically decrease transmission loss by 29%. Given that there is approximately 7% transmission loss in the U.S. annually, a 50% reduction of transmission loss due to PFCs implementation would result in savings equivalent to 2% of total transmission loss per year. In the case of California, in 2008, the total transmission loss was 20,000 GWh. If PFCs were implemented, savings from reduced transmission loss would be 400 GWh in 2008.

**Table 10. Power Factor Correction Controller implementation Data Table**

	Units		Notes	
<b>Power Factor Correction</b>				
<b>ET-Cal-JW7</b>				
Improves the power factor in electric appliances to near unity, reducing distribution losses				
<i>Market Information:</i>				
Industries			Crosscutting	
End-use(s)			Utilities	
Energy types			Electricity	
Market segment			Retrofit	
2015 basecase	GWh		20000	CA grid transmission losses of 2008
<i>Reference technology</i>				
Description		500 kW manufacturing plant		
Throughput or annual operating hours	hours		7884	10% off-time in a year
Electricity use	MWh		3,942	
Fuel use	MBtu		0.00	
Primary Energy use	MBtu		33625	
<i>New Measure Information:</i>				
Description		500 kW manufacturing plant with Power Factor Correction installed		
Electricity use	MWh		3,863	
Fuel use	MBtu		0.00	
Primary Energy use	MBtu		32953	
Current status			Commercialized	
Date of commercialization			Unknown	
Estimated average measure lifetime	Years		20	
<i>Savings Information:</i>				
Elec Savings	MWh/%		79	2%
Fuel savings	MBtu/%		0.00	0%
Primary energy savings	MBtu/%		673	2%
Penetration rate			high	
Feasible applications	%		100%	Currently limited due to lack of incentives
Other key assumptions for savings				
CA Electricity savings potential in 2015	GWh		400	
Fuel savings potential in 2015	TBtu		0	
Primary energy savings potential in 2015	TBtu		3.4	
<i>Cost Effectiveness</i>				
Investment cost	\$		20000	
Type of cost			Full	
Change in annual costs (O&M/other benefit)	\$		8600	
Cost of conserved energy (electricity)	\$/kWh		3.05	
Cost of conserved energy (fuel)	\$/Mbtu		N/A	
Cost of conserved energy (primary energy)	\$/Mbtu		0.36	
Simple payback period	Years		2.3	
Internal rate of return	%		42%	
<i>Key non energy factors</i>				
Productivity benefits			compelling	Fewer failures
Product quality benefits			Significant	Less over-heating
Environmental benefits			None	
Other benefits			Significant	Enables smart grid, LEDs
Current promotional activity	H,M,L		Low	
<i>Evaluation</i>				
Major market barriers			Little policy support	E.g. from Energy Star / NIST
Likelihood of success	H,M,L		High if policy in place	
Recommended next steps			Show significant energy savings	
Data quality assessment	E,G,F,P		Good	
<i>Sources:</i>				
2015 basecase				EIA 2010
Basecase energy use				Ellenbogen 2010
New Measure energy savings				Ellenbogen 2010
Lifetime				Author's Estimate
Feasible applications				Author's Estimate
Costs				Ellenbogen 2010
Key non energy factors				Ellenbogen 2009
Principal contacts				
Additional notes and sources				

### 3.9 Super Boiler

Steam generation is one of the largest energy consuming processes in the U.S. industry. It accounted for 2871 TBtu (3043 PJ) of reported industrial end use by regular fuel consumption (oil, gas, coal) in 2006 ([EIA], 2009), about 30 percent of the reported total. However, these numbers underestimate the actual consumption due to the use of non-regular fuels for steam generation. Therefore, the (industrial) boiler inventory of 2005 (Energy and Environmental Analysis, 2005) estimates industrial boiler energy consumption at 6500 TBtu (6890 PJ), which is 37 percent of the total energy consumption. Efficiency improvements in this area could lead to large energy savings.

Typical efficiencies of new industrial boilers range between 70 and 85 percent with regular fuels ([CIBO], 2003). In 2000 the U.S. Department of Energy initiated a new program to increase energy efficiency in steam generating systems. An important outcome of this program was the development of a 'Super Boiler' by the Gas Technology Institute and Cleaver-Brooks, which achieved fuel to steam efficiencies of 93-94 percent ([DOE-ITP], 2008). As industrial boilers lose most energy in the flue gas stack, their approach to increase boiler efficiency focused on the flue gas (Wang et al., 2008).

Two key technologies were developed to reduce flue gas temperature, volume and moisture content: a premixed staged combustion process and a transport membrane-based heat recovery system (Wang et al., 2008). The staged combustion process made use of a GTI-patented forced internal recirculation (FIR) burner, which decreases NO<sub>x</sub> emissions while slightly increasing efficiency. However, the main efficiency gain lay in the heat recovery system. By use of a ceramic membrane both the sensible heat and the latent heat contained in the water vapor is captured. Especially capturing the latent heat has proved to be difficult, but this type of membrane overcame this problem by its capillary effect.

Demonstration of the technology was first performed on a small scale with two 80 boiler horsepower (0.78 MW) firetube boilers. 94 percent fuel efficiency was demonstrated with an output of up to 4 MBtu per hour ([DOE-ITP], 2008). Boiler pilots of 200-300 boiler horsepower (1.96 - 2.94 MW) were installed at three locations: Specification Rubber Products Inc. (Alabaster, AL), Clement Pappas & Co (Ontario, CA) and Third Dimension Inc. (West Jordan, UT). While the first pilot in Alabama with a single stage combustion proved to be successful (Wang et al., 2008) and is running continuously since 2006 according to the company's website, online reports on the other locations (which would use two stage combustion) are scarce.

In October 2009 the Gas Technology Institute announced that they had licensed the Transport Membrane Condenser technology to Cannon Boilers Works ([GTI], 2009). Expectations are that the technology will be commercially available by the end of 2010 under the name Ultramizer and can be installed on new and existing industrial boilers at that time (Parkinson, 2010). Most recently, the first commercial design unit has been installed at the City Brewing plant in Latrobe, PA. 200 to 400 boiler horsepower units will be commercialized first, with larger units (400 to 800 HP) following in 2011 (Cannon Boiler Works, 2010).

In the data table we use the same energy consumption by industrial boilers as in 2005: 6500 TBtu (Energy and Environmental Analysis, 2005). Assuming an average efficiency increase from 75 to 90 percent the technology could have a fuel savings potential of over 1000 TBtu when fully

applied. Its expected payback period is 5.5 years due to the fuel saved over an expected lifetime of 30 years ([IEA ETSAP], 2010).

However, some limitations still exist. The initial design was too complex and cumbersome. Also, industrial markets would like to have fuel flexibility, which was not present (Connor, 2007). Nevertheless, a large potential for this energy efficient technology remains and the future introduction of the Transport Membrane Condenser to the market will be an important step in its implementation in industry.

For California this technology might also be very worthwhile, as its potential savings are large. Assuming California's industrial energy consumption consists for 25 percent out of industrial boilers and 17 percent savings by super boilers, it could save about 80 TBtu.



**Table 11. Super boiler Data table**

	Units	Notes	
<b>Super Boiler</b>			
<b>Advanced flue gas heat recovery system of boilers</b>			
<i>Market Information:</i>			
Industries		Crosscutting	
End-use(s)		Process heating	
Energy types		Fuels, electricity	
Market segment		New, retrofit	
2015 basecase use	TBtu	6500.0	EEA 2005
<i>Reference technology</i>			
Description		Regular industrial boiler (75% eff)	EEA 2005
Throughput or annual op. hrs.	h	1	
Electricity use	kWh	0	
Fuel use	MBtu	11.5	IEA ETSAP 2010
Primary energy use	MBtu	11.5	IEA ETSAP 2010
<i>New Measure Information:</i>			
Description		Super boiler with TMC (90% eff)	Parkinson 2010
Electricity use	kWh	0	
Fuel use	MBtu	9.6	
Primary Energy use	MBtu	9.6	
Current status		Pre-Commercial	Cannon Works 2010
Date of commercialization		2010	Cannon Works 2010
Est. avg. measure life	Years	30	IEA ETSAP 2010
<i>Savings Information:</i>			
Electricity savings	kWh/%	0	0%
Fuel savings	MBtu/%	1.9	17%
Primary energy savings	MBtu/%	1.9	17%
Penetration rate		Low	
Feasible applications	%	100%	Author's estimate
Other key assumptions			
Elec svgs potential in 2015	GWh	0	
Fuel svgs potential in 2015	Tbtu	1083	
Primary energy svgs potential in 2015	Tbtu	1083	
<i>Cost Effectiveness</i>			
Investment cost	\$	60000	IEA ETSAP 2010
Type of cost			
Change in other costs	\$	-10880	IEA ETSAP 2010
Cost of saved energy (elec)	\$/kWh	-1741.99	
Cost of saved energy (fuel)	\$/Mbtu	-1741.99	
Cost of saved energy (primary)	\$/Mbtu	-1741.99	
Simple payback period	Years	5.5	
Internal rate of return	%	17%	
<i>Key non energy factors</i>			
Productivity benefits			
Product quality benefits		None	
Environmental benefits		Significant	Lower NOx emissions, reduced water use
Other benefits		Some	Boiler size reduction
Current promotional activity	H,M,L	Low	
<i>Evaluation</i>			
Major market barriers		Competition economizers, fuel flexibility, complex design	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Successful commercialization	
Data quality assessment	E,G,F,P	Fair	
<i>Sources:</i>			
2015 basecase		EEA 2005	
Basecase energy use		IEA ETSAP 2010	
New measure energy savings		Parkinson 2010	
Lifetime		IEA ETSAP 2010	
Feasible applications		Author's estimate	
Costs		IEA ETSAP 2010	
Key non energy factors			
Principal contacts			
Additional notes and sources			

### 3.10 CO<sub>2</sub> as a refrigerant

Cooling and refrigeration processes account for 1-2 percent of primary energy use in U.S. industry of which about a third is used in food industry ([EIA], 2009). Since the main synthetic refrigerants (CFCs, HCFCs) are currently being phased out of use due to their ozone-depletion and global warming potential, interest in natural refrigerants like ammonia (NH<sub>3</sub>) and carbon dioxide (CO<sub>2</sub>) has increased significantly in the last two decades. Of these two, carbon dioxide is more easily available, is not flammable or toxic and has a higher volumetric capacity ([IIR], 2000). At lower temperatures it also has excellent energy efficiency characteristics.

Carbon dioxide has a long history as a refrigerant, dating back to the 19th century. In those days it was mostly used on ships, in theaters and in shops ([ASHRAE], 2009). Later, it fell out of favor because of the introduction of halocarbons. However, in the 1990s it attracted renewed attention due to the work by Lorentzen (Lorentzen, 1995). Since that moment some experts regard carbon dioxide as 'the natural refrigerant of the future' (Tillner-Rueth, 2009).

Carbon dioxide can be used as a regular refrigerant in mechanical vapor recompression systems, but there is an important caveat to its use. Carbon dioxide has a critical temperature of 88 degree F (31°C) at standard pressure, complicating its use at higher temperatures. Another complication is that subcritical CO<sub>2</sub> gas condensates at higher pressures compared to normal refrigeration systems. These issues result in more complex and expensive systems. There are two large classes of CO<sub>2</sub> refrigerators which work successfully with these conditions: trans-critical systems and cascade systems (which also use ammonia). Trans-critical systems resemble classic single stage refrigerators, but deliver their heat in supercritical conditions and as a consequence there is no condensation. Partial condensation only takes place at the expansion valve (Danfoss, 2008). Supercritical pressures in this system vary between 50 and 120 bars and are mostly installed in small units due to CO<sub>2</sub>'s large volumetric capacity (Reulens, 2009). Nevertheless, components for larger (industrial) units are scarce.

The other option is CO<sub>2</sub>/NH<sub>3</sub> cascade refrigerators, which combine the good thermodynamic properties of carbon dioxide at low temperatures and these of ammonia at higher temperatures. In a cascade system there are two refrigeration cycles linked via a cascade heat exchanger and this allows carbon dioxide to be kept at subcritical conditions. This system is more complicated than trans-critical systems, but here regular components can be used. Also, it is more suited for larger systems (Reulens, 2009). In the data table we use the theoretical energy consumption in a moderate climate of such a cascade system with that of a HFC system for comparison (Sawalha, 2008).

However, the extent of energy savings and efficiency with CO<sub>2</sub> systems remain unclear due to a lack of high quality data applicable to general refrigerator systems. Carbon dioxide seems excellent for low temperature applications, but would perform moderately at higher temperatures where refrigeration is perhaps more needed. Also, the costs of average CO<sub>2</sub> systems are unknown. The scarce materials for high pressure construction might make capital costs higher than alternatives. Nevertheless, CO<sub>2</sub> refrigerators are being installed in supermarkets and at industries in significant numbers (e.g. by Star Refrigeration).

Refrigeration is a crosscutting process which is found in industrial, commercial and residential applications. For the data table we kept the assessment to the U.S. food industry, where refrigeration is used widely to keep food from decay. In this field there is also a less

conventional commercial method which can use CO<sub>2</sub> as refrigerant: cryogenic freezing. By dropping liquid carbon dioxide on a food item, it may freeze rapidly and efficiently (Lang, 2006). Its advantages would be low costs and higher productivity, but it is unsure how it affects food quality (Lan & Farid, 2004). Also, cryogenic freezing can be done with liquid nitrogen which is even cheaper and more abundant than carbon dioxide. While the technology has gained some interest in scientific literature in the last decade, it does not appear to be largely applied.

Taken all together, there is a definite potential for carbon dioxide in refrigerating uses. However, at the moment both costs and energy efficiency are too uncertain to make a solid assessment of its future. Still, the number of companies investing in carbon dioxide refrigerants is large and continues to grow (Maté & Papathanasopoulos, 2010). In food industry there appears to be a slower adaptation, which is explained due to the lack of trained engineers and the larger capital cost of a completely new system (Watson, 2010). Success of CO<sub>2</sub> refrigeration will depend on increased knowledge and further demonstration of cost- and energy-efficient installations.

California has a large food processing industry, which uses about 4,500 GWh of electricity annually (Coito, Worrell, Friedmann, & Rufo, 2005). Assuming the share of cooling and refrigeration in this consumption is comparable to the national average in the food industry, California uses close to 300 GWh of electricity for this purpose annually. Significant energy efficiency gains which could be achieved by carbon dioxide refrigeration, could therefore lead to reducing electricity use. In December 2009 the California Air Resources Board acknowledged the first state regulations regarding halocarbon refrigerant use with an exemption for natural refrigerants like CO<sub>2</sub> ([CARB], 2009). This could lead to further implementation of carbon dioxide refrigeration, although the barriers from the previous paragraph still hold.

**Table 12. CO<sub>2</sub> refrigeration Data table**

	Units	Notes	
<b>CO<sub>2</sub> as a refrigerant</b>			
<b>The use of carbon dioxide for refrigeration purposes</b>			
<i>Market Information:</i>			
Industries		Food	
End-use(s)		Process cooling	
Energy types		Electricity	
Market segment		New	
2015 basecase use	TBtu	70.0	
<i>Reference technology</i>			
Description	R404A supermarket refrigeration system (theoretical, Sawalha 2008)		
Throughput or annual op. hrs.	h	1	
Electricity use	kWh	24263	
Fuel use	MBtu	0.0	
Primary energy use	MBtu	206.2	
<i>New Measure Information:</i>			
Description	CO <sub>2</sub> /NH <sub>3</sub> supermarket cascade system (theoretical, Sawalha 2008)		
Electricity use	kWh	22027	
Fuel use	MBtu	0.0	
Primary Energy use	MBtu	187.2	
Current status		Commercial	
Date of commercialization		<1995	Lorentzen 1995
Est. avg. measure life	Years	20	Author's Estimate
<i>Savings Information:</i>			
Electricity savings	kWh/%	2236	9%
Fuel savings	MBtu/%	0.0	0%
Primary energy savings	MBtu/%	19.0	9%
Penetration rate		Low	
Feasible applications	%	100%	Author's Estimate
<i>Other key assumptions</i>			
Elec svgs potential in 2015	GWh	759	
Fuel svgs potential in 2015	TBtu	0	
Primary energy svgs potential in 2015	TBtu	6.45	
<i>Cost Effectiveness</i>			
Investment cost	\$	N/A	
Type of cost			
Change in other costs	\$	N/A	
Cost of saved energy (elec)	\$/kWh	N/A	
Cost of saved energy (fuel)	\$/Mbtu	N/A	
Cost of saved energy (primary)	\$/Mbtu	N/A	
Simple payback period	Years	N/A	
Internal rate of return	%	N/A	
<i>Key non energy factors</i>			
Productivity benefits		None	
Product quality benefits		None	
Environmental benefits		Low ODP/GWP	
Other benefits		Less toxic/not flammable	
Current promotional activity	H,M,L	High	
<i>Evaluation</i>			
Major market barriers		Competition NH3, larger investment costs	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Extending CO2 freezing knowledge	
Data quality assessment	E,G,F,P	Poor	
<i>Sources:</i>			
2015 basecase			EIA 2009
Basecase energy use			Sawalha 2008
New measure energy savings			Sawalha 2008
Lifetime			Author's Estimate
Feasible applications			Author's Estimate
Costs			N/A
Key non energy factors			Reulens 2009
Principal contacts			
Additional notes and sources			

### 3.11 Submerged Combustion Melting

As one of the oldest industries in the world, the glass industry produces a substantial number of diverse glass products, such as flat glasses, container glasses, pressed/blown glasses and glass

wool. In the U.S. about 20 million short tons (18 Mt) of glass products are manufactured annually, which corresponds to a fifth of global glass production ([GMIC], 2004). It is an energy-intensive industry with an estimated annual primary energy use of 281 TBtu (298 PJ) in the U.S. ([EIA], 2009).

The largest energy consumer in glass production is the melting process, which is performed with the same basic equipment as a century ago ([DOE-ITP], 2006). Since the 1990s there is major interest in finding a new melting technology because of the need to reduce energy consumption and decrease the capital intensity of the industry. Also, more stringent environmental regulations might increase the need for new melting processes ([GMIC], 2004).

The regular melting process uses a continuously operated tank furnace fed by the batch mixture. Most furnaces are heated by natural gas, but they might be aided by electrical heating which increases melting speeds. Due to NO<sub>x</sub> formation in a normal combustion atmosphere, there is an increase in using oxy-fuel burning conditions. Energy consumption depends on the mixture and type of product but averages 6.5 MBtu per short ton (7.6 GJ/t) ([GMIC], 2004; Worrell, Galitsky, Masanet, & Graus, 2008).

An interesting new melting technology was developed in the 1960s and 1970s in the former Soviet Union and made use of submerged combustion to melt the batch, increase heat transfer and improve mixing properties. In this technique combustion takes place underneath the tank and the resulting hot flue gasses are bubbled through the molten liquid. The advantages of submerged combustion melting (SCM) are higher thermal efficiency, product quality and productivity, as well as a reduction in NO<sub>x</sub> emissions and capital costs (Greenman, 2008). Currently, a couple of SCM plants are in operation for glass melting purposes in Ukraine and Belarus ([GMIC], 2004).

In 2003, a U.S. consortium with five large glass companies, glass suppliers and the Gas Technology Institute started a project on this technology to see if could be developed commercially for the U.S. glass industry ([DOE-ITP], 2006). A SCM pilot was successfully presented throughout 2005 and 2006 (Rue, 2005), but demonstration on a larger scale has been slow. The first commercial plant to use the SCM technology is an abrasive manufacturer in La Porte, IN (Indiana Melting & Manufacturing). However, the continuous operation of the plant has been delayed for long periods. Only after Steel Dynamics acquired 90 percent of the company, it now appears the plant will be running in 2010 (Fritz, 2010).

The major barrier which needs to be overcome is likely to be investment costs. While the Gas Technology Institute estimated capital costs to be 80 percent lower than regular melting technologies, it is still a significant amount. Actual SCM installation costs are unknown; in the data table we assume capital cost to be 80 percent lower than rebuilding a regular melting system (which is \$ 10 million) ([GMIC], 2004). By using 23 percent savings on the energy bill for a 300 t/day plant, the payback period would be close to four years. Other barriers which have been encountered during the pilot are quality issues (bubbles) and a residence time which was too short because of the design (Beerkens, Schaeffer, & Speith, 2008). Therefore, the potential for this technology appears to be significant but it needs to resolve these of issues and demonstrate stable, high quality glass production.

California has twelve glass production plants out of 149 nationwide (Worrell et al., 2008). Implementing this technology in these plants might reduce primary in-state energy

consumption up to 3 Tbtu, assuming these plants produce about ten percent of total U.S. production.

**Table 13. Submerged combustion melting Data table**

	Units	Notes	
<b>Submerged Combustion Melting</b>			
<b>Using submerged combustion for more energy efficient glass batch melting</b>			
<i>Market Information:</i>			
Industries		Glass	
End-use(s)		Other	
Energy types		Natural gas, Electricity	
Market segment		Replace on failure	
2015 basecase use	tons	20,000,000	GMIC 2004
<i>Reference technology</i>			
Description	Traditional melting		
Throughput or annual op. hrs.	tons	1	
Electricity use	kWh		
Fuel use	MBtu		
Primary energy use	MBtu	6.5	Worrel 2008
<i>New Measure Information:</i>			
Description	Submerged Combustion Melting		
Electricity use	kWh		
Fuel use	MBtu		
Primary Energy use	MBtu	5.0	DOE-ITP 2006
Current status		1st commercial plant startup	
Date of commercialization		2010	
Est. avg. measure life	Years	20	Author's Estimate
<i>Savings Information:</i>			
Electricity savings	kWh/%	0	0%
Fuel savings	MBtu/%	0.0	0%
Primary energy savings	MBtu/%	1.5	23% DOE-ITP 2006
Penetration rate		Low	Greenman 2008
Feasible applications	%	90%	GMIC 2004
Other key assumptions			
Elec svgs potential in 2015	GWh		
Fuel svgs potential in 2015	Tbtu		
Primary energy svgs potential in 2015	Tbtu	27	
<i>Cost Effectiveness</i>			
Investment cost	\$	2,000,000	Author's Estimate
Type of cost		Full	
Change in other costs	\$	-547500	GMIC 2004, Author's Estimate
Cost of saved energy (elec)	\$/kWh		
Cost of saved energy (fuel)	\$/Mbtu		
Cost of saved energy (primary)	\$/Mbtu	-227977.06	
Simple payback period	Years	3.7	
Internal rate of return	%	27%	
<i>Key non energy factors</i>			
Productivity benefits		Lower capital / surface for same production	
Product quality benefits		Less defects due to better mixing	
Environmental benefits		Reduced NOx emissions	
Other benefits		Easy start / stop operation	
Current promotional activity	H,M,L	Low	
<i>Evaluation</i>			
Major market barriers		Investment costs	
Likelihood of success	H,M,L	Medium	
Recommended next steps		Demonstration with regular glass products	
Data quality assessment	E,G,F,P	Fair	
<i>Sources:</i>			
2015 basecase		GMIC 2004	
Basecase energy use		Worrel 2008	
New measure energy savings		DOE-ITP 2006	
Lifetime		Author's Estimate	
Feasible applications		GMIC 2004	
Costs		GMIC 2004, Author's Estimate	
Key non energy factors		Greenman 2008	
Principal contacts			
Additional notes and sources			

## REFERENCES

- [Anon]. (2007). MagnaDrive Adjustable Speed Drive (ASD). Retrieved 17 November, 2010, from <http://www.eng-tips.com/viewthread.cfm?qid=187627>
- [ASHRAE], American Society of Heating, Refrigeration and Air-Conditioning Engineers. (2009). ASHRAE Position Document on Natural Refrigerants. Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers.
- [CARB], California Air Resources Board. (2009). California takes another step to reducing GHG emissions.
- [CDFA], California Department of Food and Agriculture. (2010). California Agricultural Production Statistics 2008. Sacramento, CA: California Department of Food and Agriculture.
- [CEC]. California Energy Commission. Report 500-02-047F. Design and Optimization of Solar Absorption Chillers. MARCH 2002.
- [CIBO], Council of Industrial Boiler Owners. (2003, March). Energy Efficiency & Industrial Boiler Efficiency: An Industry Perspective.
- [DOE-ITP], U.S. Department of Energy Industrial Technologies Program. (2006). Energy-Efficient Glass Melting - Next Generation Melter. Washington, DC: U.S. Department of Energy.
- [DOE-ITP], U.S. Department of Energy Industrial Technologies Program. (2008). Combustion Success Story: First Super Boiler Demonstration. Washington, DC: U.S. Department of Energy.
- [DOE-OIT], U.S. Department of Energy, Office of Industrial Technologies. (2000). United States Industrial Electric Motor Systems Market Opportunities Assessment. Burlington, MA: Xenergy.
- [EIA], U.S. Energy Information Administration. (2009). 2006 Manufacturing Energy Consumption Survey. Washington, DC: U.S. Energy Information Administration.
- [EIA], U.S. Energy Information Administration. (2010). California Electricity Profile - Table 10. In sept10ca.xls (Ed.), State Electricity Profiles. Washington, DC.
- [EIA], U.S. Energy Information Administration. (2010a). Retail Electricity Sales in California Industrial Sector in 2010, [http://www.eia.gov/cneaf/electricity/page/sales\\_revenue.xls](http://www.eia.gov/cneaf/electricity/page/sales_revenue.xls), accessed March 2011.
- [EPA], U.S. Environmental Protection Agency. (2008). Clean Watershed Needs Survey: U.S. Environmental Protection Agency.
- [EPA], United States Environmental Protection Agency. (1983). Design Manual: Municipal Wastewater Stabilization Ponds (No. 625/1-83-015). Washington, DC: United States Environmental Protection Agency.

- [EPA], United States Environmental Protection Agency. (2004). Primer for Municipal Wastewater Treatment Systems (No. 832-R-04-001). Washington, DC: United States Environmental Protection Agency.
- [GMIC], Glass Manufacturing Industry Council. (2004). Glass Melting Technology: A Technical and Economic Assessment (No. DE-FC36-02D14315). Westerville, OH: Glass Manufacturing Industry Council.
- [GTI], Gas Technology Institute. (2009, October 6th). GTI Signs Licensing Agreement for Transport Membrane Condenser with Cannon Boiler Works. Retrieved August 25th, 2010, from [http://www.gastechnology.org/webroot/app/xn/xd.aspx?it=enweb&xd=6NewsRoom/2009/cannonboiler\\_NR\\_10-06-2009.xml](http://www.gastechnology.org/webroot/app/xn/xd.aspx?it=enweb&xd=6NewsRoom/2009/cannonboiler_NR_10-06-2009.xml)
- [IEA ETSAP], International Energy Agency - Energy Technology Systems Analysis Programme. (2010). Industrial Combustion Boilers (No. Technology Brief I01). Paris, France: International Energy Agency.
- [IIR], International Institut of Refrigeration. (2000). 15th Informatory Note on Refrigerants: Carbon Dioxide as a Refrigerant. Paris, France: International Institut of Refrigeration.
- [NEEA], Northwest Energy Efficiency Alliance. (2009). 2009 Annual Report. Portland, OR: Northwest Energy Efficiency Alliance.
- Angenent, L. T., Karim, K., Al-Dahhan, M. H., & Domiguez-Espinosa, R. (2004). Production of bioenergy and biochemicals from industrial and agricultural wastewater. *Trends in Biotechnology*, 22(9), 477-485.
- Appelbaum, B. (2002). Water and Sustainability: U.S. Electricity Consumption for Water Supply & Treatment - The Next Half Century (No. 1006787). Palo Alto, CA: Electric Power Research Institute (EPRI).
- Appels, L., Baeyens, J., Degreve, J., & Dewil, R. (2008). Principles and potential of the anaerobic digestion of waste-activated sludge. *Progress in Energy and Combustion Science*, 34(6), 755-781.
- Beerkens, R., Schaeffer, H., & Speith, S. (2008). Conclusions of the expert meeting on "Innovative Glass Melting Technology in the Year 2020", Innovative Melting of Glass. Brig, Switzerland.
- Biswas, P. (2009). Advanced Water Treatment Technologies for Onsite Water Reuse. In *Emerging Technologies Demonstration Grant Program* (Ed.): California Energy Commission.
- Blanc, C. (2009). Modeling of a Vanadium Redox Flow Battery Electricity Storage System. Ecole Polytechnique Fédérale de Lausanne, Lausanne, Switzerland.
- Braaksma, A. (2010). G-gas: from Groningen gas to Green gas? An assessment of the Dutch green gas potential and its delivery to the natural gas system based on Groningen gas quality. University of Groningen, Groningen, Netherlands.
- Cannon Boiler Works. (2010, 10 August). Ultramizer: Ultimate Heat Recovery System.



- Chvala, W. D., & Winiarski, D. W. (2002). Technology Demonstration: Magnetically-Coupled Adjustable Speed Drive Systems. Paper presented at the Association of Energy Engineers (AEE), World Energy Engineering Congress (WEEC).
- Chvala, W. D., Winiarski, D. W., & Mulkerin, M. C. (2002). New Technology Demonstration Program: Technology Demonstration of Magnetically-Coupled Adjustable Speed Drive Systems (No. PNNL-13879). Richland, WA: Pacific Northwest National Laboratory.
- Coito, F., Worrell, E., Friedmann, R., & Rufo, M. (2005). California Industrial Energy Efficiency Potential (No. LBNL-59956). Berkeley, CA: Lawrence Berkeley National Laboratory.
- Connor, S. (2007, August). Optimizing Steam Generation: A Call to Conserve Finite Resources and Reduce Valuable Space. Cleaver Brooks.
- Danfoss. (2008). Transcritical Refrigeration Systems with Carbon Dioxide (CO<sub>2</sub>): How to design and operate a small-capacity (< 10 kW) transcritical CO<sub>2</sub> system.
- de la Rue du Can et al et al. 2010. California Energy Balance Update and Decomposition Analysis for the Industry and Building Sectors. LBNL Report to CEC.
- Ellenbogen, R. (2009). Power Quality: How It Affects All of Us and How to Improve It. New Rochelle, NY: Power Factor Correction.
- Ellenbogen, R. (2010). At Load Power Factor Correction: Pilot Project to determine the feasibility and economics of small scale "At Load" Power Factor Correction. New Rochelle, NY: Power Factor Correction.
- Elliott, R. N. (2005). Roadmap to Energy in the Water and Wastewater Industry (No. IE054). Washington, DC: American Council for an Energy-Efficient Economy.
- Eltawil, M. A., & Zhao, Z. M. (2010). Grid-connected photovoltaic power systems: Technical and potential problems-A review. *Renewable & Sustainable Energy Reviews*, 14(1), 112-129.
- Energy and Environmental Analysis, Inc. (2005). Characterization of the U.S. Industrial Commercial Boiler Population.
- Fairchild Semiconductor. (2004). Power Factor Correction (PFC) Basics (No. Application Note 42047). San Jose, CA: Fairchild Semiconductor.
- Fritz, M. (2010). Indiana Melting near full operations; production of new material in works. *The News Dispatch*.
- Gleick, P. H., Haasz, D., Henges-Jeck, C., Srinivasan, V., Wolff, G., Cushing, K. K., et al. (2003). *Waste Not, Want Not: The Potential for Urban Water Conservation in California*. Oakland, CA: Pacific Institute.
- Gratzel, M. (2001). Photoelectrochemical cells. *Nature*, 414(6861), 338-344.
- Greenman, M. (2008, 13 November). Innovation in the Glass Industry. Paper presented at the 19<sup>o</sup> Encontro Técnico da Abividro, São Paulo, Brazil.
- Henning, Hans-Marin. 2004. *Solar-assisted Air-Conditioning in Buildings*. Springer Wien New York.

- Hirneisen, K. A., Black, E. P., Cascarino, J. L., Fino, V. R., Hoover, D. G., & Kniel, K. E. (2010). Viral Inactivation in Foods: A Review of Traditional and Novel Food-Processing Technologies. *Comprehensive Reviews in Food Science and Food Safety*, 9(1), 3-20.
- Intel. (2009). ENERGY STAR\* Version 5.0 System Implementation: Whitepaper (No. 321556-001). Santa Clara, CA: Intel.
- Keyser, G. E. (2009). Power Conservation, Improved Control, and Equipment Protection with Drive Output Synchronized Closed Transition.
- Klein, G., Krebs, M., Hall, V., O'Brien, T., & Blevins, B. B. (2005). California's Water - Energy Relationship (No. CEC-700-2005-011-SF). Sacramento, CA: California Energy Commission.
- Lan, S. H., & Farid, M. M. (2004). Experimental analysis of cryogenic freezing of food. *Journal of Chemical Engineering of Japan*, 37(2), 304-309.
- Lang, G. (2006, 19 January). Cryogenic Freezing. Paper presented at the Industrial Refrigeration Consortium Research & Technology Forum.
- Lee, B. S., & Gushee, D. E. (2008). Electricity Storage: The Achilles' Heel of Renewable Energy. *Chemical Engineering Progress*.
- Lekov, A., Thompson, L., McKane, A., Song, K., & Piette, M. A. (2009). Opportunities for Energy Efficiency and Open Automated Demand Response in Wastewater Treatment Facilities in California - Phase I Report (No. LBNL-2572E). Berkeley, CA: Lawrence Berkeley National Laboratory.
- Lettinga, G. (1995). Anaerobic-Digestion and Waste-Water Treatment Systems. *Antonie Van Leeuwenhoek International Journal of General and Molecular Microbiology*, 67(1), 3-28.
- Loge, F. J. (2009). Demonstration of Mid-Scale Concentrated Solar Power - Dish/Engine (CSP-D/E) System to Offset Peak Energy Cost at a Wastewater Treatment Facility. In *Emerging Technologies Demonstration Grant Program (Ed.)*: California Energy Commission.
- Lorentzen, G. (1993a). Application of 'natural' refrigerants. IIF/IIR Energy Efficiency in Refrigeration and Global Warming Impact - Proceedings of meetings of Commissions B1/2 of the International Institute for Refrigeration(IIR)/Institut International de Froide (IIF).
- Lorentzen, G. (1993b). Large heat pumps using CO2 refrigerant. IIF/IIR Energy Efficiency in Refrigeration and Global Warming Impact - Proceedings of meetings of Commissions B1/2 of the International Institute for Refrigeration(IIR)/Institut International de Froide (IIF).
- Lorentzen, G. (1995). The use of natural refrigerants: a complete solution to the CFC/HCFC predicament. *International Journal of Refrigeration*, 18(3), 190.
- Lowe, M., Golini, R., Gereffi, G., Ahmed, G., & Tokuoka, S. (2010). U.S. Adoption of High-Efficiency Motors and Drives: Lessons Learned. Durham, NC: Center on Globalization, Governance & Competitiveness, Duke University.

- Martin, N., Worrell, E., Ruth, M., Price, L., Elliott, R. N., Shipley, A. M., et al. (2000). *Emerging Energy-Efficient Industrial Technologies* (No. LBNL 46990). Berkeley, CA: Lawrence Berkeley National Laboratory.
- Maté, J., & Papathanasopoulos, C. (2010). *Cool Technologies: Working Without HFCs - Examples of HFC-Free Cooling Technologies in Various Industrial Sectors*: Greenpeace.
- McGarvey, J. A., Miller, W. G., Lathrop, J. R., Silva, C. J., & Bullard, G. L. (2009). Induction of purple sulfur bacterial growth in dairy wastewater lagoons by circulation. *Letters in Applied Microbiology*, 49(4), 427-433.
- Mills, D. (2004). Advances in solar thermal electricity technology. *Solar Energy*, 76(1-3), 19-31.
- Misakian, M., Nelson, T. L., & Feero, W. E. (2009). *Regarding Electric Energy Savings, Power Factors, and Carbon Footprints: A Primer* (No. NIST Technical Note 1654). Gaithersburg, MD: National Institute for Standards and Technology.
- Nelson, K. L. (2005). Small and Decentralized Systems for Wastewater Treatment and Reuse. In H. Vaux, J. Crook & R. Parkin (Eds.), *Water Conservation, Reuse, and Recycling: Proceedings of an Iranian-American Workshop* (pp. 54-66). Washington, DC: National Academies Press.
- Olmez, H., & Kretzschmar, U. (2009). Potential alternative disinfection methods for organic fresh-cut industry for minimizing water consumption and environmental impact. *Lwt-Food Science and Technology*, 42(3), 686-693.
- Oppenheimer, J. (2009). High-Efficiency Submersible Mixers for Wastewater Pond Aeration. In *Emerging Technologies Demonstration Grant Program* (Ed.): California Energy Commission.
- Park, L., & Bennett, B. (2010). *Embedded Energy in Water Studies - Study 2: Water Agency and Function Component Study and Embedded Energy-Water Load Profiles*. Sacramento, CA: California Public Utilities Commission.
- Parkinson, G. (2010). 'Super Boiler' achieves higher efficiency through the recovery of waste heat. *Chemical Engineering* (January).
- Quantec LLC. (2003). *MagnaDrive: Market Progress Evaluation Report No. 3* (No. E03-118). Portland, OR: Quantec.
- Quantec LLC. (2005). *MagnaDrive: Market Progress Evaluation Report No. 4* (No. E05-149). Portland, OR: Quantec.
- Reulens, W. (2009). *Natural Refrigerant CO2* (No. NARECO2). Diepenbeek, Belgium: Katholieke Hogeschool Limburg.
- Ridao, A. R., Garcia, E. H., Escobar, B. M., & Toro, M. Z. (2007). Solar energy in Andalusia (Spain): present state and prospects for the future. *Renewable & Sustainable Energy Reviews*, 11(1), 148-161.
- Rue, D. (2005, 26 October). *Submerged Combustion Melting: The Next Generation Melting System*. Paper presented at the 66th Glass Problems Conference, Champaign, IL.

- Saidur, R. (2010). A review on electrical motors energy use and energy savings. *Renewable & Sustainable Energy Reviews*, 14(3), 877-898.
- Sardeing, R., Poux, M., Melen, S. P., Avriillier, P., & Xuereb, C. (2005). Aeration of large size tanks by a surface agitator. *Chemical Engineering & Technology*, 28(5), 587-595.
- Sawalha, S. (2008). Theoretical evaluation of trans-critical CO<sub>2</sub> systems in supermarket refrigeration. Part II: System modifications and comparisons of different solutions. *International Journal of Refrigeration*, 31(3), 525.
- Shoemaker, S. (2006). *Technology Roadmap: Energy Efficiency in California's Food Industry* (No. CEC-500-2006-073). Sacramento, CA: California Energy Commission.
- Shon, H. K., Vigneswaran, S., & Snyder, S. A. (2006). Effluent organic matter (EfOM) in wastewater: Constituents, effects, and treatment. *Critical Reviews in Environmental Science and Technology*, 36(4), 327-374.
- Siano, P., Chen, P., Chen, Z., & Piccolo, A. (2010). Evaluating maximum wind energy exploitation in active distribution networks. *Generation Transmission & Distribution*, 4(5), 598-608. Institution of Engineering and Technology.
- Skyllas-Kazacos, M., & Robins, R. (1988). *All-vanadium redox battery*. United States: Unisearch Ltd.
- Strickland, W., Sopher, C. D., Rice, R. G., & Battles, G. T. (2007). Six Years of Ozone Processing of Fresh Cut Salad Mixes. Paper presented at the IOA Conference and Exhibition, Valencia, Spain.
- Sutardja, S. (2009, 18 May). Tech's little green secret. Reuters.
- Tillner-Rueth, R. (2009). Environmentally Friendly Refrigeration in the Retail Trade: Refrigerant R22 soon to be a Thing of the Past - Future Ecological Alternative Can Be CO<sub>2</sub>. In V. Hasse, L. Edeber & D. Colbourne (Eds.), *Natural Refrigerants: Sustainable Ozone- and Climate-Friendly Alternatives to HCFCs*. Eschborn, Germany: Deutsche Gesellschaft für Technische Zusammenarbeit (GTZ).
- Toca, C. (2009). Application of High Capacity Electric Energy Storage via Vanadium Redox Flow Batteries, in conjunction with Fuel Cells, to a Wastewater Treatment Facility. In *Emerging Technologies Demonstration Grant Program* (Ed.): California Energy Commission.
- Tredinnick, S. (2010). Magnetic Couplings: A peachy 'new' flavor for ASDs? *District Energy* (2), 66-67.
- Wang, D., Knight, R., Chojnacki, D., Molvie, P., Tynkov, B., & Willems, D. (2008). Saving Energy with the High Efficiency Super Boiler. *Energy Engineering*, 105(3), 38 - 48.
- Water Environment Federation. (2009). *Energy Conservation in Water and Wastewater Facilities*. New York, NY: McGraw-Hill.
- Watson, E. (2010, 3 August). BOC: Carbon dioxide will remain niche refrigerant in food production. [FoodManufacture.co.uk](http://FoodManufacture.co.uk).

- Woody, T. (2010, 29 October). Warp Speed for Risky Solar Ventures. *New York Times*.
- Worrell, E., Galitsky, C., Masanet, E., & Graus, W. (2008). Energy Efficiency Improvement and Cost Saving Opportunities for the Glass Industry (No. LBNL-57335-Revision). Berkeley, CA: Lawrence Berkeley National Laboratory.
- Xu, T., Slaat, J., and Sathaye, J. 2010. Characterizing Costs, Savings and Benefits of a Selection of Energy Efficient Emerging Technologies in the United States. LBNL Report to CEC/CIEE.
- Zhou, C. (2009). CASCADE Clean Energy System for California Energy Commission PIER ETDG in Water and Waste Water Projects. In *Emerging Technologies Demonstration Grant Program* (Ed.): California Energy Commission.
- Zhou, H., & Smith, D. W. (2001). Advanced technologies in water and wastewater treatment. *Canadian Journal of Civil Engineering*, 28, 49-66.