

A Simulation Based Comparison of AC and DC Power Distribution Networks in Buildings

ACEEE 2018 Summer Study on Buildings

Daniel Gerber, Vagelis Vossos, Richard Brown, Chris Marnay, Wei Feng

dgerb@lbl.gov


Lawrence Berkeley National Laboratory

Motivation


- Solar PV generation, battery storage, and most loads are natively DC
- How much efficiency savings with DC building distribution?
- Particularly relevant for Zero Net Energy (ZNE) and microgrid buildings

Research Goal


- Determine the cost savings with DC distribution
- Modeled buildings for study
 - Medium sized office building, retail, and restaurant
 - PV and Load profiles for San Francisco, CA
 - Electrical loss models in Modelica



Medium Office Building



Retail




Restaurant

Office Building with AC Distribution


Voltage Domains:

120V AC, **48V DC**, **380V DC**



1. Maximum Power Point Tracking (MPPT) Inverter
2. Battery Inverter
3. Load Packaged Rectifier (all loads are internally DC)

Office Building with DC Distribution




Techno-Economic Analysis Overview

$$\text{LCC} = \text{Total Installed Cost} + \text{Lifetime Operating Cost}$$




Lifetime Operating Cost

$$= \sum_{y=1}^{\text{Lifetime}} \frac{\text{Operating Cost}(y)}{(1+r)^y}$$

$$\text{PBP} = \frac{\text{Total Installed Cost}_{\text{DC}} - \text{Total Installed Cost}_{\text{AC}}}{\text{Annual Operating Cost}_{\text{AC}} - \text{Annual Operating Cost}_{\text{DC}}}$$



Total Installed Cost – Loads



Building load profiles


- Electronics: wall adapters required for AC
- Lighting: LED drivers required for AC and DC
- Motor Loads (HVAC, elevator): Bridge rectifiers required for AC, but very low cost

Total Installed Cost – Equipment

Parameter	Minimum/ Default Value	Maximum Value	Unit
<i>First Cost Parameters</i>			
AC inverter cost	190	290	\$/kW
AC battery inverter cost	370	660	\$/kW
DC optimizer cost	100	220	\$/kW
DC grid-tie inverter*	370	660	\$/kW
DC 380-48 V converter	250	450	\$/kW
AC circuit breaker (20A)	16	18	\$/unit
DC circuit breaker (20A)	30	36	\$/unit
AC LED driver	Cost-power regression, $\pm 10\%$		\$/unit
DC LED driver	Cost-power regression, $\pm 10\%$		\$/unit
AC wall adapter cost	Cost-power regression, $\pm 10\%$		\$/kW
Sales tax	8.5%		%
<i>Operating Cost Parameters</i>			
Distr. Syst. Efficiency	Varies		%
System lifetime	8	12	years
Office discount rate	5.05% with 1.05 std deviation		%
Restaurant discount rate	6.07% with 0.92% std deviation		%
Retail discount rate	5.63% with 1.05% std deviation		%
Electricity prices	Varies by time-of-use rate		\$/kWh
Electricity price trends	94% - 114% of base year price		%
<i>Monte Carlo Simulation Parameters</i>			
Number of simulations	1000 runs		

- Grid equipment costs from online sources
- Monte Carlo analysis with Gaussian distribution

Lifetime Operating Cost - Loss Analysis



- AC building loss dominated by **load packaged rectifiers**
- DC building loss dominated by **grid tie inverter**
- Both buildings suffer **battery chemical loss**

Results


		50% PV, No Batt.	50% PV, 50% Batt.	50% PV, 100% Batt.	100% PV, No Batt.	100% PV, 50% Batt.	100% PV, 100% Batt.
Medium Office	Mean LCC Savings (\$)	-57,000	56,000	83,000	-112,000	90,000	181,000
	% Simulations with Positive LCC Savings	3.0%	94.3%	99.1%	0.3%	96.8%	100.0%
	Mean PBP (years)	13.0	4.0	2.3	17.2	3.3	0.0
Retail	Mean LCC Savings (\$)	-79,000	-27,000	-21,000	-63,000	11,000	64,000
	% Simulations with Positive LCC Savings	0.0%	14.9%	21.8%	0.3%	64.7%	98.2%
	Mean PBP (years)	21.1	11.4	10.6	17.3	6.4	1.9
Restaurant	Mean LCC Savings (\$)	14,000	56,000	60,000	-29,000	42,000	109,000
	% Simulations with Positive LCC Savings	92.9%	100.0%	100.0%	5.7%	98.8%	100.0%
	Mean PBP (years)	4.9	0	0	12.6	2.1	0

- LCC savings correspond to 10 years (average equipment lifetime)
- Greatest DC savings with lots of PV and battery
- Lowest DC savings with lots of PV and no battery

Backup


Modelica

- Object oriented modeling language
- Useful for complex systems that span electrical, mechanical, etc. domains
- GUI provided by Dymola or Open Modelica
- Popular for building and automotive simulations



Load Models


- All loads are DC or have internal DC stage
- AC building: loads are native/internal DC
 - All loads require load-packaged rectifier
- DC building: loads are direct DC
 - Lighting requires LED driver
 - HVAC (VFD motors) and plug loads assumed to be able to interface directly with DC distribution lines
- Load profiles are from Energy Plus



Converter Models

AC Product	CEC Efficiency
String Inverter	96.0%
Battery Inverter	92.1%
Low Power Rectifier	89.9%
High Power Rectifier	90.8%
AC LED Driver	90.2%


DC Product	CEC Efficiency
Power Optimizer	99.4%
MPPT Chg. Controller	98.5%
DC-DC Transformer	97.6%
Grid Tie Inverter	96.6%
DC LED Driver	95.6%



- Converters represent the most significant power loss
- Loss is based on efficiency curves obtained from manufacturer product data
- Power quality is not modeled in this study


Battery Model

- $P_{\text{excess}} = P_{\text{solar}} - P_{\text{load}}$
- Charge battery when excess $P_{\text{excess}} > 0$
- Discharge battery when $P_{\text{excess}} < 0$





Wire Model

- Model resistive losses as lumped resistance
- Wire gauge from expected load ampacity
- Wire length modeled by geometric methods



Efficiency Results



- Efficiency for annual simulation: $1 - (\text{Total Loss} / \text{Total Load})$
- Efficiency savings with DC increases with solar capacity and battery capacity
- Baseline parameter values
 - 390 kW solar capacity – amount required for ZNE
 - 1380 kW-h battery capacity – 50% of amount required to store all excess solar on sunniest day

Results – Medium Office Building

Medium Office Building						
Parameter/PV & Battery Scenario	50% PV, No Batt.	50% PV, 50% Batt.	50% PV, 100% Batt.	100% PV, No Batt.	100% PV, 50% Batt.	100% PV, 100% Batt.
AC First Cost (\$)	93,000	190,000	212,000	152,000	272,000	331,000
DC First Cost (\$)	245,000	245,000	245,000	365,000	334,000	332,000
AC LCC (\$)	843,000	973,000	1,006,000	300,000	530,000	660,000
DC LCC (\$)	894,000	911,000	917,000	412,000	439,000	479,000
Mean LCC Savings (\$)	-57,000	56,000	83,000	-112,000	90,000	181,000
% Simulations with Positive LCC Savings	3.0%	94.3%	99.1%	0.3%	96.8%	100.0%
Mean PBP (years)	13.0	4.0	2.3	17.2	3.3	0.0

- LCC savings correspond to 10 years (average equipment lifetime)
- Greatest DC savings with lots of PV and battery
- Lowest DC savings with lots of PV and no battery

