

Lawrence Berkeley National Laboratory

Recent Work

Title

FSD HARDWARE MONITORING

Permalink

<https://escholarship.org/uc/item/38f616jt>

Author

Shalz, Loren.

Publication Date

1968-10-28

ey. J

University of California Ernest O. Lawrence Radiation Laboratory

RECEIVED
LAWRENCE
RADIATION LABORATORY
NOV 21 1968
LIBRARY AND
DOCUMENTS SECTION

FSD HARDWARE MONITORING

Loren Shalz

October 28, 1968

TWO-WEEK LOAN COPY

*This is a Library Circulating Copy
which may be borrowed for two weeks.
For a personal retention copy, call
Tech. Info. Division, Ext. 5545*

UCRL-18548

ey. J

|

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

International Conference on Advanced Data
Processing for Bubble and Spark Chambers
Argonne, Illinois - Oct. 28-30, 1968
(Proceedings)

UCRL-18548
Preprint

UNIVERSITY OF CALIFORNIA

Lawrence Radiation Laboratory
Berkeley, California

AEC Contract No. W-7405-eng-48

FSD HARDWARE MONITORING

Loren Shalz

October 28, 1968

UCRL-18548

UNIVERSITY OF CALIFORNIA

Lawrence Radiation Laboratory
Berkeley, California

AEC Contract No. W-7405-eng-48

FSD HARDWARE MONITORING

Loren Shalz

October 28, 1968

FSD HARDWARE MONITORING

Loren Shalz

Lawrence Radiation Laboratory
Berkeley, California

28 October 1968

Increased usage of the FSD by DAPR makes it more imperative that we have reliable, economical and efficient means of monitoring hardware performance. Unlike in HAZE, there is no "human guidance" against which current measuring performance is compared.

The output from the digital and track center detection logic and the maintenance of calibration (relating normal and orthogonal mode measurements) are most fittingly monitored by the control computer.

The following is a brief description of the programs which monitor these features.

DIGITAL OUTPUT CHECKING

The digital output of the FSD consists of stage positions, track center values and a full grating count. The stage positions and the most significant digits of the track centers are from a direct readout from gratings. The five least significant digits of the track centers are from interpolation counters.

A frame of film is scanned several times in both normal and orthogonal modes. A variety of tests are made to see if the data transmitted is in the proper format and if each word is within tolerable limits. After each scan, an online report informs the computer operator of the kinds and number of errors. An offline listing gives the details of the data associated with errors, an histogram of the scan line separations, the average scan line separation and histograms of the output from each of three interpolation counters to determine if they are biased.

TEST PATTERN

For the purposes of calibration and track center detector monitoring a special test pattern (Figure 1) is used. The test pattern is an array of fiducials plus a set of 7 parallel lines and 7 converging lines for each mode

of measuring. Our current test frame is on 16 mm. film with the fiducial arms and converging lines about 30μ wide. The parallel lines range from about 15μ to 105μ in width. This enables us to study the effect of track width on track center determination. The lines are about 500μ apart.

TRACK CENTER DETECTOR CHECKING

The Berkeley FSD determines track center by integrating to find center of area. This method was chosen because it is relatively insensitive to fluctuations in the shape of the input signal. Since the integration plus recovery time of an integrator is about $10\mu\text{sec}$, we have three integrators to enable the digitizing of close tracks.

Having checked the fidelity of the digital output we check the integrators by studying repeated digitizings, with the stage stopped, of the same point on each of the parallel lines on the test frame. Only one integrator is activated at a time.

Recent hardware changes which facilitate this procedure provide the ability under program control:

- 1) to obtain digitizings without stage motion
- 2) to select any one integrator while disabling the other two
- 3) to set the digitizing threshold

Communication to the FSD is via the mode-speed-density word.

The digitizings associated with each line are determined from a frequency distribution of all digitizings in the vicinity of the 7 lines. For each test, the integrator used, digitizing threshold and total number of scan lines is printed online. For each line, the least and greatest track center values, the average track center value and RMS deviation, the total number of digitizings and the fraction of times the line digitized follow.

CALIBRATION

The calibration program determines the coefficients in the transformations which relate normal and orthogonal modes by means of a common orthogonal coordinate system in microns. The transformations are assumed linear and consist of a shear, translation and magnification.

A set of fiducials on the test frame is located and transformed using the coefficients currently in the HAZE and DAPR programs. Then, by a least squares method corrections to the current coefficients are computed and new ones derived.

An offline listing gives the fiducial locations, current coefficients, corrections, the new coefficients and residuals. An appraisal of the acceptability of the current coefficients is printed online.

RESULTS

Experience with the diagnostic programs indicates that the hardware is reliable. Significant errors in the digital output seldom occur. The average track center values from the integrators agree to within about 1.5μ for the 30μ through 90μ lines. Two of the integrators yield comparable results on the 15μ and 105μ lines while the remaining integrator disagrees by larger amounts depending on the digitizing threshold and mode of measurement. We are able to relate normal and orthogonal measurements to within about 2.5μ with systematic differences of up to 5μ on some of the fiducials which we cannot remove at this time. Further investigation of this problem will be done.


PLANS FOR THE FUTURE

The three phases of hardware monitoring will be incorporated into a single real-time program operating under TRIST, our multiprogrammed executive program. This will allow background computations to be done should long periods of FSD monitoring be desired for maintenance. More flexibility in the kinds of output will be provided and the program will suggest likely sources of hardware malfunction and make qualitative judgments as to the acceptability of the hardware.

We will soon have available on the FSD a very slow or crawl stage speed. This will be used in conjunction with the converging lines on the test pattern to investigate digitizings from close and crossing tracks.

A feature planned at least for FSD Unit II is the ability to transmit data to and retrieve the same data from the FSD memories. This will provide a direct and effective means of memory checking using logical checksums.

TEST PATTERN



XBL 6810-6020

Fig. 1.

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.