

Lawrence Berkeley National Laboratory

Lawrence Berkeley National Laboratory

Title

INDOOR AIR QUALITY AND ENERGY EFFICIENT VENTILATION RATES AT A NEW YORK CITY ELEMENTARY SCHOOL

Permalink


<https://escholarship.org/uc/item/3kx0s0th>

Author

Young, Rodger A.

Publication Date

1981-05-01



Lawrence Berkeley Laboratory

UNIVERSITY OF CALIFORNIA

ENERGY & ENVIRONMENT DIVISION

RECEIVED
LIBRARY
JUN 17 1981
DOCUMENT


INDOOR AIR QUALITY AND ENERGY EFFICIENT VENTILATION
RATES AT A NEW YORK CITY ELEMENTARY SCHOOL

Rodger A. Young, James V. Berk, Craig D. Hollowell,
James H. Pepper, and Isaac Turiel

May 1981

TWO-WEEK LOAN COPY

This is a Library Circulating Copy
which may be borrowed for two weeks.
For a personal retention copy, call
Tech. Info. Division, Ext. 6782



LBL-11828
e.2

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

LBL-11828
EEB-Vent 80-23

INDOOR AIR QUALITY AND ENERGY EFFICIENT VENTILATION
RATES AT A NEW YORK CITY ELEMENTARY SCHOOL

Rodger A. Young, James V. Berk, Craig D. Hollowell,
James H. Pepper, and Isaac Turiel

Building Ventilation and Indoor Air Quality Program
Energy and Environment Division
Lawrence Berkeley Laboratory
University of California
Berkeley, CA 94720

May 1981

The work was supported by the Assistant Secretary for Conservation and Solar Energy, Office of Buildings and Community Systems, Buildings Division of the U.S. Department of Energy under Contract No. W-7405-ENG-48.

TABLE OF CONTENTS

	<u>Page No.</u>
ABSTRACT	v
INTRODUCTION	1
EXPERIMENTAL FACILITIES AND METHODS.	4
The School Building and Heating System	4
Experimental Procedures and Ventilation Rates	5
The EEB Mobile Laboratory: Description and Indoor Air Quality Parameters Monitored	6
Odor Measurements	11
RESULTS AND DISCUSSION	12
Gaseous Contaminants	12
Particulates	29
Odor Perception	38
ENERGY SAVINGS.	40
CONCLUSIONS	41
ACKNOWLEDGEMENTS.	42
REFERENCES.	43
APPENDIX.	44

ABSTRACT

The Lawrence Berkeley Laboratory assessed the indoor air quality at Oakland Gardens Elementary School in New York City under three different ventilation rates. A mobile laboratory was used to monitor air quality in two classrooms, a hallway, and outdoors. The parameters measured were air exchange rates, particulates, odor perception, carbon dioxide, carbon monoxide, sulfur dioxide, ozone, nitrogen oxides, radon, formaldehyde and total aldehydes. When the ventilation rate was reduced, carbon dioxide concentrations increased significantly, but did not exceed current occupational standards. At the low ventilation rate, odor acceptability decreased and in one of the classrooms the odors were judged unacceptable according to current ASHRAE standards. Calculations indicate that moderate energy savings can be achieved by reducing the ventilation rate in the classrooms.

keywords: air pollution, carbon dioxide, carbon monoxide, energy conservation, indoor air quality, nitrogen oxides, odors, particulate mass, schools, sulfur dioxide, ventilation.

INTRODUCTION

Rising energy costs have motivated school administrators to review their energy consumption patterns. The possibility of energy savings is significant: schools alone account for 3% of the primary energy consumed in the United States (approximately 1.87×10^9 gigajoules/yr or 1.77×10^{15} Btu/yr). More than half of the energy used by institutional buildings, such as schools, is for heating, cooling, and ventilation to maintain the comfort of the building occupants (see Figure 1). Heating or cooling outside air as it enters the building requires a significant amount of energy. Reducing the volume of outside air that has to be heated will reduce energy consumption and effect considerable dollar savings.

Lowering the ventilation rate, however, may adversely affect indoor air quality. Although pollution is normally associated with the outdoor environment, a number of pollutants have indoor sources or are found in higher concentrations indoors. For example, carbon dioxide is a by-product of human respiration; formaldehyde and other organic compounds come from building materials and furniture; odors come from the occupants themselves and their activities (cleaning, painting, etc.); nitrogen oxides, carbon monoxide, carbon dioxide, and many organic compounds are products of combustion. In conventional buildings, natural infiltration and/or a mechanical ventilation system allows air to enter the building to dilute or remove indoor-generated pollutants. When the ventilation rate is reduced, these indoor-generated contaminants can build up to levels that could possibly impair the health, safety, or comfort of the occupants.

There is no national standard for ventilation rates in buildings. The most widely accepted standards are those of the American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE). ASHRAE Standard 62-73, entitled Standards for Natural and Mechanical Ventilation,¹ gives minimum and recommended ventilation rates for several types of building spaces. The first part of section 6.5 of this standard pertains to schools and is presented in Table 1. The recommended outside air quantity requirements appear to be based largely on odor research performed over forty years ago by C.P. Yaglou et al.² at Harvard University's School of Public Health. The ventilation requirements given are for 100% outdoor air; where recirculation of air is permitted, a reduction to 15% of the specified required ventilation rate is allowed if adequate temperature control, particulate filters, and high efficiency odor and gas removal equipment are employed so that the air entering the building space has been purified to meet specified air quality requirements. ASHRAE additionally specifies that "in no case shall the outdoor air quantity be reduced to less than 5 cfm per person." In response to demands for energy conservation in buildings, ASHRAE published a new standard in 1975. This standard, ASHRAE 90-75R, Energy Conservation in New Building Design,³ has stipulated that the minimum ventilation rate for each type of occupancy given in ASHRAE 62-73 must be used in designing new buildings. At present, the ASHRAE standard for minimum quantity of ventilation air for classrooms in new schools is $16.9 \text{ m}^3/\text{h}$ (10 cfm) per occupant. In systems with recirculated air, a reduction to $8.5 \text{ m}^3/\text{h}$ (5 cfm) per occupant is permitted if the air is purified to meet certain prescribed air quality requirements.

INSTITUTIONAL AND COMMERCIAL BUILDING ENERGY USE (1975)




Figure 1. Primary energy use for all non-residential buildings divided into four main functional uses (from Oak Ridge National Laboratory, Commercial Energy Use: A Disaggregation by Fuel, Building Type and End Use, ORNL/CON-14)

XBL 796-10231

Table 1. Ventilation standards for schools
(ASHRAE 62-73).

	Estimated persons/ 1000 sq ft floor area. Use only when design occupancy is not known	Required ventilation air, cubic feet per minute per human occupant, (when the number is bracketed, refer to the notes).		Comments
		Minimum	Recommended	
Schools				
Classrooms	50	10	10-15	
Multiple Use Rooms	70	10	10-15	
Laboratories	30	10	10-15	*
Craft Shops, Vocational Training Shops	30	10	10-15	*
Music, Rehearsal Rooms	70	10	15-20	
Auditoriums	150	5	5-7½	
Gymnasiums	70	20	25-30	
Libraries	20	7	10-12	
Common Rooms, Lounges	70	10	10-15	
Offices	10	7	10-15	
Lavatories	100	15	20-25	
Locker Rooms	20	(30)	(40)-(50)	**
Lunchrooms, Dining Halls	100	10	15-20	
Corridors	50	15	20-25	
Utility Rooms	3	5	7-10	
Dormitory Bedrooms	20	7	10-15	

*Special contaminant control systems may be required

**cfm/locker

(For existing schools, the recommended ventilation rate for classrooms is 16.9-25.4 m³/h or 10-15 cfm per occupant).

Implementation of the lower ventilation rates in Standard 90-75R raised questions concerning the indoor air quality in buildings, especially with regard to high levels of carbon monoxide and particulates in areas where smoking is allowed. To address the issue of energy efficient ventilation rates and a safe, healthy, and comfortable indoor environment, ASHRAE has revised Standard 62-73. The new standard, ASHRAE 62-81, Ventilation for Acceptable Indoor Air Quality,⁴ has recently been approved and will be issued in 1981. Different requirements are specified for smoking and non-smoking areas. The smoking areas have requirements which are higher than the non-smoking areas. For classrooms in schools, the minimum outdoor air requirements are 8.5 m³/h (5 cfm) for non-smoking areas and 42.2 m³/h (25 cfm) for smoking areas.

Interest in energy efficient ventilation rates has focused attention on air quality of indoor environments. To determine the effects of more energy-efficient ventilation rates, the Building Ventilation and Indoor Air Quality Program at Lawrence Berkeley Laboratory (LBL) has designed the "Energy Efficient Buildings (EEB) Mobile Laboratory" as a means of conducting field studies in various types of buildings. We have used the mobile laboratory to monitor indoor air quality in schools under different ventilation rates. Initial studies were conducted at a California high school⁵ and an Ohio elementary school.⁶ The Oakland Gardens Elementary School, P.S. 203, in New York City was the third school where indoor air quality was monitored by the EEB Mobile Lab. In this study, we focused on measuring odors, particulates, and gaseous pollutants at three different ventilation rates. The odors measurements were conducted by The Research Corporation of New England (TRC) under subcontract to LBL.

EXPERIMENTAL FACILITIES AND METHODS

The field study of indoor air quality at the Oakland Gardens Elementary School took place from November 10, 1979, to January 18, 1980. The school building, the experimental procedures, the mobile laboratory used for monitoring indoor air quality, and the sampling techniques to measure odors are described below.

The School Building and Mechanical Ventilation System

The Oakland Gardens Elementary School (P.S. 203), located at 5411 Springfield Blvd, Bayside, Queens NY, is a three story building constructed in 1961. In the basement of the school are the boiler room, kitchen, and student lunchroom. The three upper floors house 36 classrooms, a library, and administrative offices. An attachment on the north side of the building contains the gymnasium (upper floor) and an auditorium (lower floor). The total area of the entire school is 7339 m² (79,000 ft²).

During normal school hours (8:30 A.M. to 3:30 P.M.), there are generally 35-40 students in each classroom. The volume of each room is 219 m³ or 7716 ft³ (dimensions of the classrooms are 8.7 X 8.7 X 2.9 m or 28.5 X 28.5 X 9.5 ft). Each room is heated by steam fin-tube radiation heaters, which are thermostatically controlled. Two oil-fired boilers, which are operated manually by the school fireman, provide hot water and steam to the individual room heaters.

Most classrooms have three exhaust vents: two in the student coat closets and one by the door. Exhaust fans, located on the roof, draw air from the exhaust vents inside the rooms directly to the roof. There is no recirculation of air inside the building. Since there are no air intake registers, ventilation air arises solely from infiltration of air through cracks around the windows and doors.

Experimental Procedures and Ventilation Rates

We had originally planned to monitor three classrooms on the third floor of the school; however, because one of the classrooms was not occupied, we selected the hallway as the third site. The three indoor sites were Room 323, Room 325, and the hallway between the two classrooms. Both classrooms were occupied by fifth-grade students.

The two exhaust vents in the coat closets were sealed and the flow of air through the third vent by the door was determined using an instrument that averages the velocity measurements from multiple sensors spaced in an equal-area traverse. We found that the air flow rate through the exhaust vent was very low compared to total air flow in the room during unoccupied periods as measured by the tracer gas decay technique.* Therefore, all subsequent infiltration rates were measured by tracer gas decay using either nitrous oxide (N₂O) or sulfur hexafluoride (SF₆) during times when the rooms were unoccupied and the windows and doors were closed. All calculations of the ventilation rate are averages of 5-6 measurements taken on different days and are based on an occupancy of 40 students in each classroom.

We began by monitoring the air quality under the existing school heating and ventilation conditions. It must be noted that under these conditions all exhaust vents were open but the exhaust fans off, and the room heaters were under thermostat control. However, because the infiltration rate was very low (1.2 m³/h or 0.7 cfm per occupant) with the exhaust fans off, the carbon dioxide levels rose to 9000 mg/m³ (5000 ppm) in less than three hours. When the CO₂ levels exceeded 9000 mg/m³ (5000 ppm), we turned on the exhaust fans. The higher infiltration rate in the classrooms when the exhaust fans were on and all three exhaust vents open (45.5 m³/h or 27.0 cfm per occupant) rapidly lowered the CO₂ concentrations. We then decided to monitor under three ventilation

* Using a smoke pencil, we determined that air was leaving the classroom from cracks in the wall and around the light and clock fixtures, in addition to the air leaving through the exhaust vent.

rates between these two extremes and the exhaust fans were always on at all times during our testing in order to keep the CO₂ levels below the 9000 mg/m³ (5000 ppm) standard of the Occupational Safety and Health Agency (OSHA)⁷. Even though this standard is set for a time-weighted average of 8 hours, we did not want to exceed this level during our testing.

The first rate, which we shall call the "high" ventilation rate, was approximately 14.8 m³/h (8.8 cfm) per occupant. This ventilation rate was achieved by sealing the two exhaust vents in the student coat closets and leaving the third exhaust grille by the door completely unhindered. An "intermediate" ventilation rate of approximately 8.2 m³/h (4.9 cfm) per occupant was then obtained by partially covering approximately half of the third exhaust grille. A third, "low" ventilation rate (4.4 m³/h or 2.9 cfm per occupant) was achieved by almost completely covering the third vent. (Figure 2 shows the third exhaust grille by the door when it is open and partially taped in the intermediate mode.) Tracer gas measurements were made in both classrooms to assure uniform ventilation rates in each room during monitoring.

We monitored the indoor air quality for approximately seven weeks, between two and three weeks at each ventilation rate. During the monitoring period, we asked the students to keep the doors to Rooms 323 and 325 closed: this request was generally honored. Except for odors, all air quality parameters were measured by the EEB Mobile Laboratory.

The EEB Mobile Laboratory: Description and Indoor Air Quality Parameters Monitored

The EEB Mobile Laboratory, shown in Figure 3 beside the school, is a semi-trailer that has been modified for use as a laboratory.⁸ It contains sampling, calibration, and monitoring systems for field studies of indoor air quality in buildings. Table 2 shows the instrumentation in the EEB Mobile Lab and the parameters it is designed to monitor.

For those parameters that were measured on a continuous basis (temperature, humidity, carbon dioxide, carbon monoxide, sulfur dioxide, ozone, and nitrogen oxides), connection between the indoor sites and the mobile lab was made by electrical cable and teflon sampling lines. At each sampling site were a sampling line inlet and sensors to measure temperature and humidity. (Figure 4 shows the sampling lines and sensors suspended from the ceiling in Room 325.) For analysis of the common gaseous inorganic pollutants, air from the three indoor sites and one outdoor site was drawn into the trailer and directed to a glass sampling manifold from which the various instruments withdrew air for analysis. The four lines were sampled in sequence under the control of a microprocessor, which automatically energized specific solenoids and then recorded the data on a floppy disk. The microprocessor also directed a daily calibration of the analyzers. In this study, the sites were sampled sequentially for ten-minute intervals; thus, each site was monitored for a ten-minute period every forty minutes.






Figure 2. Upper Photo: Exhaust grille by the door in one of the classrooms monitored.
Lower Photo: Exhaust grille by the door partially sealed with duct tape to lower the ventilation rate to the intermediate mode. (CBB808-9008)




CBB807-8197

Figure 3. The EEB Mobile Laboratory stationed at Oakland Gardens Elementary School (P.S. 203), New York City.

Table 2. Instrumentation in the EEB Mobile Lab for monitoring indoor and outdoor air quality parameters.

Purpose	Method/Instrument	Manufacturer/Model
<u>Continuous monitoring of the following parameters:</u>		
Gases:		
CO ₂	NDIR	Horiba PIR 2000
CO	NDIR	Bendix 8501-5CA
SO ₂	UV fluorescence	Thermo Electron 43
NO, NO _x	Chemiluminescence	Thermo Electron 14D
O ₃	UV absorption	Dasibi 1003-AH
Indoor temperature & moisture:		
Dry-bulb temperature	Thermistor	Yellow Springs 701
Relative humidity	Lithium chloride hygrometer	Yellow Springs 91 HC
Outdoor meteorology:		
Dry-bulb temperature	Thermistor	MRI 915-2
Relative humidity	Lithium chloride hygrometer	MRI 915-2
Wind speed	Generator	MRI 1074-2
Wind direction	Potentiometer	MRI 1074-2
Solar radiation	Spectral pyranometer	Eppley PSP
Infiltration	Automated controlled-flow measurement or tracer gas decay/IR absorption	LBL/Wilkes
<u>Time-averaged monitoring of the following parameters:</u>		
Gases:		
Radon	Electrostatic collection/thermoluminescence	LBL
Formaldehyde/total aldehydes	Absorption (gas bubblers)/colorimetry	LBL
Selected organic compounds	Tenax GC adsorption tubes/GC analysis	LBL
Inhalable particulates (fine & coarse fractions)	Virtual impaction/filtration	LBL
<u>Data acquisition:</u>		
	Microprocessor Multiplexer A/D	Intel System 80/20-4 Burr Brown Micromux Receiver MM6016 AA Remote MM6401
	Floppy disk drive Modem	ICOM FD3712-56/20-19 Vadic VA-317S



CBB 807-8195

Figure 4. Sampling lines and temperature and humidity sensors in one of the classrooms monitored, Oakland Gardens Elementary School, NYC.

For those parameters measured on a time-integrated basis (see the second part of Table 2) different sampling techniques were required. The instruments used were placed inside the building and were independent of microprocessor control.

Particulate matter in Room 323, the hallway, and outdoors was measured using dichotomous air samplers (DAS). The DAS, developed at LBL,⁹ uses a flow-controlled virtual impaction system to separate the aerosol into fine and coarse fractions (below 2.5 μm and between 2.5 and 15 μm , respectively). The particulate matter was collected for 24-hour periods on teflon filters. The samples were returned to LBL for analysis of mass (using beta gauge techniques) and for measurements of the concentrations of 28 elements* by X-ray fluorescence.

Formaldehyde and total aliphatic aldehydes were measured for 24-hour intervals for five weeks in Room 325 and outdoors using a flow-controlled system developed at LBL.¹⁰ The samples were collected in gas bubblers at approximately 5°C to increase the collection efficiency, and were shipped back to LBL for analysis. Formaldehyde, which was collected in aqueous solution, was analyzed using either chromotropic acid¹¹ or pararosaniline.¹² Total aliphatic aldehydes were collected in solutions containing 3-methyl-2-benzothiazolinone hydrazone (MBTH) and analyzed using a standard colorimetric procedure.¹¹

Radon concentrations were measured in Room 325 and the boiler room using battery-operated passive radon monitors.¹³ The LBL passive monitor is cylindrical in shape, approximately 8 inches in diameter and 12 inches high. The sensitive volume is defined by a metal funnel and perforated steel screen. A rubber stopper with a brass electrode is placed in the neck of the funnel. A lithium fluoride thermoluminescent dosimeter (TLD) chip is held in place above the end of the electrode by a molded plastic holder. Three 300 V dry cells provide -900 V to the electrode, with the funnel and screen as reference. Radon gas diffuses into the sensitive volume to a concentration equal to that in the surrounding air. After a sampling period of approximately one week, the chips were sent back to LBL for readout, from which the average radon concentrations were determined..

Odor Measurements

TRC measured odor perception in its mobile odors laboratory brought to the Oakland Gardens Elementary School. These measurements were conducted for a two-week period in December 1979 under the high and low ventilation rates described above. "Odor panelists" were recruited from people in the area who were not regular occupants of the school building. Air samples from the building were collected in 100-liter Tedlar bags and brought to the odors laboratory. Four sites were tested: the two test rooms (Rooms 323 and 325), a control room (Room 322), and

*The elements analyzed are: Al, Si, S, P, Cl, Ar, K, Ca, Ti, V, Cr, Mn, Fe, Ni, Cu, Zn, Ga, As, Se, Br, Rb, Sr, Cd, Ba, Sn, Sb, Hg, Pb.

outdoors.

At all sites, the sensory perception of odors was measured in two ways: The first method employed a forced-choice triangle olfactometer (Figure 5) for determining the number of dilutions necessary to bring an odorous air sample to a level at which 50% of the members of the odor panel could no longer detect it; this neutral level is expressed as ED₅₀.¹⁴ The olfactometer is equipped with five stations; the first four present dilution ratios of 81, 27, 9, and 3, and the fifth presents the undiluted odor. There are three glass sniffing ports at each station; two supply filtered outside air and the other supplies the air from within the building in one of the five concentrations, progressing from weakest to strongest (undiluted). For each of the five concentrations, the odor panelist indicates which of the three ports he or she believes delivers odorous air. The second method for testing odor intensity, used immediately after the first, employed a device called a butanol olfactometer (Figure 6). For this test, panelists are presented with the undiluted odor and asked to compare it with progressively increasing concentrations of butanol until they perceive a match between the intensity of the butanol and the intensity of the undiluted sample.¹⁵


In addition to the procedures described above, both the odor panelists and the building occupants filled out questionnaires (Figure 7), giving their reaction to various aspects of the room environment, including the presence of odors, and rating each on a nine-point scale. Each aspect was also rated for acceptability.

TRC also collected air samples for laboratory analysis of the odorant composition. For this purpose, two liters of room air were passed through tubes packed with porous polymer Tenax, which adsorbs the organics and odorants present in the air. The odorants adsorbed were then identified by gas chromatographic and mass spectroscopic (GC/MS) techniques, and their character and intensity were determined by a GC/odorogram and sensory judge.

RESULTS AND DISCUSSIONS


Gaseous Contaminants

The data on the gaseous pollutants at the indoor sites collected during school hours (8:30 a.m. and 3:30 p.m.) were compared with outdoor levels and are displayed in histograms in the Appendix. For each pollutant the concentrations during the last four minutes of each ten-minute sampling period were averaged and these averages have been sorted into bins along the horizontal axis of the histograms. (Histograms selected for discussion are presented in the text. The Appendix contains the histograms for the hallway and each classroom of all the data on the common inorganic pollutants - carbon monoxide, carbon dioxide, sulfur dioxide, ozone, and the nitrogen oxides.) The data on aldehydes and radon is also discussed in this section. The indoor concentrations of the various pollutants can be compared with the relevant ambient air quality standards listed in Table 3.



XBB802-2681

Figure 5. Forced-choice triangle olfactometer. The subject chooses, by smell, which of the three nozzles emits odorous air.



XBB802-2680

Figure 6. Subject using the butanol binary dilution olfactometer to find a level of butanol intensity that matches the percent intensity of the "occupancy odor."

Day Number _____ Date _____ Time _____ Room Number _____

EVALUATION SHEET

<u>Rating of Individual Elements of the Room Environment</u>		<u>Acceptable</u>	<u>Unacceptable</u>
Cold _____	Hot _____	<input type="checkbox"/>	<input type="checkbox"/>
Humid _____	Dry _____	<input type="checkbox"/>	<input type="checkbox"/>
Drafty _____	Stuffy _____	<input type="checkbox"/>	<input type="checkbox"/>
Stale _____	Fresh _____	<input type="checkbox"/>	<input type="checkbox"/>
No odor _____	Strong odor _____	<input type="checkbox"/>	<input type="checkbox"/>
Loud noise _____	No noise _____	<input type="checkbox"/>	<input type="checkbox"/>
<u>Overall Rating of the Room Environment</u>			
Acceptable _____	Unacceptable _____		

- 15 -

1. Do you have a cold today?

Yes No

2a. If you are a smoker, about how many hours ago today did you have your last smoke?

_____ hours ago

2b. If you are not a smoker or if you did not smoke today, check this box

Figure 7. Questionnaire filled out by students and odor panelists.

Table 3. Selected ambient air quality standards and guidelines.^a

Contaminant	Agency	Long Term		Short Term	
		Level	Averaging Time	Level	Averaging Time (hrs)
Carbon monoxide	EPA	—	—	40 mg/m ³ (35 ppm)	1
				10 mg/m ³ (9 ppm)	8
Nitrogen dioxide	EPA	100 µg/m ³ (50 ppb)	year	—	—
Sulfur dioxide	EPA	80 µg/m ³ (30 ppb)	year	365 µg/m ³ (140 ppb)	24
Ozone	EPA	—	—	240 µg/m ³ (120 ppb)	1
Hydrocarbons	EPA	—	—	160 µg/m ³ (250 ppb)	3 ^b
Particulates	EPA	75 µg/m ³	year	260 µg/m ³	24
Lead	EPA	1.5 µg/m ³	3 mos	—	—
Carbon dioxide	OSHA	—	—	9,000 mg/m ³ (5,000 ppm)	8
	NIOSH	—	—	18,000 mg/m ³ (10,000 ppm)	10
Formaldehyde	Europe ^c	—	—	120 µg/m ³ (100 ppb)	maximum
Radon in buildings	EPA ^d & Canada ^e	0.02 WL (~4 nCi/m ³)	year	—	—

^aEPA standards for all contaminants except radon are the National Ambient Air Quality Standards; also listed are occupational standards for CO₂ and guidelines for formaldehyde and radon in buildings.

^b6-9 a.m.

^cRecommended in Denmark, Sweden, West Germany, and the Netherlands

^dEPA recommendation to the governor of Florida for homes on phosphate lands.

^ePolicy statement by the Atomic Energy Control Board, Canada.

The Classrooms. Table 4 gives the average concentrations of continuously monitored gaseous pollutants in the two test classrooms at each of the three ventilation rates. Outdoor concentrations are also presented for comparative purposes. Inside the classrooms, carbon dioxide was the only gaseous pollutant found in significantly high concentrations; its primary sources were the occupants themselves. Figure 8 shows a profile of the carbon dioxide concentrations during a typical school day. The level of carbon dioxide rose when the students entered the room for the morning and afternoon sessions; it fell at noon and at 3:00 p.m. when the students left the classroom. Daily profiles differed slightly due to variations in classroom occupancy and activity.

Figure 9 presents a histogram of the carbon dioxide concentrations in Room 323 for each ventilation rate. As the quantity of outside air entering the room decreased, there was less "fresh" air to dilute the CO₂ generated by the students and as expected, the levels of CO₂ increased as the ventilation rate decreased. But even at our lowest ventilation rate (4.4 m³/h or 4.9 cfm per occupant), the average concentration did not exceed 3870 mg/m³ (2150 ppm), as shown in Table 4. (The maximum concentrations of carbon dioxide in the two Rooms 323 and 325 -- 6995 mg/m³ (3890 ppm) and 5760 mg/m³ (3200 ppm), respectively -- also occurred when we were monitoring at our low ventilation rate.) At all three ventilation rates, the concentrations of carbon dioxide in both classrooms were well below the occupational standards of 9000 mg/m³ (5000 ppm) set by OSHA⁷ and 18,000 mg/m³ (10,000 ppm) set by NIOSH,¹⁶ both of which refer to a time weighted average for 8 and 10 hour work-shifts, respectively. It should be noted, however, that relying on natural infiltration alone when the windows and doors were closed was not sufficient to keep the CO₂ at levels considered safe for human health. With the exhaust fans off, the carbon dioxide levels rose from background levels of 684 mg/m³ (380 ppm) to the 9000 mg/m³ (5000 ppm) OSHA standard in less than three hours. This finding supports the computations of the National Bureau of Standards in their study of ventilation requirements of New York City school buildings¹⁷ which concluded that mechanical ventilation should be used when the students are in school classrooms. A ventilation rate of 4.4 m³/h (3 cfm) per occupant was sufficient to keep the carbon dioxide concentrations below 7200 mg/m³ (4000 ppm) at all sites.

The ratios of indoor to outdoor carbon dioxide concentrations in the two classrooms were calculated, and the results for Room 323 are summarized in Figure 10. As shown, the ratio increased as the ventilation rate decreased, indicating that the carbon dioxide was generated indoors and was not being diluted as rapidly at the lower ventilation rates.

Indoor concentrations of the other gaseous pollutants were very low, generally lower than the outdoor levels, and except for nitrogen dioxide in one of the classrooms, they never exceeded the National Ambient Air Quality Standards (NAAQS) promulgated by the Environmental Protection Agency (EPA).¹⁸

Both sulfur dioxide (SO₂) and ozone showed consistently lower indoor than outdoor concentrations. This phenomenon is not unusual, for these reactive gases are primarily generated outdoors and the building

Table 4. Average concentrations of continuously monitored gaseous pollutants at three ventilation rates, Oakland, Gardens Elementary School, NYC.

Pollutant	Ventilation Rate ^a	Site ^b		
		Outdoors	Room 323	Room 325
CO (ppm)	high	1.5 ± 1.1	1.3 ± 1.0	1.4 ± 1.0
	intermediate	1.2 ± 0.7	1.1 ± 0.7	1.1 ± 0.7
	low	1.7 ± 1.3	7.1 ± 1.3	1.7 ± 1.1
CO ₂ (ppm)	high	395 ± 51	1184 ± 457	1259 ± 540
	intermediate	405 ± 26	1750 ± 710	1508 ± 532
	low	413 ± 23	2138 ± 745	2015 ± 595
NO ₂ (ppb)	high	42 ± 16	58 ± 12	42 ± 14
	intermediate	48 ± 19	55 ± 23	41 ± 14
	low	49 ± 13	55 ± 17	38 ± 13
NO (ppb)	high	23 ± 26	14 ± 23	15 ± 22
	intermediate	29 ± 26	20 ± 26	19 ± 23
	low	50 ± 37	47 ± 37	48 ± 30
SO ₂ (ppb)	high	15 ± 16	5 ± 8	4 ± 6
	intermediate	15 ± 8	4 ± 3	3 ± 2
	low	23 ± 15	5 ± 4	4 ± 3
O ₃ (ppb)	high	5 ± 6	3 ± 7	3 ± 2
	intermediate	3 ± 4	2 ± 2	2 ± 1
	low	4 ± 4	3 ± 3	4 ± 9


^aVentilation rates:

High: = 14.8 m³/h (8.8 cfm) per occupant
 Intermediate: = 8.2 m³/h (4.9 cfm) per occupant
 Low: = 4.4 m³/h (2.9 cfm) per occupant

^bValues for each site are the average concentration and standard deviation of data collected during school hours.

Room 323 - Oakland Gardens Elementary School


January 8, 1980



XBL 808-1565

Figure 8. Carbon dioxide levels during a 24-hour period in Room 323.


Room 323 - Oakland Gardens Elementary School



XBL 808-1575

Figure 9. Histograms of indoor and outdoor CO₂ concentrations in Room 323 at three ventilation rates.

Room 323 – Oakland Gardens Elementary School



XBL 808-1572


Figure 10. Histograms of the ratio of indoor-to-outdoor CO₂ concentrations in Room 323 at three ventilation rates.

envelope often acts as a barrier to their entry. Ozone is produced by a photochemical reaction occurring during the daytime: sulfur dioxide is found in the emissions from automobiles and power plants. The frequency distribution of the SO_2 concentrations in Room 325 at the three ventilation rates (see Figure 11) shows that the levels of SO_2 were low indoors at the highest ventilation rate, and decreased slightly as the ventilation rate decreased. The maximum indoor concentration was $91 \mu\text{g}/\text{m}^3$ (35 ppb) -- well below the EPA ambient air quality standard of $365 \mu\text{g}/\text{m}^3$ (140 ppb) for a 24-hour period. Indoor concentrations of ozone were very low; they were too low to observe any change with ventilation rate. All indoor concentrations of ozone were less than $39 \mu\text{g}/\text{m}^3$ (20 ppb), well below the one-hour NAAQS for ozone of $240 \mu\text{g}/\text{m}^3$ (120 ppb).

The nitrogen oxides are products of combustion. The boiler and kitchen stoves, which are the only combustion sources in the school, are located in the basement. Hence, we did not expect to see high levels of nitrogen oxides inside the classrooms. As shown in Figure 12, the indoor concentrations of nitric oxide (NO) actually increased at the low ventilation rate. This increase was most likely a reflection of the increased outdoor concentrations of NO during the monitoring period at the low ventilation rate. The concentrations of NO_2 decreased slightly at the two lower ventilation rates, as seen in Figure 13, but the decrease was not of the same magnitude as the change in ventilation rate. The ratios of indoor-to-outdoor NO_2 concentrations, shown in Figure 14, are approximately unity for all ventilation rates, indicating that NO_2 is generated outdoors and that indoor concentrations follow changes in the outdoor levels. If a pollutant is generated primarily outdoors and is not very reactive, (such as NO or NO_2) we would expect the indoor levels to be similar to outdoor levels at all ventilation rates because the pollutant will not decay once inside the building. In contrast, the concentrations of the reactive pollutant SO_2 , which is also generated primarily outdoors, decreased as the ventilation rate decreased, because SO_2 is likely to react or adsorb on surfaces either upon entering or while inside the building, resulting in lower indoor than outdoor concentrations. (Those instances where indoor/outdoor ratios were high generally correlated with high odor levels or with the use of cleaning solutions in the hallway, and may be due to interferences from ammonia and organonitrogen compounds that are encountered in the chemiluminescence method of analyzing nitrogen oxides.)

The EPA ambient air quality standard for NO_2 is $100 \mu\text{g}/\text{m}^3$ (50 ppb) for a one-year period; there is no short term standard. The average outdoor concentration of NO_2 , as indicated in Table 4, was very close to this standard. NO_2 levels in Room 325 were similar to or slightly lower than the outdoor levels at the three ventilation rates. In Room 323 the average concentration of NO_2 was slightly higher than outdoor levels and exceeded the one-year EPA ambient air quality standard during the high and intermediate ventilation rates by 5 and 8 ppb, respectively. We have no explanation why the NO_2 levels were higher in Room 323 than the outdoor or Room 325 levels other than the fact that ammonia cleaning solutions were often used in the adjoining student restrooms. The restrooms doors were always open to the hallway and higher NO_2 levels in the adjacent Room 323 and the hallway could be caused by the interference of ammonia mentioned above. We feel, however, that the large standard


Room 325 - Oakland Gardens Elementary School



XBL 808-1579

Figure 11. Histograms of indoor and outdoor SO₂ concentrations in Room 325 at three ventilation rates.


Room 325 - Oakland Gardens Elementary School



XBL 808-1569

Figure 12. Histograms of the indoor and outdoor NO concentrations in Room 325 at three ventilation rates.


Room 325 - Oakland Gardens Elementary School



XBL 808-1581

Figure 13. Histograms of the indoor and outdoor NO₂ concentrations in Room 325 at three ventilation rates.

Room 325 - Oakland Gardens Elementary School



XBL 808-1568

Figure 14. Histograms of the ratios of indoor-to-outdoor NO₂ concentrations at three ventilation rates.

deviation indicates that an average concentration that slightly exceeded the NAAQS (by 5-8 ppb) is not significant.

The average concentrations of carbon monoxide (CO) at each of the three ventilation rates were less than 10.4 mg/m^3 (1.7 ppm). Outdoor levels were approximately the same. Carbon monoxide is produced from incomplete combustion of fossil fuels. Since there were no combustion sources inside the classrooms, it is not surprising that only very low levels were measured. The NAAQS for CO for a one-hour period of 40 mg/m^3 (35 ppm) was never exceeded. The maximum measurement -- 10.4 mg/m^3 (9 ppm) -- was recorded one time in Room 323 in the morning and was probably from outdoor air containing CO generated by cars during the early commute hours.

The measurements of formaldehyde and total aldehydes that were taken for approximately five weeks in Room 323 showed very low concentrations at all three ventilation rates, with no significant difference from one ventilation rate to another. The average indoor formaldehyde concentration was $22 \pm 11 \text{ } \mu\text{g/m}^3$ (18 ± 9 ppb); the outdoor concentration was $13 \pm 1 \text{ } \mu\text{g/m}^3$ (11 ± 6 ppb). The average indoor concentration of total aldehydes, expressed as equivalents of formaldehyde, was $32 \pm 24 \text{ } \mu\text{g/m}^3$ (27 ± 20 ppb); the outdoor concentration was $17 \pm 18 \text{ } \mu\text{g/m}^3$ (14 ± 15 ppb). These concentrations were well below the guidelines recommended or proposed in several European countries of $120 \text{ } \mu\text{g/m}^3$ (100 ppb).^{19,20,21}

The concentrations of radon measured in Room 325 and in the boiler room in the basement of the school were less than 1 nCi/m^3 . These concentrations are below the .02 WL (approximately 4 nCi/m^3) recommended by the Atomic Energy Control Board of Canada²² and by the EPA to the governor of the state of Florida for homes built on phosphate reclaimed lands.²³

The Hallway. Table 5 presents the average and maximum concentrations of gaseous pollutants in the hallway. Since the ventilation rate in the hallway was neither measured nor changed in any way, the averages listed in Table 5 include all the data collected during school hours for the entire seven-week sampling period for both outdoors and hallway. When compared to the average concentrations found in the classrooms (Table 4), it is evident that there is little difference between the hallway and the two classrooms monitored. The concentration of all pollutants, except NO_2 , were less than the EPA ambient air quality standards. NO_2 levels were $103 \text{ } \mu\text{g/m}^3$ (55 ± 17 ppb), slightly higher than the one-year EPA standard for outdoor air, but considering outdoor levels and possible interferences from ammonia and the large standard deviation, these levels are not considered significant.

Summary of Gaseous Contaminants. Of the common inorganic gaseous pollutants measured, only carbon dioxide was seen in significantly high concentrations inside the school; however, even at the low ventilation rate of $4.4 \text{ m}^3/\text{h}$ (3 cfm) per occupant, CO_2 concentrations did not exceed current occupational standards. The indoor concentrations of carbon monoxide, sulfur dioxide, ozone, nitric oxide, formaldehyde, and radon were also lower than the relevant ambient air quality standards. In one

Table 5. Average and maximum concentrations of gaseous pollutants in the hallway during school hours, Oakland Gardens Elementary School, NYC.

Gas (unit)	Average Concentration ^a		Maximum Concentration ^b	
	Hallway	Outdoors	Hallway	Outdoors
CO (ppm)	1.6 ± 1.1	1.4 ± 1.0	8-10	6-8
CO ₂ (ppm)	1491 ± 492	404 ± 37	2900-3000	500-600
SO ₂ (ppb)	3 ± 3	17 ± 14	20-25	87
O ₃ (ppb)	3 ± 2	4 ± 5	10-20	20-30
NO ₂ (ppb)	55 ± 17	47 ± 17	120-130	110-120
NO (ppb)	31 ± 33	34 ± 32	228	231 (149) ^c

^aValues given are average concentrations and standard deviations of the gases for the data collected during school hours.

^bIf one value was much higher than others, this value is given. Otherwise, a range of the maximum values measured is given. The maximum outdoor concentrations do not necessarily correspond to the times of maximum indoor concentrations.

^cOutdoor NO concentration at the time of maximum hallway NO concentration.

of the classrooms and the hallway, the indoor concentrations of nitrogen dioxide slightly exceeded the one-year EPA standard for outdoor air.

Particulates


Particulates were measured in Room 323, the hallways and outdoors and the results are displayed as daily bar graphs. The data on fine particulates (those with a diameter less than 2.5 microns) are displayed separately. The fine particulates are of special interest because they have a high probability of reaching the lungs and bronchial passages, whereas coarse particulates, which have a diameter between 2.5 and 15 microns, tend to be filtered out by the nasal passages. The data called "total inhalable particulates" is the sum of the fine and coarse fractions and is the total mass of particulates with diameters less than 15 microns. Even though the EPA ambient air quality standard for particulates is promulgated for "total suspended particulates" (TSP), which refer to all particulate mass suspended in the air including particulates of diameter greater than 15 microns, we will compare the TSP standard with the total inhalable particulates measured in the school.

Average concentrations of particulate mass have been calculated for school days only in order to indicate the levels that the students are exposed to on a daily basis.

Room 323. The measurements of fine and total inhalable particulates in Room 323 are summarized in Figure 15. As shown, the concentration of the fine particulate mass outdoors was usually higher than that indoors except for one day when the fine particulate mass indoors was almost twice the outdoor concentration. The fine particulate mass indoors ranged from 8 to 56 $\mu\text{g}/\text{m}^3$ (average = 22 $\mu\text{g}/\text{m}^3$) and constituted approximately 45-50% of the total mass. The fine particulate mass outdoors was slightly higher, ranging from 11 to 55 $\mu\text{g}/\text{m}^3$ (average = 28 $\mu\text{g}/\text{m}^3$), and was approximately 70-75% of the total mass, a much larger percentage than seen indoors. Indoor concentrations of total inhalable particulates were sometimes higher than outdoor levels, but there did not appear to be any correlation between these variations. On the average, however, the indoor concentration of total inhalable particulates (58 $\mu\text{g}/\text{m}^3$) was higher than average outdoor levels (37 $\mu\text{g}/\text{m}^3$).

Table 6 lists the average concentrations of the particulate mass at each ventilation rate. As shown, the changes in ventilation rate did not seem to effect the concentrations of the particulate mass. A much longer sampling period would be required to determine accurately whether or not levels of fine particulate mass are, in fact, influenced by changes in ventilation rate. The concentrations of total inhalable particulates in Room 323 were significantly higher than outdoor levels at all three ventilation rates. The coarse particulate fraction indoors was much higher than that found outdoors. The particulates were probably being generated indoors and the variation in concentrations did not depend on the ventilation rate but rather on the student activity during the day.

Room 323 - Oakland Gardens Elementary School



XBL804-787

Figure 15. Comparison of particulate mass in Room 323 and outdoors.

Table 6. Average concentrations and standard deviations of particulate mass during school days, Room 323, Oakland Gardens Elementary School, NYC.

Fine Particulate Mass (<2.5 μm)			
Ventilation rate ^a	Room 323 ($\mu\text{g}/\text{m}^3$)	Outdoors ($\mu\text{g}/\text{m}^3$)	Ratio ^b
High	25 \pm 16	24 \pm 70	1.04 \pm .45
Intermediate	20 \pm 60	36 \pm 22	0.82 \pm .67
Low	19 \pm 90	24 \pm 18	0.93 \pm .25

Total Inhalable Particulates (<15 μm)			
Ventilation rate ^a	Room 323 ($\mu\text{g}/\text{m}^3$)	Outdoors ($\mu\text{g}/\text{m}^3$)	Ratio ^b
High	61 \pm 21	35 \pm 10	1.85 \pm 0.53
Intermediate	65 \pm 15	49 \pm 27	1.79 \pm 1.0
Low	48 \pm 13	34 \pm 22	1.69 \pm 0.56

^aVentilation rates:

High = 14.8 m³/h (8.8 cfm) per occupant
 Intermediate = 8.2 m³/h (4.9 cfm) per occupant
 Low = 4.4 m³/h (2.9 cfm) per occupant

^bThe Room 323/outdoor ratios were calculated for each day and values given represent the average of the ratios.

The National Ambient Air Quality Standards (NAAQS) for TSP for a one-year period is $75 \mu\text{g}/\text{m}^3$; the 24-hour standard is $240 \mu\text{g}/\text{m}^3$. The average concentration of total inhalable particulates in Room 323 was $58 \mu\text{g}/\text{m}^3$, which is less than the one-year NAAQS for TSP. The maximum concentration recorded for any single day ($101 \mu\text{g}/\text{m}^3$) was also well below the NAAQS for TSP of $240 \mu\text{g}/\text{m}^3$ for a 24-hour period.


Hallway. In contrast to Room 323, the concentrations of both fine and total inhalable particulates in the hallway, as shown in Figure 16, were higher than the outdoor levels. Days when the hallway concentrations were similar to the outdoor levels were usually weekends or holidays when there was no activity indoors. These elevated indoor levels were probably caused by students congregating in the hallway on their way to other activity rooms and by the fact that doors to other classrooms were left open to the hallway. Both situations would generate more particulates or stir up existing particulates.

Table 7 shows that the average concentration of total inhalable particulate mass in the hallway was five times the outdoor level; the fine particulate mass was approximately twice the outdoor concentration. The maximum 24 hour sample was $198 \mu\text{g}/\text{m}^3$, which is approximately 80% of the NAAQS for TSP for a 24-hour period. For the data collected during school days, the average of $145 \mu\text{g}/\text{m}^3$ for total inhalable particulates in the hallway is almost twice the NAAQS for a one-year average.

Elemental Analysis. The elemental analysis of the particulates by X-ray fluorescence revealed only trace amounts of most of the twenty-eight elements measured in Room 323 and the hallway. In the fine particulate fraction, only sulfur, lead, and bromine were found in concentrations above the level of detectability. In the coarse fraction, only sulfur was measurable. Most of the mass was probably carbon, hydrogen, nitrogen and oxygen which are not detected by X-ray analysis. Figures 17, 18, and 19 show the daily concentrations of fine particulate sulfur, lead, and bromine in Room 323 and outdoors. As shown, the outdoor concentrations usually were higher than the indoor levels. Table 8 shows the average and maximum concentrations of these three elements at all three sites monitored. The data showed no differences when separated by ventilation rate. In Room 323 the average concentrations of all three elements were approximately half the outdoor levels. The average concentration of fine particulate sulfur for Room 323 was $2.5 \mu\text{g}/\text{m}^3$ (the maximum 24-hour measurement was $9.8 \mu\text{g}/\text{m}^3$). Since most of the elemental sulfur is assumed to be in the form of sulfates, this concentration represents an average of approximately $7.5 \mu\text{g}/\text{m}^3$ as sulfate. The hallway concentrations were higher than outdoor levels, following the trend of particulates in the school.

Of the three elements, only lead, which is associated with automobile exhaust, is included in the NAAQS by the EPA. The NAAQS for lead is $1.5 \mu\text{g}/\text{m}^3$ for a three-month period (any calendar quarter). For the four-week sampling period, the average indoor concentrations were less than $1.3 \mu\text{g}/\text{m}^3$. The average of the concentrations of lead at all three sites monitored were lower than the NAAQS, although in the hallway the value was exceeded during several 24-hour periods.

Hallway – Oakland Gardens Elementary School



XBL 805-789

Figure 16. Comparison of particulate mass in the hallway and outdoors.

Table 7. Average concentrations and standard deviations of particulate mass during school days in the hallway, Oakland Gardens Elementary School, NYC.

	Fine Particulate Mass ^a ($\mu\text{g}/\text{m}^3$)	Total Inhalable Particulates ^b ($\mu\text{g}/\text{m}^3$)
Hallway	59 ± 20	145 ± 340
Outdoors	26 ± 15	37 ± 190
Ratio ^c	2.5 ± .7	4.9 ± 1.9

^aLess than 2.5 microns

^bLess than 15 microns

^cThe hallway/outdoors ratios were calculated for each day and values given represent the average of the ratios.


Table 8. Average and maximum concentrations of fine particulate sulfur, lead, and bromine during school days, Oakland Gardens Elementary School, NYC.

Element	Room 323		Outdoors		Hallway	
	Average ^a	Max.	Average ^a	Max.	Average ^a	Max.
Sulfur ($\mu\text{g}/\text{m}^3$)	2.7 ± 2.0	9.80	3.2 ± 1.5	6.90	6.3 ± 3.6	14.1
Lead ($\mu\text{g}/\text{m}^3$)	0.5 ± 0.3	1.03	1.2 ± 1.0	3.35	1.3 ± 1.0	3.53 (4.23) ^b
Bromine (ng/m^3)	141 ± 93	364	395 ± 398	1324	378 ± 366	1209 (1350) ^b

^aAverage concentrations ± one standard deviation

^bMaximum mass on weekends or holidays
(higher than maximum mass on school days)


Room 323—Oakland Gardens Elementary School



XBL 805-935

Figure 17. Comparison of the mass of fine particulate sulfur in Room 323 and outdoors.


Room 323 – Oakland Gardens Elementary School



XBL 805-788

Figure 18. Comparison of the mass of fine particulate lead in Room 323 and outdoors.

Room 323—Oakland Gardens Elementary School



XBL 805-849

Figure 19. Comparison of the mass of fine particulate bromine in Room 323 and outdoors.

Odor Perception

The Oakland Gardens Elementary School was the second site visited by TRC as part of its field monitoring program to determine ventilation requirements for controlling odors in buildings.²⁴ The sensory perception of odors, odor acceptability, and the chemical (organic) composition of indoor air were studied for a two-week period with the ventilation system in the high and low operating modes.

Table 9 summarizes the results of measurements of odor dilution ratio, odor intensity, and odor acceptability in the two test rooms (Rooms 323 and 325) and of acceptability measurements in a control room where no changes were made in the ventilation rate (Room 322). Under high ventilation conditions, the ED₅₀ for outside and inside air were quite similar (4.3 and 4.1 respectively). In the low ventilation mode, the ED₅₀ increased by approximately 50% in the two classrooms and outdoors. Similar results were obtained from the odor intensity measurement, i.e., a small increase in intensity with decreasing ventilation rate.

Both occupants and panelists judged odor acceptability. Table 9 shows the odor acceptability as perceived by the panelists under high and low ventilation rates. The acceptability range of the high ventilation condition was 75-86% by the panelists. The control room (Room 322), where the ventilation rate was lower than the two test rooms, was judged to be the least acceptable. Under the low ventilation conditions, the acceptance was lower in all three rooms, 49-68%. Note that although no change in ventilation was made in the control room, the odor acceptability by the panelists dropped from 75 to 51%. During the testing under the low ventilation rate, the outdoor air also increased in odor perceptibility, the ED₅₀ increasing by approximately 50%. The uncertainty in these odors measurements is high (15-20%). It is difficult to determine if the decrease in odor acceptability in the classrooms was due to a decrease in ventilation rate or from the fact that the outdoor air and indoor air in adjacent rooms had a higher odor content.

According to the section of ASHRAE Standard 62-73 pertaining to the odor acceptability of outdoor air, at least 60% of a panel of no fewer than 10 untrained observers must agree that the air is free of objectionable odors. If this standard were applied to indoor air, the odor levels in the three classrooms would be acceptable under the high ventilation conditions. Under the low ventilation conditions, however, the odor levels would be unacceptable in two of the three classrooms monitored, (one of the test classrooms and the control room). It should be noted that the "low" ventilation rate was only 4.4 m³/h (3 cfm) per occupant, which is less than the present ASHRAE minimum. Criteria for indoor air quality with respect to odor levels are now being developed by ASHRAE for Standard 62-73R. One of the changes being proposed is that at least 80% of a panel of no fewer than 20 untrained observers must agree on the acceptability of the air quality as regards odor. Based on the responses of only 10 untrained observers and considering that 80% of this panel must agree on the odor acceptability, the odor level was acceptable in two of the three classrooms under the high

Table 9. Summary of data on odor perception by the panelists of air samples outdoors and from three classrooms under high and low ventilation rates at Oakland Gardens Elementary School, NYC.

	Odor Dilution Ratio (ED ₅₀)		Odor Intensity Butanol Scale		Average Acceptability	
	High Vent.	Low Vent.	High Vent.	Low Vent.	High Vent.	Low Vent.
<u>Room 323</u>						
A.M.	3.3	6.8	1.6	2.4		
P.M.	4.4	6.1	1.6	2.1		
Average	3.9	6.5	1.6	2.3	82	68
<u>Room 325</u>						
A.M.	3.6	7.5	1.5	2.2		
P.M.	5.0	3.5	1.4	2.2		
Average	4.3	5.5	1.4	2.2	86	49
<u>Room 322 (Control Room)</u>						
Average	-	-	-	-	75 ^a	52 ^a
<u>Outdoors</u>						
Average	3.2	4.8	1.6	2.1	-	-

^aVentilation rate was unchanged for the control room. See discussion on odor perception.

ventilation conditions of 15.2 m³/h (9 cfm) per occupant. The "unacceptable" classroom was the control classroom which had an infiltration rate of less than 1.7 m³/h (1 cfm) per occupant because the exhaust fans were not used. At the low ventilation rate (4.4 m³/h or ~3 cfm per occupant), none of the classrooms would have been acceptable. Because of the large uncertainty in the measurements of odor perception, these results indicate that at least 20 panelists and longer testing periods should be used.

Odorant concentrations were too low to allow specific chemical identification by gas chromatographic-odorogram analysis.

ENERGY SAVINGS

Since Oakland Gardens Elementary School operated under conditions with the exhaust fans off and this ventilation rate was too low to maintain adequate air quality, a reduction in energy consumption through a reduced ventilation rate by turning off the exhaust fans is not feasible in this school. Therefore, we have computed potential energy savings achievable by reducing the ventilation rate for an elementary school of similar size to Oakland Gardens Elementary School but operating with a ventilation rate in the classrooms of 25.3 m³/h (15 cfm) per occupant, the recommended ASHRAE value.

If a similar elementary school averaged 35 students in each of its 36 classrooms, there would be a total of 1260 students. A reduction in ventilation rate from 25.3 to 8.9 m³/h (15 to 5 cfm) per occupant would then be 16.8 m³/h (10 cfm) per occupant and result in a total reduction of 20,678 m³/h (12260 cfm).

To determine the yearly ventilation-heating load for the climate of New York City, we used previous calculations of ventilation heating load²⁵ in various locations of the United States. Oakland Gardens Elementary School is located in a 2722 degree-day base 18.3°C (4900 degree-day, base 65°F) climate. For the 9 A.M. to 5 P.M. period over a full heating season, 0.031 gigajoules (50,000 Btu) is required to heat each m³/h (cfm) of outside air to an indoor temperature of 21 °C (70°F). Assuming a heating system efficiency of 0.65, we calculate the energy savings as shown below.

$$\begin{aligned} \text{Energy Savings} &= \frac{(\text{Vent. heating load})(\text{Vent. rate reduction})}{(\text{Heating system efficiency})} \\ &= \frac{.031 \frac{\text{GJ}}{\text{m}^3/\text{h}} (21,269 \text{ m}^3/\text{h})}{0.65} \\ &= 1014 \text{ GJ} \quad (9.61 \times 10^8 \text{ Btu}) \end{aligned}$$

Considering that the No. 6 heating oil used in the New York City schools has 1.53×10^5 Btu/gallon, this energy represents 6278 gallons of heating oil. At a cost of 85 cents per gallon, the energy cost savings would be approximately \$5335 per year for an elementary school similar in size to Oakland Gardens Elementary School with approximately 1260 students and a ventilation rate of $25.3 \text{ m}^3/\text{h}$ (15 cfm) per occupant. This amount represents the savings which would be realized from a ventilation reduction in classrooms only. A much higher amount would be saved by reducing ventilation not only in classrooms but in the entire school, including activity rooms such as the lunchroom, gymnasium, and auditorium.

CONCLUSIONS

In this study of indoor air quality at Oakland Gardens Elementary School, the only air quality problems encountered were high levels of particulates in the hallway (but not in the individual classrooms), nitrogen dioxide levels both indoors and outdoors that were close to or slightly exceeding EPA ambient air quality standards, and a decrease in odor acceptability (to <60%) in one of the classrooms at the "low" ventilation rate of $4.4 \text{ m}^3/\text{h}$ (3 cfm) per occupant. Only the deterioration of odor acceptability can be attributed to a reduction in ventilation rate. The small number of panelists used and the large uncertainty in the odor measurements make the odor data difficult to assess. The levels of the other gaseous pollutants and of particulates in the classrooms were below relevant air quality standards even at the "low" ventilation rate of $4.4 \text{ m}^3/\text{h}$ (3 cfm) per occupant.

We conclude that the ventilation rate can be reduced to the "intermediate" ventilation rate of $8.4 \text{ m}^3/\text{h}$ (5 cfm) per occupant without any significant deterioration of the air quality indoors and without adverse effects on the health, safety, and comfort of the occupants. $8.4 \text{ m}^3/\text{h}$ (5 cfm) per occupant is the new ASHRAE 62-81 requirements for school classrooms where smoking is not allowed (or approximately one-half the older ASHRAE recommendations for this school from ASHRAE 62-73). Mechanical ventilation (exhaust fans on) is required in this school to maintain carbon dioxide levels below $9000 \text{ mg}/\text{m}^3$ (5000 ppm). Our calculations indicate that moderate savings in energy costs can be achieved through a reduction in ventilation rate for schools (similar to Oakland Gardens Elementary School) currently operating with a ventilation rate in the classrooms of $25.3 \text{ m}^3/\text{h}$ (15 cfm) per occupant. These results corroborate the findings of our field studies at Carondelet High School in California⁵ and at Fairmoor Elementary School in Ohio.⁶

ACKNOWLEDGEMENTS

The authors wish to acknowledge the many people who assisted us in this field study. We wish to thank Mr. H. Eisendorf of the New York City Board of Education for his efforts in coordinating the project. We wish to thank the principal, Mr. Al Yurman, the staff and students of Oakland Gardens Elementary School for their cooperation. In particular, we would like to thank the students in classrooms 323 and 325 and their teachers, Ms Knobel and Rosenthal, for their patience and cooperation during the study. Special thanks to the school engineer, Art Capitini, and his staff, Bill DiMaggio and Dana Hamilton, for their invaluable help around the school. Paul Jann and Richard Duffee of TRC supplied us with the odor data.

The LBL Ventilation staff also helped immeasurably in completing this project. Specifically, we would like to thank Steve Brown for his help in the data reduction and work on the infiltration system in New York City, James Koonce for the coordination and set up of the experiment, and Laurel Cook for having

REFERENCES

1. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Standards for Natural and Mechanical Ventilation, ASHRAE 62-73 (New York, 1973).
2. C.P. Yaglou, E.C. Riley, and D.I. Coogins, "Ventilation Requirements," ASHRAE Transactions 42 (1936):133-163.
3. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Energy Conservation in New Building Design, ASHRAE 90-75R (New York, 1975).
4. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Ventilation for Acceptable Indoor Air Quality, ASHRAE 62-1981 (New York, 1981).
5. J.V. Berk, C.D. Hollowell, C. Lin, and I. Turiel, The Effects of Energy Efficient Ventilation Rates on Indoor Air Quality at a California High School, Lawrence Berkeley Laboratory Report, LBL-7832 (April 1978).
6. J.V. Berk, R. Young, C.D. Hollowell, I. Turiel, and J. Pepper, The Effects of Energy Efficient Ventilation Rates on Indoor Air Quality at an Ohio Elementary School, Lawrence Berkeley Laboratory Report, LBL-10223 (April 1980).
7. Occupational Safety and Health Administration, U.S. Dept. of Labor, Code of Federal Regulations, 29 CFR 1910.1000 (July 1, 1979).
8. J.V. Berk, C.D. Hollowell, C. Lin, and J. Pepper, Design of a Mobile Laboratory for Ventilation Studies and Indoor Air Pollution Monitoring, Lawrence Berkeley Laboratory Report, LBL-7817 (April 1978).
9. B.W. Loo, J.M. Jaklevic, and F.S. Goulding, "Dichotomous Virtual Impactors for Large Scale Monitoring of Airborne Particulate Matter," in Fine Particles, ed. B.Y.U. Liu (New York: Academic Press, 1976).
10. D.W. Anthon, L.Z. Fanning, C.D. Hollowell, and C. Lin, Air Sampling Using Pneumatic Flow Controllers, Lawrence Berkeley Laboratory Report, LBL-9403 (December 1979).
11. M. Ketz, Methods of Air Sampling and Analysis, 2nd ed. (Washington, D.C.: American Public Health Association, 1977).
12. D.W. Anthon, L.Z. Fanning, and R.R. Miksch, Modified Pararosaniline Method for Determination of Formaldehyde in Air Lawrence Berkeley Laboratory Report in progress.
13. M.L. Boegel, W.W. Nazaroff, and J.G. Ingersoll, Instructions for Operating LBL Passive Environmental Radon Monitor (PERM), Lawrence Berkeley Laboratory, Report, LBL 10246 (August 1979).

14. A. Dravnieks and W.H. Prokop, "Source Emission Odor Measurement by a Dynamic Forced-Choice Triangle Olfactometer," Journal of the Air Pollution Control Association 25 (1975):28.
15. L.E. Marks, Sensory Processes: The New Psychophysics (New York: Academic Press, 1974).
16. National Institute for Occupational Safety and Health, Criteria for a Recommended Standard: Occupational Exposure to Carbon Dioxide, HEW Pub. No. 76-94 (Washington, D.C.: Department of Health, Education and Welfare, 1976).
17. S.T. Liu, S.M. Hunt, and F.J. Powell, Evaluation of Ventilation Requirements and Energy Consumption in Existing New York City School Buildings, National Bureau of Standards Report No. NBS BSS 97 (Washington D.C., U.S. Department of Commerce, National Bureau of Standards, April 1977).
18. Environmental Protection Agency, "National Primary and Secondary Air Quality Standards," Code of Federal Regulations, 40 CFR 50 (July 1, 1979).
19. I. Andersen, "Formaldehyde in the Indoor Environment - Health Implications and Setting of Standards," paper presented at the International Indoor Climate Symposium, Copenhagen, Denmark, August 30-September 2, 1978.
20. R. Baars, "The Formal Aspects of the Formaldehyde Problem in the Netherlands," paper presented at the International Indoor Climate Symposium, Copenhagen, Denmark, August 30-September 2, 1978.
21. H. Wahren, "Formaldehyde Indoor Air Standards in Sweden," paper presented at the CPSC technical workshop on Formaldehyde, Washington, D.C., April 9-11, 1980.
22. Atomic Energy Control Board (AECB) [of Canada], Criteria for Radioactive Clean-up in Canada, AECB Information Bulletin 77-2 (April 7, 1977).
23. Environmental Protection Agency, "Indoor Radiation Exposure Due to Radium-226 in Florida Phosphate Lands; Radiation Protection Recommendations and Request for Comment," Federal Register 44, 38664-38670 (July 2, 1979).
24. R.A. Duffee and P. Jann, Ventilation/Odor Study: Field, Lawrence Berkeley Laboratory Report, LBL-12632 (April 1981).
25. J.V. Berk, C.D. Hollowell, C. Lin, and I. Turiel, The Effects of Reduced Ventilation on Indoor Air Quality and Energy Use in Schools, Lawrence Berkeley Laboratory Report, LBL-9382 (June 1979).


APPENDIX

The Appendix contains histograms of the concentrations of the common inorganic pollutants: carbon dioxide, carbon monoxide, nitrogen dioxide, nitric oxide, ozone and sulfur dioxide. Only the data collected during regular school hours, 8:30 A.M. to 3:30 P.M., has been included. For Rooms 323 and 325, the data on a particular pollutant has been grouped by ventilation rate.

<u>Site</u>	<u>Pollutant</u>	<u>Page</u>
Room 323:	CO ₂	46
	CO	47
	NO ₂	48
	NO	49
	O ₃	50
	SO ₂	51
Room 325:	CO ₂	52
	CO	53
	NO ₂	54
	NO	55
	O ₃	56
	SO ₂	57
Hallway:	CO ₂	58
	CO	59
	NO ₂	60
	NO	61
	O ₃	62
	SO ₂	63

CO₂ CONCENTRATIONS AT VARIOUS
VENTILATION RATES


Room 323 - Oakland Gardens Elementary School



XBL 808-1573

CO CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 323 - Oakland Gardens Elementary School



XBL 808-1578

NO₂ CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 323 - Oakland Gardens Elementary School



XBL 808-1574

NO CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 323 - Oakland Gardens Elementary School



XBL 808-1576

O₃ CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 323 - Oakland Gardens Elementary School



XBL 808-1577

SO₂ CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 323 - Oakland Gardens Elementary School



XBL 808-1575

CO₂ CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 325 - Oakland Gardens Elementary School



XBL 808-1570

CO CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 325 - Oakland Gardens Elementary School



XBL 808-1566

NO₂ CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 325 - Oakland Gardens Elementary School



XBL 808-1581

NO CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 325 – Oakland Gardens Elementary School



XBL 808-1569

O₃ CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 325 - Oakland Gardens Elementary School



XBL 808-1580

SO₂ CONCENTRATIONS AT VARIOUS VENTILATION RATES


Room 325 - Oakland Gardens Elementary School



XBL 808-1579

INDOOR/OUTDOOR CARBON DIOXIDE


Hallway - Oakland Gardens Elementary School



XBL 808-1586

INDOOR/OUTDOOR CARBON MONOXIDE


Hallway – Oakland Gardens Elementary School



XBL 808-1587

INDOOR/OUTDOOR NITROGEN DIOXIDE


Hallway – Oakland Gardens Elementary School



XBL 808-1585

INDOOR/OUTDOOR NITRIC OXIDE


Hallway - Oakland Gardens Elementary School



XBL 808-1583

INDOOR/OUTDOOR OZONE


Hallway – Oakland Gardens Elementary School



XBL 808-1588

INDOOR/OUTDOOR SULFUR DIOXIDE

Hallway – Oakland Gardens Elementary School



XBL 808-1584

