

Lawrence Berkeley National Laboratory

Lawrence Berkeley National Laboratory

Title

2.1E Sample Run Book

Permalink

<https://escholarship.org/uc/item/81x084ms>

Author

Winkelmann, F.C.

Publication Date

1994-05-16

Peer reviewed

SPACE SPACE1-1

MONTH	L I G H T I N G		E Q U I P M E N T		P R O C E S S	
	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	402.18	193.67	0.00	0.0000	0.0000
FEB	0.00	349.67	167.88	0.00	0.0000	0.0000
MAR	0.00	386.57	185.58	0.00	0.0000	0.0000
APR	0.00	400.28	193.16	0.00	0.0000	0.0000
MAY	0.00	402.18	193.67	0.00	0.0000	0.0000
JUN	0.00	369.07	176.99	0.00	0.0000	0.0000
JUL	0.00	402.18	193.67	0.00	0.0000	0.0000
AUG	0.00	402.18	193.67	0.00	0.0000	0.0000
SEP	0.00	369.07	176.99	0.00	0.0000	0.0000
OCT	0.00	402.18	193.67	0.00	0.0000	0.0000
NOV	0.00	353.47	168.90	0.00	0.0000	0.0000
DEC	0.00	386.57	185.58	0.00	0.0000	0.0000

ANNUAL	0.00	4625.43	2223.36	0.00	0.0000	0.0000

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- LS-K *BUILDING* INPUT FUELS SUMMARY

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 3

WEATHER FILE- TRY CHICAGO

BUILDING

MONTH	L I G H T I N G		E Q U I P M E N T		P R O C E S S	
	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	1904.24	917.01	0.00	0.0000	0.0000
FEB	0.00	1655.62	794.91	0.00	0.0000	0.0000
MAR	0.00	1830.37	878.71	0.00	0.0000	0.0000
APR	0.00	1895.24	914.61	0.00	0.0000	0.0000
MAY	0.00	1904.24	917.01	0.00	0.0000	0.0000
JUN	0.00	1747.50	838.01	0.00	0.0000	0.0000
JUL	0.00	1904.24	917.01	0.00	0.0000	0.0000
AUG	0.00	1904.24	917.01	0.00	0.0000	0.0000
SEP	0.00	1747.49	838.01	0.00	0.0000	0.0000
OCT	0.00	1904.24	917.01	0.00	0.0000	0.0000
NOV	0.00	1673.62	799.71	0.00	0.0000	0.0000
DEC	0.00	1830.37	878.71	0.00	0.0000	0.0000
ANNUAL	0.00	21903.13	10529.22	0.00	0.0000	0.0000

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- LS-L MANAGEMENT AND SOLAR SUMMARY FOR SPACE

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS
SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 3
WEATHER FILE- TRY CHICAGO

DATA FOR SPACE SPACE1-1

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	91833.594	44721.133
FEB	0.	106403.789	44042.688
MAR	0.	101484.391	40590.414
APR	0.	121678.523	32228.947
MAY	0.	114414.562	25011.039
JUN	0.	119506.453	19855.189
JUL	0.	124538.578	22544.020
AUG	0.	124817.953	28443.521
SEP	0.	141770.906	36432.680
OCT	0.	124279.734	41222.324
NOV	0.	92218.547	43065.477
DEC	0.	58324.055	42647.609
ANNUAL	0.	110041.141	44721.133

MMDDHH	GLOBAL DRY BULB TEMP F	GLOBAL WIND SPEED KNOTS	GLOBAL SOLAR BTU/HR- SQFT	BUILDING SENSIBLE CLG LOAD BTU/HR
	---- (4)	----(17)	----(15)	----(19)
8 5 1	77.2	6.5	0.0	13754.
8 5 2	75.4	6.5	0.0	11618.
8 5 3	73.9	6.5	0.0	9722.
8 5 4	72.7	6.5	0.0	8061.
8 5 5	71.8	6.5	0.0	6637.
8 5 6	71.2	6.5	14.7	9282.
8 5 7	71.0	6.5	73.7	16061.
8 5 8	71.8	6.5	136.0	48682.
8 5 9	73.9	6.5	191.7	54022.
8 5 10	77.2	6.5	237.0	58066.
8 5 11	81.0	6.5	268.7	59631.
8 5 12	84.8	6.5	284.9	58113.
8 5 13	88.1	6.5	284.3	66171.
8 5 14	90.2	6.5	266.9	73522.
8 5 15	91.0	6.5	234.1	77069.
8 5 16	90.8	6.5	188.0	78377.
8 5 17	90.2	6.5	131.6	79840.
8 5 18	89.3	6.5	69.1	66388.
8 5 19	88.1	6.5	11.3	51033.
8 5 20	86.6	6.5	0.0	41320.
8 5 21	84.8	6.5	0.0	33620.
8 5 22	83.0	6.5	0.0	29098.
8 5 23	81.0	6.5	0.0	25137.
8 5 24	79.0	6.5	0.0	21617.

DAILY SUMMARY (AUG 5)

MN	71.0	6.5	0.0	6637.
MX	91.0	6.5	284.9	79840.
SM	1944.0	156.4	2391.8	996843.
AV	81.0	6.5	99.7	41535.

MONTHLY SUMMARY (AUG)

MN	71.0	6.5	0.0	6637.
MX	91.0	6.5	284.9	79840.
SM	1944.0	156.4	2391.8	996843.
AV	81.0	6.5	99.7	41535.

YEARLY SUMMARY

MN	71.0	6.5	0.0	6637.
MX	91.0	6.5	284.9	79840.
SM	1944.0	156.4	2391.8	996843.
AV	81.0	6.5	99.7	41535.

	GLOBAL	GLOBAL	GLOBAL	BUILDING
	DRY BULB TEMP F	WIND SPEED KNOTS	GLOBAL SOLAR BTU/HR- SQFT	SENSIBLE CLG LOAD BTU/HR
	---- (.4)	---- (17)	---- (15)	---- (19)
8 5 1	61.0	7.0	0.0	2620.
8 5 2	59.0	0.0	0.0	1178.
8 5 3	57.0	4.0	0.0	358.
8 5 4	57.0	5.0	0.0	183.
8 5 5	55.0	4.0	0.0	146.
8 5 6	52.0	0.0	14.7	1928.
8 5 7	57.0	0.0	73.1	9782.
8 5 8	62.0	0.0	134.4	44195.
8 5 9	68.0	0.0	154.7	50107.
8 5 10	72.0	3.0	228.6	57516.
8 5 11	74.0	0.0	263.1	61080.
8 5 12	76.0	7.0	280.5	59162.
8 5 13	77.0	6.0	262.1	66258.
8 5 14	78.0	5.0	246.5	72205.
8 5 15	77.0	6.0	216.3	74465.
8 5 16	76.0	6.0	131.7	71804.
8 5 17	77.0	9.0	72.3	69819.
8 5 18	76.0	9.0	32.9	54277.
8 5 19	75.0	7.0	6.3	40991.
8 5 20	72.0	7.0	0.0	32576.
8 5 21	69.0	4.0	0.0	24984.
8 5 22	68.0	4.0	0.0	21017.
8 5 23	67.0	4.0	0.0	17755.
8 5 24	66.0	6.0	0.0	14905.
DAILY SUMMARY (AUG 5)				
MN	52.0	0.0	0.0	146.
MX	78.0	9.0	280.5	74465.
SM	1628.0	103.0	2117.3	849310.
AV	67.8	4.3	88.2	35388.
MONTHLY SUMMARY (AUG)				
MN	52.0	0.0	0.0	146.
MX	78.0	9.0	280.5	74465.
SM	1628.0	103.0	2117.3	849310.
AV	67.8	4.3	88.2	35388.
YEARLY SUMMARY				
MN	52.0	0.0	0.0	146.
MX	78.0	9.0	280.5	74465.
SM	1628.0	103.0	2117.3	849310.
AV	67.8	4.3	88.2	35388.

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

SYST-1

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE						
SYST-1	VAVS		1.020	5000.0		52.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	6354.	7.311	3.6	0.	0.000	0.0	0.167	195.964	0.770	-44.161	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
SPACE5-1	1454.	0.	0.000	0.300	408.	0.00	0.00	25.13	-91.09	-75.39	1.0	
SPACE1-1	1909.	0.	0.000	0.300	224.	0.00	0.00	32.99	-119.59	-98.98	1.0	
SPACE2-1	887.	0.	0.000	0.300	102.	0.00	0.00	15.33	-55.58	-46.00	1.0	
SPACE3-1	1268.	0.	0.000	0.300	224.	0.00	0.00	21.92	-79.45	-65.75	1.0	
SPACE4-1	835.	0.	0.000	0.300	102.	0.00	0.00	14.42	-52.28	-43.26	1.0	
PLENUM-1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-D PLANT MONTHLY LOADS SUMMARY FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 DEFAULT-PLANT

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -					- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	0.00000				0.000	-32.540	7 8	-1.F	-1.F	-441.109	3078.	12.721	
FEB	0.00000				0.000	-25.221	4 8	7.F	6.F	-419.194	2665.	12.701	
MAR	0.00000				0.000	-15.190	25 8	14.F	12.F	-377.563	2904.	12.371	
APR	1.52664	29 18	69.F	65.F	68.311	-3.705	8 8	30.F	27.F	-246.024	2992.	13.298	
MAY	5.10064	21 14	85.F	75.F	132.661	-0.420	9 9	43.F	39.F	-40.320	3085.	14.424	
JUN	14.55954	20 16	90.F	77.F	178.041	0.000				0.000	3054.	15.339	
JUL	28.78266	8 16	92.F	74.F	214.902	0.000				0.000	3779.	18.322	
AUG	23.67940	19 16	90.F	71.F	183.011	0.000				0.000	3545.	17.242	
SEP	9.23581	11 16	86.F	72.F	138.083	-0.227	23 8	36.F	34.F	-99.033	2932.	15.530	
OCT	2.26933	4 17	78.F	61.F	49.778	-2.190	21 8	30.F	29.F	-258.277	2994.	12.617	
NOV	0.35773	1 16	72.F	59.F	54.561	-12.995	25 8	27.F	25.F	-325.673	2644.	13.017	
DEC	0.00000				0.000	-25.768	26 8	15.F	15.F	-393.064	2940.	12.345	
TOTAL	85.512					-118.258					36610.		
MAX					214.902					-441.109		18.322	
MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY)						2274.994 (KBTU)							
MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE)						2147.572 (KBTU)							

----- N U M B E R O F H O U R S -----											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	0	305	0	439	744	0	305	63	0	0	0.000	0.475
FEB	0	256	0	416	672	0	256	47	0	0	0.000	0.475
MAR	0	240	0	504	715	29	248	17	0	8	0.000	0.475
APR	69	102	0	549	516	204	229	0	0	58	0.000	11.735
MAY	115	40	0	589	485	259	220	0	0	65	0.000	13.348
JUN	203	0	0	517	171	549	207	0	0	4	0.000	15.156
JUL	241	0	0	503	7	737	241	0	0	0	0.000	17.942
AUG	238	0	0	506	43	701	238	0	0	0	0.000	16.987
SEP	155	13	0	552	346	374	205	0	0	37	0.000	14.658
OCT	99	86	1	560	511	233	225	0	0	41	0.000	11.103
NOV	12	186	0	522	686	34	209	1	0	11	0.000	12.583
DEC	0	276	0	468	744	0	276	45	0	0	0.000	0.475
ANNUAL	1132	1504	1	6125	5640	3120	2859	173	0	224		

MONTH	FAN ELECTRIC ENERGY DURING HEATING (KWH)	FAN ELECTRIC ENERGY DURING COOLING (KWH)	FAN ELECTRIC ENERGY DURING HEATING-COOLING (KWH)	FAN ELECTRIC ENERGY DURING FLOATING (KWH)
JAN	256.361	0.000	0.000	0.000
FEB	214.658	0.000	0.000	0.000
MAR	188.892	0.000	0.000	5.833
APR	77.282	59.311	0.000	45.241
MAY	29.165	172.787	0.000	61.428
JUN	0.000	465.212	0.000	3.377
JUL	0.000	957.790	0.000	0.000
AUG	0.000	723.851	0.000	0.000
SEP	9.505	303.856	0.000	32.739
OCT	63.882	77.672	0.729	31.766
NOV	148.524	13.215	0.000	8.918
DEC	230.728	0.000	0.000	0.000
ANNUAL	1218.994	2773.703	0.729	189.301

----- COOLING -----						----- HEATING -----						----- ELEC -----	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	0.00000				0.000	-32.540	7 8	-1.F	-1.F	-441.109	3078.	12.721	
FEB	0.00000				0.000	-25.221	4 8	7.F	6.F	-419.194	2665.	12.701	
MAR	0.00000				0.000	-15.190	25 8	14.F	12.F	-377.563	2904.	12.371	
APR	1.52664	29 18	69.F	65.F	68.311	-3.705	8 8	30.F	27.F	-246.024	2992.	13.298	
MAY	5.10064	21 14	85.F	75.F	132.661	-0.420	9 9	43.F	39.F	-40.320	3085.	14.424	
JUN	14.55954	20 16	90.F	77.F	178.041	0.000				0.000	3054.	15.339	
JUL	28.78266	8 16	92.F	74.F	214.902	0.000				0.000	3779.	18.322	
AUG	23.67940	19 16	90.F	71.F	183.011	0.000				0.000	3545.	17.242	
SEP	9.23581	11 16	86.F	72.F	138.083	-0.227	23 8	36.F	34.F	-99.033	2932.	15.530	
OCT	2.26933	4 17	78.F	61.F	49.778	-2.190	21 8	30.F	29.F	-258.277	2994.	12.617	
NOV	0.35773	1 16	72.F	59.F	54.561	-12.995	25 8	27.F	25.F	-325.673	2644.	13.017	
DEC	0.00000				0.000	-25.768	26 8	15.F	15.F	-393.064	2940.	12.345	
TOTAL	85.512					-118.258					36610.		
MAX					214.902					-441.109		18.322	

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-B SYSTEM MONTHLY LOADS SUMMARY FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

- - ZONE COOLING - -		- - ZONE HEATING - -		- - BASEBOARDS - -		- - PREHEAT OR FURN FAN ELEC - -		
MONTH	COOLING BY ZONE COILS OR NAT VENTIL (MBTU)	MAXIMUM COOLING BY ZONE COILS OR NAT VENTIL (KBTU/HR)	HEATING BY ZONE COILS OR FURNACE (MBTU)	MAXIMUM HEATING BY ZONE COILS OR FURNACE (KBTU/HR)	BASEBOARD HEATING ENERGY (MBTU)	MAXIMUM BASEBOARD HEATING ENERGY (KBTU/HR)	PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (MBTU)	MAXIMUM PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (KBTU/HR)
JAN	0.00000	0.000	-17.82038	-297.637	0.00000	0.000	-4.75593	-67.279
FEB	0.00000	0.000	-14.18888	-294.461	0.00000	0.000	-2.92867	-51.287
MAR	0.00000	0.000	-8.90534	-273.295	0.00000	0.000	-0.85343	-49.556
APR	0.00000	0.000	-2.10489	-209.516	0.00000	0.000	-0.02173	-8.605
MAY	0.00000	0.000	-0.07233	-20.454	0.00000	0.000	0.00000	0.000
JUN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUL	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
AUG	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
SEP	0.00000	0.000	-0.09337	-63.534	0.00000	0.000	-0.00095	-0.948
OCT	0.00000	0.000	-1.16098	-195.242	0.00000	0.000	-0.02610	-7.933
NOV	0.00000	0.000	-8.25455	-257.724	0.00000	0.000	-0.21340	-15.096
DEC	0.00000	0.000	-15.28043	-282.811	0.00000	0.000	-1.52668	-42.234
TOTAL	0.000		-67.881		0.000		-10.327	
MAX		0.000		-297.637		0.000		-67.279

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-C SYSTEM MONTHLY LOAD HOURS FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

----- N U M B E R O F H O U R S ----- --COINCIDENT LOADS--

MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	0	305	0	439	744	0	305	63	0	0	0.000	0.475
FEB	0	256	0	416	672	0	256	47	0	0	0.000	0.475
MAR	0	240	0	504	711	29	248	17	0	8	0.000	0.475
APR	69	102	0	549	504	204	229	0	0	58	0.000	11.735
MAY	115	40	0	589	452	259	220	0	0	65	0.000	13.348
JUN	203	0	0	517	147	549	207	0	0	4	0.000	15.156
JUL	241	0	0	503	2	737	241	0	0	0	0.000	17.942
AUG	238	0	0	506	30	701	238	0	0	0	0.000	16.987
SEP	155	13	0	552	314	374	205	0	0	37	0.000	14.658
OCT	99	86	1	560	494	233	225	0	0	41	0.000	11.103
NOV	12	186	0	522	676	34	209	1	0	11	0.000	12.583
DEC	0	276	0	468	744	0	276	45	0	0	0.000	0.475
ANNUAL	1132	1504	1	6125	5490	3120	2859	173	0	224		

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-H SYSTEM MONTHLY LOADS SUMMARY FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

MONTH	- FAN ELEC -		- FUEL HEAT -		- FUEL COOL -		- ELEC HEAT -		- ELEC COOL -	
	FAN ENERGY (KWH)	MAXIMUM FAN LOAD (KW)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)
JAN	256.	3.984	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
FEB	215.	3.878	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAR	195.	3.320	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
APR	182.	2.198	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAY	263.	2.955	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUN	469.	4.156	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUL	958.	7.304	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
AUG	724.	5.987	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
SEP	346.	4.123	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
OCT	173.	1.794	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
NOV	171.	3.021	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
DEC	231.	3.543	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
TOTAL	4181.		0.000		0.000		0.		0.	
MAX		7.304		0.000		0.000		0.000		0.000

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	0.00000	0.00000	0.000			-32.54049	0.00000	-441.10925
FEB	0.00000	0.00000	0.000			-25.22139	0.00000	-419.19385
MAR	0.00000	0.00000	0.000			-15.18957	0.00000	-377.56302
APR	1.46930	0.05734	68.311	0.848	29 18	-3.70518	0.00000	-246.024
MAY	4.54812	0.55252	132.661	0.777	21 14	-0.42017	0.00000	-40.320
JUN	13.34809	1.21146	178.041	0.793	20 16	0.00000	0.00000	0.000
JUL	25.94250	2.84016	214.902	0.883	8 16	0.00000	0.00000	0.000
AUG	21.18397	2.49544	183.011	0.919	19 16	0.00000	0.00000	0.000
SEP	8.60116	0.63464	138.083	0.849	11 16	-0.22747	0.00000	-99.033
OCT	2.17180	0.09753	49.778	1.000	4 17	-2.19046	0.00000	-258.277
NOV	0.35701	0.00072	54.561	1.000	1 16	-12.99550	0.00000	-325.673
DEC	0.00000	0.00000	0.000			-25.76809	0.00000	-393.06366
	-----	-----	-----	-----		-----	-----	-----
TOTAL	77.622	7.890				-118.258	0.000	
MAX			214.902	0.883				-441.109

- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
JUL 8				JAN 7			JUL 8			
HOURLY COOLING LOAD KBTU	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD KBTU	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD KBTU	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	76.F 68.F	0.000	6.F	6.F	0.000	0.000	76.F	68.F
2	0.000	0.000	76.F 68.F	-146.914	4.F	4.F	0.000	0.000	76.F	68.F
3	0.000	0.000	75.F 68.F	0.000	2.F	2.F	0.000	0.000	75.F	68.F
4	0.000	0.000	74.F 68.F	-155.152	2.F	2.F	0.000	0.000	74.F	68.F
5	0.000	0.000	73.F 67.F	0.000	2.F	2.F	0.000	0.000	73.F	67.F
6	0.000	0.000	72.F 67.F	-163.423	1.F	1.F	0.000	0.000	72.F	67.F
7	164.625 *	0.913	72.F 67.F	0.000	0.F	0.F	164.625 *	0.913	72.F	67.F
8	184.814 *	0.860	77.F 70.F	-441.109	-1.F	-1.F	184.814 *	0.860	77.F	70.F
9	182.204 *	0.855	83.F 72.F	-287.347	0.F	0.F	182.204 *	0.855	83.F	72.F
10	193.900 *	0.841	86.F 74.F	-233.795	2.F	1.F	193.900 *	0.841	86.F	74.F
11	196.262 *	0.865	89.F 74.F	-198.142	4.F	3.F	196.262 *	0.865	89.F	74.F
12	193.265 *	0.901	90.F 73.F	-167.741	6.F	5.F	193.265 *	0.901	90.F	73.F
13	202.205 *	0.898	91.F 73.F	-149.663	8.F	6.F	202.205 *	0.898	91.F	73.F
14	208.722 *	0.900	92.F 73.F	-128.669	9.F	7.F	208.722 *	0.900	92.F	73.F
15	214.902 *	0.883	92.F 74.F	-112.424	10.F	8.F	214.902 *	0.883	92.F	74.F
16	205.470	0.905	93.F 73.F	-106.730	9.F	7.F	205.470	0.905	93.F	73.F
17	201.179	0.903	93.F 73.F	-107.148	8.F	6.F	201.179	0.903	93.F	73.F
18	0.000	0.000	92.F 73.F	-115.849	5.F	4.F	0.000	0.000	92.F	73.F
19	0.000	0.000	90.F 72.F	0.000	4.F	3.F	0.000	0.000	90.F	72.F
20	0.000	0.000	83.F 70.F	0.000	2.F	1.F	0.000	0.000	83.F	70.F
21	0.000	0.000	82.F 68.F	0.000	3.F	2.F	0.000	0.000	82.F	68.F
22	0.000	0.000	82.F 70.F	0.000	4.F	3.F	0.000	0.000	82.F	70.F
23	0.000	0.000	82.F 70.F	0.000	4.F	3.F	0.000	0.000	82.F	70.F
24	0.000	0.000	80.F 69.F	0.000	5.F	4.F	0.000	0.000	80.F	69.F
SUM							2147.547			
MAX	214.902			-441.109						

SYSTEM-TYPE VAVS SQFT/TON 279.2
 COOLING PEAK 42.98 (BTU/HR- SQFT) HEATING PEAK -88.22 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.27 (CFM/SQFT) MIN-OA/PERSON 20.40 (CFM)
 OA FRAC AT CLG PEAK 0.172 OA FRAC AT HTG PEAK 0.230

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	AVERAGE SPACE TEMP					AVERAGE TEMPERATURE DIFFERENCE			SUMMED TEMP DIFFERENCE		HUMIDITY RATIO DIFFERENCE BETWEEN OUTDOOR AND ROOM AIR (FRAC. OR MULT.)
	ALL HOURS (F)	COOLING HOURS (F)	HEATING HOURS (F)	FAN ON HOURS (F)	FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN ON HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR HEATING HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	
JAN	62.16		65.65	65.65	59.74	-36.82	-40.46	-34.29	514.20	1141.49	-0.00103
FEB	62.36		66.19	66.19	60.00	-34.84	-38.08	-32.85	406.20	975.57	-0.00091
MAR	65.34		68.59	68.71	63.66	-26.97	-30.75	-25.09	311.82	840.66	-0.00110
APR	71.74	74.21	70.63	72.68	71.31	-20.15	-19.85	-20.29	116.27	607.26	-0.00082
MAY	75.54	77.37	71.89	75.96	75.36	-18.76	-15.96	-19.94	41.85	583.60	-0.00072
JUN	79.66	78.22		78.16	80.27	-12.57	-6.37	-15.07		387.11	-0.00075
JUL	82.88	79.19		79.19	84.65	-7.31	-1.39	-10.15		289.98	0.00127
AUG	80.77	78.62		78.62	81.79	-8.93	-2.62	-11.89		310.85	0.00056
SEP	77.10	77.70	71.08	76.84	77.21	-15.72	-9.76	-18.09	12.59	482.64	-0.00109
OCT	71.86	74.74	70.77	73.07	71.34	-18.22	-15.71	-19.30	86.06	564.90	-0.00107
NOV	66.11	76.39	69.27	69.92	64.54	-25.16	-29.14	-23.53	240.00	754.84	-0.00068
DEC	62.48		66.48	66.48	60.13	-30.75	-34.66	-28.45	398.62	953.37	-0.00099
ANNUAL	71.55	77.78	67.66	72.23	71.23	-21.27	-21.42	-21.20	2127.60	7892.27	-0.00061

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-L FAN ELECTRIC ENERGY

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

MONTH	FAN ELEC DURING HEATING (KWH)	FAN ELEC DURING COOLING (KWH)	FAN ELEC DURING HEAT & COOL (KWH)	FAN ELEC DURING FLOATING (KWH)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00 10	10 20	20 30	30 40	40 50	50 60	60 70	70 80	80 90	90 100	100 +	
JAN	256.361	0.000	0.000	0.000	0	0	0	286	10	4	4	1	0	0	0	305
FEB	214.658	0.000	0.000	0.000	0	0	0	239	10	3	3	1	0	0	0	256
MAR	188.892	0.000	0.000	5.833	0	0	0	242	3	1	2	0	0	0	0	248
APR	77.282	59.311	0.000	45.241	0	0	0	216	11	2	0	0	0	0	0	229
MAY	29.165	172.787	0.000	61.428	0	0	0	144	45	27	4	0	0	0	0	220
JUN	0.000	465.212	0.000	3.377	0	0	0	23	49	80	51	4	0	0	0	207
JUL	0.000	957.790	0.000	0.000	0	0	0	1	9	35	72	66	29	28	1	241
AUG	0.000	723.851	0.000	0.000	0	0	0	9	24	62	91	40	12	0	0	238
SEP	9.505	303.856	0.000	32.739	0	0	0	88	45	37	32	3	0	0	0	205
OCT	63.882	77.672	0.729	31.766	0	0	0	224	1	0	0	0	0	0	0	225
NOV	148.524	13.215	0.000	8.918	0	0	0	200	5	2	2	0	0	0	0	209
DEC	230.728	0.000	0.000	0.000	0	0	0	259	11	0	6	0	0	0	0	276
ANNUAL	1218.994	2773.703	0.729	189.301	0	0	0	1931	223	253	267	115	41	28	1	2859

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY

HR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
80-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	
70-80	0	0	0	0	0	0	0	0	1	0	0	0	0	1	0	1	1	0	0	0	0	0	0	0	4	
60-70	0	0	0	0	0	0	0	6	5	5	5	4	4	2	2	3	3	3	0	0	0	0	0	0	42	
50-60	0	0	0	0	0	0	0	45	58	57	53	32	33	29	28	34	35	4	0	0	0	0	0	0	408	
40-50	0	0	0	0	0	0	0	42	43	45	41	60	61	69	66	59	61	9	0	0	0	0	0	0	556	
30-40	0	0	0	0	0	0	0	26	62	61	57	49	38	48	52	55	51	27	0	0	0	0	0	0	526	
0-30	0	0	0	0	0	0	0	7	83	84	96	107	116	103	103	100	101	83	0	0	0	0	0	0	983	
*** **																										

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-G ZONE LOADS SUMMARY IN

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1 FOR SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

MONTH	C O O L I N G				MAXIMUM COOLING LOAD (KBTU/HR)	H E A T I N G				MAXIMUM HEATING LOAD (KBTU/HR)	E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP		HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP		ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-4.040	7 8	-1.F	-1.F	-71.992	596.	2.429
FEB	0.00000				0.000	-3.251	4 8	7.F	6.F	-70.902	518.	2.429
MAR	0.00000				0.000	-2.057	25 8	14.F	12.F	-65.053	572.	2.429
APR	0.00000				0.000	-0.553	1 8	43.F	39.F	-45.566	593.	2.429
MAY	0.00000				0.000	-0.034	13 9	47.F	43.F	-8.113	596.	2.429
JUN	0.00000				0.000	0.000				0.000	546.	2.429
JUL	0.00000				0.000	0.000				0.000	596.	2.429
AUG	0.00000				0.000	0.000				0.000	596.	2.429
SEP	0.00000				0.000	-0.030	23 8	36.F	34.F	-17.036	546.	2.429
OCT	0.00000				0.000	-0.265	21 8	30.F	29.F	-43.523	596.	2.429
NOV	0.00000				0.000	-1.979	18 8	34.F	34.F	-58.601	522.	2.429
DEC	0.00000				0.000	-3.595	26 8	15.F	15.F	-66.874	572.	2.429
TOTAL	0.000					-15.804					6849.	
MAX					0.000					-71.992		2.429

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-F ZONE DEMAND SUMMARY IN

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1 FOR SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

---DEMANDS--- --BASEBOARDS-- --TEMPERATURES-- --LOADS NOT MET--

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.32026	-3.393	0.00000	0.000	76.3	55.8	0	0
FEB	0.31210	-2.703	0.00000	0.000	76.1	55.8	0	0
MAR	0.62230	-1.443	0.00000	0.000	75.4	55.9	0	0
APR	1.70057	-0.336	0.00000	0.000	77.7	67.0	7	0
MAY	2.46513	-0.006	0.00000	0.000	77.9	70.9	0	0
JUN	3.35010	0.000	0.00000	0.000	78.3	75.1	0	0
JUL	5.25626	0.000	0.00000	0.000	79.1	76.7	0	0
AUG	4.63841	0.000	0.00000	0.000	78.9	76.5	0	0
SEP	3.21619	-0.015	0.00000	0.000	78.6	70.7	0	0
OCT	1.96739	-0.144	0.00000	0.000	77.9	70.3	0	0
NOV	0.62700	-1.258	0.00000	0.000	77.9	55.9	0	0
DEC	0.16774	-2.819	0.00000	0.000	75.2	55.8	0	0

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-0 TEMPERATURE SCATTER PLOT

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1 FOR SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	88	90	96	100	106	119	132	141	144	139	15	0	0	0	0	0	0	1170
70-75	0	0	0	0	0	0	0	38	162	156	152	145	132	119	110	107	112	110	0	0	0	0	0	0	1343
65-70	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	0	0	0	0	0	7
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

*** ** **

MMDDHH	GLOBAL	GLOBAL	SPACE1-1	SPACE1-1	SPACE1-1	SYST-1	SYST-1	SYST-1
	DRY BULB TEMP F	WET BULB TEMP F	THERMOST SETPOINT F	ZONE TEMP F	EXTRACTN RATE BTU/HR	CLG COIL AIR TEMP F	RETURN AIR TEMP F	TOT CLG COIL PWR BTU/HR
	----(8)	----(7)	----(7)	----(6)	----(8)	----(2)	----(4)	----(6)
8 5 1	77.2	67.0	-999.0	96.6	0.	0.0	0.0	0.
8 5 2	75.4	66.1	-999.0	96.0	0.	0.0	0.0	0.
8 5 3	73.9	65.4	-999.0	95.5	0.	0.0	0.0	0.
8 5 4	72.7	64.7	-999.0	95.0	0.	0.0	0.0	0.
8 5 5	71.8	64.2	-999.0	94.5	0.	0.0	0.0	0.
8 5 6	71.2	63.9	78.0	80.9	48692.	58.5	87.5	178437.
8 5 7	71.0	63.8	78.0	80.1	36040.	58.3	85.0	166582.
8 5 8	71.8	64.0	78.0	79.7	35092.	58.2	82.6	160428.
8 5 9	73.9	64.8	78.0	79.3	34929.	58.0	82.7	165387.
8 510	77.2	66.2	78.0	79.0	34343.	57.9	83.4	173594.
8 511	81.0	67.8	78.0	79.0	33277.	58.0	84.2	180833.
8 512	84.8	69.5	78.0	78.9	32766.	58.0	85.2	187542.
8 513	88.1	71.1	78.0	79.1	33921.	57.9	86.0	201795.
8 514	90.2	72.2	78.0	79.7	34452.	58.0	86.7	211104.
8 515	91.0	72.7	78.0	79.9	35136.	58.0	87.2	217218.
8 516	90.8	72.8	78.0	79.9	35286.	58.0	87.3	218057.
8 517	90.2	72.6	78.0	79.7	35052.	58.0	86.9	213977.
8 518	89.3	72.3	-999.0	87.8	0.	0.0	0.0	0.
8 519	88.1	71.8	-999.0	88.8	0.	0.0	0.0	0.
8 520	86.6	71.2	-999.0	89.2	0.	0.0	0.0	0.
8 521	84.8	70.4	-999.0	88.9	0.	0.0	0.0	0.
8 522	83.0	69.6	-999.0	88.6	0.	0.0	0.0	0.
8 523	81.0	68.8	-999.0	88.3	0.	0.0	0.0	0.
8 524	79.0	67.9	-999.0	88.0	0.	0.0	0.0	0.
DAILY SUMMARY (AUG 5)								
MN	71.0	63.8	-999.0	78.9	0.	0.0	0.0	0.
MX	91.0	72.8	78.0	96.6	48692.	58.5	87.5	218057.
SM	1944.0	1640.8	-11052.0	2052.5	428985.	696.7	1024.7	2274955.
AV	81.0	68.4	-460.5	85.5	17874.	29.0	42.7	94790.
MONTHLY SUMMARY (AUG)								
MN	71.0	63.8	-999.0	78.9	0.	0.0	0.0	0.
MX	91.0	72.8	78.0	96.6	48692.	58.5	87.5	218057.
SM	1944.0	1640.8	-11052.0	2052.5	428985.	696.7	1024.7	2274955.
AV	81.0	68.4	-460.5	85.5	17874.	29.0	42.7	94790.
YEARLY SUMMARY								
MN	71.0	63.8	-999.0	78.9	0.	0.0	0.0	0.
MX	91.0	72.8	78.0	96.6	48692.	58.5	87.5	218057.
SM	1944.0	1640.8	-11052.0	2052.5	428985.	696.7	1024.7	2274955.
AV	81.0	68.4	-460.5	85.5	17874.	29.0	42.7	94790.

	GLOBAL	GLOBAL	SPACE1-1	SPACE1-1	SPACE1-1	SYST-1	SYST-1	SYST-1
	DRY BULB TEMP F	WET BULB TEMP F	THERMOST SETPOINT F	ZONE TEMP F	EXTRACTN RATE BTU/HR	CLG COIL AIR TEMP F	RETURN AIR TEMP F	TOT CLG COIL PWR BTU/HR
	----(8)	----(7)	----(7)	----(6)	----(8)	----(2)	----(4)	----(6)
8 5 1	61.0	59.0	-999.0	80.5	0.	0.0	0.0	0.
8 5 2	59.0	58.0	-999.0	80.1	0.	0.0	0.0	0.
8 5 3	57.0	56.0	-999.0	79.6	0.	0.0	0.0	0.
8 5 4	57.0	56.0	-999.0	79.2	0.	0.0	0.0	0.
8 5 5	55.0	54.0	-999.0	78.7	0.	0.0	0.0	0.
8 5 6	52.0	50.0	-999.0	78.4	0.	0.0	0.0	0.
8 5 7	57.0	54.0	-999.0	78.3	0.	0.0	0.0	0.
8 5 8	62.0	58.0	78.0	77.1	11085.	58.5	71.4	11565.
8 5 9	68.0	61.0	78.0	77.1	12717.	57.3	74.8	52275.
8 510	72.0	63.0	78.0	77.3	14571.	57.9	77.4	70249.
8 511	74.0	64.0	78.0	77.5	16788.	57.8	80.4	86804.
8 512	76.0	63.0	78.0	77.7	18073.	57.8	83.1	92040.
8 513	77.0	63.0	78.0	77.9	21113.	57.6	84.9	108793.
8 514	78.0	63.0	78.0	78.2	23954.	57.7	85.7	120845.
8 515	77.0	62.0	78.0	78.3	25580.	57.8	86.0	124485.
8 516	76.0	62.0	78.0	78.3	25080.	57.9	85.9	119886.
8 517	77.0	62.0	78.0	78.2	23640.	57.9	85.2	114577.
8 518	76.0	61.0	-999.0	83.2	0.	0.0	0.0	0.
8 519	75.0	61.0	-999.0	83.7	0.	0.0	0.0	0.
8 520	72.0	59.0	-999.0	83.7	0.	0.0	0.0	0.
8 521	69.0	58.0	-999.0	83.2	0.	0.0	0.0	0.
8 522	68.0	57.0	-999.0	82.8	0.	0.0	0.0	0.
8 523	67.0	58.0	-999.0	82.5	0.	0.0	0.0	0.
8 524	66.0	57.0	-999.0	82.0	0.	0.0	0.0	0.
DAILY SUMMARY (AUG 5)								
MN	52.0	50.0	-999.0	77.1	0.	0.0	0.0	0.
MX	78.0	64.0	78.0	83.7	25580.	58.5	86.0	124485.
SM	1628.0	1419.0	-13206.0	1913.5	192601.	578.1	814.8	901518.
AV	67.8	59.1	-550.2	79.7	8025.	24.1	33.9	37563.
MONTHLY SUMMARY (AUG)								
MN	52.0	50.0	-999.0	77.1	0.	0.0	0.0	0.
MX	78.0	64.0	78.0	83.7	25580.	58.5	86.0	124485.
SM	1628.0	1419.0	-13206.0	1913.5	192601.	578.1	814.8	901518.
AV	67.8	59.1	-550.2	79.7	8025.	24.1	33.9	37563.
YEARLY SUMMARY								
MN	52.0	50.0	-999.0	77.1	0.	0.0	0.0	0.
MX	78.0	64.0	78.0	83.7	25580.	58.5	86.0	124485.
SM	1628.0	1419.0	-13206.0	1913.5	192601.	578.1	814.8	901518.
AV	67.8	59.1	-550.2	79.7	8025.	24.1	33.9	37563.

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-A EQUIPMENT SIZES

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	0.457	1 1										
HEM-REC-CHLR	0.222	1 1										

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-B COST REFERENCE DATA (USED FOR DEFAULT COSTS)

DIVIDE INTO ZONES: ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	SIZE (MBTU)	UNIT COST (K\$)	INSTALD COST FACTOR	CONSUM- ABLES (\$/HR)	MAINTA- NANCE (HRS/YR)	EQPMT LIFE (HRS)	HOURS ALREADY USED	HRS TO MINOR OVHAUL	MINOR OVHAUL COST (\$)	HRS TO MAJOR OVHAUL	MAJOR OVHAUL COST (\$)
HW-BOILER	40.000	300.000	1.400	0.000	8.0	220000.	0.	10000.	2000.	50000.	25000.
HEM-REC-CHLR	12.000	100.000	1.200	0.000	16.0	100000.	0.	20000.	5000.	50000.	15000.

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-C EQUIPMENT COSTS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	SIZE (MBTU)	UNIT COST (K\$)	INSTALD COST FACTOR	CONSUM- ABLES (\$/HR)	MAINTA- NANCE (HRS/YR)	EQPMT LIFE (HRS)	HOURS ALREADY USED	HRS TO MINOR OVHAUL	MINOR OVHAUL COST (\$)	HRS TO MAJOR OVHAUL	MAJOR OVHAUL COST (\$)
MW-BOILER	0.457	15.003	1.400	0.000	3.3	140687.	0.	4089.	100.	20447.	1250.
HEM-REC-CHLR	0.222	6.911	1.200	0.000	7.2	67112.	0.	9008.	346.	22520.	1037.

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PV-E EQUIPMENT LOAD RATIOS

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	PART LOAD RATIOS			ELECTRIC INPUT TO NOMINAL CAPACITY RATIO (BTU/BTU)
	MINIMUM	MAXIMUM	OPTIMUM	
HW-BOILER	0.2500	1.2000	1.0000	0.0220
HEM-RBC-CHLR	0.2500	1.0000	1.0000	0.2740

N A M E	COEFF 1	COEFF 2	COEFF 3	COEFF 4	COEFF 5	COEFF 6
STM-BOILER-HIR-F	0.082597	0.996764	-0.079361	0.000000	0.000000	0.000000
HW-BOILER-HIR-FP	0.082597	0.996764	-0.079361	0.000000	0.000000	0.000000
FURNACE-HIR-FPLR	0.018610	1.094209	-0.112819	0.000000	0.000000	0.000000
DHW-HIR-FPLR	0.021826	0.977630	0.000543	0.000000	0.000000	0.000000
OPEN-CENT-CAP-FT	-1.742040	0.029292	-0.000067	0.048054	-0.000291	-0.000106
OPEN-REC-CAP-FT	-4.161461	0.207050	-0.001931	0.004723	-0.000040	-0.000087
HERM-CENT-CAP-FT	-1.742040	0.029292	-0.000067	0.048054	-0.000291	-0.000106
HERM-REC-CAP-FT	-4.161461	0.207050	-0.001931	0.004723	-0.000040	-0.000087
OPEN-CENT-EIR-FT	3.117500	-0.109236	0.001389	0.003750	0.000150	-0.000375
OPEN-REC-EIR-FT	4.720965	-0.187504	0.002192	0.009209	0.000098	-0.000322
HERM-CENT-EIR-FT	3.117500	-0.109236	0.001389	0.003750	0.000150	-0.000375
HERM-REC-EIR-FT	4.720965	-0.187504	0.002192	0.009209	0.000098	-0.000322
OPEN-CENT-EIR-FP	0.222903	0.313387	0.463710	0.000000	0.000000	0.000000
OPEN-REC-EIR-FPL	0.088065	1.137742	-0.225806	0.000000	0.000000	0.000000
HERM-CENT-EIR-FP	0.222903	0.313387	0.463710	0.000000	0.000000	0.000000
HERM-REC-EIR-FPL	0.088065	1.137742	-0.225806	0.000000	0.000000	0.000000
DBUN-CAP-FT	-1.742040	0.029292	-0.000067	0.048054	-0.000291	-0.000106
DBUN-EIR-FT	3.117500	-0.109236	0.001389	0.003750	0.000150	-0.000375
DBUN-EIR-FPLR	0.349032	0.263871	0.387097	0.000000	0.000000	0.000000
DBUN-CAP-FTRISE	1.000000	-0.005650	-0.000305	0.000000	0.000000	0.000000
DBUN-EIR-FTRISE	1.000000	0.012250	0.000175	0.000000	0.000000	0.000000
ABSOR1-CAP-FT	0.723412	0.079006	-0.000897	-0.025285	-0.000048	0.000276
ABSOR2-CAP-FT	-0.816039	-0.038707	0.000450	0.071491	-0.000636	0.000312
ABSORG-CAP-FT	1.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSOR1-CAP-FTS	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSOR2-CAP-FTS	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSOR1-HIR-FT	0.652273	0.000000	0.000000	-0.000545	0.000055	0.000000
ABSOR2-HIR-FT	1.658750	0.000000	0.000000	-0.029000	0.000250	0.000000
ABSORG-HIR-FT	4.428713	-0.132986	0.001253	0.000000	0.000000	0.000000
ABSOR1-HIR-FPLR	0.087773	0.744921	0.167306	0.000000	0.000000	0.000000
ABSOR2-HIR-FPLR	0.135512	0.617981	0.246513	0.000000	0.000000	0.000000
ABSORG-HIR-FPLR	0.135512	0.617981	0.246513	0.000000	0.000000	0.000000
ABSOR1-HIR-FPLR	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
TWR-GPM-FRA	-2.228889	0.166795	-0.014102	0.032223	0.185602	0.242519
TWR-GPM-FWB	0.605314	-0.035545	0.008041	-0.028603	0.000250	0.004909
TWR-FAN-FPLR	0.331629	-0.885676	0.605565	0.948482	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
DIESEL-I/O-FPLR	0.107000	0.893000	0.000000	0.000000	0.000000	0.000000
DIESEL-EXH-FPLR	0.024516	0.332387	0.643097	0.000000	0.000000	0.000000
DIESEL-JCLB-FPLR	0.287936	1.020452	-0.308387	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
GTURB-I/O-FPLR	0.442979	0.397400	0.156962	0.000000	0.000000	0.000000
GTURB-EXH-FPLR	0.295626	0.493019	0.211355	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
GTURB-CAP-FT	1.240000	-0.004100	0.000000	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
STURB-ENTH-FPLX	38.792358	-0.211386	0.000529	1.020087	0.000917	-0.003499
STURB-I/O-FPLR	0.488308	0.994154	-0.482462	0.000000	0.000000	0.000000

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-G EQUIPMENT QUADRATICS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

(CONTINUED)

N A M E	COEFF 1	COEFF 2	COEFF 3	COEFF 4	COEFF 5	COEFF 6
TC-CHLR-CAP-FT	-0.351443	0.056583	-0.000054	-0.045625	-0.000043	-0.000012
ABSORG-HIR1-FTI	0.861737	-0.007089	0.000103	0.000000	0.000000	0.000000
ABSORG-HIR2-FTI	0.814450	0.000824	0.000013	0.000000	0.000000	0.000000
ABSORG-QCOND-FTI	0.640000	-0.001300	0.000000	0.000000	0.000000	0.000000
ABSG-HCAP-FQC	0.863599	-1.304953	0.441353	0.000000	0.000000	0.000000
ENG-CH-CAP-FT	0.573597	0.018680	0.000000	-0.004653	0.000000	0.000000
ENG-CH-COP-FPLR1	1.143357	0.022890	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FPLR2	1.388614	-0.388614	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FT	1.236238	0.016892	0.000000	-0.011524	0.000000	0.000000
ENG-CH-HREJ-FPLR	1.052699	-0.052699	0.000000	0.000000	0.000000	0.000000
ENG-CH-HREJ-FT	0.705841	0.003461	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FPLRS	0.380200	2.360900	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FTS	1.088152	0.014106	0.000000	-0.008339	0.000000	0.000000

MONTH	S I T E E N E R G Y												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	33.5	0.0	3.9	0.0	0.0	0.0	0.0	51.6	0.8	0.0	51.6	64.9	91.7
FEB	26.0	0.0	3.3	0.0	0.0	0.0	0.0	40.2	0.7	0.0	40.2	51.5	74.3
MAR	15.9	0.0	3.4	0.0	0.0	0.0	0.0	25.0	0.5	0.0	25.0	36.5	59.6
APR	4.0	1.8	3.4	0.0	0.0	0.0	0.3	6.4	0.1	0.0	6.4	18.0	41.4
MAY	0.5	5.6	3.9	0.0	0.0	0.0	0.7	0.9	0.0	0.0	0.9	14.0	40.4
JUN	0.0	15.4	4.9	0.0	0.0	0.0	1.9	0.0	0.0	0.0	0.0	16.8	50.5
JUL	0.0	29.8	7.0	0.0	0.0	0.0	3.2	0.0	0.0	0.0	0.0	23.9	71.6
AUG	0.0	24.7	6.4	0.0	0.0	0.0	2.8	0.0	0.0	0.0	0.0	21.7	65.0
SEP	0.3	9.9	4.2	0.0	0.0	0.0	1.3	0.4	0.0	0.0	0.4	14.8	43.4
OCT	2.5	2.7	3.5	0.0	0.0	0.0	0.4	3.9	0.1	0.0	3.9	15.9	40.0
NOV	13.6	0.4	3.1	0.0	0.0	0.0	0.1	21.3	0.4	0.0	21.3	31.9	53.0
DEC	26.6	0.0	3.7	0.0	0.0	0.0	0.0	41.5	0.7	0.0	41.5	53.9	78.9
TOTAL	122.8	90.5	50.6	0.0	0.0	0.0	10.7	191.1	3.4	0.0	191.1	363.9	709.7

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413./KWH	METER-1 100000./THERMS
JAN			
	ENERGY CONSUMPTION (UNITS/MO)	3918.1	515.5
	PEAK DEMAND (UNITS/HR OR DAY)	16.2	5.6
	PEAK DAY/HR	7/ 9	7/ 8
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	3333.6	401.5
	PEAK DEMAND (UNITS/HR OR DAY)	16.1	5.3
	PEAK DAY/HR	4/ 9	4/ 8
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	3377.5	250.2
	PEAK DEMAND (UNITS/HR OR DAY)	15.8	4.9
	PEAK DAY/HR	25/ 9	25/ 8
APR			
	ENERGY CONSUMPTION (UNITS/MO)	3417.1	63.8
	PEAK DEMAND (UNITS/HR OR DAY)	22.2	3.4
	PEAK DAY/HR	29/15	8/ 8
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	3857.1	8.8
	PEAK DEMAND (UNITS/HR OR DAY)	28.4	0.7
	PEAK DAY/HR	21/14	9/ 9
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	4933.9	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	33.8	0.0
	PEAK DAY/HR	20/16	0/ 0
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	6989.9	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	39.2	0.0
	PEAK DAY/HR	8/15	0/ 0
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	6351.4	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	36.0	0.0
	PEAK DAY/HR	19/16	0/ 0
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	4196.0	4.4
	PEAK DEMAND (UNITS/HR OR DAY)	30.7	1.7
	PEAK DAY/HR	11/15	23/ 8
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	3519.4	39.2
	PEAK DEMAND (UNITS/HR OR DAY)	19.8	3.6
	PEAK DAY/HR	31/15	21/ 8
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	3098.8	212.8
	PEAK DEMAND (UNITS/HR OR DAY)	21.1	4.3
	PEAK DAY/HR	1/15	25/ 8
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	3651.2	414.6
	PEAK DEMAND (UNITS/HR OR DAY)	15.8	5.1
	PEAK DAY/HR	9/11	26/ 8
TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	50644.1	1910.8
	PEAK DEMAND (UNITS/HR OR DAY)	39.2	5.6

EQUIPMENT	HOURS AT PERCENT PART LOAD RATIO												TOTAL HOURS	ANNUAL LOAD (MBTU)	FALSE LOAD (MBTU)	ELEC USED (KWH)	THERMAL USED (MBTU)
	0 --	10 --	20 --	30 --	40 --	50 --	60 --	70 --	80 --	90 --	100 -	110+					
HW-BOILER	482	507	309	99	50	23	13	13	5	3	0	1504	122.8	0.0	2636.	191.1	
	482	507	309	99	50	23	13	13	5	3	0						
HERM-REC-CHLR	194	164	136	178	180	126	80	40	25	9	0	1132	90.5	0.0	9851.	0.0	
	194	164	136	178	180	126	80	40	25	9	0						

HOT LOOP CIRCULATION PUMP ELECTRICAL USE = 743. KWH
 COLD LOOP CIRCULATION PUMP ELECTRICAL USE = 805. KWH
 CONDENSER WATER PUMP ELECTRICAL USE = 0. KWH
 TOWER OR CONDENSER FAN ELECTRICAL USE = 1661. KWH

NOTES TO TABLE

- 1) THE FIRST PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE HOURLY OPERATING CAPACITY
- 2) THE SECOND PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE TOTAL INSTALLED CAPACITY

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PS-D PLANT LOADS SATISFIED

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	122.8	100.0
LOAD SATISFIED	122.8	100.0
TOTAL LOAD ON PLANT	122.8	
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HEM-REC-CHLR	90.5	100.0
LOAD SATISFIED	90.5	100.0
TOTAL LOAD ON PLANT	90.5	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	50644.1	100.0
LOAD SATISFIED	50644.1	100.0
TOTAL LOAD ON PLANT	50642.9	

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PS-D PLANT LOADS SATISFIED

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	122.8	122.8	0.000	0.000	0
COOLING LOADS	90.5	90.5	0.000	0.000	0
ELECTRICAL LOADS	172.8	172.8	0.000	0.000	0

ELECTRICAL END-USES IN KWH

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
AREA LIGHTS	1904.	1656.	1830.	1895.	1904.	1748.	1904.	1904.	1748.	1904.	1674.	1830.	21902.
MAX KW	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
DAY/HR	2/11	1/11	1/11	1/11	1/11	3/11	1/11	1/11	3/11	1/11	1/11	2/11	
MISC EQUIPMT	917.	795.	879.	915.	917.	838.	917.	917.	838.	917.	800.	879.	10528.
MAX KW	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0
DAY/HR	2/ 9	1/ 9	1/ 9	1/ 9	1/ 9	3/ 9	1/ 9	1/ 9	3/ 9	1/ 9	1/ 9	2/ 9	
SPACE HEAT	690.	542.	355.	93.	14.	0.	0.	0.	7.	58.	301.	575.	2636.
MAX KW	2.9	2.9	2.9	2.9	1.1	0.0	0.0	0.0	2.6	2.9	2.9	2.9	2.9
DAY/HR	1/ 1	1/ 8	1/ 8	1/ 8	9/ 9	0/ 0	0/ 0	0/ 0	23/ 8	15/ 8	4/ 8	2/ 8	
SPACE COOL	0.	0.	0.	178.	522.	1419.	2612.	2221.	928.	270.	41.	0.	8189.
MAX KW	0.0	0.0	0.0	6.7	12.5	16.2	18.7	16.5	13.0	5.8	5.9	0.0	18.7
DAY/HR	0/ 0	0/ 0	0/ 0	29/18	21/14	20/16	8/16	19/16	11/15	4/17	1/16	0/ 0	
HEAT REJECT	0.	0.	0.	55.	135.	317.	428.	416.	213.	85.	13.	0.	1661.
MAX KW	0.0	0.0	0.0	1.8	1.8	1.8	1.8	1.8	1.8	1.7	1.8	0.0	1.8
DAY/HR	0/ 0	0/ 0	0/ 0	26/15	16/17	3/12	1/ 9	1/11	4/18	4/17	1/16	0/ 0	
PUMPS & MISC	151.	126.	119.	99.	101.	144.	171.	169.	117.	113.	100.	136.	1547.
MAX KW	0.5	0.5	0.5	0.7	0.7	0.7	0.7	0.7	0.7	1.2	0.7	0.5	1.2
DAY/HR	1/ 1	1/ 8	1/ 8	1/13	1/10	3/ 9	1/ 8	1/ 8	3/12	16/13	1/ 9	1/ 9	
VENT FANS	256.	215.	195.	182.	263.	469.	958.	724.	346.	173.	171.	231.	4181.
MAX KW	4.0	3.9	3.3	2.2	3.0	4.2	7.3	6.0	4.1	1.8	3.0	3.5	7.3
DAY/HR	7/ 8	4/ 8	25/ 8	1/ 8	21/16	20/16	15/ 9	19/16	9/16	21/ 8	18/ 8	26/ 8	
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
TOTAL KWH	3918.	3334.	3377.	3417.	3857.	4934.	6990.	6351.	4196.	3519.	3099.	3651.	50644.

FUEL END-USES IN MBTU

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
SPACE HEAT	51.6	40.2	25.0	6.4	0.9	0.0	0.0	0.0	0.4	3.9	21.3	41.5	191.1
MAX MBTU	0.558	0.535	0.490	0.344	0.071	0.000	0.000	0.000	0.167	0.358	0.433	0.507	0.558
DAY/HR	7/ 8	4/ 8	25/ 8	8/ 8	9/ 9	0/ 0	0/ 0	0/ 0	23/ 8	21/ 8	25/ 8	26/ 8	
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
TOTAL MBTU	51.6	40.2	25.0	6.4	0.9	0.0	0.0	0.0	0.4	3.9	21.3	41.5	191.1

ENERGY-RESOURCE: ELECTRICITY
 UNITS: KWH

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
PEAK DEMAND:	16.2	16.1	15.8	22.2	28.4	33.8	39.2	36.0	30.7	19.8	21.1	15.8
DAY/HR:	7/ 9	4/ 9	25/ 9	29/15	21/14	20/16	8/15	19/16	11/15	31/15	1/15	9/11
BREAKDOWN												
AREA LIGHTS:	6.75	6.75	6.75	7.50	6.75	7.50	7.50	7.50	7.50	7.50	7.50	7.50
(%):	41.76	41.81	42.68	33.83	23.78	22.16	19.14	20.84	24.45	37.84	35.62	47.50
MISC EQUIPMT:	4.00	4.00	4.00	4.00	4.00	3.50	4.00	3.50	4.00	4.00	4.00	4.00
(%):	24.75	24.78	25.29	18.04	14.09	10.34	10.21	9.73	13.04	20.18	19.00	25.34
SPACE HEAT:	2.95	2.95	2.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.95
(%):	18.24	18.27	18.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	18.68
SPACE COOL:	0.00	0.00	0.00	6.34	12.51	16.16	18.33	16.46	13.02	5.16	5.59	0.00
(%):	0.00	0.00	0.00	28.58	44.05	47.73	46.78	45.74	42.46	26.03	26.53	0.00
HEAT REJECT:	0.00	0.00	0.00	1.82	1.82	1.82	1.82	1.82	1.82	1.56	1.74	0.00
(%):	0.00	0.00	0.00	8.23	6.43	5.39	4.66	5.07	5.95	7.89	8.28	0.00
PUMPS & MISC:	0.49	0.49	0.49	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.49
(%):	3.05	3.06	3.12	3.21	2.50	2.10	1.81	1.98	2.32	3.59	3.38	3.13
VENT FANS:	1.97	1.95	1.62	1.80	2.60	4.16	6.82	5.99	3.61	0.89	1.52	0.85
(%):	12.19	12.08	10.25	8.11	9.15	12.28	17.41	16.64	11.78	4.47	7.20	5.35

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PS-F ENERGY-RESOURCE PEAK BREAKDOWN BY END-USE

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

(CONTINUED)

ENERGY-RESOURCE: NATURAL-GAS
 UNITS: THERMS

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
PEAK DEMAND:	5.6	5.3	4.9	3.4	0.7	0.0	0.0	0.0	1.7	3.6	4.3	5.1
DAY/HR:	7/ 8	4/ 8	25/ 8	8/ 8	9/ 9	0/ 0	0/ 0	0/ 0	23/ 8	21/ 8	25/ 8	26/ 8
BREAKDOWN												
AREA LIGHTS:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
MISC EQUIPMT:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SPACE HEAT:	5.58	5.35	4.90	3.44	0.71	0.00	0.00	0.00	1.67	3.58	4.33	5.07
(%):	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00	100.00	100.00	100.00	100.00
SPACE COOL:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HEAT REJECT:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PUMPS & MISC:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
VENT FANS:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

TOTAL HOURS AT HOURLY DEMAND AND TIME OF DAY

HOURLY	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
	40	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	2
	37	0	0	0	0	0	0	0	0	2	1	2	2	1	3	6	5	3	3	0	0	0	0	0	0	28
	34	0	0	0	0	0	0	0	0	0	2	5	4	2	6	8	9	9	6	0	0	0	0	0	0	51
	31	0	0	0	0	0	0	0	0	4	4	4	5	7	13	23	24	14	13	0	0	0	0	0	0	111
D	28	0	0	0	0	0	0	0	0	8	11	14	20	15	26	26	27	28	31	0	0	0	0	0	0	206
E	25	0	0	0	0	0	0	0	2	13	23	33	30	30	22	16	14	22	22	0	0	0	0	0	0	227
M K	21	0	0	0	0	0	0	0	2	23	21	11	10	17	12	9	8	11	10	0	0	0	0	0	0	134
A W	18	0	0	0	0	0	0	0	3	19	13	32	17	14	14	14	15	11	9	0	0	0	0	0	0	161
N	15	0	0	0	0	0	0	0	8	146	151	136	138	99	110	128	111	62	65	0	0	0	0	0	0	1154
D	12	0	0	0	0	0	0	0	9	37	26	15	26	67	46	21	38	92	93	0	0	0	0	0	0	470
	9	0	0	0	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	41
	6	9	9	14	10	13	11	15	104	5	4	5	5	4	3	4	5	4	4	260	5	6	8	8	8	523
	3	356	356	351	355	352	354	350	196	108	109	108	108	109	110	109	108	109	109	105	360	359	357	357	357	5652
PERCENT TOTAL DEMAND	0.4	0.4	0.4	0.4	0.4	0.4	0.5	2.5	8.1	8.4	8.8	8.8	8.3	8.9	9.5	9.3	8.8	8.7	3.1	1.6	0.9	0.4	0.4	0.4	0.4	

PEAK ELECTRICAL LOAD BREAKDOWN

SOURCE	KW	PCT
SYSTEMS LOAD	18.322	46.8
CIRCULATION PUMPS	0.711	1.8
HERM-REC-CHLR	20.155	51.4
TOTAL	39.188	

SMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PS-H EQUIPMENT USE STATISTICS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	AVG OPER RATIO	MAX LOAD (MBTU)	MON		-----		-----		-----		-----	
			DAY	HR	SIZE (MBTU)	OPER HRS	SIZE (MBTU)	OPER HRS	SIZE (MBTU)	OPER HRS	SIZE (MBTU)	OPER HRS
HW-BOILER	0.178	0.444	1	7 8	0.457	1504						
HEM-REC-CHLR	0.359	0.219	7	8 16	0.222	1132						

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PS-I EQUIPMENT LIFE CYCLE COSTS

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT TOTALS

HW-BOILER	23.3		
NOMINAL SIZE (MBTU)		0.457	
NUMBER INSTALLED		1	
FIRST COST (K\$)	21.0	21.0	
ANNUAL COST (K\$)	1.2	1.2	
CYCLICAL COST (K\$)	1.1	1.1	
-----TOTAL----- (K\$)		23.3	
HERM-REC-CHLR	11.7		
NOMINAL SIZE (MBTU)		0.222	
NUMBER INSTALLED		1	
FIRST COST (K\$)	8.3	8.3	
ANNUAL COST (K\$)	2.5	2.5	
CYCLICAL COST (K\$)	0.9	0.9	
-----TOTAL----- (K\$)		11.7	

EQUIPMENT TOTAL	35.0		

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		
AREA LIGHTS	74.7	0.0
MISC EQUIPMT	35.9	0.0
SPACE HEAT	9.0	191.1
SPACE COOL	27.9	0.0
HEAT REJECT	5.7	0.0
PUMPS & MISC	5.3	0.0
VENT FANS	14.3	0.0
TOTAL	172.8	191.1

TOTAL SITE ENERGY	363.93 MBTU	72.8 KBTU/SQFT-YR GROSS-AREA	72.8 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	709.67 MBTU	141.9 KBTU/SQFT-YR GROSS-AREA	141.9 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.7
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

ENERGY TYPE: SITE UNITS:	ELECTRICITY KWH	NATURAL-GAS THERMS
CATEGORY OF USE -----		
AREA LIGHTS	21902.	0.
MISC EQUIPMT	10527.	0.
SPACE HEAT	2636.	1911.
SPACE COOL	8189.	0.
HEAT REJECT	1661.	0.
PUMPS & MISC	1547.	0.
VENT FANS	4181.	0.
	-----	-----
TOTAL	50644.	1911.

TOTAL ELECTRICITY	50644. KWH	10.129 KWH	/SQFT-YR GROSS-AREA	10.129 KWH	/SQFT-YR NET-AREA
TOTAL NATURAL-GAS	1911. THERMS	0.382 THERMS	/SQFT-YR GROSS-AREA	0.382 THERMS	/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.7
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

MMDDHH	HERM-REC -CHLR LOAD BTU/HR	HERM-REC -CHLR OPER PT LD RATIO FRAC.OR MULT.	HERM-REC -CHLR ADJUSTED EIR BTU/BTU
	---- (1)	---- (10)	---- (16)
8 5 1	0.	0.000	0.000
8 5 2	0.	0.000	0.000
8 5 3	0.	0.000	0.000
8 5 4	0.	0.000	0.000
8 5 5	0.	0.000	0.000
8 5 6	0.	0.000	0.000
8 5 7	0.	0.000	0.000
8 5 8	15929.	0.250	0.081
8 5 9	56639.	0.250	0.083
8 5 10	74613.	0.318	0.102
8 5 11	91168.	0.390	0.121
8 5 12	96404.	0.416	0.130
8 5 13	113157.	0.488	0.147
8 5 14	125208.	0.540	0.161
8 5 15	128849.	0.552	0.161
8 5 16	124249.	0.531	0.155
8 5 17	118941.	0.511	0.153
8 5 18	0.	0.000	0.000
8 5 19	0.	0.000	0.000
8 5 20	0.	0.000	0.000
8 5 21	0.	0.000	0.000
8 5 22	0.	0.000	0.000
8 5 23	0.	0.000	0.000
8 5 24	0.	0.000	0.000
DAILY SUMMARY (AUG 5)			
MN	0.	0.000	0.000
MX	128849.	0.552	0.161
SM	945157.	4.246	1.293
AV	39382.	0.177	0.054
MONTHLY SUMMARY (AUG)			
MN	0.	0.000	0.000
MX	128849.	0.552	0.161
SM	945157.	4.246	1.293
AV	39382.	0.177	0.054
YEARLY SUMMARY			
MN	0.	0.000	0.000
MX	128849.	0.552	0.161
SM	945157.	4.246	1.293
AV	39382.	0.177	0.054

LIFE-CYCLE COSTING PARAMETERS

DISCOUNT RATE (PERCENT)	LABOR INFLATION RATE (PERCENT)	MATERIALS INFLATION RATE (PERCENT)	PROJECT LIFE (YRS)
5.0	0.0	0.0	25.0

BUILDING COMPONENT COST INPUT DATA (CURRENT DOLLARS)

COST NAME	NUMBER OF UNITS	UNIT NAME	LIFE (YRS)	UNIT	UNIT	UNIT	UNIT	UNIT	UNIT
				FIRST COST (\$)	INSTALL -ATION COST (\$)	ANNUAL MAINT COST (\$)	MINOR OVERHAUL COST (\$)	MINOR OVERHAUL INTERVAL (YRS)	MAJOR OVERHAUL COST (\$)

NO BUILDING COMPONENT COSTS SPECIFIED

YEAR	ENERGY (\$)			OPERATIONS (\$)				TOTAL SAVINGS-ENERGY PLUS OPRNS	
	ENERGY COST	ENERGY COST	ENERGY COST	OPRNS COST	OPRNS COST -- THIS RUN				
	BASELINE	THIS RUN	SAVINGS	BASELINE	PLANT	BUILDING	TOTAL		
1	0.	4369.	-4369.	0.	249.	0.	249.	-249.	-4619.
2	0.	4431.	-4431.	0.	238.	0.	238.	-238.	-4668.
3	0.	4493.	-4493.	0.	314.	0.	314.	-314.	-4807.
4	0.	4557.	-4557.	0.	216.	0.	216.	-216.	-4772.
5	0.	4622.	-4622.	0.	205.	0.	205.	-205.	-4827.
6	0.	4688.	-4688.	0.	272.	0.	272.	-272.	-4960.
7	0.	4756.	-4756.	0.	186.	0.	186.	-186.	-4942.
8	0.	4824.	-4824.	0.	412.	0.	412.	-412.	-5236.
9	0.	4894.	-4894.	0.	236.	0.	236.	-236.	-5130.
10	0.	4966.	-4966.	0.	161.	0.	161.	-161.	-5127.
11	0.	5038.	-5038.	0.	212.	0.	212.	-212.	-5250.
12	0.	5113.	-5113.	0.	146.	0.	146.	-146.	-5258.
13	0.	5188.	-5188.	0.	139.	0.	139.	-139.	-5327.
14	0.	5265.	-5265.	0.	828.	0.	828.	-828.	-6093.
15	0.	5344.	-5344.	0.	126.	0.	126.	-126.	-5470.
16	0.	5424.	-5424.	0.	279.	0.	279.	-279.	-5702.
17	0.	5505.	-5505.	0.	159.	0.	159.	-159.	-5664.
18	0.	5588.	-5588.	0.	109.	0.	109.	-109.	-5697.
19	0.	5673.	-5673.	0.	104.	0.	104.	-104.	-5776.
20	0.	5759.	-5759.	0.	531.	0.	531.	-531.	-6290.
21	0.	5847.	-5847.	0.	94.	0.	94.	-94.	-5941.
22	0.	5936.	-5936.	0.	124.	0.	124.	-124.	-6060.
23	0.	6027.	-6027.	0.	85.	0.	85.	-85.	-6113.
24	0.	6120.	-6120.	0.	189.	0.	189.	-189.	-6309.
25	0.	6215.	-6215.	0.	108.	0.	108.	-108.	-6323.
TOTALS (\$)	0.	130641.	-130641.	0.	5721.	0.	5721.	-5721.	-136362.

LIFE-CYCLE BUILDING AND PLANT NON-ENERGY COSTS (\$)

COST NAME	FIRST COST (INCLUDING INSTALLATION)	REPLACEMENTS	OPERATIONS	TOTAL	INVESTMENT (FIRST COST PLUS REPLACEMENTS)
NO BUILDING COMPONENT COSTS SPECIFIED					
PLANT EQUIPMENT	29298.	0.	5721.	35019.	29298.
TOTALS	29298.	0.	5721.	35019.	29298.

ENERGY SAVINGS

	ANNUAL ENERGY USE BASELINE		ANNUAL ENERGY USE THIS RUN		ANNUAL ENERGY SAVINGS		ANNUAL ENERGY SAVINGS
	(MBTU)	(MWH)	(MBTU)	(MWH)	(MBTU)	(MWH)	(PCT)
AT SITE	0.00	0.00	363.93	106.63	-363.93	-106.63	0.0
AT SOURCE	0.00	0.00	709.67	207.93	-709.67	-207.93	0.0

INVESTMENT STATISTICS

PROJECT LIFE 25.0 YEARS

INVESTMENT THIS RUN (\$)	BASELINE REPLACEMENT COSTS (\$)	INCREMENTAL INVESTMENT (\$)	COST SAVINGS (\$)	RATIO OF SAVINGS TO INCREMENTAL INVESTMENT (SIR)	DISCOUNTED PAYBACK PERIOD (YEARS)	RATIO OF LIFE CYCLE ENERGY SAVINGS (AT SITE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)	RATIO OF LIFE-CYCLE ENERGY SAVINGS (AT SOURCE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)
29298.	0.	29298.	-136362.	-4.65	999.00	-0.31	-0.09	-0.61	-0.18

OVERALL LIFE-CYCLE COSTS (\$)

	FIRST COST	OPRNS COST	REPLACEMENTS	ENERGY COST	T O T A L
BASELINE	0.	0.	0.	0.	0.
THIS RUN	29298.	5721.	0.	130641.	165660.
SAVINGS (\$)	-29298.	-5721.	0.	-130641.	-165660.
(PCT)	0.0	0.0	0.0	0.0	0.0

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-D ENERGY COST SUMMARY

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 1

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-TARIFF	ELECTRICITY	1 2 3 4 5	50644. KWH	3223.	0.0636	YES
GAS-RATE	NATURAL-GAS	1 2 3 4 5	1911. THERMS	1146.	0.6000	YES

 4369.

ENERGY COST/GROSS BLDG AREA: 0.87
 ENERGY COST/NET BLDG AREA: 0.87

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-TARIFF

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 ELEC-TARIFF

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 1

UTILITY-RATE: ELEC-TARIFF

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHR (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	3918	3918	16.2	16.2	245	0	0	0	0	0	0	0.0624	245
FEB	3334	3334	16.1	16.1	208	0	0	0	0	0	0	0.0625	208
MAR	3378	3378	15.8	15.8	212	0	0	0	0	0	0	0.0629	212
APR	3417	3417	22.2	22.2	218	0	0	0	0	0	0	0.0637	218
MAY	3857	3857	28.4	28.4	247	0	0	0	0	0	0	0.0641	247
JUN	4934	4934	33.8	33.8	318	0	0	0	0	0	0	0.0644	318
JUL	6990	6990	39.2	39.2	448	0	0	0	0	0	0	0.0641	448
AUG	6351	6351	36.0	36.0	408	0	0	0	0	0	0	0.0642	408
SEP	4196	4196	30.7	30.7	270	0	0	0	0	0	0	0.0643	270
OCT	3519	3519	19.8	19.8	225	0	0	0	0	0	0	0.0639	225
NOV	3099	3099	21.1	21.1	196	0	0	0	0	0	0	0.0631	196
DEC	3651	3651	15.8	15.8	229	0	0	0	0	0	0	0.0626	229
TOTAL	50644	50644	39.2		3223	0	0	0	0	0	0	0.0636	3223

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE: GAS-RATE

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOB-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 1

UTILITY-RATE: GAS-RATE

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31

100000. BTU/THERMS
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERMS	BILLING ENERGY THERMS	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	516	516	5.6	5.6	309	0	0	0	0	0	0	0.6000	309
FEB	402	402	5.3	5.3	241	0	0	0	0	0	0	0.6000	241
MAR	250	250	4.9	4.9	150	0	0	0	0	0	0	0.6000	150
APR	64	64	3.4	3.4	38	0	0	0	0	0	0	0.6000	38
MAY	9	9	0.7	0.7	5	0	0	0	0	0	0	0.6000	5
JUN	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
JUL	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
AUG	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
SEP	4	4	1.7	1.7	3	0	0	0	0	0	0	0.6000	3
OCT	39	39	3.6	3.6	23	0	0	0	0	0	0	0.6000	23
NOV	213	213	4.3	4.3	128	0	0	0	0	0	0	0.6000	128
DEC	415	415	5.1	5.1	249	0	0	0	0	0	0	0.6000	249
TOTAL	1911	1911	5.6		1146	0	0	0	0	0		0.6000	1146

Simple Structure — Run 3a

LDL PROCESSOR INPUT DATA

Thu Nov 4 16:29:40 1993 LDL RUN 4

```

* 684 *
* 685 * TITLE          LINE-1 *SIMPLE STRUCTURE RUN 3A, CHICAGO *
* 686 *                LINE-2 *INCREASED ROOF INSULATION * ..
* 687 *
* 688 *                RUN-PERIOD      JAN 1 1974 THRU DEC 31 1974  ..
* 689 *                ABORT           ERRORS ..
* 690 *                DIAGNOSTIC      WARNINGS ..
* 691 *                LOADS-REPORT    SUMMARY = (LS-C,LS-D)
* 692 *                VERIFICATION = (LV-B,LV-D) ..
* 693 *                BUILDING-LOCATION LATITUDE=42.0 LONGITUDE=88.0
* 694 *                ALTITUDE=610
* 695 *                TIME-ZONE=6 AZIMUTH=30.0 ..
* 696 *
* 697 * $              BUILDING DESCRIPTION
* 698 *
* 699 * $ STRUCTURE    THE BUILDING IS IDENTICAL TO THAT IN RUN 3 ABOVE EXCEPT
* 700 * $              THAT THE ROOF HAS AN ADDITIONAL INCH OF INSULATION.
* 701 *
* 702 * $ SYSTEMS AND PLANT SIZING IS TAKEN FROM RESULTS OF RUN 3.
* 703 *
* 704 * $ ECONOMICS SPECIFICATIONS ARE THE SAME AS RUN3, BUT INCLUDE THE COSTS
* 705 * $              OF THE IMPROVEMENTS ADDED FOR THE RUN AND THE RESULTS OF RUN 3
* 706 * $              AS A BASELINE.
* 707 * $
* 708 * $ BASELINE     BASELINE ECONOMICS DATA ARE TAKEN FROM
* 709 * $              SIMPLE STRUCTURE RUN 3 REPORTS ES-A AND ES-C.
* 710 * $
* 711 * $ IMPROVEMENT  5000 SQFT OF INSULATION AT 1.10 DOLLARS/SQFT
* 712 *
* 713 *                $ CONSTRUCTION AND GLASS-TYPES
* 714 *
* 715 * ROO-1 =LAYERS  =MAT=(RG01,BR01,IN46,WD01)  1-F-R .76 ..
* 716 * WA-1-2 =LAYERS =MAT=(WD01,PW03,IN02,GP01) ..
* 717 * WALL-1 =CONSTRUCTION  LAYERS=WA-1-2 ..
* 718 * ROOF-1 =CONSTRUCTION  LAYERS=ROO-1 ..
* 719 * CLNG-1 =CONSTRUCTION  U = 0.27 ..
* 720 * SB-U =CONSTRUCTION  U = 1.5 ..
* 721 * FLOOR-1 =CONSTRUCTION  U = 0.05 ..
* 722 *
* 723 * W-1 =GLASS-TYPE  GLASS-TYPE-CODE = 3 PANES = 2 ..
* 724 * DOORS =GLASS-TYPE  GLASS-TYPE-CODE = 5 ..
* 725 *
* 726 *                $ OCCUPANCY SCHEDULE
* 727 *
* 728 * OC-1 =DAY-SCHEDULE  (1,8) (0.0)
* 729 *                (9,11) (1.0)
* 730 *                (12,14) (0.8,0.4,0.8)
* 731 *                (15,18) (1.0)
* 732 *                (19,21) (0.5,0.1,0.1)
* 733 *                (22,24) (0.0) ..
* 734 *
* 735 * OC-2 =DAY-SCHEDULE  (1,24) (0.0) .
* 736 *
* 737 * OC-WEEK =WEEK-SCHEDULE  (WD) OC-1 (WEH) OC-2 ..
* 738 *

```

```

* 739 * OCCUPY-1      =SCHEDULE          THRU DEC 31 OC-WEEK ..
* 740 *
* 741 *              $ LIGHTING SCHEDULE
* 742 *
* 743 * LT-1          =DAY-SCHEDULE      (1,8) (0.05)
* 744 *              (9,14) (0.9,0.95,1.0,0.95,0.8,0.9)
* 745 *              (15,18) (1.0)
* 746 *              (19,21) (0.6,0.2,0.2)
* 747 *              (22,24) (0.05) ..
* 748 *
* 749 * LT-2          =DAY-SCHEDULE      (1,24) (0.05) ..
* 750 *
* 751 * LT-WEEK       =WEEK-SCHEDULE      (MON,FRI) LT-1 (WEH) LT-2 ..
* 752 *
* 753 * LIGHTS-1      =SCHEDULE          THRU DEC 31 LT-WEEK ..
* 754 *
* 755 *              $ OFFICE EQUIPMENT SCHEDULE
* 756 *
* 757 * EQ-1          =DAY-SCHEDULE      (1,8) (0.02)
* 758 *              (9,14) (0.4,0.9,0.9,0.9,0.9,0.9)
* 759 *              (15,20) (0.8,0.7,0.5,0.5,0.3,0.3)
* 760 *              (21,24) (0.02) ..
* 761 *
* 762 * EQ-2          =DAY-SCHEDULE      (1,24) (0.2) ..
* 763 *
* 764 * EQ-WEEK       =WEEK-SCHEDULE      (MON,FRI) EQ-1 (WEH) EQ-2 ..
* 765 *
* 766 * EQUIP-1       =SCHEDULE          THRU DEC 31 EQ-WEEK ..
* 767 *
* 768 *              $ INFILTRATION SCHEDULE
* 769 *
* 770 * INFIL-SCH     =SCHEDULE          THRU MAR 31 (ALL) (1,24) (1)
* 771 *              THRU OCT 31 (ALL) (1,24) (0)
* 772 *              THRU DEC 31 (ALL) (1,24) (1) ..
* 773 *
* 774 *
* 775 *              $ SET DEFAULT VALUES
* 776 *
* 777 *              SET-DEFAULT FOR SPACE FLOOR-WEIGHT=70 ..
* 778 *              SET-DEFAULT FOR EXTERIOR-WALL CONSTRUCTION=WALL-1 ..
* 779 *              SET-DEFAULT FOR WINDOW HEIGHT=4.0 GLASS-TYPE=W-1 Y=3 ..
* 780 *
* 781 *              $ GENERAL SPACE DEFINITION
* 782 *
* 783 * OFFICE         =SPACE-CONDITIONS  PEOPLE-SCHEDULE      =OCCUPY-1
* 784 *              NUMBER-OF-PEOPLE      =50
* 785 *              PEOPLE-HEAT-GAIN       =4'
* 786 *              LIGHTING-SCHEDULE     =LIGHTS-1
* 787 *              LIGHTING-TYPE         =REC-FLUOR-RV
* 788 *              LIGHT-TO-SPACE        =.80
* 789 *              LIGHTING-W/SQFT       =1.5
* 790 *              EQUIP-SCHEDULE        =EQUIP-1
* 791 *              EQUIPMENT-W/SQFT       =1
* 792 *              INF-METHOD           =AIR-CHANGE
* 793 *              AIR-CHANGES/HR       =0.25
* 794 *              INF-SCHEDULE          =INFIL-SCH ..
* 795 *
* 796 *              $ SPECIFIC SPACE DETAILS
* 797 *
* 798 * PLENUM-1       =SPACE              ZONE-TYPE=PLENUM AREA=5000
* 799 *              VOLUME=10000 Z=8 FLOOR-WEIGHT=5 ..
* 800 *
* 801 * WALL-1PF      =EXTERIOR-WALL      HEIGHT = 2 WIDTH = 100

```

```

* 802 *                               AZIMUTH = 180 ..
* 803 *
* 804 *   WALL-1PR   =EXTERIOR-WALL   HEIGHT = 2  WIDTH = 50
* 805 *                               AZIMUTH = 90  X = 100 ..
* 806 *
* 807 *   WALL-1PB   =EXTERIOR-WALL   HEIGHT = 2  WIDTH = 100
* 808 *                               X = 100  Y = 50  AZIMUTH = 0  ..
* 809 *
* 810 *   WALL-1PL   =EXTERIOR-WALL   HEIGHT = 2  WIDTH = 50
* 811 *                               AZIMUTH = 270 Y = 50 ..
* 812 *
* 813 *   TOP-1      =ROOF              HEIGHT=50  WIDTH=100
* 814 *                               X=0  Y=0  Z=2  AZIMUTH = 180
* 815 *                               TILT=0  GND-REFLECTANCE=0
* 816 *                               CONSTRUCTION = ROOF-1 ..
* 817 *
* 818 *   SPACE1-1   =SPACE              SPACE-CONDITIONS = OFFICE
* 819 *                               AREA = 1056  VOLUME = 8448
* 820 *                               NUMBER-OF-PEOPLE = 11 ..
* 821 *   FRONT-1   =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 100
* 822 *                               X=0  Y=0  Z=0  AZIMUTH = 180 ..
* 823 *   WF-1       =WINDOW           WIDTH = 45  X = 10 ..
* 824 *   DF-1       =WINDOW           WIDTH = 8  HEIGHT = 8
* 825 *                               X = 70  Y = 0  GLASS-TYPE=DOORS
* 826 *                               OVERHANG-A 1  OVERHANG-B .5
* 827 *                               OVERHANG-W 10 OVERHANG-D 4 ..
* 828 *
* 829 *   C1-1       =INTERIOR-WALL   AREA = 1056  NEXT-TO PLENUM-1
* 830 *                               CONSTRUCTION = CLNG-1 ..
* 831 *
* 832 *   F1-1       =UNDERGROUND-FLOOR AREA = 1056  CONSTRUCTION = FLOOR-1 ..
* 833 *
* 834 *   SB12        =INTERIOR-WALL   AREA=135.76 NEXT-TO SPACE2-1
* 835 *                               CONSTRUCTION = SB-U ..
* 836 *
* 837 *   SB14        =INTERIOR-WALL   LIKE SB12  NEXT-TO SPACE4-1 ..
* 838 *   SB15        =INTERIOR-WALL   AREA 608   NEXT-TO SPACES5-1
* 839 *                               CONSTRUCTION = SB-U ..
* 840 *
* 841 *   SPACE2-1   =SPACE              SPACE-CONDITIONS = OFFICE
* 842 *                               AREA = 456  VOLUME = 3648
* 843 *                               NUMBER-OF-PEOPLE = 5 ..
* 844 *
* 845 *   RIGHT-1    =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 50
* 846 *                               X=100  Y=0  Z=0  AZIMUTH = 90 ..
* 847 *
* 848 *   WR-1       =WINDOW           WIDTH = 25  X = 12.5 ..
* 849 *
* 850 *   C2-1       =INTERIOR-WALL   AREA = 456  NEXT-TO PLENUM-1
* 851 *                               CONSTRUCTION = CLNG-1 ..
* 852 *
* 853 *   F2-1       =UNDERGROUND-FLOOR AREA = 456  CONSTRUCTION = CLNG-1 ..
* 854 *
* 855 *   SB23        =INTERIOR-WALL   AREA = 135.76 NEXT-TO SPACE3-1
* 856 *                               CONSTRUCTION = SB-U ..
* 857 *
* 858 *   SB25        =INTERIOR-WALL   AREA = 208  NEXT-TO SPACES5-1
* 859 *                               CONSTRUCTION = SB-U ..
* 860 *
* 861 *   SPACE3-1   =SPACE              SPACE-CONDITIONS = OFFICE
* 862 *                               AREA = 1056  VOLUME = 8448
* 863 *                               NUMBER-OF-PEOPLE = 11 ..
* 864 *

```

```

* 865 *   BACK-1   =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 100
* 866 *                                     X=100 Y=50  Z=0  AZIMUTH = 0  ..
* 867 *
* 868 *   WB-1     =WINDOW           WIDTH = 45  X = 10  ..
* 869 *   DB-1     =WINDOW           WIDTH = 7   HEIGHT = 7
* 870 *                                     X = 70  Y = 0  GLASS-TYPE=DOORS  ..
* 871 *
* 872 *   C3-1     =INTERIOR-WALL   AREA = 1056  NEXT-TO PLENUM-1
* 873 *                                     CONSTRUCTION = CLNG-1  ..
* 874 *
* 875 *   F3-1     =UNDERGROUND-FLOOR AREA = 1056
* 876 *                                     CONSTRUCTION = FLOOR-1  ..
* 877 *
* 878 *   SB34     =INTERIOR-WALL   AREA = 135.8  NEXT-TO SPACE4-1
* 879 *                                     CONSTRUCTION = SB-U  ..
* 880 *
* 881 *   SB35     =INTERIOR-WALL   AREA = 608   NEXT-TO SPACES5-1
* 882 *                                     CONSTRUCTION = SB-U  ..
* 883 *
* 884 *   SPACE4-1 =SPACE              SPACE-CONDITIONS = OFFICE
* 885 *                                     AREA = 456  VOLUME = 3648
* 886 *                                     NUMBER-OF-PEOPLE = 5  ..
* 887 *
* 888 *   LEFT-1    =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 50
* 889 *                                     X=0   Y=50  Z=0  AZIMUTH = 270  ..
* 890 *
* 891 *   WL-1      =WINDOW           WIDTH = 25  X = 12.5  ..
* 892 *
* 893 *   C4-1      =INTERIOR-WALL   AREA = 456   NEXT-TO PLENUM-1
* 894 *                                     CONSTRUCTION = CLNG-1  ..
* 895 *
* 896 *   F4-1      =UNDERGROUND-FLOOR AREA = 456
* 897 *                                     CONSTRUCTION = FLOOR-1  ..
* 898 *
* 899 *   SB45      =INTERIOR-WALL   AREA = 208   NEXT-TO SPACES5-1
* 900 *                                     CONSTRUCTION = SB-U  ..
* 901 *
* 902 *   SPACES5-1 =SPACE              SPACE-CONDITIONS = OFFICE
* 903 *                                     AREA = 1976  VOLUME = 15808
* 904 *                                     NUMBER-OF-PEOPLE = 20  ..
* 905 *
* 906 *   C5-1      =INTERIOR-WALL   AREA = 1976  NEXT-TO PLENUM-1
* 907 *                                     CONSTRUCTION = CLNG-1  ..
* 908 *
* 909 *   F5-1      =UNDERGROUND-FLOOR AREA = 1976  CONSTRUCTION = FLOOR-1  ..
* 910 *
* 911 *   END      ..
* 912 *   COMPUTE LOADS  ..
* 913 *   INPUT SYSTEMS  ..

```

SDL PROCESSOR INPUT DATA

Thu Nov 4 16:29:40 1993SDL RUN 2

```

* 914 *
* 915 *          SYSTEMS-REPORT SUMMARY=(SS-A,SS-J) ..
* 916 *
* 917 *          $ SYSTEMS SCHEDULES
* 918 *
* 919 * FAN-1      =DAY-SCHEDULE      (1,6) (0) (7,8) (-999) (9,18) (1) (19,24) (0) ..
* 920 * FAN-2      =DAY-SCHEDULE      (1,24) (0) ..
* 921 * FAN-SCHED  =SCHEDULE          THRU DEC 31 (WD) FAN-1 (WEH) FAN-2 ..
* 922 *
* 923 * HEAT-1      =DAY-SCHEDULE      (1,8) (55) (9,18) (70) (19,24) (55) ..
* 924 * HEAT-2      =DAY-SCHEDULE      (1,24) (55) ..
* 925 * HEAT-WEEK  =WEEK-SCHEDULE    (MON,FRI) HEAT-1 (WEH) HEAT-2 ..
* 926 * HEAT-SCHED =SCHEDULE          THRU DEC 31 HEAT-WEEK ..
* 927 * COOLOFF    =SCHEDULE          THRU DEC 31 (ALL) (1,24) (60) ..
* 928 * HEATOFF    =SCHEDULE          THRU DEC 31 (ALL) (1,24) (60) ..
* 929 *
* 930 * COOL-1      =DAY-SCHEDULE      (1,8) (99) (9,18) (78) (19,24) (99) ..
* 931 * COOL-2      =DAY-SCHEDULE      (1,24) (99) ..
* 932 * COOL-WEEK  =WEEK-SCHEDULE    (MON,FRI) COOL-1 (WEH) COOL-2 ..
* 933 * COOL-SCHED =SCHEDULE          THRU DEC 31 COOL-WEEK ..
* 934 *
* 935 * R1          =DAY-RESET-SCH   SUPPLY-HI=60  SUPPLY-LO=52
* 936 *                                OUTSIDE-LO=30 OUTSIDE-HI=75 ..
* 937 * SAT-RESET  =RESET-SCHEDULE  THRU DEC 31 (ALL) R1 ..
* 938 *
* 939 *
* 940 *          $ SYSTEM DESCRIPTION
* 941 *
* 942 * ZAIR        =ZONE-AIR      OA-CFM/PER=20 ..
* 943 *
* 944 * CONTROL      =ZONE-CONTROL  DESIGN-HEAT-T=70 DESIGN-COOL-T=76
* 945 *                                HEAT-TEMP-SCH= HEAT-SCHED
* 946 *                                COOL-TEMP-SCH= COOL-SCHED
* 947 *                                THERMOSTAT-TYPE=REVERSE-ACTION ..
* 948 *
* 949 *          $ FOLLOWING AIR FLOWS ARE FROM RUN 3 SV-A REPORT.
* 950 *          $ DIVIDED BY ALTITUDE MULTIPLIER
* 951 *
* 952 * SPACE1-1    =ZONE          ZONE-AIR=ZAIR  SIZING-OPTION=ADJUST-LOADS
* 953 *                                ZONE-CONTROL=CONTROL  ASSIGNED-CFM=2133 ..
* 954 *
* 955 * SPACE2-1    =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=957 ..
* 956 * SPACE3-1    =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=1509 ..
* 957 * SPACE4-1    =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=953 ..
* 958 * SPACE5-1    =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=1814 ..
* 959 *
* 960 * PLENUM-1    =ZONE          ZONE-TYPE=PLENUM  SIZING-OPTION=ADJUST-LOADS
* 961 *                                DESIGN-HEAT-T=50  DESIGN-COOL-T=95 ..
* 962 *
* 963 * S-CONT       =SYSTEM-CONTROL COOLING-SCHEDULE= COOLOFF
* 964 *                                HEATING-SCHEDULE= HEATOFF
* 965 *                                HEAT-SET-T=65
* 966 *                                COOL-CONTROL=RESET
* 967 *                                COOL-RESET-SCH=SAT-RESET
* 968 *                                MIN-SUPPLY-T=60 ..

```

```

* 969 *
* 970 * S-FAN      =SYSTEM-FANS    FAN-SCHEDULE=FAN-SCHED FAN-CONTROL=SPEED
* 971 *          SUPPLY-STATIC=5.5 SUPPLY-EFF=.55
* 972 *          NIGHT-CYCLE-CTRL=CYCLE-ON-ANY ..
* 973 *
* 974 * S-TERM    =SYSTEM-TERMINAL REHEAT-DELTA-T=58
* 975 *          MIN-CFM-RATIO=0.3 ..
* 976 *
* 977 * SYST-1    =SYSTEM          SYSTEM-TYPE=VAVS
* 978 *          SUPPLY-CFM=7366
* 979 *          SYSTEM-CONTROL= S-CONT
* 980 *          SYSTEM-FANS= S-FAN
* 981 *          SYSTEM-TERMINAL= S-TERM
* 982 *          ECONO-LIMIT-T=65
* 983 *          RETURN-AIR-PATH= PLENUM-ZONES
* 984 *          PLENUM-NAMES= (PLENUM-1)
* 985 *          ZONE-NAMES= (SPACE5-1,SPACE1-1,SPACE2-1
* 986 *                   SPACE3-1,SPACE4-1,PLENUM-1) ..
* 987 *
* 988 * END      ..
* 989 * COMPUTE SYSTEMS ..
* 990 *
* 991 * INPUT PLANT ..

```

P D L P R O C E S S O R I N P U T D A T A

Thu Nov 4 16:29:40 1993PDL RUN 2

```
* 992 *
* 993 *          PLANT-REPORT SUMMARY=(PS-A,BEPS) ..
* 994 *
* 995 *          $ EQUIPMENT DESCRIPTION
* 996 *
* 997 *          $ HOT-WATER BOILER
* 998 *
* 999 * SBOIL1  =PLANT-EQUIPMENT TYPE=HW-BOILER SIZE=.457 .. $ SIZE FROM RUN 3
*1000 *
*1001 *          PLANT-PARAMETERS HERM-REC-COND-TYPE=AIR ..
*1002 *
*1003 *          $ AIR-COOLED RECIPROCATING CHILLER
*1004 *
*1005 * CHIL1   =PLANT-EQUIPMENT TYPE=HERM-REC-CHLR SIZE=.222 .. $ SIZE FROM RUN 3
*1006 *
*1007 * PLANT-COSTS      PROJECT-LIFE=25 DISCOUNT-RATE=5 ..
*1008 * ENERGY-RESOURCE RESOURCE=ELECTRICITY ..
*1009 * ENERGY-RESOURCE RESOURCE=NATURAL-GAS ENERGY/UNIT=100000
*1010 *                UNIT-NAME=THERMS ..
*1011 * END ..
*1012 * COMPUTE PLANT ..
*1013 * INPUT ECONOMICS ..
```

EDL PROCESSOR INPUT DATA

Thu Nov 4 16:29:40 1993EDL RUN 2

```

*1014 *
*1015 *      $ COST OF ADDED ROOF INSULATION
*1016 *
*1017 * ROOF-INSUL =COMPONENT-COST  UNIT-NAME=*SQFT*  NUMBER-OF-UNITS=5000
*1018 *                               FIRST-COST=0.80  INSTALL-COST=0.30 ..
*1019 *
*1020 *      $ BASELINE COSTS (INCLUDES COST OF BASELINE PLANT EQUIPMENT)
*1021 *
*1022 *      BASELINE
*1023 *
*1024 *          $ following is from "FIRST COST, INCLUDING INSTALLATION",
*1025 *          $ in Run 3, Report ES-B
*1026 *
*1027 *      FIRST-COST=29298
*1028 *
*1029 *          $ following is from total "REPLACEMENTS"
*1030 *          $ in Run 3, Report ES-B
*1031 *
*1032 *      REPLACE-COST=0
*1033 *
*1034 *          $ following is from "ENERGY COST THIS RUN"
*1035 *          $ in Run 3, Report ES-A
*1036 *
*1037 *      ENERGY-COST = (4369,4431,4493,4557,4622,4688,4756,
*1038 *                    4824,4894,4966,5038,5113,5188,5265,5344,5424,
*1039 *                    5505,5588,5673,5759,5847,5936,6027,6120,6215)
*1040 *
*1041 *          $ following is from "OPRNS COST -- THIS RUN, TOTAL"
*1042 *          $ in Run 3, Report ES-A
*1043 *
*1044 *      OPERATIONS-COST = (249,238,314,216,205,272,
*1045 *                    186,412,236,161,212,146,139,828,126,279,
*1046 *                    159,109,104,531,94,124,85,189,108)
*1047 *
*1048 *          $ following is from "ANNUAL ENERGY USE THIS RUN, AT SITE"
*1049 *          $ in Run 3, Report ES-C
*1050 *
*1051 *      ENERGY-USE-SITE = 363.93
*1052 *
*1053 *          $ following is from "ANNUAL ENERGY USE THIS RUN, AT SOURCE"
*1054 *          $ in Run 3, Report ES-C
*1055 *
*1056 *      ENERGY-USE-SRC = 709.67 ..
*1057 *
*1058 *
*1059 * ECONOMICS-REPORT SUMMARY=(ALL-SUMMARY) VERIFICATION=(ALL-VERIFICATION) ..
*1060 *
*1061 * ELEC-TARIFF-UTILITY-RATE  RESOURCE=ELECTRICITY
*1062 *                           ENERGY-CHG-SCH=ENERGY-SCH
*1063 *                           ESCALATION=7 ..
*1064 *
*1065 * ENERGY-SCH =SCHEDULE THRU DEC 31 (WD) (1,8) (.05)          $OFF-PEAK
*1066 *                                     (9,12) (.06)             $$HOULDER
*1067 *                                     (13,17) (.07)            $PEAK
*1068 *                                     (18,22) (.06)            $$HOULDER

```



```

*1069 *                (23,24) (.05)          SOFF-PEAK
*1070 *
*1071 *                (SAT) (1,8) (.05)       SOFF-PEAK
*1072 *                (9,17) (.06)          Sshoulder
*1073 *                (18,24) (.05)         SOFF-PEAK
*1074 *
*1075 *                (SUN,HOL) (1,24) (.05) .. SOFF-PEAK
*1076 *
*1077 * GAS-RATE   =UTILITY-RATE   RESOURCE=NATURAL-GAS
*1078 *                                     ENERGY-CHG = .6 ..
*1079 *
*1080 * END ..
*1081 * COMPUTE ECONOMICS ..
*1082 * STOP ..

```

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- LV 3 SUMMARY OF SPACES OCCURRING IN THE PROJECT

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 4

WEATHER FILE- TRY CHICAGO

NUMBER OF SPACES 6 EXTERIOR 5 INTERIOR 1

SPACE	SPACE*FLOOR MULTIPLIER	SPACE TYPE	AZIMUTH	LIGHTING (WATT / SQFT)	PEOPLE	EQUIP (WATT / SQFT)	INFILTRATION METHOD	AIR CHANGES PER HOUR	AREA (SQFT)	VOLUME (CUFT)
PLENUM-1	1.0	EXT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	5000.00	10000.00
SPACE1-1	1.0	EXT	0.0	1.50	11.0	1.00	AIR-CHANGE	0.25	1056.00	8448.00
SPACE2-1	1.0	EXT	0.0	1.50	5.0	1.00	AIR-CHANGE	0.25	456.00	3648.00
SPACE3-1	1.0	EXT	0.0	1.50	11.0	1.00	AIR-CHANGE	0.25	1056.00	8448.00
SPACE4-1	1.0	EXT	0.0	1.50	5.0	1.00	AIR-CHANGE	0.25	456.00	3648.00
SPACE5-1	1.0	INT	0.0	1.50	20.0	1.00	AIR-CHANGE	0.25	1976.00	15808.00
BUILDING TOTALS					52.0				10000.00	50000.00

SIMPLE STRUCTURE RUN 3A, CHICAGO INCREASED ROOF INSULATION
 DESIGN-DAY SIZING OF VAV SYSTEM SHOW ALL REPORTS
 REPORT- LV-D DETAILS OF EXTERIOR SURFACES IN THE PROJECT

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 4
 WEATHER FILE- TRY CHICAGO

NUMBER OF EXTERIOR SURFACES 9 RECTANGULAR 9 OTHER 0
 (U-VALUE INCLUDES OUTSIDE AIR FILM; WINDOW INCLUDES FRAME, IF DEFINED)

SURFACE	SPACE	- - - W I N D O W S - - -		- - - - W A L L - - - -		- W A L L + W I N D O W S -		AZIMUTH
		U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	
WALL-1PB	PLENUM-1	0.000	0.00	0.067	200.00	0.067	200.00	NORTH
BACK-1	SPACE3-1	0.565	229.00	0.067	571.00	0.210	800.00	NORTH
RIGHT-1	SPACE2-1	0.467	100.00	0.067	300.00	0.167	400.00	EAST
WALL-1PR	PLENUM-1	0.000	0.00	0.067	100.00	0.067	100.00	EAST
WALL-1PF	PLENUM-1	0.000	0.00	0.067	200.00	0.067	200.00	SOUTH
FRONT-1	SPACE1-1	0.587	244.00	0.067	556.00	0.226	800.00	SOUTH
WALL-1PL	PLENUM-1	0.000	0.00	0.067	100.00	0.067	100.00	WEST
LEFT-1	SPACE4-1	0.467	100.00	0.067	300.00	0.167	400.00	WEST
TOP-1	PLENUM-1	0.000	0.00	0.047	5000.00	0.047	5000.00	ROOF
F1-1	SPACE1-1	0.000	0.00	0.050	1056.00	0.050	1056.00	UNDERGRND
F2-1	SPACE2-1	0.000	0.00	0.270	456.00	0.270	456.00	UNDERGRND
F3-1	SPACE3-1	0.000	0.00	0.050	1056.00	0.050	1056.00	UNDERGRND
F4-1	SPACE4-1	0.000	0.00	0.050	456.00	0.050	456.00	UNDERGRND
F5-1	SPACE5-1	0.000	0.00	0.050	1976.00	0.050	1976.00	UNDERGRND

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- LV-D DETAILS OF EXTERIOR SURFACES IN THE PROJECT

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 4

WEATHER FILE- TRY CHICAGO

(CONTINUED)

	AVERAGE U-VALUE/WINDOWS (BTU/HR-SQFT-F)	AVERAGE U-VALUE/WALLS (BTU/HR-SQFT-F)	AVERAGE U-VALUE WALLS+WINDOWS (BTU/HR-SQFT-F)	WINDOW AREA (SQFT)	WALL AREA (SQFT)	WINDOW+WALL AREA (SQFT)
NORTH	0.565	0.067	0.181	229.00	771.00	1000.00
EAST	0.467	0.067	0.147	100.00	400.00	500.00
SOUTH	0.587	0.067	0.194	244.00	756.00	1000.00
WEST	0.467	0.067	0.147	100.00	400.00	500.00
ROOF	0.000	0.047	0.047	0.00	5000.00	5000.00
ALL WALLS	0.544	0.067	0.174	673.00	2327.00	3000.00
WALLS+ROOFS	0.544	0.053	0.095	673.00	7327.00	8000.00
UNDERGRND	0.000	0.070	0.070	0.00	5000.00	5000.00
BUILDING	0.544	0.060	0.085	673.00	12327.00	13000.00

*** BUILDING ***

FLOOR AREA 5000 SQFT 465 SQMT
 VOLUME 50000 CUFT 1416 CURT

TIME	COOLING LOAD		HEATING LOAD	
	AUG 19	6PM	FEB 4	6AM
DRY-BULB TEMP	90F	32C	7F	-14C
WET-BULB TEMP	71F	22C	6F	-14C

	SENSIBLE		LATENT		SENSIBLE			
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)		
WALL CONDUCTION	4.297	1.259	0.000	0.000	-7.004	-2.052		
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000		
WINDOW GLASS-FRM COND	8.963	2.626	0.000	0.000	-21.909	-6.419		
WINDOW GLASS SOLAR	29.977	8.783	0.000	0.000	1.242	0.364		
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000		
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000		
UNDERGROUND SURF COND	-1.401	-0.411	0.000	0.000	-11.561	-3.387		
OCCUPANTS TO SPACE	11.607	3.401	6.776	1.985	0.001	0.000		
LIGHT TO SPACE	17.920	5.251	0.000	0.000	1.026	0.301		
EQUIPMENT TO SPACE	8.872	2.599	0.000	0.000	0.830	0.243		
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000		
INFILTRATION	0.000	0.000	0.000	0.000	-9.685	-2.838		
TOTAL	80.234	23.508	6.776	1.985	-47.060	-13.788		
TOTAL LOAD	87.009 KBTU/H		25.494 KW		-47.060 KBTU/H		-13.788 KW	
TOTAL LOAD / AREA	17.40BTU/H.SQFT		54.882 W /SQMT		9.412BTU/H.SQFT		29.684 W /SQMT	

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 * *****

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	4.49885	25 16	48.F	42.F	46.997	-12.798	7 5	2.F	2.F	-45.880	3027.	12.000
FEB	4.07415	15 16	31.F	26.F	48.481	-11.796	4 6	7.F	6.F	-47.060	2654.	12.000
MAR	5.82094	5 17	57.F	46.F	48.474	-8.775	24 6	8.F	7.F	-44.483	2936.	12.000
APR	11.70507	26 15	78.F	61.F	65.887	-2.922	8 6	32.F	29.F	-23.486	2994.	12.000
MAY	14.89968	20 15	77.F	68.F	66.853	-1.170	9 5	40.F	38.F	-13.599	3027.	12.000
JUN	18.99737	20 15	90.F	77.F	74.772	-0.193	17 5	54.F	49.F	-5.237	2812.	12.000
JUL	24.94236	9 15	94.F	74.F	79.777	-0.004	5 5	60.F	54.F	-0.472	3027.	12.000
AUG	22.82894	19 17	90.F	71.F	80.234	-0.009	5 5	55.F	54.F	-2.754	3027.	12.000
SEP	17.11742	26 16	82.F	61.F	76.772	-0.483	23 6	37.F	34.F	-12.273	2812.	12.000
OCT	13.00402	10 16	68.F	53.F	70.816	-1.900	21 6	30.F	29.F	-18.011	3027.	12.000
NOV	6.24292	8 15	60.F	49.F	64.713	-6.776	15 6	28.F	26.F	-30.286	2720.	12.000
DEC	4.20004	10 15	41.F	35.F	49.924	-11.676	9 6	14.F	13.F	-38.725	2936.	12.000
TOTAL	148.332					-58.501					34996.	
MAX					80.234					-47.060		12.000

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 2

SYST-1

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
SYST-1	VAVS	1.020	5000.0	52.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/HR)	HEATING EIR (BTU/HR)
	7513.	8.646	3.6	0.	0.000	0.0	0.141	216.189	0.804	-1.917	0.00	0.37
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
	SPACE5-1	1850.	0.	0.000	0.300	408.	0.00	0.00	31.97	-115.90	-95.92	1.0
	SPACE1-1	2176.	0.	0.000	0.300	224.	0.00	0.00	37.60	-136.28	-112.79	1.0
	SPACE2-1	976.	0.	0.000	0.300	102.	0.00	0.00	16.87	-61.15	-50.60	1.0
	SPACE3-1	1539.	0.	0.000	0.300	224.	0.00	0.00	26.60	-96.41	-79.79	1.0
	SPACE4-1	972.	0.	0.000	0.300	102.	0.00	0.00	16.80	-60.89	-50.39	1.0
	PLENUM-1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-24.696	7 8	-1.F	-1.F	-393.441	3292.	12.886
FEB	0.00000				0.000	-19.176	4 8	7.F	6.F	-395.605	2871.	12.862
MAR	0.00000				0.000	-11.439	25 8	14.F	12.F	-357.888	3147.	12.862
APR	1.64851	29 18	69.F	65.F	52.931	-2.702	1 8	43.F	39.F	-190.842	3194.	12.862
MAY	4.78337	21 14	85.F	75.F	108.533	-0.073	9 9	43.F	39.F	-22.369	3261.	13.490
JUN	13.31118	20 17	90.F	78.F	144.459	0.000				0.000	3192.	14.251
JUL	25.36230	15 8	72.F	70.F	208.830	0.000				0.000	3779.	18.752
AUG	21.61059	26 15	90.F	75.F	152.463	0.000				0.000	3616.	16.577
SEP	9.14995	11 15	87.F	72.F	120.025	-0.007	23 9	39.F	36.F	-6.566	3133.	14.966
OCT	2.83521	4 17	78.F	61.F	52.819	-0.704	21 8	30.F	29.F	-157.061	3223.	12.862
NOV	0.37585	1 16	72.F	59.F	49.879	-9.119	18 8	34.F	34.F	-244.497	2904.	12.862
DEC	0.00000				0.000	-18.609	9 8	13.F	12.F	-353.233	3161.	12.862
TOTAL	79.077					-86.524					38773.	
MAX					208.830					-395.605		18.752

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
	JUL 15				FEB 4			JUL 8			
1	0.000	0.000	77.F	72.F	0.000	11.F	9.F	0.000	0.000	76.F	68.F
2	0.000	0.000	77.F	72.F	-100.562	11.F	9.F	0.000	0.000	76.F	68.F
3	0.000	0.000	76.F	71.F	0.000	10.F	9.F	0.000	0.000	75.F	68.F
4	0.000	0.000	75.F	71.F	-108.452	9.F	8.F	0.000	0.000	74.F	68.F
5	0.000	0.000	73.F	70.F	0.000	8.F	7.F	0.000	0.000	73.F	67.F
6	0.000	0.000	72.F	70.F	-119.407	7.F	6.F	0.000	0.000	72.F	67.F
7	208.830 *	0.881	72.F	70.F	0.000	6.F	5.F	191.575 *	0.928	72.F	67.F
8	199.172 *	0.861	75.F	70.F	-395.605	7.F	6.F	196.065 *	0.870	77.F	70.F
9	177.857	0.873	76.F	69.F	-246.265	7.F	6.F	188.506	0.861	83.F	72.F
10	173.407	0.883	78.F	69.F	-194.114	10.F	9.F	193.424	0.842	86.F	74.F
11	169.101	0.880	80.F	70.F	-163.056	14.F	13.F	186.416	0.861	89.F	74.F
12	154.657	0.893	81.F	70.F	-139.462	18.F	17.F	169.024	0.893	90.F	73.F
13	161.425	0.865	82.F	71.F	-118.089	23.F	21.F	173.001	0.886	91.F	73.F
14	158.620	0.887	83.F	70.F	-103.090	24.F	22.F	174.959	0.887	92.F	73.F
15	152.590	0.893	81.F	69.F	-90.578	24.F	21.F	177.597	0.866	92.F	74.F
16	144.039	0.885	80.F	69.F	-85.341	23.F	22.F	166.044	0.891	93.F	73.F
17	142.142	0.873	79.F	69.F	-80.663	22.F	21.F	162.546	0.889	93.F	73.F
18	0.000	0.000	77.F	67.F	-78.142	21.F	20.F	0.000	0.000	92.F	73.F
19	0.000	0.000	76.F	67.F	0.000	20.F	19.F	0.000	0.000	90.F	72.F
20	0.000	0.000	74.F	66.F	0.000	19.F	17.F	0.000	0.000	83.F	70.F
21	0.000	0.000	71.F	65.F	0.000	20.F	18.F	0.000	0.000	82.F	68.F
22	0.000	0.000	69.F	64.F	0.000	21.F	19.F	0.000	0.000	82.F	70.F
23	0.000	0.000	67.F	63.F	0.000	22.F	20.F	0.000	0.000	82.F	70.F
24	0.000	0.000	67.F	63.F	0.000	22.F	20.F	0.000	0.000	80.F	69.F
SUM								1979.156			
MAX	208.830				-395.605						

SYSTEM-TYPE	VAVS	SQFT/TON	287.3
COOLING PEAK	41.77 (BTU/HR- SQFT)	HEATING PEAK	-79.12 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.50 (CFM/SQFT)	MIN-OA/PERSON	20.40 (CFM)
OA FRAC AT CLG PEAK	0.156	OA FRAC AT HTG PEAK	0.211

* ASTERISKS INDICATE HOURS LOADS NOT MET

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-A EQUIPMENT SIZES

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 2

WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	0.457	1 1										
HERM-REC-CHLR	0.222	1 1										

S I T E E N E R G Y													* SOURCE
MONTH	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	25.4	0.0	4.0	0.0	0.0	0.0	0.0	39.8	0.7	0.0	39.8	53.4	80.5
FEB	19.8	0.0	3.4	0.0	0.0	0.0	0.0	30.9	0.5	0.0	30.9	42.5	65.7
MAR	12.1	0.0	3.5	0.0	0.0	0.0	0.0	19.1	0.4	0.0	19.1	31.1	55.2
APR	3.0	1.9	3.6	0.0	0.0	0.0	0.3	4.8	0.1	0.0	4.8	17.2	41.8
MAY	0.1	5.3	4.0	0.0	0.0	0.0	0.7	0.2	0.0	0.0	0.2	13.8	41.1
JUN	0.0	14.2	5.0	0.0	0.0	0.0	1.8	0.0	0.0	0.0	0.0	17.0	51.1
JUL	0.0	26.4	6.8	0.0	0.0	0.0	3.0	0.0	0.0	0.0	0.0	23.1	69.2
AUG	0.0	22.6	6.3	0.0	0.0	0.0	2.7	0.0	0.0	0.0	0.0	21.4	64.3
SEP	0.0	9.8	4.4	0.0	0.0	0.0	1.3	0.0	0.0	0.0	0.0	15.0	45.0
OCT	0.8	3.2	3.8	0.0	0.0	0.0	0.5	1.3	0.0	0.0	1.3	14.1	39.8
NOV	9.6	0.4	3.3	0.0	0.0	0.0	0.1	15.3	0.3	0.0	15.3	26.5	48.9
DEC	19.2	0.0	3.7	0.0	0.0	0.0	0.0	30.1	0.5	0.0	30.1	42.7	67.9
TOTAL	90.1	83.8	51.6	0.0	0.0	0.0	10.3	141.6	2.6	0.0	141.6	317.8	670.4

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	90.1	100.0
LOAD SATISFIED	90.1	100.0
TOTAL LOAD ON PLANT	90.1	
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HERM-REC-CHLR	83.8	100.0
LOAD SATISFIED	83.8	100.0
TOTAL LOAD ON PLANT	83.8	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	51640.9	100.0
LOAD SATISFIED	51640.9	100.0
TOTAL LOAD ON PLANT	51639.6	

SIMPLE STRUCTURE RUN 3A, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PS-D PLANT LOADS SATISFIED

INCREASED ROOF INSULATION
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 2

WEATHER FILE- TRY CHICAGO

(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	90.1	90.1	0.000	0.000	0
COOLING LOADS	83.8	83.8	0.000	0.000	0
ELECTRICAL LOADS	176.2	176.2	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		

AREA LIGHTS	74.7	0.0
MISC EQUIPMT	44.7	0.0
SPACE HEAT	6.9	141.6
SPACE COOL	26.6	0.0
HEAT REJECT	5.9	0.0
PUMPS & MISC	4.6	0.0
VENT FANS	12.9	0.0

TOTAL	176.2	141.6

TOTAL SITE ENERGY	317.85 MBTU	63.6 KBTU/SQFT-YR GROSS-AREA	63.6 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	670.40 MBTU	134.1 KBTU/SQFT-YR GROSS-AREA	134.1 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.4
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

LIFE-CYCLE COSTING PARAMETERS

DISCOUNT RATE (PERCENT)	LABOR INFLATION RATE (PERCENT)	MATERIALS INFLATION RATE (PERCENT)	PROJECT LIFE (YRS)
5.0	0.0	0.0	25.0

BUILDING COMPONENT COST INPUT DATA (CURRENT DOLLARS)

COST NAME	NUMBER OF UNITS	UNIT NAME	LIFE (YRS)	UNIT FIRST COST (\$)	UNIT INSTALL -ATION COST (\$)	UNIT ANNUAL MAINT COST (\$)	UNIT MINOR OVERHAUL COST (\$)	MINOR OVERHAUL INTERVAL (YRS)	UNIT MAJOR OVERHAUL COST (\$)	MAJOR OVERHAUL INTERVAL (YRS)
ROOF-INSUL	5000.0	SQFT	999.0	0.80	0.30	0.00	0.00	999.00	0.00	999.00

YEAR	ENERGY (\$)			OPERATIONS (\$)				TOTAL SAVINGS- ENERGY PLUS OPRNS	
	ENERGY COST	ENERGY COST	ENERGY COST	OPRNS COST	OPRNS COST -- THIS RUN				OPRNS COST
	BASELINE	THIS RUN	SAVINGS	BASELINE	PLANT	BUILDING	TOTAL		SAVINGS
1	4369.	4111.	258.	249.	249.	0.	249.	0.	258.
2	4431.	4173.	258.	238.	238.	0.	238.	0.	259.
3	4493.	4236.	257.	314.	226.	0.	226.	88.	345.
4	4557.	4301.	256.	216.	215.	0.	215.	1.	257.
5	4622.	4366.	256.	205.	205.	0.	205.	0.	256.
6	4688.	4433.	255.	272.	195.	0.	195.	77.	331.
7	4756.	4502.	254.	186.	186.	0.	186.	0.	254.
8	4824.	4571.	253.	412.	177.	0.	177.	235.	488.
9	4894.	4642.	252.	236.	169.	0.	169.	67.	319.
10	4966.	4714.	252.	161.	161.	0.	161.	0.	252.
11	5038.	4788.	250.	212.	153.	0.	153.	59.	309.
12	5113.	4863.	250.	146.	146.	0.	146.	0.	250.
13	5188.	4939.	249.	139.	139.	0.	139.	0.	249.
14	5265.	5017.	248.	928.	132.	0.	132.	696.	944.
15	5344.	5097.	247.	126.	126.	0.	126.	0.	247.
16	5424.	5177.	247.	279.	120.	0.	120.	159.	406.
17	5505.	5260.	245.	159.	114.	0.	114.	45.	290.
18	5588.	5344.	244.	109.	109.	0.	109.	0.	244.
19	5673.	5429.	244.	104.	104.	0.	104.	0.	244.
20	5759.	5517.	242.	531.	99.	0.	99.	432.	675.
21	5847.	5606.	241.	94.	94.	0.	94.	0.	241.
22	5936.	5696.	240.	124.	90.	0.	90.	34.	274.
23	6027.	5789.	238.	85.	85.	0.	85.	0.	238.
24	6120.	5883.	237.	189.	81.	0.	81.	108.	345.
25	6215.	5978.	237.	108.	77.	0.	77.	31.	267.
TOTALS (\$)	130642.	124431.	6211.	5722.	3691.	0.	3691.	2031.	8243.

SIMPLE STRUCTURE RUN 3A, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- ES-B LIFE-CYCLE BUILDING AND PLANT NON-ENERGY COSTS

INCREASED ROOF INSULATION
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

LIFE-CYCLE BUILDING AND PLANT NON-ENERGY COSTS (\$)

COST NAME	FIRST COST (INCLUDING INSTALLATION)	REPLACEMENTS	OPERATIONS	TOTAL	INVESTMENT (FIRST COST PLUS REPLACEMENTS)
-----	-----	-----	-----	-----	-----
ROOF-INSUL	5500.	0.	0.	5500.	5500.
PLANT EQUIPMENT	29273.	0.	3691.	32964.	29273.
-----	-----	-----	-----	-----	-----
TOTALS	34773.	0.	3691.	38464.	34773.

ENERGY SAVINGS

	ANNUAL ENERGY USE BASELINE		ANNUAL ENERGY USE THIS RUN		ANNUAL ENERGY SAVINGS		ANNUAL ENERGY SAVINGS
	(MBTU)	(MWH)	(MBTU)	(MWH)	(MBTU)	(MWH)	(PCT)
AT SITE	363.93	106.63	317.85	93.13	46.08	13.50	12.7
AT SOURCE	709.67	207.93	670.40	196.43	39.27	11.51	5.5

INVESTMENT STATISTICS

PROJECT LIFE 25.0 YEARS

INVESTMENT THIS RUN (\$)	BASLINE REPLACEMENT COSTS (\$)	INCREMENTAL INVESTMENT (\$)	COST SAVINGS (\$)	RATIO OF SAVINGS TO INCREMENTAL INVESTMENT (SIR)	DISCOUNTED PAYBACK PERIOD (YEARS)	RATIO OF LIFE CYCLE ENERGY SAVINGS (AT SITE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)	RATIO OF LIFE-CYCLE ENERGY SAVINGS (AT SOURCE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)
34773.	0.	5475.	8243.	1.51	16.18	0.21	0.06	0.18	0.05

OVERALL LIFE-CYCLE COSTS (\$)

	FIRST COST	OPRNS COST	REPLACEMENTS	ENERGY COST	T O T A L
BASELINE	29298.	5722.	0.	130642.	165662.
THIS RUN	34773.	3691.	0.	124431.	162894.
SAVINGS (\$)	-5475.	2031.	0.	6211.	2768.
(PCT)	-18.7	35.5	0.0	4.8	1.7

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-D ENERGY COST SUMMARY

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-TARIFF	ELECTRICITY	1 2 3 4 5	51641. KWH	3261.	0.0631	YES
GAS-RATE	NATURAL-GAS	1 2 3 4 5	1416. THERMS	850.	0.6000	YES

 4111.

ENERGY COST/GROSS BLDG AREA: 0.82
 ENERGY COST/NET BLDG AREA: 0.82

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

INCREASED ROOF INSULATION
 SHOW ALL REPORTS
 ELEC-TARIFF

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

UTILITY-RATE: ELEC-TARIFF

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	3972	3972	16.3	16.3	247	0	0	0	0	0	0	0.0622	247
FEB	3400	3400	16.2	16.2	212	0	0	0	0	0	0	0.0623	212
MAR	3525	3525	16.2	16.2	220	0	0	0	0	0	0	0.0624	220
APR	3613	3613	20.1	20.1	228	0	0	0	0	0	0	0.0632	228
MAY	3993	3993	26.4	26.4	253	0	0	0	0	0	0	0.0635	253
JUN	4992	4992	30.4	30.4	318	0	0	0	0	0	0	0.0637	318
JUL	6757	6757	37.6	37.6	430	0	0	0	0	0	0	0.0636	430
AUG	6276	6276	32.8	32.8	400	0	0	0	0	0	0	0.0638	400
SEP	4396	4396	28.7	28.7	280	0	0	0	0	0	0	0.0637	280
OCT	3755	3755	20.2	20.2	238	0	0	0	0	0	0	0.0634	238
NOV	3274	3274	20.1	20.1	204	0	0	0	0	0	0	0.0624	204
DEC	3688	3688	16.2	16.2	230	0	0	0	0	0	0	0.0624	230
TOTAL	51641	51641	37.6		3261	0	0	0	0	0		0.0631	3261

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

INCREASED ROOF INSULATION
 SHOW ALL REPORTS
 GAS-RATE

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

UTILITY-RATE: GAS-RATE

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDO... HOUR
 BILLING-DA... 31

100000. BTU/THERMS
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS


MIN-WON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERMS	BILLING ENERGY THERMS	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	398	398	5.1	5.1	239	0	0	0	0	0	0	0.6000	239
FEB	309	309	5.1	5.1	185	0	0	0	0	0	0	0.6000	185
MAR	191	191	4.7	4.7	115	0	0	0	0	0	0	0.6000	115
APR	48	48	2.8	2.8	29	0	0	0	0	0	0	0.6000	29
MAY	2	2	0.4	0.4	1	0	0	0	0	0	0	0.6000	1
JUN	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
JUL	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
AUG	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
SEP	0	0	0.2	0.2	0	0	0	0	0	0	0	0.6000	0
OCT	13	13	2.4	2.4	8	0	0	0	0	0	0	0.6000	8
NOV	153	153	3.4	3.4	92	0	0	0	0	0	0	0.6000	92
DEC	301	301	4.6	4.6	181	0	0	0	0	0	0	0.6000	181
TOTAL	1416	1416	5.1		850	0	0	0	0	0		0.6000	850

31-Story Office Building


Plan and elevation views. Each floor is divided into four perimeter zones and one core zone.



XBL 791-8074

31-Story Office Building, LOAD1

DrawBDL axonometric view of top floor and mid-floor (multiplier = 30) as input into BDL. The roof and interior surfaces are not shown.



791-8074A

LDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993LDL RUN 1

```

* 2 * TITLE          LINE-1 *31-STORY OFFICE BLDG, CHICAGO - LOAD1*
* 3 *              LINE-2 *STD ASHRAE WEIGHTING FACTORS * ..
* 4 *
* 5 *              ABORT          ERRORS          ..
* 6 *              DIAGNOSTIC     WARNINGS        ..
* 7 *
* 8 *              LOADS-REPORT     SUMMARY=(LS-C,LS-D)      ..
* 9 *              RUN-PERIOD       JAN 1 1988 THRU DEC 31 1988 ..
* 10 *             BUILDING-LOCATION  LATITUDE=42  LONGITUDE=88
* 11 *                                     TIME-ZONE=6  ALTITUDE=610 ..
* 12 *
* 13 *              $ BUILDING DESCRIPTION
* 14 *
* 15 * $ STRUCTURE   STEEL FRAME WITH 4IN CONCRETE FLOORS AND ROOF.  31 OCCUPIED
* 16 * $             STORIES, 13FT FLOOR TO FLOOR HEIGHT, 9FT CEILINGS.  RETURN
* 17 * $             AIR CEILING PLENUMS ARE NOT DEFINED PER SE -- INPUT USES THE
* 18 * $             SIMPLER APPROACH OF RETURN-AIR-PATH = DUCT.
* 19 *
* 20 * $ CURTAIN WALL USING CODE-WORDS FROM DOE-2 LIBRARY ( REFERENCE MANUAL PART 2 )
* 21 * $             AND STARTING WITH OUTSIDE WORKING INWARD; 1/4IN SPANDREL GLASS
* 22 * $             ( NOT IN LIBRARY - SEE MATERIAL SPGL ); 2IN POLYSTYRENE INSUL
* 23 * $             R-8 (IN35); STEEL BACKPANEL (AS01); 2IN AIRSPACE (AL21);
* 24 * $             3/4IN GYPSUM BOARD FINISH (GP03) .
* 25 *
* 26 * $ ROOF        ROOF GRAVEL (RG02); BUILT-UP ROOFING (BR01); 3IN ROOF INSUL R-8
* 27 * $             (IN76); 4IN CONCRETE (CC03); INSIDE-FILM-RESISTANCE .76 .
* 28 *
* 29 * $ WINDOWS     DOUBLE-GLAZED TINTED, SOLAR TRANSMITTANCE=.53, GLASS TYPE CODE=5.
* 30 * $             WINDOWS HAVE INSIDE BLINDS WITH A 70% PROBABILITY OF BEING PULLED
* 31 * $             IF TRANSMITTED DIRECT SOLAR RADIATION EXCEEDS 40BTUH PER SQFT.
* 32 * $             BLINDS ARE CONSIDERED TO BE REOPENED WITH A PROBABILITY OF 50%
* 33 * $             WHEN TRANSMITTED DIRECT SOLAR IS LESS THAN 40BTUH PER SQFT.
* 34 *
* 35 * $ INTERIORS   CEILINGS ARE SUSPENDED ACCOUSTIC TILE.
* 36 * $             PARTITIONS SIMULATE CONVECTIVE HEAT TRANSFER BETWEEN CORE AND
* 37 * $             PERIMETER SPACES USING A U-VALUE OF 1.5 BTUH/SQFT-F
* 38 *
* 39 * $ SPACE LOADS LIGHTING IS RECESSED FLUORESCENT AT 1.5 WATTS/SQFT.
* 40 * $             OFFICE EQUIPMENT IS 1 WATTS/SQFT.
* 41 * $             PEOPLE: 100SQFT/PERSON FOR PERIMETER SPACES
* 42 * $             200SQFT/PERSON FOR CORE AREAS.
* 43 * $             INFILTRATION IS .3 AIR CHANGES/HR FOR PERIMETER AREAS WHEN FANS
* 44 * $             ARE OFF, AND .06 AIR CHANGES/HR WHEN FANS ARE ON.
* 45 *
* 46 * $ HVAC DESCRIPTIONS ARE GIVEN WITH EACH INDIVIDUAL SYSTEM AND PLANT INPUT.
* 47 *
* 48 *              $ MATERIALS NOT IN DOE-2 LIBRARY
* 49 *
* 50 * SPGS=MATERIAL  TH=.0208  COND=.590  DENS=172.  S-H=.20
* 51 *
* 52 *              $ WALL CONSTRUCTIONS
* 53 *
* 54 * ROOFER         LAYERS MAT (RG02,BR01,IN76,CC03)  I-F-R .76 ..
* 55 * WALLER         LAYERS MAT (SPGS,IN35,AS01,AL21,GP03) ..
* 56 * RF            =CONSTRUCTION  LAYERS=ROOFER ..

```



```

* 57 * WL1      =CONSTRUCTION   LAYERS=WALLER  ..
* 58 * BW      =CONSTRUCTION   U=.05    ..
* 59 * SB-U    =CONSTRUCTION   U=1.5    ..
* 60 *
* 61 *          $ GLASS DESCRIPTION
* 62 *
* 63 * GT1      GLASS-TYPE G-T-C 5 PANES 2  ..
* 64 *
* 65 *          $ SCHEDULES
* 66 *
* 67 * OC1      =DAY-SCHEDULE   (1,8) (0.)      (9,10) (1.)
* 68 *          (11,13) (.8,.4,.8) (14,24) (1.,1.,1.,
* 69 *          .3,.1.,1.,1.0.,0.,0.,0.) ..
* 70 * OC2      =DAY-SCHEDULE   (1,24) (0.0) ..
* 71 * PEOPLE   =WEEK-SCHEDULE (MON,FRI) OC1 (WEH) OC2 ..
* 72 * OCCUP    =SCHEDULE      THRU DEC 31 PEOPLE ..
* 73 *
* 74 * L1       =DAY-SCHEDULE   (1,6) (.05)      (7,24) (.1,.9,.9,
* 75 *          .95,.95,.95,.8,.8,.9,.9,.95,.8,.7,.6,
* 76 *          .4,.3,.2,.2) ..
* 77 * L2       =DAY-SCHEDULE   (1,24) (.05) ..
* 78 * LIGHTS   =WEEK-SCHEDULE (MON,FRI) L1 (WEH) L2 ..
* 79 * LT1      =SCHEDULE      THRU DEC 31 LIGHTS ..
* 80 *
* 81 * ES1      =DAY-SCHEDULE   (1,8) (0.)      (9,20) (.35,.50,
* 82 *          .55,.9,.6,.8,.7,.75,.3,.3,.5,.05)
* 83 *          (21,24) (0.0) ..
* 84 * ES2      =DAY-SCHEDULE   (1,24) (0.0) ..
* 85 * EQUIP    =WEEK-SCHEDULE (MON,FRI) ES1 (WEH) ES2 ..
* 86 * EQ1      =SCHEDULE      THRU DEC 31 EQUIP ..
* 87 *
* 88 * I1       =DAY-SCHEDULE   (1,7) (1.)      (8,18) (0.2)
* 89 *          (19,24) (1.) ..
* 90 * I2       =DAY-SCHEDULE   (1,24) (1.) ..
* 91 * INFILT   =WEEK-SCHEDULE (MON,FRI) I1 (WEH) I2 ..
* 92 * INF1     =SCHEDULE      THRU DEC 31 INFILT ..
* 93 *
* 94 * SHADE-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.5) ..
* 95 * CLOSE-SHADE =SCHEDULE THRU DEC 31 (ALL) (1,24) (40) ..
* 96 * OPEN-PROB =SCHEDULE THRU DEC 31 (ALL) (1,24) (.5) ..
* 97 *
* 98 *          $ SPACE DESCRIPTIONS
* 99 *
* 100 * OFFICE   =SPACE-CONDITIONS TEMPERATURE=(75) FLOOR-WEIGHT=70
* 101 *          LIGHTING-W/SQFT=1.5 EQUIPMENT-W/SQFT=1
* 102 *          PEOPLE-HEAT-GAIN=450
* 103 *          EQUIP-SCHEDULE=EQ1 LIGHTING-SCHEDULE=LT1
* 104 *          PEOPLE-SCHEDULE=OCCUP AIR-CHANGES/HR=.3
* 105 *          INF-SCHEDULE=INF1 LIGHT-TO-SPACE=.80
* 106 *          INF-METHOD=AIR-CHANGE
* 107 *          LIGHTING-TYPE=REC-FLUOR-RV ..
* 108 *
* 109 * A-STORAGE =SPACE          TEMPERATURE=(75) FLOOR-WEIGHT=150
* 110 *          VOLUME=400000 AREA=20000
* 111 *          LIGHTING-W/SQFT=1.5
* 112 *          LIGHTING-SCHEDULE=LT1 ..
* 113 *          UNDERGROUND-WALL AREA=12000 CONSTRUCTION=BW ..
* 114 *          UNDERGROUND-FLOOR AREA=20000 CONSTRUCTION=BW ..
* 115 *
* 116 *          SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=13.0 AZIMUTH=180 ..
* 117 *          SET-DEFAULT FOR WINDOW HEIGHT=6.5 Y=2.5 GLASS-TYPE=GT1
* 118 *          MAX-SOLAR-SCH=CLOSE-SHADE
* 119 *          WIN-SHADE-TYPE=MOVABLE-INTERIOR

```

```

* 120 *
* 121 *
* 122 *
* 123 *
* 124 * RZ1      =SPACE      SPACE-CONDITIONS=OFFICE VOLUME=107100
* 125 *          AREA=11900 NUMBER-OF-PEOPLE=60
* 126 *          AIR-CHANGES/HR=0.01 X=15 Y=15 Z=390 ..
* 127 * ROOF1    =ROOF        HEIGHT=170 WIDTH=70 AZIMUTH=180 TILT=0
* 128 *          GND-REFLECTANCE=0 CONSTRUCTION=RF ..
* 129 * IR22     =INTERIOR-WALL NEXT-TO R22 AREA=1530
* 130 *          CONSTRUCTION=SB-U ..
* 131 * IR23     =INTERIOR-WALL NEXT-TO R23 AREA=630
* 132 *          CONSTRUCTION=SB-U ..
* 133 * IR24     =INTERIOR-WALL LIKE IR22 NEXT-TO R24 ..
* 134 * IR25     =INTERIOR-WALL LIKE IR23 NEXT-TO R25 ..
* 135 *
* 136 * RZ2      =SPACE      SPACE-CONDITIONS=OFFICE VOLUME=24975
* 137 *          AREA=2775 NUMBER-OF-PEOPLE=28
* 138 *          AZIMUTH=-90 X=100 Y=200 Z=390 ..
* 139 * E2       =EXTERIOR-WALL WIDTH=200 CONSTRUCTION=WL1 ..
* 140 * W2       =WINDOW      WIDTH=200 ..
* 141 * ROOF2    =ROOF        HEIGHT=15 WIDTH=185 AZIMUTH=180 TILT=0
* 142 *          GND-REFLECTANCE=0 CONSTRUCTION=RF ..
* 143 *
* 144 * RZ3      =SPACE      SPACE-CONDITIONS= OFFICE VOLUME=11475
* 145 *          AREA=1275 NUMBER-OF-PEOPLE=13
* 146 *          AZIMUTH=180 X=100 Y=200 Z=390 ..
* 147 * E3       =EXTERIOR-WALL WIDTH=100 CONSTRUCTION=WL1 ..
* 148 * W3       =WINDOW      WIDTH=100 ..
* 149 * ROOF3    =ROOF        HEIGHT=15 WIDTH=85 AZIMUTH=180 TILT=0
* 150 *          GND-REFLECTANCE=0 CONSTRUCTION=RF ..
* 151 *
* 152 * RZ4      =SPACE      LIKE R22 AZIMUTH=90 X=0 Y=200 ..
* 153 *          EXTERIOR-WALL LIKE E2 ..
* 154 *          WINDOW      LIKE W2 ..
* 155 *          ROOF        LIKE ROOF2 ..
* 156 *
* 157 * RZ5      =SPACE      LIKE R23 AZIMUTH=0 X=0 Y=0 ..
* 158 *          EXTERIOR-WALL LIKE E3 ..
* 159 *          WINDOW      LIKE W3 ..
* 160 *          ROOF        LIKE ROOF3 ..
* 161 *
* 162 * T21      =SPACE      LIKE RZ1 FLOOR-MULTIPLIER=30 Z=195 ..
* 163 * IT22     =INTERIOR-WALL LIKE IR22 NEXT-TO T22 ..
* 164 * IT23     =INTERIOR-WALL LIKE IR23 NEXT-TO T23 ..
* 165 * IT24     =INTERIOR-WALL LIKE IR22 NEXT-TO T24 ..
* 166 * IT25     =INTERIOR-WALL LIKE IR23 NEXT-TO T25 ..
* 167 *
* 168 * T22      =SPACE      LIKE R22 FLOOR-MULTIPLIER=30 Z=195 ..
* 169 *          EXTERIOR-WALL LIKE E2 ..
* 170 *          WINDOW      LIKE W2 ..
* 171 *
* 172 * T23      =SPACE      LIKE R23 FLOOR-MULTIPLIER=30 Z=195 ..
* 173 *          EXTERIOR-WALL LIKE E3 ..
* 174 *          WINDOW      LIKE W3 ..
* 175 *
* 176 * T24      =SPACE      LIKE R24 FLOOR-MULTIPLIER=30 Z=195 ..
* 177 *          EXTERIOR-WALL LIKE E2 ..
* 178 *          WINDOW      LIKE W2 ..
* 179 *
* 180 * T25      =SPACE      LIKE R25 FLOOR-MULTIPLIER=30 Z=195 ..
* 181 *          EXTERIOR-WALL LIKE E3 ..
* 182 *          WINDOW      LIKE W3 ..

```

* 183 *
* 184 * END ..
* 185 * COMPUTE LOADS ..
* 186 * INPUT SYSTEMS ..

*** BUILDING ***

FLOOR AREA 640000 SQFT 59456 SQMT
 VOLUME 5980000 CUFT 169354 CUMT

TIME	COOLING LOAD				HEATING LOAD	
	***** JUL 9 4PM				***** JAN 1 7AM	
DRY-BULB TEMP	94F	34C			-1F	-18C
WET-BULB TEMP	74F	23C			-1F	-18C
	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
	-----	-----	-----	-----	-----	-----
WALL CONDUCTION	316.266	92.666	0.000	0.000	-826.453	-242.151
ROOF CONDUCTION	40.922	11.990	0.000	0.000	-143.559	-42.063
WINDOW GLASS+FRM COND	1681.924	492.804	0.000	0.000	-4335.515	-1270.306
WINDOW GLASS SOLAR	3562.686	1043.867	0.000	0.000	290.437	85.098
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-17.600	-5.157	0.000	0.000	-56.000	-16.408
OCCUPANTS TO SPACE	1014.692	297.305	780.200	228.598	0.000	0.000
LIGHT TO SPACE	2123.957	622.319	0.000	0.000	58.976	17.280
EQUIPMENT TO SPACE	1376.767	403.393	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	52.818	15.476	57.857	16.952	-1150.446	-337.081
	-----	-----	-----	-----	-----	-----
TOTAL	10152.430	2974.662	838.057	245.551	-6162.560	-1805.630
TOTAL LOAD	10990.487 KBTU/H		3220.213 KW		-6162.560 KBTU/H	-1805.630 KW
TOTAL LOAD / AREA	17.17BTU/H.SQFT		54.160 W /SQMT		9.629BTU/H.SQFT	30.368 W /SQMT

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *

REPORT- LS-D BUILDING MONTHLY LOADS SUMMARY

WEATHER FILE- TRY CHICAGO

----- COOLING -----							----- HEATING -----					----- ELEC -----		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	675.86096	25	16	48.F	42.F	4729.054	-1853.456	1	7	-1.F	-1.F	-6162.559	332713.	1470.000
FEB	690.91943	25	16	27.F	22.F	5383.071	-1533.816	4	6	7.F	6.F	-5747.923	314407.	1470.000
MAR	1013.27417	3	16	79.F	62.F	7047.375	-1015.720	24	6	8.F	7.F	-5839.985	377263.	1470.000
APR	1531.55164	27	15	82.F	61.F	8987.365	-456.614	8	6	32.F	29.F	-4188.527	361261.	1470.000
MAY	1839.31677	20	15	77.F	68.F	9168.952	-222.062	9	5	40.F	38.F	-2772.635	332713.	1470.000
JUN	2483.81152	4	15	85.F	67.F	9680.896	-43.781	23	5	52.F	48.F	-1251.471	361261.	1470.000
JUL	2974.76562	9	15	94.F	74.F	10152.431	-5.772	23	5	61.F	60.F	-508.765	347563.	1470.000
AUG	2669.71899	12	15	85.F	72.F	9566.644	-12.595	5	5	55.F	54.F	-684.197	362413.	1470.000
SEP	1839.88354	10	15	82.F	70.F	8846.675	-177.489	22	6	35.F	31.F	-2652.321	346411.	1470.000
OCT	1240.67822	5	15	74.F	62.F	7701.893	-462.705	21	6	30.F	29.F	-3022.637	332713.	1470.000
NOV	848.28888	2	15	75.F	61.F	7152.317	-1158.444	15	3	26.F	25.F	-4633.186	331560.	1470.000
DEC	690.18445	10	15	41.F	35.F	4795.656	-1704.426	9	6	14.F	13.F	-4923.012	347563.	1470.000
TOTAL	18498.254						-8646.882						4147840.	
MAX						10152.431						-6162.559		1470.000

31-Story Office Building, LOAD1 — Run 1 Systems, Plant, Economics

SDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993SDL RUN 1

```

* 187 * TITLE      LINE-4 *RUN 1 DUAL-DUCT VARIABLE VOLUME SYSTEM* ..
* 188 *
* 189 *           $ HVAC SYSTEM DESCRIPTION
* 190 *
* 191 * $ DESIGN TEMPS  COOLING 76F HEATING 70F.
* 192 * $ SYSTEM TYPE  A SINGLE DUAL DUCT VARIABLE VOLUME SYSTEM SERVES THE ENTIRE
* 193 * $                BUILDING. THE SYSTEM HAS A DRY BULB CONTROLLED ECONOMIZER WITH
* 194 * $                A LIMIT TEMP OF 68F, INLET VANES ON BOTH SUPPLY AND RETURN FANS,
* 195 * $                AND THE DD/VAV BOXES HAVE A MINIMUM STOP OF 30%. THE TEMPERATURE
* 196 * $                OF THE COLD DECK SUPPLY AIR IS CONTROLLED BY THE WARMEST ZONE
* 197 * $                AND THE HOT DECK AIR BY THE COLDEST ZONE. MINIMUM VENTILATION
* 198 * $                AIR IS 20 CFM/PERSON AND THE SYSTEM OPERATES FROM 7AM TO 6PM ON
* 199 * $                WEEKDAYS AND IS OFF WEEKENDS AND HOLIDAYS. THERE IS A LOW
* 200 * $                LIMIT SETPOINT OF 55F TO PREVENT FREEZING. FROM MAY 1 THRU NOV 1
* 201 * $                THE SYSTEM IS ALLOWED TO CYCLE ON TO PROVIDE NIGHT VENTILATION
* 202 * $                FOR FREE OA COOLING BUT ONLY IF THE SPACE TEMP IS ABOVE 74F.
* 203 *
* 204 *
* 205 *           SYSTEMS-REPORT      SUMMARY=(SS-A,SS-C,SS-D,SS-J) ..
* 206 *
* 207 *           $ SCHEDULES
* 208 *
* 209 * HRS1          = DAY-SCHEDULE (1,7) (0) (8,18) (1) (19,24) (0) ..
* 210 * HRS2          = DAY-SCHEDULE (1,24) (0) ..
* 211 * DAYS1         = WEEK-SCHEDULE (MON,FRI) HRS1 (WEH) HRS2 ..
* 212 * AHU-SCHED    = SCHEDULE THRU DEC 31  DAYS1 ..           $ FANS $
* 213 *
* 214 * SUMMER-VENT  = SCHEDULE THRU MAY 1 (ALL) (1,24) (0)
* 215 *                THRU NOV 1 (ALL) (1,24) (1)
* 216 *                THRU DEC 31 (ALL) (1,24) (0) ..
* 217 *
* 218 * VENT-SETPT   = SCHEDULE THRU DEC 31 (ALL) (1,24) (74) ..
* 219 *
* 220 * COOLON       = SCHEDULE THRU DEC 31 (ALL) (1,24) (55) ..
* 221 * HEATON       = SCHEDULE THRU DEC 31 (ALL) (1,24) (60) ..
* 222 *
* 223 * HRSH1        = DAY-SCHEDULE (1,7) (55) (8,18) (70) (19,24) (55) ..
* 224 * HRSH2        = DAY-SCHEDULE (1,24) (55) ..
* 225 * DAYHEAT      = WEEK-SCHEDULE (MON,FRI) HRSH1 (WEH) HRSH2 ..
* 226 * THEAT       = SCHEDULE THRU DEC 31  DAYHEAT ..           $ HEATING $
* 227 *
* 228 * HRSC1        = DAY-SCHEDULE (1,7) (99) (8,18) (76) (19,24) (99) ..
* 229 * HRSC2        = DAY-SCHEDULE (1,24) (99) ..
* 230 * DAYCOOL     = WEEK-SCHEDULE (MON,FRI) HRSC1 (WEH) HRSC2 ..
* 231 * TCOOL       = SCHEDULE THRU DEC 31  DAYCOOL ..           $ COOLING $
* 232 *
* 233 *
* 234 *           $ ZONE SUB-COMMANDS
* 235 *
* 236 * SAIR         = ZONE-AIR      OA-CFM/PER=20 ..
* 237 *
* 238 * CONTROL      = ZONE-CONTROL  HEAT-TEMP-SCH=THEAT COOL-TEMP-SCH=TCOOL
* 239 *                DESIGN-HEAT-T=70 DESIGN-COOL-T=74
* 240 *                THERMOSTAT-TYPE=REVERSE-ACTION ..
* 241 *

```

```

* 242 *           $ ZONE DESCRIPTION
* 243 *
* 244 * RZ1       = ZONE           ZONE-TYPE=CONDITIONED ZONE-AIR=SAIR
* 245 *           ZONE-CONTROL=CONTROL CFM/SQFT=.9 ..
* 246 *
* 247 * RZ2       = ZONE LIKE RZ1 ..
* 248 * RZ3       = ZONE LIKE RZ1 ..
* 249 * RZ4       = ZONE LIKE RZ1 ..
* 250 * RZ5       = ZONE LIKE RZ1 ..
* 251 * TZ1       = ZONE LIKE RZ1 ..
* 252 * TZ2       = ZONE LIKE TZ1 ..
* 253 * TZ3       = ZONE LIKE TZ1 ..
* 254 * TZ4       = ZONE LIKE TZ1 ..
* 255 * TZ5       = ZONE LIKE TZ1 ..
* 256 * A-STORAGE= ZONE LIKE RZ1 AIR-CHANGES/HR=4 OA-CHANGES=0.5 ..
* 257 *
* 258 *           $ SYSTEM SUB-COMMANDS
* 259 *
* 260 * S-CTRL    = SYSTEM-CONTROL COOLING-SCHEDULE=COOLON
* 261 *           HEATING-SCHEDULE=HEATON
* 262 *           HEAT-CONTROL=COLDEST COOL-CONTROL=WARMEST
* 263 *           MAX-SUPPLY-T=105 MIN-SUPPLY-T=55 ..
* 264 *
* 265 * S-FAN      = SYSTEM-FANS   FAN-SCHEDULE=AHU-SCHED FAN-CONTROL=INLET
* 266 *           SUPPLY-STATIC=5.5 SUPPLY-EFF=0.55
* 267 *           RETURN-STATIC=2.0 RETURN-EFF=0.55
* 268 *           NIGHT-VENT-CTRL=SCHEDULED+DEMAND
* 269 *           NIGHT-VENT-SCH=SUMMER-VENT
* 270 *           NIGHT-VENT-RATIOS=(1,1,0,0)
* 271 *           NIGHT-CYCLE-CTRL=CYCLE-ON-FIRST ..
* 272 *
* 273 * S-TERM     = SYSTEM-TERMINAL MIN-CFM-RATIO=0.3 ..
* 274 *
* 275 *           $ SYSTEMS DESCRIPTION
* 276 *
* 277 * DUAL-DUCT   = SYSTEM         SYSTEM-TYPE=DDS SYSTEM-CONTROL=S-CTRL
* 278 *           SYSTEM-FANS=S-FAN VENT-TEMP-SCH=VENT-SETPT
* 279 *           SYSTEM-TERMINAL=S-TERM RETURN-AIR-PATH=DUCT
* 280 *           ECONO-LIMIT-T=68 ZONE-NAMES=(RZ1,RZ2,RZ3,
* 281 *             RZ4,RZ5,TZ1,TZ2,TZ3,TZ4,TZ5,A-STORAGE)
* 282 *           SUPPLY-CFM=750000 ..
* 283 *
* 284 * PLANT1     = PLANT-ASSIGNMENT SYSTEM-NAMES = (DUAL-DUCT)
* 285 *           INT-ELEC-KW = 100 $ FOR ELEVATORS
* 286 *           INT-ELEC-SCH = 'CUP
* 287 *           DHW-SIZE=0
* 288 *           DHW-GAL/MIN = 2.22
* 289 *           DHW-SCH = OCCUP ..
* 290 *
* 291 * OC1        =DAY-SCHEDULE    (1,8) (0.) (9,10) (1.)
* 292 *           (11,13) (.8,.4,.8) (14,24) (1.,1.,1.,
* 293 *             .3.,1.,1.,1.,0.,0.,0.,0.) ..
* 294 * OC2        =DAY-SCHEDULE    (1,24) (0.0) ..
* 295 * PEOPLE     =WEEK-SCHEDULE   (MON,FRI) OC1 (WEH) OC2 ..
* 296 * OCCUP      =SCHEDULE        THRU DEC 31 PEOPLE ..
* 297 *
* 298 *
* 299 * END ..
* 300 * COMPUTE SYSTEMS ..
* 301 *
* 302 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993PDL RUN 1

```

* 303 *
* 304 * PLANT1 = PLANT-ASSIGNMENT ..
* 305 *
* 306 *           $ PLANT DESCRIPTION
* 307 *
* 308 * $ SCREW TYPE CHILLERS ARE ALLOWED TO RUN ONLY IF OA TEMPERATURE IS ABOVE 60F.
* 309 * $ THE GAS BOILER IS ALLOWED TO RUN ONLY IF OA TEMPERATURE IS BELOW 60F.
* 310 * $ THESE LIMITS ARE PLACED IN SYSTEMS INPUT VIA COOLING AND HEATING SCHEDULES.
* 311 * $ ALL PIECES OF EQUIPMENT ARE ALLOWED TO SIZE AUTOMATICALLY.
* 312 * $ THE CHILLED WATER PUMPS ARE VARIABLE SPEED WHEREAS THE HEATING PUMPS
* 313 * $ ARE CONSTANT SPEED (FLOW). CURVE-FIT COMMANDS ARE USED TO REPLACE THE STANDARD
* 314 * $ HERMETIC CENTRIFUGAL CHILLER DEFAULT CURVES AND THUS SIMULATE A SCREW TYPE
* 315 * $ CHILLER WITH MULTIPLE COMPRESSORS.
* 316 *
* 317 *           PLANT-REPORT           SUMMARY=(PS-A, BEPS) ..
* 318 *
* 319 * SBOIL      =PLANT-EQUIPMENT     TYPE=HW-BOILER  SIZE=-999  INSTALLED-NUMBER=2 ..
* 320 * DHWH       =PLANT-EQUIPMENT     TYPE=DHW-HEATER SIZE -999  INSTALLED-NUMBER=2 ..
* 321 *
* 322 *           PLANT-PARAMETERS       HCIRC-PUMP-TYPE=FIXED-SPEED
* 323 *                                           CCIRC-PUMP-TYPE=VARIABLE-SPEED ..
* 324 *
* 325 * CMPC       =PLANT-EQUIPMENT     TYPE=HERM-CENT-CHLR SIZE=-999
* 326 *                                           INSTALLED-NUMBER=2 ..
* 327 *
* 328 *
* 329 * CTOWER    =PLANT-EQUIPMENT     TYPE=COOLING-TWR SIZE=-999 ..
* 330 *
* 331 * PART-LOAD-RATIO TYPE=HERM-CENT-CHLR
* 332 * MIN-RATIO=0.1 MAX-RATIO=1.05 OPERATING-RATIO=0.4 E-I-R=.23 ..
* 333 *
* 334 * DIAGNOSTIC COMMENTS ..
* 335 *
* 336 * BLR-HIR-FPLR CURVE-FIT TYPE LINEAR
* 337 * DATA (1..1.) (.1..109) ..

```

```

COEFFICIENT( 1) = 0.01000000
COEFFICIENT( 2) = 0.99000001
COEFFICIENT( 3) = 0.00000000
COEFFICIENT( 4) = 0.00000000
COEFFICIENT( 5) = 0.00000000
COEFFICIENT( 6) = 0.00000000

```

INDEPENDENT	INPUT DEPENDENT	CALL DEPENDENT	DIFFERENCE	PRINT DIFF
1.000	1.000			
0.100	0.109	0.109	0.000	0.000

ROOT MEAN SQUARE DIFFERENCE = 0.000

```

* 338 * SCREW-EIR-FPLR CURVE-FIT TYPE QUADRATIC
* 339 * DATA (1.0,1.0) (.8,.7) (.6,.45) (.4,.25) (.2,.13) ..

```

```

COEFFICIENT( 1) = 0.05225713
COEFFICIENT( 2) = 0.22597121

```


COEFFICIENT(3) = 0.72177273
 COEFFICIENT(4) = 0.00000000
 COEFFICIENT(5) = 0.00000000
 COEFFICIENT(6) = 0.00000000

INDEPENDENT	INPUT DEPENDENT	CALL DEPENDENT	DIFFERENCE	PRINT DIFF
1.000	1.000			
0.800	0.700	0.695	0.005	0.719
0.600	0.450	0.448	0.002	0.516
0.400	0.250	0.258	-0.008	3.252
0.200	0.130	0.126	0.004	2.829

ROOT MEAN SQUARE DIFFERENCE = 0.006
 * 340 * SCREW-CAP-FT CURVE-FIT TYPE BI-QUADRATIC
 * 341 * DATA (44,85,1.0) (40,75,.97) (40,85,.94) (40,95,.90) (44,75,1.03)
 * 342 * (44,95,.96) (50,75,1.13) (50,85,1.1) (50,95,1.06) ..

COEFFICIENT(1) = 0.57026076
 COEFFICIENT(2) = 0.00093736
 COEFFICIENT(3) = 0.00016746
 COEFFICIENT(4) = 0.00501750
 COEFFICIENT(5) = -0.00005008
 COEFFICIENT(6) = -0.00000011

INDEPENDENT	INDEPENDENT	INPUT DEPENDENT	CALC DEPENDENT	DIFFERENCE	PRCNT DIFF
44.000	85.000	1.000			
40.000	75.000	0.970	0.970	0.000	0.003
40.000	85.000	0.940	0.940	0.000	0.003
40.000	95.000	0.900	0.900	0.000	0.005
44.000	75.000	1.030	1.030	0.000	0.005
44.000	95.000	0.960	0.960	0.000	0.007
50.000	75.000	1.130	1.130	0.000	0.002
50.000	85.000	1.100	1.100	0.000	0.003
50.000	95.000	1.060	1.060	0.000	0.006

ROOT MEAN SQUARE DIFFERENCE = 0.000
 * 343 * SCREW-EIR-FT CURVE-FIT TYPE BI-QUADRATIC
 * 344 * DATA (44,85,1.0) (40,75,.88) (40,85,1.06) (40,95,1.26) (44,75,.84)
 * 345 * (44,95,1.18) (50,75,.79) (50,85,.93) (50,95,1.09) ..

COEFFICIENT(1) = 0.03537060
 COEFFICIENT(2) = -0.00968459
 COEFFICIENT(3) = 0.00033442
 COEFFICIENT(4) = 0.01752476
 COEFFICIENT(5) = 0.00010020
 COEFFICIENT(6) = -0.00039319

INDEPENDENT	INDEPENDENT	INPUT DEPENDENT	CALC DEPENDENT	DIFFERENCE	PRCNT DIFF
44.000	85.000	1.000			
40.000	75.000	0.880	0.882	-0.002	0.173
40.000	85.000	1.060	1.060	0.000	0.017
40.000	95.000	1.260	1.258	0.002	0.146
44.000	75.000	0.840	0.837	0.003	0.334
44.000	95.000	1.180	1.182	-0.002	0.202
50.000	75.000	0.790	0.791	-0.001	0.097
50.000	85.000	0.930	0.930	0.000	0.027
50.000	95.000	1.090	1.089	0.001	0.113

ROOT MEAN SQUARE DIFFERENCE = 0.002
* 346 *
* 347 * DIAGNOSTIC WARNINGS ..
* 348 *
* 349 * EQUIPMENT-QUAD
* 350 * HW-BOILER-HIR-FPLR BLR-HIR-FPLR
* 351 * HERM-CENT-EIR-FPLR SCREW-EIR-FPLR
* 352 * HERM-CENT-CAP-FT SCREW-CAP-FT
* 353 * HERM-CENT-EIR-FT SCREW-EIR-FT ..
* 354 *
* 355 * END ..
* 356 * COMPUTE PLANT ..
* 357 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993EDL RUN 1

```
* 358 * ECONOMICS-REPORT S (ES-D,ES-E,ES-F) ..
* 359 *
* 360 *           $ ENERGY COST DESCRIPTION
* 361 *
* 362 * $ THE INPUT FOR UTILITY RATES IS THE SIMPLEST POSSIBLE, USING UNIFORM RATES
* 363 * $ FOR BOTH GAS AND ELECTRICITY. THERE IS A FIXED MONTHLY CHARGE AND A RATE
* 364 * $ LIMITATION ON ELECTRICITY OF 7 CENTS/KWH. THE DEMAND CHARGE IS A NOMINAL
* 365 * $ FLAT RATE OF 5 DOLLARS/KW YEAR-AROUND.
* 366 *
* 367 * ELBC-RATE = UTILITY-RATE RESOURCE=ELECTRICITY
* 368 *           MONTH-CHGS = (2000)
* 369 *           ENERGY-CHG = .055
* 370 *           DEMAND-CHGS = (5)
* 371 *           RATE-LIMITATION = .07 ..
* 372 *
* 373 * GAS-RATE = UTILITY-RATE RESOURCE=NATURAL-GAS
* 374 *           ENERGY-CHG =.70 .. $ DOLLARS/THERM
* 375 * END ..
* 376 * COMPUTE ECONOMICS ..
* 377 *
* 378 * INPUT SYSTEMS ..
```

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER			FLOOR AREA (SQFT)			MAX PEOPLE			
DUAL-DUCT	DDS	1.020			640000.0			4402.			
SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
765000.	880.282	3.6	765000.	320.102	1.3	0.122	24975.178	0.745	38507.746	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
R21	9964.	0.	0.000	0.300	1224.	0.00	0.00	204.47	0.00	-376.66	1.0
R22	4917.	0.	0.000	0.300	571.	0.00	0.00	100.91	0.00	-185.88	1.0
R23	1525.	0.	0.000	0.300	265.	0.00	0.00	31.29	0.00	-57.64	1.0
R24	4878.	0.	0.000	0.300	571.	0.00	0.00	100.09	0.00	-184.38	1.0
R25	2130.	0.	0.000	0.300	265.	0.00	0.00	43.72	0.00	-80.53	1.0
T21	9964.	0.	0.000	0.300	1224.	0.00	0.00	204.47	0.00	-376.66	30.0
T22	4942.	0.	0.000	0.300	571.	0.00	0.00	101.41	0.00	-186.81	30.0
T23	1484.	0.	0.000	0.300	265.	0.00	0.00	30.46	0.00	-56.11	30.0
T24	5276.	0.	0.000	0.300	571.	0.00	0.00	108.27	0.00	-199.45	30.0
T25	2225.	0.	0.000	0.300	265.	0.00	0.00	45.66	0.00	-84.11	30.0
A-STORAGE	24810.	0.	0.000	0.300	3400.	0.00	0.00	509.11	0.00	-937.83	1.0

SPACE SPACE1-1

MONTH	L I G H T I N G		E Q U I P M E N T		P R O C E S S	
	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	402.18	193.67	0.00	0.0000	0.0000
FEB	0.00	349.67	167.88	0.00	0.0000	0.0000
MAR	0.00	386.57	185.58	0.00	0.0000	0.0000
APR	0.00	400.28	193.16	0.00	0.0000	0.0000
MAY	0.00	402.18	193.67	0.00	0.0000	0.0000
JUN	0.00	369.07	176.99	0.00	0.0000	0.0000
JUL	0.00	402.18	193.67	0.00	0.0000	0.0000
AUG	0.00	402.18	193.67	0.00	0.0000	0.0000
SEP	0.00	369.07	176.99	0.00	0.0000	0.0000
OCT	0.00	402.18	193.67	0.00	0.0000	0.0000
NOV	0.00	353.47	168.90	0.00	0.0000	0.0000
DEC	0.00	386.57	185.58	0.00	0.0000	0.0000

ANNUAL	0.00	4625.43	2223.36	0.00	0.0000	0.0000

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- LS-K *BUILDING* INPUT FUELS SUMMARY

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 3

WEATHER FILE- TRY CHICAGO

BUILDING

MONTH	L I G H T I N G		E Q U I P M E N T		P R O C E S S	
	TASK LIGHTING (KWH)	TOTAL LIGHTING (KWH)	GENERAL EQUIPMENT (KWH)	PROCESS ELECTRIC (KWH)	PROCESS GAS (MBTU)	PROCESS HOT WATER (MBTU)
JAN	0.00	1904.24	917.01	0.00	0.0000	0.0000
FEB	0.00	1655.62	794.91	0.00	0.0000	0.0000
MAR	0.00	1830.37	878.71	0.00	0.0000	0.0000
APR	0.00	1895.24	914.61	0.00	0.0000	0.0000
MAY	0.00	1904.24	917.01	0.00	0.0000	0.0000
JUN	0.00	1747.50	838.01	0.00	0.0000	0.0000
JUL	0.00	1904.24	917.01	0.00	0.0000	0.0000
AUG	0.00	1904.24	917.01	0.00	0.0000	0.0000
SEP	0.00	1747.49	838.01	0.00	0.0000	0.0000
OCT	0.00	1904.24	917.01	0.00	0.0000	0.0000
NOV	0.00	1673.62	799.71	0.00	0.0000	0.0000
DEC	0.00	1830.37	878.71	0.00	0.0000	0.0000
ANNUAL	0.00	21903.13	10529.22	0.00	0.0000	0.0000

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- LS-L MANAGEMENT AND SOLAR SUMMARY FOR SPACE

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS
SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 3
WEATHER FILE- TRY CHICAGO

DATA FOR SPACE SPACE1-1

MONTH	NUMBER OF HOURS MANAGEMENT WOULD BE EMPLOYED	AVERAGE DAILY SOLAR RADIATION INTO SPACE (BTU/DAY)	MAXIMUM HOURLY SOLAR RADIATION INTO SPACE (BTU/HR)
JAN	0.	91833.594	44721.133
FEB	0.	106403.789	44042.688
MAR	0.	101484.391	40590.414
APR	0.	121678.523	32228.947
MAY	0.	114414.562	25011.039
JUN	0.	119506.453	19855.189
JUL	0.	124538.578	22544.020
AUG	0.	124817.953	28443.521
SEP	0.	141770.906	36432.680
OCT	0.	124279.734	41222.324
NOV	0.	92218.547	43065.477
DEC	0.	58324.055	42647.609
ANNUAL	0.	110041.141	44721.133

MMDDHH	GLOBAL DRY BULB TEMP F	GLOBAL WIND SPEED KNOTS	GLOBAL SOLAR BTU/HR- SQFT	BUILDING SENSIBLE CLG LOAD BTU/HR
	---- (4)	----(17)	----(15)	----(19)
8 5 1	77.2	6.5	0.0	13754.
8 5 2	75.4	6.5	0.0	11618.
8 5 3	73.9	6.5	0.0	9722.
8 5 4	72.7	6.5	0.0	8061.
8 5 5	71.8	6.5	0.0	6637.
8 5 6	71.2	6.5	14.7	9282.
8 5 7	71.0	6.5	73.7	16061.
8 5 8	71.8	6.5	136.0	48682.
8 5 9	73.9	6.5	191.7	54022.
8 510	77.2	6.5	237.0	58066.
8 511	81.0	6.5	268.7	59631.
8 512	84.8	6.5	284.9	58113.
8 513	88.1	6.5	284.3	66171.
8 514	90.2	6.5	266.9	73522.
8 515	91.0	6.5	234.1	77069.
8 516	90.8	6.5	188.0	78377.
8 517	90.2	6.5	131.6	79840.
8 518	89.3	6.5	69.1	66388.
8 519	88.1	6.5	11.3	51033.
8 520	86.6	6.5	0.0	41320.
8 521	84.8	6.5	0.0	33620.
8 522	83.0	6.5	0.0	29098.
8 523	81.0	6.5	0.0	25137.
8 524	79.0	6.5	0.0	21617.

DAILY SUMMARY (AUG 5)

MN	71.0	6.5	0.0	6637.
MX	91.0	6.5	284.9	79840.
SM	1944.0	156.4	2391.8	996843.
AV	81.0	6.5	99.7	41535.

MONTHLY SUMMARY (AUG)

MN	71.0	6.5	0.0	6637.
MX	91.0	6.5	284.9	79840.
SM	1944.0	156.4	2391.8	996843.
AV	81.0	6.5	99.7	41535.

YEARLY SUMMARY

MN	71.0	6.5	0.0	6637.
MX	91.0	6.5	284.9	79840.
SM	1944.0	156.4	2391.8	996843.
AV	81.0	6.5	99.7	41535.

	GLOBAL	GLOBAL	GLOBAL	BUILDING
	DRY BULB TEMP F	WIND SPEED KNOTS	GLOBAL SOLAR BTU/HR- SQFT	SENSIBLE CLG LOAD BTU/HR
	---- (.4)	---- (17)	---- (15)	---- (19)
8 5 1	61.0	7.0	0.0	2620.
8 5 2	59.0	0.0	0.0	1178.
8 5 3	57.0	4.0	0.0	358.
8 5 4	57.0	5.0	0.0	183.
8 5 5	55.0	4.0	0.0	146.
8 5 6	52.0	0.0	14.7	1928.
8 5 7	57.0	0.0	73.1	9782.
8 5 8	62.0	0.0	134.4	44195.
8 5 9	68.0	0.0	154.7	50107.
8 5 10	72.0	3.0	228.6	57516.
8 5 11	74.0	0.0	263.1	61080.
8 5 12	76.0	7.0	280.5	59162.
8 5 13	77.0	6.0	262.1	66258.
8 5 14	78.0	5.0	246.5	72205.
8 5 15	77.0	6.0	216.3	74465.
8 5 16	76.0	6.0	131.7	71804.
8 5 17	77.0	9.0	72.3	69819.
8 5 18	76.0	9.0	32.9	54277.
8 5 19	75.0	7.0	6.3	40991.
8 5 20	72.0	7.0	0.0	32576.
8 5 21	69.0	4.0	0.0	24984.
8 5 22	68.0	4.0	0.0	21017.
8 5 23	67.0	4.0	0.0	17755.
8 5 24	66.0	6.0	0.0	14905.
DAILY SUMMARY (AUG 5)				
MN	52.0	0.0	0.0	146.
MX	78.0	9.0	280.5	74465.
SM	1628.0	103.0	2117.3	849310.
AV	67.8	4.3	88.2	35388.
MONTHLY SUMMARY (AUG)				
MN	52.0	0.0	0.0	146.
MX	78.0	9.0	280.5	74465.
SM	1628.0	103.0	2117.3	849310.
AV	67.8	4.3	88.2	35388.
YEARLY SUMMARY				
MN	52.0	0.0	0.0	146.
MX	78.0	9.0	280.5	74465.
SM	1628.0	103.0	2117.3	849310.
AV	67.8	4.3	88.2	35388.

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

SYST-1

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE						
SYST-1	VAVS		1.020	5000.0		52.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/HR)	HEATING EIR (BTU/HR)
	6354.	7.311	3.6	0.	0.000	0.0	0.167	195.964	0.770	-44.161	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
SPACE5-1	1454.	0.	0.000	0.300	408.	0.00	0.00	25.13	-91.09	-75.39	1.0	
SPACE1-1	1909.	0.	0.000	0.300	224.	0.00	0.00	32.99	-119.59	-98.98	1.0	
SPACE2-1	887.	0.	0.000	0.300	102.	0.00	0.00	15.33	-55.58	-46.00	1.0	
SPACE3-1	1268.	0.	0.000	0.300	224.	0.00	0.00	21.92	-79.45	-65.75	1.0	
SPACE4-1	835.	0.	0.000	0.300	102.	0.00	0.00	14.42	-52.28	-43.26	1.0	
PLENUM-1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-D PLANT MONTHLY LOADS SUMMARY FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 DEFAULT-PLANT

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -					- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	0.00000				0.000	-32.540	7 8	-1.F	-1.F	-441.109	3078.	12.721	
FEB	0.00000				0.000	-25.221	4 8	7.F	6.F	-419.194	2665.	12.701	
MAR	0.00000				0.000	-15.190	25 8	14.F	12.F	-377.563	2904.	12.371	
APR	1.52664	29 18	69.F	65.F	68.311	-3.705	8 8	30.F	27.F	-246.024	2992.	13.298	
MAY	5.10064	21 14	85.F	75.F	132.661	-0.420	9 9	43.F	39.F	-40.320	3085.	14.424	
JUN	14.55954	20 16	90.F	77.F	178.041	0.000				0.000	3054.	15.339	
JUL	28.78266	8 16	92.F	74.F	214.902	0.000				0.000	3779.	18.322	
AUG	23.67940	19 16	90.F	71.F	183.011	0.000				0.000	3545.	17.242	
SEP	9.23581	11 16	86.F	72.F	138.083	-0.227	23 8	36.F	34.F	-99.033	2932.	15.530	
OCT	2.26933	4 17	78.F	61.F	49.778	-2.190	21 8	30.F	29.F	-258.277	2994.	12.617	
NOV	0.35773	1 16	72.F	59.F	54.561	-12.995	25 8	27.F	25.F	-325.673	2644.	13.017	
DEC	0.00000				0.000	-25.768	26 8	15.F	15.F	-393.064	2940.	12.345	
TOTAL	85.512					-118.258					36610.		
MAX					214.902					-441.109		18.322	
MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY)						2274.994 (KBTU)							
MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE)						2147.572 (KBTU)							

----- N U M B E R O F H O U R S -----											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	0	305	0	439	744	0	305	63	0	0	0.000	0.475
FEB	0	256	0	416	672	0	256	47	0	0	0.000	0.475
MAR	0	240	0	504	715	29	248	17	0	8	0.000	0.475
APR	69	102	0	549	516	204	229	0	0	58	0.000	11.735
MAY	115	40	0	589	485	259	220	0	0	65	0.000	13.348
JUN	203	0	0	517	171	549	207	0	0	4	0.000	15.156
JUL	241	0	0	503	7	737	241	0	0	0	0.000	17.942
AUG	238	0	0	506	43	701	238	0	0	0	0.000	16.987
SEP	155	13	0	552	346	374	205	0	0	37	0.000	14.658
OCT	99	86	1	560	511	233	225	0	0	41	0.000	11.103
NOV	12	186	0	522	686	34	209	1	0	11	0.000	12.583
DEC	0	276	0	468	744	0	276	45	0	0	0.000	0.475
ANNUAL	1132	1504	1	6125	5640	3120	2859	173	0	224		

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-M FAN ELECTRIC ENERGY FOR PLANT

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 DEFAULT-PLANT

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

MONTH	FAN ELECTRIC ENERGY DURING HEATING (KWH)	FAN ELECTRIC ENERGY DURING COOLING (KWH)	FAN ELECTRIC ENERGY DURING HEATING-COOLING (KWH)	FAN ELECTRIC ENERGY DURING FLOATING (KWH)
JAN	256.361	0.000	0.000	0.000
FEB	214.658	0.000	0.000	0.000
MAR	188.892	0.000	0.000	5.833
APR	77.282	59.311	0.000	45.241
MAY	29.165	172.787	0.000	61.428
JUN	0.000	465.212	0.000	3.377
JUL	0.000	957.790	0.000	0.000
AUG	0.000	723.851	0.000	0.000
SEP	9.505	303.856	0.000	32.739
OCT	63.882	77.672	0.729	31.766
NOV	148.524	13.215	0.000	8.918
DEC	230.728	0.000	0.000	0.000
ANNUAL	1218.994	2773.703	0.729	189.301

----- COOLING -----						----- HEATING -----					----- ELEC -----	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-32.540	7 8	-1.F	-1.F	-441.109	3078.	12.721
FEB	0.00000				0.000	-25.221	4 8	7.F	6.F	-419.194	2665.	12.701
MAR	0.00000				0.000	-15.190	25 8	14.F	12.F	-377.563	2904.	12.371
APR	1.52664	29 18	69.F	65.F	68.311	-3.705	8 8	30.F	27.F	-246.024	2992.	13.298
MAY	5.10064	21 14	85.F	75.F	132.661	-0.420	9 9	43.F	39.F	-40.320	3085.	14.424
JUN	14.55954	20 16	90.F	77.F	178.041	0.000				0.000	3054.	15.339
JUL	28.78266	8 16	92.F	74.F	214.902	0.000				0.000	3779.	18.322
AUG	23.67940	19 16	90.F	71.F	183.011	0.000				0.000	3545.	17.242
SEP	9.23581	11 16	86.F	72.F	138.083	-0.227	23 8	36.F	34.F	-99.033	2932.	15.530
OCT	2.26933	4 17	78.F	61.F	49.778	-2.190	21 8	30.F	29.F	-258.277	2994.	12.617
NOV	0.35773	1 16	72.F	59.F	54.561	-12.995	25 8	27.F	25.F	-325.673	2644.	13.017
DEC	0.00000				0.000	-25.768	26 8	15.F	15.F	-393.064	2940.	12.345
TOTAL	85.512					-118.258					36610.	
MAX					214.902					-441.109		18.322

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-B SYSTEM MONTHLY LOADS SUMMARY FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

- - ZONE COOLING - -		- - ZONE HEATING - -		- - BASEBOARDS - -		- - PREHEAT OR FURN FAN ELEC - -		
MONTH	COOLING BY ZONE COILS OR NAT VENTIL (MBTU)	MAXIMUM COOLING BY ZONE COILS OR NAT VENTIL (KBTU/HR)	HEATING BY ZONE COILS OR FURNACE (MBTU)	MAXIMUM HEATING BY ZONE COILS OR FURNACE (KBTU/HR)	BASEBOARD HEATING ENERGY (MBTU)	MAXIMUM BASEBOARD HEATING ENERGY (KBTU/HR)	PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (MBTU)	MAXIMUM PREHEAT COIL ENERGY OR ELEC FOR FURN FAN (KBTU/HR)
JAN	0.00000	0.000	-17.82038	-297.637	0.00000	0.000	-4.75593	-67.279
FEB	0.00000	0.000	-14.18888	-294.461	0.00000	0.000	-2.92867	-51.287
MAR	0.00000	0.000	-8.90534	-273.295	0.00000	0.000	-0.85343	-49.556
APR	0.00000	0.000	-2.10489	-209.516	0.00000	0.000	-0.02173	-8.605
MAY	0.00000	0.000	-0.07233	-20.454	0.00000	0.000	0.00000	0.000
JUN	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUL	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
AUG	0.00000	0.000	0.00000	0.000	0.00000	0.000	0.00000	0.000
SEP	0.00000	0.000	-0.09337	-63.534	0.00000	0.000	-0.00095	-0.948
OCT	0.00000	0.000	-1.16098	-195.242	0.00000	0.000	-0.02610	-7.933
NOV	0.00000	0.000	-8.25455	-257.724	0.00000	0.000	-0.21340	-15.096
DEC	0.00000	0.000	-15.28043	-282.811	0.00000	0.000	-1.52668	-42.234
TOTAL	0.000		-67.881		0.000		-10.327	
MAX		0.000		-297.637		0.000		-67.279

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-C SYSTEM MONTHLY LOAD HOURS FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

----- N U M B E R O F H O U R S ----- --COINCIDENT LOADS--

MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	0	305	0	439	744	0	305	63	0	0	0.000	0.475
FEB	0	256	0	416	672	0	256	47	0	0	0.000	0.475
MAR	0	240	0	504	711	29	248	17	0	8	0.000	0.475
APR	69	102	0	549	504	204	229	0	0	58	0.000	11.735
MAY	115	40	0	589	452	259	220	0	0	65	0.000	13.348
JUN	203	0	0	517	147	549	207	0	0	4	0.000	15.156
JUL	241	0	0	503	2	737	241	0	0	0	0.000	17.942
AUG	238	0	0	506	30	701	238	0	0	0	0.000	16.987
SEP	155	13	0	552	314	374	205	0	0	37	0.000	14.658
OCT	99	86	1	560	494	233	225	0	0	41	0.000	11.103
NOV	12	186	0	522	676	34	209	1	0	11	0.000	12.583
DEC	0	276	0	468	744	0	276	45	0	0	0.000	0.475
ANNUAL	1132	1504	1	6125	5490	3120	2859	173	0	224		

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-H SYSTEM MONTHLY LOADS SUMMARY FOR

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

MONTH	- FAN ELEC -		- FUEL HEAT -		- FUEL COOL -		- ELEC HEAT -		- ELEC COOL -	
	FAN ENERGY (KWH)	MAXIMUM FAN LOAD (KW)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)
JAN	256.	3.984	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
FEB	215.	3.878	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAR	195.	3.320	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
APR	182.	2.198	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
MAY	263.	2.955	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUN	469.	4.156	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
JUL	958.	7.304	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
AUG	724.	5.987	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
SEP	346.	4.123	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
OCT	173.	1.794	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
NOV	171.	3.021	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
DEC	231.	3.543	0.000	0.000	0.000	0.000	0.	0.000	0.	0.000
TOTAL	4181.		0.000		0.000		0.		0.	
MAX		7.304		0.000		0.000		0.000		0.000

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	0.00000	0.00000	0.000			-32.54049	0.00000	-441.10925
FEB	0.00000	0.00000	0.000			-25.22139	0.00000	-419.19385
MAR	0.00000	0.00000	0.000			-15.18957	0.00000	-377.56302
APR	1.46930	0.05734	68.311	0.848	29 18	-3.70518	0.00000	-246.024
MAY	4.54812	0.55252	132.661	0.777	21 14	-0.42017	0.00000	-40.320
JUN	13.34809	1.21146	178.041	0.793	20 16	0.00000	0.00000	0.000
JUL	25.94250	2.84016	214.902	0.883	8 16	0.00000	0.00000	0.000
AUG	21.18397	2.49544	183.011	0.919	19 16	0.00000	0.00000	0.000
SEP	8.60116	0.63464	138.083	0.849	11 16	-0.22747	0.00000	-99.033
OCT	2.17180	0.09753	49.778	1.000	4 17	-2.19046	0.00000	-258.277
NOV	0.35701	0.00072	54.561	1.000	1 16	-12.99550	0.00000	-325.673
DEC	0.00000	0.00000	0.000			-25.76809	0.00000	-393.06366
	-----	-----	-----	-----		-----	-----	-----
TOTAL	77.622	7.890				-118.258	0.000	
MAX			214.902	0.883				-441.109

- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
JUL 8				JAN 7			JUL 8			
HOURLY COOLING LOAD KBTU	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD KBTU	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD KBTU	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	76.F 68.F	0.000	6.F	6.F	0.000	0.000	76.F	68.F
2	0.000	0.000	76.F 68.F	-146.914	4.F	4.F	0.000	0.000	76.F	68.F
3	0.000	0.000	75.F 68.F	0.000	2.F	2.F	0.000	0.000	75.F	68.F
4	0.000	0.000	74.F 68.F	-155.152	2.F	2.F	0.000	0.000	74.F	68.F
5	0.000	0.000	73.F 67.F	0.000	2.F	2.F	0.000	0.000	73.F	67.F
6	0.000	0.000	72.F 67.F	-163.423	1.F	1.F	0.000	0.000	72.F	67.F
7	164.625 *	0.913	72.F 67.F	0.000	0.F	0.F	164.625 *	0.913	72.F	67.F
8	184.814 *	0.860	77.F 70.F	-441.109	-1.F	-1.F	184.814 *	0.860	77.F	70.F
9	182.204 *	0.855	83.F 72.F	-287.347	0.F	0.F	182.204 *	0.855	83.F	72.F
10	193.900 *	0.841	86.F 74.F	-233.795	2.F	1.F	193.900 *	0.841	86.F	74.F
11	196.262 *	0.865	89.F 74.F	-198.142	4.F	3.F	196.262 *	0.865	89.F	74.F
12	193.265 *	0.901	90.F 73.F	-167.741	6.F	5.F	193.265 *	0.901	90.F	73.F
13	202.205 *	0.898	91.F 73.F	-149.663	8.F	6.F	202.205 *	0.898	91.F	73.F
14	208.722 *	0.900	92.F 73.F	-128.669	9.F	7.F	208.722 *	0.900	92.F	73.F
15	214.902 *	0.883	92.F 74.F	-112.424	10.F	8.F	214.902 *	0.883	92.F	74.F
16	205.470	0.905	93.F 73.F	-106.730	9.F	7.F	205.470	0.905	93.F	73.F
17	201.179	0.903	93.F 73.F	-107.148	8.F	6.F	201.179	0.903	93.F	73.F
18	0.000	0.000	92.F 73.F	-115.849	5.F	4.F	0.000	0.000	92.F	73.F
19	0.000	0.000	90.F 72.F	0.000	4.F	3.F	0.000	0.000	90.F	72.F
20	0.000	0.000	83.F 70.F	0.000	2.F	1.F	0.000	0.000	83.F	70.F
21	0.000	0.000	82.F 68.F	0.000	3.F	2.F	0.000	0.000	82.F	68.F
22	0.000	0.000	82.F 70.F	0.000	4.F	3.F	0.000	0.000	82.F	70.F
23	0.000	0.000	82.F 70.F	0.000	4.F	3.F	0.000	0.000	82.F	70.F
24	0.000	0.000	80.F 69.F	0.000	5.F	4.F	0.000	0.000	80.F	69.F
SUM							2147.547			
MAX	214.902			-441.109						

SYSTEM-TYPE VAVS SQFT/TON 279.2
 COOLING PEAK 42.98 (BTU/HR- SQFT) HEATING PEAK -88.22 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.27 (CFM/SQFT) MIN-OA/PERSON 20.40 (CFM)
 OA FRAC AT CLG PEAK 0.172 OA FRAC AT HTG PEAK 0.230

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	AVERAGE SPACE TEMP					AVERAGE TEMPERATURE DIFFERENCE			SUMMED TEMP DIFFERENCE		HUMIDITY RATIO DIFFERENCE BETWEEN OUTDOOR AND ROOM AIR (FRAC.OR MULT.)
	ALL HOURS (F)	COOLING HOURS (F)	HEATING HOURS (F)	FAN ON HOURS (F)	FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN ON HOURS (F)	BETWEEN OUTDOOR& ROOM AIR FAN OFF HOURS (F)	BETWEEN OUTDOOR& ROOM AIR HEATING HOURS (F)	BETWEEN OUTDOOR& ROOM AIR ALL HOURS (F)	
JAN	62.16		65.65	65.65	59.74	-36.82	-40.46	-34.29	514.20	1141.49	-0.00103
FEB	62.36		66.19	66.19	60.00	-34.84	-38.08	-32.85	406.20	975.57	-0.00091
MAR	65.34		68.59	68.71	63.66	-26.97	-30.75	-25.09	311.82	840.66	-0.00110
APR	71.74	74.21	70.63	72.68	71.31	-20.15	-19.85	-20.29	116.27	607.26	-0.00082
MAY	75.54	77.37	71.89	75.96	75.36	-18.76	-15.96	-19.94	41.85	583.60	-0.00072
JUN	79.66	78.22		78.16	80.27	-12.57	-6.37	-15.07		387.11	-0.00075
JUL	82.88	79.19		79.19	84.65	-7.31	-1.39	-10.15		289.98	0.00127
AUG	80.77	78.62		78.62	81.79	-8.93	-2.62	-11.89		310.85	0.00056
SEP	77.10	77.70	71.08	76.84	77.21	-15.72	-9.76	-18.09	12.59	482.64	-0.00109
OCT	71.86	74.74	70.77	73.07	71.34	-18.22	-15.71	-19.30	86.06	564.90	-0.00107
NOV	66.11	76.39	69.27	69.92	64.54	-25.16	-29.14	-23.53	240.00	754.84	-0.00068
DEC	62.48		66.48	66.48	60.13	-30.75	-34.66	-28.45	398.62	953.37	-0.00099
ANNUAL	71.55	77.78	67.66	72.23	71.23	-21.27	-21.42	-21.20	2127.60	7892.27	-0.00061

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-L FAN ELECTRIC ENERGY

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

MONTH	FAN ELEC DURING HEATING (KWH)	FAN ELEC DURING COOLING (KWH)	FAN ELEC DURING HEAT & COOL (KWH)	FAN ELEC DURING FLOATING (KWH)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	256.361	0.000	0.000	0.000	0	0	0	286	10	4	4	1	0	0	0	305
FEB	214.658	0.000	0.000	0.000	0	0	0	239	10	3	3	1	0	0	0	256
MAR	188.892	0.000	0.000	5.833	0	0	0	242	3	1	2	0	0	0	0	248
APR	77.282	59.311	0.000	45.241	0	0	0	216	11	2	0	0	0	0	0	229
MAY	29.165	172.787	0.000	61.428	0	0	0	144	45	27	4	0	0	0	0	220
JUN	0.000	465.212	0.000	3.377	0	0	0	23	49	80	51	4	0	0	0	207
JUL	0.000	957.790	0.000	0.000	0	0	0	1	9	35	72	66	29	28	1	241
AUG	0.000	723.851	0.000	0.000	0	0	0	9	24	62	91	40	12	0	0	238
SEP	9.505	303.856	0.000	32.739	0	0	0	88	45	37	32	3	0	0	0	205
OCT	63.882	77.672	0.729	31.766	0	0	0	224	1	0	0	0	0	0	0	225
NOV	148.524	13.215	0.000	8.918	0	0	0	200	5	2	2	0	0	0	0	209
DEC	230.728	0.000	0.000	0.000	0	0	0	259	11	0	6	0	0	0	0	276
ANNUAL	1218.994	2773.703	0.729	189.301	0	0	0	1931	223	253	267	115	41	28	1	2859

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY

HR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
80-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1
70-80	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	0	1	1	0	0	0	0	0	0	0	4
60-70	0	0	0	0	0	0	0	6	5	5	5	4	4	2	2	3	3	3	0	0	0	0	0	0	0	42
50-60	0	0	0	0	0	0	0	45	58	57	53	32	33	29	28	34	35	4	0	0	0	0	0	0	0	408
40-50	0	0	0	0	0	0	0	42	43	45	41	60	61	69	66	59	61	9	0	0	0	0	0	0	0	556
30-40	0	0	0	0	0	0	0	26	62	61	57	49	38	48	52	55	51	27	0	0	0	0	0	0	0	526
0-30	0	0	0	0	0	0	0	7	83	84	96	107	116	103	103	100	101	83	0	0	0	0	0	0	0	983
*** **																										

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-G ZONE LOADS SUMMARY IN

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1 FOR SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

C O O L I N G					H E A T I N G					E L E C		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-4.040	7 8	-1.F	-1.F	-71.992	596.	2.429
FEB	0.00000				0.000	-3.251	4 8	7.F	6.F	-70.902	518.	2.429
MAR	0.00000				0.000	-2.057	25 8	14.F	12.F	-65.053	572.	2.429
APR	0.00000				0.000	-0.553	1 8	43.F	39.F	-45.566	593.	2.429
MAY	0.00000				0.000	-0.034	13 9	47.F	43.F	-8.113	596.	2.429
JUN	0.00000				0.000	0.000				0.000	546.	2.429
JUL	0.00000				0.000	0.000				0.000	596.	2.429
AUG	0.00000				0.000	0.000				0.000	596.	2.429
SEP	0.00000				0.000	-0.030	23 8	36.F	34.F	-17.036	546.	2.429
OCT	0.00000				0.000	-0.265	21 8	30.F	29.F	-43.523	596.	2.429
NOV	0.00000				0.000	-1.979	18 8	34.F	34.F	-58.601	522.	2.429
DEC	0.00000				0.000	-3.595	26 8	15.F	15.F	-66.874	572.	2.429
TOTAL	0.000					-15.804					6849.	
MAX					0.000					-71.992		2.429

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-F ZONE DEMAND SUMMARY IN

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1 FOR SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1
 WEATHER FILE- TRY CHICAGO

- - - - DEMANDS - - - - - BASEBOARDS - - - - - TEMPERATURES - - - - - LOADS NOT MET - -

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.32026	-3.393	0.00000	0.000	76.3	55.8	0	0
FEB	0.31210	-2.703	0.00000	0.000	76.1	55.8	0	0
MAR	0.62230	-1.443	0.00000	0.000	75.4	55.9	0	0
APR	1.70057	-0.336	0.00000	0.000	77.7	67.0	7	0
MAY	2.46513	-0.006	0.00000	0.000	77.9	70.9	0	0
JUN	3.35010	0.000	0.00000	0.000	78.3	75.1	0	0
JUL	5.25626	0.000	0.00000	0.000	79.1	76.7	0	0
AUG	4.63841	0.000	0.00000	0.000	78.9	76.5	0	0
SEP	3.21619	-0.015	0.00000	0.000	78.6	70.7	0	0
OCT	1.96739	-0.144	0.00000	0.000	77.9	70.3	0	0
NOV	0.62700	-1.258	0.00000	0.000	77.9	55.9	0	0
DEC	0.16774	-2.819	0.00000	0.000	75.2	55.8	0	0

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SS-0 TEMPERATURE SCATTER PLOT

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 SYST-1 FOR SPACE1-1

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	0	0	0	0	0	0	0	88	90	96	100	106	119	132	141	144	139	15	0	0	0	0	0	0	1170
70-75	0	0	0	0	0	0	0	38	162	156	152	145	132	119	110	107	112	110	0	0	0	0	0	0	1343
65-70	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	0	0	0	0	7	
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

*** ** **

MMDDHH	GLOBAL	GLOBAL	SPACE1-1	SPACE1-1	SPACE1-1	SYST-1	SYST-1	SYST-1
	DRY BULB TEMP F	WET BULB TEMP F	THERMOST SETPOINT F	ZONE TEMP F	EXTRACTN RATE BTU/HR	CLG COIL AIR TEMP F	RETURN AIR TEMP F	TOT CLG COIL PWR BTU/HR
	----(8)	----(7)	----(7)	----(6)	----(8)	----(2)	----(4)	----(6)
8 5 1	77.2	67.0	-999.0	96.6	0.	0.0	0.0	0.
8 5 2	75.4	66.1	-999.0	96.0	0.	0.0	0.0	0.
8 5 3	73.9	65.4	-999.0	95.5	0.	0.0	0.0	0.
8 5 4	72.7	64.7	-999.0	95.0	0.	0.0	0.0	0.
8 5 5	71.8	64.2	-999.0	94.5	0.	0.0	0.0	0.
8 5 6	71.2	63.9	78.0	80.9	48692.	58.5	87.5	178437.
8 5 7	71.0	63.8	78.0	80.1	36040.	58.3	85.0	166582.
8 5 8	71.8	64.0	78.0	79.7	35092.	58.2	82.6	160428.
8 5 9	73.9	64.8	78.0	79.3	34929.	58.0	82.7	165387.
8 510	77.2	66.2	78.0	79.0	34343.	57.9	83.4	173594.
8 511	81.0	67.8	78.0	79.0	33277.	58.0	84.2	180833.
8 512	84.8	69.5	78.0	78.9	32766.	58.0	85.2	187542.
8 513	88.1	71.1	78.0	79.1	33921.	57.9	86.0	201795.
8 514	90.2	72.2	78.0	79.7	34452.	58.0	86.7	211104.
8 515	91.0	72.7	78.0	79.9	35136.	58.0	87.2	217218.
8 516	90.8	72.8	78.0	79.9	35286.	58.0	87.3	218057.
8 517	90.2	72.6	78.0	79.7	35052.	58.0	86.9	213977.
8 518	89.3	72.3	-999.0	87.8	0.	0.0	0.0	0.
8 519	88.1	71.8	-999.0	88.8	0.	0.0	0.0	0.
8 520	86.6	71.2	-999.0	89.2	0.	0.0	0.0	0.
8 521	84.8	70.4	-999.0	88.9	0.	0.0	0.0	0.
8 522	83.0	69.6	-999.0	88.6	0.	0.0	0.0	0.
8 523	81.0	68.8	-999.0	88.3	0.	0.0	0.0	0.
8 524	79.0	67.9	-999.0	88.0	0.	0.0	0.0	0.
DAILY SUMMARY (AUG 5)								
MN	71.0	63.8	-999.0	78.9	0.	0.0	0.0	0.
MX	91.0	72.8	78.0	96.6	48692.	58.5	87.5	218057.
SM	1944.0	1640.8	-11052.0	2052.5	428985.	696.7	1024.7	2274955.
AV	81.0	68.4	-460.5	85.5	17874.	29.0	42.7	94790.
MONTHLY SUMMARY (AUG)								
MN	71.0	63.8	-999.0	78.9	0.	0.0	0.0	0.
MX	91.0	72.8	78.0	96.6	48692.	58.5	87.5	218057.
SM	1944.0	1640.8	-11052.0	2052.5	428985.	696.7	1024.7	2274955.
AV	81.0	68.4	-460.5	85.5	17874.	29.0	42.7	94790.
YEARLY SUMMARY								
MN	71.0	63.8	-999.0	78.9	0.	0.0	0.0	0.
MX	91.0	72.8	78.0	96.6	48692.	58.5	87.5	218057.
SM	1944.0	1640.8	-11052.0	2052.5	428985.	696.7	1024.7	2274955.
AV	81.0	68.4	-460.5	85.5	17874.	29.0	42.7	94790.

	GLOBAL	GLOBAL	SPACE1-1	SPACE1-1	SPACE1-1	SYST-1	SYST-1	SYST-1
	DRY BULB TEMP F	WET BULB TEMP F	THERMOST SETPOINT F	ZONE TEMP F	EXTRACTN RATE BTU/HR	CLG COIL AIR TEMP F	RETURN AIR TEMP F	TOT CLG COIL PWR BTU/HR
	----(8)	----(7)	----(7)	----(6)	----(8)	----(2)	----(4)	----(6)
8 5 1	61.0	59.0	-999.0	80.5	0.	0.0	0.0	0.
8 5 2	59.0	58.0	-999.0	80.1	0.	0.0	0.0	0.
8 5 3	57.0	56.0	-999.0	79.6	0.	0.0	0.0	0.
8 5 4	57.0	56.0	-999.0	79.2	0.	0.0	0.0	0.
8 5 5	55.0	54.0	-999.0	78.7	0.	0.0	0.0	0.
8 5 6	52.0	50.0	-999.0	78.4	0.	0.0	0.0	0.
8 5 7	57.0	54.0	-999.0	78.3	0.	0.0	0.0	0.
8 5 8	62.0	58.0	78.0	77.1	11085.	58.5	71.4	11565.
8 5 9	68.0	61.0	78.0	77.1	12717.	57.3	74.8	52275.
8 510	72.0	63.0	78.0	77.3	14571.	57.9	77.4	70249.
8 511	74.0	64.0	78.0	77.5	16788.	57.8	80.4	86804.
8 512	76.0	63.0	78.0	77.7	18073.	57.8	83.1	92040.
8 513	77.0	63.0	78.0	77.9	21113.	57.6	84.9	108793.
8 514	78.0	63.0	78.0	78.2	23954.	57.7	85.7	120845.
8 515	77.0	62.0	78.0	78.3	25580.	57.8	86.0	124485.
8 516	76.0	62.0	78.0	78.3	25080.	57.9	85.9	119886.
8 517	77.0	62.0	78.0	78.2	23640.	57.9	85.2	114577.
8 518	76.0	61.0	-999.0	83.2	0.	0.0	0.0	0.
8 519	75.0	61.0	-999.0	83.7	0.	0.0	0.0	0.
8 520	72.0	59.0	-999.0	83.7	0.	0.0	0.0	0.
8 521	69.0	58.0	-999.0	83.2	0.	0.0	0.0	0.
8 522	68.0	57.0	-999.0	82.8	0.	0.0	0.0	0.
8 523	67.0	58.0	-999.0	82.5	0.	0.0	0.0	0.
8 524	66.0	57.0	-999.0	82.0	0.	0.0	0.0	0.
DAILY SUMMARY (AUG 5)								
MN	52.0	50.0	-999.0	77.1	0.	0.0	0.0	0.
MX	78.0	64.0	78.0	83.7	25580.	58.5	86.0	124485.
SM	1628.0	1419.0	-13206.0	1913.5	192601.	578.1	814.8	901518.
AV	67.8	59.1	-550.2	79.7	8025.	24.1	33.9	37563.
MONTHLY SUMMARY (AUG)								
MN	52.0	50.0	-999.0	77.1	0.	0.0	0.0	0.
MX	78.0	64.0	78.0	83.7	25580.	58.5	86.0	124485.
SM	1628.0	1419.0	-13206.0	1913.5	192601.	578.1	814.8	901518.
AV	67.8	59.1	-550.2	79.7	8025.	24.1	33.9	37563.
YEARLY SUMMARY								
MN	52.0	50.0	-999.0	77.1	0.	0.0	0.0	0.
MX	78.0	64.0	78.0	83.7	25580.	58.5	86.0	124485.
SM	1628.0	1419.0	-13206.0	1913.5	192601.	578.1	814.8	901518.
AV	67.8	59.1	-550.2	79.7	8025.	24.1	33.9	37563.

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-A EQUIPMENT SIZES

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	0.457	1 1										
HEM-REC-CHLR	0.222	1 1										

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-B COST REFERENCE DATA (USED FOR DEFAULT COSTS)

DIVIDE INTO ZONES: ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	SIZE (MBTU)	UNIT COST (K\$)	INSTALD COST FACTOR	CONSUM- ABLES (\$/HR)	MAINTA- NANCE (HRS/YR)	EQPMT LIFE (HRS)	HOURS ALREADY USED	HRS TO MINOR OVHAUL	MINOR OVHAUL COST (\$)	HRS TO MAJOR OVHAUL	MAJOR OVHAUL COST (\$)
HW-BOILER	40.000	300.000	1.400	0.000	8.0	220000.	0.	10000.	2000.	50000.	25000.
HEM-REC-CHLR	12.000	100.000	1.200	0.000	16.0	100000.	0.	20000.	5000.	50000.	15000.

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-C EQUIPMENT COSTS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	SIZE (MBTU)	UNIT COST (K\$)	INSTALD COST FACTOR	CONSUM- ABLES (\$/HR)	MAINTA- NANCE (HRS/YR)	EQPMT LIFE (HRS)	HOURS ALREADY USED	HRS TO MINOR OVHAUL	MINOR OVHAUL COST (\$)	HRS TO MAJOR OVHAUL	MAJOR OVHAUL COST (\$)
MW-BOILER	0.457	15.003	1.400	0.000	3.3	140687.	0.	4089.	100.	20447.	1250.
HEM-REC-CHLR	0.222	6.911	1.200	0.000	7.2	67112.	0.	9008.	346.	22520.	1037.

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PV-E EQUIPMENT LOAD RATIOS

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	PART LOAD RATIOS			ELECTRIC INPUT TO NOMINAL CAPACITY RATIO (BTU/BTU)
	MINIMUM	MAXIMUM	OPTIMUM	
HW-BOILER	0.2500	1.2000	1.0000	0.0220
HEM-RBC-CHLR	0.2500	1.0000	1.0000	0.2740

N A M E	COEFF 1	COEFF 2	COEFF 3	COEFF 4	COEFF 5	COEFF 6
STM-BOILER-HIR-F	0.082597	0.996764	-0.079361	0.000000	0.000000	0.000000
HW-BOILER-HIR-FP	0.082597	0.996764	-0.079361	0.000000	0.000000	0.000000
FURNACE-HIR-FPLR	0.018610	1.094209	-0.112819	0.000000	0.000000	0.000000
DHW-HIR-FPLR	0.021826	0.977630	0.000543	0.000000	0.000000	0.000000
OPEN-CENT-CAP-FT	-1.742040	0.029292	-0.000067	0.048054	-0.000291	-0.000106
OPEN-REC-CAP-FT	-4.161461	0.207050	-0.001931	0.004723	-0.000040	-0.000087
HERM-CENT-CAP-FT	-1.742040	0.029292	-0.000067	0.048054	-0.000291	-0.000106
HERM-REC-CAP-FT	-4.161461	0.207050	-0.001931	0.004723	-0.000040	-0.000087
OPEN-CENT-EIR-FT	3.117500	-0.109236	0.001389	0.003750	0.000150	-0.000375
OPEN-REC-EIR-FT	4.720965	-0.187504	0.002192	0.009209	0.000098	-0.000322
HERM-CENT-EIR-FT	3.117500	-0.109236	0.001389	0.003750	0.000150	-0.000375
HERM-REC-EIR-FT	4.720965	-0.187504	0.002192	0.009209	0.000098	-0.000322
OPEN-CENT-EIR-FP	0.222903	0.313387	0.463710	0.000000	0.000000	0.000000
OPEN-REC-EIR-FPL	0.088065	1.137742	-0.225806	0.000000	0.000000	0.000000
HERM-CENT-EIR-FP	0.222903	0.313387	0.463710	0.000000	0.000000	0.000000
HERM-REC-EIR-FPL	0.088065	1.137742	-0.225806	0.000000	0.000000	0.000000
DBUN-CAP-FT	-1.742040	0.029292	-0.000067	0.048054	-0.000291	-0.000106
DBUN-EIR-FT	3.117500	-0.109236	0.001389	0.003750	0.000150	-0.000375
DBUN-EIR-FPLR	0.349032	0.263871	0.387097	0.000000	0.000000	0.000000
DBUN-CAP-FTRISE	1.000000	-0.005650	-0.000305	0.000000	0.000000	0.000000
DBUN-EIR-FTRISE	1.000000	0.012250	0.000175	0.000000	0.000000	0.000000
ABSOR1-CAP-FT	0.723412	0.079006	-0.000897	-0.025285	-0.000048	0.000276
ABSOR2-CAP-FT	-0.816039	-0.038707	0.000450	0.071491	-0.000636	0.000312
ABSORG-CAP-FT	1.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSORS-CAP-FT	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSORS-CAP-FTS	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSOR1-HIR-FT	0.652273	0.000000	0.000000	-0.000545	0.000055	0.000000
ABSOR2-HIR-FT	1.658750	0.000000	0.000000	-0.029000	0.000250	0.000000
ABSORG-HIR-FT	4.428713	-0.132986	0.001253	0.000000	0.000000	0.000000
ABSORS-HIR-FT	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSORS-HIR-FTS	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
ABSOR1-HIR-FPLR	0.087773	0.744921	0.167306	0.000000	0.000000	0.000000
ABSOR2-HIR-FPLR	0.135512	0.617981	0.246513	0.000000	0.000000	0.000000
ABSORG-HIR-FPLR	0.135512	0.617981	0.246513	0.000000	0.000000	0.000000
ABSORS-HIR-FPLR	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
TWR-GPM-FRA	-2.228889	0.166795	-0.014102	0.032223	0.185602	0.242519
TWR-GPM-FWB	0.605314	-0.035545	0.008041	-0.028603	0.000250	0.004909
TWR-FAN-FPLR	0.331629	-0.885676	0.605565	0.948482	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
DIESEL-I/O-FPLR	0.107000	0.893000	0.000000	0.000000	0.000000	0.000000
DIESEL-EXH-FPLR	0.024516	0.332387	0.643097	0.000000	0.000000	0.000000
DIESEL-JCLB-FPLR	0.287936	1.020452	-0.308387	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
GTURB-I/O-FPLR	0.442979	0.397400	0.156962	0.000000	0.000000	0.000000
GTURB-EXH-FPLR	0.295626	0.493019	0.211355	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
GTURB-CAP-FT	1.240000	-0.004100	0.000000	0.000000	0.000000	0.000000
**	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
STURB-ENTH-FPLX	38.792358	-0.211386	0.000529	1.020087	0.000917	-0.003499
STURB-I/O-FPLR	0.488308	0.994154	-0.482462	0.000000	0.000000	0.000000

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-G EQUIPMENT QUADRATICS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

(CONTINUED)

N A M E	COEFF 1	COEFF 2	COEFF 3	COEFF 4	COEFF 5	COEFF 6
TC-CHLR-CAP-FT	-0.351443	0.056583	-0.000054	-0.045625	-0.000043	-0.000012
ABSORG-HIR1-FTI	0.861737	-0.007089	0.000103	0.000000	0.000000	0.000000
ABSORG-HIR2-FTI	0.814450	0.000824	0.000013	0.000000	0.000000	0.000000
ABSORG-QCOND-FTI	0.640000	-0.001300	0.000000	0.000000	0.000000	0.000000
ABSG-HCAP-FQC	0.863599	-1.304953	0.441353	0.000000	0.000000	0.000000
ENG-CH-CAP-FT	0.573597	0.018680	0.000000	-0.004653	0.000000	0.000000
ENG-CH-COP-FPLR1	1.143357	0.022890	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FPLR2	1.388614	-0.388614	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FT	1.236238	0.016892	0.000000	-0.011524	0.000000	0.000000
ENG-CH-HREJ-FPLR	1.052699	-0.052699	0.000000	0.000000	0.000000	0.000000
ENG-CH-HREJ-FT	0.705841	0.003461	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FPLRS	0.380200	2.360900	0.000000	0.000000	0.000000	0.000000
ENG-CH-COP-FTS	1.088152	0.014106	0.000000	-0.008339	0.000000	0.000000

MONTH	S I T E E N E R G Y												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	33.5	0.0	3.9	0.0	0.0	0.0	0.0	51.6	0.8	0.0	51.6	64.9	91.7
FEB	26.0	0.0	3.3	0.0	0.0	0.0	0.0	40.2	0.7	0.0	40.2	51.5	74.3
MAR	15.9	0.0	3.4	0.0	0.0	0.0	0.0	25.0	0.5	0.0	25.0	36.5	59.6
APR	4.0	1.8	3.4	0.0	0.0	0.0	0.3	6.4	0.1	0.0	6.4	18.0	41.4
MAY	0.5	5.6	3.9	0.0	0.0	0.0	0.7	0.9	0.0	0.0	0.9	14.0	40.4
JUN	0.0	15.4	4.9	0.0	0.0	0.0	1.9	0.0	0.0	0.0	0.0	16.8	50.5
JUL	0.0	29.8	7.0	0.0	0.0	0.0	3.2	0.0	0.0	0.0	0.0	23.9	71.6
AUG	0.0	24.7	6.4	0.0	0.0	0.0	2.8	0.0	0.0	0.0	0.0	21.7	65.0
SEP	0.3	9.9	4.2	0.0	0.0	0.0	1.3	0.4	0.0	0.0	0.4	14.8	43.4
OCT	2.5	2.7	3.5	0.0	0.0	0.0	0.4	3.9	0.1	0.0	3.9	15.9	40.0
NOV	13.6	0.4	3.1	0.0	0.0	0.0	0.1	21.3	0.4	0.0	21.3	31.9	53.0
DEC	26.6	0.0	3.7	0.0	0.0	0.0	0.0	41.5	0.7	0.0	41.5	53.9	78.9
TOTAL	122.8	90.5	50.6	0.0	0.0	0.0	10.7	191.1	3.4	0.0	191.1	363.9	709.7

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413./KWH	METER-1 100000./THERMS
JAN			
	ENERGY CONSUMPTION (UNITS/MO)	3918.1	515.5
	PEAK DEMAND (UNITS/HR OR DAY)	16.2	5.6
	PEAK DAY/HR	7/ 9	7/ 8
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	3333.6	401.5
	PEAK DEMAND (UNITS/HR OR DAY)	16.1	5.3
	PEAK DAY/HR	4/ 9	4/ 8
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	3377.5	250.2
	PEAK DEMAND (UNITS/HR OR DAY)	15.8	4.9
	PEAK DAY/HR	25/ 9	25/ 8
APR			
	ENERGY CONSUMPTION (UNITS/MO)	3417.1	63.8
	PEAK DEMAND (UNITS/HR OR DAY)	22.2	3.4
	PEAK DAY/HR	29/15	8/ 8
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	3857.1	8.8
	PEAK DEMAND (UNITS/HR OR DAY)	28.4	0.7
	PEAK DAY/HR	21/14	9/ 9
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	4933.9	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	33.8	0.0
	PEAK DAY/HR	20/16	0/ 0
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	6989.9	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	39.2	0.0
	PEAK DAY/HR	8/15	0/ 0
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	6351.4	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	36.0	0.0
	PEAK DAY/HR	19/16	0/ 0
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	4196.0	4.4
	PEAK DEMAND (UNITS/HR OR DAY)	30.7	1.7
	PEAK DAY/HR	11/15	23/ 8
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	3519.4	39.2
	PEAK DEMAND (UNITS/HR OR DAY)	19.8	3.6
	PEAK DAY/HR	31/15	21/ 8
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	3098.8	212.8
	PEAK DEMAND (UNITS/HR OR DAY)	21.1	4.3
	PEAK DAY/HR	1/15	25/ 8
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	3651.2	414.6
	PEAK DEMAND (UNITS/HR OR DAY)	15.8	5.1
	PEAK DAY/HR	9/11	26/ 8
TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	50644.1	1910.8
	PEAK DEMAND (UNITS/HR OR DAY)	39.2	5.6

EQUIPMENT	HOURS AT PERCENT PART LOAD RATIO												TOTAL HOURS	ANNUAL LOAD (MBTU)	FALSE LOAD (MBTU)	ELEC USED (KWH)	THERMAL USED (MBTU)
	0 --	10 --	20 --	30 --	40 --	50 --	60 --	70 --	80 --	90 --	100 -	110+					
HW-BOILER	482	507	309	99	50	23	13	13	5	3	0	1504	122.8	0.0	2636.	191.1	
	482	507	309	99	50	23	13	13	5	3	0						
HERM-REC-CHLR	194	164	136	178	180	126	80	40	25	9	0	1132	90.5	0.0	9851.	0.0	
	194	164	136	178	180	126	80	40	25	9	0						

HOT LOOP CIRCULATION PUMP ELECTRICAL USE = 743. KWH
 COLD LOOP CIRCULATION PUMP ELECTRICAL USE = 805. KWH
 CONDENSER WATER PUMP ELECTRICAL USE = 0. KWH
 TOWER OR CONDENSER FAN ELECTRICAL USE = 1661. KWH

NOTES TO TABLE

- 1) THE FIRST PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE HOURLY OPERATING CAPACITY
- 2) THE SECOND PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE TOTAL INSTALLED CAPACITY

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PS-D PLANT LOADS SATISFIED

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	122.8	100.0
LOAD SATISFIED	122.8	100.0
TOTAL LOAD ON PLANT	122.8	
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HEM-REC-CHLR	90.5	100.0
LOAD SATISFIED	90.5	100.0
TOTAL LOAD ON PLANT	90.5	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	50644.1	100.0
LOAD SATISFIED	50644.1	100.0
TOTAL LOAD ON PLANT	50642.9	

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PS-D PLANT LOADS SATISFIED

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	122.8	122.8	0.000	0.000	0
COOLING LOADS	90.5	90.5	0.000	0.000	0
ELECTRICAL LOADS	172.8	172.8	0.000	0.000	0

ELECTRICAL END-USES IN KWH

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
AREA LIGHTS	1904.	1656.	1830.	1895.	1904.	1748.	1904.	1904.	1748.	1904.	1674.	1830.	21902.
MAX KW	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
DAY/HR	2/11	1/11	1/11	1/11	1/11	3/11	1/11	1/11	3/11	1/11	1/11	2/11	
MISC EQUIPMT	917.	795.	879.	915.	917.	838.	917.	917.	838.	917.	800.	879.	10528.
MAX KW	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0
DAY/HR	2/ 9	1/ 9	1/ 9	1/ 9	1/ 9	3/ 9	1/ 9	1/ 9	3/ 9	1/ 9	1/ 9	2/ 9	
SPACE HEAT	690.	542.	355.	93.	14.	0.	0.	0.	7.	58.	301.	575.	2636.
MAX KW	2.9	2.9	2.9	2.9	1.1	0.0	0.0	0.0	2.6	2.9	2.9	2.9	2.9
DAY/HR	1/ 1	1/ 8	1/ 8	1/ 8	9/ 9	0/ 0	0/ 0	0/ 0	23/ 8	15/ 8	4/ 8	2/ 8	
SPACE COOL	0.	0.	0.	178.	522.	1419.	2612.	2221.	928.	270.	41.	0.	8189.
MAX KW	0.0	0.0	0.0	6.7	12.5	16.2	18.7	16.5	13.0	5.8	5.9	0.0	18.7
DAY/HR	0/ 0	0/ 0	0/ 0	29/18	21/14	20/16	8/16	19/16	11/15	4/17	1/16	0/ 0	
HEAT REJECT	0.	0.	0.	55.	135.	317.	428.	416.	213.	85.	13.	0.	1661.
MAX KW	0.0	0.0	0.0	1.8	1.8	1.8	1.8	1.8	1.8	1.7	1.8	0.0	1.8
DAY/HR	0/ 0	0/ 0	0/ 0	26/15	16/17	3/12	1/ 9	1/11	4/18	4/17	1/16	0/ 0	
PUMPS & MISC	151.	126.	119.	99.	101.	144.	171.	169.	117.	113.	100.	136.	1547.
MAX KW	0.5	0.5	0.5	0.7	0.7	0.7	0.7	0.7	0.7	1.2	0.7	0.5	1.2
DAY/HR	1/ 1	1/ 8	1/ 8	1/13	1/10	3/ 9	1/ 8	1/ 8	3/12	16/13	1/ 9	1/ 9	
VENT FANS	256.	215.	195.	182.	263.	469.	958.	724.	346.	173.	171.	231.	4181.
MAX KW	4.0	3.9	3.3	2.2	3.0	4.2	7.3	6.0	4.1	1.8	3.0	3.5	7.3
DAY/HR	7/ 8	4/ 8	25/ 8	1/ 8	21/16	20/16	15/ 9	19/16	9/16	21/ 8	18/ 8	26/ 8	
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
TOTAL KWH	3918.	3334.	3377.	3417.	3857.	4934.	6990.	6351.	4196.	3519.	3099.	3651.	50644.

FUEL END-USES IN MBTU

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
SPACE HEAT	51.6	40.2	25.0	6.4	0.9	0.0	0.0	0.0	0.4	3.9	21.3	41.5	191.1
MAX MBTU	0.558	0.535	0.490	0.344	0.071	0.000	0.000	0.000	0.167	0.358	0.433	0.507	0.558
DAY/HR	7/ 8	4/ 8	25/ 8	8/ 8	9/ 9	0/ 0	0/ 0	0/ 0	23/ 8	21/ 8	25/ 8	26/ 8	
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
TOTAL MBTU	51.6	40.2	25.0	6.4	0.9	0.0	0.0	0.0	0.4	3.9	21.3	41.5	191.1

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PS-P ENERGY-RESOURCE PEAK BREAKDOWN BY END-USE

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

ENERGY-RESOURCE: ELECTRICITY
 UNITS: KWH

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
PEAK DEMAND:	16.2	16.1	15.8	22.2	28.4	33.8	39.2	36.0	30.7	19.8	21.1	15.8
DAY/HR:	7/ 9	4/ 9	25/ 9	29/15	21/14	20/16	8/15	19/16	11/15	31/15	1/15	9/11
BREAKDOWN												
AREA LIGHTS:	6.75	6.75	6.75	7.50	6.75	7.50	7.50	7.50	7.50	7.50	7.50	7.50
(%):	41.76	41.81	42.68	33.83	23.78	22.16	19.14	20.84	24.45	37.84	35.62	47.50
MISC EQUIPMT:	4.00	4.00	4.00	4.00	4.00	3.50	4.00	3.50	4.00	4.00	4.00	4.00
(%):	24.75	24.78	25.29	18.04	14.09	10.34	10.21	9.73	13.04	20.18	19.00	25.34
SPACE HEAT:	2.95	2.95	2.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.95
(%):	18.24	18.27	18.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	18.68
SPACE COOL:	0.00	0.00	0.00	6.34	12.51	16.16	18.33	16.46	13.02	5.16	5.59	0.00
(%):	0.00	0.00	0.00	28.58	44.05	47.73	46.78	45.74	42.46	26.03	26.53	0.00
HEAT REJECT:	0.00	0.00	0.00	1.82	1.82	1.82	1.82	1.82	1.82	1.56	1.74	0.00
(%):	0.00	0.00	0.00	8.23	6.43	5.39	4.66	5.07	5.95	7.89	8.28	0.00
PUMPS & MISC:	0.49	0.49	0.49	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.49
(%):	3.05	3.06	3.12	3.21	2.50	2.10	1.81	1.98	2.32	3.59	3.38	3.13
VENT FANS:	1.97	1.95	1.62	1.80	2.60	4.16	6.82	5.99	3.61	0.89	1.52	0.85
(%):	12.19	12.08	10.25	8.11	9.15	12.28	17.41	16.64	11.78	4.47	7.20	5.35

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PS-F ENERGY-RESOURCE PEAK BREAKDOWN BY END-USE

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

(CONTINUED)

ENERGY-RESOURCE: NATURAL-GAS
 UNITS: THERMS

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
PEAK DEMAND:	5.6	5.3	4.9	3.4	0.7	0.0	0.0	0.0	1.7	3.6	4.3	5.1
DAY/HR:	7/ 8	4/ 8	25/ 8	8/ 8	9/ 9	0/ 0	0/ 0	0/ 0	23/ 8	21/ 8	25/ 8	26/ 8
BREAKDOWN												
AREA LIGHTS:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
MISC EQUIPMT:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SPACE HEAT:	5.58	5.35	4.90	3.44	0.71	0.00	0.00	0.00	1.67	3.58	4.33	5.07
(%):	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00	100.00	100.00	100.00	100.00
SPACE COOL:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HEAT REJECT:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PUMPS & MISC:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
VENT FANS:	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
(%):	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

TOTAL HOURS AT HOURLY DEMAND AND TIME OF DAY

HOURLY	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
	40	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	2	
	37	0	0	0	0	0	0	0	0	2	1	2	2	1	3	6	5	3	3	0	0	0	0	0	28	
	34	0	0	0	0	0	0	0	0	0	2	5	4	2	6	8	9	9	6	0	0	0	0	0	51	
	31	0	0	0	0	0	0	0	0	4	4	4	5	7	13	23	24	14	13	0	0	0	0	0	111	
D	28	0	0	0	0	0	0	0	0	8	11	14	20	15	26	26	27	28	31	0	0	0	0	0	206	
E	25	0	0	0	0	0	0	0	2	13	23	33	30	30	22	16	14	22	22	0	0	0	0	0	227	
M K	21	0	0	0	0	0	0	0	2	23	21	11	10	17	12	9	8	11	10	0	0	0	0	0	134	
A W	18	0	0	0	0	0	0	0	3	19	13	32	17	14	14	14	15	11	9	0	0	0	0	0	161	
N	15	0	0	0	0	0	0	0	8	146	151	136	138	99	110	128	111	62	65	0	0	0	0	0	1154	
D	12	0	0	0	0	0	0	0	9	37	26	15	26	67	46	21	38	92	93	0	0	0	0	0	470	
	9	0	0	0	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	41	
	6	9	9	14	10	13	11	15	104	5	4	5	5	4	3	4	5	4	4	260	5	6	8	8	8	523
	3	356	356	351	355	352	354	350	196	108	109	108	108	109	110	109	108	109	109	105	360	359	357	357	357	5652
PERCENT TOTAL DEMAND	0.4	0.4	0.4	0.4	0.4	0.4	0.5	2.5	8.1	8.4	8.8	8.8	8.3	8.9	9.5	9.3	8.8	8.7	3.1	1.6	0.9	0.4	0.4	0.4		

PEAK ELECTRICAL LOAD BREAKDOWN

SOURCE	KW	PCT
SYSTEMS LOAD	18.322	46.8
CIRCULATION PUMPS	0.711	1.8
HERM-REC-CHLR	20.155	51.4
TOTAL	39.188	

SMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PS-H EQUIPMENT USE STATISTICS

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	AVG OPER RATIO	MAX LOAD (MBTU)	MON		-----		-----		-----		-----	
			DAY	HR	SIZE (MBTU)	OPER HRS	SIZE (MBTU)	OPER HRS	SIZE (MBTU)	OPER HRS	SIZE (MBTU)	OPER HRS
HW-BOILER	0.178	0.444	1	7 8	0.457	1504						
HEM-REC-CHLR	0.359	0.219	7	8 16	0.222	1132						

SIMPLE STRUCTURE RUN 3, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PS-I EQUIPMENT LIFE CYCLE COSTS

DIVIDE INTO ZONES; ADD PLENUM
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT TOTALS

HW-BOILER	23.3		
NOMINAL SIZE (MBTU)		0.457	
NUMBER INSTALLED		1	
FIRST COST (K\$)	21.0	21.0	
ANNUAL COST (K\$)	1.2	1.2	
CYCLICAL COST (K\$)	1.1	1.1	
-----TOTAL----- (K\$)		23.3	
HERM-REC-CHLR	11.7		
NOMINAL SIZE (MBTU)		0.222	
NUMBER INSTALLED		1	
FIRST COST (K\$)	8.3	8.3	
ANNUAL COST (K\$)	2.5	2.5	
CYCLICAL COST (K\$)	0.9	0.9	
-----TOTAL----- (K\$)		11.7	

EQUIPMENT TOTAL	35.0		

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		
AREA LIGHTS	74.7	0.0
MISC EQUIPMT	35.9	0.0
SPACE HEAT	9.0	191.1
SPACE COOL	27.9	0.0
HEAT REJECT	5.7	0.0
PUMPS & MISC	5.3	0.0
VENT FANS	14.3	0.0
TOTAL	172.8	191.1

TOTAL SITE ENERGY	363.93 MBTU	72.8 KBTU/SQFT-YR GROSS-AREA	72.8 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	709.67 MBTU	141.9 KBTU/SQFT-YR GROSS-AREA	141.9 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.7
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

ENERGY TYPE: SITE UNITS:	ELECTRICITY KWH	NATURAL-GAS THERMS
CATEGORY OF USE -----		
AREA LIGHTS	21902.	0.
MISC EQUIPMT	10527.	0.
SPACE HEAT	2636.	1911.
SPACE COOL	8189.	0.
HEAT REJECT	1661.	0.
PUMPS & MISC	1547.	0.
VENT FANS	4181.	0.
	-----	-----
TOTAL	50644.	1911.

TOTAL ELECTRICITY	50644. KWH	10.129 KWH	/SQFT-YR GROSS-AREA	10.129 KWH	/SQFT-YR NET-AREA
TOTAL NATURAL-GAS	1911. THERMS	0.382 THERMS	/SQFT-YR GROSS-AREA	0.382 THERMS	/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.7
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

MMDDHH	HERM-REC -CHLR LOAD BTU/HR	HERM-REC -CHLR OPER PT LD RATIO FRAC.OR MULT.	HERM-REC -CHLR ADJUSTED EIR BTU/BTU
	---- (1)	---- (10)	---- (16)
8 5 1	0.	0.000	0.000
8 5 2	0.	0.000	0.000
8 5 3	0.	0.000	0.000
8 5 4	0.	0.000	0.000
8 5 5	0.	0.000	0.000
8 5 6	0.	0.000	0.000
8 5 7	0.	0.000	0.000
8 5 8	15929.	0.250	0.081
8 5 9	56639.	0.250	0.083
8 5 10	74613.	0.318	0.102
8 5 11	91168.	0.390	0.121
8 5 12	96404.	0.416	0.130
8 5 13	113157.	0.488	0.147
8 5 14	125208.	0.540	0.161
8 5 15	128849.	0.552	0.161
8 5 16	124249.	0.531	0.155
8 5 17	118941.	0.511	0.153
8 5 18	0.	0.000	0.000
8 5 19	0.	0.000	0.000
8 5 20	0.	0.000	0.000
8 5 21	0.	0.000	0.000
8 5 22	0.	0.000	0.000
8 5 23	0.	0.000	0.000
8 5 24	0.	0.000	0.000
DAILY SUMMARY (AUG 5)			
MN	0.	0.000	0.000
MX	128849.	0.552	0.161
SM	945157.	4.246	1.293
AV	39382.	0.177	0.054
MONTHLY SUMMARY (AUG)			
MN	0.	0.000	0.000
MX	128849.	0.552	0.161
SM	945157.	4.246	1.293
AV	39382.	0.177	0.054
YEARLY SUMMARY			
MN	0.	0.000	0.000
MX	128849.	0.552	0.161
SM	945157.	4.246	1.293
AV	39382.	0.177	0.054

LIFE-CYCLE COSTING PARAMETERS

DISCOUNT RATE (PERCENT)	LABOR INFLATION RATE (PERCENT)	MATERIALS INFLATION RATE (PERCENT)	PROJECT LIFE (YRS)
5.0	0.0	0.0	25.0

BUILDING COMPONENT COST INPUT DATA (CURRENT DOLLARS)

COST NAME	NUMBER OF UNITS	UNIT NAME	LIFE (YRS)	UNIT	UNIT	UNIT	UNIT	UNIT	UNIT
				FIRST COST (\$)	INSTALL -ATION COST (\$)	ANNUAL MAINT COST (\$)	MINOR OVERHAUL COST (\$)	MINOR OVERHAUL INTERVAL (YRS)	MAJOR OVERHAUL COST (\$)

NO BUILDING COMPONENT COSTS SPECIFIED

YEAR	ENERGY (\$)			OPERATIONS (\$)				TOTAL SAVINGS-ENERGY PLUS OPRNS	
	ENERGY COST	ENERGY COST	ENERGY COST	OPRNS COST	OPRNS COST -- THIS RUN				
	BASELINE	THIS RUN	SAVINGS	BASELINE	PLANT	BUILDING	TOTAL		
1	0.	4369.	-4369.	0.	249.	0.	249.	-249.	-4619.
2	0.	4431.	-4431.	0.	238.	0.	238.	-238.	-4668.
3	0.	4493.	-4493.	0.	314.	0.	314.	-314.	-4807.
4	0.	4557.	-4557.	0.	216.	0.	216.	-216.	-4772.
5	0.	4622.	-4622.	0.	205.	0.	205.	-205.	-4827.
6	0.	4688.	-4688.	0.	272.	0.	272.	-272.	-4960.
7	0.	4756.	-4756.	0.	186.	0.	186.	-186.	-4942.
8	0.	4824.	-4824.	0.	412.	0.	412.	-412.	-5236.
9	0.	4894.	-4894.	0.	236.	0.	236.	-236.	-5130.
10	0.	4966.	-4966.	0.	161.	0.	161.	-161.	-5127.
11	0.	5038.	-5038.	0.	212.	0.	212.	-212.	-5250.
12	0.	5113.	-5113.	0.	146.	0.	146.	-146.	-5258.
13	0.	5188.	-5188.	0.	139.	0.	139.	-139.	-5327.
14	0.	5265.	-5265.	0.	828.	0.	828.	-828.	-6093.
15	0.	5344.	-5344.	0.	126.	0.	126.	-126.	-5470.
16	0.	5424.	-5424.	0.	279.	0.	279.	-279.	-5702.
17	0.	5505.	-5505.	0.	159.	0.	159.	-159.	-5664.
18	0.	5588.	-5588.	0.	109.	0.	109.	-109.	-5697.
19	0.	5673.	-5673.	0.	104.	0.	104.	-104.	-5776.
20	0.	5759.	-5759.	0.	531.	0.	531.	-531.	-6290.
21	0.	5847.	-5847.	0.	94.	0.	94.	-94.	-5941.
22	0.	5936.	-5936.	0.	124.	0.	124.	-124.	-6060.
23	0.	6027.	-6027.	0.	85.	0.	85.	-85.	-6113.
24	0.	6120.	-6120.	0.	189.	0.	189.	-189.	-6309.
25	0.	6215.	-6215.	0.	108.	0.	108.	-108.	-6323.
TOTALS (\$)	0.	130641.	-130641.	0.	5721.	0.	5721.	-5721.	-136362.

LIFE-CYCLE BUILDING AND PLANT NON-ENERGY COSTS (\$)

COST NAME	FIRST COST (INCLUDING INSTALLATION)	REPLACEMENTS	OPERATIONS	TOTAL	INVESTMENT (FIRST COST PLUS REPLACEMENTS)
-----	-----	-----	-----	-----	-----
NO BUILDING COMPONENT COSTS SPECIFIED					
PLANT EQUIPMENT	29298.	0.	5721.	35019.	29298.
	-----	-----	-----	-----	-----
TOTALS	29298.	0.	5721.	35019.	29298.

ENERGY SAVINGS

	ANNUAL ENERGY USE BASELINE		ANNUAL ENERGY USE THIS RUN		ANNUAL ENERGY SAVINGS		ANNUAL ENERGY SAVINGS
	(MBTU)	(MWH)	(MBTU)	(MWH)	(MBTU)	(MWH)	(PCT)
AT SITE	0.00	0.00	363.93	106.63	-363.93	-106.63	0.0
AT SOURCE	0.00	0.00	709.67	207.93	-709.67	-207.93	0.0

INVESTMENT STATISTICS

PROJECT LIFE 25.0 YEARS

INVESTMENT THIS RUN (\$)	BASELINE REPLACEMENT COSTS (\$)	INCREMENTAL INVESTMENT (\$)	COST SAVINGS (\$)	RATIO OF SAVINGS TO INCREMENTAL INVESTMENT (SIR)	DISCOUNTED PAYBACK PERIOD (YEARS)	RATIO OF LIFE CYCLE ENERGY SAVINGS (AT SITE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)	RATIO OF LIFE-CYCLE ENERGY SAVINGS (AT SOURCE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)
29298.	0.	29298.	-136362.	-4.65	999.00	-0.31	-0.09	-0.61	-0.18

OVERALL LIFE-CYCLE COSTS (\$)

	FIRST COST	OPRNS COST	REPLACEMENTS	ENERGY COST	T O T A L
BASELINE	0.	0.	0.	0.	0.
THIS RUN	29298.	5721.	0.	130641.	165660.
SAVINGS (\$)	-29298.	-5721.	0.	-130641.	-165660.
(PCT)	0.0	0.0	0.0	0.0	0.0

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-D ENERGY COST SUMMARY

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 1

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-TARIFF	ELECTRICITY	1 2 3 4 5	50644. KWH	3223.	0.0636	YES
GAS-RATE	NATURAL-GAS	1 2 3 4 5	1911. THERMS	1146.	0.6000	YES

 4369.

ENERGY COST/GROSS BLDG AREA: 0.87
 ENERGY COST/NET BLDG AREA: 0.87

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-TARIFF

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS
 ELEC-TARIFF

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 1

UTILITY-RATE: ELEC-TARIFF

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	3918	3918	16.2	16.2	245	0	0	0	0	0	0	0.0624	245
FEB	3334	3334	16.1	16.1	208	0	0	0	0	0	0	0.0625	208
MAR	3378	3378	15.8	15.8	212	0	0	0	0	0	0	0.0629	212
APR	3417	3417	22.2	22.2	218	0	0	0	0	0	0	0.0637	218
MAY	3857	3857	28.4	28.4	247	0	0	0	0	0	0	0.0641	247
JUN	4934	4934	33.8	33.8	318	0	0	0	0	0	0	0.0644	318
JUL	6990	6990	39.2	39.2	448	0	0	0	0	0	0	0.0641	448
AUG	6351	6351	36.0	36.0	408	0	0	0	0	0	0	0.0642	408
SEP	4196	4196	30.7	30.7	270	0	0	0	0	0	0	0.0643	270
OCT	3519	3519	19.8	19.8	225	0	0	0	0	0	0	0.0639	225
NOV	3099	3099	21.1	21.1	196	0	0	0	0	0	0	0.0631	196
DEC	3651	3651	15.8	15.8	229	0	0	0	0	0	0	0.0626	229
TOTAL	50644	50644	39.2		3223	0	0	0	0	0		0.0636	3223

SIMPLE STRUCTURE RUN 3, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE: GAS-RATE

DIVIDE INTO ZONES; ADD PLENUM
 SHOW ALL REPORTS

DOB-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 1

UTILITY-RATE: GAS-RATE

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31

100000. BTU/THERMS
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERMS	BILLING ENERGY THERMS	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	516	516	5.6	5.6	309	0	0	0	0	0	0	0.6000	309
FEB	402	402	5.3	5.3	241	0	0	0	0	0	0	0.6000	241
MAR	250	250	4.9	4.9	150	0	0	0	0	0	0	0.6000	150
APR	64	64	3.4	3.4	38	0	0	0	0	0	0	0.6000	38
MAY	9	9	0.7	0.7	5	0	0	0	0	0	0	0.6000	5
JUN	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
JUL	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
AUG	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
SEP	4	4	1.7	1.7	3	0	0	0	0	0	0	0.6000	3
OCT	39	39	3.6	3.6	23	0	0	0	0	0	0	0.6000	23
NOV	213	213	4.3	4.3	128	0	0	0	0	0	0	0.6000	128
DEC	415	415	5.1	5.1	249	0	0	0	0	0	0	0.6000	249
TOTAL	1911	1911	5.6		1146	0	0	0	0	0		0.6000	1146

Simple Structure — Run 3a

LDL PROCESSOR INPUT DATA

Thu Nov 4 16:29:40 1993 LDL RUN 4

```

* 684 *
* 685 * TITLE          LINE-1 *SIMPLE STRUCTURE RUN 3A, CHICAGO *
* 686 *              LINE-2 *INCREASED ROOF INSULATION * ..
* 687 *
* 688 *              RUN-PERIOD      JAN 1 1974 THRU DEC 31 1974  ..
* 689 *              ABORT          ERRORS ..
* 690 *              DIAGNOSTIC     WARNINGS ..
* 691 *              LOADS-REPORT   SUMMARY = (LS-C,LS-D)
* 692 *              VERIFICATION = (LV-B,LV-D) ..
* 693 *              BUILDING-LOCATION LATITUDE=42.0 LONGITUDE=88.0
* 694 *              ALTITUDE=610
* 695 *              TIME-ZONE=6  AZIMUTH=30.0  ..
* 696 *
* 697 * $              BUILDING DESCRIPTION
* 698 *
* 699 * $ STRUCTURE  THE BUILDING IS IDENTICAL TO THAT IN RUN 3 ABOVE EXCEPT
* 700 * $              THAT THE ROOF HAS AN ADDITIONAL INCH OF INSULATION.
* 701 *
* 702 * $ SYSTEMS AND PLANT SIZING IS TAKEN FROM RESULTS OF RUN 3.
* 703 *
* 704 * $ ECONOMICS SPECIFICATIONS ARE THE SAME AS RUN3, BUT INCLUDE THE COSTS
* 705 * $              OF THE IMPROVEMENTS ADDED FOR THE RUN AND THE RESULTS OF RUN 3
* 706 * $              AS A BASELINE.
* 707 * $
* 708 * $ BASELINE   BASELINE ECONOMICS DATA ARE TAKEN FROM
* 709 * $              SIMPLE STRUCTURE RUN 3 REPORTS ES-A AND ES-C.
* 710 * $
* 711 * $ IMPROVEMENT 5000 SQFT OF INSULATION AT 1.10 DOLLARS/SQFT
* 712 *
* 713 *              $ CONSTRUCTION AND GLASS-TYPES
* 714 *
* 715 * ROO-1 =LAYERS =MAT=(RG01,BR01,IN46,WD01) 1-F-R .76 ..
* 716 * WA-1-2 =LAYERS =MAT=(WD01,PW03,IN02,GP01) ..
* 717 * WALL-1 =CONSTRUCTION LAYERS=WA-1-2 ..
* 718 * ROOF-1 =CONSTRUCTION LAYERS=ROO-1 ..
* 719 * CLNG-1 =CONSTRUCTION U = 0.27 ..
* 720 * SB-U =CONSTRUCTION U = 1.5 ..
* 721 * FLOOR-1 =CONSTRUCTION U = 0.05 ..
* 722 *
* 723 * W-1 =GLASS-TYPE GLASS-TYPE-CODE = 3 PANES = 2 ..
* 724 * DOORS =GLASS-TYPE GLASS-TYPE-CODE = 5 ..
* 725 *
* 726 *              $ OCCUPANCY SCHEDULE
* 727 *
* 728 * OC-1 =DAY-SCHEDULE (1,8) (0.0)
* 729 *              (9,11) (1.0)
* 730 *              (12,14) (0.8,0.4,0.8)
* 731 *              (15,18) (1.0)
* 732 *              (19,21) (0.5,0.1,0.1)
* 733 *              (22,24) (0.0) ..
* 734 *
* 735 * OC-2 =DAY-SCHEDULE (1,24) (0.0) .
* 736 *
* 737 * OC-WEEK =WEEK-SCHEDULE (WD) OC-1 (WEH) OC-2 ..
* 738 *

```



```

* 739 * OCCUPY-1      =SCHEDULE          THRU DEC 31 OC-WEEK ..
* 740 *
* 741 *              $ LIGHTING SCHEDULE
* 742 *
* 743 * LT-1          =DAY-SCHEDULE      (1,8) (0.05)
* 744 *              (9,14) (0.9,0.95,1.0,0.95,0.8,0.9)
* 745 *              (15,18) (1.0)
* 746 *              (19,21) (0.6,0.2,0.2)
* 747 *              (22,24) (0.05) ..
* 748 *
* 749 * LT-2          =DAY-SCHEDULE      (1,24) (0.05) ..
* 750 *
* 751 * LT-WEEK       =WEEK-SCHEDULE      (MON,FRI) LT-1 (WEH) LT-2 ..
* 752 *
* 753 * LIGHTS-1      =SCHEDULE          THRU DEC 31 LT-WEEK ..
* 754 *
* 755 *              $ OFFICE EQUIPMENT SCHEDULE
* 756 *
* 757 * EQ-1          =DAY-SCHEDULE      (1,8) (0.02)
* 758 *              (9,14) (0.4,0.9,0.9,0.9,0.9,0.9)
* 759 *              (15,20) (0.8,0.7,0.5,0.5,0.3,0.3)
* 760 *              (21,24) (0.02) ..
* 761 *
* 762 * EQ-2          =DAY-SCHEDULE      (1,24) (0.2) ..
* 763 *
* 764 * EQ-WEEK       =WEEK-SCHEDULE      (MON,FRI) EQ-1 (WEH) EQ-2 ..
* 765 *
* 766 * EQUIP-1       =SCHEDULE          THRU DEC 31 EQ-WEEK ..
* 767 *
* 768 *              $ INFILTRATION SCHEDULE
* 769 *
* 770 * INFIL-SCH     =SCHEDULE          THRU MAR 31 (ALL) (1,24) (1)
* 771 *              THRU OCT 31 (ALL) (1,24) (0)
* 772 *              THRU DEC 31 (ALL) (1,24) (1) ..
* 773 *
* 774 *
* 775 *              $ SET DEFAULT VALUES
* 776 *
* 777 *              SET-DEFAULT FOR SPACE FLOOR-WEIGHT=70 ..
* 778 *              SET-DEFAULT FOR EXTERIOR-WALL CONSTRUCTION=WALL-1 ..
* 779 *              SET-DEFAULT FOR WINDOW HEIGHT=4.0 GLASS-TYPE=W-1 Y=3 ..
* 780 *
* 781 *              $ GENERAL SPACE DEFINITION
* 782 *
* 783 * OFFICE         =SPACE-CONDITIONS  PEOPLE-SCHEDULE      =OCCUPY-1
* 784 *              NUMBER-OF-PEOPLE      =50
* 785 *              PEOPLE-HEAT-GAIN       =4'
* 786 *              LIGHTING-SCHEDULE     =LIGHTS-1
* 787 *              LIGHTING-TYPE         =REC-FLUOR-RV
* 788 *              LIGHT-TO-SPACE        =.80
* 789 *              LIGHTING-W/SQFT       =1.5
* 790 *              EQUIP-SCHEDULE        =EQUIP-1
* 791 *              EQUIPMENT-W/SQFT      =1
* 792 *              INF-METHOD           =AIR-CHANGE
* 793 *              AIR-CHANGES/HR       =0.25
* 794 *              INF-SCHEDULE          =INFIL-SCH ..
* 795 *
* 796 *              $ SPECIFIC SPACE DETAILS
* 797 *
* 798 * PLENUM-1       =SPACE              ZONE-TYPE=PLENUM AREA=5000
* 799 *              VOLUME=10000 Z=8 FLOOR-WEIGHT=5 ..
* 800 *
* 801 * WALL-1PF      =EXTERIOR-WALL      HEIGHT = 2 WIDTH = 100

```

```

* 802 *                               AZIMUTH = 180 ..
* 803 *
* 804 *   WALL-1PR   =EXTERIOR-WALL   HEIGHT = 2  WIDTH = 50
* 805 *                               AZIMUTH = 90  X = 100 ..
* 806 *
* 807 *   WALL-1PB   =EXTERIOR-WALL   HEIGHT = 2  WIDTH = 100
* 808 *                               X = 100  Y = 50  AZIMUTH = 0  ..
* 809 *
* 810 *   WALL-1PL   =EXTERIOR-WALL   HEIGHT = 2  WIDTH = 50
* 811 *                               AZIMUTH = 270 Y = 50 ..
* 812 *
* 813 *   TOP-1      =ROOF              HEIGHT=50  WIDTH=100
* 814 *                               X=0  Y=0  Z=2  AZIMUTH = 180
* 815 *                               TILT=0  GND-REFLECTANCE=0
* 816 *                               CONSTRUCTION = ROOF-1 ..
* 817 *
* 818 *   SPACE1-1   =SPACE              SPACE-CONDITIONS = OFFICE
* 819 *                               AREA = 1056  VOLUME = 8448
* 820 *                               NUMBER-OF-PEOPLE = 11 ..
* 821 *   FRONT-1   =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 100
* 822 *                               X=0  Y=0  Z=0  AZIMUTH = 180 ..
* 823 *   WF-1       =WINDOW           WIDTH = 45  X = 10 ..
* 824 *   DF-1       =WINDOW           WIDTH = 8  HEIGHT = 8
* 825 *                               X = 70  Y = 0  GLASS-TYPE=DOORS
* 826 *                               OVERHANG-A 1  OVERHANG-B .5
* 827 *                               OVERHANG-W 10 OVERHANG-D 4 ..
* 828 *
* 829 *   C1-1       =INTERIOR-WALL   AREA = 1056  NEXT-TO PLENUM-1
* 830 *                               CONSTRUCTION = CLNG-1 ..
* 831 *
* 832 *   F1-1       =UNDERGROUND-FLOOR AREA = 1056  CONSTRUCTION = FLOOR-1 ..
* 833 *
* 834 *   SB12        =INTERIOR-WALL   AREA=135.76 NEXT-TO SPACE2-1
* 835 *                               CONSTRUCTION = SB-U ..
* 836 *
* 837 *   SB14        =INTERIOR-WALL   LIKE SB12  NEXT-TO SPACE4-1 ..
* 838 *   SB15        =INTERIOR-WALL   AREA 608   NEXT-TO SPACES5-1
* 839 *                               CONSTRUCTION = SB-U ..
* 840 *
* 841 *   SPACE2-1   =SPACE              SPACE-CONDITIONS = OFFICE
* 842 *                               AREA = 456  VOLUME = 3648
* 843 *                               NUMBER-OF-PEOPLE = 5 ..
* 844 *
* 845 *   RIGHT-1    =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 50
* 846 *                               X=100  Y=0  Z=0  AZIMUTH = 90 ..
* 847 *
* 848 *   WR-1       =WINDOW           WIDTH = 25  X = 12.5 ..
* 849 *
* 850 *   C2-1       =INTERIOR-WALL   AREA = 456  NEXT-TO PLENUM-1
* 851 *                               CONSTRUCTION = CLNG-1 ..
* 852 *
* 853 *   F2-1       =UNDERGROUND-FLOOR AREA = 456  CONSTRUCTION = CLNG-1 ..
* 854 *
* 855 *   SB23        =INTERIOR-WALL   AREA = 135.76 NEXT-TO SPACE3-1
* 856 *                               CONSTRUCTION = SB-U ..
* 857 *
* 858 *   SB25        =INTERIOR-WALL   AREA = 208  NEXT-TO SPACES5-1
* 859 *                               CONSTRUCTION = SB-U ..
* 860 *
* 861 *   SPACE3-1   =SPACE              SPACE-CONDITIONS = OFFICE
* 862 *                               AREA = 1056  VOLUME = 8448
* 863 *                               NUMBER-OF-PEOPLE = 11 ..
* 864 *

```

```

* 865 *   BACK-1   =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 100
* 866 *                                     X=100 Y=50  Z=0  AZIMUTH = 0  ..
* 867 *
* 868 *   WB-1     =WINDOW           WIDTH = 45  X = 10  ..
* 869 *   DB-1     =WINDOW           WIDTH = 7   HEIGHT = 7
* 870 *                                     X = 70  Y = 0  GLASS-TYPE=DOORS  ..
* 871 *
* 872 *   C3-1     =INTERIOR-WALL   AREA = 1056  NEXT-TO PLENUM-1
* 873 *                                     CONSTRUCTION = CLNG-1  ..
* 874 *
* 875 *   F3-1     =UNDERGROUND-FLOOR  AREA = 1056
* 876 *                                     CONSTRUCTION = FLOOR-1  ..
* 877 *
* 878 *   SB34     =INTERIOR-WALL   AREA = 135.8  NEXT-TO SPACE4-1
* 879 *                                     CONSTRUCTION = SB-U  ..
* 880 *
* 881 *   SB35     =INTERIOR-WALL   AREA = 608   NEXT-TO SPACES5-1
* 882 *                                     CONSTRUCTION = SB-U  ..
* 883 *
* 884 *   SPACE4-1 =SPACE           SPACE-CONDITIONS = OFFICE
* 885 *                                     AREA = 456  VOLUME = 3648
* 886 *                                     NUMBER-OF-PEOPLE = 5  ..
* 887 *
* 888 *   LEFT-1    =EXTERIOR-WALL   HEIGHT = 8  WIDTH = 50
* 889 *                                     X=0   Y=50  Z=0  AZIMUTH = 270  ..
* 890 *
* 891 *   WL-1     =WINDOW           WIDTH = 25  X = 12.5  ..
* 892 *
* 893 *   C4-1     =INTERIOR-WALL   AREA = 456   NEXT-TO PLENUM-1
* 894 *                                     CONSTRUCTION = CLNG-1  ..
* 895 *
* 896 *   F4-1     =UNDERGROUND-FLOOR  AREA = 456
* 897 *                                     CONSTRUCTION = FLOOR-1  ..
* 898 *
* 899 *   SB45     =INTERIOR-WALL   AREA = 208   NEXT-TO SPACES5-1
* 900 *                                     CONSTRUCTION = SB-U  ..
* 901 *
* 902 *   SPACES5-1 =SPACE           SPACE-CONDITIONS = OFFICE
* 903 *                                     AREA = 1976  VOLUME = 15808
* 904 *                                     NUMBER-OF-PEOPLE = 20  ..
* 905 *
* 906 *   C5-1     =INTERIOR-WALL   AREA = 1976  NEXT-TO PLENUM-1
* 907 *                                     CONSTRUCTION = CLNG-1  ..
* 908 *
* 909 *   F5-1     =UNDERGROUND-FLOOR  AREA = 1976  CONSTRUCTION = FLOOR-1  ..
* 910 *
* 911 *   END      ..
* 912 *   COMPUTE LOADS  ..
* 913 *   INPUT SYSTEMS  ..

```

SDL PROCESSOR INPUT DATA

Thu Nov 4 16:29:40 1993SDL RUN 2

```

* 914 *
* 915 *          SYSTEMS-REPORT SUMMARY=(SS-A,SS-J) ..
* 916 *
* 917 *          $ SYSTEMS SCHEDULES
* 918 *
* 919 * FAN-1      =DAY-SCHEDULE      (1,6) (0) (7,8) (-999) (9,18) (1) (19,24) (0) ..
* 920 * FAN-2      =DAY-SCHEDULE      (1,24) (0) ..
* 921 * FAN-SCHED =SCHEDULE          THRU DEC 31 (WD) FAN-1 (WEH) FAN-2 ..
* 922 *
* 923 * HEAT-1      =DAY-SCHEDULE      (1,8) (55) (9,18) (70) (19,24) (55) ..
* 924 * HEAT-2      =DAY-SCHEDULE      (1,24) (55) ..
* 925 * HEAT-WEEK  =WEEK-SCHEDULE    (MON,FRI) HEAT-1 (WEH) HEAT-2 ..
* 926 * HEAT-SCHED =SCHEDULE          THRU DEC 31 HEAT-WEEK ..
* 927 * COOLOFF    =SCHEDULE          THRU DEC 31 (ALL) (1,24) (60) ..
* 928 * HEATOFF    =SCHEDULE          THRU DEC 31 (ALL) (1,24) (60) ..
* 929 *
* 930 * COOL-1      =DAY-SCHEDULE      (1,8) (99) (9,18) (78) (19,24) (99) ..
* 931 * COOL-2      =DAY-SCHEDULE      (1,24) (99) ..
* 932 * COOL-WEEK  =WEEK-SCHEDULE    (MON,FRI) COOL-1 (WEH) COOL-2 ..
* 933 * COOL-SCHED =SCHEDULE          THRU DEC 31 COOL-WEEK ..
* 934 *
* 935 * R1          =DAY-RESET-SCH   SUPPLY-HI=60  SUPPLY-LO=52
* 936 *              OUTSIDE-LO=30  OUTSIDE-HI=75 ..
* 937 * SAT-RESET  =RESET-SCHEDULE  THRU DEC 31 (ALL) R1 ..
* 938 *
* 939 *
* 940 *          $ SYSTEM DESCRIPTION
* 941 *
* 942 * ZAIR        =ZONE-AIR      OA-CFM/PER=20 ..
* 943 *
* 944 * CONTROL     =ZONE-CONTROL  DESIGN-HEAT-T=70  DESIGN-COOL-T=76
* 945 *              HEAT-TEMP-SCH= HEAT-SCHED
* 946 *              COOL-TEMP-SCH= COOL-SCHED
* 947 *              THERMOSTAT-TYPE=REVERSE-ACTION ..
* 948 *
* 949 *          $ FOLLOWING AIR FLOWS ARE FROM RUN 3 SV-A REPORT.
* 950 *          $ DIVIDED BY ALTITUDE MULTIPLIER
* 951 *
* 952 * SPACE1-1   =ZONE          ZONE-AIR=ZAIR  SIZING-OPTION=ADJUST-LOADS
* 953 *              ZONE-CONTROL=CONTROL  ASSIGNED-CFM=2133 ..
* 954 *
* 955 * SPACE2-1   =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=957 ..
* 956 * SPACE3-1   =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=1509 ..
* 957 * SPACE4-1   =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=953 ..
* 958 * SPACE5-1   =ZONE          LIKE SPACE1-1  ASSIGNED-CFM=1814 ..
* 959 *
* 960 * PLENUM-1   =ZONE          ZONE-TYPE=PLENUM  SIZING-OPTION=ADJUST-LOADS
* 961 *              DESIGN-HEAT-T=50  DESIGN-COOL-T=95 ..
* 962 *
* 963 * S-CONT      =SYSTEM-CONTROL  COOLING-SCHEDULE= COOLOFF
* 964 *              HEATING-SCHEDULE= HEATOFF
* 965 *              HEAT-SET-T=65
* 966 *              COOL-CONTROL=RESET
* 967 *              COOL-RESET-SCH=SAT-RESET
* 968 *              MIN-SUPPLY-T=60 ..

```

```

* 969 *
* 970 * S-FAN      =SYSTEM-FANS    FAN-SCHEDULE=FAN-SCHED FAN-CONTROL=SPEED
* 971 *          SUPPLY-STATIC=5.5 SUPPLY-EFF=.55
* 972 *          NIGHT-CYCLE-CTRL=CYCLE-ON-ANY ..
* 973 *
* 974 * S-TERM    =SYSTEM-TERMINAL REHEAT-DELTA-T=58
* 975 *          MIN-CFM-RATIO=0.3 ..
* 976 *
* 977 * SYST-1    =SYSTEM          SYSTEM-TYPE=VAVS
* 978 *          SUPPLY-CFM=7366
* 979 *          SYSTEM-CONTROL= S-CONT
* 980 *          SYSTEM-FANS= S-FAN
* 981 *          SYSTEM-TERMINAL= S-TERM
* 982 *          ECONO-LIMIT-T=65
* 983 *          RETURN-AIR-PATH= PLENUM-ZONES
* 984 *          PLENUM-NAMES= (PLENUM-1)
* 985 *          ZONE-NAMES= (SPACE5-1,SPACE1-1,SPACE2-1
* 986 *                   SPACE3-1,SPACE4-1,PLENUM-1) ..
* 987 *
* 988 * END      ..
* 989 * COMPUTE SYSTEMS ..
* 990 *
* 991 * INPUT PLANT ..

```

P D L P R O C E S S O R I N P U T D A T A

Thu Nov 4 16:29:40 1993PDL RUN 2

```
* 992 *
* 993 *      PLANT-REPORT SUMMARY=(PS-A,BEPS) ..
* 994 *
* 995 *      $ EQUIPMENT DESCRIPTION
* 996 *
* 997 *      $ HOT-WATER BOILER
* 998 *
* 999 * SBOIL1 =PLANT-EQUIPMENT TYPE=HW-BOILER SIZE=.457 .. $ SIZE FROM RUN 3
*1000 *
*1001 *      PLANT-PARAMETERS HERM-REC-COND-TYPE=AIR ..
*1002 *
*1003 *      $ AIR-COOLED RECIPROCATING CHILLER
*1004 *
*1005 * CHIL1 =PLANT-EQUIPMENT TYPE=HERM-REC-CHLR SIZE=.222 .. $ SIZE FROM RUN 3
*1006 *
*1007 * PLANT-COSTS      PROJECT-LIFE=25 DISCOUNT-RATE=5 ..
*1008 * ENERGY-RESOURCE RESOURCE=ELECTRICITY ..
*1009 * ENERGY-RESOURCE RESOURCE=NATURAL-GAS ENERGY/UNIT=100000
*1010 *      UNIT-NAME=THERMS ..
*1011 * END ..
*1012 * COMPUTE PLANT ..
*1013 * INPUT ECONOMICS ..
```

EDL PROCESSOR INPUT DATA

Thu Nov 4 16:29:40 1993EDL RUN 2

```

*1014 *
*1015 *      $ COST OF ADDED ROOF INSULATION
*1016 *
*1017 * ROOF-INSUL =COMPONENT-COST  UNIT-NAME=*SQFT*  NUMBER-OF-UNITS=5000
*1018 *                               FIRST-COST=0.80  INSTALL-COST=0.30 ..
*1019 *
*1020 *      $ BASELINE COSTS (INCLUDES COST OF BASELINE PLANT EQUIPMENT)
*1021 *
*1022 *      BASELINE
*1023 *
*1024 *          $ following is from *FIRST COST, INCLUDING INSTALLATION*,
*1025 *          $ in Run 3, Report ES-B
*1026 *
*1027 *      FIRST-COST=29298
*1028 *
*1029 *          $ following is from total *REPLACEMENTS*
*1030 *          $ in Run 3, Report ES-B
*1031 *
*1032 *      REPLACE-COST=0
*1033 *
*1034 *          $ following is from *ENERGY COST THIS RUN*
*1035 *          $ in Run 3, Report ES-A
*1036 *
*1037 *      ENERGY-COST = (4369,4431,4493,4557,4622,4688,4756,
*1038 *                    4824,4894,4966,5038,5113,5188,5265,5344,5424,
*1039 *                    5505,5588,5673,5759,5847,5936,6027,6120,6215)
*1040 *
*1041 *          $ following is from *OPRNS COST -- THIS RUN, TOTAL*
*1042 *          $ in Run 3, Report ES-A
*1043 *
*1044 *      OPERATIONS-COST = (249,238,314,216,205,272,
*1045 *                    186,412,236,161,212,146,139,828,126,279,
*1046 *                    159,109,104,531,94,124,85,189,108)
*1047 *
*1048 *          $ following is from *ANNUAL ENERGY USE THIS RUN, AT SITE*
*1049 *          $ in Run 3, Report ES-C
*1050 *
*1051 *      ENERGY-USE-SITE = 363.93
*1052 *
*1053 *          $ following is from *ANNUAL ENERGY USE THIS RUN, AT SOURCE*
*1054 *          $ in Run 3, Report ES-C
*1055 *
*1056 *      ENERGY-USE-SRC = 709.67 ..
*1057 *
*1058 *
*1059 * ECONOMICS-REPORT SUMMARY=(ALL-SUMMARY) VERIFICATION=(ALL-VERIFICATION) ..
*1060 *
*1061 * ELEC-TARIFF-UTILITY-RATE  RESOURCE=ELECTRICITY
*1062 *                               ENERGY-CHG-SCH=ENERGY-SCH
*1063 *                               ESCALATION=7 ..
*1064 *
*1065 * ENERGY-SCH =SCHEDULE THRU DEC 31 (WD) (1,8) (.05)          $OFF-PEAK
*1066 *                               (9,12) (.06)                  $$HOULDER
*1067 *                               (13,17) (.07)                 $PEAK
*1068 *                               (18,22) (.06)                  $$HOULDER

```

```

*1069 *                (23,24) (.05)          SOFF-PEAK
*1070 *
*1071 *                (SAT) (1, 8) (.05)      SOFF-PEAK
*1072 *                (9, 17) (.06)         SSHOULDER
*1073 *                (18,24) (.05)         SOFF-PEAK
*1074 *
*1075 *                (SUN,HOL) (1,24) (.05) .. SOFF-PEAK
*1076 *
*1077 * GAS-RATE   =UTILITY-RATE  RESOURCE=NATURAL-GAS
*1078 *                                     ENERGY-CHG = .6 ..
*1079 *
*1080 * END ..
*1081 * COMPUTE ECONOMICS ..
*1082 * STOP ..

```


SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- LV 3 SUMMARY OF SPACES OCCURRING IN THE PROJECT

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 4

WEATHER FILE- TRY CHICAGO

NUMBER OF SPACES 6 EXTERIOR 5 INTERIOR 1

SPACE	SPACE*FLOOR MULTIPLIER	SPACE TYPE	AZIMUTH	LIGHTING (WATT / SQFT)	PEOPLE	EQUIP (WATT / SQFT)	INFILTRATION METHOD	AIR CHANGES PER HOUR	AREA (SQFT)	VOLUME (CUFT)
PLENUM-1	1.0	EXT	0.0	0.00	0.0	0.00	NO-INFILT.	0.00	5000.00	10000.00
SPACE1-1	1.0	EXT	0.0	1.50	11.0	1.00	AIR-CHANGE	0.25	1056.00	8448.00
SPACE2-1	1.0	EXT	0.0	1.50	5.0	1.00	AIR-CHANGE	0.25	456.00	3648.00
SPACE3-1	1.0	EXT	0.0	1.50	11.0	1.00	AIR-CHANGE	0.25	1056.00	8448.00
SPACE4-1	1.0	EXT	0.0	1.50	5.0	1.00	AIR-CHANGE	0.25	456.00	3648.00
SPACE5-1	1.0	INT	0.0	1.50	20.0	1.00	AIR-CHANGE	0.25	1976.00	15808.00
BUILDING TOTALS					52.0				10000.00	50000.00

SIMPLE STRUCTURE RUN 3A, CHICAGO INCREASED ROOF INSULATION
 DESIGN-DAY SIZING OF VAV SYSTEM SHOW ALL REPORTS
 REPORT- LV-D DETAILS OF EXTERIOR SURFACES IN THE PROJECT

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 4
 WEATHER FILE- TRY CHICAGO

NUMBER OF EXTERIOR SURFACES 9 RECTANGULAR 9 OTHER 0
 (U-VALUE INCLUDES OUTSIDE AIR FILM; WINDOW INCLUDES FRAME, IF DEFINED)

SURFACE	SPACE	- - - W I N D O W S - - -		- - - - W A L L - - - -		- W A L L + W I N D O W S -		AZIMUTH
		U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	
WALL-1PB	PLENUM-1	0.000	0.00	0.067	200.00	0.067	200.00	NORTH
BACK-1	SPACE3-1	0.565	229.00	0.067	571.00	0.210	800.00	NORTH
RIGHT-1	SPACE2-1	0.467	100.00	0.067	300.00	0.167	400.00	EAST
WALL-1PR	PLENUM-1	0.000	0.00	0.067	100.00	0.067	100.00	EAST
WALL-1PF	PLENUM-1	0.000	0.00	0.067	200.00	0.067	200.00	SOUTH
FRONT-1	SPACE1-1	0.587	244.00	0.067	556.00	0.226	800.00	SOUTH
WALL-1PL	PLENUM-1	0.000	0.00	0.067	100.00	0.067	100.00	WEST
LEFT-1	SPACE4-1	0.467	100.00	0.067	300.00	0.167	400.00	WEST
TOP-1	PLENUM-1	0.000	0.00	0.047	5000.00	0.047	5000.00	ROOF
F1-1	SPACE1-1	0.000	0.00	0.050	1056.00	0.050	1056.00	UNDERGRND
F2-1	SPACE2-1	0.000	0.00	0.270	456.00	0.270	456.00	UNDERGRND
F3-1	SPACE3-1	0.000	0.00	0.050	1056.00	0.050	1056.00	UNDERGRND
F4-1	SPACE4-1	0.000	0.00	0.050	456.00	0.050	456.00	UNDERGRND
F5-1	SPACE5-1	0.000	0.00	0.050	1976.00	0.050	1976.00	UNDERGRND

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- LV-D DETAILS OF EXTERIOR SURFACES IN THE PROJECT

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993LDL RUN 4

WEATHER FILE- TRY CHICAGO

(CONTINUED)

	AVERAGE U-VALUE/WINDOWS (BTU/HR-SQFT-F)	AVERAGE U-VALUE/WALLS (BTU/HR-SQFT-F)	AVERAGE U-VALUE WALLS+WINDOWS (BTU/HR-SQFT-F)	WINDOW AREA (SQFT)	WALL AREA (SQFT)	WINDOW+WALL AREA (SQFT)
NORTH	0.565	0.067	0.181	229.00	771.00	1000.00
EAST	0.467	0.067	0.147	100.00	400.00	500.00
SOUTH	0.587	0.067	0.194	244.00	756.00	1000.00
WEST	0.467	0.067	0.147	100.00	400.00	500.00
ROOF	0.000	0.047	0.047	0.00	5000.00	5000.00
ALL WALLS	0.544	0.067	0.174	673.00	2327.00	3000.00
WALLS+ROOFS	0.544	0.053	0.095	673.00	7327.00	8000.00
UNDERGRND	0.000	0.070	0.070	0.00	5000.00	5000.00
BUILDING	0.544	0.060	0.085	673.00	12327.00	13000.00

*** BUILDING ***

FLOOR AREA 5000 SQFT 465 SQMT
 VOLUME 50000 CUFT 1416 CURT

TIME	COOLING LOAD		HEATING LOAD	
	AUG 19	6PM	FEB 4	6AM
DRY-BULB TEMP	90F	32C	7F	-14C
WET-BULB TEMP	71F	22C	6F	-14C

	SENSIBLE		LATENT		SENSIBLE			
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)		
WALL CONDUCTION	4.297	1.259	0.000	0.000	-7.004	-2.052		
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000		
WINDOW GLASS-FRM COND	8.963	2.626	0.000	0.000	-21.909	-6.419		
WINDOW GLASS SOLAR	29.977	8.783	0.000	0.000	1.242	0.364		
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000		
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000		
UNDERGROUND SURF COND	-1.401	-0.411	0.000	0.000	-11.561	-3.387		
OCCUPANTS TO SPACE	11.607	3.401	6.776	1.985	0.001	0.000		
LIGHT TO SPACE	17.920	5.251	0.000	0.000	1.026	0.301		
EQUIPMENT TO SPACE	8.872	2.599	0.000	0.000	0.830	0.243		
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000		
INFILTRATION	0.000	0.000	0.000	0.000	-9.685	-2.838		
TOTAL	80.234	23.508	6.776	1.985	-47.060	-13.788		
TOTAL LOAD	87.009 KBTU/H		25.494 KW		-47.060 KBTU/H		-13.788 KW	
TOTAL LOAD / AREA	17.40BTU/H.SQFT		54.882 W /SQMT		9.412BTU/H.SQFT		29.684 W /SQMT	

 *
 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 *

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	4.49885	25 16	48.F	42.F	46.997	-12.798	7 5	2.F	2.F	-45.880	3027.	12.000
FEB	4.07415	15 16	31.F	26.F	48.481	-11.796	4 6	7.F	6.F	-47.060	2654.	12.000
MAR	5.82094	5 17	57.F	46.F	48.474	-8.775	24 6	8.F	7.F	-44.483	2936.	12.000
APR	11.70507	26 15	78.F	61.F	65.887	-2.922	8 6	32.F	29.F	-23.486	2994.	12.000
MAY	14.89968	20 15	77.F	68.F	66.853	-1.170	9 5	40.F	38.F	-13.599	3027.	12.000
JUN	18.99737	20 15	90.F	77.F	74.772	-0.193	17 5	54.F	49.F	-5.237	2812.	12.000
JUL	24.94236	9 15	94.F	74.F	79.777	-0.004	5 5	60.F	54.F	-0.472	3027.	12.000
AUG	22.82894	19 17	90.F	71.F	80.234	-0.009	5 5	55.F	54.F	-2.754	3027.	12.000
SEP	17.11742	26 16	82.F	61.F	76.772	-0.483	23 6	37.F	34.F	-12.273	2812.	12.000
OCT	13.00402	10 16	68.F	53.F	70.816	-1.900	21 6	30.F	29.F	-18.011	3027.	12.000
NOV	6.24292	8 15	60.F	49.F	64.713	-6.776	15 6	28.F	26.F	-30.286	2720.	12.000
DEC	4.20004	10 15	41.F	35.F	49.924	-11.676	9 6	14.F	13.F	-38.725	2936.	12.000
TOTAL	148.332					-58.501					34996.	
MAX					80.234					-47.060		12.000

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993SDL RUN 2

SYST-1

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
SYST-1	VAVS	1.020	5000.0	52.									
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	
	7513.	8.646	3.6	0.	0.000	0.0	0.141	216.189	0.804	-1.917	0.00	0.37	
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	SPACE5-1	1850.	0.	0.000	0.300	408.	0.00	0.00	31.97	-115.90	-95.92	1.0	
	SPACE1-1	2176.	0.	0.000	0.300	224.	0.00	0.00	37.60	-136.28	-112.79	1.0	
	SPACE2-1	976.	0.	0.000	0.300	102.	0.00	0.00	16.87	-61.15	-50.60	1.0	
	SPACE3-1	1539.	0.	0.000	0.300	224.	0.00	0.00	26.60	-96.41	-79.79	1.0	
	SPACE4-1	972.	0.	0.000	0.300	102.	0.00	0.00	16.80	-60.89	-50.39	1.0	
	PLENUM-1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-24.696	7 8	-1.F	-1.F	-393.441	3292.	12.886
FEB	0.00000				0.000	-19.176	4 8	7.F	6.F	-395.605	2871.	12.862
MAR	0.00000				0.000	-11.439	25 8	14.F	12.F	-357.888	3147.	12.862
APR	1.64851	29 18	69.F	65.F	52.931	-2.702	1 8	43.F	39.F	-190.842	3194.	12.862
MAY	4.78337	21 14	85.F	75.F	108.533	-0.073	9 9	43.F	39.F	-22.369	3261.	13.490
JUN	13.31118	20 17	90.F	78.F	144.459	0.000				0.000	3192.	14.251
JUL	25.36230	15 8	72.F	70.F	208.830	0.000				0.000	3779.	18.752
AUG	21.61059	26 15	90.F	75.F	152.463	0.000				0.000	3616.	16.577
SEP	9.14995	11 15	87.F	72.F	120.025	-0.007	23 9	39.F	36.F	-6.566	3133.	14.966
OCT	2.83521	4 17	78.F	61.F	52.819	-0.704	21 8	30.F	29.F	-157.061	3223.	12.862
NOV	0.37585	1 16	72.F	59.F	49.879	-9.119	18 8	34.F	34.F	-244.497	2904.	12.862
DEC	0.00000				0.000	-18.609	9 8	13.F	12.F	-353.233	3161.	12.862
TOTAL	79.077					-86.524					38773.	
MAX					208.830					-395.605		18.752

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
	JUL 15				FEB 4			JUL 8			
1	0.000	0.000	77.F	72.F	0.000	11.F	9.F	0.000	0.000	76.F	68.F
2	0.000	0.000	77.F	72.F	-100.562	11.F	9.F	0.000	0.000	76.F	68.F
3	0.000	0.000	76.F	71.F	0.000	10.F	9.F	0.000	0.000	75.F	68.F
4	0.000	0.000	75.F	71.F	-108.452	9.F	8.F	0.000	0.000	74.F	68.F
5	0.000	0.000	73.F	70.F	0.000	8.F	7.F	0.000	0.000	73.F	67.F
6	0.000	0.000	72.F	70.F	-119.407	7.F	6.F	0.000	0.000	72.F	67.F
7	208.830 *	0.881	72.F	70.F	0.000	6.F	5.F	191.575 *	0.928	72.F	67.F
8	199.172 *	0.861	75.F	70.F	-395.605	7.F	6.F	196.065 *	0.870	77.F	70.F
9	177.857	0.873	76.F	69.F	-246.265	7.F	6.F	188.506	0.861	83.F	72.F
10	173.407	0.883	78.F	69.F	-194.114	10.F	9.F	193.424	0.842	86.F	74.F
11	169.101	0.880	80.F	70.F	-163.056	14.F	13.F	186.416	0.861	89.F	74.F
12	154.657	0.893	81.F	70.F	-139.462	18.F	17.F	169.024	0.893	90.F	73.F
13	161.425	0.865	82.F	71.F	-118.089	23.F	21.F	173.001	0.886	91.F	73.F
14	158.620	0.887	83.F	70.F	-103.090	24.F	22.F	174.959	0.887	92.F	73.F
15	152.590	0.893	81.F	69.F	-90.578	24.F	21.F	177.597	0.866	92.F	74.F
16	144.039	0.885	80.F	69.F	-85.341	23.F	22.F	166.044	0.891	93.F	73.F
17	142.142	0.873	79.F	69.F	-80.663	22.F	21.F	162.546	0.889	93.F	73.F
18	0.000	0.000	77.F	67.F	-78.142	21.F	20.F	0.000	0.000	92.F	73.F
19	0.000	0.000	76.F	67.F	0.000	20.F	19.F	0.000	0.000	90.F	72.F
20	0.000	0.000	74.F	66.F	0.000	19.F	17.F	0.000	0.000	83.F	70.F
21	0.000	0.000	71.F	65.F	0.000	20.F	18.F	0.000	0.000	82.F	68.F
22	0.000	0.000	69.F	64.F	0.000	21.F	19.F	0.000	0.000	82.F	70.F
23	0.000	0.000	67.F	63.F	0.000	22.F	20.F	0.000	0.000	82.F	70.F
24	0.000	0.000	67.F	63.F	0.000	22.F	20.F	0.000	0.000	80.F	69.F
SUM								1979.156			
MAX	208.830				-395.605						

SYSTEM-TYPE	VAVS	SQFT/TON	287.3
COOLING PEAK	41.77 (BTU/HR- SQFT)	HEATING PEAK	-79.12 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.50 (CFM/SQFT)	MIN-OA/PERSON	20.40 (CFM)
OA FRAC AT CLG PEAK	0.156	OA FRAC AT HTG PEAK	0.211

* ASTERISKS INDICATE HOURS LOADS NOT MET

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- PV-A EQUIPMENT SIZES

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 2

WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	0.457	1 1										
HERM-REC-CHLR	0.222	1 1										

S I T E E N E R G Y													* SOURCE
MONTH	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	25.4	0.0	4.0	0.0	0.0	0.0	0.0	39.8	0.7	0.0	39.8	53.4	80.5
FEB	19.8	0.0	3.4	0.0	0.0	0.0	0.0	30.9	0.5	0.0	30.9	42.5	65.7
MAR	12.1	0.0	3.5	0.0	0.0	0.0	0.0	19.1	0.4	0.0	19.1	31.1	55.2
APR	3.0	1.9	3.6	0.0	0.0	0.0	0.3	4.8	0.1	0.0	4.8	17.2	41.8
MAY	0.1	5.3	4.0	0.0	0.0	0.0	0.7	0.2	0.0	0.0	0.2	13.8	41.1
JUN	0.0	14.2	5.0	0.0	0.0	0.0	1.8	0.0	0.0	0.0	0.0	17.0	51.1
JUL	0.0	26.4	6.8	0.0	0.0	0.0	3.0	0.0	0.0	0.0	0.0	23.1	69.2
AUG	0.0	22.6	6.3	0.0	0.0	0.0	2.7	0.0	0.0	0.0	0.0	21.4	64.3
SEP	0.0	9.8	4.4	0.0	0.0	0.0	1.3	0.0	0.0	0.0	0.0	15.0	45.0
OCT	0.8	3.2	3.8	0.0	0.0	0.0	0.5	1.3	0.0	0.0	1.3	14.1	39.8
NOV	9.6	0.4	3.3	0.0	0.0	0.0	0.1	15.3	0.3	0.0	15.3	26.5	48.9
DEC	19.2	0.0	3.7	0.0	0.0	0.0	0.0	30.1	0.5	0.0	30.1	42.7	67.9
TOTAL	90.1	83.8	51.6	0.0	0.0	0.0	10.3	141.6	2.6	0.0	141.6	317.8	670.4

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	90.1	100.0
LOAD SATISFIED	90.1	100.0
TOTAL LOAD ON PLANT	90.1	
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HERM-REC-CHLR	83.8	100.0
LOAD SATISFIED	83.8	100.0
TOTAL LOAD ON PLANT	83.8	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	51640.9	100.0
LOAD SATISFIED	51640.9	100.0
TOTAL LOAD ON PLANT	51639.6	

SIMPLE STRUCTURE RUN 3A, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- PS-D PLANT LOADS SATISFIED

INCREASED ROOF INSULATION
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993PDL RUN 2

WEATHER FILE- TRY CHICAGO

(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	90.1	90.1	0.000	0.000	0
COOLING LOADS	83.8	83.8	0.000	0.000	0
ELECTRICAL LOADS	176.2	176.2	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE -----		
AREA LIGHTS	74.7	0.0
MISC EQUIPMT	44.7	0.0
SPACE HEAT	6.9	141.6
SPACE COOL	26.6	0.0
HEAT REJECT	5.9	0.0
PUMPS & MISC	4.6	0.0
VENT FANS	12.9	0.0
	-----	-----
TOTAL	176.2	141.6

TOTAL SITE ENERGY 317.85 MBTU 63.6 KBTU/SQFT-YR GROSS-AREA 63.6 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 670.40 MBTU 134.1 KBTU/SQFT-YR GROSS-AREA 134.1 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.4
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

LIFE-CYCLE COSTING PARAMETERS

DISCOUNT RATE (PERCENT)	LABOR INFLATION RATE (PERCENT)	MATERIALS INFLATION RATE (PERCENT)	PROJECT LIFE (YRS)
5.0	0.0	0.0	25.0

BUILDING COMPONENT COST INPUT DATA (CURRENT DOLLARS)

COST NAME	NUMBER OF UNITS	UNIT NAME	LIFE (YRS)	UNIT FIRST COST (\$)	UNIT INSTALL -ATION COST (\$)	UNIT ANNUAL MAINT COST (\$)	UNIT MINOR OVERHAUL COST (\$)	MINOR OVERHAUL INTERVAL (YRS)	UNIT MAJOR OVERHAUL COST (\$)	MAJOR OVERHAUL INTERVAL (YRS)
ROOF-INSUL	5000.0	SQFT	999.0	0.80	0.30	0.00	0.00	999.00	0.00	999.00

YEAR	ENERGY (\$)			OPERATIONS (\$)				TOTAL SAVINGS- ENERGY PLUS OPRNS	
	ENERGY COST	ENERGY COST	ENERGY COST	OPRNS COST	OPRNS COST -- THIS RUN				OPRNS COST
	BASELINE	THIS RUN	SAVINGS	BASELINE	PLANT	BUILDING	TOTAL		SAVINGS
1	4369.	4111.	258.	249.	249.	0.	249.	0.	258.
2	4431.	4173.	258.	238.	238.	0.	238.	0.	259.
3	4493.	4236.	257.	314.	226.	0.	226.	88.	345.
4	4557.	4301.	256.	216.	215.	0.	215.	1.	257.
5	4622.	4366.	256.	205.	205.	0.	205.	0.	256.
6	4688.	4433.	255.	272.	195.	0.	195.	77.	331.
7	4756.	4502.	254.	186.	186.	0.	186.	0.	254.
8	4824.	4571.	253.	412.	177.	0.	177.	235.	488.
9	4894.	4642.	252.	236.	169.	0.	169.	67.	319.
10	4966.	4714.	252.	161.	161.	0.	161.	0.	252.
11	5038.	4788.	250.	212.	153.	0.	153.	59.	309.
12	5113.	4863.	250.	146.	146.	0.	146.	0.	250.
13	5188.	4939.	249.	139.	139.	0.	139.	0.	249.
14	5265.	5017.	248.	928.	132.	0.	132.	696.	944.
15	5344.	5097.	247.	126.	126.	0.	126.	0.	247.
16	5424.	5177.	247.	279.	120.	0.	120.	159.	406.
17	5505.	5260.	245.	159.	114.	0.	114.	45.	290.
18	5588.	5344.	244.	109.	109.	0.	109.	0.	244.
19	5673.	5429.	244.	104.	104.	0.	104.	0.	244.
20	5759.	5517.	242.	531.	99.	0.	99.	432.	675.
21	5847.	5606.	241.	94.	94.	0.	94.	0.	241.
22	5936.	5696.	240.	124.	90.	0.	90.	34.	274.
23	6027.	5789.	238.	85.	85.	0.	85.	0.	238.
24	6120.	5883.	237.	189.	81.	0.	81.	108.	345.
25	6215.	5978.	237.	108.	77.	0.	77.	31.	267.
TOTALS (\$)	130642.	124431.	6211.	5722.	3691.	0.	3691.	2031.	8243.

SIMPLE STRUCTURE RUN 3A, CHICAGO
DESIGN-DAY SIZING OF VAV SYSTEM
REPORT- ES-B LIFE-CYCLE BUILDING AND PLANT NON-ENERGY COSTS

INCREASED ROOF INSULATION
SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

LIFE-CYCLE BUILDING AND PLANT NON-ENERGY COSTS (\$)

COST NAME	FIRST COST (INCLUDING INSTALLATION)	REPLACEMENTS	OPERATIONS	TOTAL	INVESTMENT (FIRST COST PLUS REPLACEMENTS)
-----	-----	-----	-----	-----	-----
ROOF-INSUL	5500.	0.	0.	5500.	5500.
PLANT EQUIPMENT	29273.	0.	3691.	32964.	29273.
-----	-----	-----	-----	-----	-----
TOTALS	34773.	0.	3691.	38464.	34773.

ENERGY SAVINGS

	ANNUAL ENERGY USE BASELINE		ANNUAL ENERGY USE THIS RUN		ANNUAL ENERGY SAVINGS		ANNUAL ENERGY SAVINGS (PCT)
	(MBTU)	(MWH)	(MBTU)	(MWH)	(MBTU)	(MWH)	
AT SITE	363.93	106.63	317.85	93.13	46.08	13.50	12.7
AT SOURCE	709.67	207.93	670.40	196.43	39.27	11.51	5.5

INVESTMENT STATISTICS

PROJECT LIFE 25.0 YEARS

INVESTMENT THIS RUN (\$)	BASELINE REPLACEMENT COSTS (\$)	INCREMENTAL INVESTMENT (\$)	COST SAVINGS (\$)	RATIO OF SAVINGS TO INCREMENTAL INVESTMENT (SIR)	DISCOUNTED PAYBACK PERIOD (YEARS)	RATIO OF LIFE CYCLE ENERGY SAVINGS (AT SITE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)	RATIO OF LIFE-CYCLE ENERGY SAVINGS (AT SOURCE) TO INCREMENTAL INVESTMENT (MBTU/\$)	(MWH/\$)
34773.	0.	5475.	8243.	1.51	16.18	0.21	0.06	0.18	0.05

OVERALL LIFE-CYCLE COSTS (\$)

	FIRST COST	OPRNS COST	REPLACEMENTS	ENERGY COST	T O T A L
BASELINE	29298.	5722.	0.	130642.	165662.
THIS RUN	34773.	3691.	0.	124431.	162894.
SAVINGS (\$)	-5475.	2031.	0.	6211.	2768.
(PCT)	-18.7	35.5	0.0	4.8	1.7

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-D ENERGY COST SUMMARY

INCREASED ROOF INSULATION
 SHOW ALL REPORTS

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-TARIFF	ELECTRICITY	1 2 3 4 5	51641. KWH	3261.	0.0631	YES
GAS-RATE	NATURAL-GAS	1 2 3 4 5	1416. THERMS	850.	0.6000	YES

 4111.

ENERGY COST/GROSS BLDG AREA: 0.82
 ENERGY COST/NET BLDG AREA: 0.82

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

INCREASED ROOF INSULATION
 SHOW ALL REPORTS
 ELEC-TARIFF

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

UTILITY-RATE: ELEC-TARIFF

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	3972	3972	16.3	16.3	247	0	0	0	0	0	0	0.0622	247
FEB	3400	3400	16.2	16.2	212	0	0	0	0	0	0	0.0623	212
MAR	3525	3525	16.2	16.2	220	0	0	0	0	0	0	0.0624	220
APR	3613	3613	20.1	20.1	228	0	0	0	0	0	0	0.0632	228
MAY	3993	3993	26.4	26.4	253	0	0	0	0	0	0	0.0635	253
JUN	4992	4992	30.4	30.4	318	0	0	0	0	0	0	0.0637	318
JUL	6757	6757	37.6	37.6	430	0	0	0	0	0	0	0.0636	430
AUG	6276	6276	32.8	32.8	400	0	0	0	0	0	0	0.0638	400
SEP	4396	4396	28.7	28.7	280	0	0	0	0	0	0	0.0637	280
OCT	3755	3755	20.2	20.2	238	0	0	0	0	0	0	0.0634	238
NOV	3274	3274	20.1	20.1	204	0	0	0	0	0	0	0.0624	204
DEC	3688	3688	16.2	16.2	230	0	0	0	0	0	0	0.0624	230
TOTAL	51641	51641	37.6		3261	0	0	0	0	0		0.0631	3261

SIMPLE STRUCTURE RUN 3A, CHICAGO
 DESIGN-DAY SIZING OF VAV SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

INCREASED ROOF INSULATION
 SHOW ALL REPORTS
 GAS-RATE

DOE-2.1E-001 Thu Nov 4 16:29:40 1993EDL RUN 2

UTILITY-RATE: GAS-RATE

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDO... HOUR
 BILLING-DA... 31

100000. BTU/THERMS
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS


MIN-WON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERMS	BILLING ENERGY THERMS	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	398	398	5.1	5.1	239	0	0	0	0	0	0	0.6000	239
FEB	309	309	5.1	5.1	185	0	0	0	0	0	0	0.6000	185
MAR	191	191	4.7	4.7	115	0	0	0	0	0	0	0.6000	115
APR	48	48	2.8	2.8	29	0	0	0	0	0	0	0.6000	29
MAY	2	2	0.4	0.4	1	0	0	0	0	0	0	0.6000	1
JUN	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
JUL	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
AUG	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
SEP	0	0	0.2	0.2	0	0	0	0	0	0	0	0.6000	0
OCT	13	13	2.4	2.4	8	0	0	0	0	0	0	0.6000	8
NOV	153	153	3.4	3.4	92	0	0	0	0	0	0	0.6000	92
DEC	301	301	4.6	4.6	181	0	0	0	0	0	0	0.6000	181
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
TOTAL	1416	1416	5.1		850	0	0	0	0	0		0.6000	850

31-Story Office Building


Plan and elevation views. Each floor is divided into four perimeter zones and one core zone.



XBL 791-8074

31-Story Office Building, LOAD1

DrawBDL axonometric view of top floor and mid-floor (multiplier = 30) as input into BDL. The roof and interior surfaces are not shown.



791-8074A

LDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993LDL RUN 1

```

* 2 * TITLE          LINE-1 *31-STORY OFFICE BLDG, CHICAGO - LOAD1*
* 3 *              LINE-2 *STD ASHRAE WEIGHTING FACTORS * ..
* 4 *
* 5 *              ABORT      ERRORS      ..
* 6 *              DIAGNOSTIC  WARNINGS   ..
* 7 *
* 8 *              LOADS-REPORT  SUMMARY=(LS-C,LS-D)    ..
* 9 *              RUN-PERIOD   JAN 1 1988 THRU DEC 31 1988 ..
* 10 *             BUILDING-LOCATION LATITUDE=42  LONGITUDE=88
* 11 *                                     TIME-ZONE=6  ALTITUDE=610 ..
* 12 *
* 13 *              $ BUILDING DESCRIPTION
* 14 *
* 15 * $ STRUCTURE   STEEL FRAME WITH 4IN CONCRETE FLOORS AND ROOF.  31 OCCUPIED
* 16 * $             STORIES, 13FT FLOOR TO FLOOR HEIGHT, 9FT CEILINGS.  RETURN
* 17 * $             AIR CEILING PLENUMS ARE NOT DEFINED PER SE -- INPUT USES THE
* 18 * $             SIMPLER APPROACH OF RETURN-AIR-PATH = DUCT.
* 19 *
* 20 * $ CURTAIN WALL USING CODE-WORDS FROM DOE-2 LIBRARY ( REFERENCE MANUAL PART 2 )
* 21 * $             AND STARTING WITH OUTSIDE WORKING INWARD; 1/4IN SPANDREL GLASS
* 22 * $             ( NOT IN LIBRARY - SEE MATERIAL SPGL ); 2IN POLYSTYRENE INSUL
* 23 * $             R-8 (IN35); STEEL BACKPANEL (AS01); 2IN AIRSPACE (AL21);
* 24 * $             3/4IN GYPSUM BOARD FINISH (GP03) .
* 25 *
* 26 * $ ROOF        ROOF GRAVEL (RG02); BUILT-UP ROOFING (BR01); 3IN ROOF INSUL R-8
* 27 * $             (IN76); 4IN CONCRETE (CC03); INSIDE-FILM-RESISTANCE .76 .
* 28 *
* 29 * $ WINDOWS     DOUBLE-GLAZED TINTED, SOLAR TRANSMITTANCE=.53, GLASS TYPE CODE=5.
* 30 * $             WINDOWS HAVE INSIDE BLINDS WITH A 70% PROBABILITY OF BEING PULLED
* 31 * $             IF TRANSMITTED DIRECT SOLAR RADIATION EXCEEDS 40BTUH PER SQFT.
* 32 * $             BLINDS ARE CONSIDERED TO BE REOPENED WITH A PROBABILITY OF 50%
* 33 * $             WHEN TRANSMITTED DIRECT SOLAR IS LESS THAN 40BTUH PER SQFT.
* 34 *
* 35 * $ INTERIORS   CEILINGS ARE SUSPENDED ACCOUSTIC TILE.
* 36 * $             PARTITIONS SIMULATE CONVECTIVE HEAT TRANSFER BETWEEN CORE AND
* 37 * $             PERIMETER SPACES USING A U-VALUE OF 1.5 BTUH/SQFT-F
* 38 *
* 39 * $ SPACE LOADS  LIGHTING IS RECESSED FLUORESCENT AT 1.5 WATTS/SQFT.
* 40 * $             OFFICE EQUIPMENT IS 1 WATTS/SQFT.
* 41 * $             PEOPLE: 100SQFT/PERSON FOR PERIMETER SPACES
* 42 * $             200SQFT/PERSON FOR CORE AREAS.
* 43 * $             INFILTRATION IS .3 AIR CHANGES/HR FOR PERIMETER AREAS WHEN FANS
* 44 * $             ARE OFF, AND .06 AIR CHANGES/HR WHEN FANS ARE ON.
* 45 *
* 46 * $ HVAC DESCRIPTIONS ARE GIVEN WITH EACH INDIVIDUAL SYSTEM AND PLANT INPUT.
* 47 *
* 48 *              $ MATERIALS NOT IN DOE-2 LIBRARY
* 49 *
* 50 * SPGS=MATERIAL  TH=.0208  COND=.590  DENS=172.  S-H=.20
* 51 *
* 52 *              $ WALL CONSTRUCTIONS
* 53 *
* 54 * ROOFER         LAYERS MAT (RG02,BR01,IN76,CC03)  I-F-R .76 ..
* 55 * WALLER         LAYERS MAT (SPGS,IN35,AS01,AL21,GP03) ..
* 56 * RF            =CONSTRUCTION  LAYERS=ROOFER ..

```

```

* 57 * WL1      =CONSTRUCTION   LAYERS=WALLER ..
* 58 * BW      =CONSTRUCTION   U=.05 ..
* 59 * SB-U    =CONSTRUCTION   U=1.5 ..
* 60 *
* 61 *          $ GLASS DESCRIPTION
* 62 *
* 63 * GT1     GLASS-TYPE G-T-C 5 PANES 2 ..
* 64 *
* 65 *          $ SCHEDULES
* 66 *
* 67 * OC1     =DAY-SCHEDULE   (1,8) (0.)      (9,10) (1.)
* 68 *          (11,13) (.8,.4,.8) (14,24) (1.,1.,1.,
* 69 *          .3,.1.,1.,1.0.,0.,0.,0.) ..
* 70 * OC2     =DAY-SCHEDULE   (1,24) (0.0) ..
* 71 * PEOPLE  =WEEK-SCHEDULE (MON,FRI) OC1 (WEH) OC2 ..
* 72 * OCCUP   =SCHEDULE      THRU DEC 31 PEOPLE ..
* 73 *
* 74 * L1      =DAY-SCHEDULE   (1,6) (.05)      (7,24) (.1,.9,.9,
* 75 *          .95,.95,.95,.8,.8,.9,.9,.95,.8,.7,.6,
* 76 *          .4,.3,.2,.2) ..
* 77 * L2      =DAY-SCHEDULE   (1,24) (.05) ..
* 78 * LIGHTS  =WEEK-SCHEDULE (MON,FRI) L1 (WEH) L2 ..
* 79 * LT1     =SCHEDULE      THRU DEC 31 LIGHTS ..
* 80 *
* 81 * ES1     =DAY-SCHEDULE   (1,8) (0.)      (9,20) (.35,.50,
* 82 *          .55,.9,.6,.8,.7,.75,.3,.3,.5,.05)
* 83 *          (21,24) (0.0) ..
* 84 * ES2     =DAY-SCHEDULE   (1,24) (0.0) ..
* 85 * EQUIP   =WEEK-SCHEDULE (MON,FRI) ES1 (WEH) ES2 ..
* 86 * EQ1     =SCHEDULE      THRU DEC 31 EQUIP ..
* 87 *
* 88 * I1      =DAY-SCHEDULE   (1,7) (1.)      (8,18) (0.2)
* 89 *          (19,24) (1.) ..
* 90 * I2      =DAY-SCHEDULE   (1,24) (1.) ..
* 91 * INFILT  =WEEK-SCHEDULE (MON,FRI) I1 (WEH) I2 ..
* 92 * INF1    =SCHEDULE      THRU DEC 31 INFILT ..
* 93 *
* 94 * SHADE-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.5) ..
* 95 * CLOSE-SHADE =SCHEDULE THRU DEC 31 (ALL) (1,24) (40) ..
* 96 * OPEN-PROB =SCHEDULE THRU DEC 31 (ALL) (1,24) (.5) ..
* 97 *
* 98 *          $ SPACE DESCRIPTIONS
* 99 *
* 100 * OFFICE  =SPACE-CONDITIONS TEMPERATURE=(75) FLOOR-WEIGHT=70
* 101 *          LIGHTING-W/SQFT=1.5 EQUIPMENT-W/SQFT=1
* 102 *          PEOPLE-HEAT-GAIN=450
* 103 *          EQUIP-SCHEDULE=EQ1 LIGHTING-SCHEDULE=LT1
* 104 *          PEOPLE-SCHEDULE=OCCUP AIR-CHANGES/HR=.3
* 105 *          INF-SCHEDULE=INF1 LIGHT-TO-SPACE=.80
* 106 *          INF-METHOD=AIR-CHANGE
* 107 *          LIGHTING-TYPE=REC-FLUOR-RV ..
* 108 *
* 109 * A-STORAGE =SPACE          TEMPERATURE=(75) FLOOR-WEIGHT=150
* 110 *          VOLUME=400000 AREA=20000
* 111 *          LIGHTING-W/SQFT=1.5
* 112 *          LIGHTING-SCHEDULE=LT1 ..
* 113 *          UNDERGROUND-WALL AREA=12000 CONSTRUCTION=BW ..
* 114 *          UNDERGROUND-FLOOR AREA=20000 CONSTRUCTION=BW ..
* 115 *
* 116 *          SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=13.0 AZIMUTH=180 ..
* 117 *          SET-DEFAULT FOR WINDOW HEIGHT=6.5 Y=2.5 GLASS-TYPE=GT1
* 118 *          MAX-SOLAR-SCH=CLOSE-SHADE
* 119 *          WIN-SHADE-TYPE=MOVABLE-INTERIOR

```



```

* 120 *
* 121 *
* 122 *
* 123 *
* 124 * RZ1      =SPACE      SPACE-CONDITIONS=OFFICE VOLUME=107100
* 125 *          AREA=11900 NUMBER-OF-PEOPLE=60
* 126 *          AIR-CHANGES/HR=0.01 X=15 Y=15 Z=390 ..
* 127 * ROOF1    =ROOF        HEIGHT=170 WIDTH=70 AZIMUTH=180 TILT=0
* 128 *          GND-REFLECTANCE=0 CONSTRUCTION=RF ..
* 129 * IR22     =INTERIOR-WALL NEXT-TO R22 AREA=1530
* 130 *          CONSTRUCTION=SB-U ..
* 131 * IR23     =INTERIOR-WALL NEXT-TO R23 AREA=630
* 132 *          CONSTRUCTION=SB-U ..
* 133 * IR24     =INTERIOR-WALL LIKE IR22 NEXT-TO R24 ..
* 134 * IR25     =INTERIOR-WALL LIKE IR23 NEXT-TO R25 ..
* 135 *
* 136 * RZ2      =SPACE      SPACE-CONDITIONS=OFFICE VOLUME=24975
* 137 *          AREA=2775 NUMBER-OF-PEOPLE=28
* 138 *          AZIMUTH=-90 X=100 Y=200 Z=390 ..
* 139 * E2       =EXTERIOR-WALL WIDTH=200 CONSTRUCTION=WL1 ..
* 140 * W2       =WINDOW      WIDTH=200 ..
* 141 * ROOF2    =ROOF        HEIGHT=15 WIDTH=185 AZIMUTH=180 TILT=0
* 142 *          GND-REFLECTANCE=0 CONSTRUCTION=RF ..
* 143 *
* 144 * RZ3      =SPACE      SPACE-CONDITIONS= OFFICE VOLUME=11475
* 145 *          AREA=1275 NUMBER-OF-PEOPLE=13
* 146 *          AZIMUTH=180 X=100 Y=200 Z=390 ..
* 147 * E3       =EXTERIOR-WALL WIDTH=100 CONSTRUCTION=WL1 ..
* 148 * W3       =WINDOW      WIDTH=100 ..
* 149 * ROOF3    =ROOF        HEIGHT=15 WIDTH=85 AZIMUTH=180 TILT=0
* 150 *          GND-REFLECTANCE=0 CONSTRUCTION=RF ..
* 151 *
* 152 * RZ4      =SPACE      LIKE R22 AZIMUTH=90 X=0 Y=200 ..
* 153 *          EXTERIOR-WALL LIKE E2 ..
* 154 *          WINDOW      LIKE W2 ..
* 155 *          ROOF        LIKE ROOF2 ..
* 156 *
* 157 * RZ5      =SPACE      LIKE R23 AZIMUTH=0 X=0 Y=0 ..
* 158 *          EXTERIOR-WALL LIKE E3 ..
* 159 *          WINDOW      LIKE W3 ..
* 160 *          ROOF        LIKE ROOF3 ..
* 161 *
* 162 * T21      =SPACE      LIKE RZ1 FLOOR-MULTIPLIER=30 Z=195 ..
* 163 * IT22     =INTERIOR-WALL LIKE IR22 NEXT-TO T22 ..
* 164 * IT23     =INTERIOR-WALL LIKE IR23 NEXT-TO T23 ..
* 165 * IT24     =INTERIOR-WALL LIKE IR22 NEXT-TO T24 ..
* 166 * IT25     =INTERIOR-WALL LIKE IR23 NEXT-TO T25 ..
* 167 *
* 168 * T22      =SPACE      LIKE R22 FLOOR-MULTIPLIER=30 Z=195 ..
* 169 *          EXTERIOR-WALL LIKE E2 ..
* 170 *          WINDOW      LIKE W2 ..
* 171 *
* 172 * T23      =SPACE      LIKE R23 FLOOR-MULTIPLIER=30 Z=195 ..
* 173 *          EXTERIOR-WALL LIKE E3 ..
* 174 *          WINDOW      LIKE W3 ..
* 175 *
* 176 * T24      =SPACE      LIKE R24 FLOOR-MULTIPLIER=30 Z=195 ..
* 177 *          EXTERIOR-WALL LIKE E2 ..
* 178 *          WINDOW      LIKE W2 ..
* 179 *
* 180 * T25      =SPACE      LIKE R25 FLOOR-MULTIPLIER=30 Z=195 ..
* 181 *          EXTERIOR-WALL LIKE E3 ..
* 182 *          WINDOW      LIKE W3 ..

```

* 183 *
* 184 * END ..
* 185 * COMPUTE LOADS ..
* 186 * INPUT SYSTEMS ..

*** BUILDING ***

FLOOR AREA 640000 SQFT 59456 SQMT
 VOLUME 5980000 CUFT 169354 CUMT

TIME	COOLING LOAD		HEATING LOAD	
	***** JUL 9 4PM		***** JAN 1 7AM	
DRY-BULB TEMP	94F	34C	-1F	-18C
WET-BULB TEMP	74F	23C	-1F	-18C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	316.266	92.666	0.000	0.000	-826.453	-242.151
ROOF CONDUCTION	40.922	11.990	0.000	0.000	-143.559	-42.063
WINDOW GLASS+FRM COND	1681.924	492.804	0.000	0.000	-4335.515	-1270.306
WINDOW GLASS SOLAR	3562.686	1043.867	0.000	0.000	290.437	85.098
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-17.600	-5.157	0.000	0.000	-56.000	-16.408
OCCUPANTS TO SPACE	1014.692	297.305	780.200	228.598	0.000	0.000
LIGHT TO SPACE	2123.957	622.319	0.000	0.000	58.976	17.280
EQUIPMENT TO SPACE	1376.767	403.393	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	52.818	15.476	57.857	16.952	-1150.446	-337.081
TOTAL	10152.430	2974.662	838.057	245.551	-6162.560	-1805.630
TOTAL LOAD	10990.487 KBTU/H		3220.213 KW		-6162.560 KBTU/H	-1805.630 KW
TOTAL LOAD / AREA	17.17BTU/H.SQFT		54.160 W /SQMT		9.629BTU/H.SQFT	30.368 W /SQMT

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *

REPORT- LS-D BUILDING MONTHLY LOADS SUMMARY

WEATHER FILE- TRY CHICAGO

----- COOLING -----							----- HEATING -----					----- ELEC -----		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	675.86096	25	16	48.F	42.F	4729.054	-1853.456	1	7	-1.F	-1.F	-6162.559	332713.	1470.000
FEB	690.91943	25	16	27.F	22.F	5383.071	-1533.816	4	6	7.F	6.F	-5747.923	314407.	1470.000
MAR	1013.27417	3	16	79.F	62.F	7047.375	-1015.720	24	6	8.F	7.F	-5839.985	377263.	1470.000
APR	1531.55164	27	15	82.F	61.F	8987.365	-456.614	8	6	32.F	29.F	-4188.527	361261.	1470.000
MAY	1839.31677	20	15	77.F	68.F	9168.952	-222.062	9	5	40.F	38.F	-2772.635	332713.	1470.000
JUN	2483.81152	4	15	85.F	67.F	9680.896	-43.781	23	5	52.F	48.F	-1251.471	361261.	1470.000
JUL	2974.76562	9	15	94.F	74.F	10152.431	-5.772	23	5	61.F	60.F	-508.765	347563.	1470.000
AUG	2669.71899	12	15	85.F	72.F	9566.644	-12.595	5	5	55.F	54.F	-684.197	362413.	1470.000
SEP	1839.88354	10	15	82.F	70.F	8846.675	-177.489	22	6	35.F	31.F	-2652.321	346411.	1470.000
OCT	1240.67822	5	15	74.F	62.F	7701.893	-462.705	21	6	30.F	29.F	-3022.637	332713.	1470.000
NOV	848.28888	2	15	75.F	61.F	7152.317	-1158.444	15	3	26.F	25.F	-4633.186	331560.	1470.000
DEC	690.18445	10	15	41.F	35.F	4795.656	-1704.426	9	6	14.F	13.F	-4923.012	347563.	1470.000
TOTAL	18498.254						-8646.882						4147840.	
MAX						10152.431						-6162.559		1470.000

31-Story Office Building, LOAD1 — Run 1 Systems, Plant, Economics

SDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993SDL RUN 1

```

* 187 * TITLE      LINE-4 *RUN 1 DUAL-DUCT VARIABLE VOLUME SYSTEM* ..
* 188 *
* 189 *              $ HVAC SYSTEM DESCRIPTION
* 190 *
* 191 * $ DESIGN TEMPS  COOLING 76F HEATING 70F.
* 192 * $ SYSTEM TYPE  A SINGLE DUAL DUCT VARIABLE VOLUME SYSTEM SERVES THE ENTIRE
* 193 * $                BUILDING. THE SYSTEM HAS A DRY BULB CONTROLLED ECONOMIZER WITH
* 194 * $                A LIMIT TEMP OF 68F, INLET VANES ON BOTH SUPPLY AND RETURN FANS,
* 195 * $                AND THE DD/VAV BOXES HAVE A MINIMUM STOP OF 30%. THE TEMPERATURE
* 196 * $                OF THE COLD DECK SUPPLY AIR IS CONTROLLED BY THE WARMEST ZONE
* 197 * $                AND THE HOT DECK AIR BY THE COLDEST ZONE. MINIMUM VENTILATION
* 198 * $                AIR IS 20 CFM/PERSON AND THE SYSTEM OPERATES FROM 7AM TO 6PM ON
* 199 * $                WEEKDAYS AND IS OFF WEEKENDS AND HOLIDAYS. THERE IS A LOW
* 200 * $                LIMIT SETPOINT OF 55F TO PREVENT FREEZING. FROM MAY 1 THRU NOV 1
* 201 * $                THE SYSTEM IS ALLOWED TO CYCLE ON TO PROVIDE NIGHT VENTILATION
* 202 * $                FOR FREE OA COOLING BUT ONLY IF THE SPACE TEMP IS ABOVE 74F.
* 203 *
* 204 *
* 205 *          SYSTEMS-REPORT      SUMMARY=(SS-A,SS-C,SS-D,SS-J) ..
* 206 *
* 207 *          $ SCHEDULES
* 208 *
* 209 * HRS1          = DAY-SCHEDULE (1,7) (0) (8,18) (1) (19,24) (0) ..
* 210 * HRS2          = DAY-SCHEDULE (1,24) (0) ..
* 211 * DAYS1        = WEEK-SCHEDULE (MON,FRI) HRS1 (WEH) HRS2 ..
* 212 * AHU-SCHED    = SCHEDULE THRU DEC 31  DAYS1 ..          $ FANS $
* 213 *
* 214 * SUMMER-VENT  = SCHEDULE THRU MAY 1 (ALL) (1,24) (0)
* 215 *                THRU NOV 1 (ALL) (1,24) (1)
* 216 *                THRU DEC 31 (ALL) (1,24) (0) ..
* 217 *
* 218 * VENT-SETPT   = SCHEDULE THRU DEC 31 (ALL) (1,24) (74) ..
* 219 *
* 220 * COOLON       = SCHEDULE THRU DEC 31 (ALL) (1,24) (55) ..
* 221 * HEATON       = SCHEDULE THRU DEC 31 (ALL) (1,24) (60) ..
* 222 *
* 223 * HRSH1        = DAY-SCHEDULE (1,7) (55) (8,18) (70) (19,24) (55) ..
* 224 * HRSH2        = DAY-SCHEDULE (1,24) (55) ..
* 225 * DAYHEAT      = WEEK-SCHEDULE (MON,FRI) HRSH1 (WEH) HRSH2 ..
* 226 * THEAT        = SCHEDULE THRU DEC 31  DAYHEAT ..          $ HEATING $
* 227 *
* 228 * HRSC1        = DAY-SCHEDULE (1,7) (99) (8,18) (76) (19,24) (99) ..
* 229 * HRSC2        = DAY-SCHEDULE (1,24) (99) ..
* 230 * DAYCOOL      = WEEK-SCHEDULE (MON,FRI) HRSC1 (WEH) HRSC2 ..
* 231 * TCOOL        = SCHEDULE THRU DEC 31  DAYCOOL ..          $ COOLING $
* 232 *
* 233 *
* 234 *          $ ZONE SUB-COMMANDS
* 235 *
* 236 * SAIR          = ZONE-AIR      OA-CFM/PER=20 ..
* 237 *
* 238 * CONTROL       = ZONE-CONTROL  HEAT-TEMP-SCH=THEAT COOL-TEMP-SCH=TCOOL
* 239 *                DESIGN-HEAT-T=70 DESIGN-COOL-T=74
* 240 *                THERMOSTAT-TYPE=REVERSE-ACTION ..
* 241 *

```

```

* 242 *           $ ZONE DESCRIPTION
* 243 *
* 244 * RZ1       = ZONE           ZONE-TYPE=CONDITIONED ZONE-AIR=SAIR
* 245 *                               ZONE-CONTROL=CONTROL CFM/SQFT=.9 ..
* 246 *
* 247 * RZ2       = ZONE LIKE RZ1 ..
* 248 * RZ3       = ZONE LIKE RZ1 ..
* 249 * RZ4       = ZONE LIKE RZ1 ..
* 250 * RZ5       = ZONE LIKE RZ1 ..
* 251 * TZ1       = ZONE LIKE RZ1 ..
* 252 * TZ2       = ZONE LIKE TZ1 ..
* 253 * TZ3       = ZONE LIKE TZ1 ..
* 254 * TZ4       = ZONE LIKE TZ1 ..
* 255 * TZ5       = ZONE LIKE TZ1 ..
* 256 * A-STORAGE= ZONE LIKE RZ1   AIR-CHANGES/HR=4 OA-CHANGES=0.5 ..
* 257 *
* 258 *           $ SYSTEM SUB-COMMANDS
* 259 *
* 260 * S-CTRL    = SYSTEM-CONTROL COOLING-SCHEDULE=COOLON
* 261 *                               HEATING-SCHEDULE=HEATON
* 262 *                               HEAT-CONTROL=COLDEST COOL-CONTROL=WARMEST
* 263 *                               MAX-SUPPLY-T=105 MIN-SUPPLY-T=55 ..
* 264 *
* 265 * S-FAN     = SYSTEM-FANS     FAN-SCHEDULE=AHU-SCHED FAN-CONTROL=INLET
* 266 *                               SUPPLY-STATIC=5.5 SUPPLY-EFF=0.55
* 267 *                               RETURN-STATIC=2.0 RETURN-EFF=0.55
* 268 *                               NIGHT-VENT-CTRL=SCHEDULED+DEMAND
* 269 *                               NIGHT-VENT-SCH=SUMMER-VENT
* 270 *                               NIGHT-VENT-RATIOS=(1,1,0,0)
* 271 *                               NIGHT-CYCLE-CTRL=CYCLE-ON-FIRST ..
* 272 *
* 273 * S-TERM    = SYSTEM-TERMINAL MIN-CFM-RATIO=0.3 ..
* 274 *
* 275 *           $ SYSTEMS DESCRIPTION
* 276 *
* 277 * DUAL-DUCT  = SYSTEM           SYSTEM-TYPE=DDS   SYSTEM-CONTROL=S-CTRL
* 278 *                               SYSTEM-FANS=S-FAN VENT-TEMP-SCH=VENT-SETPT
* 279 *                               SYSTEM-TERMINAL=S-TERM RETURN-AIR-PATH=DUCT
* 280 *                               ECONO-LIMIT-T=68 ZONE-NAMES=(RZ1,RZ2,RZ3,
* 281 *                               RZ4,RZ5,TZ1,TZ2,TZ3,TZ4,TZ5,A-STORAGE)
* 282 *                               SUPPLY-CFM=750000 ..
* 283 *
* 284 * PLANT1    = PLANT-ASSIGNMENT SYSTEM-NAMES = (DUAL-DUCT)
* 285 *                               INT-ELEC-KW = 100 $ FOR ELEVATORS
* 286 *                               INT-ELEC-SCH = 'CUP
* 287 *                               DHW-SIZE=0
* 288 *                               DHW-GAL/MIN = 2.22
* 289 *                               DHW-SCH = OCCUP ..
* 290 *
* 291 * OC1       =DAY-SCHEDULE      (1,8) (0.) (9,10) (1.)
* 292 *                               (11,13) (.8,.4,.8) (14,24) (1.,1.,1.,
* 293 *                               .3.,1.,1.,1.,0.,0.,0.,0.) ..
* 294 * OC2       =DAY-SCHEDULE      (1,24) (0.0) ..
* 295 * PEOPLE    =WEEK-SCHEDULE     (MON,FRI) OC1 (WEH) OC2 ..
* 296 * OCCUP     =SCHEDULE          THRU DEC 31 PEOPLE ..
* 297 *
* 298 *
* 299 * END ..
* 300 * COMPUTE SYSTEMS ..
* 301 *
* 302 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993PDL RUN 1

```

* 303 *
* 304 * PLANT1 = PLANT-ASSIGNMENT ..
* 305 *
* 306 *           $ PLANT DESCRIPTION
* 307 *
* 308 * $ SCREW TYPE CHILLERS ARE ALLOWED TO RUN ONLY IF OA TEMPERATURE IS ABOVE 60F.
* 309 * $ THE GAS BOILER IS ALLOWED TO RUN ONLY IF OA TEMPERATURE IS BELOW 60F.
* 310 * $ THESE LIMITS ARE PLACED IN SYSTEMS INPUT VIA COOLING AND HEATING SCHEDULES.
* 311 * $ ALL PIECES OF EQUIPMENT ARE ALLOWED TO SIZE AUTOMATICALLY.
* 312 * $ THE CHILLED WATER PUMPS ARE VARIABLE SPEED WHEREAS THE HEATING PUMPS
* 313 * $ ARE CONSTANT SPEED (FLOW). CURVE-FIT COMMANDS ARE USED TO REPLACE THE STANDARD
* 314 * $ HERMETIC CENTRIFUGAL CHILLER DEFAULT CURVES AND THUS SIMULATE A SCREW TYPE
* 315 * $ CHILLER WITH MULTIPLE COMPRESSORS.
* 316 *
* 317 *           PLANT-REPORT           SUMMARY=(PS-A, BEPS) ..
* 318 *
* 319 * SBOIL      =PLANT-EQUIPMENT   TYPE=HW-BOILER  SIZE=-999  INSTALLED-NUMBER=2 ..
* 320 * DHWH       =PLANT-EQUIPMENT   TYPE=DHW-HEATER SIZE -999  INSTALLED-NUMBER=2 ..
* 321 *
* 322 *           PLANT-PARAMETERS      HCIRC-PUMP-TYPE=FIXED-SPEED
* 323 *                                           CCIRC-PUMP-TYPE=VARIABLE-SPEED ..
* 324 *
* 325 * CMPC       =PLANT-EQUIPMENT   TYPE=HERM-CENT-CHLR SIZE=-999
* 326 *                                           INSTALLED-NUMBER=2 ..
* 327 *
* 328 *
* 329 * CTOWER    =PLANT-EQUIPMENT   TYPE=COOLING-TWR SIZE=-999 ..
* 330 *
* 331 * PART-LOAD-RATIO TYPE=HERM-CENT-CHLR
* 332 * MIN-RATIO=0.1 MAX-RATIO=1.05 OPERATING-RATIO=0.4 E-I-R=.23 ..
* 333 *
* 334 * DIAGNOSTIC COMMENTS ..
* 335 *
* 336 * BLR-HIR-FPLR CURVE-FIT TYPE LINEAR
* 337 * DATA (1..1.) (.1..109) ..

```

```

COEFFICIENT( 1) = 0.01000000
COEFFICIENT( 2) = 0.99000001
COEFFICIENT( 3) = 0.00000000
COEFFICIENT( 4) = 0.00000000
COEFFICIENT( 5) = 0.00000000
COEFFICIENT( 6) = 0.00000000

```

INDEPENDENT	INPUT DEPENDENT	CALL DEPENDENT	DIFFERENCE	PRINT DIFF
1.000	1.000			
0.100	0.109	0.109	0.000	0.000

ROOT MEAN SQUARE DIFFERENCE = 0.000

```

* 338 * SCREW-EIR-FPLR CURVE-FIT TYPE QUADRATIC
* 339 * DATA (1.0,1.0) (.8,.7) (.6,.45) (.4,.25) (.2,.13) ..

```

```

COEFFICIENT( 1) = 0.05225713
COEFFICIENT( 2) = 0.22597121

```

COEFFICIENT(3) = 0.72177273
 COEFFICIENT(4) = 0.00000000
 COEFFICIENT(5) = 0.00000000
 COEFFICIENT(6) = 0.00000000

INDEPENDENT	INPUT DEPENDENT	CALL DEPENDENT	DIFFERENCE	PRINT DIFF
1.000	1.000			
0.800	0.700	0.695	0.005	0.719
0.600	0.450	0.448	0.002	0.516
0.400	0.250	0.258	-0.008	3.252
0.200	0.130	0.126	0.004	2.829

ROOT MEAN SQUARE DIFFERENCE = 0.006
 * 340 * SCREW-CAP-FT CURVE-FIT TYPE BI-QUADRATIC
 * 341 * DATA (44,85,1.0) (40,75,.97) (40,85,.94) (40,95,.90) (44,75,1.03)
 * 342 * (44,95,.96) (50,75,1.13) (50,85,1.1) (50,95,1.06) ..

COEFFICIENT(1) = 0.57026076
 COEFFICIENT(2) = 0.00093736
 COEFFICIENT(3) = 0.00016746
 COEFFICIENT(4) = 0.00501750
 COEFFICIENT(5) = -0.00005008
 COEFFICIENT(6) = -0.00000011

INDEPENDENT	INDEPENDENT	INPUT DEPENDENT	CALC DEPENDENT	DIFFERENCE	PRCNT DIFF
44.000	85.000	1.000			
40.000	75.000	0.970	0.970	0.000	0.003
40.000	85.000	0.940	0.940	0.000	0.003
40.000	95.000	0.900	0.900	0.000	0.005
44.000	75.000	1.030	1.030	0.000	0.005
44.000	95.000	0.960	0.960	0.000	0.007
50.000	75.000	1.130	1.130	0.000	0.002
50.000	85.000	1.100	1.100	0.000	0.003
50.000	95.000	1.060	1.060	0.000	0.006

ROOT MEAN SQUARE DIFFERENCE = 0.000
 * 343 * SCREW-EIR-FT CURVE-FIT TYPE BI-QUADRATIC
 * 344 * DATA (44,85,1.0) (40,75,.88) (40,85,1.06) (40,95,1.26) (44,75,.84)
 * 345 * (44,95,1.18) (50,75,.79) (50,85,.93) (50,95,1.09) ..

COEFFICIENT(1) = 0.03537060
 COEFFICIENT(2) = -0.00968459
 COEFFICIENT(3) = 0.00033442
 COEFFICIENT(4) = 0.01752476
 COEFFICIENT(5) = 0.00010020
 COEFFICIENT(6) = -0.00039319

INDEPENDENT	INDEPENDENT	INPUT DEPENDENT	CALC DEPENDENT	DIFFERENCE	PRCNT DIFF
44.000	85.000	1.000			
40.000	75.000	0.880	0.882	-0.002	0.173
40.000	85.000	1.060	1.060	0.000	0.017
40.000	95.000	1.260	1.258	0.002	0.146
44.000	75.000	0.840	0.837	0.003	0.334
44.000	95.000	1.180	1.182	-0.002	0.202
50.000	75.000	0.790	0.791	-0.001	0.097
50.000	85.000	0.930	0.930	0.000	0.027
50.000	95.000	1.090	1.089	0.001	0.113

ROOT MEAN SQUARE DIFFERENCE = 0.002
* 346 *
* 347 * DIAGNOSTIC WARNINGS ..
* 348 *
* 349 * EQUIPMENT-QUAD
* 350 * HW-BOILER-HIR-FPLR BLR-HIR-FPLR
* 351 * HERM-CENT-EIR-FPLR SCREW-EIR-FPLR
* 352 * HERM-CENT-CAP-FT SCREW-CAP-FT
* 353 * HERM-CENT-EIR-FT SCREW-EIR-FT ..
* 354 *
* 355 * END ..
* 356 * COMPUTE PLANT ..
* 357 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993EDL RUN 1

```
* 358 * ECONOMICS-REPORT S (ES-D,ES-E,ES-F) ..
* 359 *
* 360 *           $ ENERGY COST DESCRIPTION
* 361 *
* 362 * $ THE INPUT FOR UTILITY RATES IS THE SIMPLEST POSSIBLE, USING UNIFORM RATES
* 363 * $ FOR BOTH GAS AND ELECTRICITY. THERE IS A FIXED MONTHLY CHARGE AND A RATE
* 364 * $ LIMITATION ON ELECTRICITY OF 7 CENTS/KWH. THE DEMAND CHARGE IS A NOMINAL
* 365 * $ FLAT RATE OF 5 DOLLARS/KW YEAR-AROUND.
* 366 *
* 367 * ELBC-RATE = UTILITY-RATE RESOURCE=ELECTRICITY
* 368 *           MONTH-CHGS = (2000)
* 369 *           ENERGY-CHG = .055
* 370 *           DEMAND-CHGS = (5)
* 371 *           RATE-LIMITATION = .07 ..
* 372 *
* 373 * GAS-RATE = UTILITY-RATE RESOURCE=NATURAL-GAS
* 374 *           ENERGY-CHG =.70 .. $ DOLLARS/THERM
* 375 * END ..
* 376 * COMPUTE ECONOMICS ..
* 377 *
* 378 * INPUT SYSTEMS ..
```

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
DUAL-DUCT	DDS	1.020	640000.0	4402.									
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	
	765000.	880.282	3.6	765000.	320.102	1.3	0.122	24975.178	0.745	38507.746	0.00	0.37	
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER		
R21	9964.	0.	0.000	0.300	1224.	0.00	0.00	204.47	0.00	-376.66	1.0		
R22	4917.	0.	0.000	0.300	571.	0.00	0.00	100.91	0.00	-185.88	1.0		
R23	1525.	0.	0.000	0.300	265.	0.00	0.00	31.29	0.00	-57.64	1.0		
R24	4878.	0.	0.000	0.300	571.	0.00	0.00	100.09	0.00	-184.38	1.0		
R25	2130.	0.	0.000	0.300	265.	0.00	0.00	43.72	0.00	-80.53	1.0		
T21	9964.	0.	0.000	0.300	1224.	0.00	0.00	204.47	0.00	-376.66	30.0		
T22	4942.	0.	0.000	0.300	571.	0.00	0.00	101.41	0.00	-186.81	30.0		
T23	1484.	0.	0.000	0.300	265.	0.00	0.00	30.46	0.00	-56.11	30.0		
T24	5276.	0.	0.000	0.300	571.	0.00	0.00	108.27	0.00	-199.45	30.0		
T25	2225.	0.	0.000	0.300	265.	0.00	0.00	45.66	0.00	-84.11	30.0		
A-STORAGE	24810.	0.	0.000	0.300	3400.	0.00	0.00	509.11	0.00	-937.83	1.0		

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-1360.075	4 8	2.F 2.F		-32294.734	487696.	2017.333
FEB	0.00000				0.000	-902.488	8 8	7.F 6.F		-27977.312	447234.	2015.254
MAR	96.10119	3 15	76.F	65.F	9312.090	-293.062	24 8	6.F 5.F		-11400.101	522411.	2022.900
APR	676.91876	28 15	78.F	68.F	13260.128	-50.972	8 8	31.F 28.F		-4102.924	504773.	2091.482
MAY	558.87231	21 14	85.F	75.F	14771.589	-38.075	6 23	39.F 32.F		-5109.092	592791.	2071.204
JUN	1592.44739	21 16	82.F	72.F	15581.333	-4.944	1 8	50.F 49.F		-749.133	701938.	2119.384
JUL	2780.08643	19 16	90.F	75.F	19637.363	0.000				0.000	748423.	2302.989
AUG	2318.93164	16 16	86.F	73.F	16268.928	-0.261	4 8	58.F 56.F		-82.480	778051.	2141.416
SEP	830.72363	10 16	82.F	70.F	13722.426	-36.284	23 3	36.F 34.F		-2885.901	635695.	2084.419
OCT	305.18964	5 16	74.F	62.F	8111.271	-92.795	18 8	43.F 41.F		-6469.029	527490.	2105.047
NOV	135.12518	2 16	77.F	62.F	7739.572	-368.909	15 8	27.F 26.F		-19181.605	469326.	2028.545
DEC	0.00000				0.000	-854.511	27 8	31.F 30.F		-24501.088	497948.	2013.748
TOTAL	9294.387					-4002.373					6913781.	
MAX					19637.363					-32294.734		2302.989

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 0.000 (KBTU)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 201088.800 (KBTU)

----- C O O L I N G -----						----- H E A T I N G -----					----- E L E C -----	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-1360.075	4 8	2.F	2.F	-32294.734	472496.	1977.333
FEB	0.00000				0.000	-902.488	8 8	7.F	6.F	-27977.312	432794.	1975.254
MAR	96.10119	3 15	76.F	65.F	9312.090	-293.062	24 8	6.F	5.F	-11400.101	504931.	1982.900
APR	676.91876	28 15	78.F	68.F	13260.128	-50.972	8 8	31.F	28.F	-4102.924	488053.	2051.482
MAY	558.87231	21 14	85.F	75.F	14771.589	-38.075	6 23	39.F	32.F	-5109.092	577591.	2031.203
JUN	1592.44739	21 16	82.F	72.F	15581.333	-4.944	1 8	50.F	49.F	-749.133	685218.	2079.384
JUL	2780.08643	19 16	90.F	75.F	19637.363	0.000				0.000	732462.	2262.989
AUG	2318.93164	16 16	86.F	73.F	16268.928	-0.261	4 8	58.F	56.F	-82.480	761331.	2101.416
SEP	830.72363	10 16	82.F	70.F	13722.426	-36.284	23 8	36.F	34.F	-2885.901	619735.	2044.419
OCT	305.18964	5 16	74.F	62.F	8111.271	-92.795	18 8	43.F	41.F	-6469.029	512290.	2065.047
NOV	135.12518	2 16	77.F	62.F	7739.572	-368.909	15 8	27.F	26.F	-19181.605	454126.	1988.545
DEC	0.00000				0.000	-854.511	27 8	31.F	30.F	-24501.088	481988.	1973.748
TOTAL	9294.387					-4002.373					6723011.	
MAX					19637.363					-32294.734		2262.989

----- N U M B E R O F H O U R S ----- --COINCIDENT LOADS--

MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	0	277	0	467	744	0	277	57	0	0	0.000	48.000
FEB	0	235	0	437	672	1	235	26	0	0	0.000	48.000
MAR	21	236	5	492	711	47	253	0	0	1	0.000	1835.089
APR	112	154	24	478	504	290	242	0	0	0	0.000	1913.863
MAY	247	138	45	404	452	394	370	0	150	30	0.000	1857.121
JUN	423	37	22	282	147	653	463	0	221	25	0.000	1985.587
JUL	471	0	0	273	2	744	510	0	279	39	0.000	2131.033
AUG	481	8	3	258	30	742	542	0	300	56	0.000	1998.371
SEP	295	100	34	359	314	506	406	0	175	45	0.000	1938.555
OCT	136	160	20	468	494	326	297	0	77	21	0.000	1853.431
NOV	38	212	13	483	676	68	237	10	7	0	0.000	1846.406
DEC	0	267	0	477	744	0	267	36	0	0	0.000	48.000
ANNUAL	2224	1824	166	4878	5490	3771	4099	129	1209	217		

HOUR	COOLING				HEATING			DAY COOLING PEAK			
	JUL 19				JAN 4			JUL 19			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY-BULB TEMP	WET-BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP
1	0.000	0.000	79.F	72.F	0.000	6.F	6.F	0.000	0.000	79.F	72.F
2	0.000	0.000	79.F	72.F	-9638.244	5.F	5.F	0.000	0.000	79.F	72.F
3	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
4	0.000	0.000	78.F	72.F	-9782.389	4.F	4.F	0.000	0.000	78.F	72.F
5	0.025	0.712	77.F	72.F	0.000	3.F	3.F	0.025	0.712	77.F	72.F
6	0.000	0.000	78.F	72.F	-10077.901	3.F	3.F	0.000	0.000	78.F	72.F
7	18286.602	0.884	77.F	72.F	0.000	2.F	2.F	18286.602	0.884	77.F	72.F
8	18453.250	0.829	79.F	72.F	-32294.734	2.F	2.F	18453.250	0.829	79.F	72.F
9	17884.889	0.845	82.F	72.F	-18999.021	4.F	3.F	17884.889	0.845	82.F	72.F
10	18224.994	0.851	85.F	73.F	-15659.052	7.F	6.F	18224.994	0.851	85.F	73.F
11	18715.545	0.864	88.F	74.F	-13227.115	11.F	9.F	18715.545	0.864	88.F	74.F
12	18165.553	0.855	89.F	74.F	-11438.996	16.F	13.F	18165.553	0.855	89.F	74.F
13	18929.281	0.837	90.F	75.F	-9487.539	18.F	15.F	18929.281	0.837	90.F	75.F
14	19152.379	0.833	89.F	75.F	-7530.267	20.F	16.F	19152.379	0.833	89.F	75.F
15	19637.363	0.840	90.F	75.F	-6679.233	20.F	16.F	19637.363	0.840	90.F	75.F
16	17473.195	0.841	91.F	76.F	-5753.929	20.F	16.F	17473.195	0.841	91.F	76.F
17	16165.688	0.849	90.F	75.F	-6808.142	19.F	15.F	16165.688	0.849	90.F	75.F
18	0.000	0.000	86.F	74.F	-7249.688	16.F	13.F	0.000	0.000	86.F	74.F
19	0.000	0.000	86.F	74.F	0.000	13.F	11.F	0.000	0.000	86.F	74.F
20	0.000	0.000	80.F	72.F	0.000	11.F	9.F	0.000	0.000	80.F	72.F
21	0.000	0.000	79.F	72.F	0.000	10.F	8.F	0.000	0.000	79.F	72.F
22	0.025	0.712	77.F	71.F	0.000	11.F	9.F	0.025	0.712	77.F	71.F
23	0.000	0.000	76.F	71.F	0.000	7.F	6.F	0.000	0.000	76.F	71.F
24	0.012	0.446	74.F	70.F	0.000	6.F	5.F	0.012	0.446	74.F	70.F
SUM								201088.812			
MAX	19637.363				-32294.734						

SYSTEM-TYPE DDS SQFT/TON 391.1
 COOLING PEAK 30.68 (BTU/HR- SQFT) HEATING PEAK -50.46 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.20 (CFM/SQFT) MIN-OA/PERSON 21.17 (CFM)
 OA FRAC AT CLG PEAK 0.158 OA FRAC AT HTG PEAK 0.251

* ASTERISKS INDICATE HOURS LOADS NOT MET

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	16.255	2 2										
DHW-HEATER	0.057	2 2										
HEM-CENT-CHLR	10.015	2 2										
COOLING-TWR	12.444	2 2										

MONTH	S I T E E N E R G Y												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	1436.6	0.0	519.5	0.0	0.0	0.0	0.0	1825.1	31.8	0.0	1825.1	3598.0	7144.3
FEB	969.6	0.0	473.2	0.0	0.0	0.0	0.0	1238.5	25.9	0.0	1238.5	2853.4	6083.8
MAR	363.5	99.1	544.2	0.0	0.0	0.0	6.1	469.3	15.8	0.0	469.3	2326.8	6042.3
APR	101.9	694.9	553.1	0.0	0.0	0.0	40.8	135.0	7.6	0.0	135.0	2022.8	5798.8
MAY	82.8	589.0	645.2	0.0	0.0	0.0	45.9	110.2	6.5	0.0	110.2	2312.3	6717.3
JUN	28.1	1651.0	816.1	0.0	0.0	0.0	112.6	39.8	1.6	0.0	39.8	2825.3	8397.1
JUL	13.5	2861.1	945.6	0.0	0.0	0.0	197.2	20.9	0.0	0.0	20.9	3248.2	9703.7
AUG	15.7	2392.6	940.2	0.0	0.0	0.0	161.8	23.8	0.3	0.0	23.8	3232.6	9651.0
SEP	71.3	868.3	704.0	0.0	0.0	0.0	63.3	95.2	5.0	0.0	95.2	2497.9	7304.0
OCT	140.9	321.6	560.8	0.0	0.0	0.0	24.5	184.8	8.8	0.0	184.8	2098.8	5927.5
NOV	429.4	140.2	494.2	0.0	0.0	0.0	9.2	551.7	15.7	0.0	551.7	2238.5	5612.7
DEC	928.8	0.0	525.3	0.0	0.0	0.0	0.0	1188.9	27.3	0.0	1188.9	2981.7	6567.8
TOTAL	4582.0	9617.9	7721.4	0.0	0.0	0.0	661.3	5883.2	146.4	0.0	5883.3	32236.3	84950.3

MONTH	S I T E E N E R G Y												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	1436.6	0.0	519.5	0.0	0.0	0.0	0.0	1825.1	31.8	0.0	1825.1	3598.0	7144.3
FEB	969.6	0.0	473.2	0.0	0.0	0.0	0.0	1238.5	25.9	0.0	1238.5	2853.4	6083.8
MAR	363.5	99.1	544.2	0.0	0.0	0.0	6.1	469.3	15.8	0.0	469.3	2326.8	6042.3
APR	101.9	694.9	553.1	0.0	0.0	0.0	40.8	135.0	7.6	0.0	135.0	2022.8	5798.8
MAY	82.8	589.0	645.2	0.0	0.0	0.0	45.9	110.2	6.5	0.0	110.2	2312.3	6717.3
JUN	28.1	1651.0	816.1	0.0	0.0	0.0	112.6	39.8	1.6	0.0	39.8	2825.3	8397.1
JUL	13.5	2861.1	945.6	0.0	0.0	0.0	197.2	20.9	0.0	0.0	20.9	3248.2	9703.7
AUG	15.7	2392.6	940.2	0.0	0.0	0.0	161.8	23.8	0.3	0.0	23.8	3232.6	9651.0
SEP	71.3	868.3	704.0	0.0	0.0	0.0	63.3	95.2	5.0	0.0	95.2	2497.9	7304.0
OCT	140.9	321.6	560.8	0.0	0.0	0.0	24.5	184.8	8.8	0.0	184.8	2098.8	5927.5
NOV	429.4	140.2	494.2	0.0	0.0	0.0	9.2	551.7	15.7	0.0	551.7	2238.5	5612.7
DEC	928.8	0.0	525.3	0.0	0.0	0.0	0.0	1188.9	27.3	0.0	1188.9	2981.7	6567.8
TOTAL	4582.0	9617.9	7721.4	0.0	0.0	0.0	661.3	5883.2	146.4	0.0	5883.3	32236.3	84950.3

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	4394.8	95.9
DHW-HEATER	187.2	4.1
LOAD SATISFIED	4582.0	100.0
TOTAL LOAD ON PLANT	4582.1	

COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HERM-CENT-CHLR	9617.8	100.0
LOAD SATISFIED	9617.8	100.0
TOTAL LOAD ON PLANT	9617.8	

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	7721433.0	100.0
LOAD SATISFIED	7721433.0	100.0
TOTAL LOAD ON PLANT	7721451.0	

TOWER ABOVE DESIGN TEMPERATURE OF 85.F 0 HOURS

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	4582.1	4582.0	0.000	0.000	0
COOLING LOADS	9617.8	9617.8	0.000	0.000	0
ELECTRICAL LOADS	26353.1	26353.0	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE -----		
AREA LIGHTS	10810.3	0.0
MISC EQUIPMT	3997.2	0.0
SPACE HEAT	281.1	5598.3
SPACE COOL	1461.7	0.0
HEAT REJECT	539.1	0.0
PUMPS & MISC	474.6	0.0
VENT FANS	8789.0	0.0
DOMHOT WATER	0.0	284.9
	-----	-----
TOTAL	26353.0	5883.2

TOTAL SITE ENERGY 32236.27 MBTU 50.4 KBTU/SQFT-YR GROSS-AREA 50.4 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 84950.23 MBTU 132.7 KBTU/SQFT-YR GROSS-AREA 132.7 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.0
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

REPORT- ES-D ENERGY COST SUMMARY

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-RATE	ELECTRICITY	1 2 3 4 5	7721433. KWH	564500.	0.0731	YES
GAS-RATE	NATURAL-GAS	1 2 3 4 5	58833. THERM	41183.	0.7000	YES

 605683.

ENERGY COST/GROSS BLDG AREA: 0.95
 ENERGY COST/NET BLDG AREA: 0.95

31-STORY OFFICE BLDG, CHICAGO - LOAD1 STD ASHRAE WEIGHTING FACTORS DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 1
 RUN 1 DUAL-DUCT VARIABLE VOLUME SYSTEM
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-RATE

UTILITY-RATE: ELEC-RATE RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0700
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	519453	519453	2157.2	2157.2	28570	10786	0	0	0	2000	0	0.0739	38362
FEB	473171	473171	2154.7	2154.7	26024	10774	0	0	0	2000	0	0.0742	35122
MAR	544248	544248	2492.4	2492.4	29934	12462	0	0	0	2000	0	0.0737	40097
APR	553110	553110	2828.4	2828.4	30421	14142	0	0	0	2000	0	0.0736	40718
MAY	645226	645226	2944.6	2944.6	35487	14723	0	0	0	2000	0	0.0731	47166
JUN	816149	816149	3119.7	3119.7	44888	15599	0	0	0	2000	0	0.0725	59130
JUL	945592	945592	3700.9	3700.9	52008	18504	0	0	0	2000	0	0.0721	68191
AUG	940158	940158	3204.0	3204.0	51709	16020	0	0	0	2000	0	0.0721	67811
SEP	703986	703986	2901.8	2901.8	38719	14509	0	0	0	2000	0	0.0728	51279
OCT	560817	560817	2418.5	2418.5	30845	12093	0	0	0	2000	0	0.0736	41257
NOV	494236	494236	2404.2	2404.2	27183	12021	0	0	0	2000	0	0.0740	36596
DEC	525288	525288	2153.6	2153.6	28891	10768	0	0	0	2000	0	0.0738	38770
TOTAL	7721433	7721433	3700.9		424679	162400	0	0	0	24000		0.0731	564500

31-STORY OFFICE BLDG, CHICAGO - LOAD1 STD ASHRAE WEIGHTING FACTORS DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 1
 REPORT- ES-E SUMMARY OF UTILITY-RATE: RUN 1 DUAL-DUCT VARIABLE VOLUME SYSTEM GAS-RATE

UTILITY-RATE: GAS-RATE RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS
 MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	18251	18251	406.4	406.4	12776	0	0	0	0	0	0	0.7000	12776
FEB	12385	12385	353.0	353.0	8670	0	0	0	0	0	0	0.7000	8670
MAR	4693	4693	145.8	145.8	3285	0	0	0	0	0	0	0.7000	3285
APR	1350	1350	55.5	55.5	945	0	0	0	0	0	0	0.7000	945
MAY	1102	1102	68.0	68.0	771	0	0	0	0	0	0	0.7000	771
JUN	398	398	12.4	12.4	279	0	0	0	0	0	0	0.7000	279
JUL	209	209	1.2	1.2	146	0	0	0	0	0	0	0.7000	146
AUG	238	238	4.4	4.4	167	0	0	0	0	0	0	0.7000	167
SEP	952	952	40.0	40.0	667	0	0	0	0	0	0	0.7000	667
OCT	1848	1848	84.8	84.8	1294	0	0	0	0	0	0	0.7000	1294
NOV	5517	5517	244.1	244.1	3862	0	0	0	0	0	0	0.7000	3862
DEC	11889	11889	310.0	310.0	8322	0	0	0	0	0	0	0.7000	8322
TOTAL	58833	58833	406.4		41183	0	0	0	0	0		0.7000	41183

31-Story Office Building, LOAD1 — Run 2 Systems, Plant, Economics

SDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993SDL RUN 2

```

* 379 *
* 380 *      TITLE      LINE-2 *RUN 2 VARIABLE AIR VOLUME SYSTEM *
* 381 *                LINE-4 *ELECTRIC THERMOSTATIC BASEBOARDS *
* 382 *                LINE-5 *WARM-UP CYCLE USES GAS HEAT* ..
* 383 *
* 384 *                $ HVAC SYSTEM DESCRIPTION
* 385 *
* 386 * $ DESIGN TEMPS COOLING 78F HEATING 70F.
* 387 * $ SYSTEM TYPE  A SINGLE VARIABLE AIR VOLUME SYSTEM SERVES THE ENTIRE BUILDING.
* 388 * $                THE SYSTEM HAS A DRY BULB CONTROLLED ECONOMIZER WITH A LIMIT
* 389 * $                TEMP OF 68F. THE FAN HAS INLET VANES.
* 390 * $                THE VAV BOXES HAVE A MINIMUM STOP OF 25%.
* 391 * $                ELECTRIC BASEBOARDS IN ALL PERIMETER SPACES ARE
* 392 * $                SUFFICIENTLY LARGE TO HEAT THE SPACE BUT NOT PICK UP THE HEATING
* 393 * $                LOAD ON A COLD WINTER MORNING; THEREFORE, A GAS WARM-UP CYCLE IS
* 394 * $                IS PROVIDED WHICH MINIMIZES THE USE OF THE ELECTRIC BASEBOARDS
* 395 * $                AND REDUCES THE ELECTRIC DEMAND CHARGES. IT IS VERY DIFFICULT
* 396 * $                TO SIMULATE THE DYNAMICS OF THIS CONTROL STRATEGY CORRECTLY AS
* 397 * $                ON SOME MORNINGS SPACES ARE UNDERHEATED, AND ON OTHERS THEY ARE
* 398 * $                OVERHEATED. THE OPERATOR OF THE BUILDING WOULD IN FACT NEED TO
* 399 * $                TUNE THE SUPPLY AIR TEMPERATURE SETPOINT TO ELIMINATE THE
* 400 * $                PROBLEM.
* 401 *
* 402 * $                THE SUPPLY AIR TEMPERATURE IS SET AT 100F FOR ONE HOUR ON WINTER
* 403 * $                MORNINGS AND THE CONTROL OF THE VAV BOXES OPENS THE BOXES
* 404 * $                FULL FOR THOSE HOURS. THE SUPPLY AIR TEMPERATURE IS 60F AT ALL
* 405 * $                OTHER TIMES. MINIMUM VENTILATION AIR IS 20 CFM/PERSON AND THE
* 406 * $                FAN OPERATES FROM 7AM TO 6PM WEEKDAYS AND IS OFF ON WEEKENDS AND
* 407 * $                HOLIDAYS. THERE IS A NIGHT LOW LIMIT SETTING FOR PERIMETER
* 408 * $                THERMOSTATS TO HOLD SPACE AT 55F. THE FANS DO NOT RUN AT NIGHT
* 409 * $                BUT CAN CYCLE ON AS EARLY 12 PM TO HOLD SETBACK. THE MINIMUM OA
* 410 * $                DAMPERS ARE HELD CLOSED DURING MORNING STARTUP YEAR ROUND,
* 411 * $                HOWEVER THE ECONOMIZER DAMPERS ARE ACTIVATED IF NEEDED.
* 412 *
* 413 *      ABORT          ERRORS ..
* 414 *      DIAGNOSTIC     WARNINGS ..
* 415 *      SYSTEMS-REPORT SUMMARY=(SS-A,SS-D,SS-J) ..
* 416 *
* 417 *      $ SCHEDULES
* 418 *
* 419 * HRS1      = DAY-SCHEDULE (1,7) (0) (8,18) (1) (19,24) (0) ..
* 420 * HRS2      = DAY-SCHEDULE (1,24) (0) ..
* 421 * DAYS1     = WEEK-SCHEDULE (MON,FRI) HRS1 (WEH) HRS2 ..
* 422 * AHU-SCHED = SCHEDULE THRU DEC 31 DAYS1 .. $ FANS $
* 423 *
* 424 * HRSH1     = DAY-SCHEDULE (1,8) (55) (9,18) (70) (19,24) (55) ..
* 425 * HRSH2     = DAY-SCHEDULE (1,24) (55) ..
* 426 * DAYHEAT   = WEEK-SCHEDULE (MON,FRI) HRSH1 (WEH) HRSH2 ..
* 427 * THEAT     = SCHEDULE THRU DEC 31 DAYHEAT .. $ HEATING $
* 428 *
* 429 * HRSC1     = DAY-SCHEDULE (1,7) (99) (8,18) (78) (19,24) (99) ..
* 430 * HRSC2     = DAY-SCHEDULE (1,24) (99) ..
* 431 * DAYCOOL   = WEEK-SCHEDULE (MON,FRI) HRSC1 (WEH) HRSC2 ..
* 432 * TCOOL     = SCHEDULE THRU DEC 31 DAYCOOL .. $ COOLING $
* 433 *

```

```

* 434 * COOLON          = SCHEDULE THRU DEC 31 (ALL) (1,24) (55) ..
* 435 * HEATON          = SCHEDULE THRU DEC 31 (ALL) (1,24) (60) ..
* 436 *
* 437 * REV-STAT-ACT    = SCHEDULE THRU MAR 15 (ALL) (1,8) (1) (9,24) (-999)
* 438 *                  THRU DEC 15 (ALL) (1,24) (-999)
* 439 *                  THRU DEC 31 (ALL) (1,8) (1) (9,24) (-999) ..
* 440 *
* 441 * SA1 = DAY-SCHEDULE (1,8) (110) (9,18) (60) (19,24) (110) ..
* 442 * SA2 = DAY-SCHEDULE (1,8) (90) (9,18) (60) (19,24) (90) ..
* 443 * SAT-SETPT = SCHEDULE THRU MAR 15 (MON) SA1 (TUE,FRI) SA2 (WEH) (1,24) (110)
* 444 *                  THRU MAY 15 (WD) SA2 (WEH) (1,24) (90)
* 445 *                  THRU SEP 15 (ALL) (1,24) (55)
* 446 *                  THRU OCT 15 (WD) SA2 (WEH) (1,24) (90)
* 447 *                  THRU DEC 31 (MON) SA1 (TUE,FRI) SA2 (WEH) (1,24) (110) ..
* 448 *
* 449 * OA-DAMPER-POS = SCHEDULE THRU DEC 31 (ALL) (1,8) (.01) (9,18) (-999) (19,24) (.01) ..
* 450 *
* 451 *           $ ZONE SUB-COMMANDS
* 452 *
* 453 * ZAIR           = ZONE-AIR      OA-CFM/PER=20 ..
* 454 *
* 455 * CONTROL        = ZONE-CONTROL  DESIGN-HEAT-T=70  DESIGN-COOL-T=74
* 456 *                  HEAT-TEMP-SCH=THEAT  COOL-TEMP-SCH=TCOOL
* 457 *                  BASEBOARD-CTRL=THERMOSTATIC
* 458 *                  THERMOSTAT-TYPE=REVERSE-ACTION ..
* 459 *
* 460 *           $ ZONE DESCRIPTION
* 461 *
* 462 * RZ1           = ZONE          ZONE-AIR=ZAIR  ZONE-CONTROL=CONTROL
* 463 *                  MIN-CFM-SCH=REV-STAT-ACT  CFM/SQFT=1
* 464 *                  BASEBOARD-RATING=-55000 ..
* 465 * RZ2           = ZONE LIKE RZ1  BASEBOARD-RATING=-140000 ..
* 466 * RZ3           = ZONE LIKE RZ2  B-R=-69000 ..
* 467 * RZ4           = ZONE LIKE RZ2  ..
* 468 * RZ5           = ZONE LIKE RZ3  ..
* 469 * TZ1           = ZONE LIKE RZ1  ..
* 470 * TZ2           = ZONE LIKE RZ2  B-R=-120000 ..
* 471 * TZ3           = ZONE LIKE TZ2  B-R=-60000 ..
* 472 * TZ4           = ZONE LIKE TZ2  ..
* 473 * TZ5           = ZONE LIKE TZ3  ..
* 474 * A-STORAGE= ZONE LIKE RZ1      AIR-CHANGES/HR=4  OA-CHANGES=0.5 ..
* 475 *
* 476 *           $ SYSTEM SUB-COMMANDS
* 477 *
* 478 * S-CTRL        = SYSTEM-CONTROL  COOLING-SCHEDULE=COOLON
* 479 *                  HEATING-SCHEDULE=HEATON  COOL-CONTROL = SCHEDULED
* 480 *                  HEAT-SET-T=100  COOL-SET-SCH=SAT-SETPT
* 481 *                  MIN-SUPPLY-T=55  MAX-SUPPLY-T=100
* 482 *                  MIN-HUMIDITY=25 ..
* 483 *
* 484 * S-FAN         = SYSTEM-FANS     FAN-SCHEDULE=AHU-SCHED  FAN-CONTROL=INLET
* 485 *                  SUPPLY-STATIC=5.5  SUPPLY-EFF=0.55
* 486 *                  RETURN-STATIC=2.0  RETURN-EFF=0.53 ..
* 487 *
* 488 * S-TERM        = SYSTEM-TERMINAL  REHEAT-DELTA-T=20  MIN-CFM-RATIO=0.25 ..
* 489 *
* 490 *           $ SYSTEM DESCRIPTION
* 491 *
* 492 * BLDG          = SYSTEM          SYSTEM-TYPE=VAVS  SYSTEM-CONTROL=S-CTRL
* 493 *                  SYSTEM-FANS=S-FAN  MIN-AIR-SCH=OA-DAMPER-POS
* 494 *                  SYSTEM-TERMINAL=S-TERM  RETURN-AIR-PATH=DUCT
* 495 *                  BASEBOARD-SOURCE=ELECTRIC  PREHEAT=HOT-WATER
* 496 *                  HEAT-SOURCE=HOT-WATER  HUMIDIFIER-TYPE=HOT-WATER

```

```

* 497 *          ECONO-LIMIT-T=68  ZONE-NAMES=(RZ1,RZ2,RZ3,RZ4,
* 498 *          RZ5,TZ1,TZ2,TZ3,TZ4,TZ5) ..
* 499 *
* 500 * BASMT-SYS = SYSTEM          SYSTEM-TYPE=S2RH  MAX-SUPPLY-T=105
* 501 *          MIN-SUPPLY-T=55  SUPPLY-STATIC=2.5
* 502 *          SUPPLY-EFF=.5    FAN-SCHEDULE=AHU-SCHED
* 503 *          HEATING-SCHEDULE=HEATON  HEAT-SOURCE=ELECTRIC
* 504 *          COOLING-SCHEDULE=COOLON
* 505 *          ZONE-NAMES=(A-STORAGE) ..
* 506 *
* 507 * PLANT1 = PLANT-ASSIGNMENT  SYSTEM-NAMES = (BLDG,BASMT-SYS)
* 508 *          INT-ELEC-KW = 100 $ FOR ELEVATORS
* 509 *          INT-ELEC-SCH = OCCUP
* 510 *          DHW-SIZE=0
* 511 *          DHW-GAL/MIN = 2.22
* 512 *          DHW-SCH      = OCCUP ..
* 513 *
* 514 * OC1          =DAY-SCHEDULE   (1,8) (0.)      (9,10) (1.)
* 515 *          (11,13) (.8,.4,.8) (14,24) (1..1..1..
* 516 *          .3,.1,.1,.1,0..0..0..0..) ..
* 517 * OC2          =DAY-SCHEDULE   (1,24) (0.0) ..
* 518 * PEOPLE      =WEEK-SCHEDULE  (MON,FRI) OC1      (WEH) OC2 ..
* 519 * OCCUP       =SCHEDULE       THRU DEC 31  PEOPLE ..
* 520 * END ..
* 521 * COMPUTE SYSTEMS ..
* 522 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993PDL RUN 2

```

* 523 * PLANT1 = PLANT-ASSIGNMENT ..
* 524 *
* 525 *          PLANT-REPORT          SUMMARY=(PS-A,BEPS) ..
* 526 *
* 527 *          $ EQUIPMENT DESCRIPTION
* 528 *
* 529 * $ THE PLANT USES CHILLED WATER STORAGE. THE CHILLER CHARGES
* 530 * $ THE TANKS AT NIGHT. STORED CHILLED WATER IS RELEASED FROM 12NOON TO 5PM,
* 531 * $ WHICH IS THE ON-PEAK PERIOD OF THE TIME-OF-DAY RATE SCHEDULE.
* 532 * $ THE CHILLER PROVIDES OFF-PEAK COOLING AND SUPPLEMENTS THE TANK
* 533 * $ DURING THE ON-PEAK PERIOD IF NECESSARY.
* 534 * $ DAYTIME HEATING IS DONE WITH ELECTRIC BASEBOARDS,
* 535 * $ BUT FOR NIGHTTIME HEATING AND FOR EARLY MORNING
* 536 * $ START-UP A GAS HOT WATER GENERATOR IS USED.
* 537 *
* 538 * CMPC      =PLANT-EQUIPMENT      TYPE=HERM-CENT-CHLR  SIZE=13.5  I-N=2  ..
* 539 *
* 540 * DHWH      =PLANT-EQUIPMENT      TYPE=ELEC-DHW-HEATER  SIZE=-999  ..
* 541 *
* 542 * HWG       =PLANT-EQUIPMENT      TYPE=HW-BOILER       SIZE=-999  ..
* 543 *
* 544 * CTWR      =PLANT-EQUIPMENT      TYPE=COOLING-TWR     SIZE=-999  ..
* 545 *
* 546 * CTANK     =PLANT-EQUIPMENT      TYPE=CTANK-STORAGE   SIZE=50    I-N=1  ..
* 547 *
* 548 *
* 549 * ENERGY-STORAGE  COOL-STORE-RATE=13.5  COOL-SUPPLY-RATE=13.5
* 550 *                  COOL-STORE-SCH=TANK-CHG  CTANK-LOSS-COEF=50
* 551 *                  CTANK-BASE-T=54  CTANK-T-RANGE=10  CTANK-ENV-T=53  ..
* 552 *
* 553 * TANK-CHG=SCHEDULE THRU MAY 1 (ALL) (1,24) (0)
* 554 *                  THRU OCT 1 (ALL) (1,7) (1) (8,24) (0)
* 555 *                  THRU DEC 31 (ALL) (1,24) (0)  ..
* 556 *
* 557 * TANK-CHARGE =LOAD-ASSIGNMENT  TYPE=COOLING  LOAD-RANGE=13.5
* 558 *                  PLANT-EQUIPMENT=CMPC  N=1  ..
* 559 *
* 560 * RELEASE-CHG =LOAD-ASSIGNMENT  TYPE=COOLING  LOAD-RANGE=27
* 561 *                  PLANT-EQUIPMENT=CTANK  N=1
* 562 *                  PLANT-EQUIPMENT=CMPC  N=1  ..
* 563 *
* 564 * OFF-PEAK-CLG=LOAD-ASSIGNMENT  TYPE=COOLING  LOAD-RANGE=27
* 565 *                  PLANT-EQUIPMENT =CMPC  N=2  ..
* 566 *
* 567 * CHW-CTRL =DAY-ASSIGN-SCH (1,7) (TANK-CHARGE) (8,12) (OFF-PEAK-CLG)
* 568 *                  (13,17) (RELEASE-CHG) (18,24) (OFF-PEAK-CLG)  ..
* 569 * WEH-CTRL =DAY-ASSIGN-SCH (1,24) (OFF-PEAK-CLG)  ..
* 570 *
* 571 * CHILLER-CTRL=SCHEDULE THRU DEC 31 (WD) CHW-CTRL (WEH) WEH-CTRL  ..
* 572 *
* 573 * LOAD-MANAGEMENT  PRED-LOAD-RANGE=999
* 574 *                  ASSIGN-SCHEDULE=(DEFAULT,CHILLER-CTRL,DEFAULT)  ..
* 575 *
* 576 * END  ..
* 577 * COMPUTE PLANT  ..

```

* 578 *
* 579 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993EDL RUN 2

```

* 580 *
* 581 *           $ ENERGY COST DESCRIPTION
* 582 *
* 583 * $ ELECTRICITY IS CHARGED ACCORDING TO A TIME-OF-DAY SCHEDULE THAT CHANGES FROM
* 584 * $ SUMMER TO WINTER SEASONS. THE DEMAND CHARGE ALSO CHANGES, FROM 5 DOLLARS/KW
* 585 * $ IN WINTER TO 6 DOLLARS/KW IN SUMMER.
* 586 * $ THERE IS NO RATCHET OR OTHER SPECIAL FEATURES.
* 587 * $ HOWEVER, NOTE THAT IT IS ASSUMED THAT THE PEAK DEAMAND
* 588 * $ OCCURS DURING THE ON-PEAK PERIOD SINCE THERE IS NO DEMAND CHARGE FOR
* 589 * $ THE OFF-PEAK OR SHOULDER PERIODS.
* 590 *
* 591 * ECONOMICS-REPORT S=(ES-D,ES-E,ES-F) ..
* 592 *
* 593 * GAS-RATE = UTILITY-RATE   RESOURCE=NATURAL-GAS
* 594 *                               ENERGY-CHG = .60 ..
* 595 *
* 596 * ELEC-RATE = UTILITY-RATE   RESOURCE = ELECTRICITY
* 597 *                               BLOCK-CHARGES = (WINTER-OFF-P,WINTER-SHOUL,
* 598 *                               WINTER-ON-P,SUMMER-OFF-P,
* 599 *                               SUMMER-SHOUL,SUMMER-ON-P
* 600 *                               WINTER-DEMAND,SUMMER-DEMAND) ..
* 601 *
* 602 *           $ THE FLAGS USED IN THE BLOCK-CHARGES AND SCHEDULE BELOW
* 603 *
* 604 *           $           WINTER   SUMMER
* 605 *           $           OFF-PEAK  1.1   2.1
* 606 *           $           SHOULDER  1.2   2.2
* 607 *           $           ON-PEAK   1.3   2.3
* 608 *
* 609 * WINTER-OFF-P = BLOCK-CHARGE  BLOCK-SCH = SEASONS-SCH
* 610 *                               SCH-FLAG = 1.1
* 611 *                               BLOCK1-TYPE = KWH/KW
* 612 *                               BLOCK1-DATA = (200,.04,0
* 613 *                               800,.05,0) ..
* 614 * WINTER-SHOUL = BLOCK-CHARGE  BLOCK-SCH =SEASONS-SCH
* 615 *                               SCH-FLAG = 1.2
* 616 *                               BLOCK1-TYPE = KWH/KW
* 617 *                               BLOCK1-DATA = (200,.045,0
* 618 *                               800,.055,0) ..
* 619 * WINTER-ON-P = BLOCK-CHARGE  BLOCK-SCH = SEASONS-SCH
* 620 *                               SCH-FLAG = 1.3
* 621 *                               BLOCK1-TYPE = KWH/KW
* 622 *                               BLOCK1-DATA = (200,.05,0
* 623 *                               800,.06,0) ..
* 624 *
* 625 * WINTER-DEMAND = BLOCK-CHARGE  BLOCK-SCH = SEASONS-SCH
* 626 *                               SCH-FLAG = 1.3
* 627 *                               TOU-SEASON-LINKS = (SUMMER-DEMAND)
* 628 *                               BLOCK1-TYPE = DEMAND
* 629 *                               BLOCK1-DATA = ( 1,5.00) ..
* 630 *
* 631 * SUMMER-OFF-P = BLOCK-CHARGE  BLOCK-SCH = SEASONS-SCH
* 632 *                               SCH-FLAG = 2.1
* 633 *                               BLOCK1-TYPE = KWH/KW
* 634 *                               BLOCK1-DATA = (175,.045,0

```

```

* 635 *                               800,.055,0) ..
* 636 * SUMMER-SHOUL = BLOCK-CHARGE  BLOCK-SCH = SEASONS-SCH
* 637 *                               SCH-FLAG = 2.2
* 638 *                               BLOCK1-TYPE = KWH/KW
* 639 *                               BLOCK1-DATA = (175,.055,0
* 640 *                               800,.065,0) ..
* 641 * SUMMER-ON-P = BLOCK-CHARGE  BLOCK-SCH = SEASONS-SCH
* 642 *                               SCH-FLAG = 2.3
* 643 *                               BLOCK1-TYPE = KWH/KW
* 644 *                               BLOCK1-DATA = (175,.065,0
* 645 *                               800,.075,0) ..
* 646 *
* 647 * SUMMER-DEMAND = BLOCK-CHARGE  BLOCK-SCH = SEASONS-SCH
* 648 *                               SCH-FLAG = 2.3
* 649 *                               TOU-SEASON-LINKS = (WINTER-DEMAND)
* 650 *                               BLOCK1-TYPE = DEMAND
* 651 *                               BLOCK1-DATA = ( 1,6.00) ..
* 652 *
* 653 * SEASONS-SCH  SCHEDULE  THRU MAY 15 (WD) (1,8)(1.1) (9,12)(1.2) (13,17)(1.3)
* 654 *                               (18,22)(1.2) (23,24)(1.1)
* 655 *                               (WEH) (1,8)(1.1) (9,24)(1.2)
* 656 *                               THRU SEP 15 (WD) (1,8)(2.1) (9,12)(2.2) (13,18)(2.3)
* 657 *                               (19,24)(2.2)
* 658 *                               (WEH) (1,8)(2.1) (9,24)(2.2)
* 659 *                               THRU DEC 31 (WD) (1,8)(1.1) (9,12)(1.2) (13,17)(1.3)
* 660 *                               (18,22)(1.2) (23,24)(1.1)
* 661 *                               (WEH) (1,8)(1.1) (9,24)(1.2) ..
* 662 * END ..
* 663 * COMPUTE ECONOMICS ..
* 664 * INPUT SYSTEMS ..

```

31-STORY OFFICE BLDG, CHICAGO - LOAD1
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

RUN 2 VARIABLE AIR VOLUME SYSTEM
 ELECTRIC THERMOSTATIC BASEBOARDS
 BLDG

DOE-2.1E-001 Wed Nov 10 14:35:12 1993SDL RUN 2
 WARM-UP CYCLE USES GAS HEAT
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
BLDG	VAVS	1.020	620000.0	4402.								
SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	
849109.	977.066	3.6	849109.	368.704	1.4	0.106	33083.254	0.676	-30765.266	0.00	0.37	
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
RZ1	12138.	0.	0.000	0.250	1224.	0.00	0.00	249.07	-262.18	-448.27	1.0	
RZ2	5391.	0.	0.000	0.250	571.	0.00	0.00	110.63	-116.45	-314.67	1.0	
RZ3	1672.	0.	0.000	0.250	265.	0.00	0.00	34.31	-36.11	-123.17	1.0	
RZ4	5348.	0.	0.000	0.250	571.	0.00	0.00	109.74	-115.51	-313.27	1.0	
RZ5	2336.	0.	0.000	0.250	265.	0.00	0.00	47.93	-50.45	-144.68	1.0	
TZ1	12138.	0.	0.000	0.250	1224.	0.00	0.00	249.07	-262.18	-448.27	30.0	
TZ2	5418.	0.	0.000	0.250	571.	0.00	0.00	111.18	-117.03	-295.54	30.0	
TZ3	1627.	0.	0.000	0.250	265.	0.00	0.00	33.39	-35.15	-112.73	30.0	
TZ4	5785.	0.	0.000	0.250	571.	0.00	0.00	118.70	-124.95	-307.42	30.0	
TZ5	2440.	0.	0.000	0.250	265.	0.00	0.00	50.06	-52.69	-139.04	30.0	

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -						- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	0.00000				0.000	-480.937	11 8	15.F	14.F	-25227.889	718884.	5016.672	
FEB	0.00000				0.000	-424.595	8 8	7.F	6.F	-25438.799	597583.	4303.577	
MAR	83.19585	3 16	79.F	62.F	7999.346	-256.093	1 8	28.F	27.F	-20184.379	607251.	3695.740	
APR	605.01703	28 15	78.F	68.F	13718.789	-128.728	9 17	47.F	36.F	-2658.760	525790.	2333.793	
MAY	681.43768	21 14	85.F	75.F	16606.508	-73.512	6 17	48.F	38.F	-3559.978	480318.	2161.021	
JUN	2267.18628	21 16	82.F	72.F	19424.721	-0.127	16 8	54.F	48.F	-122.216	532027.	2288.137	
JUL	3411.16089	19 8	77.F	72.F	23438.977	0.000				0.000	522663.	2419.513	
AUG	3058.12817	16 8	72.F	68.F	21856.553	0.000				0.000	537604.	2311.094	
SEP	1121.87512	10 15	82.F	70.F	15121.777	-54.955	23 17	59.F	46.F	-2273.243	502109.	2188.370	
OCT	345.68723	5 16	74.F	62.F	9919.728	-85.576	18 8	43.F	41.F	-3569.758	478057.	2165.382	
NOV	158.14256	2 16	77.F	62.F	10400.727	-101.933	15 8	27.F	26.F	-7094.745	573664.	4715.411	
DEC	0.00000				0.000	-256.720	27 8	31.F	30.F	-25258.002	696788.	4494.943	
TOTAL	11731.829					-1863.177					6772698.		
MAX					23438.977					-25438.799		5016.672	
MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY)					0.000 (KBTU)								
MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE)					230887.600 (KBTU)								

- - - - - C O O L I N G - - - - -					- - - - - H E A T I N G - - - - -					- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-1228.748	11 8	15.F	14.F	-25227.889	686369.	4731.019
FEB	0.00000				0.000	-850.592	8 8	7.F	6.F	-25438.799	566911.	4092.727
MAR	83.19585	3 16	79.F	62.F	7999.346	-431.543	1 8	28.F	27.F	-20184.379	573556.	3510.529
APR	605.01703	28 15	78.F	68.F	13718.789	-137.147	16 12	51.F	40.F	-2657.328	496185.	2167.263
MAY	681.13385	21 14	85.F	75.F	16518.898	-74.092	6 17	48.F	38.F	-3559.978	453719.	2076.871
JUN	2261.16309	21 16	82.F	72.F	19304.686	-0.127	16 8	54.F	48.F	-122.216	502915.	2203.988
JUL	3384.38525	19 8	77.F	72.F	23257.844	0.000				0.000	494790.	2335.364
AUG	3039.20337	16 8	72.F	68.F	21856.553	0.000				0.000	508457.	2226.944
SEP	1117.51477	10 15	82.F	70.F	14948.386	-55.046	23 17	59.F	46.F	-2273.243	474262.	2104.220
OCT	345.51819	5 10	74.F	62.F	9919.728	-93.907	18 8	43.F	41.F	-3569.758	451453.	2081.232
NOV	158.08046	2 16	77.F	62.F	10338.622	-435.736	15 9	28.F	26.F	-14506.762	546747.	4559.283
DEC	0.00000				0.000	-894.017	27 8	31.F	30.F	-25258.002	666612.	4322.104
TOTAL	11675.214					-4200.956					6421994.	
MAX					23257.844					-25438.799		4731.019

COOLING				HEATING			DAY COOLING PEAK				
JUL 19				FEB 8			JUL 19				
HOURLY	COOLING	SENSIBLE	DRY-	WET-	HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-
LOAD	HEAT	BULB	BULB	HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB	
(KBTU)	RATIO	TEMP	TEMP	(KBTU)	TEMP	TEMP	(KBTU)	RATIO	TEMP	TEMP	
1	0.000	0.000	79.F	72.F	-1676.769	14.F	12.F	0.000	0.000	79.F	72.F
2	0.000	0.000	79.F	72.F	-1777.842	12.F	11.F	0.000	0.000	79.F	72.F
3	0.000	0.000	78.F	72.F	-1863.587	9.F	8.F	0.000	0.000	78.F	72.F
4	0.000	0.000	78.F	72.F	-2201.448	8.F	7.F	0.000	0.000	78.F	72.F
5	0.000	0.000	77.F	72.F	-2206.422	6.F	5.F	0.000	0.000	77.F	72.F
6	0.000	0.000	78.F	72.F	-2255.855	5.F	4.F	0.000	0.000	78.F	72.F
7	23257.844	0.984	77.F	72.F	-2305.349	5.F	5.F	23257.844	0.984	77.F	72.F
8	22514.631	0.842	79.F	72.F	-25438.799	7.F	6.F	22514.631	0.842	79.F	72.F
9	21396.689	0.852	82.F	72.F	-2892.448	13.F	11.F	21396.689	0.852	82.F	72.F
10	21279.252	0.855	85.F	73.F	-11614.917	14.F	12.F	21279.252	0.855	85.F	73.F
11	21347.191	0.865	88.F	74.F	-9849.519	17.F	14.F	21347.191	0.865	88.F	74.F
12	20449.969	0.854	89.F	74.F	-8485.560	19.F	16.F	20449.969	0.854	89.F	74.F
13	20894.680	0.837	90.F	75.F	-7360.321	21.F	17.F	20894.680	0.837	90.F	75.F
14	20834.625	0.832	89.F	75.F	-5674.086	21.F	17.F	20834.625	0.832	89.F	75.F
15	21063.539	0.836	90.F	75.F	-5062.012	21.F	17.F	21063.539	0.836	90.F	75.F
16	18657.373	0.836	91.F	76.F	-3646.734	21.F	17.F	18657.373	0.836	91.F	76.F
17	17188.213	0.841	90.F	75.F	-4622.370	20.F	17.F	17188.213	0.841	90.F	75.F
18	0.000	0.000	86.F	74.F	-5997.368	18.F	15.F	0.000	0.000	86.F	74.F
19	0.000	0.000	86.F	74.F	0.000	17.F	15.F	0.000	0.000	86.F	74.F
20	0.000	0.000	80.F	72.F	0.000	15.F	13.F	0.000	0.000	80.F	72.F
21	0.000	0.000	79.F	72.F	0.000	13.F	12.F	0.000	0.000	79.F	72.F
22	0.000	0.000	77.F	71.F	0.000	13.F	12.F	0.000	0.000	77.F	71.F
23	0.000	0.000	76.F	71.F	0.000	12.F	11.F	0.000	0.000	76.F	71.F
24	0.000	0.000	74.F	70.F	0.000	9.F	8.F	0.000	0.000	74.F	70.F
SUM								228884.000			
MAX	23257.844				-25438.799						

SYSTEM-TYPE VAVS SQFT/TON 319.9
 COOLING PEAK 37.51 (BTU/HR- SQFT) HEATING PEAK -41.03 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.37 (CFM/SQFT) MIN-OA/PERSON 20.40 (CFM)
 OA FRAC AT CLG PEAK 0.012 OA FRAC AT HTG PEAK 0.010

* ASTERISKS INDICATE HOURS LOADS NOT MET

----- C O O L I N G -----						----- H E A T I N G -----					----- E L E C -----	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-30.984	4 9	4.F	3.F	-543.070	17315.	185.654
FEB	0.00000				0.000	-28.954	8 9	13.F	11.F	-305.531	16233.	116.055
MAR	0.00000				0.000	-21.719	1 9	30.F	28.F	-239.701	16215.	96.767
APR	0.00000				0.000	-5.386	19 9	39.F	35.F	-144.093	12885.	68.754
MAY	0.30392	21 13	87.F	76.F	93.557	-0.012	10 9	46.F	43.F	-12.392	11399.	44.150
JUN	6.02330	9 15	83.F	73.F	165.044	0.000				0.000	12391.	44.149
JUL	26.77848	13 17	97.F	78.F	259.228	0.000				0.000	11913.	44.149
AUG	18.92442	26 17	94.F	76.F	254.092	0.000				0.000	12427.	44.149
SEP	4.36051	10 11	77.F	69.F	191.406	-0.035	22 8	34.F	31.F	-14.893	11887.	47.013
OCT	0.16904	4 17	78.F	61.F	68.037	-0.017	1 8	33.F	32.F	-15.733	11404.	47.259
NOV	0.06210	2 16	77.F	62.F	62.104	-3.910	29 9	29.F	28.F	-138.523	11717.	67.122
DEC	0.00000				0.000	-18.103	27 9	31.F	30.F	-217.205	14217.	90.176
TOTAL	56.622					-108.819					160002.	
MAX					259.228					-543.070		185.654

HOUR	COOLING				HEATING			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY-BULB TEMP	WET-BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP
	JUL 13				JAN 4			JUL 14			
1	0.000	0.000	76.F	66.F	0.000	6.F	6.F	0.000	0.000	83.F	72.F
2	0.000	0.000	74.F	66.F	0.000	5.F	5.F	0.000	0.000	81.F	72.F
3	0.000	0.000	74.F	65.F	0.000	4.F	4.F	0.000	0.000	80.F	71.F
4	0.000	0.000	73.F	62.F	0.000	4.F	4.F	0.000	0.000	78.F	71.F
5	0.000	0.000	72.F	62.F	0.000	3.F	3.F	0.000	0.000	77.F	70.F
6	0.000	0.000	72.F	63.F	0.000	3.F	3.F	0.000	0.000	78.F	71.F
7	0.000	0.000	73.F	65.F	0.000	2.F	2.F	171.014	0.696	79.F	71.F
8	123.313	0.526	76.F	69.F	0.000	2.F	2.F	184.646	0.699	82.F	72.F
9	169.597	0.703	82.F	72.F	-543.070	4.F	3.F	211.456	0.687	86.F	74.F
10	198.345	0.681	86.F	74.F	-495.242	7.F	6.F	213.700	0.714	88.F	74.F
11	221.819	0.661	89.F	76.F	-465.945	11.F	9.F	238.488	0.686	91.F	76.F
12	240.226	0.642	93.F	78.F	-427.645	16.F	13.F	233.342	0.715	94.F	76.F
13	242.319	0.666	95.F	78.F	-409.028	18.F	15.F	246.195	0.707	96.F	77.F
14	239.493	0.710	96.F	77.F	-383.750	20.F	16.F	212.832	0.704	87.F	74.F
15	243.268	0.718	97.F	77.F	-362.419	20.F	16.F	177.021	0.454	76.F	71.F
16	259.228	0.689	97.F	78.F	-346.622	20.F	16.F	183.168	0.668	78.F	72.F
17	242.758	0.735	99.F	77.F	-332.858	19.F	15.F	179.725	0.653	78.F	72.F
18	0.000	0.000	97.F	76.F	-336.910	16.F	13.F	0.000	0.000	89.F	75.F
19	0.000	0.000	95.F	75.F	0.000	13.F	11.F	0.000	0.000	87.F	75.F
20	0.000	0.000	93.F	75.F	0.000	11.F	9.F	0.000	0.000	84.F	74.F
21	0.000	0.000	90.F	74.F	0.000	10.F	8.F	0.000	0.000	84.F	74.F
22	0.000	0.000	87.F	73.F	0.000	11.F	9.F	0.000	0.000	82.F	74.F
23	0.000	0.000	86.F	73.F	0.000	7.F	6.F	0.000	0.000	80.F	72.F
24	0.000	0.000	85.F	73.F	0.000	6.F	5.F	0.000	0.000	78.F	72.F
SUM								2251.587			
MAX	259.228				-543.070						

SYSTEM-TYPE SZRH SQFT/TON 925.8
 COOLING PEAK 12.96 (BTU/HR- SQFT) HEATING PEAK -27.15 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.36 (CFM/SQFT)
 OA FRAC AT CLG PEAK 0.125 OA FRAC AT HTG PEAK 0.125

* ASTERISKS INDICATE HOURS LOADS NOT MET

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD
	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL
HW-BOILER	25.608	1								
ELEC-DHW-HEATER	0.114	1								
HEM-CENT-CHLR	13.500	2								
COOLING-TWR	10.913	3								
CTANK-STORAGE	50.000	1								
COOL-STORE-RATE =	13.500		(MBTU/H)							
COOL-SUPPLY-RATE=	13.500		(MBTU/H)							

S I T E E N E R G Y													SOURCE
MONTH	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	535.1	0.0	740.5	0.0	0.0	0.0	0.0	782.1	249.8	0.0	782.1	3309.5	8365.0
FEB	476.5	0.0	617.6	0.0	0.0	0.0	0.0	693.5	153.3	0.0	693.5	2801.3	7017.5
MAR	315.7	93.4	636.3	0.0	0.0	0.0	9.4	465.9	77.5	0.0	465.9	2637.7	6981.9
APR	169.8	655.1	594.7	0.0	0.0	0.0	55.2	248.3	17.6	0.0	248.3	2277.8	6337.5
MAY	97.7	799.2	556.4	0.0	0.0	0.0	67.3	135.1	8.9	0.0	135.1	2034.0	5832.4
JUN	15.7	2342.1	707.8	0.0	0.0	0.0	170.5	0.8	5.3	0.0	0.8	2416.5	7248.8
JUL	13.5	3556.2	771.4	0.0	0.0	0.0	244.0	0.0	4.7	0.0	0.0	2632.7	7898.8
AUG	13.7	3135.4	762.0	0.0	0.0	0.0	219.6	0.0	4.8	0.0	0.0	2600.5	7802.3
SEP	76.2	1240.5	606.9	0.0	0.0	0.0	97.2	102.5	7.6	0.0	102.5	2173.9	6317.3
OCT	115.4	347.0	527.8	0.0	0.0	0.0	39.8	166.2	12.4	0.0	166.2	1967.7	5571.2
NOV	139.3	174.5	601.9	0.0	0.0	0.0	16.4	202.5	110.9	0.0	202.5	2256.9	6366.4
DEC	312.7	0.0	714.7	0.0	0.0	0.0	0.0	450.3	210.0	0.0	450.3	2889.6	7768.9
TOTAL	2281.4	12343.5	7838.0	0.0	0.0	0.0	919.4	3247.1	862.7	0.0	3247.1	29998.1	83508.1

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD		
HW-BOILER	2094.2	91.8		
ELEC-DHW-HEATER	187.2	8.2		
=====				
LOAD SATISFIED	2281.4	100.0		
TOTAL LOAD ON PLANT	2281.4			
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD		
HERM-CENT-CHLR	12343.5	100.0		
=====				
LOAD SATISFIED	12343.5	100.0		
TOTAL LOAD ON PLANT	12343.5			
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD		
ELECTRICITY	7838039.5	100.0		
=====				
LOAD SATISFIED	7838039.5	100.0		
TOTAL LOAD ON PLANT	7838303.5			
STORAGE TANK USE	MBTU STORED	MBTU RETURNED	MBTU LOST	MBTU RESIDUAL
CTANK-STORAGE	4135.8	4134.8	0.87	0.06

TOWER ABOVE DESIGN TEMPERATURE OF 85.F 0 HOURS

31-STORY OFFICE BLDG, CHICAGO - LOAD1
REPORT- PS-D PLANT LOADS SATISFIED

RUN 2 VARIABLE AIR VOLUME SYSTEM
ELECTRIC THERMOSTATIC BASEBOARDS

DOE-2.1E-001 Wed Nov 10 14:35:12 1993PDL RUN 2
WARM-UP CYCLE USES GAS HEAT
WEATHER FILE- TRY CHICAGO
(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	2281.4	2281.4	0.000	0.000	0
COOLING LOADS	12343.5	12343.5	57.109	5.354	32
ELECTRICAL LOADS	26751.9	26751.0	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		
AREA LIGHTS	10810.3	0.0
MISC EQUIPMT	3997.2	0.0
SPACE HEAT	2598.6	3247.1
SPACE COOL	2378.6	0.0
HEAT REJECT	419.9	0.0
PUMPS & MISC	468.1	0.0
VENT FANS	5861.1	0.0
DOMHOT WATER	217.3	0.0
TOTAL	26751.1	3247.1

TOTAL SITE ENERGY 29998.22 MBTU 46.9 KBTU/SQFT-YR GROSS-AREA 46.9 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 83508.49 MBTU 130.5 KBTU/SQFT-YR GROSS-AREA 130.5 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 3.9
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.4

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

31-STORY OFFICE BLDG, CHICAGO - LOAD1
 REPORT- ES-D ENERGY COST SUMMARY

RUN 2 VARIABLE AIR VOLUME SYSTEM
 ELECTRIC THERMOSTATIC BASEBOARDS

DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 2
 WARM-UP CYCLE USES GAS HEAT

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
GAS-RATE	NATURAL-GAS	1 2 3 4 5	32471. THERM	19483.	0.6000	YES
ELEC-RATE	ELECTRICITY	1 2 3 4 5	7838040. KWH	595752.	0.0760	YES

 615235.

ENERGY COST/GROSS BLDG AREA: 0.96
 ENERGY COST/NET BLDG AREA: 0.96

31-STORY OFFICE BLDG, CHICAGO - LOAD1
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

RUN 2 VARIABLE AIR VOLUME SYSTEM
 ELECTRIC THERMOSTATIC BASEBOARDS
 GAS-RATE

DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 2
 WARM-UP CYCLE USES GAS HEAT

UTILITY-RATE: GAS-RATE RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	7821	7821	317.9	317.9	4692	0	0	0	0	0	0	0.6000	4692
FEB	6935	6935	320.1	320.1	4161	0	0	0	0	0	0	0.6000	4161
MAR	4659	4659	264.0	264.0	2795	0	0	0	0	0	0	0.6000	2795
APR	2483	2483	46.2	46.2	1490	0	0	0	0	0	0	0.6000	1490
MAY	1351	1351	60.9	60.9	811	0	0	0	0	0	0	0.6000	811
JUN	8	8	4.8	4.8	5	0	0	0	0	0	0	0.6000	5
JUL	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
AUG	0	0	0.0	0.0	0	0	0	0	0	0	0	0.0000	0
SEP	1025	1025	39.9	39.9	615	0	0	0	0	0	0	0.6000	615
OCT	1662	1662	61.1	61.1	997	0	0	0	0	0	0	0.6000	997
NOV	2025	2025	114.9	114.9	1215	0	0	0	0	0	0	0.6000	1215
DEC	4503	4503	318.2	318.2	2702	0	0	0	0	0	0	0.6000	2702
TOTAL	32471	32471	320.1		19483	0	0	0	0	0		0.6000	19483

31-STORY OFFICE BLDG, CHICAGO - LOAD1 RUN 2 VARIABLE AIR VOLUME SYSTEM DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 2
 ELECTRIC THERMOSTATIC BASEBOARDS WARM-UP CYCLE USES GAS HEAT
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-RATE

UTILITY-RATE: ELEC-RATE RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS	BLOCK-CHARGES	DEMAND-RATCHETS	MIN-MON-RATCHETS
MIN-ENERGY: 0.0	WINTER-OFF-P		
MAX-ENERGY: 0.0	WINTER-SHOUL	WINTER-DEMAND	
MIN-DEMAND: 0.0	WINTER-ON-P	SUMMER-DEMAND	
MAX-DEMAND: 0.0	SUMMER-OFF-P		
QUALIFY-RATE: ALL-MONTHS	SUMMER-SHOUL		
USE-MIN-QUAL: NO	SUMMER-ON-P		

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	740522	740522	5242.9	5242.9	34144	18759	0	0	0	0	0	0.0714	52903
FEB	617579	617579	4465.4	4465.4	28630	17922	0	0	0	0	0	0.0754	46552
MAR	636339	636339	3775.2	3775.2	29531	14610	0	0	0	0	0	0.0694	44141
APR	594652	594652	3085.4	3085.4	27746	15427	0	0	0	0	0	0.0726	43173
MAY	556384	556384	3257.2	3257.2	29112	14034	0	0	0	0	0	0.0775	43146
JUN	707817	707817	3484.0	3484.0	40840	17714	0	0	0	0	0	0.0827	58554
JUL	771373	771373	3811.1	3811.1	44334	18973	0	0	0	0	0	0.0821	63307
AUG	761952	761952	3648.0	3648.0	43863	17574	0	0	0	0	0	0.0806	61437
SEP	606918	606918	3078.0	3078.0	31462	14911	0	0	0	0	0	0.0764	46373
OCT	527844	527844	2789.8	2789.8	24593	13949	0	0	0	0	0	0.0730	38542
NOV	601948	601948	4896.1	4896.1	28013	17529	0	0	0	0	0	0.0757	45542
DEC	714713	714713	4632.2	4632.2	33203	18879	0	0	0	0	0	0.0729	52082
TOTAL	7838040	7838040	5242.9		395471	200281	0	0	0	0		0.0760	595752

REPORT- ES-F BLOCK-CHARGE AND RATCHET SUMMARY FOR: ELEC-RATE

UTILITY-RATE: ELEC-RATE
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR

WINTER-OFF-P	USE: TIME-OF-USE												
METERED ENERGY:	101083	70558	66003	53122	33673	0	0	0	45415	49970	52607	70150	
BILLING ENERGY:	101083	70558	66003	53122	33673	0	0	0	45415	49970	52607	70150	542581
KWH/KW DEMAND:	2404.8	2404.8	2404.8	1532.2	1654.1	0.0	0.0	0.0	1506.2	1567.2	1635.8	2404.8	
ENERGY CHGS (\$):	4043	2822	2640	2125	1347	0	0	0	1817	1999	2104	2806	21703
WINTER-SHOUL	USE: TIME-OF-USE												
METERED ENERGY:	374244	308760	325254	291074	131420	0	0	0	148723	259821	311664	366207	
BILLING ENERGY:	374244	308760	325254	291074	131420	0	0	0	148723	259821	311664	366207	2517167
KWH/KW DEMAND:	5242.9	4465.4	3775.2	2974.2	2612.3	0.0	0.0	0.0	2931.9	2653.2	4896.1	4632.2	
ENERGY CHGS (\$):	16841	13894	14636	13098	5914	0	0	0	6693	11692	14025	16479	113273
WINTER-ON-P	USE: TIME-OF-USE												
METERED ENERGY:	265196	238262	245083	250458	100751	0	0	0	112778	218054	237678	278357	
BILLING ENERGY:	265196	238262	245083	250458	100751	0	0	0	112778	218054	237678	278357	1946618
KWH/KW DEMAND:	3751.9	3584.4	2922.1	3085.4	2303.3	0.0	0.0	0.0	2582.6	2789.8	3505.8	3775.7	
ENERGY CHGS (\$):	13260	11913	12254	12523	5038	0	0	0	5639	10903	11884	13918	97331
SUMMER-OFF-P	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	40643	107781	129078	124020	45544	0	0	0	
BILLING ENERGY:	0	0	0	0	40643	107781	129078	124020	45544	0	0	0	447066
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	2241.4	2865.1	3321.5	3178.9	2135.7	0.0	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	1829	4850	5809	5581	2049	0	0	0	20118
SUMMER-SHOUL	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	125871	301229	322381	318381	127532	0	0	0	
BILLING ENERGY:	0	0	0	0	125871	301229	322381	318381	127532	0	0	0	1195393
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	3257.2	3484.0	3811.1	3648.0	3078.0	0.0	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	6923	16568	17731	17511	7014	0	0	0	65747
SUMMER-ON-P	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	124028	298808	319915	319553	126927	0	0	0	
BILLING ENERGY:	0	0	0	0	124028	298808	319915	319553	126927	0	0	0	1189231
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	2530.8	2952.3	3162.2	2929.0	2700.4	0.0	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	8062	19423	20794	20771	8250	0	0	0	77300
WINTER-DEMAND	USE: TIME-OF-USE												
METERED DEMAND:	3751.9	3584.4	2922.1	3085.4	2303.3	0.0	0.0	0.0	2582.6	2789.8	3505.8	3775.7	
BILLING DEMAND:	3751.9	3584.4	2922.1	3085.4	2530.8	0.0	0.0	0.0	2700.4	2789.8	3505.8	3775.7	
PRORATE FACTOR:	1.0000	1.0000	1.0000	1.0000	0.4545	0.0000	0.0000	0.0000	0.4783	1.0000	1.0000	1.0000	
DEMAND CHGS (\$):	18759	17922	14610	15427	5752	0	0	0	6457	13949	17529	18879	129284
SUMMER-DEMAND	USE: TIME-OF-USE												
METERED DEMAND:	0.0	0.0	0.0	0.0	2530.8	2952.3	3162.2	2929.0	2700.4	0.0	0.0	0.0	
BILLING DEMAND:	0.0	0.0	0.0	0.0	2530.8	2952.3	3162.2	2929.0	2700.4	0.0	0.0	0.0	
PRORATE FACTOR:	0.0000	0.0000	0.0000	0.0000	0.5455	1.0000	1.0000	1.0000	0.5217	0.0000	0.0000	0.0000	
DEMAND CHGS (\$):	0	0	0	0	8283	17714	18973	17574	8453	0	0	0	70997

TOTAL ENERGY:	740523	617580	636340	594654	556386	707818	771374	761954	606919	527845	601949	714714	7838056
TOTAL CHARGES (\$):	52903	46552	44141	43173	43146	58554	63307	61437	46373	38542	45542	52082	595752

31-Story Office Building, LOAD1 — Run 3 Systems, Plant, Economics

SDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993SDL RUN 3

```

* 665 *
* 666 *      TITLE      LINE-2 *RUN 3 VARIABLE AIR VOLUME SYSTEM *
* 667 *      LINE-4 *OA RESET BASEBOARDS *
* 668 *      LINE-5 *-
* 669 *
* 670 *      $ HAVC SYSTEM DESCRIPTION
* 671 *
* 672 * $ DESIGN TEMPS COOLING 76F HEATING 70F.
* 673 * $ SYSTEM TYPE  A SINGLE VARIABLE AIR VOLUME SYSTEM SERVES THE ENTIRE BUILDING.
* 674 * $                THE SYSTEM HAS A DRY BULB CONTROLLED ECONOMIZER WITH A LIMIT
* 675 * $                TEMPERATURE OF 68F AND THE FANS HAVE A SPEED CONTROLLER. THE VAV
* 676 * $                BOXES HAVE A MINIMUM STOP OF 20%. BASEBOARD RADIATION IS NOT
* 677 * $                CONTROLLED BY SPACE THERMOSTATS BUT BY A RESET CONTROL THAT
* 678 * $                IS A FUNCTION OF OA TEMP. THEREFORE THE BASEBOARD IS ACTIVE
* 679 * $                AT NIGHT BUT THE FAN SYSTEM CAN CYCLE ON IF NECESSARY TO HOLD
* 680 * $                THE NIGHT LOW LIMIT SETTING OF 55F. THE FANS CAN START AS
* 681 * $                EARLY AS 5AM BUT ARE DELAYED AS LONG AS POSSIBLE (I.E., OPTIMUM
* 682 * $                START). FANS ARE OFF AFTER 6PM AND ON WEEKENDS AND HOLIDAYS.
* 683 *
* 684 * $                THERE ARE REHEAT COILS IN THE VAV BOXES THAT ARE CONTROLLED BY
* 685 * $                SPACE THERMOSTATS SINCE THE BASEBOARD RADIATION IS SIZED ONLY
* 686 * $                FOR GLASS CONDUCTION. A HUMIDISTAT CONTROLS THE
* 687 * $                RETURN AIR HUMIDITY AT 25% RH BY ADDING STEAM TO THE AIR. TO
* 688 * $                PREVENT ADDING MOISTURE TO LARGE QUANTITIES OF OUTSIDE AIR, WHICH
* 689 * $                IS VERY COSTLY, THE ECONOMIZER DAMPERS ARE CLOSED BELOW OUTSIDE
* 690 * $                AIR TEMPERATURES OF 45F. THE FREE COOLING CYCLE ON THE CHILLERS
* 691 * $                PROVIDES NECESSARY MECHANICAL COOLING, SINCE OUTSIDE AIR COOLING
* 692 * $                IS LOCKED OUT.
* 693 *
* 694 *      SYSTEMS-REPORT      SUMMARY=(SS-A,SS-D,SS-J) ..
* 695 *
* 696 *      $ SCHEDULES
* 697 *
* 698 * HRS1      = DAY-SCHEDULE (1,5) (0) (6,7) (-999) (8,18) (1) (19,24) (0) ..
* 699 * HRS2      = DAY-SCHEDULE (1,24) (0) ..
* 700 * DAYS1     = WEEK-SCHEDULE (MON,FRI) HRS1 (WEH) HRS2 ..
* 701 * AHU-SCHED = SCHEDULE THRU DEC 31 DAYS1 .. $ FANS $
* 702 *
* 703 * HRSH1     = DAY-SCHEDULE (1,7) (55) (8,18) (70) (19,24) (55) ..
* 704 * HRSH2     = DAY-SCHEDULE (1,24) (55) ..
* 705 * DAYHEAT   = WEEK-SCHEDULE (MON,FRI) HRSH1 (WEH) HRSH2 ..
* 706 * THEAT     = SCHEDULE THRU DEC 31 DAYHEAT .. $ HEATING $
* 707 *
* 708 * HRSC1     = DAY-SCHEDULE (1,7) (99) (8,18) (76) (19,24) (99) ..
* 709 * HRSC2     = DAY-SCHEDULE (1,24) (99) ..
* 710 * DAYCOOL   = WEEK-SCHEDULE (MON,FRI) HRSC1 (WEH) HRSC2 ..
* 711 * TCOOL     = SCHEDULE THRU DEC 31 DAYCOOL .. $ COOLING $
* 712 *
* 713 * HEATON    = SCHEDULE THRU DEC 31 (ALL) (1,24) (60) ..
* 714 *
* 715 * SAT-FOA   = SCHEDULE THRU DEC 31 (ALL) SA1 ..
* 716 * SA1       = DAY-RESET-SCH SUPPLY-HI 65 SUPPLY-LO 55
* 717 *                OUTSIDE-LO 20 OUTSIDE-HI 75 ..
* 718 *
* 719 * BASEB     = RESET-SCHEDULE THRU MAR 15 (ALL) BASE1

```

```

* 720 *                THRU DEC 15 (ALL) BASE2
* 721 *                THRU DEC 31 (ALL) BASE3 ..
* 722 *
* 723 * BASE1          = DAY-RESET-SCH OUTSIDE-HI = 60 OUTSIDE-LO = 0
* 724 *                SUPPLY-HI = 1 SUPPLY-LO = 0 ..
* 725 * BASE2          = DAY-RESET-SCH OUTSIDE-HI = 60 OUTSIDE-LO = 0
* 726 *                SUPPLY-HI = 0 SUPPLY-LO = 0 ..
* 727 * BASE3          = DAY-RESET-SCH OUTSIDE-HI = 60 OUTSIDE-LO = 0
* 728 *                SUPPLY-HI = 1 SUPPLY-LO = 0 ..
* 729 *
* 730 *
* 731 *                $ ZONE SUB-COMMANDS
* 732 *
* 733 * ZAIR            = ZONE-AIR      OA-CFM/PER=20 ..
* 734 *
* 735 * CONTROL        = ZONE-CONTROL DESIGN-HEAT-T=70 DESIGN-COOL-T=74
* 736 *                HEAT-TEMP-SCH=THEAT COOL-TEMP-SCH=TCOOL
* 737 *                BASEBOARD-CTRL=OUTDOOR-RESET
* 738 *                THERMOSTAT-TYPE=REVERSE-ACTION ..
* 739 *
* 740 *                $ ZONE DESCRIPTION
* 741 *
* 742 * RZ1            = ZONE          ZONE-AIR=ZAIR ZONE-CONTROL=CONTROL CFM/SQFT=.9
* 743 *                BASEBOARD-RATING=-50000 ..
* 744 * RZ2            = ZONE LIKE RZ1 BASEBOARD-RATING=-50000 ..
* 745 * RZ3            = ZONE LIKE RZ2 B-R -25000 ..
* 746 * RZ4            = ZONE LIKE RZ2 ..
* 747 * RZ5            = ZONE LIKE RZ3 ..
* 748 * TZ1            = ZONE LIKE RZ1 ..
* 749 * TZ2            = ZONE LIKE RZ2 ..
* 750 * TZ3            = ZONE LIKE RZ3 ..
* 751 * TZ4            = ZONE LIKE TZ2 ..
* 752 * TZ5            = ZONE LIKE TZ3 ..
* 753 * A-STORAGE= ZONE LIKE RZ1      AIR-CHANGES/HR=4 OA-CHANGES=0.5 ..
* 754 *
* 755 *                $ SYSTEM SUB-COMMANDS
* 756 *
* 757 * S-CTRL         = SYSTEM-CONTROL HEATING-SCHEDULE=HEATON
* 758 *                BASEBOARD-SCH=BASEB HEAT-SET-T=60
* 759 *                COOL-CONTROL=RESET COOL-RESET-SCH=SAT-FOA
* 760 *                MIN-SUPPLY-T=55 MAX-SUPPLY-T=105
* 761 *                MIN-HUMIDITY=25 ..
* 762 *
* 763 * S-FAN          = SYSTEM-FANS    FAN-SCHEDULE=AHU-SCHED FAN-CONTROL=SPEED
* 764 *                SUPPLY-STATIC=5.5 SUPPLY-EFF=0.54
* 765 *                RETURN-STATIC=2.0 RETURN-EFF=0.51 ..
* 766 *
* 767 * S-TERM         = SYSTEM-TERMINAL REHEAT-DELTA-T=50 MIN-CFM-RATIO=0.2 ..
* 768 *
* 769 *                $ SYSTEM DESCRIPTION
* 770 *
* 771 * VARVOL         = SYSTEM          SYSTEM-TYPE=VAVS SYSTEM-CONTROL=S-CTRL
* 772 *                SYSTEM-FANS=S-FAN ECONO-LOW-LIMIT 45
* 773 *                SYSTEM-TERMINAL=S-TERM RETURN-AIR-PATH=DUCT
* 774 *                ECONO-LIMIT-T=68 ZONE-NAMES=(RZ1,RZ2,RZ3,
* 775 *                RZ4,RZ5,TZ1,TZ2,TZ3,TZ4,TZ5) ..
* 776 *
* 777 * BASMT-SYS      = SYSTEM          SYSTEM-TYPE=SZRH MAX-S-T=105 MIN-S-T=55
* 778 *                SUPPLY-STATIC=2.5 S-E=.5 F-SCH=AHU-SCHED
* 779 *                H-SCH=HEATON
* 780 *                ZONE-NAMES=(A-STORAGE) ..
* 781 *
* 782 * PLANT1        = PLANT-ASSIGNMENT SYSTEM-NAMES = (VARVOL,BASMT-SYS)

```

```

* 783 *          INT-ELEC-KW = 100 $ FOR ELEVATORS
* 784 *          INT-ELEC-SCH = OCCUP
* 785 *          DHW-SIZE=0
* 786 *          DHW-GAL/MIN = 2.22
* 787 *          DHW-SCH      = OCCUP ..
* 788 *
* 789 * OC1          =DAY-SCHEDULE      (1,8) (0.)          (9,10) (1.)
* 790 *          (11,13) (.8,.4,.8) (14,24) (1.,1.,1.,
* 791 *          .3,.1,.1,.1,0.,0.,0.,0.) ..
* 792 * OC2          =DAY-SCHEDULE      (1,24) (0.0) ..
* 793 * PEOPLE       =WEEK-SCHEDULE     (MON,FRI) OC1      (WEH) OC2 ..
* 794 * OCCUP        =SCHEDULE          THRU DEC 31 PEOPLE ..
* 795 * END          ..
* 796 * COMPUTE SYSTEMS ..
* 797 *
* 798 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993PDL RUN 3

```

* 799 * PLANT1 = PLANT-ASSIGNMENT ..
* 800 *
* 801 *          PLANT-REPORT          SUMMARY=(PS-A,BEPS) ..
* 802 *
* 803 *          $ PLANT DESCRIPTION
* 804 *
* 805 * $ THIS PLANT IS TYPICAL OF THOSE IN LARGE CITIES
* 806 * $ LIKE NEW YORK WHERE THE UTILITY
* 807 * $ FURNISHES STEAM TO THE BUILDING, AND, AS IN MANY OLDER BUILDINGS,
* 808 * $ THE PLANT HAS AN ABSORPTION CHILLER.
* 809 * $ THE INPUT DEMONSTRATES THE USE OF THE ABSORPTION CHILLER
* 810 * $ AS AN ELECTRIC PEAK SHAVING DEVICE THAT TRIES TO HOLD THE ELECTRIC DEMAND
* 811 * $ BELOW 10 MBTUH OR 2930KW.
* 812 *
* 813 * CMPC      =PLANT-EQUIPMENT      TYPE=HERM-CENT-CHLR SIZE=12.5 I-N=2 ..
* 814 *
* 815 * ABSC      =PLANT-EQUIPMENT      TYPE=ABSOR1-CHLR  SIZE=12.5 I-N=1 ..
* 816 *
* 817 * NORMAL-OP =LOAD-ASSIGNMENT      TYPE=COOLING  LOAD-RANGE=25 P-E=CMPC N=2 ..
* 818 *
* 819 * PEAK-OP   =LOAD-ASSIGNMENT      TYPE=COOLING  L-R=25
* 820 *                                     P-E=ABSC  N=1
* 821 *                                     P-E=CMPC  N=1 ..
* 822 *
* 823 * LOAD-MANAGEMENT HEAT-MULTIPLIER=0 COOL-MULTIPLIER=.27
* 824 *                   ELEC-MULTIPLIER=1
* 825 *                   PRED-LOAD-RANGE=10
* 826 *                   LOAD-ASSIGNMENT=(DEFAULT,NORMAL-OP,DEFAULT)
* 827 *                   PRED-LOAD-RANGE=999
* 828 *                   LOAD-ASSIGNMENT=(DEFAULT,PEAK-OP,DEFAULT) ..
* 829 *
* 830 * CTOWER    =PLANT-EQUIPMENT      TYPE=COOLING-TWR SIZE=-999 ..
* 831 *
* 832 *          $ ENERGY COST DESCRIPTION
* 833 *
* 834 * ENERGY-RESOURCE RESOURCE=STEAM ENERGY/UNIT=1000000
* 835 *                   SOURCE-SITE-EFF=.6 UNIT-NAME = MBTU ..
* 836 *
* 837 * ENERGY-RESOURCE RESOURCE=ELECTRICITY ..
* 838 *
* 839 * END ..
* 840 * COMPUTE PLANT ..
* 841 * INPUT ECONOMICS ..

```

EDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993EDL RUN 3

```

* 842 *
* 843 * ECONOMICS-REPORT S=(ES-D,ES-E,ES-F) ..
* 844 *
* 845 *           $ ENERGY CHARGE DESCRIPTION
* 846 *
* 847 * $ THE ELECTRICITY RATE HAS A TIME-OF-DAY SCHEDULE WITH A 12 DOLLARS/KW DEMAND
* 848 * $ CHARGE IN WINTER AND A 15 DOLLARS/KW CHARGE IN SUMMER. IT IS ASSUMED THAT
* 849 * $ THERE IS A SINGLE DEMAND METER AND THAT THE PEAK DEMAND OCCURS DURING
* 850 * $ THE ON-PEAK PERIOD. THERE IS ALSO A RATCHET OF 90% ON THE HIGHEST SUMMER
* 851 * $ PEAK DEMAND AND THE KWH/KW CHARGE IS BASED ON THE BILLING DEMAND RATHER THAN
* 852 * $ THE RECORDED OR MEASURED DEMAND.
* 853 *
* 854 * $ FOR STEAM THERE IS A STRAIGHT UNIFORM CHARGE OF 10 DOLLARS/MBTU.
* 855 * $ HOWEVER THERE IS A MINIMUM MONTHLY CHARGE OF 1000 DOLLARS WHICH APPROXIMATELY
* 856 * $ COVERS THE DOMESTIC HOT WATER USE.
* 857 *
* 858 * STEAM-CHG = UTILITY-RATE RESOURCE=STEAM ENERGY-CHG=10.00
* 859 * MIN-MON-CHGS=(1000) ..
* 860 *
* 861 * ELEC-RATE = UTILITY-RATE RESOURCE = ELECTRICITY
* 862 * BLOCK-CHARGES = (WINTER-OFF-P,WINTER-SHOUL,
* 863 * WINTER-ON-P,SUMMER-OFF-P,
* 864 * SUMMER-SHOUL,SUMMER-ON-P,
* 865 * WINTER-DEMAND,SUMMER-DEMAND)
* 866 * DEMAND-RATCHETS = (SUMMER-RATCH) ..
* 867 *
* 868 * WINTER-OFF-P = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 869 * SCH-FLAG = 1
* 870 * BLOCK1-TYPE = KWH/KW
* 871 * BLOCK1-DATA = (200,.04,0
* 872 * 800,.05,0) ..
* 873 * WINTER-SHOUL = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 874 * SCH-FLAG = 2
* 875 * BLOCK1-TYPE = KWH/KW
* 876 * BLOCK1-DATA = (200,.045,0
* 877 * 800,.055,0) ..
* 878 * WINTER-ON-P = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 879 * SCH-FLAG = 3
* 880 * BLOCK1-TYPE = KWH/KW
* 881 * BLOCK1-DATA = (200,.05,0
* 882 * 800,.06,0) ..
* 883 * WINTER-DEMAND = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 884 * TOU-SEASON-LINKS = (SUMMER-DEMAND)
* 885 * SCH-FLAG = 3
* 886 * BLOCK1-TYPE = DEMAND
* 887 * BLOCK1-DATA = (1.12,00) ..
* 888 *
* 889 * SUMMER-OFF-P = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 890 * SCH-FLAG = 4
* 891 * BLOCK1-TYPE = KWH/KW
* 892 * BLOCK1-DATA = (175,.045,0
* 893 * 800,.055,0) ..
* 894 * SUMMER-SHOUL = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 895 * SCH-FLAG = 5
* 896 * BLOCK1-TYPE = KWH/KW

```

```

* 897 *          BLOCK1-DATA = (175,.055,0
* 898 *          800,.065,0) ..
* 899 * SUMMER-ON-P = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 900 *          SCH-FLAG = 6
* 901 *          BLOCK1-TYPE = KWH/KW
* 902 *          BLOCK1-DATA = (175,.065,0
* 903 *          800,.075,0) ..
* 904 * SUMMER-DEMAND = BLOCK-CHARGE BLOCK-SCH = SEASONS-SCH
* 905 *          TOU-SEASON-LINKS = (WINTER-DEMAND)
* 906 *          SCH-FLAG = 6
* 907 *          BLOCK1-TYPE = DEMAND
* 908 *          BLOCK1-DATA = (1,15.00) ..
* 909 *
* 910 * SUMMER-RATCH = RATCHET          RATCHET-SCH = SUM-RAT-SCH
* 911 *          SCH-FLAG = 1
* 912 *          NUM-MONTHS = 12
* 913 *          FRACTION = .90 ..
* 914 *
* 915 * SUM-RAT-SCH = SCHEDULE          THRU MAY 15 (ALL) (1,24) (0)
* 916 *          THRU SEP 15 (ALL) (1,24) (1)
* 917 *          THRU DEC 31 (ALL) (1,24) (0) ..
* 918 *
* 919 * SEASONS-SCH SCHEDULE THRU MAY 15 (WD) (1,8) (1) (9,12) (2) (13,17) (3)
* 920 *          (18,22) (2) (23,24) (1)
* 921 *          (WEH) (1,8) (1) (9,24) (2)
* 922 *          THRU SEP 15 (WD) (1,8) (4) (9,12) (5) (13,18) (6)
* 923 *          (19,24) (5)
* 924 *          (WEH) (1,6) (4) (9,24) (5)
* 925 *          THRU DEC 31 (WD) (1,8) (1) (9,12) (2) (13,17) (3)
* 926 *          (18,22) (2) (23,24) (1)
* 927 *          (WEH) (1,8) (1) (9,24) (2) ..
* 928 * END ..
* 929 * COMPUTE ECONOMICS ..
* 930 *
* 931 * INPUT LOADS ..

```

REPORT- SV-A SYSTEM DESIGN PARAMETERS

VARVOL

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
VARVOL	VAVS	1.020	620000.0	4402.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	811481.	951.060	3.7	811481.	366.183	1.4	0.111	31849.852	0.674	0.000	0.00	0.37
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
	RZ1	10924.	0.	0.000	0.200	1224.	0.00	0.00	224.16	-589.91	-462.93	1.0
	RZ2	5391.	0.	0.000	0.200	571.	0.00	0.00	110.63	-291.12	-253.78	1.0
	RZ3	1672.	0.	0.000	0.200	265.	0.00	0.00	34.31	-90.28	-88.19	1.0
	RZ4	5348.	0.	0.000	0.200	571.	0.00	0.00	109.74	-288.78	-252.14	1.0
	RZ5	2336.	0.	0.000	0.200	265.	0.00	0.00	47.93	-126.13	-113.29	1.0
	TZ1	10924.	0.	0.000	0.200	1224.	0.00	0.00	224.16	-589.91	-462.93	30.0
	TZ2	5418.	0.	0.000	0.200	571.	0.00	0.00	111.18	-292.57	-254.80	30.0
	TZ3	1627.	0.	0.000	0.200	265.	0.00	0.00	33.39	-87.88	-86.52	30.0
	TZ4	5785.	0.	0.000	0.200	571.	0.00	0.00	118.70	-312.37	-268.66	30.0
	TZ5	2440.	0.	0.000	0.200	265.	0.00	0.00	50.06	-131.73	-117.21	30.0

REPORT- SV-A SYSTEM DESIGN PARAMETERS BASMT-SYS WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE							
BASMT-SYS	SZRH	1.020	20000.0	0.							
SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
27200.	15.649	1.8	0.	0.000	0.0	0.125	948.825	0.721	-1227.298	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
A-STORAGE	27200.	0.	0.000	1.000	3400.	0.00	0.00	558.14	0.00	-1078.16	1.0

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -						- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	836.90778	4 7	2.F	2.F	12960.485	-2872.071	12 7	-6.F	-7.F	-10944.467	458628.	2737.903	
FEB	767.65100	9 16	23.F	19.F	8112.404	-2484.821	9 7	2.F	2.F	-8627.833	432833.	2439.711	
MAR	379.99835	3 15	76.F	65.F	9294.560	-1041.017	24 7	6.F	5.F	-17061.723	447998.	2047.118	
APR	590.44543	28 15	78.F	68.F	12429.391	-130.508	8 7	32.F	29.F	-7332.346	424922.	1839.387	
MAY	587.58905	21 14	85.F	75.F	16181.095	-46.335	10 7	41.F	39.F	-2942.354	407028.	2030.905	
JUN	2132.48633	21 16	82.F	72.F	19492.824	0.000				0.000	477973.	2274.687	
JUL	3399.83398	19 7	78.F	72.F	24591.713	0.000				0.000	489093.	2516.045	
AUG	2978.57129	16 7	73.F	68.F	21840.842	0.000				0.000	490204.	2291.614	
SEP	995.00549	10 16	82.F	70.F	14546.001	-30.382	22 8	34.F	31.F	-2248.202	421892.	1914.044	
OCT	295.05307	5 16	74.F	62.F	9229.723	-81.396	21 7	30.F	29.F	-5844.290	382512.	1705.445	
NOV	139.13741	2 16	77.F	62.F	9285.938	-536.348	15 7	27.F	25.F	-23077.816	382983.	1737.591	
DEC	215.86208	30 16	38.F	33.F	4538.136	-1795.730	13 7	34.F	33.F	-18403.383	412222.	1888.473	
TOTAL	13318.555					-9018.632					5230078.		
MAX					24591.713					-23077.816		2737.903	

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE)

0.000 (KBTU)
 250185.616 (KBTU)

----- C O O L I N G -----						----- H E A T I N G -----						----- E L E C -----	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	836.90778	4 7	2.F	2.F	12960.485	-2838.256	12 7	-6.F	-7.F	-10627.519	431857.	2653.753	
FEB	767.65100	9 16	23.F	19.F	8112.404	-2453.258	9 7	2.F	2.F	-8329.184	407428.	2297.062	
MAR	379.99835	3 15	76.F	65.F	9294.560	-1017.361	24 7	6.F	5.F	-16817.875	419175.	1962.968	
APR	590.44543	28 15	78.F	68.F	12429.391	-124.739	8 7	32.F	29.F	-7332.346	395733.	1739.786	
MAY	586.51184	21 14	85.F	75.F	16023.778	-46.309	10 7	41.F	39.F	-2942.354	380429.	1946.756	
JUN	2123.28296	21 16	82.F	72.F	19347.477	0.000				0.000	448861.	2190.538	
JUL	3367.74121	19 7	78.F	72.F	24591.713	0.000				0.000	461220.	2431.895	
AUG	2953.61230	16 7	73.F	68.F	21840.842	0.000				0.000	461057.	2207.464	
SEP	989.21368	10 16	82.F	70.F	14354.195	-30.359	22 8	34.F	31.F	-2234.634	394055.	1829.895	
OCT	294.33704	5 16	74.F	62.F	9160.113	-81.363	21 7	30.F	29.F	-5844.290	355913.	1606.422	
NOV	138.83478	2 16	77.F	62.F	9200.800	-531.762	15 7	27.F	25.F	-23077.816	356405.	1653.442	
DEC	215.86208	30 16	38.F	33.F	4538.136	-1776.498	13 7	34.F	33.F	-18211.879	384270.	1804.324	
TOTAL	13244.418					-8899.935					4896432.		
MAX					24591.713					-23077.816		2653.753	

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -					- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-33.813	4 7	2.F	2.F	-587.425	11571.	44.149
FEB	0.00000				0.000	-31.562	8 7	5.F	5.F	-355.787	10965.	44.149
MAR	0.00000				0.000	-23.656	1 7	28.F	26.F	-270.999	13145.	44.149
APR	0.00000				0.000	-5.769	19 7	38.F	36.F	-177.284	12469.	44.149
MAY	1.07714	21 13	87.F	76.F	167.358	-0.026	10 8	42.F	40.F	-20.263	11399.	44.149
JUN	9.20262	9 15	83.F	73.F	187.044	0.000				0.000	12391.	44.149
JUL	32.09126	13 17	97.F	78.F	279.431	0.000				0.000	11913.	44.149
AUG	24.95892	26 17	94.F	76.F	271.527	0.000				0.000	12427.	44.149
SEP	5.79182	10 17	83.F	70.F	196.117	-0.023	22 8	34.F	31.F	-13.569	11877.	44.149
OCT	0.71604	4 17	78.F	61.F	88.591	-0.034	1 8	33.F	32.F	-14.381	11399.	44.149
NOV	0.30262	2 16	77.F	62.F	85.139	-4.586	29 7	28.F	27.F	-173.835	11379.	44.149
DEC	0.00000				0.000	-19.233	27 7	31.F	30.F	-246.132	11991.	44.149
TOTAL	74.140					-118.701					142926.	
MAX					279.431					-587.425		44.149

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD
	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL
HEM-CENT-CHLR	12.500	2	2									
ABSOR1-CHLR	12.500	1	1									
COOLING-TWR	12.611	5	5									

MONTH	S I T E E N E R G Y											13	14	SOURCE
	2	3	4	5	6	7	8	9	10	11	12			
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)	
JAN	3244.4	947.1	562.5	0.0	0.0	241.0	85.2	3003.3	18.7	0.0	0.0	5164.1	11167.0	
FEB	2630.0	871.5	534.5	0.0	0.0	25.4	84.8	2604.7	16.9	0.0	0.0	4454.2	9856.4	
MAR	1133.1	456.3	515.0	0.0	0.0	0.0	53.4	1133.1	11.8	0.0	0.0	2890.7	7161.8	
APR	170.0	671.2	495.9	0.0	0.0	0.0	67.4	170.0	3.5	0.0	0.0	1862.5	5361.4	
MAY	158.0	662.4	471.5	0.0	0.0	89.1	63.3	68.9	1.2	0.0	0.0	1767.3	5091.7	
JUN	1156.5	2253.6	609.3	0.0	0.0	1141.3	131.3	15.2	0.0	0.0	0.0	3236.0	8166.7	
JUL	2712.9	3523.9	651.2	0.0	0.0	2699.4	162.2	13.5	0.0	0.0	0.0	4935.6	11190.2	
AUG	1731.2	3108.0	656.8	0.0	0.0	1717.5	166.6	13.7	0.0	0.0	0.0	3972.7	9610.5	
SEP	96.5	1088.0	515.2	0.0	0.0	46.3	92.3	50.2	1.0	0.0	0.0	1854.9	5436.5	
OCT	117.2	366.4	434.9	0.0	0.0	0.0	48.7	117.2	3.6	0.0	0.0	1601.4	4648.2	
NOV	582.3	184.4	415.4	0.0	0.0	0.0	27.3	582.3	5.1	0.0	0.0	2000.0	5224.0	
DEC	1891.9	290.7	471.5	0.0	0.0	0.0	46.3	1891.9	12.9	0.0	0.0	3501.0	7981.0	
TOTAL	15623.9	14423.4	6333.6	0.0	0.0	5959.9	1028.8	9664.0	74.7	0.0	0.0	37240.3	90895.5	

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
STEAM	15624.0	100.0
LOAD SATISFIED	15624.0	100.0
TOTAL LOAD ON PLANT	15623.9	
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HERM-CENT-CHLR	10574.2	73.3
ABSOR1-CHLR	3849.2	26.7
LOAD SATISFIED	14423.4	100.0
TOTAL LOAD ON PLANT	14423.4	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	6333589.0	100.0
LOAD SATISFIED	6333589.0	100.0
TOTAL LOAD ON PLANT	6333653.5	

TOWER ABOVE DESIGN TEMPERATURE OF 85.F 0 HOURS

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	15623.9	15624.0	0.000	0.000	0
COOLING LOADS	14423.4	14423.4	0.000	0.000	0
ELECTRICAL LOADS	21616.6	21616.3	0.000	0.000	0

ENERGY TYPE:	ELECTRICITY	STEAM
UNITS: MBTU		
CATEGORY OF USE		
AREA LIGHTS	10810.3	0.0
MISC EQUIPMT	3997.2	0.0
SPACE HEAT	0.0	9476.8
SPACE COOL	2253.7	5959.9
HEAT REJECT	643.3	0.0
PUMPS & MISC	869.2	0.0
VENT FANS	3042.6	0.0
DOMHOT WATER	0.0	187.2
	-----	-----
TOTAL	21616.3	15624.0

TOTAL SITE ENERGY 37240.27 MBTU 58.2 KBTU/SQFT-YR GROSS-AREA 58.2 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 90895.38 MBTU 142.0 KBTU/SQFT-YR GROSS-AREA 142.0 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 4.3
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
STEAM-CHG	STEAM		15624. MBTU	156275.	10.0022	YES
ELEC-RATE	ELECTRICITY	1 2 3 4 5	6333589. KWH	763611.	0.1206	YES
				919885.		

ENERGY COST/GROSS BLDG AREA: 1.44
 ENERGY COST/NET BLDG AREA: 1.44

31-STORY OFFICE BLDG, CHICAGO - LOAD1 RUN 3 VARIABLE AIR VOLUME SYSTEM DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 3
 REPORT- ES-E SUMMARY OF UTILITY-RATE: OA RESET BASEBOARDS
 STEAM-CHG

UTILITY-RATE: STEAM-CHG RESOURCE: STEAM DEMAND-WINDOW: HOUR 1000000. BTU/MBTU
 METERS: BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY MBTU	BILLING ENERGY MBTU	METERED DEMAND MBTU	BILLING DEMAND MBTU	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	3244	3244	26.9	26.9	32444	0	0	0	0	0	1000	10.0000	32444
FEB	2630	2630	18.1	18.1	26300	0	0	0	0	0	1000	10.0000	26300
MAR	1133	1133	17.2	17.2	11330	0	0	0	0	0	1000	10.0000	11330
APR	170	170	7.5	7.5	1700	0	0	0	0	0	1000	10.0000	1700
MAY	158	158	24.1	24.1	1580	0	0	0	0	0	1000	10.0000	1580
JUN	1157	1157	25.4	25.4	11565	0	0	0	0	0	1000	10.0000	11565
JUL	2713	2713	25.7	25.7	27129	0	0	0	0	0	1000	10.0000	27129
AUG	1731	1731	25.3	25.3	17312	0	0	0	0	0	1000	10.0000	17312
SEP	96	96	23.3	23.3	965	0	0	0	0	0	1000	10.3633	1000
OCT	117	117	6.0	6.0	1172	0	0	0	0	0	1000	10.0000	1172
NOV	582	582	23.2	23.2	5823	0	0	0	0	0	1000	10.0000	5823
DEC	1892	1892	18.6	18.6	18919	0	0	0	0	0	1000	10.0000	18919
TOTAL	15624	15624	26.9		156240	0	0	0	0	0		10.0022	156275

31-STORY OFFICE BLDG, CHICAGO - LOAD1 RUN 3 VARIABLE AIR VOLUME SYSTEM DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 3
 OA RESET BASEBOARDS
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-RATE

UTILITY-RATE: ELEC-RATE RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS		BLOCK-CHARGES		DEMAND-RATCHETS		MIN-MON-RATCHETS	
MIN-ENERGY:	0.0	WINTER-OFF-P		WINTER-DEMAND		SUMMER-RATCH	
MAX-ENERGY:	0.0	WINTER-SHOUL		SUMMER-DEMAND			
MIN-DEMAND:	0.0	WINTER-ON-P					
MAX-DEMAND:	0.0	SUMMER-OFF-P					
QUALIFY-RATE:	ALL-MONTHS	SUMMER-SHOUL					
USE-MIN-QUAL:	NO	SUMMER-ON-P					

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	562481	562481	2955.4	2955.4	26054	35018	0	0	0	0	0	0.1086	61073
FEB	534479	534479	2886.6	2886.6	24789	34639	0	0	0	0	0	0.1112	59427
MAR	514984	514984	2610.9	2766.3	23904	33196	0	0	0	0	0	0.1109	57100
APR	495903	495903	2695.5	2766.3	23104	33196	0	0	0	0	0	0.1135	56300
MAY	471530	471530	2798.0	2798.0	25076	38154	0	0	0	0	0	0.1341	63230
JUN	609299	609299	2812.5	2812.5	35867	41989	0	0	0	0	0	0.1278	77857
JUL	651245	651245	3073.7	3073.7	38112	43938	0	0	0	0	0	0.1260	82050
AUG	656755	656755	2883.4	2883.4	38556	41908	0	0	0	0	0	0.1225	80464
SEP	515203	515203	2805.1	2805.1	27261	37873	0	0	0	0	0	0.1264	65134
OCT	434853	434853	2368.1	2766.3	20224	33196	0	0	0	0	0	0.1228	53420
NOV	415386	415386	2370.1	2766.3	19294	33196	0	0	0	0	0	0.1264	52490
DEC	471472	471472	2296.5	2766.3	21871	33196	0	0	0	0	0	0.1168	55066
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
TOTAL	6333589	6333589	3073.7		324113	439498	0	0	0	0		0.1206	763611

REPORT- ES-F BLOCK-CHARGE AND RATCHET SUMMARY FOR: ELEC-RATE

UTILITY-RATE: ELEC-RATE
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR

WINTER-OFF-P	USE: TIME-OF-USE												
METERED ENERGY:	70971	63626	56737	48206	22322	0	0	0	23773	43839	43962	53418	
BILLING ENERGY:	70971	63626	56737	48206	22322	0	0	0	23773	43839	43962	53418	426854
KWH/KW DEMAND:	2766.3	2766.3	2766.3	2766.3	2766.3	0.0	0.0	0.0	2766.3	2766.3	2766.3	2766.3	
ENERGY CHGS (\$):	2839	2545	2269	1928	893	0	0	0	951	1754	1758	2137	17074
WINTER-SHOUL	USE: TIME-OF-USE												
METERED ENERGY:	272013	259807	255557	241750	108901	0	0	0	124520	216038	207049	233780	
BILLING ENERGY:	272013	259807	255557	241750	108901	0	0	0	124520	216038	207049	233780	1919414
KWH/KW DEMAND:	2955.4	2859.6	2766.3	2766.3	2766.3	0.0	0.0	0.0	2766.3	2766.3	2766.3	2766.3	
ENERGY CHGS (\$):	12241	11691	11500	10879	4901	0	0	0	5603	9722	9317	10520	86374
WINTER-ON-P	USE: TIME-OF-USE												
METERED ENERGY:	219500	211050	202690	205947	89587	0	0	0	107522	174976	164375	184277	
BILLING ENERGY:	219500	211050	202690	205947	89587	0	0	0	107522	174976	164375	184277	1559923
KWH/KW DEMAND:	2918.2	2886.6	2766.3	2766.3	2766.3	0.0	0.0	0.0	2766.3	2766.3	2766.3	2766.3	
ENERGY CHGS (\$):	10975	10552	10135	10297	4479	0	0	0	5376	8749	8219	9214	77996
SUMMER-OFF-P	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	20012	56643	76306	69459	21058	0	0	0	
BILLING ENERGY:	0	0	0	0	20012	56643	76306	69459	21058	0	0	0	243478
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	2766.3	2766.3	2766.3	2766.3	2766.3	0.0	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	901	2549	3434	3126	948	0	0	0	10957
SUMMER-SHOUL	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	109298	260423	269322	274394	110862	0	0	0	
BILLING ENERGY:	0	0	0	0	109298	260423	269322	274394	110862	0	0	0	1024299
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	2766.3	2812.5	3073.7	2883.4	2805.1	0.0	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	6011	14323	14813	15092	6097	0	0	0	56336
SUMMER-ON-P	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	121410	292234	305617	312903	127469	0	0	0	
BILLING ENERGY:	0	0	0	0	121410	292234	305617	312903	127469	0	0	0	1159632
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	2798.0	2799.3	2929.2	2793.8	2791.9	0.0	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	7892	18995	19865	20339	8285	0	0	0	75376
WINTER-DEMAND	USE: TIME-OF-USE												
METERED DEMAND:	2918.2	2886.6	2420.5	2695.5	2249.6	0.0	0.0	0.0	2637.3	2368.1	2370.1	2275.4	
BILLING DEMAND:	2918.2	2886.6	2766.3	2766.3	2798.0	0.0	0.0	0.0	2791.9	2766.3	2766.3	2766.3	
PRORATE FACTOR:	1.0000	1.0000	1.0000	1.0000	0.4545	0.0000	0.0000	0.0000	0.4783	1.0000	1.0000	1.0000	
DEMAND CHGS (\$):	35018	34639	33196	33196	15262	0	0	0	16023	33196	33196	33196	266920
SUMMER-DEMAND	USE: TIME-OF-USE												
METERED DEMAND:	0.0	0.0	0.0	0.0	2798.0	2799.3	2929.2	2793.8	2791.9	0.0	0.0	0.0	
BILLING DEMAND:	0.0	0.0	0.0	0.0	2798.0	2799.3	2929.2	2793.8	2791.9	0.0	0.0	0.0	
PRORATE FACTOR:	0.0000	0.0000	0.0000	0.0000	0.5455	1.0000	1.0000	1.0000	0.5217	0.0000	0.0000	0.0000	
DEMAND CHGS (\$):	0	0	0	0	22892	41989	43938	41908	21850	0	0	0	172577
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====

TOTAL ENERGY:	562484	534482	514984	495903	471530	609299	651245	656755	515204	434853	415386	471475	6333600
TOTAL CHARGES (\$):	61073	59427	57100	56300	63230	77857	82050	80464	65134	53420	52490	55066	763611

31-STORY OFFICE BLDG, CHICAGO - LOAD1 RUN 3 VARIABLE AIR VOLUME SYSTEM
OA RESET BASEBOARDS


DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 3

REPORT- ES-F RATCHET SUMMARY FOR: ELEC-RATE

RATCHETS	TYPE	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
SUMMER-RATCH	HIGHEST	2766.3	2766.3	2766.3	2766.3	2766.3	2766.3	2766.3	2766.3	2766.3	2766.3	2766.3	2766.3

31-Story Office Building, LOAD2

DrawBDL axonometric view of top floor and mid-floor (multiplier = 30) as input into BDL. The roof and interior walls are not shown. For daylighting simulation, each 25-ft-wide bay on the perimeter of all four exposures is input as a separate zone with a multiplier. There are eight bays per floor on the east and west, and four bays per floor on the north and south.



791-8074AA

LDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993LDL RUN 2

```

* 932 * TITLE          LINE-1 *31-STORY OFFICE BLDG, CHICAGO - LOAD2 *
* 933 *                LINE-2 * CUSTOM WEIGHTING FACTORS & DAYLIGHTING *
* 934 *                LINE-3 * * ..
* 935 *
* 936 *                ABORT      ERRORS    ..
* 937 *                DIAGNOSTIC  WARNINGS ..
* 938 *
* 939 *                LOADS-REPORT V=(LV-K)  SUMMARY=(LS-C,LS-D,LS-I) ..
* 940 *                RUN-PERIOD   JAN 1 1988 THRU DEC 31 1988 ..
* 941 *                BUILDING-LOCATION LATITUDE=42 LONGITUDE=88
* 942 *                TIME-ZONE=6  ALTITUDE=610
* 943 *                ATM-MOISTURE=(.36,.32,.40,.53,.76,1.11,1.21,1.12,.88,.66,
* 944 *                .43,.35)
* 945 *                ATM-TURBIDITY=(.15,.18,.21,.18,.18,.19,.22,.16,.16,.14,.13,
* 946 *                .15) ..
* 947 *
* 948 *                $ BUILDING DESCRIPTION
* 949 *
* 950 * $              THIS EXAMPLE HAS THREE SPECIAL FEATURES:
* 951 * $
* 952 * $              1 IT USES CUSTOM WEIGHTING FACTORS FOR THE EXTERIOR ZONES,
* 953 * $              WHICH GIVES A BETTER SIMULATION
* 954 * $              OF BUILDING MASS AND HVAC SYSTEM PERFORMANCE.
* 955 * $              THE INTERIOR ZONES ARE INPUT
* 956 * $              USING STANDARD ASHRAE WEIGHTING FACTORS WITH
* 957 * $              A FLOOR WEIGHT OF 150LB/SQFT TO REPRESENT THE MASS OF ELEVATOR
* 958 * $              SHAFT WALLS, WHICH ARE ASSUMED TO BE HEAVY REINFORCED
* 959 * $              CONSTRUCTION FOR WIND BRACING.
* 960 * $
* 961 * $              2 IT DEMONSTRATES DAYLIGHTING AND ASSOCIATED ELECTRIC LIGHTING
* 962 * $              CONTROLS, EACH 25 FT WIDE BAY ON
* 963 * $              ALL FOUR EXPOSURES IS TREATED AS A SEPARATE ZONE.
* 964 * $              THERE ARE 8 BAYS PER FLOOR ON THE EAST AND WEST EXPOSURES
* 965 * $              AND 4 BAYS PER FLOOR ON THE NORTH AND SOUTH.
* 966 * $
* 967 * $              3 IT DEMONSTRATES HOW DOE-2 INPUT CAN BE SHORTENED BY
* 968 * $              OMITTING U-NAMES FOR EVERY WALL AND FLOOR SURFACE. THIS
* 969 * $              MAKES THE VERIFICATION REPORTS LESS READABLE AS MOST SURFACES
* 970 * $              ARE NOT IDENTIFIED.
* 971 * $              IN ADDITION, AS ANOTHER WAY OF SHORTENING THE INPUT,
* 972 * $              ABBREVIATIONS ARE USED EXTENSIVELY,
* 973 * $              BUT THE FIRST INPUT ENTRY IS WRITTEN USING THE FULL KEYWORD
* 974 * $              FOR CLARIFICATION. EQUAL SIGNS ARE ALSO OMITTED IN MOST
* 975 * $              CASES.
* 976 * $
* 977 * $              NOTE THAT THE FOLLOWING DESCRIPTION IS IDENTICAL TO
* 978 * $              *31-STORY OFFICE BLDG - LOAD1* EXCEPT THAT:
* 979 * $              (1) CEILING PLENUMS HAVE BEEN ADDED;
* 980 * $              (2) DAYLIGHTING IS SPECIFIED; AND
* 981 * $              (3) FOR THE DAYLIGHTING CALCULATION, THE PERIMETER ZONES HAVE BEEN
* 982 * $              DIVIDED INTO INDIVIDUAL ROOMS, SO THAT R22, R24, T22, AND T24
* 983 * $              NOW HAVE MULTIPLIER=8 AND R23,R25,T23, AND T25 HAVE MULTIPLIER=4
* 984 * $              (AS BEFORE, THE T2 ZONES ALSO HAVE FLOOR-MULTIPLIER=30, SO THAT
* 985 * $              THERE ARE 8X30=240 T22 AND T24 ZONES AND 4X30=120 T23 AND T25
* 986 * $              ZONES).

```

* 987 *
 * 988 * \$ STRUCTURE STEEL FRAME WITH 4" CONCRETE FLOORS AND ROOF. 31 OCCUPIED
 * 989 * \$ STORIES. 13FT FLOOR TO FLOOR HEIGHT, 9FT CEILINGS. RETURN
 * 990 * \$ AIR CEILING PLENUMS ARE DEFINED; ONE FOR THE TOP FLOOR AND ONE
 * 991 * \$ FOR THE TYPICAL FLOORS.
 * 992 *
 * 993 * \$ CURTAIN WALL USING CODE-WORDS FROM DOE-2 LIBRARY (REFERENCE MANUAL, PART 2)
 * 994 * \$ AND STARTING WITH OUTSIDE WORKING INWARD; 1/4IN SPANDREL GLASS
 * 995 * \$ (NOT IN LIBRARY - SEE MATERIAL SPGL); 2IN POLYSTYRENE INSUL
 * 996 * \$ R-8 (IN35); STEEL BACKPANEL (AS01); 2IN AIRSPACE (AL21);
 * 997 * \$ 3/4IN GYPSUM BOARD FINISH (GP03) .
 * 998 *
 * 999 * \$ ROOF ROOF GRAVEL (RG02); BUILT-UP ROOFING (BR01); 3IN ROOF INSUL R-8
 * 1000 * \$ (IN76); 4IN CONCRETE (CC03); INSIDE-FILM-RESISTANCE .76 .
 * 1001 *
 * 1002 * \$ WINDOWS DOUBLE-GLAZED TINTED. SOLAR TRANSMITTANCE=.53. GLASS TYPE CODE=5.
 * 1003 * \$ WINDOWS HAVE INSIDE BLINDS THAT ARE PULLED WHENEVER TRANSMITTED
 * 1004 * \$ DIRECT SOLAR RADIATION EXCEEDS 40 BTUH PER SQFT AND IF THE WINDOW
 * 1005 * \$ GLARE INDEX EXCEEDS A VALUE OF 22. THE BLINDS ARE CONSIDERED
 * 1006 * \$ TO BE REOPENED WITH A PROBABILITY OF .4 WHEN SOLAR EFFECT IS LESS
 * 1007 * \$ THAN 40 BTUH.
 * 1008 *
 * 1009 * \$ INTERIORS CEILINGS ARE SUSPENDED ACCOUSTIC TILE.
 * 1010 * \$ PARTITIONS SIMULATE CONVECTIVE HEAT TRANSFER BETWEEN CORE AND
 * 1011 * \$ PERIMETER SPACES USING A U-VALUE OF 1.5.
 * 1012 *
 * 1013 * \$ SPACE LOADS LIGHTING RECESSED FLUORSCENT AT 1.5 WATTS/SQFT.
 * 1014 * \$ OFFICE EQUIPMENT 1 WATTS/SQFT.
 * 1015 * \$ PEOPLE 100SQFT/PERSON FOR PERIMETER SPACES
 * 1016 * \$ 200SQFT/PERSON FOR CORE AREAS.
 * 1017 * \$ INFILTRATION .3 AIR CHANGES/HR FOR PERIMETER AREAS WHEN FANS
 * 1018 * \$ ARE OFF -.06 AIR CHANGES/HR WHEN FANS ARE ON.
 * 1019 *
 * 1020 * \$ HVAC DESCRIPTIONS ARE TO BE FOUND WITH EACH INDIVIDUAL SYSTEM AND PLANT INPUT.
 * 1021 *
 * 1022 * \$ MATERIALS NOT IN DOE-2 LIBRARY
 * 1023 *
 * 1024 * \$ SPGS=MATERIAL TH=.0208 COND=.590 DENS=172. S-H=.20 ..
 * 1025 *
 * 1026 * \$ WALL CONSTRUCTIONS
 * 1027 *
 * 1028 * \$ ROOFER =LAYERS MAT (RG02,BR01,IN76,CC03) 1-F-R .76 ..
 * 1029 * \$ WALLER =LAYERS MAT (SPGS,IN35,AS01,AL21,GP03) ..
 * 1030 * \$ FLR-UP =LAYERS MAT (CP01,CC03) ..
 * 1031 * \$ FLR-DN =LAYERS MAT (CC03,CP01) ..
 * 1032 * \$ PARTITION =LAYERS MAT (GP01,AL21,GP01) ..
 * 1033 *
 * 1034 * \$ RF =CONSTRUCTION LAYERS=ROOFER ..
 * 1035 * \$ WL1 =CONSTRUCTION LAYERS=WALLER ..
 * 1036 * \$ CEIL =CONS U=.20 ..
 * 1037 * \$ FLOOR-ABOVE =CONS LAYERS=FLR-UP ..
 * 1038 * \$ FLOOR =CONS LAYERS=FLR-DN ..
 * 1039 * \$ PA2 =CONS LAYERS =PARTITION ..
 * 1040 * \$ BW =CONSTRUCTION U=.05 ..
 * 1041 * \$ SB-U =CONSTRUCTION U=1.5 ..
 * 1042 *
 * 1043 * \$ GLASS DESCRIPTION
 * 1044 *
 * 1045 * \$ GT1 =GLASS-TYPE GLASS-TYPE-CODE=5 PANES=2 VIS-TRANS=.35 ..
 * 1046 *
 * 1047 * \$ SCHEDULES
 * 1048 *
 * 1049 * \$ OC1 =DAY-SCHEDULE (1,8) (0.) (9,10) (1.)

```

*1050 * (11,13) (.0,.4,.0) (14,24) (1,.1,.1..
*1051 * .3,.1,.1..1.0..0..0..0.) ..
*1052 * OC2 =DAY-SCHEDULE (1,24) (0.0) ..
*1053 * OCCUP =SCHEDULE THRU DEC 31 (WD) OC1 (WEH) OC2 ..
*1054 *
*1055 * L1 =DAY-SCHEDULE (1,6) (.05) (7,24) (.1,.9,.9,
*1056 * .95,.95,.95,.0,.0,.9,.9,.95,.0,.7,.6,
*1057 * .4,.3,.2,.2) ..
*1058 * L2 =DAY-SCHEDULE (1,24) (.05) ..
*1059 * LIGHTS =SCHEDULE THRU DEC 31 (WD) L1 (WEH) L2 ..
*1060 *
*1061 * ES1 =DAY-SCHEDULE (1,8) (0.) (9,20) (.35,.50,
*1062 * .55,.9,.6,.0,.7,.75,.3,.3,.5,.05)
*1063 * (21,24) (0.0) ..
*1064 * ES2 =DAY-SCHEDULE (1,24) (0.0) ..
*1065 * EQUIP =SCHEDULE THRU DEC 31 (WD) ES1 (WEH) ES2 ..
*1066 *
*1067 * I1 =DAY-SCHEDULE (1,7) (1.) (8,18) (0.2)
*1068 * (19,24) (1.) ..
*1069 * I2 =DAY-SCHEDULE (1,24) (1.) ..
*1070 * INFIL =SCHEDULE THRU DEC 31 (WD) I1 (WEH) I2 ..
*1071 *
*1072 * SHADE-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.75) ..
*1073 * TRANS-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.35) ..
*1074 * COND-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.9) ..
*1075 * CLOSE-SHADE =SCHEDULE THRU DEC 31 (ALL) (1,24) (40) ..
*1076 * REOPEN-PROB =SCHEDULE THRU DEC 31 (ALL) (1,24) (.5) ..
*1077 *
*1078 * $ SPACE DESCRIPTIONS
*1079 *
*1080 * OFFICE =SPACE-CONDITIONS TEMPERATURE=(75) FLOOR-WEIGHT=0 $ FOR CWF
*1081 * LIGHTING-W/SQFT=1.5 EQUIPMENT-W/SQFT=1
*1082 * PEOPLE-HEAT-GAIN=450
*1083 * EQUIP-SCHEDULE=EQUIP L-SCH=LIGHTS
*1084 * PEOPLE-SCHEDULE=OCCUP AIR-CHANGES/HR=.5
*1085 * INF-SCHEDULE=INFIL LIGHT-TO-SPACE=.80
*1086 * INF-METHOD=AIR-CHANGE
*1087 * LIGHTING-TYPE=REC-FLUOR-RV ..
*1088 *
*1089 * A-STORAGE =SPACE TEMPERATURE=(75) FLOOR-WEIGHT=150
*1090 * VOLUME=400000 AREA=20000
*1091 * LIGHTING-W/SQFT=1.5
*1092 * LIGHTING-SCHEDULE=LIGHTS ..
*1093 * UNDERGROUND-WALL AREA=12000 CONSTRUCTION=BW ..
*1094 * UNDERGROUND-FLOOR AREA=20000 CONSTRUCTION=BW ..
*1095 *
*1096 * SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=9. AZIMUTH=180 ..
*1097 * SET-DEFAULT FOR WINDOW HEIGHT=6.5 GLASS-TYPE=GT1
*1098 * MAX-SOLAR-SCH=CLOSE-SHADE
*1099 * WIN-SHADE-TYPE=MOVABLE-INTERIOR
*1100 * SHADING-SCHEDULE=SHADE-MULT
*1101 * CONDUCT-SCHEDULE=COND-MULT
*1102 * VIS-TRANS-SCH=TRANS-MULT
*1103 * OPEN-SHADE-SCH=REOPEN-PROB
*1104 * SUN-CTRL-PROB=.7 ..
*1105 *
*1106 * RZ1 SPACE SPACE-CONDITIONS OFFICE VOLUME 107100 AREA 11900
*1107 * X 15 Y 15 Z 390 N-O-P 60 AIR-CHANGES/HR 0.01
*1108 * F-W 150 ..
*1109 * IN1 I-W AREA 191 CONS SB-U' NEXT-TO R22 ..
*1110 * IN2 I-W AREA 158 CONS SB-U N-T R23 ..
*1111 * I-W LIKE IN1 N-T R24 ..
*1112 * I-W LIKE IN2 N-T R25 ..

```

```

*1113 *      CL1  I-W  AREA 11900  CONS CEIL TILT 0  NEXT-TO PLEN1  ..
*1114 *
*1115 * R22      SPACE  S-C OFFICE  A 346.8  V 3114  N-O-P 4  M 8
*1116 *          AZ -90  X 100  Y 87.5  Z 390
*1117 *          DAYLIGHTING YES  LIGHT-REF-POINT1 (12.5,9,2.5)
*1118 *          LIGHT-SET-POINT1 50  LIGHT-CTRL-TYPE1 CONTINUOUS
*1119 *          MAX-GLARE 22  ..
*1120 *      CU1   E-W  H 9  W 25  CONS WL1  .. $ EAST-FACING
*1121 *
*1122 * $ FOR CU1, NOTE THAT THE SUM OF BUILDING AZIMUTH (0) + SPACE AZIMUTH (-90)
*1123 * $ + WALL AZIMUTH (180, FROM SET-DEFAULT) = 90, SO THIS WALL FACES EAST
*1124 *
*1125 *          W1   WI  W 25  Y 2.5  ..
*1126 *      IN3  I-W  A 125  CONS PA2  I-W-TYPE ADIABATIC  ..
*1127 *      IN4  I-W  LIKE IN3  ..
*1128 *      FL1  I-W  A 347  CONS FLOOR TILT 180  I-W-TYPE ADIABATIC  ..
*1129 *      CL2  I-W  A 347  CONS CEIL  TILT 0  NEXT-TO PLEN1  ..
*1130 *
*1131 * R23      SPACE  LIKE R22  A 319  V 2869  AZ 180  X 62.5  Y 200  M 4  ..
*1132 *          E-W  LIKE CU1  .. WI LIKE W1  .. $ NORTH-FACING
*1133 *          I-W  LIKE IN3  .. I-W LIKE IN3  ..
*1134 *          I-W  LIKE FL1  .. I-W LIKE CL2  ..
*1135 *
*1136 * R24      SPACE  LIKE R22  AZ 90  X 0  Y 112.5  M 8  ..
*1137 *          E-W  LIKE CU1  .. WI LIKE W1  .. $ WEST-FACING
*1138 *          I-W  LIKE IN3  .. I-W LIKE IN3  ..
*1139 *          I-W  LIKE FL1  .. I-W LIKE CL2  ..
*1140 *
*1141 * R25      SPACE  LIKE R23  AZ 0  X 37.5  Y 0  M 4  ..
*1142 *          E-W  LIKE CU1  .. WI LIKE W1  .. $ SOUTH-FACING
*1143 *          I-W  LIKE IN3  .. I-W LIKE IN3  ..
*1144 *          I-W  LIKE FL1  .. I-W LIKE CL2  ..
*1145 *
*1146 * PLEN1    SPACE  ZONE-TYPE PLENUM T=(75) A 20000  V 60000  F-W 0
*1147 *          Z 399  ..
*1148 *      EW3  E-W  H 4  W 100  AZ 0  X 100  Y 200  CONS WL1  ..
*1149 *      EW4  E-W  LIKE EW3  W 200  AZ 90  X 100  Y 0  ..
*1150 *      EW5  E-W  LIKE EW3  AZ 180  X 0  Y 0  ..
*1151 *      EW4  E-W  LIKE EW2  AZ 270  X 0  Y 200  ..
*1152 *      ROOF H 200  W 100  AZ 180  TILT 0  CONS RF  G-R 0  ..
*1153 *
*1154 * T21      SPACE  LIKE R21  FLOOR-MULTIPLIER 30  Z 195  ..
*1155 *          I-W  LIKE IN1  N-T T22  ..
*1156 *          I-W  LIKE IN2  N-T T23  ..
*1157 *          I-W  LIKE IN1  N-T T24  ..
*1158 *          I-W  LIKE IN2  N-T T25  ..
*1159 *          I-W  LIKE CL1  N-T PLEN2  ..
*1160 *
*1161 * T22      SPACE  LIKE R22  F-M 30  Z 195  ..
*1162 *          E-W  LIKE CU1  .. WI LIKE W1  ..
*1163 *          I-W  LIKE IN3  .. I-W LIKE IN3  ..
*1164 *          I-W  LIKE FL1  ..
*1165 *      CL3  I-W  LIKE CL2  NEXT-TO PLEN2  ..
*1166 *
*1167 * T23      SPACE  LIKE R23  F-M 30  Z 195  ..
*1168 *          E-W  LIKE CU1  .. WI LIKE W1  ..
*1169 *          I-W  LIKE IN3  .. I-W LIKE IN3  ..
*1170 *          I-W  LIKE FL1  .. I-W LIKE CL3  ..
*1171 *
*1172 * T24      SPACE  LIKE R24  F-M 30  Z 195  ..
*1173 *          E-W  LIKE CU1  .. WI LIKE W1  ..
*1174 *          I-W  LIKE IN3  .. I-W LIKE IN3  ..
*1175 *          I-W  LIKE FL1  .. I-W LIKE CL3  ..

```

```

*1176 *
*1177 * T25      SPACE  LIKE R25  F-M 30  2 195  ..
*1178 *          E-W   LIKE CU1  ..  WI  LIKE W1  ..
*1179 *          I-W   LIKE IN3  ..  I-W LIKE IN3  ..
*1180 *          I-W   LIKE FL1  ..  I-W LIKE CL3  ..
*1181 *
*1182 * PLEN2    SPACE  LIKE PLEN1 F-M 30  2 204  ..
*1183 *          E-W   LIKE EW3  ..
*1184 *          E-W   LIKE EW2  ..
*1185 *          E-W   LIKE EW5  ..
*1186 *          E-W   LIKE EW4  ..
*1187 *          I-W   A 20000  CONS FLOOR-ABOVE I-W-TYPE ADIABATIC TILT 0 ..
*1188 *
*1189 * END  ..

```

REPORT- LV-K WEIGHTING FACTOR SUMMARY

SP NAME-- WF NAME--	A-STORAGE	RZ1	RZ2	RZ3	RZ4	RZ5	PLEN1
SOLAR							
V0	0.17292	0.17292	0.59119	0.59119	0.59119	0.59119	0.42502
V1	-0.11227	-0.11227	-0.46877	-0.46877	-0.46877	-0.46877	-0.47226
V2	0.00000	0.00000	0.07832	0.07832	0.07832	0.07832	0.09427
W1	0.93935	0.93935	0.97737	0.97737	0.97737	0.97737	1.22661
W2	0.00000	0.00000	-0.21427	-0.21427	-0.21427	-0.21427	-0.27852
GENERAL LIGHTING							
V0	0.51215	0.57446	0.79045	0.79045	0.79045	0.79045	0.36633
V1	-0.45150	-0.51380	-0.69610	-0.69610	-0.69610	-0.69610	-0.38993
V2	0.00000	0.00000	0.12995	0.12995	0.12995	0.12995	0.07147
W1	0.93935	0.93935	0.96337	0.96337	0.96337	0.96337	1.21206
W2	0.00000	0.00000	-0.20454	-0.20454	-0.20454	-0.20454	-0.26546
TASK LIGHTING							
V0	0.48093	0.48093	0.74783	0.74783	0.74783	0.74783	0.55009
V1	-0.42028	-0.42028	-0.64174	-0.64174	-0.64174	-0.64174	-0.62835
V2	0.00000	0.00000	0.11478	0.11478	0.11478	0.11478	0.12772
W1	0.93935	0.93935	0.96337	0.96337	0.96337	0.96337	1.21206
W2	0.00000	0.00000	-0.20455	-0.20455	-0.20455	-0.20455	-0.26546
PEOPLE-EQUIPMENT							
V0	0.67521	0.67521	0.75138	0.75138	0.75138	0.75138	0.55643
V1	-0.61455	-0.61455	-0.64627	-0.64627	-0.64627	-0.64627	-0.63657
V2	0.00000	0.00000	0.11604	0.11604	0.11604	0.11604	0.12966
W1	0.93935	0.93935	0.96337	0.96337	0.96337	0.96337	1.21206
W2	0.00000	0.00000	-0.20454	-0.20454	-0.20454	-0.20454	-0.26546
CONDUCTION							
V0	0.67521	0.67521	0.78261	0.78261	0.78261	0.78261	0.59074
V1	-0.61455	-0.61455	-0.68610	-0.68610	-0.68610	-0.68610	-0.68108
V2	0.00000	0.00000	0.12716	0.12716	0.12716	0.12716	0.14017
W1	0.93935	0.93935	0.96337	0.96337	0.96337	0.96337	1.21206
W2	0.00000	0.00000	-0.20455	-0.20455	-0.20455	-0.20455	-0.26546
AIR TEMP (BTU/HR-SQFT-F)							
G0*	1.84393	1.84393	0.45493	0.49458	0.45493	0.49458	0.52949
G1*	-1.99232	-1.99232	-0.63965	-0.69540	-0.63965	-0.69540	-0.71934
G2*	0.14838	0.14838	0.18417	0.20022	0.18417	0.20022	0.19022
G3*	0.00000	0.00000	0.00055	0.00060	0.00055	0.00060	-0.00036
P1	-0.93935	-0.93935	-0.93751	-0.93751	-0.93751	-0.93751	-1.25344
P2	0.00000	0.00000	0.18959	0.18959	0.18959	0.18959	0.30344

REPORT- LV-K WEIGHTING FACTOR SUMMARY

----- (CONTINUED) -----

SP NAME-- WF NAME--	TZ1	TZ2	TZ3	TZ4	TZ5	PLEN2
SOLAR						
V0	0.17292	0.59119	0.59119	0.59119	0.59119	0.43979
V1	-0.11227	-0.46877	-0.46877	-0.46877	-0.46877	-0.46752
V2	0.00000	0.07832	0.07832	0.07832	0.07832	0.08778
W1	0.93935	0.97737	0.97737	0.97737	0.97737	1.19684
W2	0.00000	-0.21427	-0.21427	-0.21427	-0.21427	-0.25739
GENERAL LIGHTING						
V0	0.57446	0.79045	0.79045	0.79045	0.79045	0.38260
V1	-0.51380	-0.69610	-0.69610	-0.69610	-0.69610	-0.38594
V2	0.00000	0.12995	0.12995	0.12995	0.12995	0.06530
W1	0.93935	0.96337	0.96337	0.96337	0.96337	1.17820
W2	0.00000	-0.20454	-0.20454	-0.20454	-0.20454	-0.24075
TASK LIGHTING						
V0	0.48093	0.74783	0.74783	0.74783	0.74783	0.56165
V1	-0.42028	-0.64174	-0.64174	-0.64174	-0.64174	-0.61570
V2	0.00000	0.11478	0.11478	0.11478	0.11478	0.11618
W1	0.93935	0.96337	0.96337	0.96337	0.96337	1.17820
W2	0.00000	-0.20455	-0.20455	-0.20455	-0.20455	-0.24075
PEOPLE-EQUIPMENT						
V0	0.67521	0.75138	0.75138	0.75138	0.75138	0.56782
V1	-0.61455	-0.64627	-0.64627	-0.64627	-0.64627	-0.62362
V2	0.00000	0.11604	0.11604	0.11604	0.11604	0.11793
W1	0.93935	0.96337	0.96337	0.96337	0.96337	1.17820
W2	0.00000	-0.20454	-0.20454	-0.20454	-0.20454	-0.24075
CONDUCTION						
V0	0.67521	0.78261	0.78261	0.78261	0.78261	0.62211
V1	-0.61455	-0.68610	-0.68610	-0.68610	-0.68610	-0.69328
V2	0.00000	0.12716	0.12716	0.12716	0.12716	0.13336
W1	0.93935	0.96337	0.96337	0.96337	0.96337	1.17820
W2	0.00000	-0.20455	-0.20455	-0.20455	-0.20455	-0.24075
AIR TEMP (BTU/HR-SQFT-F)						
G0*	1.84393	0.45493	0.49458	0.45493	0.49458	0.73939
G1*	-1.99232	-0.63965	-0.69540	-0.63965	-0.69540	-0.98453
G2*	0.14838	0.18417	0.20022	0.18417	0.20022	0.24567
G3*	0.00000	0.00055	0.00060	0.00055	0.00060	-0.00053
P1	-0.93935	-0.93751	-0.93751	-0.93751	-0.93751	-1.22491
P2	0.00000	0.18959	0.18959	0.18959	0.18959	0.28319

*1190 * COMPUTE LOADS ..
*1191 * INPUT SYSTEMS ..

*** BUILDING ***

FLOOR AREA 640025 SQFT 59458 SQMT
 VOLUME 7836156 CUFT 221920 CUMT

TIME	COOLING LOAD		HEATING LOAD	
	JUL 13	4PM	JAN 12	3AM
DRY-BULB TEMP	97F	36C	1F	-17C
WET-BULB TEMP	77F	25C	0F	-18C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	129.241	37.868	0.000	0.000	-286.874	-84.054
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	1894.288	555.026	0.000	0.000	-4087.626	-1197.674
WINDOW GLASS SOLAR	4445.044	1302.398	0.000	0.000	3.298	0.966
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-17.600	-5.157	0.000	0.000	-56.000	-16.408
OCCUPANTS TO SPACE	1116.352	327.091	857.121	251.136	1.650	0.483
LIGHT TO SPACE	1457.277	426.982	0.000	0.000	81.580	23.903
EQUIPMENT TO SPACE	1344.543	393.951	0.000	0.000	2.232	0.654
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	150.299	44.038	192.850	56.505	-2480.536	-726.797
TOTAL	10519.444	3082.197	1049.971	307.642	-6822.276	-1998.927
TOTAL LOAD	11569.416 KBTU/H	3389.839 KW			-6822.276 KBTU/H	-1998.927 KW
TOTAL LOAD / AREA	18.08BTU/H.SQFT	57.010 W /SQMT			10.659BTU/H.SQFT	33.618 W /SQMT

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 * *****

C O O L I N G						H E A T I N G						E L E C	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	808.21442	25 15	47.F	42.F	6024.511	-1819.494	12 3	1.F	0.F	-6822.276	300281.	1349.438	
FEB	834.27246	25 16	27.F	22.F	6864.054	-1661.532	4 6	7.F	6.F	-6257.168	277062.	1333.500	
MAR	1159.44556	3 15	76.F	65.F	7450.762	-1311.005	24 5	9.F	8.F	-6681.700	324199.	1251.543	
APR	1638.80640	27 15	82.F	61.F	9119.307	-764.648	8 6	32.F	29.F	-5164.872	303483.	1222.188	
MAY	1841.75269	20 14	76.F	67.F	9513.387	-522.187	6 3	38.F	35.F	-3994.568	276221.	1219.561	
JUN	2304.76953	4 15	85.F	67.F	10225.854	-236.597	22 23	54.F	48.F	-2229.502	297458.	1219.561	
JUL	2695.18799	13 15	97.F	77.F	10519.444	-88.570	23 5	61.F	60.F	-1275.956	286591.	1219.561	
AUG	2396.09668	19 15	90.F	71.F	10285.552	-130.676	5 5	55.F	54.F	-1372.005	301370.	1219.561	
SEP	1881.36218	17 15	82.F	66.F	9826.906	-421.772	29 6	46.F	44.F	-3444.435	294181.	1221.081	
OCT	1372.15564	22 15	70.F	55.F	8202.183	-697.232	2 4	31.F	28.F	-3799.418	289995.	1289.510	
NOV	962.80908	8 15	60.F	49.F	8115.301	-1284.995	15 3	26.F	25.F	-5110.487	296965.	1325.629	
DEC	782.75873	10 15	41.F	35.F	6606.250	-1720.530	8 20	18.F	16.F	-5292.845	316174.	1362.779	
TOTAL	18677.631					-10659.238					3563981.		
MAX					10519.444					-6822.276		1362.779	

*** BUILDING ***

MONTH	HOUR OF DAY																								ALL HOURS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
JAN	0	0	0	0	0	0	0	1	9	16	18	18	18	18	16	11	1	0	0	0	0	0	0	0	9
FEB	0	0	0	0	0	0	0	6	15	17	18	18	18	18	16	9	0	0	0	0	0	0	0	0	11
MAR	0	0	0	0	0	0	4	14	19	19	19	19	19	18	19	18	15	3	0	0	0	0	0	0	13
APR	0	0	0	0	0	2	14	18	18	19	19	19	19	19	18	18	18	10	0	0	0	0	0	0	14
MAY	0	0	0	0	0	10	18	18	19	19	19	19	19	19	19	19	19	15	4	0	0	0	0	0	15
JUN	0	0	0	0	1	13	18	19	19	19	19	19	19	19	19	19	18	18	10	0	0	0	0	0	16
JUL	0	0	0	0	0	11	18	19	19	19	19	19	19	19	19	18	18	18	10	0	0	0	0	0	16
AUG	0	0	0	0	0	4	16	19	18	19	19	19	19	19	19	19	19	15	3	0	0	0	0	0	15
SEP	0	0	0	0	0	0	11	18	18	19	19	19	18	18	19	18	15	5	0	0	0	0	0	0	14
OCT	0	0	0	0	0	0	4	14	18	18	18	18	18	17	18	15	6	0	0	0	0	0	0	0	12
NOV	0	0	0	0	0	0	0	8	14	18	18	18	18	18	15	8	0	0	0	0	0	0	0	0	9
DEC	0	0	0	0	0	0	0	1	9	15	18	18	18	18	13	6	0	0	0	0	0	0	0	0	8
ANNUAL	0	0	0	0	0	4	13	13	16	18	19	18	18	18	18	16	11	7	2	0	0	0	0	0	13

NOTE- THE ENTRIES IN THIS REPORT ARE NOT
 SUBJECT TO THE DAYLIGHTING REPORT SCHEDULE

31-Story Office Building, LOAD2 — Run 4 Systems, Plant, Economics

SDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993SDL RUN 4

```

*1192 * TITLE LINE-2 * RUN 4 - FOUR PIPE FANCOIL PERIMETER *
*1193 * LINE-4 * VAR TEMP SINGLE ZONE INTERIOR * ..
*1194 *
*1195 *           $ HVAC SYSTEM DESCRIPTION
*1196 *
*1197 * $ DESIGN TEMPS COOLING 76F HEATING 70F
*1198 * $ SYSTEM TYPE A TYPICAL FOUR PIPE FANCOIL SYSTEM SERVES THE PERIMETER ZONES.
*1199 * $ THE INTERIOR IS SERVED BY A VARIABLE TEMPERATURE CONSTANT VOLUME
*1200 * $ AIR HANDLING UNIT WHICH SUPPLIES OUTSIDE AIR VENTILATION OF
*1201 * $ 20 CFM/PERSON FOR THE ENTIRE BUILDING (INCLUDING PERIMETER).
*1202 * $ THE INTERIOR SYSTEM IS CONTROLLED TO SATISFY THE TYPICAL CORE
*1203 * $ AREA BUT THERE IS A REHEAT COIL ON THE TOP FLOOR TO HANDLE
*1204 * $ THE ROOF LOAD. THE MINIMUM OUTSIDE AIR DAMPER IS HELD CLOSED
*1205 * $ UNTIL 8AM WHICH IS THE POINT OF OCCUPANCY EVEN THOUGH FANS START
*1206 * $ AT 7AM. FANS CAN START AS EARLY AS 5AM WHEN NECESSARY TO PICK
*1207 * $ UP THE MORNING START-UP LOADS. THE LOW-LIMIT SETPOINT IS 55F
*1208 * $ NIGHTS AND WEEKENDS BUT ONLY THE FANCOIL UNITS ARE OPERATIVE.
*1209 *
*1210 *
*1211 * SYSTEMS-REPORT S (SS-A,SS-D,SS-J) ..
*1212 *
*1213 * FANSON SCH THRU DEC 31 (WD) (1,5)(0) (6,7)(-999) (8,18)(1) (19,24) (0)
*1214 * (WEH) (1,24) (0) ..
*1215 *
*1216 * HEAT-SETPT SCH THRU DEC 31 (WD) (1,7) (55) (8,18) (70) (19,24) (55)
*1217 * (WEH) (1,24) (55) ..
*1218 * COOL-SETPT SCH THRU DEC 31 (WD) (1,7) (99) (8,18) (76) (19,24) (99)
*1219 * (WEH) (1,24) (99) ..
*1220 *
*1221 * HEATON SCH THRU DEC 31 (ALL) (1,24) (65) ..
*1222 *
*1223 * OA-DAMP-POS SCH THRU DEC 31 (ALL) (1,8) (.01) (9,18) (-999) (19,24) (.01) ..
*1224 *
*1225 * ENV ZONE-CONTROL D-H-T 70 D-C-T 74 H-T-SCH HEAT-SETPT C-T-SCH COOL-SETPT ..
*1226 *
*1227 * RZ1 Z Z-C ENV OUTSIDE-AIR-CFM 2500 SIZING-OPTION ADJUST-LOADS
*1228 * CFM/SQFT .9 ..
*1229 * RZ2 Z LIKE RZ1 O-A-CFM 28 ..
*1230 * RZ3 Z LIKE RZ2 O-A-CFM 28 ..
*1231 * RZ4 Z LIKE RZ2 O-A-CFM 28 ..
*1232 * RZ5 Z LIKE RZ2 O-A-CFM 28 ..
*1233 * TZ1 Z Z-C ENV O-A-CFM 2500 CFM/SQFT .9 ..
*1234 * TZ2 Z LIKE RZ2 ..
*1235 * TZ3 Z LIKE RZ3 ..
*1236 * TZ4 Z LIKE RZ4 ..
*1237 * TZ5 Z LIKE RZ5 ..
*1238 * PLEN1 Z Z-TYPE PLENUM S-O ADJUST-LOADS D-H-T 50 D-C-T 90 ..
*1239 * PLEN2 Z Z-TYPE PLENUM ..
*1240 * A-STORAGE Z LIKE RZ1 AIR-CHANGES/HR 4 ..
*1241 *
*1242 *
*1243 * CORESYS SYSTEM S-TYPE SZRH MAX-S-T 105 MIN-S-T 55 SUPPLY-STATIC 4.0
*1244 * SUPPLY-EFF .55 F-SCH FANSON H-SCH HEATON
*1245 * MIN-AIR-SCH OA-DAMP-POS REHEAT-DELTA-T 30
*1246 * ECONO-LIMIT-T 68 ECONO-LOW-LIMIT 45
    
```

```

*1247 *          RETURN-AIR-PATH PLENUM-ZONES  RETURN-STATIC 1.5  R-E .50
*1248 *          PLENUM-NAMES (PLEN1,PLEN2) 2-N (T21,RZ1,PLEN1,PLEN2,
*1249 *          A-STORAGE) ..
*1250 * FANCOIL SYSTEM S-TYPE FPFC MAX-SUPPLY-T 105 MIN-SUPPLY-T 60
*1251 *          N-C-C CYCLE-ON-ANY F-SCH FANSON H-SCH HEATON
*1252 *          SUPPLY-STATIC .20 SUPPLY-EFF .20
*1253 *          OA-FROM-SYSTEM = CORESYS $OUTSIDE AIR OF CORESYS
*1254 *          $MUST EXCEED FANCOIL UNITS
*1255 *          2-N (RZ2,RZ3,RZ4,RZ5,T22,T23,T24,T25) ..
*1256 *
*1257 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (CORESYS,FANCOIL)
*1258 *          INT-ELEC-KW = 100 $ FOR ELEVATORS
*1259 *          INT-ELEC-SCH = OCCUP
*1260 *          DHW-SIZE=0
*1261 *          DHW-GAL/MIN = 2.22
*1262 *          DHW-SCH = OCCUP ..
*1263 *
*1264 * OC1          =DAY-SCHEDULE      (1,8) (0.)      (9,10) (1.)
*1265 *          (11,13) (.8,.4,.8) (14,24) (1.,1.,1.,
*1266 *          .3.,1.,1.,1,0.,0.,0.,0.) ..
*1267 * OC2          =DAY-SCHEDULE      (1,24) (0.0) ..
*1268 * PEOPLE       =WEEK-SCHEDULE     (MON,FRI) OC1 (WEH) OC2 ..
*1269 * OCCUP        =SCHEDULE          THRU DEC 31 PEOPLE ..
*1270 * END ..
*1271 * COMPUTE SYSTEMS ..
*1272 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993PDL RUN 4

```

*1273 * PLANT1 = PLANT-ASSIGNMENT ..
*1274 *
*1275 *           $ PLANT DESCRIPTION
*1276 *
*1277 * $ MECHANICAL COOLING IS AVAILABLE YEAR-ROUND FROM A HEAT
*1278 * $ RECOVERY PLANT USING A DOUBLE BUNDLE CHILLER BASE LOADED IN WINTER.
*1279 * $ HEAT RECOVERED FROM THE DOUBLE BUNDLE CHILLER IS STORED IN A HOT WATER TANK
*1280 * $ AND USED FOR MORNING START UP.
*1281 * $ TWO STANDARD CENTRIFUGAL CHILLERS ARE BASE LOADED IN SUMMER WITH THE DOUBLE
*1282 * $ BUNDLE CHILLER OFF. THE GAS FIRED HOT WATER GENERATOR CAN SUPPLEMENT THE
*1283 * $ DOUBLE BUNDLE IF NECESSARY BUT IT CANNOT CHARGE THE STORAGE TANK.
*1284 *
*1285 * PLANT-REPORT S (PS-A,BEPS) ..
*1286 *
*1287 * CMPC P-E TYPE HERM-CENT-CHLR SIZE 7.8 I-N 2 ..
*1288 * HWG P-E TYPE HW-BOILER SIZE 17 I-N 1 ..
*1289 * DHH P-E TYPE DHW-HEATER SIZE .1 ..
*1290 * RCVY P-E TYPE DBUN-CHLR SIZE 10 I-N 1 ..
*1291 * STOR P-E TYPE HTANK-STORAGE SIZE 20 I-N 1 ..
*1292 *
*1293 * HEAT-RECOVERY SUPPLY-1 (DBUN-CHLR,HTANK-STORAGE)
*1294 * DEMAND-1 (SPACE-HEAT)
*1295 * SUPPLY-2 (DBUN-CHLR)
*1296 * DEMAND-2 (HTANK-STORAGE) ..
*1297 *
*1298 * ENERGY-STORAGE HEAT-STORE-RATE 10 HEAT-SUPPLY-RATE 12
*1299 * HTANK-T-RANGE 10 HTANK-LOSS-COEF 400
*1300 * HTANK-ENV-T 65 HEAT-STORE-SCH ALWAYS ..
*1301 *
*1302 * ALWAYS SCH THRU DEC 31 (ALL) (1,24) (1) ..
*1303 *
*1304 * PLANT-PARAMETERS CCIRC-PUMP-TYPE VARIABLE-SPEED
*1305 * HCIRC-PUMP-TYPE FIXED-SPEED DBUN-MIN-HEAT .8 ..
*1306 *
*1307 * WIN-HEAT LOAD-ASSIGNMENT TYPE HEATING L-R 99
*1308 * P-E STOR N 1
*1309 * P-E HWG N 1 ..
*1310 *
*1311 * HT2 DAY-ASSIGN-SCH (1,24) (WIN-HEAT) ..
*1312 * HEAT-CTRL SCHEDULE THRU DEC 31 (ALL) HT2 ..
*1313 *
*1314 * WINTER-OP LOAD-ASSIGNMENT TYPE COOLING L-R 99
*1315 * P-E RCVY N 1
*1316 * P-E CMPC N 1 ..
*1317 *
*1318 * SUMMER-OP LOAD-ASSIGNMENT TYPE COOLING L-R 99
*1319 * P-E CMPC N 2 ..
*1320 *
*1321 * C1 DAY-ASSIGN-SCH (1,24) (WINTER-OP) ..
*1322 * C2 DAY-ASSIGN-SCH (1,24) (SUMMER-OP) ..
*1323 * CHLR-CTRL SCHEDULE THRU MAY 15 (ALL) C1
*1324 * THRU SEP 15 (ALL) C2
*1325 * THRU DEC 31 (ALL) C1 ..
*1326 *
*1327 * LOAD-MANAGEMENT PRED-LOAD-RANGE 999

```

*1328 * ASSIGN-SCHEDULE (HEAT-CTRL,CHLR-CTRL,DEFAULT) ..
*1329 *
*1330 * END ..
*1331 * COMPUTE PLANT ..
*1332 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993EDL RUN 4

```

*1333 *
*1334 *           $ ENERGY CHARGE DESCRIPTION
*1335 *
*1336 * $ THE ELECTRIC UTILITY RATE CONSISTES OF A BLOCK CHARGE WITH A RATE CHANGE
*1337 * $ BASED ON THE DEMAND BEING ABOVE OR BELOW 2400KW, PLUS A
*1338 * $ UNIFORM DEMAND CHARGE. HOWEVER, BECAUSE THE BUILDING HAS A POOR POWER
*1339 * $ FACTOR, THE UTILITY HAS LEVIED AN EXCESS KVAR FRACTION OF .2 SINCE IT
*1340 * $ HAS BEEN DETERMINED THAT THE POWER FACTOR IS ONLY .79, WHEREAS THIS TYPE OF
*1341 * $ BUILDING SHOULD BE OPERATING AT WITH A POWER FACTOR OF 0.9. THERE IS
*1342 * $ RATCHET OF .9 BASED ON THE AVERAGE OF THE THREE HIGHEST PEAKS THAT OCCUR
*1343 * $ DURING THE YEAR.
*1344 *
*1345 * $ THE GAS UTILITY CHARGES ARE BASED ON A RATE OF 55 CENTS/THERM IF THE
*1346 * $ MONTHLY DEMAND IS LESS THAN 110 THERMS/HR AND 70 CENTS WHEN IT IS OVER THAT.
*1347 *
*1348 *
*1349 * ECONOMICS-REPORT S=(ES-D,ES-E,ES-F) ..
*1350 *
*1351 * <THAN-2000KW = UTILITY-RATE RESOURCE = ELECTRICITY
*1352 *           DEMAND-CHGS = (10)
*1353 *           RATE-LIMITATION = .10
*1354 *           DEMAND-QUALS = (0,2400)
*1355 *           QUALIFY-RATE = MONTH-BY-MONTH
*1356 *           BLOCK-CHARGES = (HIGH-COST)
*1357 *           DEMAND-RATCHETS = (3-MON-AVG)
*1358 *           POWER-FACTOR = .79
*1359 *           EXCESS-KVAR-FRAC = .11
*1360 *           EXCESS-KVAR-CHG = 10 ..
*1361 *
*1362 * 3-MON-AVG = RATCHET           NUM-MONTHS = 12
*1363 *           RATCHET-SCH = ALL-YEAR
*1364 *           SCH-FLAG = 1
*1365 *           TYPE = AVERAGE
*1366 *           FRACTION = .9 ..
*1367 *
*1368 * ALL-YEAR = SCHEDULE THRU MAY 30 (ALL) (1,24)(0)
*1369 *           THRU SEP 30 (ALL) (1,24)(1)
*1370 *           THRU DEC 31 (ALL) (1,24)(0) ..
*1371 *
*1372 * HIGH-COST = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
*1373 *           BLOCK1-DATA = (4000,.065,
*1374 *           6000,.055
*1375 *           10000,.045)
*1376 *           BLOCK2-TYPE = KWH/KW
*1377 *           BLOCK2-DATA = (500,.035,0
*1378 *           1,.030,0) ..
*1379 *
*1380 * >THAN-2000KW = UTILITY-RATE RESOURCE = ELECTRICITY
*1381 *           DEMAND-CHGS = (10)
*1382 *           RATE-LIMITATION = .10
*1383 *           DEMAND-QUALS = (2400,0)
*1384 *           QUALIFY-RATE = MONTH-BY-MONTH
*1385 *           BLOCK-CHARGES = (LOW-COST)
*1386 *           DEMAND-RATCHETS = (3-MON-AVG)
*1387 *           POWER-FACTOR = .79

```

```

*1388 *          EXCESS-KVAR-FRAC = .11
*1389 *          EXCESS-KVAR-CHG = 10 ..
*1390 *
*1391 * LOW-COST   = BLOCK-CHARGE  BLOCK1-TYPE = ENERGY
*1392 *          BLOCK1-DATA = (4000,.055,
*1393 *                    6000,.045
*1394 *                    10000,.035)
*1395 *          BLOCK2-TYPE = KWH/KW
*1396 *          BLOCK2-DATA = (500,.030,0
*1397 *                    1,.025,0) ..
*1398 *
*1399 * BELOW-110  = UTILITY-RATE  RESOURCE = NATURAL-GAS
*1400 *          DEMAND-QUALS = (0,110)
*1401 *          QUALIFY-RATE = MONTH-BY-MONTH
*1402 *          ENERGY-CHG = .55 ..
*1403 *
*1404 * ABOVE-110  = UTILITY-RATE  RESOURCE = NATURAL-GAS
*1405 *          DEMAND-QUALS = (110,0)
*1406 *          QUALIFY-RATE = MONTH-BY-MONTH
*1407 *          ENERGY-CHG = .70 ..
*1408 *
*1409 * END ..
*1410 * COMPUTE ECONOMICS ..
*1411 *
*1412 * INPUT SYSTEMS ..

```

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
CORESYS	S2RH	1.020	388900.0	1860.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	365850.	306.169	2.6	365850.	126.295	1.1	0.223	14765.264	0.672	-19423.416	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
TZ1	10924.	0.	0.000	1.000	2550.	0.00	0.00	224.16	-353.94	-412.93	30.0	
RZ1	10924.	0.	0.000	1.000	2550.	0.00	0.00	224.16	-353.94	-412.93	1.0	
PLEN1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	
PLEN2	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	30.0	
A-STORAGE	27200.	0.	0.000	1.000	2550.	0.00	0.00	558.14	-881.28	-1028.16	1.0	

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
FANCOIL	FPFC	1.020	251124.8	2976.									
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	
	811713.	0.000	0.4	0.	0.000	0.0	0.101	0.000	0.000	0.000	0.00	0.37	
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	RZ2	1166.	0.	0.134	1.000	29.	23.57	0.92	17.29	-44.78	-43.16	8.0	
	RZ3	675.	0.	0.078	1.000	29.	14.44	0.89	10.01	-26.86	-25.05	4.0	
	RZ4	1146.	0.	0.132	1.000	29.	22.82	0.93	16.98	-44.03	-42.40	8.0	
	RZ5	1395.	0.	0.161	1.000	29.	27.65	0.94	20.68	-53.13	-51.60	4.0	
	TZ2	1155.	0.	0.133	1.000	29.	23.32	0.92	17.12	-44.38	-42.75	240.0	
	TZ3	606.	0.	0.070	1.000	29.	13.11	0.88	8.99	-24.35	-22.51	120.0	
	TZ4	1129.	0.	0.130	1.000	29.	22.94	0.92	16.74	-43.42	-41.79	240.0	
	TZ5	1367.	0.	0.157	1.000	29.	27.12	0.94	20.26	-52.10	-50.55	120.0	

- - - - - C O O L I N G - - - - -							- - - - - H E A T I N G - - - - -					- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	73.82199	25 15	47.F	42.F	3236.050	-1040.307	4 6	3.F	3.F	-24148.729	450934.	1915.304	
FEB	123.96275	25 16	27.F	22.F	3810.732	-725.996	8 7	5.F	5.F	-12569.847	419524.	1899.366	
MAR	284.04797	3 15	76.F	65.F	8127.443	-276.879	1 8	28.F	27.F	-6905.583	484104.	1817.409	
APR	977.75800	28 15	78.F	68.F	12680.301	-31.678	8 8	31.F	28.F	-3226.991	449190.	1788.054	
MAY	1096.08435	21 14	85.F	75.F	15747.660	-6.736	10 8	42.F	40.F	-624.135	407635.	1785.427	
JUN	2195.45581	21 16	82.F	72.F	17644.016	-3.955	28 8	59.F	54.F	-160.801	448213.	1785.427	
JUL	3248.66187	13 16	97.F	77.F	19616.564	-1.393	6 8	64.F	58.F	-363.203	436375.	1785.427	
AUG	2863.75269	16 15	85.F	73.F	17484.006	-1.155	2 8	65.F	64.F	-129.461	455831.	1785.427	
SEP	1360.46155	10 15	82.F	70.F	15266.467	-2.458	22 8	34.F	31.F	-567.055	435060.	1786.948	
OCT	656.14038	5 16	74.F	62.F	10409.931	-11.162	21 8	30.F	29.F	-1159.818	421725.	1855.377	
NOV	323.04776	2 15	75.F	61.F	10476.650	-225.421	29 8	29.F	27.F	-9080.154	436229.	1899.100	
DEC	52.28515	10 15	41.F	35.F	3620.678	-617.199	27 8	31.F	30.F	-12491.229	471283.	1928.646	
TOTAL	13255.493					-2944.338					5316124.		
MAX					19616.564					-24148.729		1928.646	

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 0.000 (KBTU)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 198008.368 (KBTU)

C O O L I N G						H E A T I N G					E L E C	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-765.101	4 6	3.F	3.F	-19472.742	304977.	1318.656
FEB	0.00000				0.000	-588.209	8 7	5.F	5.F	-10725.037	288713.	1318.656
MAR	11.77368	3 15	76.F	65.F	2072.431	-218.051	1 7	28.F	26.F	-5921.586	344008.	1318.656
APR	163.65411	28 15	78.F	68.F	5806.282	-14.679	1 7	40.F	37.F	-1308.509	324820.	1318.656
MAY	132.01375	21 13	87.F	76.F	7707.107	-5.493	10 9	46.F	43.F	-265.324	296760.	1318.656
JUN	838.27191	21 15	81.F	72.F	9252.763	-3.955	28 8	59.F	54.F	-160.801	328280.	1318.656
JUL	1683.74109	19 14	90.F	75.F	11010.372	-1.393	6 8	64.F	58.F	-363.203	319141.	1318.656
AUG	1405.40552	16 15	85.F	73.F	9836.833	-1.155	2 8	65.F	64.F	-129.461	332872.	1318.656
SEP	390.45990	10 16	82.F	70.F	7082.210	-1.673	23 9	39.F	36.F	-254.046	310657.	1318.656
OCT	68.55700	5 16	74.F	62.F	3667.577	-4.535	27 9	40.F	36.F	-297.670	296327.	1318.656
NOV	62.40891	2 16	77.F	62.F	4557.225	-187.992	29 7	28.F	27.F	-7486.211	299520.	1318.656
DEC	0.01624	3 14	33.F	30.F	16.241	-503.185	27 7	31.F	30.F	-10684.330	319141.	1318.656
TOTAL	4756.305					-2295.422					3765328.	
MAX					11010.372					-19472.742		1318.656

- - - - - COOLING - - - - -					- - - HEATING - - -			DAY COOLING PEAK			
JUL 19					JAN 4			JUL 19			
HOURLY	SENSIBLE	DRY-	WET-		HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-
COOLING	HEAT	BULB	BULB		HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB
LOAD	RATIO	TEMP	TEMP		LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP
(KBTU)					(KBTU)			(KBTU)			
HOUR											
1	0.000	0.000	79.F	72.F	0.000	6.F	6.F	0.000	0.000	79.F	72.F
2	0.000	0.000	79.F	72.F	0.000	5.F	5.F	0.000	0.000	79.F	72.F
3	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
4	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
5	0.000	0.000	77.F	72.F	0.000	3.F	3.F	0.000	0.000	77.F	72.F
6	8571.109	0.984	78.F	72.F	-19472.742	3.F	3.F	8571.109	0.984	78.F	72.F
7	9273.517	0.986	77.F	72.F	-16910.035	2.F	2.F	9273.517	0.986	77.F	72.F
8	10472.361	0.754	79.F	72.F	-14897.768	2.F	2.F	10472.361	0.754	79.F	72.F
9	10524.677	0.770	82.F	72.F	-15472.430	4.F	3.F	10524.677	0.770	82.F	72.F
10	10609.516	0.773	85.F	73.F	-13767.545	7.F	6.F	10609.516	0.773	85.F	73.F
11	10842.654	0.782	88.F	74.F	-12475.425	11.F	9.F	10842.654	0.782	88.F	74.F
12	10555.061	0.776	89.F	74.F	-11288.944	16.F	13.F	10555.061	0.776	89.F	74.F
13	11010.372	0.758	90.F	75.F	-10857.404	18.F	15.F	11010.372	0.758	90.F	75.F
14	10880.451	0.749	89.F	75.F	-9858.023	20.F	16.F	10880.451	0.749	89.F	75.F
15	10841.978	0.755	90.F	75.F	-9126.853	20.F	16.F	10841.978	0.755	90.F	75.F
16	10304.237	0.744	91.F	76.F	-8569.791	20.F	16.F	10304.237	0.744	91.F	76.F
17	9583.459	0.755	90.F	75.F	-8775.312	19.F	15.F	9583.459	0.755	90.F	75.F
18	0.000	0.000	86.F	74.F	-8933.562	16.F	13.F	0.000	0.000	86.F	74.F
19	0.000	0.000	86.F	74.F	0.000	13.F	11.F	0.000	0.000	86.F	74.F
20	0.000	0.000	80.F	72.F	0.000	11.F	9.F	0.000	0.000	80.F	72.F
21	0.000	0.000	79.F	72.F	0.000	10.F	8.F	0.000	0.000	79.F	72.F
22	0.000	0.000	77.F	71.F	0.000	11.F	9.F	0.000	0.000	77.F	71.F
23	0.000	0.000	76.F	71.F	0.000	7.F	6.F	0.000	0.000	76.F	71.F
24	0.000	0.000	74.F	70.F	0.000	6.F	5.F	0.000	0.000	74.F	70.F
SUM											
MAX	11010.372				-19472.742			123469.391			

SYSTEM-TYPE	SZRH	SQFT/TON	423.9
COOLING PEAK	28.31 (BTU/HR- SQFT)	HEATING PEAK	-50.07 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	0.94 (CFM/SQFT)	MIN-OA/PERSON	43.87 (CFM)
OA FRAC AT CLG PEAK	0.223	OA FRAC AT HTG PEAK	0.010

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	73.82199	25 15	47.F	42.F	3236.050	-275.208	12 8	-7.F	-7.F	-5403.996	130758.	556.649
FEB	123.96275	25 16	27.F	22.F	3810.732	-137.787	4 8	7.F	6.F	-4646.200	116372.	540.711
MAR	272.27432	3 15	76.F	65.F	6055.012	-58.828	23 8	19.F	16.F	-3210.700	122616.	465.508
APR	814.10406	27 16	82.F	61.F	7605.653	-16.999	8 8	31.F	28.F	-3108.617	107651.	449.295
MAY	964.07074	20 15	76.F	67.F	8187.685	-1.244	10 8	42.F	40.F	-598.937	95676.	426.772
JUN	1357.18384	4 16	85.F	67.F	8849.107	0.000	10 8	64.F	59.F	-0.004	103215.	426.772
JUL	1564.92041	13 16	97.F	77.F	9326.570	0.000				0.000	101276.	426.772
AUG	1458.34961	19 16	90.F	71.F	8825.367	0.000	4 9	58.F	56.F	-0.004	106240.	427.699
SEP	970.00165	17 16	82.F	66.F	8328.922	-0.785	22 8	34.F	31.F	-567.055	108445.	454.591
OCT	587.58350	5 16	74.F	62.F	6742.354	-6.627	21 8	30.F	29.F	-1157.051	110198.	496.722
NOV	260.63892	8 15	60.F	49.F	6391.240	-37.429	26 8	25.F	22.F	-2965.361	121510.	564.947
DEC	52.26891	10 15	41.F	35.F	3620.678	-114.014	22 8	15.F	15.F	-3912.441	136183.	581.154
TOTAL	8499.186					-648.920					1360129.	
MAX					9326.570					-5403.996		581.154

MESSAGE LIST FROM PLANT PROGRAM

CAUTION.....
TOWER WILL BE DEFINED FOR CHILLERS THAT NEED IT

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	17.000	1 1								
DHW-HEATER	0.100	1 1								
HERM-CENT-CHLR	7.800	2 2								
DBUN-CHLR	10.000	1 1								
COOLING-TWR	10.487	3 3								
HTANK-STORAGE	20.000	1 1								
HEAT-STORE-RATE =	10.000	(MBTU/H)								
HEAT-SUPPLY-RATE=	12.000	(MBTU/H)								

MONTH	S I T E E N E R G Y												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	1123.4	89.9	503.2	160.5	0.0	0.0	25.7	1438.4	26.6	0.0	1438.4	3155.9	6591.5
FEB	814.6	143.6	476.4	234.3	11.1	0.0	36.2	900.1	20.7	0.0	900.1	2526.0	5778.3
MAR	364.3	308.7	556.4	263.3	226.0	0.0	63.1	158.2	9.1	0.0	158.2	2057.1	5855.5
APR	84.1	1010.2	569.9	66.3	1207.8	0.0	117.2	25.4	3.5	0.0	25.4	1970.5	5861.1
MAY	32.2	1128.8	509.8	17.2	581.8	0.0	99.3	22.7	2.8	0.0	22.7	1762.5	5242.5
JUN	31.5	2246.8	598.6	0.0	0.0	0.0	147.9	49.5	2.5	0.0	49.5	2092.4	6178.8
JUL	17.4	3318.5	654.8	0.0	0.0	0.0	217.9	27.1	0.5	0.0	27.1	2262.0	6732.4
AUG	18.6	2925.3	646.7	0.0	0.0	0.0	190.1	28.9	0.7	0.0	28.9	2235.9	6650.7
SEP	79.1	1399.4	560.3	60.1	680.5	0.0	123.7	29.6	1.6	0.0	29.6	1942.0	5767.4
OCT	47.2	684.7	517.6	33.5	906.6	0.0	94.3	20.9	1.6	0.0	20.9	1787.4	5321.0
NOV	266.1	346.9	506.7	132.4	368.3	0.0	62.3	210.8	8.2	0.0	210.8	1940.1	5399.2
DEC	709.9	69.4	515.8	129.3	0.6	0.0	23.2	908.4	21.3	0.0	908.4	2668.8	6189.9
TOTAL	3588.5	13672.2	6616.1	1096.8	3982.7	0.0	1200.9	3820.0	99.1	0.0	3820.0	26400.5	71568.4

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	2304.4	64.2
DHW-HEATER	182.0	5.1
DBUN-CHLR	1096.8	30.6
=====		
LOAD SATISFIED	3583.2	99.9
TOTAL LOAD ON PLANT	3588.5	

COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HERM-CENT-CHLR	10056.4	73.6
DBUN-CHLR	3615.9	26.4
=====		
LOAD SATISFIED	13672.3	100.0
TOTAL LOAD ON PLANT	13672.3	

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	6616102.0	100.0
=====		
LOAD SATISFIED	6616102.0	100.0
TOTAL LOAD ON PLANT	6616099.0	

STORAGE TANK USE	MBTU STORED	MBTU RETURNED	MBTU LOST	MBTU RESIDUAL
HTANK-STORAGE	580.1	440.3	129.78	10.01

TOWER ABOVE DESIGN TEMPERATURE OF 85.F 0 HOURS

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	3588.5	3583.2	9.110	3.910	527
COOLING LOADS	13672.3	13672.3	93.174	3.832	111
ELECTRICAL LOADS	22580.5	22580.6	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS	RECOVERED
CATEGORY OF USE			

AREA LIGHTS	8817.5	0.0	0.0
MISC EQUIPMT	3997.2	0.0	0.0
SPACE HEAT	161.7	3545.9	1085.2
SPACE COOL	3360.1	0.0	0.0
HEAT REJECT	422.7	0.0	0.0
PUMPS & MISC	492.3	0.0	0.0
VENT FANS	5329.0	0.0	0.0
DOMHOT WATER	0.0	274.0	0.0
	-----	-----	-----
TOTAL	22580.6	3820.0	1085.2

NOTE ABOVE FIGURES DO NOT INCLUDE THE 10.01 MBTU RESIDUAL IN THE HOT STORAGE TANK

TOTAL SITE ENERGY	26400.55 MBTU	41.2 KBTU/SQFT-YR GROSS-AREA	41.2 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	71568.46 MBTU	111.8 KBTU/SQFT-YR GROSS-AREA	111.8 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.5
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 7.3

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

REPORT- ES-D ENERGY COST SUMMARY

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
<THAN-2000KW	ELECTRICITY	1 2 3 4 5	992163. KWH	88966.	0.0897	NO
>THAN-2000KW	ELECTRICITY	1 2 3 4 5	5623940. KWH	486924.	0.0866	NO
BELOW-110	NATURAL-GAS	1 2 3 4 5	3622. THERM	1992.	0.5500	NO
ABOVE-110	NATURAL-GAS	1 2 3 4 5	34578. THERM	24204.	0.7000	NO

602087.

ENERGY COST/GROSS BLDG AREA: 0.94
ENERGY COST/NET BLDG AREA: 0.94

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 4 - FOUR PIPE FANCOIL PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 4
 VAR TEMP SINGLE ZONE INTERIOR
 REPORT- ES-E SUMMARY OF UTILITY-RATE: <THAN-2000KW

UTILITY-RATE: <THAN-2000KW RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.1000
 POWER-FACTOR: 0.79 EXCESS-KVAR-FRAC: 0.11 EXCESS-KVAR-CHG: 10.0000

RATE-QUALIFICATIONS	BLOCK-CHARGES	DEMAND-RATCHETS	MIN-MON-RATCHETS
-----	-----	-----	-----
MIN-ENERGY: 0.0	HIGH-COST	3-MON-AVG	
MAX-ENERGY: 0.0			
MIN-DEMAND: 0.0			
MAX-DEMAND: 2400.0			
QUALIFY-RATE: MONTH-BY-MONTH			
USE-MIN-QUAL: NO			

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	503235	0	2420.1	0.0	0	0	0	0	0	0	0	0.0000	0
FEB	476386	476386	2302.2	2302.2	17014	23022	0	0	0	0	0	0.0916	43623
MAR	556383	0	2458.8	0.0	0	0	0	0	0	0	0	0.0000	0
APR	569896	0	2790.8	0.0	0	0	0	0	0	0	0	0.0000	0
MAY	509752	0	2779.4	0.0	0	0	0	0	0	0	0	0.0000	0
JUN	598567	0	2780.0	0.0	0	0	0	0	0	0	0	0.0000	0
JUL	654825	0	2865.3	0.0	0	0	0	0	0	0	0	0.0000	0
AUG	646668	0	2844.7	0.0	0	0	0	0	0	0	0	0.0000	0
SEP	560331	0	2881.8	0.0	0	0	0	0	0	0	0	0.0000	0
OCT	517601	0	2720.9	0.0	0	0	0	0	0	0	0	0.0000	0
NOV	506683	0	2781.2	0.0	0	0	0	0	0	0	0	0.0000	0
DEC	515776	515776	2331.7	2331.7	18392	23317	0	0	0	0	0	0.0879	45343
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
TOTAL	6616102	992163	2881.8		35406	46340	0	0	0	0		0.0134	88966

UTILITY-RATE: <THAN-2000KW
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR
HIGH-COST	USE: YEARLY												
METERED ENERGY:	503235	476386	556383	569896	509752	598567	654825	646668	560331	517601	506683	515776	
BILLING ENERGY:	0	476386	0	0	0	0	0	0	0	0	0	515776	992163
KWH/KW DEMAND:	0.0	2302.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2331.7	
ENERGY CHGS (\$):	0	17014	0	0	0	0	0	0	0	0	0	18392	35406

TOTAL ENERGY:	0	476386	0	0	0	0	0	0	0	0	0	515776	992163
TOTAL CHARGES (\$):	0	17014	0	0	0	0	0	0	0	0	0	18392	35406

RATCHETS	TYPE	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
3-MON-AVG	AVERAGE	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 4 - FOUR PIPE FANCOIL PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 4
 VAR TEMP SINGLE ZONE INTERIOR
 REPORT- ES-E SUMMARY OF UTILITY-RATE: >THAN-2000KW

 UTILITY-RATE: >THAN-2000KW RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.1000
 POWER-FACTOR: 0.79 EXCESS-KVAR-FRAC: 0.11 EXCESS-KVAR-CHG: 10.0000

 RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0 LOW-COST 3-MON-AVG
 MAX-ENERGY: 0.0
 MIN-DEMAND: 2400.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: MONTH-BY-MONTH
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	503235	503235	2420.1	2420.1	15337	24201	0	0	0	0	0	0.0861	43309
FEB	476386	0	2302.2	0.0	0	0	0	0	0	0	0	0.0000	0
MAR	556383	556383	2458.8	2458.8	16931	24588	0	0	0	0	0	0.0815	45351
APR	569896	569896	2790.8	2790.8	17337	27908	0	0	0	0	0	0.0870	49594
MAY	509752	509752	2779.4	2779.4	15533	27794	0	0	0	0	0	0.0935	47657
JUN	598567	598567	2780.0	2780.0	18197	27800	0	0	0	0	0	0.0841	50329
JUL	654825	654825	2865.3	2865.3	19885	28653	0	0	0	0	0	0.0809	53003
AUG	646668	646668	2844.7	2844.7	19640	28447	0	0	0	0	0	0.0812	52519
SEP	560331	560331	2881.8	2881.8	17050	28818	0	0	0	0	0	0.0899	50359
OCT	517601	517601	2720.9	2720.9	15768	27209	0	0	0	0	0	0.0912	47216
NOV	506683	506683	2781.2	2781.2	15441	27812	0	0	0	0	0	0.0939	47586
DEC	515776	0	2331.7	0.0	0	0	0	0	0	0	0	0.0000	0
TOTAL	6616102	5623940	2881.8		171118	273230	0	0	0	0		0.0736	486924

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 4 - FOUR PIPE FANCOIL PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 4
 VAR TEMP SINGLE ZONE INTERIOR
 REPORT- ES-F BLOCK-CHARGE AND RATCHET SUMMARY FOR: >THAN-2000KW

 UTILITY-RATE: >THAN-2000KW
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR
LOW-COST	USE: YEARLY												
METERED ENERGY:	503235	476386	556383	569896	509752	598567	654825	646668	560331	517601	506683	515776	
BILLING ENERGY:	503235	0	556383	569896	509752	598567	654825	646668	560331	517601	506683	0	5623940
KWH/KW DEMAND:	2420.1	0.0	2458.8	2790.8	2779.4	2780.0	2865.3	2844.7	2881.8	2720.9	2781.2	0.0	
ENERGY CHGS (\$):	15337	0	16931	17337	15533	18197	19885	19640	17050	15768	15441	0	171118
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
TOTAL ENERGY:	503235	0	556383	569896	509752	598567	654825	646668	560331	517601	506683	0	5623940
TOTAL CHARGES (\$):	15337	0	16931	17337	15533	18197	19885	19640	17050	15768	15441	0	171118

RATCHETS	TYPE	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
3-MON-AVG	AVERAGE	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6	2055.6

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 4 - FOUR PIPE FANCOIL PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 4
 VAR TEMP SINGLE ZONE INTERIOR
 REPORT- ES-E SUMMARY OF UTILITY-RATE: BELOW-110

UTILITY-RATE: BELOW-110 RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 110.0
 QUALIFY-RATE: MONTH-BY-MONTH
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	14384	0	247.5	0.0	0	0	0	0	0	0	0	0.0000	0
FEB	9001	0	164.1	0.0	0	0	0	0	0	0	0	0.0000	0
MAR	1582	1582	91.0	91.0	870	0	0	0	0	0	0	0.5500	870
APR	254	254	1.4	1.4	140	0	0	0	0	0	0	0.5500	140
MAY	227	227	1.4	1.4	125	0	0	0	0	0	0	0.5500	125
JUN	495	495	6.2	6.2	272	0	0	0	0	0	0	0.5500	272
JUL	271	271	8.6	8.6	149	0	0	0	0	0	0	0.5500	149
AUG	289	289	5.9	5.9	159	0	0	0	0	0	0	0.5500	159
SEP	296	296	5.0	5.0	163	0	0	0	0	0	0	0.5500	163
OCT	209	209	1.3	1.3	115	0	0	0	0	0	0	0.5500	115
NOV	2108	0	127.7	0.0	0	0	0	0	0	0	0	0.0000	0
DEC	9084	0	165.9	0.0	0	0	0	0	0	0	0	0.0000	0
=====													
TOTAL	38200	3622	247.5		1992	0	0	0	0	0		0.0521	1992

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 4 - FOUR PIPE FANCOIL PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 4
 VAR TEMP SINGLE ZONE INTERIOR
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ABOVE-110

UTILITY-RATE: ABOVE-110 RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 110.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: MONTH-BY-MONTH
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	14384	14384	247.5	247.5	10069	0	0	0	0	0	0	0.7000	10069
FEB	9001	9001	164.1	164.1	6301	0	0	0	0	0	0	0.7000	6301
MAR	1582	0	91.0	0.0	0	0	0	0	0	0	0	0.0000	0
APR	254	0	1.4	0.0	0	0	0	0	0	0	0	0.0000	0
MAY	227	0	1.4	0.0	0	0	0	0	0	0	0	0.0000	0
JUN	495	0	6.2	0.0	0	0	0	0	0	0	0	0.0000	0
JUL	271	0	8.6	0.0	0	0	0	0	0	0	0	0.0000	0
AUG	289	0	5.9	0.0	0	0	0	0	0	0	0	0.0000	0
SEP	296	0	5.0	0.0	0	0	0	0	0	0	0	0.0000	0
OCT	209	0	1.3	0.0	0	0	0	0	0	0	0	0.0000	0
NOV	2108	2108	127.7	127.7	1476	0	0	0	0	0	0	0.7000	1476
DEC	9084	9084	165.9	165.9	6359	0	0	0	0	0	0	0.7000	6359
=====													
TOTAL	38200	34578	247.5		24204	0	0	0	0	0		0.6336	24204

31-Story Office Building, LOAD2 — Run 5 Systems, Plant, Economics

S D L P R O C E S S O R I N P U T D A T A

Wed Nov 10 14:35:12 1993SDL RUN 5

```

*1413 * TITLE LINE-2 * RUN 5 POWERED INDUCTION UNITS *
*1414 * LINE-4 * SINGLE-ZONE UNIT IN BASEMENT * ..
*1415 *
*1416 *           $ HVAC SYSTEM DESCRIPTION
*1417 *
*1418 * $ DESIGN TEMPS COOLING 76F HEATING 70F
*1419 * $ SYSTEM TYPE POWERED INDUCTION UNITS SERVE THE PERIMETER SPACES WITH
*1420 * $ PARALLEL-PIU ON THE EAST, SOUTH, AND WEST EXPOSURES AND
*1421 * $ SERIES-PIU ON THE NORTH. THE INTERIOR IS SERVED BY STANDARD
*1422 * $ VAV BOXES WITH A MINIMUM STOP OF 20%.
*1423 *
*1424 * $ THE MAIN AIR HANDLING UNITS HAVE SUPPLY AND RETURN FANS WITH
*1425 * $ SPEED CONTROL, AND AN ECONOMIZER WITH A LIMIT TEMPERATURE
*1426 * $ OF 68F. THE MINIMUM VENTILATION IS 20 CFM/PERSON AND THE
*1427 * $ FANS OPERATE FROM 7AM TO 6PM WEEKDAYS. ON NIGHTS AND ON
*1428 * $ WEEKENDS THE MAIN FANS ARE OFF BUT THE PIU FANS CAN CYCLE
*1429 * $ ON TO HOLD A MINIMUM SETPOINT OF 55F. THE MINIMUM OUTSIDE
*1430 * $ AIR DAMPERS ARE HELD CLOSED UNTIL 8AM; HOWEVER,
*1431 * $ THE ECONOMIZER IS ACTIVE FOR OA COOLING.
*1432 *
*1433 * SYSTEMS-REPORT S (SS-A,SS-D,SS-J) ..
*1434 *
*1435 * FANSON SCH THRU DEC 31 (WD) (1,5)(0) (6,7)(-999) (8,18)(1) (19,24) (0)
*1436 * (WEH) (1,24) (0) ..
*1437 *
*1438 * HEAT-SETPT SCH THRU DEC 31 (WD) (1,7) (55) (8,18) (70) (19,24) (55)
*1439 * (WEH) (1,24) (55) ..
*1440 * COOL-SETPT SCH THRU DEC 31 (WD) (1,7) (99) (8,18) (76) (19,24) (99)
*1441 * (WEH) (1,24) (99) ..
*1442 * PIU-SETPT SCH THRU DEC 31 (ALL) (1,24) (74) ..
*1443 *
*1444 * COOLON SCH THRU DEC 31 (ALL) (1,24) (55) ..
*1445 * HEATON SCH THRU DEC 31 (ALL) (1,24) (65) ..
*1446 *
*1447 * OA-DAMP-POS SCH THRU DEC 31 (ALL) (1,8) (.01) (9,18) (-999) (19,24) (.01) ..
*1448 *
*1449 * ENV ZONE-CONTROL D-H-T 70 D-C-T 74 H-T-SCH HEAT-SETPT C-T-SCH COOL-SETPT ..
*1450 *
*1451 * RZ1 Z Z-C ENV OA-CFM/PER 15 S-O ADJUST-LOADS TERMINAL-TYPE SVAV
*1452 * M-C-R .5 R-D-T 50 CFM/SQFT .9 T-TYPE REVERSE-ACTION ..
*1453 *
*1454 * RZ2 Z Z-C ENV OA-CFM/PER 15 S-O ADJUST-LOADS TERMINAL-TYPE PARALLEL-PIU
*1455 * INDUCED-AIR-ZONE RZ1 REHEAT-DELTA-T 50 M-C-R .2
*1456 * ZONE-FAN-RATIO .8 ZONE-FAN-T-SCH PIU-SETPT ..
*1457 *
*1458 * RZ3 Z LIKE RZ2 TERMINAL-TYPE SERIES-PIU ZONE-FAN-RATIO 1.1 ..
*1459 * RZ4 Z LIKE RZ2 ..
*1460 * RZ5 Z LIKE RZ2 ..
*1461 * TZ1 Z Z-C ENV OA-CFM/PER 15 TERMINAL-TYPE SVAV M-C-R .5 R-D-T 50
*1462 * CFM/SQFT .7 ..
*1463 *
*1464 * TZ2 Z Z-C ENV OA-CFM/PER 15 TERMINAL-TYPE PARALLEL-PIU M-C-R .2
*1465 * INDUCED-AIR-ZONE TZ1 R-D-T 50 ZONE-FAN-RATIO .8 ..
*1466 *
*1467 * TZ3 Z LIKE TZ2 TERMINAL-TYPE SERIES-PIU ZONE-FAN-RATIO 1.1 ..

```

```

*1468 * T24 Z LIKE T22 ..
*1469 * T25 Z LIKE T22 ..
*1470 * PLEN1 Z Z-TYPE PLENUM S-O ADJUST-LOADS D-H-T 50 D-C-T 90 ..
*1471 * PLEN2 Z Z-TYPE PLENUM ..
*1472 * A-STORAGE Z Z-C ENV AIR-CHANGES/HR 4 OA-CHANGES .5 ..
*1473 *
*1474 * MAIN SYSTEM S-TYPE PIU MAX-S-T 105 MIN-S-T 55 OA-CONTROL TEMP
*1475 * COOL-SET-T 58 MAX-HUMIDITY 55 HEAT-SET-T 60
*1476 * SUPPLY-STATIC 5.5 S-E .55 R-S 2 R-E .51 FAN-CONTROL SPEED
*1477 * MIN-F-R .2 COOL-CONTROL CONSTANT F-SCH FANSON
*1478 * N-C-C ZONE-FANS-ONLY P-N (PLEN1,PLEN2) R-A-P PLENUM-ZONES
*1479 * Z-N (RZ1,RZ2,RZ3,RZ4,RZ5,TZ1,T22,T23,TZ4,TZ5,PLEN1,PLEN2)
*1480 * MIN-AIR-SCH OA-DAMP-POS C-SCH COOLON ECONO-LIMIT-T 68 ..
*1481 *
*1482 * BASEMT SYSTEM S-TYPE SZRH MAX-S-T 105 MIN-S-T 55 SUPPLY-STATIC 2.5 S-E .50
*1483 * FAN-SCHEDULE FANSON HEATING-SCHEDULE HEATON C-SCH COOLON
*1484 * ECONO-LIMIT-T 68 Z-N (A-STORAGE) ..
*1485 *
*1486 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (MAIN,BASEMT)
*1487 * INT-ELEC-KW = 100 $ FOR ELEVATORS
*1488 * INT-ELEC-SCH = OCCUP
*1489 * DHW-SIZE=0
*1490 * DHW-GAL/MIN = 2.22
*1491 * DHW-SCH = OCCUP ..
*1492 *
*1493 * OC1 =DAY-SCHEDULE (1,8) (0.) (9,10) (1.)
*1494 * (11,13) (.8,.4,.8) (14,24) (1.,1..1.,
*1495 * .3,.1..1..1,0.,0.,0.,0.) ..
*1496 * OC2 =DAY-SCHEDULE (1,24) (0.0) ..
*1497 * PEOPLE =WEEK-SCHEDULE (MON,FRI) OC1 (WEH) OC2 ..
*1498 * OCCUP =SCHEDULE THRU DEC 31 PEOPLE ..
*1499 * END ..
*1500 * COMPUTE SYSTEMS ..
*1501 * INPUT PLANT ..

```


PDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993PDL RUN 5

```

*1502 * PLANT1 = PLANT-ASSIGNMENT ..
*1503 *
*1504 *           $ PLANT DESCRIPTION
*1505 *
*1506 * $ THIS IS A COGENERATION PLANT THAT SELLS ELECTRICITY TO THE UTILITY AND
*1507 * $ BUYS IT ON A SIMPLE BUY/SELL ARRANGEMENT. THE UTILITY PAYS 100000 DOLLARS/YR
*1508 * $ TO THE BUILDING OWNER UNDER
*1509 * $ THE AGREEMENT THAT THE BUILDING WILL RUN TWO 750KW GENERATORS
*1510 * $ FULL-OUT DURING THE ON PEAK HOURS OF 12NOON TILL 6PM. AN ABSORPTION CHILLER
*1511 * $ RECOVERS THE HEAT REJECTED BY THE GENERATORS. A CENTRIFUGAL CHILLER SERVES
*1512 * $ TO HELP BALANCE OFF THERMAL WITH ELECTRICAL LOADS. SPACE HEATING IS DONE BY
*1513 * $ RECOVERED HEAT, WITH A HOT WATER GENERATOR AS A SUPPLEMENTAL SOURCE. ONE
*1514 * $ DIESEL GENERATOR IS HELD IN RESERVE TO COVER THE DOWN TIME DUE TO MAINTENANCE
*1515 * $ ON THE GENERATION SYSTEM, AND THUS INSURE THAT TWO GENERATORS ARE AVAILABLE
*1516 * $ TO MEET THE CAPACITY AGREEMENT. THE ENGINES ARE NATURAL-GAS OTTO CYCLE EVEN
*1517 * $ THOUGH REFERRED TO AS DIESEL.
*1518 *
*1519 * PLANT-REPORT S (PS-A,PS-B,BEPS) ..
*1520 *
*1521 * HWG P-E TYPE HW-BOILER I-N 1 SIZE 10. ..
*1522 * CHL P-E TYPE HERM-CENT-CHLR I-N 1 SIZE 10. ..
*1523 * ABS P-E TYPE ABSOR1-CHLR I-N 1 SIZE 10. ..
*1524 * CTW P-E TYPE COOLING-TWR SIZE -999 ..
*1525 * COG P-E TYPE DIESEL-GEN SIZE 2.56 I-N 3 MAX-NUMBER-AVAIL 2
*1526 * FUEL-METER = M2 .. $ SEE ENERGY-RESOURCE BELOW
*1527 *
*1528 * PLANT-PARAMETERS HW-BOILER-HIR 1.33
*1529 * COGEN-TRACK-SCH=DIESEL-CTRL
*1530 * MIN-TRACK-LOAD 3 DIESEL-TRACK-MODE=TRACK-BOTH
*1531 * CCIRC-SIZE-OPT=INST-PLANT-EQUIP HCIRC-SIZE-OPT=SYSTEM-PEAK
*1532 * CCIRC-PUMP-TYPE=VARIABLE-SPEED ..
*1533 *
*1534 * DIESEL-CTRL SCH THRU DEC 31 (WD) (1,7) (0) (8,12) (3) $ 3 = TRACK-LESSER
*1535 * (13,18) (5) $ 5 = MAX-OUTPUT
*1536 * (19,24) (0) $ 0 = DO NOT RUN
*1537 * (WEH) (1,24) (0) ..
*1538 *
*1539 * HEAT-RECOVERY SUPPLY-1 (DIESEL-GEN,DIESEL-JACKET)
*1540 * DEMAND-1 (SPACE-HEAT,PROCESS-HEAT)
*1541 * SUPPLY-2 (DIESEL-GEN,DIESEL-JACKET)
*1542 * DEMAND-2 (ABSOR1-CHLR) ..
*1543 *
*1544 * PART-LOAD-RATIO TYPE HERM-CENT-CHLR E-I-R .235 ..
*1545 *
*1546 * ENERGY-RESOURCE RESOURCE=ELECTRICITY ..
*1547 * ENERGY-RESOURCE RESOURCE=NATURAL-GAS FUEL-METERS=(M1) ..
*1548 * ENERGY-RESOURCE RESOURCE=OTHER-FUEL FUEL-METERS=(M2)
*1549 * ENERGY/UNIT = 90000 $ LOW HEAT VALUE FOR A COMBUSTION ENGINE
*1550 * UNIT-NAME = THERMS
*1551 * DEM-UNIT-NAME = THERMS/HR
*1552 * OTHER-FUEL-NAME = COGEN-GAS ..
*1553 * END ..
*1554 * COMPUTE PLANT ..
*1555 * INPUT ECONOMICS ..

```

EDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993EDL RUN 5

```

*1556 *
*1557 *           $ ENERGY CHARGE DESCRIPTION
*1558 *
*1559 * $ THIS IS A BLOCK RATE STRUCTURE WITH ENERGY CHARGES SWITCHING TO KWH/KW CHARGES
*1560 * $ WITH INCREASING USAGE. THERE IS A UNIFORM DEMAND CHARGE OF 8.00 DOLLARS/KW.
*1561 * $ THERE IS A RATCHET BASED ON THE HIGHEST PEAK DURING THREE SUMMER MONTHS.
*1562 * $ THE ELECTRICITY THAT IS SOLD IS AT A FLAT RATE OF 8 CENTS/KWH. THERE IS
*1563 * $ A 100000 DOLLAR CAPACITY PAYMENT BY THE UTILITY IN RETURN FOR THE OWNER'S
*1564 * $ AGREEMENT TO OPERATE AT 1500KW CAPACITY (2 GENERATORS FULL-OUT) 5 DAYS A
*1565 * $ WEEK FROM 12NOON TILL 6PM. TO ACCOUNT FOR THE ADDITIONAL COSTS (OVER A
*1566 * $ CONVENTIONAL PLANT) OF HAVING IMMEDIATELY AVAILABLE DIESEL MAINTENANCE FOR
*1567 * $ THE ENGINE/GENERATORS, THE INCOME FROM THE CAPACITY PAYMENT IS REDUCED FROM
*1568 * $ 100000 DOLLARS TO 76000 DOLLARS. NOTE THAT THIS ADJUSTMENT MAY BE MADE
*1569 * $ AS A MONTHLY CHARGE TO THE UTILITY IN DOE2.1E. THE NATURAL GAS USED BY
*1570 * $ THE COGENERATORS IS CHARGED AT A LOWER COST THAN THAT FOR HEATING GAS.
*1571 *
*1572 * ECONOMICS-REPORT S (ES-D,ES-E,ES-F) ..
*1573 *
*1574 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
*1575 * MIN-MON-CHGS = (1200)
*1576 * DEMAND-CHGS = (8)
*1577 * DEMAND-RATCHETS = (SUMMER-PEAK)
*1578 * BLOCK-CHARGES = (PURCHASED-ELEC) ..
*1579 *
*1580 * PURCHASED-ELEC = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
*1581 * BLOCK1-DATA = (3000,.04,
*1582 * 7000,.035,
*1583 * 1,.030)
*1584 * BLOCK2-TYPE = KWH/KW
*1585 * BLOCK2-DATA = (100,.035,0
*1586 * 100,.025,0
*1587 * 1,.020,0) ..
*1588 * SUMMER-PEAK = RATCHET NUM-MONTHS = 12
*1589 * RATCHET-SCH = JUN-SEP
*1590 * SCH-FLAG = 1
*1591 * TYPE = HIGHEST-PEAK
*1592 * FRACTION = .9 ..
*1593 *
*1594 * JUN-SEP = SCHEDULE THRU MAY 31 (ALL) (1,24) (0)
*1595 * THRU SEP 30 (ALL) (1,24) (1)
*1596 * THRU DEC 31 (ALL) (1,24) (0) ..
*1597 *
*1598 * GENERATED-POWER = UTILITY-RATE RESOURCE = ELEC-BUY/SELL
*1599 * MONTH-CHGS = (6333) $76000/12 CAPACITY PMT
*1600 * ENERGY-CHG = .08 ..
*1601 *
*1602 * GAS-COST1 = UTILITY-RATE RESOURCE = OTHER-FUEL $ NATURAL-GAS USING
*1603 * $ LOW HEAT VALUE
*1604 * ENERGY-CHG = .45 ..
*1605 *
*1606 * GAS-COST2 = UTILITY-RATE RESOURCE = NATURAL-GAS
*1607 * ENERGY-CHG = .50 ..
*1608 *
*1609 *
*1610 * END ..

```

*1611 * COMPUTE ECONOMICS ..
*1612 * INPUT SYSTEMS ..

REPORT- SV-A SYSTEM DESIGN PARAMETERS

MAIN

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
MAIN	PIU	1.020	620024.8	4836.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	858293.	987.633	3.6	858293.	387.307	1.4	0.086	33750.098	0.674	-2514.050	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
RZ1	10924.	0.	0.000	0.500	918.	0.00	0.00	224.16	0.00	-412.93	1.0	
TZ1	8497.	0.	0.000	0.500	918.	0.00	0.00	174.35	0.00	-160.59	30.0	
PLEN1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	
PLEN2	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	30.0	
RZ2	859.	0.	0.000	0.200	61.	0.00	0.00	17.63	-37.12	-38.76	8.0	
RZ3	498.	0.	0.000	0.200	61.	0.00	0.00	10.64	-24.18	-25.45	4.0	
RZ4	844.	0.	0.000	0.200	61.	0.00	0.00	17.32	-36.47	-38.07	8.0	
RZ5	1028.	0.	0.000	0.200	61.	0.00	0.00	21.09	-44.40	-46.36	4.0	
TZ2	843.	0.	0.000	0.200	61.	0.00	0.00	17.31	-36.44	-38.23	240.0	
TZ3	439.	0.	0.000	0.200	61.	0.00	0.00	9.38	-21.32	-22.55	120.0	
TZ4	824.	0.	0.000	0.200	61.	0.00	0.00	16.91	-35.60	-37.35	240.0	
TZ5	999.	0.	0.000	0.200	61.	0.00	0.00	20.50	-43.16	-45.29	120.0	

ZONE NAME	FAN FLOW (CFM)	SUPPLY FLOW (CFM)	MIN FLOW RATIO	REHEAT DELTA-T (F)	FAN DELTA-T (F)	FAN KW
RZ1	0.	10924.	0.500	50.0	0.00	0.000
TZ1	0.	8497.	0.500	50.0	0.00	0.000
PLEN1	0.	0.	0.000	0.0	0.00	0.000
PLEN2	0.	0.	0.000	0.0	0.00	0.000
RZ2	687.	859.	0.200	50.0	1.02	0.227
RZ3	547.	498.	0.200	50.0	1.02	0.181
RZ4	675.	844.	0.200	50.0	1.02	0.223
RZ5	822.	1028.	0.200	50.0	1.02	0.271
TZ2	675.	843.	0.200	50.0	1.02	0.223
TZ3	483.	439.	0.200	50.0	1.02	0.159
TZ4	659.	824.	0.200	50.0	1.02	0.218
TZ5	799.	999.	0.200	50.0	1.02	0.264

REPORT- SV-A SYSTEM DESIGN PARAMETERS

SINGLE-ZONE UNIT IN BASEMENT

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER		FLOOR AREA (SQFT)		MAX PEOPLE						
BASEMT	SZRH	1.020		20000.0		0.						
SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	
27200.	15.649	1.8	0.	0.000	0.0	0.125	972.577	0.713	-1219.418	0.00	0.37	
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
A-STORAGE	27200	0.	0.000	1.000	3400.	0.00	0.00	558.14	0.00	-1028.16	1.0	

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-1237.450	4 9	4.F 3.F		-16123.612	382257.	1686.829
FEB	0.00000				0.000	-847.431	8 9	13.F 11.F		-11107.875	352186.	1633.864
MAR	87.18318	3 15	76.F	65.F	7958.514	-518.056	1 8	28.F 27.F		-9422.837	406020.	1567.994
APR	527.50043	28 15	78.F	68.F	10980.509	-107.753	5 8	34.F 30.F		-7725.423	379815.	1653.295
MAY	545.02783	21 14	85.F	75.F	14689.465	-19.518	10 8	42.F 40.F		-2854.207	350061.	1688.006
JUN	1862.96948	21 16	82.F	72.F	18002.160	-0.491	25 8	55.F 49.F		-256.868	405111.	1953.609
JUL	3118.74927	13 16	97.F	77.F	20802.381	0.000				0.000	426776.	2054.042
AUG	2654.75610	16 15	85.F	73.F	17721.020	0.000				0.000	422054.	1943.081
SEP	956.96442	10 15	82.F	70.F	15093.584	-9.076	29 8	47.F 44.F		-1737.429	374233.	1751.166
OCT	333.26004	5 16	74.F	62.F	9128.977	-65.393	21 8	30.F 29.F		-4827.550	356729.	1561.852
NOV	135.69865	2 15	75.F	61.F	8814.735	-458.315	29 8	29.F 27.F		-11314.007	373152.	1681.667
DEC	0.00000				0.000	-908.252	13 8	34.F 34.F		-11349.360	401484.	1704.223
TOTAL	10222.097					-4171.730					4629860.	
MAX					20802.381					-16123.612		2054.042

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 0.000 (KBTU)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 189884.336 (KBTU)

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -						- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	0.00000				0.000	-1203.637	4 9	4.F	3.F	-15632.481	355486.	1602.679	
FEB	0.00000				0.000	-815.869	8 9	13.F	11.F	-10838.659	326781.	1549.715	
MAR	87.18318	3 15	76.F	65.F	7958.514	-494.412	1 8	28.F	27.F	-9200.246	375395.	1483.845	
APR	527.50043	28 15	78.F	68.F	10980.509	-101.984	5 8	34.F	30.F	-7599.096	350642.	1510.646	
MAY	542.98151	21 14	85.F	75.F	14531.375	-19.492	10 8	42.F	40.F	-2834.157	323463.	1603.857	
JUN	1850.04675	21 16	82.F	72.F	17856.029	-0.491	25 8	55.F	49.F	-256.868	376000.	1810.960	
JUL	3082.54346	13 16	97.F	77.F	20537.863	0.000				0.000	398903.	1949.756	
AUG	2621.60059	16 15	85.F	73.F	17509.277	0.000				0.000	392907.	1858.931	
SEP	947.20508	10 15	82.F	70.F	14901.445	-9.052	29 8	47.F	44.F	-1737.429	346396.	1630.014	
OCT	331.25348	5 16	74.F	62.F	9028.915	-65.359	21 8	30.F	29.F	-4827.550	330130.	1470.691	
NOV	134.88367	2 15	75.F	61.F	8738.739	-453.729	29 8	29.F	27.F	-11185.349	346573.	1588.405	
DEC	0.00000				0.000	-889.020	13 8	34.F	34.F	-11202.080	373533.	1620.074	
TOTAL	10125.199					-4053.044					4296195.		
MAX					20537.863					-15632.481		1949.756	

- - - - COOLING - - - -					- - - HEATING - - -			DAY COOLING PEAK			
JUL 13					JAN 4			JUL 19			
HOURLY	SENSIBLE	DRY-	WET-		HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-
COOLING	HEAT	BULB	BULB		HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB
LOAD	RATIO	TEMP	TEMP		LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP
(KBTU)					(KBTU)			(KBTU)			
1	0.000	0.000	76.F	66.F	-1670.524	6.F	6.F	0.000	0.000	79.F	72.F
2	0.000	0.000	74.F	66.F	-3653.295	5.F	5.F	0.000	0.000	79.F	72.F
3	0.000	0.000	74.F	65.F	-1687.074	4.F	4.F	0.000	0.000	78.F	72.F
4	0.000	0.000	73.F	62.F	-3507.587	4.F	4.F	0.000	0.000	78.F	72.F
5	0.000	0.000	72.F	62.F	-1657.369	3.F	3.F	0.000	0.000	77.F	72.F
6	0.000	0.000	72.F	63.F	-3561.678	3.F	3.F	0.000	0.000	78.F	72.F
7	12058.387	0.989	73.F	65.F	-1400.479	2.F	2.F	12560.731	0.969	77.F	72.F
8	14764.851	0.844	76.F	69.F	-15244.163	2.F	2.F	16477.699	0.823	79.F	72.F
9	16525.201	0.834	82.F	72.F	-15632.481	4.F	3.F	16468.438	0.836	82.F	72.F
10	17119.006	0.835	86.F	74.F	-12360.225	7.F	6.F	18115.656	0.852	85.F	73.F
11	17599.635	0.833	89.F	76.F	-11139.708	11.F	9.F	17752.053	0.863	88.F	74.F
12	17486.299	0.806	93.F	78.F	-11122.410	16.F	13.F	17404.672	0.852	89.F	74.F
13	18198.188	0.807	95.F	78.F	-9763.665	18.F	15.F	18273.781	0.836	90.F	75.F
14	19386.039	0.834	96.F	77.F	-8776.635	20.F	16.F	19120.990	0.835	89.F	75.F
15	20537.863	0.843	97.F	77.F	-8358.760	20.F	16.F	19487.562	0.841	90.F	75.F
16	16532.377	0.833	97.F	78.F	-7853.238	20.F	16.F	16584.971	0.845	91.F	76.F
17	15300.540	0.858	99.F	77.F	-8693.424	19.F	15.F	15388.331	0.854	90.F	75.F
18	0.000	0.000	97.F	76.F	-9477.547	16.F	13.F	0.000	0.000	86.F	74.F
19	0.000	0.000	95.F	75.F	0.000	13.F	11.F	0.000	0.000	86.F	74.F
20	0.000	0.000	93.F	75.F	0.000	11.F	9.F	0.000	0.000	80.F	72.F
21	0.000	0.000	90.F	74.F	0.000	10.F	8.F	0.000	0.000	79.F	72.F
22	0.000	0.000	87.F	73.F	-11.765	11.F	9.F	0.000	0.000	77.F	71.F
23	0.000	0.000	86.F	73.F	-80.960	7.F	6.F	0.000	0.000	76.F	71.F
24	0.000	0.000	85.F	73.F	-1094.934	6.F	5.F	0.000	0.000	74.F	70.F
SUM											
MAX	20537.863				-15632.481			187634.906			

SYSTEM-TYPE	PIU	SQFT/TON	362.3
COOLING PEAK	33.12 (BTU/HR- SQFT)	HEATING PEAK	-25.21 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.38 (CFM/SQFT)	MIN-OA/PERSON	15.30 (CFM)
OA FRAC AT CLG PEAK	0.113	OA FRAC AT HTG PEAK	0.288

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-33.812	4 7	2.F	2.F	-587.128	11571.	44.149
FEB	0.00000				0.000	-31.562	8 7	5.F	5.F	-355.601	10965.	44.149
MAR	0.00000				0.000	-23.644	1 7	28.F	26.F	-270.828	13145.	44.149
APR	0.00000				0.000	-5.769	19 7	38.F	36.F	-177.325	12454.	44.149
MAY	2.04638	21 13	87.F	76.F	168.097	-0.025	10 8	42.F	40.F	-20.050	11399.	44.149
JUN	12.92317	9 15	83.F	73.F	187.738	0.000				0.000	12391.	44.149
JUL	36.20378	13 17	97.F	78.F	280.640	0.000				0.000	11913.	44.149
AUG	33.15545	26 17	94.F	76.F	272.747	0.000				0.000	12427.	44.149
SEP	9.75948	10 17	83.F	70.F	197.234	-0.023	22 8	34.F	31.F	-13.567	11877.	44.149
OCT	2.00658	5 17	74.F	62.F	102.455	-0.034	1 8	33.F	32.F	-14.379	11399.	44.149
NOV	0.81498	2 16	77.F	62.F	86.146	-4.586	29 7	28.F	27.F	-173.721	11379.	44.149
DEC	0.00000				0.000	-19.232	27 7	31.F	30.F	-245.970	11991.	44.149
TOTAL	96.910					-118.687					142910.	
MAX					280.640					-587.128		44.149

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	10.000	1 1										
HEM-CENT-CHLR	10.000	1 1										
ABSOR1-CHLR	10.000	1 1										
COOLING-TWR	12.890	3 3										
DIESEL-GEN	2.560	3 2										

MONTH	SITE ENERGY												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	1302.1	0.0	398.7	879.6	371.5	0.0	0.0	691.2	16.5	2916.3	3607.5	3952.3	4642.0
FEB	908.5	0.0	363.6	723.0	440.4	0.0	0.0	309.5	11.4	2720.1	3029.6	3326.4	3920.1
MAR	672.6	90.4	419.6	589.5	654.9	4.2	6.1	133.9	7.5	2904.8	3042.9	3470.0	4324.2
APR	714.1	544.2	415.1	681.2	450.0	16.2	31.4	40.5	3.8	2631.1	2687.8	3189.1	4191.8
MAY	669.5	565.3	384.8	653.6	364.8	12.1	33.3	15.5	1.5	2363.7	2391.4	2879.8	3856.8
JUN	1387.1	1907.9	513.3	1341.8	65.2	72.3	108.1	2.9	0.1	3267.1	3342.3	3952.0	5171.7
JUL	1901.7	3182.5	610.5	1484.4	0.0	642.4	183.7	0.6	0.0	3436.7	4079.7	4958.1	6715.2
AUG	1634.5	2710.9	581.2	1510.7	0.9	201.7	159.1	0.6	0.0	3506.6	3708.9	4465.2	5978.1
SEP	897.1	985.5	432.4	880.5	236.7	16.5	57.5	12.3	0.7	2592.5	2621.3	3190.9	4330.1
OCT	553.3	347.4	381.3	531.8	426.3	11.3	20.8	26.1	3.8	2223.3	2260.7	2787.4	3841.0
NOV	648.7	140.7	389.1	574.2	502.9	6.4	9.4	114.8	6.5	2510.5	2631.6	3088.5	4002.4
DEC	969.5	0.0	412.1	809.4	464.2	0.0	0.0	263.7	10.6	2976.7	3240.3	3613.8	4360.9
TOTAL	12258.5	10474.7	5301.6	10659.6	3977.8	983.1	609.4	1611.7	62.4	34049.3	36644.1	42873.5	55334.2

REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS	COGEN-GAS	ELECTRICITY
		METER-1 3413./KWH	METER-1 100000./THERM	METER-2 90000./THERMS	COGENERATION 3413./KWH
JAN					
	ENERGY CONSUMPTION (UNITS/MO)	398716.6	6912.1	32403.3	297692.5
	PEAK DEMAND (UNITS/HR OR DAY)	1704.3	140.9	169.8	1575.2
	PEAK DAY/HR	11/12	4/ 8	4/12	4/12
FEB					
	ENERGY CONSUMPTION (UNITS/MO)	363555.4	3095.4	30222.9	276595.3
	PEAK DEMAND (UNITS/HR OR DAY)	1651.4	88.7	169.8	1575.2
	PEAK DAY/HR	12/12	16/ 8	1/13	1/13
MAR					
	ENERGY CONSUMPTION (UNITS/MO)	419612.6	1381.3	32275.5	294484.0
	PEAK DEMAND (UNITS/HR OR DAY)	1892.3	78.2	169.8	1575.2
	PEAK DAY/HR	3/15	1/ 8	1/13	1/13
APR					
	ENERGY CONSUMPTION (UNITS/MO)	415051.1	566.8	29235.0	268182.4
	PEAK DEMAND (UNITS/HR OR DAY)	2233.4	52.5	169.8	1575.2
	PEAK DAY/HR	27/16	5/ 8	1/13	1/13
MAY					
	ENERGY CONSUMPTION (UNITS/MO)	384806.7	276.4	26263.7	241697.6
	PEAK DEMAND (UNITS/HR OR DAY)	2573.8	21.6	169.8	1575.2
	PEAK DAY/HR	21/14	11/10	3/13	3/13
JUN					
	ENERGY CONSUMPTION (UNITS/MO)	513303.8	751.8	36301.1	334652.3
	PEAK DEMAND (UNITS/HR OR DAY)	2932.9	84.3	169.8	1575.2
	PEAK DAY/HR	21/16	21/16	1/11	1/11
JUL					
	ENERGY CONSUMPTION (UNITS/MO)	610511.3	6430.0	38185.4	353138.8
	PEAK DEMAND (UNITS/HR OR DAY)	3071.3	144.2	169.8	1575.2
	PEAK DAY/HR	13/16	13/16	1/10	1/10
AUG					
	ENERGY CONSUMPTION (UNITS/MO)	581153.6	2023.1	38961.9	359546.7
	PEAK DEMAND (UNITS/HR OR DAY)	2899.3	78.9	169.8	1575.2
	PEAK DAY/HR	9/12	16/15	2/11	2/11
SEP					
	ENERGY CONSUMPTION (UNITS/MO)	432415.8	288.3	28805.6	265542.1
	PEAK DEMAND (UNITS/HR OR DAY)	2672.5	24.3	169.8	1575.2
	PEAK DAY/HR	10/15	10/15	1/13	1/13
OCT					
	ENERGY CONSUMPTION (UNITS/MO)	381334.0	374.4	24703.2	227007.2
	PEAK DEMAND (UNITS/HR OR DAY)	2050.8	23.1	169.8	1575.2
	PEAK DAY/HR	5/16	28/18	1/13	1/13
NOV					
	ENERGY CONSUMPTION (UNITS/MO)	389083.6	1211.9	27894.0	255221.8
	PEAK DEMAND (UNITS/HR OR DAY)	2020.1	94.7	169.8	1575.2
	PEAK DAY/HR	2/15	29/ 8	1/13	1/13
DEC					
	ENERGY CONSUMPTION (UNITS/MO)	412079.2	2636.7	33073.9	302646.1
	PEAK DEMAND (UNITS/HR OR DAY)	1721.7	92.4	169.8	1575.2
	PEAK DAY/HR	9/12	13/ 8	1/13	1/13
TOTAL					
	ENERGY CONSUMPTION (UNITS/YR)	5301623.5	25948.2	378325.5	3476406.8
	PEAK DEMAND (UNITS/HR OR DAY)	3071.3	144.2	169.8	1575.2

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS	COGEN-GAS	RECOVERED
CATEGORY OF USE				
AREA LIGHTS	4142.6	0.0	13457.3	0.0
MISC EQUIPMT	1259.5	0.0	7847.9	0.0
SPACE HEAT	40.0	1565.0	83.0	3477.7
SPACE COOL	435.4	983.1	2773.1	7021.8
HEAT REJECT	127.2	0.0	1077.5	0.0
PUMPS & MISC	112.6	0.0	564.8	0.0
VENT FANS	779.2	0.0	6342.9	0.0
DOMHOT WATER	1.8	46.7	1.6	160.1
COGEN SURPLS	-669.1	0.0	1901.2	0.0
TOTAL	6229.4	2594.8	34049.3	10659.6

TOTAL SITE ENERGY 42873.56 MBTU 67.0 KBTU/SQFT-YR GROSS-AREA 67.0 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 55334.24 MBTU 86.5 KBTU/SQFT-YR GROSS-AREA 86.5 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 2.6
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	5301624. KWH	437948.	0.0826	YES
GENERATED-POWER	ELEC-BUY/SELL		3476407. KWH	-354109.	-0.1019	YES
GAS-COST1	COGEN-GAS	2	378325. THERMS	170246.	0.4500	YES
GAS-COST2	NATURAL-GAS	1 3 4 5	25948. THERM	12974.	0.5000	YES

 267060.

ENERGY COST/GROSS BLDG AREA: 0.42
 ENERGY COST/NET BLDG AREA: 0.42

 UTILITY-RATE: ELEC-COST
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR

PURCHASED-ELEC USE: YEARLY													
METERED ENERGY:	398717	363555	419613	415051	384807	513304	610511	581154	432416	381334	389084	412079	
BILLING ENERGY:	398717	363555	419613	415051	384807	513304	610511	581154	432416	381334	389084	412079	5301624
KWH/KW DEMAND:	2764.1	2764.1	2764.1	2764.1	2764.1	2932.9	3071.3	2899.3	2764.1	2764.1	2764.1	2764.1	
ENERGY CHGS(\$):	12847	11968	13369	13255	12499	15881	18449	17543	13690	12413	12606	13181	167702

TOTAL ENERGY:	398717	363555	419613	415051	384807	513304	610511	581154	432416	381334	389084	412079	5301624
TOTAL CHARGES (\$):	12847	11968	13369	13255	12499	15881	18449	17543	13690	12413	12606	13181	167702

RATCHETS	TYPE	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

SUMMER-PEAK	HIGHEST	2764.1	2764.1	2764.1	2764.1	2764.1	2764.1	2764.1	2764.1	2764.1	2764.1	2764.1	2764.1

REPORT- ES-E SUMMARY OF UTILITY-RATE:

UTILITY-RATE: GENERATED-POWER

RESOURCE: ELEC-BUY/SELL
METERS:

DEMAND-WINDOW: HOUR
BILLING-DAY: 31

3413. BTU/KWH
RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
MAX-ENERGY: 0.0
MIN-DEMAND: 0.0
MAX-DEMAND: 0.0
QUALIFY-RATE: ALL-MONTHS
USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	297693	297693	1575.2	1575.2	23815	0	0	0	0	6333	0	0.1013	30148
FEB	276595	276595	1575.2	1575.2	22128	0	0	0	0	6333	0	0.1029	28461
MAR	294484	294484	1575.2	1575.2	23559	0	0	0	0	6333	0	0.1015	29892
APR	268182	268182	1575.2	1575.2	21455	0	0	0	0	6333	0	0.1036	27788
MAY	241698	241698	1575.2	1575.2	19336	0	0	0	0	6333	0	0.1062	25669
JUN	334652	334652	1575.2	1575.2	26772	0	0	0	0	6333	0	0.0989	33105
JUL	353139	353139	1575.2	1575.2	28251	0	0	0	0	6333	0	0.0979	34584
AUG	359547	359547	1575.2	1575.2	28764	0	0	0	0	6333	0	0.0976	35097
SEP	265542	265542	1575.2	1575.2	21243	0	0	0	0	6333	0	0.1038	27576
OCT	227007	227007	1575.2	1575.2	18161	0	0	0	0	6333	0	0.1079	24494
NOV	255222	255222	1575.2	1575.2	20418	0	0	0	0	6333	0	0.1048	26751
DEC	302646	302646	1575.2	1575.2	24212	0	0	0	0	6333	0	0.1009	30545
TOTAL	3476407	3476407	1575.2		278113	0	0	0	0	75996		-0.1019	-354108

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 5 POWERED INDUCTION UNITS DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 5
 SINGLE-ZONE UNIT IN BASEMENT
 REPORT- ES-E SUMMARY OF UTILITY-RATE: GAS-COST1

UTILITY-RATE: GAS-COST1 RESOURCE: COGEN-GAS DEMAND-WINDOW: HOUR 90000. BTU/THERMS
 METERS: 2 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERMS	BILLING ENERGY THERMS	METERED DEMAND THERMS/H	BILLING DEMAND THERMS/H	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	32403	32403	169.8	169.8	14581	0	0	0	0	0	0	0.4500	14581
FEB	30223	30223	169.8	169.8	13600	0	0	0	0	0	0	0.4500	13600
MAR	32275	32275	169.8	169.8	14524	0	0	0	0	0	0	0.4500	14524
APR	29235	29235	169.8	169.8	13156	0	0	0	0	0	0	0.4500	13156
MAY	26264	26264	169.8	169.8	11819	0	0	0	0	0	0	0.4500	11819
JUN	36301	36301	169.8	169.8	16335	0	0	0	0	0	0	0.4500	16335
JUL	38185	38185	169.8	169.8	17183	0	0	0	0	0	0	0.4500	17183
AUG	38962	38962	169.8	169.8	17533	0	0	0	0	0	0	0.4500	17533
SEP	28806	28806	169.8	169.8	12963	0	0	0	0	0	0	0.4500	12963
OCT	24703	24703	169.8	169.8	11116	0	0	0	0	0	0	0.4500	11116
NOV	27894	27894	169.8	169.8	12552	0	0	0	0	0	0	0.4500	12552
DEC	33074	33074	169.8	169.8	14883	0	0	0	0	0	0	0.4500	14883
TOTAL	378325	378325	169.8		170246	0	0	0	0	0		0.4500	170246

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 5 POWERED INDUCTION UNITS DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 5
 SINGLE-ZONE UNIT IN BASEMENT
 REPORT- ES-B SUMMARY OF UTILITY-RATE: GAS-COST2

UTILITY-RATE: GAS-COST2 RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	6912	6912	140.9	140.9	3456	0	0	0	0	0	0	0.5000	3456
FEB	3095	3095	88.7	88.7	1548	0	0	0	0	0	0	0.5000	1548
MAR	1381	1381	78.2	78.2	691	0	0	0	0	0	0	0.5000	691
APR	567	567	52.5	52.5	283	0	0	0	0	0	0	0.5000	283
MAY	276	276	21.6	21.6	138	0	0	0	0	0	0	0.5000	138
JUN	752	752	84.3	84.3	376	0	0	0	0	0	0	0.5000	376
JUL	6430	6430	144.2	144.2	3215	0	0	0	0	0	0	0.5000	3215
AUG	2023	2023	78.9	78.9	1012	0	0	0	0	0	0	0.5000	1012
SEP	288	288	24.3	24.3	144	0	0	0	0	0	0	0.5000	144
OCT	374	374	23.1	23.1	187	0	0	0	0	0	0	0.5000	187
NOV	1212	1212	94.7	94.7	606	0	0	0	0	0	0	0.5000	606
DEC	2637	2637	92.4	92.4	1318	0	0	0	0	0	0	0.5000	1318
TOTAL	25948	25948	144.2		12974	0	0	0	0	0		0.5000	12974

31-Story Office Building, LOAD2 — Run 6 Systems, Plant, Economics

SDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993SDL RUN 6

```

*1613 * TITLE LINE-2 * RUN 6 PACKAGED HEAT PUMPS ON PERIMETER *
*1614 *   LINE-4 * PKG HEAT PUMPS INTERIOR WITH HW COILS * ..
*1615 *
*1616 *           $ HVAC SYSTEMS DESCRIPTION
*1617 *
*1618 * $ DESIGN TEMPS   COOLING 76F HEATING 70F
*1619 * $ SYSTEM TYPES  PACKAGED SELF-CONTAINED AIR/AIR HEAT PUMPS SERVE ALL
*1620 * $                AREAS OF THE BUILDING. THE PERIMETER UNITS ARE NOT
*1621 * $                DEPENDED UPON FOR OUTSIDE AIR SO THE INTERIOR UNITS
*1622 * $                SUPPLY ALL MINIMUM VENTILATION EQUIVALENT TO 20 CFM/PERSON.
*1623 * $                THE INTERIOR HEAT PUMP UNITS ARE MODELED AS ONE PER FLOOR
*1624 * $                AND ARE EQUIPPED WITH ECONOMIZER DAMPERS (LIMIT 55F) AND
*1625 * $                CONDENSER HEAT IS AVAILABLE FOR REHEAT TO MAINTAIN 55% RH.
*1626 *
*1627 * $                THE PERIMETER UNIT (PTAC) FANS ARE SET TO
*1628 * $                RUN FROM 7AM TO 6PM WEEKDAYS.
*1629 * $                HOWEVER, THE FANS CAN START AS EARLY AS 5AM TO LIMIT THE
*1630 * $                ELECTRIC DEMAND CAUSED BY THE ELECTRIC RESISTANCE COILS IN
*1631 * $                THE UNITS. AT NIGHT THE SETBACK IS 60F AND ONLY THE
*1632 * $                PERIMETER UNITS ARE ALLOWED TO OPERATE. THE INTERIOR UNITS
*1633 * $                (PSZ) ARE ALSO HEAT PUMPS; HOWEVER, THEY HAVE HOT WATER
*1634 * $                COILS FOR SUPPLEMENTAL HEAT SINCE OA VENTILATION IS
*1635 * $                THE MAJOR HEATING LOAD ON THE BUILDING SYSTEM.
*1636 *
*1637 * SYSTEMS-REPORT S (SS-A,SS-D,SS-J) ..
*1638 *
*1639 * FANSON  SCH THRU DEC 31 (WD) (1,5)(0) (6,7)(-999) (8,18)(1) (19,24) (0)
*1640 *                (WEH) (1,24) (0) ..
*1641 *
*1642 * HEAT-SETPT SCH THRU DEC 31 (WD) (1,6)(60) (7)(65) (8,18)(70) (19,24)(60)
*1643 *                (WEH) (1,24) (60) ..
*1644 * COOL-SETPT SCH THRU DEC 31 (WD) (1,7) (99) (8,18) (76) (19,24) (99)
*1645 *                (WEH) (1,24) (99) ..
*1646 *
*1647 * OA-DAMP-POS SCH THRU DEC 31 (ALL) (1,8)(.01) (9,18)(-999) (19,24)(.01) ..
*1648 *
*1649 * ENV  ZONE-CONTROL  D-H-T 70  D-C-T 74  H-T-SCH HEAT-SETPT  C-T-SCH COOL-SETPT ..
*1650 *
*1651 * RZ1  Z  Z-C ENV  OUTSIDE-AIR-CFM 2500  S-O ADJUST-LOADS  CFM/SQFT .9  ..
*1652 * RZ2  Z  LIKE RZ1  O-A-CFM 0  ..
*1653 * RZ3  Z  LIKE RZ2  ..
*1654 * RZ4  Z  LIKE RZ2  ..
*1655 * RZ5  Z  LIKE RZ2  ..
*1656 * TZ1  Z  Z-C ENV  O-A-CFM 2500  CFM/SQFT .9  ..
*1657 * TZ2  Z  LIKE TZ1  O-A-CFM 0  ..
*1658 * TZ3  Z  LIKE TZ2  ..
*1659 * TZ4  Z  LIKE TZ2  ..
*1660 * TZ5  Z  LIKE TZ2  ..
*1661 * PLEN1 Z  Z-TYPE PLENUM  S-O ADJUST-LOADS  D-H-T 50  D-C-T 90  ..
*1662 * PLEN2 Z  Z-TYPE PLENUM  ..
*1663 * A-STORAGE Z  LIKE RZ1  AIR-CHANGES/HR 4  OA-CHANGES .5  ..
*1664 *
*1665 * PERSYS  SYSTEM  S-TYPE=PTAC  MAX-S-T=105  MIN-S-T=55  S-S=.20  S-E=.35
*1666 *                N-C-C=CYCLE-ON-ANY  F-SCH=FANSON  MIN-HP-T = 40
*1667 *                Z-N=(RZ2,RZ3,RZ4,RZ5,TZ2,TZ3,TZ4,TZ5)  HEAT-SOURCE=HEAT-PUMP

```

```

*1668 *          LOW-SPEED-RATIOS=(.5,.6,.5,.55) ..
*1669 *
*1670 * CORESY1 SYSTEM S-TYPE=PSZ MAX-S-T= 105 MIN-S-T= 55 S-S= 2.5 S-E= .50
*1671 *          MIN-AIR-SCH=OA-DAMP-POS REHEAT-DELTA-T=10 MAX-COND-RCVRY=.60
*1672 *          ECONO-LIMIT-T=55 HEAT-SOURCE=HEAT-PUMP MAX-HP-SUPP-T=40
*1673 *          MIN-HP-T= 25 MIN-HGB-RATIO= .10 MIN-UNLOAD-RATIO= .33
*1674 *          RETURN-AIR-PATH= PLENUM-ZONES PLENUM-NAMES= (PLEN1)
*1675 *          ZONE-NAMES= (RZ1,PLEN1) HP-SUPP-SOURCE= HOT-WATER
*1676 *          FAN-SCHEDULE= FANSON MAX-HUMIDITY= 55 ..
*1677 *
*1678 * CORESY2 SYSTEM LIKE CORESY1 P-N (PLEN2) 2-N (TZ1,PLEN2) ..
*1679 *
*1680 * BASEMT SYSTEM S-TYPE= PSZ MAX-S-T= 105 MIN-S-T= 55 S-S= 2.5 S-E= .5
*1681 *          HEAT-SOURCE= HOT-WATER 2-N= (A-STORAGE) F-SCH= FANSON ..
*1682 *
*1683 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (PERSYS,CORESY1,
*1684 *          CORESY2,BASEMT)
*1685 *          INT-ELEC-KW = 100 $ FOR ELEVATORS
*1686 *          INT-ELEC-SCH = OCCUP
*1687 *          DHW-SIZE=0
*1688 *          DHW-GAL/MIN = 2.22
*1689 *          DHW-SCH = OCCUP ..
*1690 *
*1691 * OC1          =DAY-SCHEDULE (1,8) (0.) (9,10) (1.)
*1692 *          (11,13) (.8,.4,.8) (14,24) (1..1..1..
*1693 *          .3,.1,.1,.1,0..0..0..0..) ..
*1694 * OC2          =DAY-SCHEDULE (1,24) (0.0) ..
*1695 * PEOPLE       =WEEK-SCHEDULE (MON,FRI) OC1 (WEH) OC2 ..
*1696 * OCCUP       =SCHEDULE THRU DEC 31 PEOPLE ..
*1697 *
*1698 * END ..
*1699 * COMPUTE SYSTEMS ..
*1700 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993PDL RUN 6

```

*1701 * PLANT1 = PLANT-ASSIGNMENT ..
*1702 *
*1703 * PLANT-REPORT S (PS-A,PS-B,PS-C,PS-D,BEPS) ..
*1704 *
*1705 * $ THIS PLANT USES TWO 300KW TURBOCHARGED GAS ENGINE GENERATORS
*1706 * $ FOR PEAK SHAVING - 2 WINTER & 1 SUMMER. A CURVE FIT HAS BEEN ENTERED TO
*1707 * $ CONVERT THE SIMULATION OF A DIESEL DRIVEN GENERATOR TO GAS ENGINE DRIVEN.
*1708 * $ THERE IS NO ATTEMPT TO RECOVER HEAT FROM THE GAS ENGINE AS IT WILL ONLY
*1709 * $ RUN DURING WEEKDAYS AND FOR VERY SHORT PERIODS. THERE IS ALSO A GAS FIRED HOT
*1710 * $ WATER GENERATOR PROVIDE THE HEATING REQUIRED BY THE INTERIOR AIR SYSTEM
*1711 * $ WHICH HAS HOT WATER HEATING COILS TO SUPPLEMENT THE HEAT PUMPS.
*1712 *
*1713 * $ NOTE THAT REPORT PS-C INDICATES THAT THE GENERATORS OPERATE
*1714 * $ 315 HOURS TO REDUCE THE RATCHETED DEMAND BY 600KW DURING WINTER. THIS REDUCTIO
*1715 * $ IN DEMAND CAN BE ACCOMPLISHED IN OTHER WAYS, SUCH AS STAGING STARTUP TIMES FOR
*1716 * $ BANKS OF PTAC UNITS, OR BY SHEDDING UNITS THROUGH AN ENERGY MANAGEMENT SYSTEM.
*1717 * $ BUT MODELING IN THIS MANNER SERVES AS PROXY FOR THESE OTHER STRATEGIES AND
*1718 * $ ALLOWS ONE TO EXPLORE THE BENEFITS, COST SAVINGS, AND EXTENT OF THE EFFORT
*1719 * $ REQUIRED TO PERFORM FULLY AND RELIABLY THE ENERGY MANAGEMENT STRATEGY.
*1720 *
*1721 * GAS-ENG P-E TYPE DIESEL-GEN SIZE 1.02 I-N 2
*1722 * FUEL-METER = M2 .. $ TO SEPARATE THIS GAS FROM OTHER USES
*1723 * HWG P-E TYPE HW-BOILER SIZE 15.0 I-N 1 ..
*1724 *
*1725 * DWH P-E TYPE DHW-HEATER SIZE .10 I-N 1 ..
*1726 *
*1727 * PLANT-PARAMETERS DIESEL-GEN-EFF .30 ..
*1728 *
*1729 * GAS-ENGINE CURVE-FIT TYPE=LINEAR COEF=(.2,.8) ..
*1730 *
*1731 * EQUIPMENT-QUAD DIESEL-I/O-FPLR= GAS-ENGINE ..
*1732 *
*1733 * PEAK-SHAVE LOAD-ASSIGNMENT TYPE= ELECTRICAL L-R= 99
*1734 * P-E= GAS-ENG N= 2
*1735 * P-E= UTILITY N= 99 ..
*1736 *
*1737 * NORMAL-OP LOAD-ASSIGNMENT TYPE= ELECTRICAL L-R= 99
*1738 * P-E= UTILITY N= 99 ..
*1739 *
*1740 * LOAD-MANAGEMENT PRED-L-R= 9 L-A= (DEFAULT,DEFAULT,NORMAL-OP)
*1741 * PRED-L-R= 100 L-A= (DEFAULT,DEFAULT,PEAK-SHAVE) ..
*1742 *
*1743 * ENERGY-RESOURCE RESOURCE ELECTRICITY ..
*1744 * ENERGY-RESOURCE RESOURCE NATURAL-GAS ENERGY/UNIT = 100000
*1745 * UNIT-NAME = THERMS FUEL-METERS = (M1,M2) ..
*1746 * END ..
*1747 * COMPUTE PLANT ..
*1748 * INPUT ECONOMICS ..

```

EDL PROCESSOR INPUT DATA

Wed Nov 10 14:35:12 1993EDL RUN 6

```

*1749 *
*1750 *           $ ENERGY CHARGE DESCRIPTION
*1751 *
*1752 * $ THIS IS A SIMPLE UNIFORM RATE FOR BOTH ENERGY AND DEMAND IN WHICH THE
*1753 * $ WINTER AND SUMMER CHARGES ARE DIFFERENT. THE
*1754 * $ DEMAND CHARGE FOR SUMMER CARRIES FOR THE WHOLE YEAR AT 15 DOLLARS/KW
*1755 * $ WITH A 100% RATCHET.
*1756 * $ A 10 DOLLAR/KW CHARGE WITH A 85% RATCHET IS LIMITED TO THE WINTER SEASON.
*1757 * $ THE METHOD OF CALCULATING THE SUMMER RATCHET IS BY SEARCHING FOR THE HIGHEST
*1758 * $ MONTH, WHEREAS THE WINTER IS THE RUNNING AVERAGE OF 2 CONSECUTIVE MONTHS.
*1759 *
*1760 * ECONOMICS-REPORT S=(ES-D,ES-E,ES-F) ..
*1761 *
*1762 * ELEC-COST = UTILITY-RATE  RESOURCE = ELECTRICITY
*1763 *                               ENERGY-CHG = .05
*1764 *                               MONTH-CHGS = (500,500,500,1000,1000,1000,
*1765 *                               1000,1000,1000,500,500,500)
*1766 *                               BLOCK-CHARGES = (SUMMER-DEMAND,WINTER-DEMAND)
*1767 *                               DEMAND-RATCHETS = (WIN-RATCHET,SUM-RATCHET) ..
*1768 *
*1769 * SUMMER-DEMAND = BLOCK-CHARGE  BLOCK-SCH      = SEASON
*1770 *                               SCH-FLAG      = 2
*1771 *                               BLOCK1-TYPE   = DEMAND
*1772 *                               BLOCK1-DATA   = (1,15) ..
*1773 *
*1774 * WINTER-DEMAND = BLOCK-CHARGE  BLOCK-SCH      = SEASON
*1775 *                               SCH-FLAG      = 1
*1776 *                               BLOCK1-TYPE   = DEMAND
*1777 *                               BLOCK1-DATA   = (1,10) ..
*1778 *
*1779 * WIN-RATCHET   = RATCHET      NUM-MONTHS = 2
*1780 *                               TYPE         = AVERAGE
*1781 *                               FRACTION    = .85
*1782 *                               SCH-FLAG    = 1
*1783 *                               RATCHET-SCH = SEASON ..
*1784 *
*1785 * SUM-RATCHET   = RATCHET      NUM-MONTHS = 12
*1786 *                               TYPE         = HIGHEST-PEAK
*1787 *                               FRACTION    = 1.0
*1788 *                               SCH-FLAG    = 2
*1789 *                               RATCHET-SCH = SEASON ..
*1790 *
*1791 * SEASON      = SCHEDULE
*1792 *                               THRU APR 12 (ALL) (1,24)(1)
*1793 *                               THRU OCT 18 (ALL) (1,24)(2)
*1794 *                               THRU DEC 31 (ALL) (1,24)(1) ..
*1795 *
*1796 * GAS-COST = UTILITY-RATE  RESOURCE = NATURAL-GAS
*1797 *                               ENERGY-CHG = .6 ..
*1798 *
*1799 * END ..
*1800 * COMPUTE ECONOMICS ..
*1801 * STOP ..

```


SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE							
PERSYS	PTAC		1.020	251124.8		2976.							
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
	592471.	0.000	0.2	0.	0.000	0.0	0.000	0.000	0.000	0.000	0.44	0.37	-37.691
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER		
R22	859.	0.	0.057	1.000	0.	21.19	0.74	17.29	-25.08	-31.71	8.0		
R23	498.	0.	0.033	1.000	0.	12.92	0.71	10.01	-15.30	-18.36	4.0		
R24	844.	0.	0.056	1.000	0.	20.26	0.76	16.98	-23.98	-31.15	8.0		
R25	1028.	0.	0.066	1.000	0.	24.79	0.76	20.68	-29.34	-37.93	4.0		
T22	843.	0.	0.055	1.000	0.	20.72	0.74	16.97	-24.52	-31.12	240.0		
T23	439.	0.	0.029	1.000	0.	11.48	0.71	8.83	-13.59	-16.19	120.0		
T24	824.	0.	0.054	1.000	0.	20.48	0.73	16.58	-24.24	-30.41	240.0		
T25	999.	0.	0.066	1.000	0.	24.11	0.75	20.10	-28.54	-36.87	120.0		

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
CORESY1	PSZ	1.020	11900.0	60.									
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
	10924.	6.285	1.8	0.	0.000	0.0	0.233	431.657	0.633	-419.990	0.36	0.37	-604.210
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	RZ1	10924.	0.	0.000	1.000	2550.	0.00	0.00	224.16	-117.98	-412.93	1.0	
	PLEN1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 6 PACKAGED HEAT PUMPS ON PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993SDL RUN 6
 PKG HEAT PUMPS INTERIOR WITH HW COILS -
 REPORT- SV-A SYSTEM DESIGN PARAMETERS CORESY2 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
CORESY2	PSZ	1.020	357000.0	1800.									
	SUPPLY FAN (CFM)	ELEBC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEBC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
	327726.	188.556	1.8	0.	0.000	0.0	0.233	13082.682	0.631	-12729.096	0.36	0.37	-17996.645
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	TZ1	10924.	0.	0.000	1.000	2550.	0.00	0.00	224.16	-117.98	-412.93	30.0	
	PLEN2	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	30.0	

REPORT- SV-A SYSTEM DESIGN PARAMETERS

BASEMT

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE							
BASEMT	PS2	1.020	20000.0	0.							
SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
27200.	15.649	1.8	0.	0.000	0.0	0.094	834.338	0.699	-1151.763	0.36	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
A-STORAGE	27200.	0.	0.000	1.000	2550.	0.00	0.00	558.14	0.00	-1028.16	1.0

- - - - - C O O L I N G - - - - -					- - - - - H E A T I N G - - - - -					- - - E L E C - - -		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-560.404	4 7	2.F	2.F	-16832.686	606630.	2649.032
FEB	0.00000				0.000	-353.349	8 7	5.F	5.F	-9447.347	548446.	2741.655
MAR	0.00000				0.000	-98.999	24 9	7.F	6.F	-4634.541	560728.	2511.064
APR	0.00000				0.000	-2.870	19 7	38.F	36.F	-135.569	537194.	2772.286
MAY	0.00000				0.000	0.000				0.000	515266.	3056.260
JUN	0.00000				0.000	0.000				0.000	642143.	3263.217
JUL	0.00000				0.000	0.000				0.000	711013.	3805.724
AUG	0.00000				0.000	0.000				0.000	688815.	3342.623
SEP	0.00000				0.000	0.000				0.000	565035.	3016.656
OCT	0.00000				0.000	0.000	4 8	49.F	41.F	-0.001	478891.	2616.646
NOV	0.00000				0.000	-1.909	29 7	28.F	27.F	-200.758	512426.	2726.561
DEC	0.00000				0.000	-79.629	20 7	23.F	22.F	-7772.390	621687.	3066.273
TOTAL	0.000					-1097.161					6988178.	
MAX					0.000					-16832.686		3805.724

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 0.000 (KBTU)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 0.000 (KBTU)

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	3002.	71.101	43.773	0.228	0.000	0.000	0.000	0.000	38.928
FEB	4890.	112.129	65.522	0.206	0.000	0.000	0.000	0.000	39.994
MAR	10278.	235.424	165.651	0.194	0.000	0.000	-16.891	0.000	38.805
APR	34341.	876.052	452.409	0.103	0.000	0.000	-175.015	0.000	93.752
MAY	42321.	1197.330	585.963	0.057	0.000	0.000	-331.266	0.000	126.760
JUN	60895.	2227.109	927.511	0.002	0.000	0.000	-855.999	0.000	184.579
JUL	74038.	3045.257	1203.019	0.000	0.000	0.000	-1299.914	0.000	189.988
AUG	66131.	2727.716	1068.362	0.000	0.000	0.000	-1148.027	0.000	194.969
SEP	41827.	1454.120	685.753	0.029	0.000	0.000	-530.553	0.000	154.160
OCT	23483.	634.922	384.438	0.094	0.000	0.000	-155.266	0.000	102.097
NOV	9840.	272.607	163.251	0.181	0.000	0.000	-55.189	0.000	42.261
DEC	2136.	50.620	29.866	0.215	0.000	0.000	-0.053	0.000	14.612
ANNUAL	373182.	12904.387	5775.517	1.307	0.000	0.000	-4568.173	0.000	1220.905

CSPP (WITH PARASITICS) = 1.84 (BTU/BTU)
 CSPP (WITHOUT PARASITICS) = 2.23 (BTU/BTU)

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	601.	-229.743	216.820	0.105	-1093.122	1118.976	0.000	0.000	0.000	136.748
FEB	873.	-275.077	229.612	0.095	-745.346	835.283	0.000	0.000	0.000	126.690
MAR	1263.	-190.148	217.469	0.097	-251.684	348.623	0.000	0.000	0.000	156.672
APR	912.	-29.271	73.197	0.058	-33.808	75.602	0.000	0.000	0.000	87.262
MAY	141.	-4.231	11.766	0.031	-1.722	4.900	0.000	0.000	0.000	37.685
JUN	0.	0.000	0.427	0.001	0.000	0.000	0.000	0.000	0.000	6.821
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.068
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.950
SEP	44.	-1.223	5.910	0.016	-1.897	4.215	0.000	0.000	0.000	22.185
OCT	801.	-14.516	37.153	0.053	-9.583	26.725	0.000	0.000	0.000	59.401
NOV	1349.	-232.605	208.562	0.090	-145.872	302.443	0.000	0.000	0.000	124.209
DEC	805.	-493.906	410.498	0.091	-433.223	733.929	0.000	0.000	0.000	168.024
ANNUAL	6788.	-1470.721	1411.415	0.637	-2716.257	3450.696	0.000	0.000	0.000	928.715

HSPF (WITH PARASITICS) = 0.88 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 0.86 (BTU/BTU)

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	71.10081	25 15	47.F	42.F	2832.155	-561.895	12 7	-6.F	-7.F	-6938.614	278176.	2083.120
FEB	112.12880	25 16	27.F	22.F	3870.774	-420.456	4 7	6.F	5.F	-5891.914	231497.	1773.323
MAR	217.68666	3 15	76.F	65.F	5229.958	-179.899	24 7	6.F	5.F	-4523.889	195998.	1356.587
APR	690.48712	27 16	82.F	61.F	7096.853	-41.793	8 7	32.F	29.F	-3850.892	201114.	1221.312
MAY	836.36127	20 15	76.F	67.F	7605.961	-3.178	6 8	37.F	33.F	-808.234	193072.	1295.029
JUN	1178.62756	4 16	85.F	67.F	8359.129	0.000				0.000	238409.	1381.989
JUL	1395.03625	13 16	97.F	77.F	8973.516	0.000				0.000	267659.	1605.157
AUG	1263.06702	19 16	90.F	71.F	8468.173	0.000				0.000	254921.	1453.328
SEP	836.97095	17 16	82.F	66.F	7991.283	-2.318	22 8	34.F	31.F	-834.356	207279.	1314.868
OCT	488.14542	5 16	74.F	62.F	6163.937	-17.142	21 7	30.F	29.F	-1689.064	174905.	1069.788
NOV	210.97493	8 15	60.F	49.F	5984.566	-157.509	15 7	27.F	25.F	-4795.658	183456.	1450.356
DEC	50.57640	10 15	41.F	35.F	3256.550	-369.000	9 7	13.F	12.F	-4625.953	224671.	1449.199
TOTAL	7351.176					-1753.190					2651130.	
MAX					8973.516					-6938.614		2083.120

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	3002.	71.101	43.773	0.000	0.000	0.000	0.000	0.534
FEB	4890.	112.129	65.522	0.000	0.000	0.000	0.000	0.885
MAR	10272.	217.687	155.236	0.000	0.000	0.000	0.000	1.358
APR	34289.	690.487	346.282	0.000	0.000	0.000	0.000	4.574
MAY	42230.	836.361	392.750	0.000	0.000	0.000	0.000	5.693
JUN	60694.	1178.628	535.701	0.000	0.000	0.000	0.000	8.280
JUL	73744.	1395.036	641.517	0.000	0.000	0.000	0.000	11.142
AUG	65871.	1263.067	580.271	0.000	0.000	0.000	0.000	9.101
SEP	41689.	836.971	409.189	0.000	0.000	0.000	0.000	5.813
OCT	23429.	488.145	270.375	0.000	0.000	0.000	0.000	3.228
NOV	9822.	210.975	132.275	0.000	0.000	0.000	0.000	1.432
DEC	2136.	50.576	29.822	0.000	0.000	0.000	0.000	0.362
ANNUAL	372068.	7351.163	3602.714	0.000	0.000	0.000	0.000	52.401

CSPF (WITH PARASITICS) = 2.01 (BTU/BTU)
 CSPF (WITHOUT PARASITICS) = 2.04 (BTU/BTU)

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	499.	-4.814	6.572	0.000	-557.081	1118.976	0.000	0.000	0.000	3.239
FEB	760.	-5.629	9.726	0.000	-414.827	835.283	0.000	0.000	0.000	2.378
MAR	1173.	-11.175	14.659	0.000	-168.724	348.623	0.000	0.000	0.000	1.007
APR	893.	-7.985	11.239	0.000	-33.808	75.602	0.000	0.000	0.000	0.229
MAY	138.	-1.455	2.676	0.000	-1.722	4.900	0.000	0.000	0.000	0.018
JUN	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SEP	44.	-0.421	1.379	0.000	-1.897	4.215	0.000	0.000	0.000	0.013
OCT	792.	-7.559	10.563	0.000	-9.583	26.725	0.000	0.000	0.000	0.095
NOV	1254.	-12.574	17.337	0.000	-144.934	302.443	0.000	0.000	0.000	0.876
DEC	605.	-4.072	7.770	0.000	-364.929	733.929	0.000	0.000	0.000	2.093
ANNUAL	6158.	-55.685	81.920	0.000	-1697.505	3450.696	0.000	0.000	0.000	9.947

HSPF (WITH PARASITICS) = 0.50 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 0.50 (BTU/BTU)

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-49.982	4 6	3.F 3.F		-630.566	11204.	68.011
FEB	0.00000				0.000	-41.290	8 7	5.F 5.F		-527.026	10809.	72.539
MAR	0.35130	3 14	74.F	64.F	177.610	-26.101	1 7	28.F 26.F		-350.827	12694.	65.774
APR	3.12756	28 15	78.F	68.F	128.748	-5.252	8 7	32.F 29.F		-181.151	10455.	50.841
MAY	7.69900	21 13	87.F	76.F	214.365	-0.915	10 7	41.F 39.F		-146.166	9333.	52.800
JUN	30.05409	21 16	82.F	72.F	271.985	0.000				0.000	11912.	58.112
JUL	55.32556	19 14	90.F	75.F	342.844	0.000				0.000	13552.	69.549
AUG	46.67692	16 16	86.F	73.F	290.667	0.000				0.000	12998.	62.229
SEP	14.40371	10 16	82.F	70.F	200.241	-0.253	23 9	39.F 36.F		-32.541	10312.	51.600
OCT	1.45965	12 10	63.F	61.F	170.105	-2.828	21 7	30.F 29.F		-159.663	8972.	47.615
NOV	1.11517	2 16	77.F	62.F	94.408	-20.489	29 7	28.F 27.F		-424.236	11432.	69.041
DEC	0.00000				0.000	-39.674	27 7	31.F 30.F		-528.149	14209.	73.763
TOTAL	160.213					-186.782					137878.	
MAX					342.844					-630.566		73.763

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	JUL 19				JAN 4			JUL 19			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	79.F	72.F	0.000	6.F	6.F	0.000	0.000	79.F	72.F
2	0.000	0.000	79.F	72.F	0.000	5.F	5.F	0.000	0.000	79.F	72.F
3	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
4	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
5	0.000	0.000	77.F	72.F	0.000	3.F	3.F	0.000	0.000	77.F	72.F
6	271.403	0.981	78.F	72.F	-630.566	3.F	3.F	271.403	0.981	78.F	72.F
7	289.034	0.984	77.F	72.F	-515.655	2.F	2.F	289.034	0.984	77.F	72.F
8	325.670	0.735	79.F	72.F	-484.139	2.F	2.F	325.670	0.735	79.F	72.F
9	329.249	0.740	82.F	72.F	-622.435	4.F	3.F	329.249	0.740	82.F	72.F
10	331.076	0.743	85.F	73.F	-574.187	7.F	6.F	331.076	0.743	85.F	73.F
11	338.617	0.751	88.F	74.F	-561.365	11.F	9.F	338.617	0.751	88.F	74.F
12	329.977	0.746	89.F	74.F	-518.553	16.F	13.F	329.977	0.746	89.F	74.F
13	342.844	0.731	90.F	75.F	-507.017	18.F	15.F	342.844	0.731	90.F	75.F
14	338.400	0.726	89.F	75.F	-473.255	20.F	16.F	338.400	0.726	89.F	75.F
15	337.602	0.734	90.F	75.F	-442.998	20.F	16.F	337.602	0.734	90.F	75.F
16	322.681	0.726	91.F	76.F	-420.390	20.F	16.F	322.681	0.726	91.F	76.F
17	301.943	0.738	90.F	75.F	-420.539	19.F	15.F	301.943	0.738	90.F	75.F
18	0.000	0.000	86.F	74.F	-428.133	16.F	13.F	0.000	0.000	86.F	74.F
19	0.000	0.000	86.F	74.F	0.000	13.F	11.F	0.000	0.000	86.F	74.F
20	0.000	0.000	80.F	72.F	0.000	11.F	9.F	0.000	0.000	80.F	72.F
21	0.000	0.000	79.F	72.F	0.000	10.F	8.F	0.000	0.000	79.F	72.F
22	0.000	0.000	77.F	71.F	0.000	11.F	9.F	0.000	0.000	77.F	71.F
23	0.000	0.000	76.F	71.F	0.000	7.F	6.F	0.000	0.000	76.F	71.F
24	0.000	0.000	74.F	70.F	0.000	6.F	5.F	0.000	0.000	74.F	70.F
SUM								3858.496			
MAX	342.844				-630.566						

SYSTEM-TYPE	PSZ	SQFT/TON	416.5
COOLING PEAK	28.81 (BTU/HR- SQFT)	HEATING PEAK	-52.99 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	0.92 (CFM/SQFT)	MIN-OA/PERSON	42.50 (CFM)
OA FRAC AT CLG PEAK	0.233	OA FRAC AT HTG PEAK	0.010

* ASTERISKS INDICATE HOURS LOADS NOT MET

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	0.	0.000	0.000	0.051	0.000	0.000	0.000	0.000	1.040
FEB	0.	0.000	0.000	0.046	0.000	0.000	0.000	0.000	1.030
MAR	1.	0.351	0.109	0.039	0.000	0.000	-0.276	0.000	0.472
APR	20.	3.128	2.074	0.021	0.000	0.000	-3.121	0.000	1.523
MAY	40.	7.699	4.387	0.013	0.000	0.000	-7.252	0.000	2.842
JUN	89.	30.054	12.103	0.001	0.000	0.000	-25.294	0.000	5.395
JUL	127.	55.326	18.621	0.000	0.000	0.000	-44.368	0.000	5.406
AUG	109.	46.677	15.546	0.000	0.000	0.000	-37.334	0.000	5.642
SEP	60.	14.404	7.448	0.006	0.000	0.000	-13.111	0.000	4.119
OCT	14.	1.460	0.822	0.019	0.000	0.000	-1.369	0.000	1.105
NOV	7.	1.115	0.799	0.037	0.000	0.000	-1.148	0.000	0.579
DEC	0.	0.000	0.000	0.044	0.000	0.000	0.000	0.000	0.225
ANNUAL	467.	160.213	61.908	0.276	0.000	0.000	-133.273	0.000	29.377

CSPF (WITH PARASITICS) = 1.75 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 2.59 (BTU/BTU)

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	75.	-18.911	11.695	0.051	-31.026	0.000	0.000	0.000	4.129
FEB	79.	-19.717	11.806	0.046	-21.573	0.000	0.000	0.000	3.861
MAR	70.	-20.461	13.111	0.041	-5.640	0.000	0.000	0.000	5.427
APR	17.	-5.252	5.054	0.026	0.000	0.000	0.000	0.000	3.883
MAY	2.	-0.915	1.402	0.016	0.000	0.000	0.000	0.000	1.920
JUN	0.	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.054
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SEP	1.	-0.253	0.561	0.008	0.000	0.000	0.000	0.000	0.901
OCT	8.	-2.828	3.633	0.025	0.000	0.000	0.000	0.000	3.743
NOV	70.	-19.552	11.898	0.042	-0.937	0.000	0.000	0.000	4.462
DEC	137.	-33.847	20.778	0.044	-5.827	0.000	0.000	0.000	5.180
ANNUAL	459.	-121.735	79.938	0.299	-65.003	0.000	0.000	0.000	33.560

HSPF (WITH PARASITICS) = 1.94 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 2.34 (BTU/BTU)

----- COOLING -----						----- HEATING -----					----- ELEC -----	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-711.032	4 7	2.F	2.F	-15790.595	290457.	1634.263
FEB	0.00000				0.000	-558.677	8 7	5.F	5.F	-8624.273	280702.	1725.835
MAR	17.38572	3 10	63.F	59.F	3154.287	-235.833	1 7	28.F	26.F	-5492.975	321409.	1558.530
APR	182.43706	28 15	78.F	68.F	4773.467	-16.035	1 7	40.F	37.F	-2005.673	296435.	1424.245
MAY	351.74741	21 13	87.F	76.F	6560.207	-1.861	13 9	47.F	43.F	-316.810	286095.	1644.077
JUN	1008.42896	21 16	82.F	72.F	8109.690	0.000	17 8	54.F	48.F	-0.003	361649.	1738.221
JUL	1562.11914	19 14	90.F	75.F	9760.990	0.000				0.000	398291.	2035.813
AUG	1389.13306	16 15	85.F	73.F	8639.983	0.000				0.000	388669.	1867.276
SEP	595.80469	10 16	82.F	70.F	6049.269	-0.549	23 9	39.F	36.F	-178.341	318866.	1562.074
OCT	143.77969	29 16	64.F	62.F	3011.577	-4.129	21 9	31.F	29.F	-243.529	268247.	1419.950
NOV	60.05118	2 16	77.F	62.F	3750.414	-200.479	29 7	28.F	27.F	-6499.085	290898.	1704.842
DEC	0.04403	2 14	43.F	38.F	44.028	-518.455	27 7	31.F	30.F	-8632.745	354817.	1880.844
TOTAL	5310.937					-2247.051					3856427.	
MAX					9760.990					-15790.595		2035.813

HOUR	- - - - - C O O L I N G - - - - -				- - - H E A T I N G - - -			D A Y C O O L I N G P E A K			
	JUL 19				JAN 4			JUL 19			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	79.F	72.F	0.000	6.F	6.F	0.000	0.000	79.F	72.F
2	0.000	0.000	79.F	72.F	0.000	5.F	5.F	0.000	0.000	79.F	72.F
3	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
4	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
5	0.000	0.000	77.F	72.F	0.000	3.F	3.F	0.000	0.000	77.F	72.F
6	7122.529	0.979	78.F	72.F	0.000	3.F	3.F	7122.529	0.979	78.F	72.F
7	7830.493	0.982	77.F	72.F	-15790.595	2.F	2.F	7830.493	0.982	77.F	72.F
8	9172.132	0.724	79.F	72.F	-11090.229	2.F	2.F	9172.132	0.724	79.F	72.F
9	9321.367	0.729	82.F	72.F	-12985.613	4.F	3.F	9321.367	0.729	82.F	72.F
10	9392.708	0.733	85.F	73.F	-11380.596	7.F	6.F	9392.708	0.733	85.F	73.F
11	9634.715	0.742	89.F	74.F	-10448.363	11.F	9.F	9634.715	0.742	89.F	74.F
12	9367.346	0.736	89.F	74.F	-9437.440	16.F	13.F	9367.346	0.736	89.F	74.F
13	9760.990	0.719	90.F	75.F	-9234.561	18.F	15.F	9760.990	0.719	90.F	75.F
14	9588.977	0.712	89.F	75.F	-8357.281	20.F	16.F	9588.977	0.712	89.F	75.F
15	9522.103	0.719	90.F	75.F	-7801.985	20.F	16.F	9522.103	0.719	90.F	75.F
16	9024.058	0.708	91.F	76.F	-7367.381	20.F	16.F	9024.058	0.708	91.F	76.F
17	8359.319	0.718	90.F	75.F	-7592.999	19.F	15.F	8359.319	0.718	90.F	75.F
18	0.000	0.000	86.F	74.F	-7864.269	16.F	13.F	0.000	0.000	86.F	74.F
19	0.000	0.000	86.F	74.F	0.000	13.F	11.F	0.000	0.000	86.F	74.F
20	0.000	0.000	80.F	72.F	0.000	11.F	9.F	0.000	0.000	80.F	72.F
21	0.000	0.000	79.F	72.F	0.000	10.F	8.F	0.000	0.000	79.F	72.F
22	0.000	0.000	77.F	71.F	0.000	11.F	9.F	0.000	0.000	77.F	71.F
23	0.000	0.000	76.F	71.F	0.000	7.F	6.F	0.000	0.000	76.F	71.F
24	0.000	0.000	74.F	70.F	0.000	6.F	5.F	0.000	0.000	74.F	70.F
SUM	9760.990				-15790.595			108096.742			
MAX											

SYSTEM-TYPE	PSZ	SQFT/TON	438.9
COOLING PEAK	27.34 (BTU/HR- SQFT)	HEATING PEAK	-44.23 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	0.92 (CFM/SQFT)	MIN-OA/PERSON	42.50 (CFM)
OA FRAC AT CLG PEAK	0.233	OA FRAC AT HTG PEAK	0.010

* ASTERISKS INDICATE HOURS LOADS NOT MET

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	0.	0.000	0.000	0.051	0.000	0.000	0.000	0.000	31.212
FEB	0.	0.000	0.000	0.046	0.000	0.000	0.000	0.000	32.177
MAR	5.	17.386	10.305	0.042	0.000	0.000	-16.615	0.000	29.924
APR	32.	182.437	104.052	0.024	0.000	0.000	-171.894	0.000	81.086
MAY	48.	351.747	188.276	0.014	0.000	0.000	-324.014	0.000	111.975
JUN	90.	1008.429	376.077	0.001	0.000	0.000	-830.704	0.000	162.171
JUL	119.	1562.119	530.457	0.000	0.000	0.000	-1255.545	0.000	162.171
AUG	107.	1389.133	462.023	0.000	0.000	0.000	-1110.694	0.000	169.250
SEP	65.	595.805	266.599	0.007	0.000	0.000	-517.442	0.000	136.751
OCT	35.	143.780	112.716	0.023	0.000	0.000	-153.898	0.000	91.382
NOV	10.	60.051	30.016	0.040	0.000	0.000	-54.040	0.000	34.107
DEC	0.	0.044	0.044	0.044	0.000	0.000	-0.053	0.000	7.722
ANNUAL	512.	5310.931	2080.567	0.292	0.000	0.000	-4434.899	0.000	1049.930

CSPP (WITH PARASITICS) = 1.70 (BTU/BTU)

CSPP (WITHOUT PARASITICS) = 2.55 (BTU/BTU)

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	27.	-206.017	198.553	0.054	-505.015	0.000	0.000	0.000	123.237
FEB	34.	-249.730	208.081	0.050	-308.947	0.000	0.000	0.000	114.549
MAR	19.	-158.513	189.699	0.056	-77.320	0.000	0.000	0.000	143.187
APR	2.	-16.035	56.904	0.032	0.000	0.000	0.000	0.000	76.581
MAY	0.	-1.861	7.689	0.015	0.000	0.000	0.000	0.000	30.246
JUN	0.	0.000	0.427	0.001	0.000	0.000	0.000	0.000	2.574
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SEP	0.	-0.549	3.970	0.008	0.000	0.000	0.000	0.000	16.410
OCT	0.	-4.129	22.957	0.028	0.000	0.000	0.000	0.000	50.196
NOV	25.	-200.479	179.327	0.048	0.000	0.000	0.000	0.000	113.262
DEC	62.	-455.988	381.951	0.047	-62.467	0.000	0.000	0.000	154.449
ANNUAL	171.	-1293.301	1249.557	0.339	-953.749	0.000	0.000	0.000	824.692

RSPP (WITH PARASITICS) = 1.48 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 1.80 (BTU/BTU)

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-24.363	4 7	2.F	2.F	-526.436	11592.	44.199
FEB	0.00000				0.000	-22.830	8 7	5.F	5.F	-296.047	10998.	44.199
MAR	0.00000				0.000	-16.039	1 7	28.F	26.F	-232.407	13147.	44.199
APR	0.00000				0.000	-2.870	19 7	38.F	36.F	-135.569	12471.	44.199
MAY	1.52248	21 13	87.F	76.F	163.366	0.000				0.000	11569.	61.408
JUN	9.99842	9 15	83.F	73.F	174.230	0.000				0.000	13455.	62.530
JUL	32.77458	13 17	97.F	78.F	243.872	0.000				0.000	15553.	73.885
AUG	28.83860	26 17	94.F	76.F	244.056	0.000				0.000	15510.	73.095
SEP	6.94092	10 17	83.F	70.F	190.271	0.000				0.000	12619.	65.415
OCT	1.53752	28 17	73.F	60.F	113.666	0.000	4 8	49.F	41.F	-0.001	11568.	55.580
NOV	0.46544	2 16	77.F	62.F	93.764	-0.972	29 8	29.F	27.F	-81.216	11440.	53.254
DEC	0.00000				0.000	-11.335	27 7	31.F	30.F	-215.421	12028.	44.199
TOTAL	82.078					-78.409					151948.	
MAX					244.056					-526.436		73.885

----- COOLING -----				--- HEATING ---			DAY COOLING PEAK				
AUG 26				JAN 4			JUL 13				
HOURLY	SENSIBLE	DRY-	WET-	HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-	
COOLING	HEAT	BULB	BULB	HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB	
LOAD	RATIO	TEMP	TEMP	LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP	
(KBTU)				(KBTU)			(KBTU)				
1	0.000	0.000	68.F	62.F	0.000	6.F	6.F	0.000	0.000	76.F	66.F
2	0.000	0.000	68.F	62.F	0.000	5.F	5.F	0.000	0.000	74.F	66.F
3	0.000	0.000	69.F	62.F	0.000	4.F	4.F	0.000	0.000	74.F	65.F
4	0.000	0.000	69.F	63.F	0.000	4.F	4.F	0.000	0.000	73.F	62.F
5	0.000	0.000	69.F	63.F	0.000	3.F	3.F	0.000	0.000	72.F	62.F
6	0.000	0.000	68.F	62.F	0.000	3.F	3.F	0.000	0.000	72.F	63.F
7	0.000	0.000	68.F	63.F	-526.436	2.F	2.F	133.172	0.797	73.F	65.F
8	0.000	0.000	70.F	65.F	-451.202	2.F	2.F	163.993	0.703	76.F	69.F
9	180.820	0.742	76.F	69.F	-431.067	4.F	3.F	188.855	0.701	82.F	72.F
10	210.128	0.719	82.F	72.F	-400.797	7.F	6.F	205.045	0.695	86.F	74.F
11	218.015	0.726	85.F	73.F	-371.186	11.F	9.F	220.807	0.682	89.F	76.F
12	219.671	0.733	89.F	74.F	-339.994	16.F	13.F	230.983	0.666	93.F	78.F
13	218.920	0.734	89.F	74.F	-325.370	18.F	15.F	229.744	0.689	95.F	78.F
14	231.512	0.724	90.F	75.F	-304.169	20.F	16.F	227.120	0.730	96.F	77.F
15	223.673	0.749	90.F	74.F	-284.785	20.F	16.F	230.313	0.736	97.F	77.F
16	244.056	0.737	94.F	76.F	-270.812	20.F	16.F	243.872	0.710	97.F	78.F
17	227.821	0.748	93.F	75.F	-257.851	19.F	15.F	227.929	0.752	99.F	77.F
18	0.000	0.000	91.F	74.F	-260.725	16.F	13.F	0.000	0.000	97.F	76.F
19	0.000	0.000	89.F	74.F	0.000	13.F	11.F	0.000	0.000	95.F	75.F
20	0.000	0.000	85.F	73.F	0.000	11.F	9.F	0.000	0.000	93.F	75.F
21	0.000	0.000	82.F	72.F	0.000	10.F	8.F	0.000	0.000	90.F	74.F
22	0.000	0.000	81.F	71.F	0.000	11.F	9.F	0.000	0.000	87.F	73.F
23	0.000	0.000	79.F	71.F	0.000	7.F	6.F	0.000	0.000	86.F	73.F
24	0.000	0.000	77.F	70.F	0.000	6.F	5.F	0.000	0.000	85.F	73.F
SUM								2301.832			
MAX	244.056				-526.436						

SYSTEM-TYPE PSZ SQFT/TON 983.4
 COOLING PEAK 12.20 (BTU/HR- SQFT) HEATING PEAK -26.32 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.36 (CFM/SQFT)
 OA FRAC AT CLG PEAK 0.094 OA FRAC AT MTG PEAK 0.094

* ASTERISKS INDICATE HOURS LOADS NOT MET

31-STORY OFFICE BLDG. CHICAGO - LOAD2
 REPORT- PV-A EQUIPMENT SIZES

RUN 6 PACKAGED HEAT PUMPS ON PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993PDL RUN 6
 PKG HEAT PUMPS INTERIOR WITH HW COILS - WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD
	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL
HW-BOILER	15.000	1	1									
DHW-HEATER	0.100	1	1									
DIESEL-GEN	1.020	2	2									

MONTH	S I T E E N E R G Y												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	603.5	0.0	620.6	0.0	0.0	0.0	12.8	883.6	240.7	14.1	897.7	3011.6	7239.9
FEB	395.3	0.0	561.2	0.0	0.0	0.0	19.2	621.4	201.6	21.2	642.6	2551.5	6370.1
MAR	145.3	0.0	568.3	0.0	0.0	0.0	48.5	231.6	120.7	0.0	231.6	2171.1	6050.7
APR	30.0	0.0	539.0	0.0	0.0	0.0	132.6	45.3	33.2	35.4	80.7	1909.7	5568.2
MAY	15.0	0.0	515.3	0.0	0.0	0.0	171.7	22.7	4.0	42.4	65.1	1810.9	5302.9
JUN	15.2	0.0	642.1	0.0	0.0	0.0	271.8	22.9	0.1	318.2	341.1	2436.4	6627.4
JUL	13.5	0.0	711.0	0.0	0.0	0.0	352.5	20.6	0.0	954.7	975.3	3112.8	7388.4
AUG	13.7	0.0	688.8	0.0	0.0	0.0	313.0	20.9	0.0	678.9	699.9	2845.1	7136.3
SEP	13.5	0.0	565.0	0.0	0.0	0.0	200.9	20.5	2.3	127.3	147.8	2037.7	5818.0
OCT	13.8	0.0	478.9	0.0	0.0	0.0	112.6	21.0	13.7	0.0	21.0	1655.5	4925.1
NOV	22.4	0.0	513.5	0.0	0.0	0.0	47.8	34.7	104.7	7.1	41.7	1792.3	5293.9
DEC	122.8	0.0	628.5	0.0	0.0	0.0	8.8	193.9	234.0	35.4	229.2	2363.6	6633.0
TOTAL	1404.1	0.0	7032.4	0.0	0.0	0.0	1692.2	2139.0	955.0	2234.8	4373.8	27698.1	74353.8

MONTH	BTU/UNIT:	ELECTRICITY METER-1 3413./KWH	NATURAL-GAS METER-1 100000./THERMS	NATURAL-GAS METER-2 100000./THERMS	ELECTRICITY COGENERATION 3413./KWH
JAN					
	ENERGY CONSUMPTION (UNITS/MO)	620614.2	8835.6	141.4	1255.2
	PEAK DEMAND (UNITS/HR OR DAY)	2675.4	207.7	70.7	627.6
	PEAK DAY/HR	18/ 8	4/ 7	12/ 8	12/ 8
FEB					
	ENERGY CONSUMPTION (UNITS/MO)	561212.8	6213.5	212.2	1882.8
	PEAK DEMAND (UNITS/HR OR DAY)	2770.8	128.6	70.7	627.6
	PEAK DAY/HR	16/ 8	8/ 7	1/ 8	1/ 8
MAR					
	ENERGY CONSUMPTION (UNITS/MO)	568276.8	2316.2	0.0	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	2511.1	74.5	0.0	0.0
	PEAK DAY/HR	3/16	24/ 9	0/ 0	0/ 0
APR					
	ENERGY CONSUMPTION (UNITS/MO)	539026.4	453.3	353.6	3138.0
	PEAK DEMAND (UNITS/HR OR DAY)	2772.3	4.6	70.7	627.6
	PEAK DAY/HR	27/16	5/ 9	20/16	20/16
MAY					
	ENERGY CONSUMPTION (UNITS/MO)	515265.8	226.9	424.3	3765.6
	PEAK DEMAND (UNITS/HR OR DAY)	3056.3	1.4	70.7	627.6
	PEAK DAY/HR	21/14	3/ 9	20/15	20/15
JUN					
	ENERGY CONSUMPTION (UNITS/MO)	642143.2	228.9	3182.4	28242.3
	PEAK DEMAND (UNITS/HR OR DAY)	3263.2	1.3	70.7	627.6
	PEAK DAY/HR	21/16	1/ 9	1/16	1/16
JUL					
	ENERGY CONSUMPTION (UNITS/MO)	711012.9	205.8	9547.2	84726.9
	PEAK DEMAND (UNITS/HR OR DAY)	3805.7	1.2	70.7	627.6
	PEAK DAY/HR	13/16	1/ 9	1/11	1/11
AUG					
	ENERGY CONSUMPTION (UNITS/MO)	688814.8	209.4	6789.1	60250.1
	PEAK DEMAND (UNITS/HR OR DAY)	3342.6	1.1	70.7	627.6
	PEAK DAY/HR	19/16	2/ 9	2/12	2/12
SEP					
	ENERGY CONSUMPTION (UNITS/MO)	565035.1	205.0	1273.0	11296.9
	PEAK DEMAND (UNITS/HR OR DAY)	3016.7	1.2	70.7	627.6
	PEAK DAY/HR	10/15	1/ 9	7/14	7/14
OCT					
	ENERGY CONSUMPTION (UNITS/MO)	478911.9	210.4	0.0	0.0
	PEAK DEMAND (UNITS/HR OR DAY)	2616.6	1.9	0.0	0.0
	PEAK DAY/HR	5/16	4/ 8	0/ 0	0/ 0
NOV					
	ENERGY CONSUMPTION (UNITS/MO)	513534.6	346.7	70.7	627.6
	PEAK DEMAND (UNITS/HR OR DAY)	2751.8	5.5	70.7	627.6
	PEAK DAY/HR	15/ 7	29/ 9	15/ 7	15/ 7
DEC					
	ENERGY CONSUMPTION (UNITS/MO)	628507.2	1938.5	353.6	3138.0
	PEAK DEMAND (UNITS/HR OR DAY)	3095.1	109.6	70.7	627.6
	PEAK DAY/HR	27/ 8	20/ 7	13/ 8	13/ 8
TOTAL					
	ENERGY CONSUMPTION (UNITS/YR)	7032355.5	21390.4	22347.5	198323.5
	PEAK DEMAND (UNITS/HR OR DAY)	3805.7	207.7	70.7	627.6

EQUIPMENT	HOURS AT PERCENT PART LOAD RATIO											TOTAL HOURS	ANNUAL LOAD (MBTU)	FALSE LOAD (MBTU)	ELEC USED (KWH)	THERMAL USED (MBTU)
	0	10	20	30	40	50	60	70	80	90	100					
HW-BOILER	826	61	89	54	16	12	5	1	2	1	1	1068	1216.9	0.0	24548.	1865.0
	826	61	89	54	16	12	5	1	2	1	1					
DHW-HEATER	6186	315	146	251	105	0	128	164	592	348	525	8760	182.0	0.0	0.	274.0
	6186	315	146	251	105	0	128	164	592	348	525					
DIESEL-GEN	0	0	0	0	0	0	0	0	0	0	316	316	676.9	0.0	0.	2234.8
	0	0	0	0	0	0	0	0	0	0	316					

HOT LOOP CIRCULATION PUMP ELECTRICAL USE = 19534. KWH
 COLD LOOP CIRCULATION PUMP ELECTRICAL USE = 0. KWH
 CONDENSER WATER PUMP ELECTRICAL USE = 0. KWH
 TOWER OR CONDENSER FAN ELECTRICAL USE = 0. KWH

NOTES TO TABLE

- 1) THE FIRST PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE HOURLY OPERATING CAPACITY
- 2) THE SECOND PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE TOTAL INSTALLED CAPACITY

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	1216.9	86.7
DHW-HEATER	182.0	13.0
	*****	*****
LOAD SATISFIED	1398.9	99.6
TOTAL LOAD ON PLANT	1404.1	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
DIESEL-GEN	198324.4	2.8
ELECTRICITY	6834032.0	97.2
	*****	*****
LOAD SATISFIED	7032356.0	100.0
TOTAL LOAD ON PLANT	7032264.5	

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	1404.1	1398.9	5.201	0.014	525
ELECTRICAL LOADS	24000.9	24001.2	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		

AREA LIGHTS	8672.8	477.8
MISC EQUIPMT	3881.6	381.9
SPACE HEAT	2813.7	1911.1
SPACE COOL	5426.9	1151.1
PUMPS & MISC	68.5	0.5
VENT FANS	2097.2	173.0
SUPPLMT HEAT	363.8	4.0
DOMHOT WATER	0.0	274.0
COGEN SURPLS	-0.1	0.4
	-----	-----
TOTAL	23324.3	4373.8

TOTAL SITE ENERGY 27698.14 MBTU 43.3 KBTU/SQFT-YR GROSS-AREA 43.3 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 74353.80 MBTU 116.2 KBTU/SQFT-YR GROSS-AREA 116.2 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.2
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 6.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

REPORT- ES-D ENERGY COST SUMMARY

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	7032356. KWH	934914.	0.1329	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	43738. THERMS	26243.	0.6000	YES

 961156.

ENERGY COST/GROSS BLDG AREA: 1.50
 ENERGY COST/NET BLDG AREA: 1.50

**** WARNING **** UTILITY-RATES DO NOT ACCOUNT FOR ALL THE ENERGY REPORTED IN PLANT ****

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 6 PACKAGED HEAT PUMPS ON PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 6
 PKG HEAT PUMPS INTERIOR WITH HW COILS -
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-COST

 UTILITY-RATE: ELEC-COST RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0 SUMMER-DEMAND WIN-RATCHET
 MAX-ENERGY: 0.0 WINTER-DEMAND SUN-RATCHET
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	620614	620614	2675.4	3805.7	31031	38057	0	0	0	500	0	0.1121	69588
FEB	561213	561213	2770.8	3805.7	28061	38057	0	0	0	500	0	0.1187	66618
MAR	568277	568277	2511.1	3805.7	28414	38057	0	0	0	500	0	0.1178	66971
APR	539026	539026	2772.3	3805.7	26951	49474	0	0	0	1000	0	0.1436	77426
MAY	515266	515266	3056.3	3805.7	25763	57086	0	0	0	1000	0	0.1627	83849
JUN	642143	642143	3263.2	3805.7	32107	57086	0	0	0	1000	0	0.1405	90193
JUL	711013	711013	3805.7	3805.7	35551	57086	0	0	0	1000	0	0.1317	93637
AUG	688815	688815	3342.6	3805.7	34441	57086	0	0	0	1000	0	0.1343	92527
SEP	565035	565035	3016.7	3805.7	28252	57086	0	0	0	1000	0	0.1528	86338
OCT	478912	478912	2616.6	3805.7	23946	49106	0	0	0	500	0	0.1536	73552
NOV	513535	513535	2751.8	3805.7	25677	38057	0	0	0	500	0	0.1251	64234
DEC	628507	628507	3095.1	3805.7	31425	38057	0	0	0	500	0	0.1113	69983
TOTAL	7032356	7032356	3805.7		351618	574296	0	0	0	9000		0.1329	934914

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 6 PACKAGED HEAT PUMPS ON PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 6
 PKG HEAT PUMPS INTERIOR WITH HW COILS -
 REPORT- ES-F BLOCK-CHARGE AND RATCHET SUMMARY FOR: ELEC-COST

UTILITY-RATE: ELEC-COST
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR
SUMMER-DEMAND USE: SEASONAL													
METERED DEMAND:	0.0	0.0	0.0	2772.3	3056.3	3263.2	3805.7	3342.6	3016.7	2616.6	0.0	0.0	
BILLING DEMAND:	0.0	0.0	0.0	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	0.0	0.0	
PRORATE FACTOR:	0.0000	0.0000	0.0000	0.6000	1.0000	1.0000	1.0000	1.0000	1.0000	0.5806	0.0000	0.0000	
DEMAND CHGS (\$):	0	0	0	34252	57086	57086	57086	57086	57086	33147	0	0	352827
WINTER-DEMAND USE: SEASONAL													
METERED DEMAND:	2675.4	2770.8	2511.1	2429.4	0.0	0.0	0.0	0.0	0.0	2540.3	2751.8	3095.1	
BILLING DEMAND:	3805.7	3805.7	3805.7	3805.7	0.0	0.0	0.0	0.0	0.0	3805.7	3805.7	3805.7	
PRORATE FACTOR:	1.0000	1.0000	1.0000	0.4000	0.0000	0.0000	0.0000	0.0000	0.0000	0.4194	1.0000	1.0000	
DEMAND CHGS (\$):	38057	38057	38057	15223	0	0	0	0	0	15959	38057	38057	221469
TOTAL CHARGES (\$):	38057	38057	38057	49474	57086	57086	57086	57086	57086	49106	38057	38057	574296

RATCHETS	TYPE	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
WIN-RATCHET	AVERAGE	2452.5	2314.7	2244.8	2099.7	0.0	0.0	0.0	0.0	0.0	2112.1	2249.1	2484.9
SUM-RATCHET	HIGHEST	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7	3805.7

31-STORY OFFICE BLDG, CHICAGO - LOAD2 RUN 6 PACKAGED HEAT PUMPS ON PERIMETER DOE-2.1E-001 Wed Nov 10 14:35:12 1993EDL RUN 6
 PKG HEAT PUMPS INTERIOR WITH HW COILS -
 REPORT- ES-E SUMMARY OF UTILITY-RATE: GAS-COST

UTILITY-RATE: GAS-COST RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERMS
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000



RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERMS	BILLING ENERGY THERMS	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	8977	8977	207.7	207.7	5386	0	0	0	0	0	0	0.6000	5386
FEB	6426	6426	128.6	128.6	3855	0	0	0	0	0	0	0.6000	3855
MAR	2316	2316	74.5	74.5	1390	0	0	0	0	0	0	0.6000	1390
APR	807	807	72.1	72.1	484	0	0	0	0	0	0	0.6000	484
MAY	651	651	72.1	72.1	391	0	0	0	0	0	0	0.6000	391
JUN	3411	3411	72.0	72.0	2047	0	0	0	0	0	0	0.6000	2047
JUL	9753	9753	71.9	71.9	5852	0	0	0	0	0	0	0.6000	5852
AUG	6999	6999	71.9	71.9	4199	0	0	0	0	0	0	0.6000	4199
SEP	1478	1478	71.9	71.9	887	0	0	0	0	0	0	0.6000	887
OCT	210	210	1.9	1.9	126	0	0	0	0	0	0	0.6000	126
NOV	417	417	75.1	75.1	250	0	0	0	0	0	0	0.6000	250
DEC	2292	2292	109.6	109.6	1375	0	0	0	0	0	0	0.6000	1375
TOTAL	43738	43738	207.7		26243	0	0	0	0	0		0.6000	26243

Medical Building


Plan and section of medical building with solar-heated atria. The overhangs allow penetration of direct solar into the atria only in the winter.



XBL 791-8075

Medical Building

DrawBDL axonometric wire frame view of surfaces as input into BDL. The triangular exterior walls of the atria are input as rectangles of equivalent area.



791-8075A

LDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993LDL RUN 1

```

* 2 * TITLE LINE-1 * MEDICAL OFFICE BUILDING, CHICAGO*
* 3 * LINE-2 * WATER LOOP HEAT PUMP WITH STORAGE *
* 4 * LINE-3 * SAMP3.INP RUN 1 * ..
* 5 *
* 6 * ABORT ERRORS ..
* 7 * DIAGNOSTIC WARNINGS ..
* 8 * RUN-PERIOD JAN 1 1988 THRU DEC 31 1988 ..
* 9 * BUILDING-LOCATION LATITUDE=42 LONGITUDE=88
* 10 * TIME-ZONE=6 ALTITUDE=610 ..
* 11 *
* 12 * LOADS-REPORT SUMMARY=(LS-B,LS-C,LS-D) ..
* 13 *
* 14 * $ BUILDING DESCRIPTION
* 15 *
* 16 * $ STRUCTURE REINFORCED CONCRETE CONSTRUCTION WITH 4IN CONCRETE FLOORS AND ROOF
* 17 * $ 10FT FLOOR TO FLOOR HEIGHT, TWO STORIES HIGH. RETURN AIR PLENUMS
* 18 * $ ARE NOT DEFINED.
* 19 *
* 20 * $ WALLS USING CODE WORDS FROM THE DOE-2 LIBRARY (REFERENCE MANUAL PART 2)
* 21 * $ AND STARTING WITH THE OUTSIDE SURFACE AND MOVING INWARD:
* 22 * $ 2IN PRECAST CONCRETE PANEL (CC03); 2IN POLYSTYRENE INSULATION
* 23 * $ R-8 (IN35); 3IN AIRSPACE (AL21); 5/8IN GYPSUM BOARD (GP04);
* 24 * $ 3/4IN FINISH PLASTER.
* 25 *
* 26 * $ ATRIUM ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
* 27 * $ 6IN CONCRETE (CC04); INSIDE FILM RESISTANCE .76
* 28 *
* 29 * $ OFFICE ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
* 30 * $ 2 FT AIR SPACE (AL33); 3/4IN LAY-IN ACCOUSTIC TILE (AC03);
* 31 * $ INSIDE-FILM-RESISTANCE .76.
* 32 *
* 33 * $ FLOORS FIRST FL IS SLAB-ON-GRADE EFFECTIVE U-VALUE OF ENTIRE AREA .05.
* 34 *
* 35 * $ WINDOWS OFFICE AREA 4FT HIGH AND FULL WIDTH OF EACH WALL, EXCEPT SOUTH
* 36 * $ WALL WHERE THERE ARE NO WINDOWS. GLASS IS DOUBLE PANE TINTED
* 37 * $ WITH A SOLAR TRANSMITTANCE OF .53. WINDOWS HAVE INSIDE DRAPES
* 38 * $ THAT HAVE A PROBABILITY OF .7 OF BEING PULLED WHEN TRANSMITTED
* 39 * $ DIRECT RADIATION IS GREATER THAN 40 BTUH. DRAPES ARE THEN REOPEN-
* 40 * $ ED WITH A PROBABILITY OF .2 WHENEVER SOLAR DROPS BELOW 40BTUH.
* 41 * $ ATRIUM GLASS IS THE SAME AS OFFICE GLASS EXCEPT THAT IT DOES NOT
* 42 * $ HAVE DRAPES. THERE ARE TWO MAIN SECTIONS OF GLASS 29' WIDE BY
* 43 * $ 30' HIGH WITH OVERHANGS AND SIDE FINS. NOTICE THAT THE SKETCH
* 44 * $ OF THE BUILDING INDICATES A LARGE OVERHANG WHICH WOULD BE VERY
* 45 * $ DIFFICULT TO BUILD. THIS WAS THE WAY IT WAS SIMULATED AS THIS
* 46 * $ METHOD IS EQUIVALENT TO MULTIPLE SURFACES THAT PROVIDE THE SAME
* 47 * $ SHADING GEOMETRY.
* 48 *
* 49 * $ INTERIORS CEILINGS ARE SIMULATED AS PART OF THE ROOF STRUCTURE ON THE TOP
* 50 * $ FLOOR. PARTITIONS SIMULATE A GLASS WALL BETWEEN ATRIUM AND
* 51 * $ OFFICE SPACES, BUT WALLS BETWEEN INTERIOR AND EXTERIOR OFFICES
* 52 * $ ARE NOT DEFINED. WALLS BETWEEN THE EQUIPMENT ROOM AND OFFICES
* 53 * $ HAVE A U-VALUE OF .28.
* 54 *
* 55 * $ SPACE LOADS LIGHTING IS RECESSED FLUORSCENT NON VENTED AT 1.5 WATTS/SQFT IN
* 56 * $ THE OFFICES AND 1 WATT/SQFT IN THE ATRIUM.
* 57 * $ PEOPLE IN OFFICES IS CALCULATED BY DOE-2 AT 150SQFT/PERSON.
* 58 * $ INFILTRATION IS SET AT .2 AIRCHANGES/HR WHEN FANS ARE OFF AND AT

```

```

* 59 * $ .1 AIRCHANGE WHEN PANS ARE ON.
* 60 * $ EQUIPMENT IN OFFICES IS SET AT 1 WATTS/SQFT
* 61 *
* 62 * $ CONSTRUCTIONS
* 63 *
* 64 *
* 65 * ROOF-O =LAYERS MAT=(BR01,IN76,CC03,AL33,AC03) I-F-R=.76 ..
* 66 * ROOF-A =LAYERS MAT=(BR01,IN76,CC04) I-F-R .76 ..
* 67 * OFF-ROF =CONSTRUCTION LAYERS ROOF-O ..
* 68 * ATR-ROF =CONSTRUCTION LAYERS ROOF-A ..
* 69 * WALL-1 =LAYERS MAT=(CC33,IN35,AL21,GP04,GP04) ..
* 70 * WL1 =CONSTRUCTION LAYERS=WALL-1 ..
* 71 * BW1 =CONSTRUCTION U=.05 ..
* 72 * BW2 =CONSTRUCTION U=.0001 ..
* 73 * WL2 =CONSTRUCTION U=1.05 $ ATRIUM GLASS PARTITIONS $ ..
* 74 * WL3 =CONSTRUCTION U=.28 $ INTERIOR PARTITIONS $ ..
* 75 *
* 76 * $ GLASS DESCRIPTION
* 77 *
* 78 * GT1 =GLASS-TYPE GLASS-TYPE-CODE 5 PANES 2 ..
* 79 * GT2 =GLASS-TYPE G-T-C 5 PANES 2 ..
* 80 *
* 81 * $ SCHEDULES
* 82 *
* 83 * OC1 =DAY-SCHEDULE (1,9) (0) (10,12) (1) (13,14) (.8,.4) ..
* 84 * (15,18) (.7) (19,21) (.4) (22,24) (.2) ..
* 85 * OC2 =DAY-SCHEDULE (1,24) (.2) ..
* 86 * OCCUPANCY =WEEK-SCHEDULE (MON,TUE) OC1 (WED) OC2
* 87 * (THU,SAT) OC1 (SUN,HOL) OC2 ..
* 88 * OCCUP =SCHEDULE THRU DEC 31 OCCUPANCY ..
* 89 *
* 90 * L1 =DAY-SCHEDULE (1,6) (.2) (7,12) (.9) (13,14) (.8,.4) ..
* 91 * (15,18) (.7) (19,21) (.4) (22,24) (.2) ..
* 92 * L2 =DAY-SCHEDULE (1,24) (.2) ..
* 93 * LIGHTS =WEEK-SCHEDULE (MON,TUE) L1 (WED) L2
* 94 * (THU,SAT) L1 (SUN,HOL) L2 ..
* 95 * LT1 =SCHEDULE THRU DEC 31 LIGHTS ..
* 96 *
* 97 * ES1 =DAY-SCHEDULE (1,9) (0) (10,21) (.9) (22,24) (.4) ..
* 98 * ES2 =DAY-SCHEDULE (1,9) (0) (10,24) (.4) ..
* 99 * EQUIPMENT =WEEK-SCHEDULE (MON,TUE) ES1 (WED) ES2
* 100 * (THU,SAT) ES1 (SUN,HOL) ES2 ..
* 101 * EQ1 =SCHEDULE THRU DEC 31 EQUIPMENT ..
* 102 *
* 103 * I1 =DAY-SCHEDULE (1,9) (1) (10,21) (.5) (22,24) (1) ..
* 104 * INFILTRAT =WEEK-SCHEDULE (ALL) I1 ..
* 105 * INF1 =SCHEDULE THRU DEC 31 INFILTRAT ..
* 106 *
* 107 * SHADE-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.6) ..
* 108 * COND-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.90) ..
* 109 * CLOSE-SHADE =SCHEDULE THRU DEC 31 (ALL) (1,24) (40) ..
* 110 * REOPEN-PROB =SCHEDULE THRU DEC 31 (ALL) (1,24) (.2) ..
* 111 *
* 112 * $ BUILDING SHADE BY ANOTHER BUILDING
* 113 *
* 114 * $ FOR PURPOSE OF DEMONSTRATION ASSUME THAT THERE IS ANOTHER BUILDING IN
* 115 * $ ALIGNMENT WITH THE MEDICAL BLDG BUT 150FT TO THE WEST. IT IS 170FT TALL
* 116 * $ AND 110FT WIDE. THE INPUT TO REPRESENT THIS AS A SHADING SURFACE IS:
* 117 *
* 118 * BUILDING-SHADE H=170 W=110 AZ=90 TILT=90 X=-150 ..
* 119 *
* 120 * $ SET DEFAULTS
* 121 *
* 122 * SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=10 AZDUTH=180
* 123 * CONSTRUCTION=WL1 ..

```

```

* 124 *      SET-DEFAULT FOR WINDOW HEIGHT=4 Y=4 GLASS-TYPE=GT1
* 125 *      MAX-SOLAR-SCH=CLOSE-SHADE SUN-CTRL-PROB .7
* 126 *      WIN-SHADE-TYPE=MOVABLE-INTERIOR
* 127 *      SHADING-SCHEDULE=SHADE-MULT
* 128 *      CONDUCT-SCHEDULE=COND-MULT
* 129 *      OPEN-SHADE-SCH=REOPEN-PROB ..
* 130 *
* 131 *          $ SPACE DESCRIPTION
* 132 *
* 133 * OFFICE      =SPACE-CONDITIONS  TEMPERATURE=(74) FLOOR-WEIGHT=70
* 134 *              EQUIPMENT-W/SQFT=1  EQUIP-SCHEDULE=EQ1
* 135 *              LIGHTING-W/SQFT=1.5 LIGHTING-SCHEDULE=LT1
* 136 *              INF-METHOD=AIR-CHANGE AIR-CHANGES/HR=.2
* 137 *              LIGHTING-TYPE=SUS-FLUOR
* 138 *              PEOPLE-HG-LAT=200  PEOPLE-HG-SENS=250
* 139 *              PEOPLE-SCHEDULE=OCCUP AREA/PERSON=150 ..
* 140 *
* 141 * ATRIUM     =SPACE-CONDITIONS  TEMPERATURE=(74) FLOOR-WEIGHT=100
* 142 *              LIGHTING-SCHEDULE=LT1
* 143 *              LIGHTING-TYPE=INCAND
* 144 *              LIGHTING-W/SQFT=1
* 145 *              INF-SCHEDULE=INF1  AIR-CHANGES/HR=.2
* 146 *              INF-METHOD=AIR-CHANGE ..
* 147 *
* 148 * B21        =SPACE              S-C=OFFICE AREA=3230 VOLUME=29070
* 149 *              AZ=90 Y=200 ..
* 150 *
* 151 * E1         =EXTERIOR-WALL      WIDTH=200 ..
* 152 * W1         =WINDOW              WIDTH=200 ..
* 153 *
* 154 * E1S        =EXTERIOR-WALL      W=17 AZ=90 X=200 ..
* 155 *
* 156 *              UNDERGROUND-FLOOR  AREA=3230 CONS=BW1 ..
* 157 *
* 158 * B22        =SPACE              S-C=OFFICE AREA=1660 VOLUME=14940
* 159 *              AZ=180 X=100 Y=200 ..
* 160 *
* 161 * E2         =EXTERIOR-WALL      WIDTH=100 ..
* 162 * W2         =WINDOW              WIDTH=100 ..
* 163 *
* 164 *              UNDERGROUND-FLOOR  AREA=1660 CONS=BW1 ..
* 165 *
* 166 * B23        =SPACE              LIKE B21 AZ=-90 X=100 Y=0 ..
* 167 *
* 168 * E3         =EXTERIOR-WALL      LIKE E1 ..
* 169 * W3         =WINDOW              LIKE W1 ..
* 170 *
* 171 * E3S        =EXTERIOR-WALL      W=17 AZ=270 Y=17 ..
* 172 *
* 173 *              UNDERGROUND-FLOOR  AREA=3230 CONS=BW1 ..
* 174 *
* 175 * T21        =SPACE              LIKE B21 Z=10 ..
* 176 *
* 177 * R1         =ROOF                H=17 W=200 AZ=180 TILT=0 Z=10
* 178 *              CONS=OFF-ROF ..
* 179 *
* 180 *              EXTERIOR-WALL      LIKE E1 ..
* 181 *              WINDOW              LIKE W1 ..
* 182 *
* 183 *              EXTERIOR-WALL      LIKE E1S ..
* 184 *
* 185 * T22        =SPACE              LIKE B22 Z=10 ..
* 186 *
* 187 *              ROOF                LIKE R1 H=20 W=83 ..
* 188 *

```

* 189 *	EXTERIOR-WALL	LIKE E2 ..
* 190 *	WINDOW	LIKE W2 ..
* 191 *		
* 192 *		
* 193 * T23	=SPACE	LIKE B23 Z=10 ..
* 194 *	ROOF	LIKE R1 H=17 W=180 ..
* 195 *	EXTERIOR-WALL	LIKE E3 ..
* 196 *	WINDOW	LIKE W3 ..
* 197 *	EXTERIOR-WALL	LIKE E3S ..
* 198 *		
* 199 * I21	=SPACE	S-C=OFFICE AREA=3540 VOLUME=70800
* 200 *		AZ=90 X=17 Y=180 ..
* 201 *		
* 202 * IN1	=INTERIOR-WALL	AREA=1200 NEXT-TO AT21 CONS=WL2 ..
* 203 * IN2	=INTERIOR-WALL	AREA=1200 NEXT-TO AT22 CONS=WL2 ..
* 204 * IN3	=INTERIOR-WALL	AREA=586 NEXT-TO EQUIP-RM CONS=WL3 ..
* 205 *	ROOF	LIKE R1 H=18 W=180 Z=20 ..
* 206 *	ROOF	LIKE R1 H=15 W=20 Y=18 Z=20 ..
* 207 *	EXTERIOR-WALL	H=20 W=18 AZ=90 X=180 ..
* 208 *	UNDERGROUND-FLOOR	AREA=3540 CONS=BW1 ..
* 209 *		
* 210 * I22	=SPACE	LIKE I21 AZ=-90 X=83 Y=0 ..
* 211 *		
* 212 *	INTERIOR-WALL	LIKE IN1 NEXT-TO AT21 ..
* 213 *	INTERIOR-WALL	LIKE IN2 NEXT-TO AT22 ..
* 214 *	INTERIOR-WALL	LIKE IN3 ..
* 215 *	EXTERIOR-WALL	H=20 W=18 AZ=270 Y=18 ..
* 216 *	ROOF	LIKE R1 H=18 W=180 Z=20 ..
* 217 *	ROOF	LIKE R1 H=15 W=20 X=160 Y=18 Z=20 ..
* 218 *	UNDERGROUND-FLOOR	AREA=3540 CONS=BW1 ..
* 219 *		
* 220 * AT21	=SPACE	S-C=ATRIUM AREA=1800 VOLUME=16200
* 221 *		X=35 Y=40
* 222 *		SOURCE-TYPE = HOT-WATER
* 223 *		SOURCE-BTU/HR = 30000
* 224 *		SOURCE-SENSIBLE = 0.0
* 225 *		SOURCE-SCHEDULE = OCCUP ..
* 226 *		
* 227 * ATROOF-1	=ROOF	HEIGHT=66.6 WIDTH=30
* 228 *		AZIMUTH=0 TILT=26 X=30 Y=60 Z=20
* 229 *		CONS=ATR-ROF ..
* 230 * E4	=EXTERIOR-WALL	H=14.5 W=60 AZ=270 Y=60 Z=20 ..
* 231 * E5	=EXTERIOR-WALL	LIKE E4 AZ=90 X=30 Y=0 ..
* 232 * F1	=UNDERGROUND-FLOOR	AREA=1800 CONS=BW2 ..
* 233 * FRAME-A	=EXTERIOR-WALL	HEIGHT=29 WIDTH=30 Z=20 ..
* 234 * WINDOW-A	=WINDOW	H=28.9 W=29.9 X=.05 Y=.05 GLASS-TYPE=GT2
* 235 *		OVERHANG-A=6 OH-B=0 OH-D=48.5 OH-W=42
* 236 *		OVERHANG-ANGLE=116 LEFT-FIN-A=0 L-F-B=0
* 237 *		L-F-H=30 L-F-D=3 RIGHT-FIN-A=0 R-F-B=0
* 238 *		R-F-H=30 R-F-D=3 ..
* 239 *	EXTERIOR-WALL	LIKE FRAME-A HEIGHT=10.7 W=30 Z=9.3 ..
* 240 *	WINDOW	LIKE WINDOW-A H=10.6 W=29.9 L-F-H=10.7
* 241 *		R-F-H=10.7 ..
* 242 *		
* 243 * AT22	=SPACE	LIKE AT21 SOURCE-BTU/HR=0.0 Y=100 ..
* 244 *		
* 245 * ATROOF-2	=ROOF	LIKE ATROOF-1 ..
* 246 *	EXTERIOR-WALL	LIKE E4 ..
* 247 *	EXTERIOR-WALL	LIKE E5 ..
* 248 *	UNDERGROUND-FLOOR	LIKE F1 ..
* 249 * FRAME-B	=EXTERIOR-WALL	LIKE FRAME-A ..
* 250 * WINDOW-B	=WINDOW	LIKE WINDOW-A ..
* 251 *		
* 252 * EQUIP-RM	=SPACE	ZONE-TYPE=UNCONDITIONED
* 253 *		AREA=1200 VOLUME=17580 X=35 ..

```
* 254 *
* 255 *      EXTERIOR-WALL      HEIGHT=20 WIDTH=30 ..
* 256 *
* 257 *      ROOF              H=41.2 W=30 CONS=OFF-ROF
* 258 *      TILT=15  2=9.3 X=30 Y=40 AZIMUTH=0 ..
* 259 *
* 260 *      INTERIOR-WALL     AREA=279 CONS=WL3 NEXT-TO AT21 ..
* 261 *      UNDERGROUND-FLOOR AREA=1200 CONS=BW1 ..
* 262 *
* 263 *      END ..
* 264 *      COMPUTE LOADS ..
* 265 *      INPUT SYSTEMS ..
```

SDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993SDL RUN 1

```

* 266 * SYSTEMS-REPORT SUMMARY (SS-A,SS-C,SS-J,SS-D) ..
* 267 *
* 268 *           $ HVAC SYSTEMS DESCRIPTION
* 269 *
* 270 *
* 271 * $ DESIGN TEMPS ATRIUM COOLING 80F-SUMMER, 70F-WINTER HEATING 65F
* 272 * $ OFFICE COOLING 76F HEATING 74F
* 273 * $ SYSTEM TYPE THE ENTIRE BUILDING IS SERVED BY A WATER LOOP HEAT PUMP (HP)
* 274 * $ SYSTEM. THE ATRIUM UNITS HAVE AN OUTSIDE AIR ECONOMIZER AND
* 275 * $ PROVIDE MINIMUM VENTILATION AIR FOR ALL SPACES TO GIVE .25 AIR-
* 276 * $ CHANGES/HOUR FOR THE ENTIRE BUILDING. IT IS ASSUMED THAT THE
* 277 * $ OFFICE UNITS PULL THEIR OUTSIDE AIR FROM THE ATRIUM. THE
* 278 * $ PERIMETER HP UNITS ARE FURNISHED WITH A WATER SIDE ECONOMIZER.
* 279 * $ THE MINIMUM OUTSIDE AIR DAMPERS TO THE ATRIUM UNITS ARE HELD
* 280 * $ CLOSED BETWEEN 9PM WHEN FANS ARE TURNED OFF UNTIL 9AM AT NORMAL
* 281 * $ START. THE FANS OPERATE FROM 9AM TO 9PM MONDAY THRU SATURDAY,
* 282 * $ AND ARE OFF ON SUNDAYS AND HOLIDAYS. THE FANS ARE ALLOWED TO
* 283 * $ START AS EARLY AS 7AM TO PICK UP HEATING AND COOLING LOADS,
* 284 * $ BUT ARE DELAYED AS LONG AS POSSIBLE. THE NIGHT SETBACK
* 285 * $ TEMPERATURE IS 65F AND THE NIGHT SETUP TEMPERATURE IS 90F.
* 286 * $ THE TEMPERATURE OF THE HP WATER LOOP IS MAINTAINED BETWEEN 55F
* 287 * $ (BOILER SET POINT OF 60F) AND 90F (TOWER SETPOINT OF 85F),
* 288 * $ BUT THE TOWER SETPOINT IS ALLOWED TO FLOAT TO LOWER
* 289 * $ TEMPERATURES BASED UPON OUTDOOR WETBULB TEMPERATURE TO
* 290 * $ IMPROVE THE EFFICIENCY OF THE HP UNITS. TOTAL SYSTEM VOLUME
* 291 * $ INCLUDING A 7500 GALLON STORAGE TANK IS 10000 GALLONS.
* 292 *
* 293 *
* 294 * $ FROM MAY 15 THRU OCT 15 A SEPARATE NIGHT VENTILATION SYSTEM
* 295 * $ CAN CYCLE ON TO PROVIDE FREE OA COOLING OF THE ATRIUM, BUT ONLY
* 296 * $ IF ITS SPACE TEMPERATURE IS ABOVE 76F. THE AIR SIDE CAPACITY
* 297 * $ OF THE NIGHT VENTILATION SYSTEM IS TWICE AS LARGE AS THE HP
* 298 * $ UNITS.
* 299 *
* 300 * $ A SERVICE WATER HEAT PUMP IS LOCATED IN ATRIUM AT21. IT
* 301 * $ SUPPLEMENTS THE DOMESTIC HOT WATER HEATER IN PLANT. THE
* 302 * $ CAPACITY OF THE HEAT PUMP IS 24000 BTH/HR.
* 303 *
* 304 *           $ SCHEDULES
* 305 *
* 306 * DAYS = WEEK-SCHEDULE (MON,SAT) (1,7)(0)(8,9)(-999)(10,21)(1)(22,24)(0)
* 307 * (SUN,HOL) (1,24)(0) ..
* 308 * AHU-SCHED = SCHEDULE THRU DEC 31 DAYS ..
* 309 *
* 310 *           $ ATRIUM COOLING SCHEDULE
* 311 *
* 312 * AT-C-WIN-HRS = DAY-SCHEDULE (1,24) (70) ..
* 313 * AT-C-SUM-HRS = DAY-SCHEDULE (1,24) (80) ..
* 314 * AT-C-WIN-DAYS = WEEK-SCHEDULE (ALL) AT-C-WIN-HRS ..
* 315 * AT-C-SUM-DAYS = WEEK-SCHEDULE (ALL) AT-C-SUM-HRS ..
* 316 * TCOOL1 = SCHEDULE THRU MAR 31 AT-C-WIN-DAYS
* 317 * THRU OCT 31 AT-C-SUM-DAYS
* 318 * THRU DEC 31 AT-C-WIN-DAYS ..
* 319 *
* 320 *           $ ATRIUM HEATING SCHEDULE
* 321 *
* 322 * AT-HEAT-HRS = DAY-SCHEDULE (1,24) (65) ..

```



```

* 323 * THEAT1      = SCHEDULE THRU DEC 31 (ALL) AT-HEAT-HRS ..
* 324 *
* 325 *              $ OFFICE COOLING SCHEDULE
* 326 *
* 327 * OFF-1       = DAY-SCHEDULE (1,9)(90)(10,21)(76)(22,24)(90) ..
* 328 * OFF-2       = DAY-SCHEDULE (1,24)(90) ..
* 329 * TCOOL2     = SCHEDULE THRU DEC 31 (MON,SAT) OFF-1 (SUN,HOL) OFF-2 ..
* 330 *
* 331 *              $ OFFICE HEATING SCHEDULE
* 332 *
* 333 * OFF-3       = DAY-SCHEDULE (1,9)(65)(10,21)(74)(22,24)(65) ..
* 334 * OFF-4       = DAY-SCHEDULE (1,24)(65) ..
* 335 * THEAT2     = SCHEDULE THRU DEC 31 (MON,SAT) OFF-3 (SUN,HOL) OFF-4 ..
* 336 *
* 337 *              $ NIGHT VENTILATION SCHEDULES
* 338 *
* 339 * VENT-T      = SCHEDULE THRU DEC 31 (ALL) (1,24)(76) ..
* 340 * VENT-ON-OFF = SCHEDULE THRU MAY 15 (ALL) (1,24)(0)
* 341 *              THRU OCT 15 (ALL) (1,24)(1)
* 342 *              THRU DEC 31 (ALL) (1,24)(0) ..
* 343 *
* 344 * MIN-OA     = SCHEDULE THRU DEC 31 (ALL) (1,9)(0)(10,21)(-999)(22,24)(0) ..
* 345 *
* 346 *              $ ZONE DESCRIPTION
* 347 *
* 348 * ENV-ATR    = ZONE-CONTROL D-H-T 70 D-C-T 74 H-T-SCH THEAT1 C-T-SCH TCOOL1
* 349 *              T-TYPE PROPORTIONAL ..
* 350 * ENV-OFF    = ZONE-CONTROL D-H-T 74 D-C-T 74 H-T-SCH THEAT2 C-T-SCH TCOOL2
* 351 *              T-TYPE PROPORTIONAL ..
* 352 * ATZ1      = ZONE          2-C ENV-ATR OUTSIDE-AIR-CFM 1665 ..
* 353 * ATZ2      = ZONE          LIKE ATZ1 ..
* 354 * EQUIP-RM  = ZONE          ZONE-TYPE=UNCONDITIONED ..
* 355 * BZ1       = ZONE          2-C ENV-OFF ZONE-REPORTS = NO ..
* 356 * BZ2       = ZONE          LIKE BZ1 ..
* 357 * BZ3       = ZONE          LIKE BZ1 ..
* 358 * TZ1       = ZONE          LIKE BZ1 ..
* 359 * TZ2       = ZONE          LIKE BZ1 ..
* 360 * TZ3       = ZONE          LIKE BZ1 ..
* 361 * IZ1       = ZONE          LIKE BZ1 ..
* 362 * IZ2       = ZONE          LIKE BZ1 ..
* 363 *
* 364 * HP-SYS-CORE = SYSTEM      SYSTEM-TYPE=HP MAX-S-T=100 MIN-S-T=55
* 365 *              SUPPLY-STATIC=2.5 SUPPLY-EFF=.45
* 366 *              OA-CONTROL = TEMP ECONO-LIMIT-T = 68
* 367 *              FAN-SCHEDULE=AHU-SCHED
* 368 *              FLUID-VOLUME = 30
* 369 *              MIN-AIR-SCH = MIN-OA
* 370 *              SHW-HP-SIZE=24000 SHW-HP-SOURCE=ZONE
* 371 *              SHW-HP-ZONE=ATZ1
* 372 *              ZONE-NAMES=(ATZ1,ATZ2,EQUIP-RM)
* 373 *              SIZING-RATIO=1.5 ..
* 374 *
* 375 *
* 376 * HP-SYS-PERM = SYSTEM      SYSTEM-TYPE = HP MAX-S-T=100 MIN-S-T=55
* 377 *              SUPPLY-STATIC=2.5 SUPPLY-EFF=.55
* 378 *              FLUID-VOLUME=30
* 379 *              FAN-SCHEDULE=AHU-SCHED
* 380 *              ZONE-NAMES=(BZ1,BZ2,BZ3,TZ1,TZ2,
* 381 *              TZ3,IZ1,IZ2) ..
* 382 *
* 383 * WLHP = PLANT-ASSIGNMENT
* 384 *       SYSTEM-NAMES = (HP-SYS-CORE,HP-SYS-PERM)
* 385 *       HP-LOOP-HEATING = FROM-SYSTEMS
* 386 *       HP-LOOP-COOLING = FROM-SYSTEMS
* 387 *       BOILER-TYPE = FUEL-BOILER

```

```

* 388 *      BOILER-SET-POINT= 60
* 389 *      TWR-SETPT-CTRL = WETBULB-RESET
* 390 *      TWR-CAP-CTRL  = TWO-SPEED-FAN
* 391 *      MIN-TWR-WTR-T = 61
* 392 *      TWR-DESIGN-WETBULB = 78
* 393 *      CIRC-PUMP-SCH  = AHU-SCHED
* 394 *      CIRC-PUMP-TYPE = VARIABLE-FLOW
* 395 *      PLANT-REPORTS  = YES
* 396 *      DHW-SIZE      = 0
* 397 *      DHW-GAL/MIN   = .222
* 398 *      DHW-SCH       = OCCUP ..
* 399 *
* 400 * TWR-FLOAT = SCHEDULE THRU MAY 15 (ALL) (1,24) (85)
* 401 *                THRU OCT 15 (ALL) (1,24) (75)
* 402 *                THRU DEC 31 (ALL) (1,24) (85) ..
* 403 *
* 404 * OC1          =DAY-SCHEDULE      (1,9) (0) (10,12) (1) (13,14) (.8,.4)
* 405 *                (15,18) (.7) (19,21) (.4) (22,24) (.2) ..
* 406 * OC2          =DAY-SCHEDULE      (1,24) (.2) ..
* 407 * OCCUPANCY    =WEEK-SCHEDULE     (MON,TUE) OC1      (WED) OC2
* 408 *                (THU,SAT) OC1    (SUN,HOL) OC2 ..
* 409 * OCCUP        =SCHEDULE          THRU DEC 31 OCCUPANCY ..
* 410 * END ..
* 411 * COMPUTE SYSTEMS ..
* 412 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993PDL RUN 1

```
* 413 * WLHP = PLANT-ASSIGNMENT ..
* 414 * PLANT-REPORT SUMMARY (PS-A,PS-D,BEPS) ..
* 415 *
* 416 *           $ PLANT DESCRIPTION
* 417 *
* 418 * DHW = PLANT-EQUIPMENT TYPE=DHW-HEATER SIZE -999 I-N 1 ..
* 419 *
* 420 * END ..
* 421 * COMPUTE PLANT ..
* 422 * INPUT ECONOMICS ..
```

EDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993EDL RUN 1

```

* 423 * DIAGNOSTIC WARNINGS ..
* 424 * ECONOMICS-REPORT SUMMARY (ES-D,ES-E) ..
* 425 *
* 426 *           $ ENERGY CHARGE DESCRIPTION
* 427 *
* 428 * $ THE ELECTRIC RATE IS TIME-OF-USE WITH SEPARATE SUMMER/WINTER MINIMUM
* 429 * $ DEMAND CHARGES. IN ADDITION IT HAS S/W DEMAND CHARGES THAT APPLY ONLY TO THE
* 430 * $ ON-PEAK HOURS. THE TWO DEMANDS ARE ADDITIVE, APPLY TO THE HIGHEST PEAK, BUT
* 431 * $ ONLY THE ON-PEAK CARRIES A RATCHET OF 90%. THE ENERGY CHARGES ARE
* 432 * $ DOLLARS/KWH FOR THREE PERIODS (I.E. ON-PEAK, INTERMEDIATE-PEAK, AND OFF-PEAK).
* 433 * $ THE FUEL FOR THE HOT WATER GENERATOR SIMULATED IN SYSTEMS PLUS THE DOMESTIC
* 434 * $ HOT-WATER HEATER IS NATURAL-GAS ..
* 435 *
* 436 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 437 *           MIN-MON-CHGS = (186)
* 438 *           DEMAND-CHGS = (2.25,2.25,2.25,2.25, 2.58,
* 439 *                        2.58,2.58,2.58,2.58,2.58,2.25)
* 440 *           BLOCK-CHARGES = (SUM-P-DEM,WIN-P-DEM)
* 441 *           ENERGY-CHG-SCH = TOU-SCH ..
* 442 *
* 443 * TOU-SCH = SCHEDULE THRU APR 30 (WD) (1,8) (.0324)
* 444 *           (9,12) (.0354)
* 445 *           (13,18) (.0394)
* 446 *           (19,21) (.0354)
* 447 *           (22,24) (.0354)
* 448 *           (WEH) (1,24) (.0354)
* 449 *           THRU OCT 31 (WD) (1,8) (.0374)
* 450 *           (9,12) (.0394)
* 451 *           (13,18) (.0444)
* 452 *           (19,21) (.0394)
* 453 *           (22,24) (.0374)
* 454 *           (WEH) (1,24) (.0374)
* 455 *           THRU DEC 31 (WD) (1,8) (.0324)
* 456 *           (9,12) (.0354)
* 457 *           (13,18) (.0394)
* 458 *           (19,21) (.0354)
* 459 *           (22,24) (.0354)
* 460 *           (WEH) (1,24) (.0354) ..
* 461 *
* 462 * SUM-P-DEM = BLOCK-CHARGE BLOCK-SCH = DEM-SCH
* 463 *           SCH-FLAG = 2
* 464 *           BLOCK1-TYPE = DEMAND
* 465 *           BLOCK1-DATA = (1,7,00)
* 466 *           DEMAND-RATCHETS = (SUM-RATCH) ..
* 467 *
* 468 * WIN-P-DEM = BLOCK-CHARGE BLOCK-SCH = DEM-SCH
* 469 *           SCH-FLAG = 1
* 470 *           BLOCK1-TYPE = DEMAND
* 471 *           BLOCK1-DATA = (1,6,50)
* 472 *           DEMAND-RATCHETS = (SUM-RATCH) ..
* 473 *
* 474 * SUM-RATCH = RATCHET NUM-MONTHS = 12
* 475 *           RATCHET-SCH = DEM-SCH
* 476 *           SCH-FLAG = 2
* 477 *           TYPE = HIGHEST-PEAK
* 478 *           FRACTION = .90 ..
* 479 *

```

```

* 480 * DEM-SCH = SCHEDULE THRU APR 30 (WD) (1.12) (0)
* 481 * (13.18) (1)
* 482 * (19.24) (0)
* 483 * (WEH) (1.24) (0)
* 484 * THRU OCT 31 (WD) (1.12) (0)
* 485 * (13.18) (2)
* 486 * (19.24) (0)
* 487 * (WEH) (1.24) (0)
* 488 * THRU DEC 31 (WD) (1.12) (0)
* 489 * (13.18) (1)
* 490 * (19.24) (0)
* 491 * (WEH) (1.24) (0) ..
* 492 *
* 493 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 494 * ENERGY-CHG = .90 ..
* 495 * END ..
* 496 * COMPUTE ECONOMICS ..
* 497 *
* 498 * INPUT LOADS ..

```

SPACE B21

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0
 FLOOR AREA 3230 SQFT 300 M2
 VOLUME 29070 CUFT 823 M3

TIME	COOLING LOAD		HEATING LOAD	
	***** AUG 19 4PM		***** JAN 1 9AM	
DRY-BULB TEMP	90F	32C	-2F	-19C
WET-BULB TEMP	71F	22C	-2F	-19C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	2.424	0.710	0.000	0.000	-7.499	-2.197
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	15.607	4.573	0.000	0.000	-26.674	-7.815
WINDOW GLASS SOLAR	26.911	7.885	0.000	0.000	2.086	0.611
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-1.292	-0.379	0.000	0.000	-5.491	-1.609
OCCUPANTS TO SPACE	3.372	0.988	3.015	0.883	1.077	0.315
LIGHT TO SPACE	10.866	3.184	0.000	0.000	3.307	0.969
EQUIPMENT TO SPACE	8.712	2.552	0.000	0.000	0.419	0.123
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.969	0.284	0.848	0.248	-5.251	-1.539
TOTAL	67.569	19.798	3.862	1.132	-38.026	-11.142
TOTAL LOAD	71.431 KBTU/H		20.929 KW		-38.026 KBTU/H	-11.142 KW
TOTAL LOAD / AREA	22.11BTU/H.SQFT		69.746 W / M2		11.773BTU/H.SQFT	37.129 W / M2

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 * *****

SPACE TZ1

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0
 FLOOR AREA 3230 SQFT 300 M2
 VOLUME 29070 CUFT 823 M3

TIME	COOLING LOAD		HEATING LOAD	
	JUL 3 6PM		JAN 1 9AM	
DRY-BULB TEMP	92F	33C	-2F	-19C
WET-BULB TEMP	73F	23C	-2F	-19C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	2.990	0.876	0.000	0.000	-7.515	-2.202
ROOF CONDUCTION	5.571	1.632	0.000	0.000	-18.754	-5.495
WINDOW GLASS+FRM COND	11.064	3.242	0.000	0.000	-27.174	-7.962
WINDOW GLASS SOLAR	27.912	8.178	0.000	0.000	2.092	0.613
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	3.495	1.024	3.015	0.883	1.077	0.315
LIGHT TO SPACE	11.210	3.284	0.000	0.000	3.307	0.969
EQUIPMENT TO SPACE	9.094	2.664	0.000	0.000	0.419	0.123
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	2.840	0.832	3.056	0.895	-6.098	-1.787
TOTAL	74.176	21.734	6.070	1.779	-52.645	-15.425
TOTAL LOAD	80.246 KBTU/H		23.512 KW		-52.645 KBTU/H -15.425 KW	
TOTAL LOAD / AREA	24.84BTU/H.SQFT		78.354 W / M2		16.299BTU/H.SQFT 51.403 W / M2	

 *
 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 *

SPACE 121

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0
 FLOOR AREA 3540 SQFT 329 M2
 VOLUME 70800 CUFT 2005 M3

TIME	COOLING LOAD		HEATING LOAD	
	***** JUL 3 6PM		***** JAN 1 4AM	
DRY-BULB TEMP	92F	33C	3F	-16C
WET-BULB TEMP	73F	23C	2F	-17C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	0.746	0.219	0.000	0.000	-1.797	-0.527
ROOF CONDUCTION	5.831	1.708	0.000	0.000	-19.304	-5.656
WINDOW GLASS-FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	-0.656	-0.192	0.000	0.000	-0.656	-0.192
UNDERGROUND SURF COND	-1.770	-0.519	0.000	0.000	-6.018	-1.763
OCCUPANTS TO SPACE	3.830	1.122	3.304	0.968	1.180	0.346
LIGHT TO SPACE	12.286	3.600	0.000	0.000	3.625	1.062
EQUIPMENT TO SPACE	9.966	2.920	0.000	0.000	0.922	0.270
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	6.988	2.047	7.519	2.203	-18.626	-5.458
TOTAL	37.221	10.906	10.823	3.171	-40.675	-11.918
TOTAL LOAD	48.044 KBTU/H		14.077 KW		-40.675 KBTU/H -11.918 KW	
TOTAL LOAD / AREA	13.57BTU/H.SQFT		42.803 W / M2		11.490BTU/H.SQFT 36.238 W / M2	

 * NOTE 1) THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2) TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *

SPACE AT21

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0
 FLOOR AREA 1800 SQFT 167 M2
 VOLUME 16200 CUFT 459 M3

TIME	COOLING LOAD		HEATING LOAD	
	JUL 9 4PM		JAN 7 6AM	
DRY-BULB TEMP	94F	34C	1F	-17C
WET-BULB TEMP	74F	23C	1F	-17C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	4.128	1.210	0.000	0.000	-9.090	-2.663
ROOF CONDUCTION	4.606	1.350	0.000	0.000	-12.357	-3.621
WINDOW GLASS+FRM COND	13.043	3.822	0.000	0.000	-36.905	-10.813
WINDOW GLASS SOLAR	16.651	4.879	0.000	0.000	2.622	0.768
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	-0.312	-0.092	0.000	0.000	-0.312	-0.092
UNDERGROUND SURF COND	-0.002	-0.001	0.000	0.000	-0.006	-0.002
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
LIGHT TO SPACE	3.976	1.165	0.000	0.000	1.283	0.376
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.338	0.099	0.351	0.103	-2.465	-0.722
TOTAL	42.429	12.432	0.351	0.103	-57.230	-16.768
TOTAL LOAD	42.780 KBTU/H	12.535 KW			-57.230 KBTU/H	-16.768 KW
TOTAL LOAD / AREA	23.77BTU/H.SQFT	74.956 W / M2			31.795BTU/H.SQFT	100.275 W / M2

```

*****
*
* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
* ---- LOADS
* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
* IN CONSIDERATION
*
*****
  
```

SPACE EQUIP-RM

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0
 FLOOR AREA 1200 SQFT 111 M2
 VOLUME 17580 CUFT 498 M3

TIME	COOLING LOAD		HEATING LOAD	
	JUL 9 6PM		JAN 2 8AM	
DRY-BULB TEMP	97F	36C	4F	-16C
WET-BULB TEMP	73F	23C	3F	-16C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	1.781	0.522	0.000	0.000	-3.045	-0.892
ROOF CONDUCTION	2.737	0.802	0.000	0.000	-6.950	-2.036
WINDOW GLASS+FRM COND	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS SOLAR	0.000	0.000	0.000	0.000	0.000	0.000
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	1.625	0.476	0.000	0.000	1.625	0.476
UNDERGROUND SURF COND	-0.360	-0.105	0.000	0.000	-1.800	-0.527
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.000	0.000	0.000	0.000	0.000	0.000
TOTAL	5.783	1.695	0.000	0.000	-10.170	-2.980
TOTAL LOAD	5.783 KBTU/H 1.695 KW				-10.170 KBTU/H -2.980 KW	
TOTAL LOAD / AREA	4.82BTU/H.SQFT 15.200 W / M2				8.475BTU/H.SQFT 26.729 W / M2	

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 * *****

*** BUILDING ***

FLOOR AREA 26920 SQFT 2501 SQMT
 VOLUME 320160 CUFT 9067 CUMT

TIME	COOLING LOAD		HEATING LOAD	
	***** JUL 3 4PM		***** JAN 1 7AM	
DRY-BULB TEMP	92F	33C	-1F	-18C
WET-BULB TEMP	74F	23C	-1F	-18C

	SENSIBLE		LATENT		SENSIBLE			
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)		
WALL CONDUCTION	21.908	6.419	0.000	0.000	-58.361	-17.100		
ROOF CONDUCTION	31.424	9.207	0.000	0.000	-112.720	-33.027		
WINDOW GLASS+FRM COND	72.469	21.233	0.000	0.000	-200.304	-58.689		
WINDOW GLASS SOLAR	135.439	39.684	0.000	0.000	23.828	6.982		
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000		
INTERNAL SURFACE COND	-1.625	-0.476	0.000	0.000	-1.625	-0.476		
UNDERGROUND SURF COND	-7.604	-2.228	0.000	0.000	-25.852	-7.575		
OCCUPANTS TO SPACE	24.597	7.207	21.765	6.377	7.773	2.278		
LIGHT TO SPACE	88.073	25.805	0.000	0.000	26.334	7.716		
EQUIPMENT TO SPACE	63.735	18.674	0.000	0.000	4.000	1.172		
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000		
INFILTRATION	23.936	7.013	30.411	8.910	-63.545	-18.619		
TOTAL	452.353	132.539	52.176	15.288	-400.470	-117.338		
TOTAL LOAD	504.529 KBTU/H		147.827 KW		-400.470 KBTU/H		-117.338 KW	
TOTAL LOAD / AREA	18.74BTU/H.SQFT		59.108 W /SQMT		14.876BTU/H.SQFT		46.917 W /SQMT	

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 * *****

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	3.86039	25 16	48.F	42.F	121.170	-121.579	1 7	-1.F	-1.F	-400.470	19174.	55.710
FEB	4.48149	16 15	43.F	36.F	97.163	-103.704	4 6	7.F	6.F	-372.809	17332.	55.710
MAR	14.83433	9 13	68.F	62.F	161.269	-69.737	24 6	8.F	7.F	-354.826	19607.	55.710
APR	50.48765	27 15	82.F	61.F	347.464	-27.861	8 5	33.F	30.F	-248.334	19282.	55.710
MAY	76.53624	20 15	77.F	68.F	352.785	-10.836	6 5	39.F	35.F	-145.577	19174.	55.710
JUN	118.25208	4 15	85.F	67.F	413.603	-1.292	25 5	52.F	47.F	-45.175	18849.	55.710
JUL	166.29558	3 15	92.F	74.F	452.353	-0.006	23 5	61.F	60.F	-1.509	19607.	55.710
AUG	143.22816	20 15	88.F	72.F	426.324	-0.103	5 5	55.F	54.F	-23.714	19607.	55.710
SEP	79.67437	11 15	86.F	72.F	377.639	-6.961	22 6	35.F	31.F	-118.785	18416.	55.710
OCT	42.50692	5 15	74.F	62.F	266.334	-22.933	21 5	30.F	29.F	-179.721	19174.	55.710
NOV	17.05823	2 15	75.F	61.F	273.918	-65.820	15 6	28.F	26.F	-287.580	18416.	55.710
DEC	3.27829	10 15	41.F	35.F	106.720	-108.653	9 6	14.F	13.F	-317.555	18741.	55.710
TOTAL	720.494					-539.484					227379.	
MAX					452.353					-400.470		55.710

MESSAGE LIST FROM SYSTEMS PROGRAM

WARNING***
IN HP-SYS-CORE OA-CONTROL HAS BEEN RESET TO FIXED TO ALLOW THE FAN CYCLING OPTION

REPORT- SV-A SYSTEM DESIGN PARAMETERS

HP-SYS-CORE

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE						
HP-SYS-CORE	HP		1.020	4800.0		0.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	5773.	0.001	2.0	0.	0.000	0.0	0.588	0.000	0.000	0.000	0.38	0.36
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
AT21	3164.	0.	2.022	1.000	1698.	149.25	0.62	63.64	-159.70	-107.43	1.0	
AT22	2609.	0.	1.668	1.000	1698.	131.85	0.63	52.49	-141.08	-90.08	1.0	
EQUIP-RM	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

HP-SYS-PERM

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
HP-SYS-PERM	HP	1.020	23320.0	155.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	21267.	0.001	1.6	0.	0.000	0.0	0.000	0.000	0.000	0.000	0.38	0.36
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
BZ1	3359.	0.	1.757	1.000	0.	92.39	0.75	67.57	-98.86	-91.14	1.0	
BZ2	1308.	0.	0.684	1.000	0.	36.84	0.74	26.31	-39.42	-35.48	1.0	
BZ3	3926.	0.	2.054	1.000	0.	108.01	0.75	78.99	-115.57	-106.54	1.0	
TZ1	3687.	0.	1.929	1.000	0.	103.43	0.74	74.18	-110.67	-100.05	1.0	
TZ2	1444.	0.	0.755	1.000	0.	40.52	0.74	29.06	-43.36	-39.19	1.0	
TZ3	3842.	0.	2.010	1.000	0.	106.21	0.75	77.30	-113.65	-104.27	1.0	
IZ1	1850.	0.	0.968	1.000	0.	58.88	0.69	37.22	-63.00	-50.20	1.0	
IZ2	1851.	0.	0.968	1.000	0.	58.90	0.69	37.23	-63.02	-50.22	1.0	

MONTH	- - - - - C O O L I N G - - - - -					- - - - - H E A T I N G - - - - -					- - - E L E C - - -	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	0.000			0.000	39330.	172.785	
FEB	0.00000				0.000	0.000			0.000	34552.	155.008	
MAR	0.00000				0.000	0.000			0.000	34397.	128.454	
APR	0.00000				0.000	0.000			0.000	31920.	116.889	
MAY	0.00000				0.000	0.000			0.000	33112.	148.983	
JUN	0.00000				0.000	0.000			0.000	40388.	164.007	
JUL	0.00000				0.000	0.000			0.000	50369.	175.635	
AUG	0.00000				0.000	0.000			0.000	46417.	171.665	
SEP	0.00000				0.000	0.000			0.000	33322.	150.471	
OCT	0.00000				0.000	0.000			0.000	29403.	98.707	
NOV	0.00000				0.000	0.000			0.000	31979.	139.168	
DEC	0.00000				0.000	0.000			0.000	36696.	149.693	
TOTAL	0.000					0.000				441880.		
MAX					0.000				0.000		175.635	

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 0.000 (KBTU)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 13273.906 (KBTU)

CIRC PUMP SIZE is 221.6 (GAL/MIN) POWER = 3.56 (KW) HEAT GAIN = 10946. (BTU/HR) or 0.1 (DEG F) MIN PLR = 0.50

MONTH	SUM PEAK DAY/HR	HEAT GAIN	ENERGY USE	HEAT MODE	COOL MODE	Number of hours within each PART LOAD range											TOTAL RUN HOURS
		(MBTU)	(KWH)	(KWH)	(KWH)	00	10	20	30	40	50	60	70	80	90	100	
		(KBTU/HR)	(KW)	(KW)	(KW)	10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM PEAK DAY/HR	3.643 10.935 30/21	1185.962 3.560 30/21	1175.030 3.560 30/21	10.931 0.475 30/ 8	0	0	0	0	0	23	0	0	0	0	327	350
FEB	SUM PEAK DAY/HR	3.337 10.935 27/21	1086.284 3.560 27/21	1075.352 3.560 27/21	10.931 0.475 27/ 8	0	0	0	0	0	23	0	0	0	0	299	322
MAR	SUM PEAK DAY/HR	3.867 10.935 31/21	1258.993 3.560 31/21	1245.209 3.560 31/21	13.783 0.475 31/ 8	0	0	0	0	0	29	6	0	0	0	343	378
APR	SUM PEAK DAY/HR	3.614 10.935 30/21	1176.510 3.560 30/21	1052.566 3.560 28/17	123.942 1.780 30/21	0	0	0	0	0	38	11	0	0	0	315	364
MAY	SUM PEAK DAY/HR	3.448 10.935 29/21	1122.506 3.560 29/21	848.640 3.560 29/18	273.866 1.780 29/21	0	0	0	0	0	41	9	0	0	0	300	350
JUN	SUM PEAK DAY/HR	3.624 10.935 30/21	1179.844 3.560 30/21	663.765 3.560 30/10	516.079 1.780 30/21	0	0	0	0	0	29	22	0	0	0	313	364
JUL	SUM PEAK DAY/HR	3.724 10.935 31/21	1212.264 3.560 31/21	631.051 3.560 31/10	581.212 1.780 31/21	0	0	0	0	0	25	10	0	0	0	329	364
AUG	SUM PEAK DAY/HR	3.676 10.935 31/21	1196.832 3.560 31/21	664.275 3.560 31/19	532.557 1.780 31/21	0	0	0	0	0	26	17	0	0	0	321	364
SEP	SUM PEAK DAY/HR	3.455 10.935 30/21	1124.839 3.560 30/21	688.745 3.560 30/21	436.094 1.780 28/21	0	0	0	0	0	38	12	0	0	0	300	350
OCT	SUM PEAK DAY/HR	3.463 10.935 30/21	1127.448 3.560 30/21	1003.065 3.560 28/14	124.383 1.780 30/21	0	0	0	0	0	37	12	0	0	0	301	350
NOV	SUM PEAK DAY/HR	3.415 10.935 30/21	1111.808 3.560 30/21	1054.952 3.560 30/21	56.856 1.780 2/21	0	0	0	0	0	26	9	0	0	0	301	336
DEC	SUM PEAK DAY/HR	3.627 10.935 30/21	1180.743 3.560 30/21	1168.861 3.560 30/21	11.882 0.475 30/ 8	0	0	0	0	0	25	0	0	0	0	325	350
YR	SUM PEAK MON/DAY	42.895 10.935 12/30	13963.502 3.560 12/30	11271.005 3.560 12/30	2692.509 1.780 11/ 2	0	0	0	0	0	360	108	0	0	0	3774	4242

BOILER SIZE is -0.6098 (MBTU/HR) EIR = 0.0200 HIR = 1.250

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	FUEL USE (MBTU) (KBTU/HR)	AUX ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM -110.683 PEAK -1359.261 DAY/HR 12/13	1055.125 3.573 30/11	144.363 1455.959 12/13	1055.125 3.573 30/11	0	0	165	43	9	14	13	10	8	7	57	326
FEB	SUM -85.352 PEAK -1319.901 DAY/HR 11/ 9	1006.353 3.573 27/13	117.867 1424.074 11/ 9	1006.353 3.573 27/13	0	0	136	80	13	7	6	13	17	14	27	313
MAR	SUM -50.692 PEAK -1280.542 DAY/HR 24/13	954.361 3.573 31/ 9	77.561 1391.685 24/13	954.361 3.573 31/ 9	0	0	296	24	12	3	2	4	0	1	4	346
APR	SUM -19.799 PEAK -271.916 DAY/HR 8/ 9	457.749 3.573 9/ 9	32.232 389.724 8/ 9	457.749 3.573 9/ 9	0	0	220	1	1	0	0	0	0	0	0	222
MAY	SUM -10.608 PEAK -132.187 DAY/HR 10/ 9	248.650 3.098 10/ 9	17.335 216.012 10/ 9	248.650 3.098 10/ 9	0	0	161	0	0	0	0	0	0	0	0	161
JUN	SUM -0.652 PEAK -65.622 DAY/HR 24/ 9	15.280 1.538 24/ 9	1.065 107.235 24/ 9	15.280 1.538 24/ 9	0	0	20	0	0	0	0	0	0	0	0	20
JUL	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 31/ 1	0.000 0.000 31/ 1	0.000 0.000 31/ 1	0	0	0	0	0	0	0	0	0	0	0	0
AUG	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 31/ 1	0.000 0.000 31/ 1	0.000 0.000 31/ 1	0	0	0	0	0	0	0	0	0	0	0	0
SEP	SUM -7.025 PEAK -105.678 DAY/HR 23/ 9	164.663 2.477 23/ 9	11.480 172.693 23/ 9	164.663 2.477 23/ 9	0	0	113	0	0	0	0	0	0	0	0	113
OCT	SUM -17.745 PEAK -192.320 DAY/HR 21/ 9	413.945 3.573 21/ 9	28.960 296.562 21/ 9	413.945 3.573 21/ 9	0	0	237	2	0	0	0	0	0	0	0	239
NOV	SUM -42.219 PEAK -557.426 DAY/HR 26/11	833.155 3.573 30/21	65.852 706.934 26/11	833.155 3.573 30/21	0	0	262	22	3	6	6	4	1	1	0	305
DEC	SUM -79.213 PEAK -1214.943 DAY/HR 9/ 9	1116.614 3.573 30/13	113.840 1336.584 9/ 9	1116.614 3.573 30/13	0	0	186	73	10	14	22	9	6	14	11	345
YR	SUM -423.986 PEAK -1359.261 MON/DAY 1/12	6265.896 3.573 12/30	610.555 1455.959 1/12	6265.896 3.573 12/30	0	0	1796	245	48	44	49	40	32	37	99	2390

TOWER SIZE is		1.225 (MBTU/HR)	FAN = 3.66 (KW)	PUMP = 1.20 (KW)	PUMP = 221.57 (GAL/MIN)	Number of hours within each PART LOAD range											TOTAL
MONTH	SUM (MBTU)	ENERGY USE (KWH)	FAN ENERGY (KWH)	PUMP ENERGY (KWH)	00	10	20	30	40	50	60	70	80	90	100	RUN	
PEAK (KBTU/HR)	(KW)	(KW)	(KW)		10	20	30	40	50	60	70	80	90	100	+	HOURS	
JAN	SUM 2.243	63.976	14.583	49.393	13	21	3	3	1	0	0	0	0	0	0	41	
	PEAK 378.301	1.676	0.472	1.205													
	DAY/HR 8/8	30/16	30/16	30/21													
FEB	SUM 1.165	64.872	14.275	50.597	27	14	0	1	0	0	0	0	0	0	0	42	
	PEAK 139.217	1.625	0.420	1.205													
	DAY/HR 25/10	27/21	27/21	27/21													
MAR	SUM 10.975	248.917	62.255	186.661	46	46	19	17	28	0	0	0	0	0	0	156	
	PEAK 394.537	1.780	0.575	1.205													
	DAY/HR 25/8	2/14	2/14	31/17													
APR	SUM 60.897	546.262	150.793	395.472	12	31	32	55	179	21	0	0	0	0	0	330	
	PEAK 569.546	2.165	0.960	1.205													
	DAY/HR 27/17	27/17	27/17	30/21													
MAY	SUM 98.644	616.264	201.684	414.582	2	18	20	34	176	89	5	3	0	0	0	347	
	PEAK 852.670	3.478	2.273	1.205													
	DAY/HR 21/13	21/13	21/13	29/21													
JUN	SUM 180.367	751.460	322.672	428.791	2	4	12	18	85	155	82	5	0	0	0	363	
	PEAK 1041.354	3.373	2.168	1.205													
	DAY/HR 21/16	21/18	21/18	30/21													
JUL	SUM 272.506	972.118	537.429	434.691	0	0	6	16	12	81	169	56	21	3	0	364	
	PEAK 1115.039	4.440	3.235	1.205													
	DAY/HR 19/12	13/13	13/13	31/21													
AUG	SUM 232.257	857.705	425.691	432.016	0	3	6	12	37	131	146	28	1	0	0	364	
	PEAK 1062.108	3.689	2.484	1.205													
	DAY/HR 16/12	26/17	26/17	31/21													
SEP	SUM 113.299	637.064	220.041	417.025	2	16	22	24	169	98	19	0	0	0	0	350	
	PEAK 901.351	3.001	1.796	1.205													
	DAY/HR 11/16	11/16	11/16	30/21													
OCT	SUM 47.454	539.542	146.225	393.319	16	43	23	69	178	0	0	0	0	0	0	329	
	PEAK 352.851	1.897	0.692	1.205													
	DAY/HR 30/16	13/21	13/21	30/21													
NOV	SUM 20.475	270.878	77.862	193.016	42	44	17	13	25	21	0	0	0	0	0	162	
	PEAK 602.232	2.244	1.039	1.205													
	DAY/HR 1/12	1/12	1/12	30/8													
DEC	SUM 0.928	44.368	9.431	34.936	15	13	0	1	0	0	0	0	0	0	0	29	
	PEAK 162.244	1.573	0.368	1.205													
	DAY/HR 9/10	15/8	15/8	30/16													
YR	SUM 1041.210	5613.422	2182.943	3430.384	177	253	160	263	890	596	421	92	22	3	0	2877	
	PEAK 1115.039	4.440	3.235	1.205													
	MON/DAY 7/19	7/13	7/13	12/30													

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00521	25 16	48.F	42.F	2.129	-48.259	2 11	6.F	5.F	-351.600	7246.	38.349
FEB	0.00039	12 15	45.F	39.F	0.392	-37.872	8 10	14.F	12.F	-270.406	6128.	31.991
MAR	1.24768	3 15	76.F	65.F	130.753	-22.726	24 10	7.F	5.F	-271.649	5387.	28.917
APR	0.39189	27 18	85.F	62.F	55.219	-4.138	8 10	32.F	28.F	-120.393	3012.	20.278
MAY	2.00826	21 13	87.F	76.F	181.318	-0.516	8 10	45.F	43.F	-44.754	2631.	28.649
JUN	11.46037	21 18	83.F	73.F	179.012	-0.029	22 10	61.F	56.F	-5.409	3995.	28.427
JUL	36.71872	13 13	93.F	78.F	214.709	-0.018	22 10	63.F	60.F	-4.745	7268.	32.269
AUG	25.35133	16 15	85.F	73.F	188.274	-0.045	3 10	62.F	58.F	-4.955	5938.	29.353
SEP	4.45718	11 15	87.F	72.F	168.764	-0.176	22 10	38.F	33.F	-35.946	2882.	27.404
OCT	0.01405	27 11	56.F	46.F	4.128	-2.044	20 21	37.F	33.F	-85.709	2636.	16.541
NOV	3.27964	2 16	77.F	62.F	157.674	-16.568	15 10	30.F	27.F	-185.607	4789.	26.943
DEC	0.00048	10 15	41.F	35.F	0.480	-37.454	25 10	19.F	18.F	-252.001	6402.	30.857
TOTAL	84.935					-169.846					58312.	
.MAX					214.709					-351.600		38.349

----- N U M B E R O F H O U R S -----											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	5	325	3	417	744	744	327	0	0	0	0.000	9.989
FEB	1	299	1	373	672	672	299	0	0	0	-14.674	10.766
MAR	30	311	5	408	744	744	343	0	0	7	0.000	21.900
APR	28	112	10	590	720	720	315	0	0	185	0.000	15.873
MAY	36	33	5	680	744	744	300	0	0	236	0.000	28.649
JUN	154	31	14	549	720	720	313	0	0	142	0.000	28.353
JUL	305	14	8	433	744	744	329	0	0	18	0.000	31.727
AUG	267	36	14	455	744	744	321	0	0	32	0.000	29.353
SEP	57	24	6	645	720	720	300	0	0	225	0.000	27.404
OCT	21	87	7	643	744	744	301	0	0	200	0.000	8.393
NOV	54	248	8	426	720	720	303	0	0	9	0.000	26.943
DEC	1	325	1	419	744	744	325	0	0	0	-13.211	10.622
ANNUAL	959	1845	82	6038	8760	8760	3776	0	0	1054		

- - - - - COOLING - - - - -				- - - HEATING - - -			DAY COOLING PEAK				
JUL 13				JAN 2			JUL 19				
HOURLY	SENSIBLE	DRY-	WET-	HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-	
COOLING	HEAT	BULB	BULB	HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB	
LOAD	RATIO	TEMP	TEMP	LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP	
(KBTU)				(KBTU)			(KBTU)				
1	0.000	0.000	76.F	66.F	0.000	1.F	0.F	0.000	0.000	79.F	72.F
2	0.000	0.000	74.F	66.F	0.000	1.F	0.F	0.000	0.000	79.F	72.F
3	0.000	0.000	74.F	65.F	0.000	1.F	0.F	0.000	0.000	78.F	72.F
4	0.000	0.000	73.F	62.F	0.000	2.F	1.F	0.000	0.000	78.F	72.F
5	0.000	0.000	72.F	62.F	0.000	2.F	1.F	0.000	0.000	77.F	72.F
6	0.000	0.000	72.F	63.F	0.000	2.F	1.F	0.000	0.000	78.F	72.F
7	0.000	0.000	73.F	65.F	0.000	3.F	2.F	0.000	0.000	77.F	72.F
8	59.240	0.968	76.F	69.F	-283.386	4.F	3.F	102.567	0.967	79.F	72.F
9	167.735	0.328	82.F	72.F	-271.184	4.F	3.F	194.227	0.421	82.F	72.F
10	189.983	0.384	86.F	74.F	-344.805	5.F	4.F	201.691	0.465	85.F	73.F
11	206.023	0.418	89.F	76.F	-351.600	6.F	5.F	210.766	0.501	88.F	74.F
12	214.709	0.471	93.F	78.F	-332.819	8.F	7.F	202.586	0.532	89.F	74.F
13	186.237	0.550	95.F	78.F	-346.146	9.F	9.F	207.209	0.510	90.F	75.F
14	172.435	0.658	96.F	77.F	-329.527	11.F	11.F	199.869	0.521	89.F	75.F
15	180.252	0.672	97.F	77.F	-341.221	12.F	12.F	197.413	0.549	90.F	75.F
16	194.852	0.617	97.F	78.F	-325.745	14.F	13.F	200.861	0.526	91.F	76.F
17	172.468	0.735	99.F	77.F	-336.470	15.F	14.F	179.456	0.556	90.F	75.F
18	157.162	0.717	97.F	76.F	-325.347	15.F	15.F	167.941	0.483	86.F	74.F
19	149.184	0.680	95.F	75.F	-332.477	17.F	16.F	172.427	0.438	86.F	74.F
20	156.628	0.575	93.F	75.F	-323.992	17.F	16.F	148.047	0.330	80.F	72.F
21	0.000	0.000	90.F	74.F	-320.822	18.F	18.F	0.000	0.000	79.F	72.F
22	0.000	0.000	87.F	73.F	0.000	17.F	17.F	0.000	0.000	77.F	71.F
23	0.000	0.000	86.F	73.F	0.000	17.F	17.F	0.000	0.000	76.F	71.F
24	0.000	0.000	85.F	73.F	0.000	17.F	17.F	0.000	0.000	74.F	70.F
SUM								2385.060			
MAX	214.709				-351.600						

SYSTEM-TYPE HP SQFT/TON 268.3
 COOLING PEAK 44.73 (BTU/HR- SQFT) HEATING PEAK -73.25 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.20 (CFM/SQFT)
 OA FRAC AT CLG PEAK 0.651 OA FRAC AT HTG PEAK 0.651

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.08837	30 17	53.F	47.F	10.521	-79.832	2 9	4.F	3.F	-630.035	29778.	128.059
FEB	0.21546	13 11	39.F	36.F	27.318	-65.814	16 9	30.F	28.F	-510.081	26267.	116.615
MAR	3.98033	9 13	68.F	62.F	107.331	-44.076	24 9	7.F	6.F	-407.950	26547.	95.015
APR	36.26588	27 17	84.F	61.F	333.590	-14.202	8 9	30.F	27.F	-294.339	26727.	96.578
MAY	60.58792	24 10	58.F	50.F	415.281	-4.540	10 9	46.F	43.F	-163.621	28494.	114.935
JUN	109.72047	21 12	73.F	67.F	560.897	-0.071	23 21	56.F	48.F	-12.111	34447.	134.171
JUL	149.06900	6 10	73.F	62.F	581.222	0.000				0.000	40916.	136.203
AUG	131.95897	16 10	75.F	70.F	565.371	0.000				0.000	38424.	136.223
SEP	68.01752	11 16	86.F	72.F	452.997	-1.817	23 9	39.F	36.F	-105.713	28513.	118.435
OCT	25.58720	5 16	74.F	62.F	234.558	-10.101	20 9	41.F	35.F	-240.308	24686.	85.354
NOV	7.54162	1 12	69.F	61.F	271.229	-38.425	15 9	28.F	26.F	-463.361	24974.	106.187
DEC	0.04925	10 15	41.F	35.F	12.888	-67.690	27 9	31.F	30.F	-505.783	27952.	114.647
TOTAL	593.083					-326.567					357723.	
MAX					581.222					-630.035		136.223

----- N U M B E R O F H O U R S -----											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING AVAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	14	327	14	417	744	744	327	0	0	0	-74.998	62.384
FEB	34	299	34	373	672	672	299	0	0	0	-120.132	76.857
MAR	154	349	154	395	744	744	349	0	0	0	-34.931	73.835
APR	302	264	240	394	720	720	326	0	0	0	0.000	96.118
MAY	308	156	155	435	744	744	309	0	0	0	0.000	110.084
JUN	335	11	11	385	720	720	335	0	0	0	0.000	134.171
JUL	339	0	0	405	744	744	339	0	0	0	0.000	132.871
AUG	338	0	0	406	744	744	338	0	0	0	0.000	134.720
SEP	311	62	61	408	720	720	312	0	0	0	0.000	114.082
OCT	297	253	237	431	744	744	313	0	0	0	0.000	83.149
NOV	118	285	93	410	720	720	310	0	0	0	0.000	94.869
DEC	12	325	12	419	744	744	325	0	0	0	-15.294	67.228
ANNUAL	2562	2331	1011	4878	8760	8760	3882	0	0	0		

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY-BULB TEMP	WET-BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP
	JUL 6				JAN 2			JUL 6			
1	0.000	0.000	62.F	54.F	0.000	1.F	0.F	0.000	0.000	62.F	54.F
2	0.000	0.000	62.F	54.F	0.000	1.F	0.F	0.000	0.000	62.F	54.F
3	0.000	0.000	61.F	54.F	0.000	1.F	0.F	0.000	0.000	61.F	54.F
4	0.000	0.000	60.F	54.F	0.000	2.F	1.F	0.000	0.000	60.F	54.F
5	0.000	0.000	61.F	55.F	0.000	2.F	1.F	0.000	0.000	61.F	55.F
6	0.000	0.000	61.F	55.F	0.000	2.F	1.F	0.000	0.000	61.F	55.F
7	429.145 *	1.000	64.F	58.F	0.000	3.F	2.F	429.145 *	1.000	64.F	58.F
8	535.864 *	0.992	69.F	61.F	-611.701	4.F	3.F	535.864 *	0.992	69.F	61.F
9	581.222 *	0.935	73.F	62.F	-630.035	4.F	3.F	581.222 *	0.935	73.F	62.F
10	574.737 *	0.935	76.F	64.F	-594.115	5.F	4.F	574.737 *	0.935	76.F	64.F
11	570.144 *	0.936	78.F	64.F	-618.331	6.F	5.F	570.144 *	0.936	78.F	64.F
12	556.404 *	0.943	79.F	65.F	-576.913	8.F	7.F	556.404 *	0.943	79.F	65.F
13	541.387 *	0.951	80.F	66.F	-599.291	9.F	9.F	541.387 *	0.951	80.F	66.F
14	549.117 *	0.944	80.F	65.F	-572.238	11.F	11.F	549.117 *	0.944	80.F	65.F
15	548.087 *	0.936	81.F	66.F	-586.647	12.F	12.F	548.087 *	0.936	81.F	66.F
16	547.182 *	0.936	81.F	66.F	-558.866	14.F	13.F	547.182 *	0.936	81.F	66.F
17	544.226 *	0.934	81.F	67.F	-571.352	15.F	14.F	544.226 *	0.934	81.F	67.F
18	526.631 *	0.952	81.F	66.F	-543.045	15.F	15.F	526.631 *	0.952	81.F	66.F
19	515.167 *	0.951	78.F	64.F	-554.547	17.F	16.F	515.167 *	0.951	78.F	64.F
20	490.127	0.954	75.F	63.F	-525.450	17.F	16.F	490.127	0.954	75.F	63.F
21	0.000	0.000	72.F	61.F	-519.040	18.F	18.F	0.000	0.000	72.F	61.F
22	0.000	0.000	71.F	61.F	0.000	17.F	17.F	0.000	0.000	71.F	61.F
23	0.000	0.000	71.F	61.F	0.000	17.F	17.F	0.000	0.000	71.F	61.F
24	0.000	0.000	69.F	61.F	0.000	17.F	17.F	0.000	0.000	69.F	61.F
SUM								7509.439			
MAX	581.222				-630.035						

SYSTEM-TYPE HP SQFT/TON 481.5
 COOLING PEAK 24.92 (BTU/HR- SQFT) HEATING PEAK -27.02 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 0.91 (CFM/SQFT) MIN-OA/PERSON 0.00 (CFM)
 OA FRAC AT CLG PEAK 0.000 OA FRAC AT HTG PEAK 0.000

* ASTERISKS INDICATE HOURS LOADS NOT MET

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD
	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL	(MBTU/H)	AVAIL
DHW-HEATER	0.026	1								

S I T E E N E R G Y													* SOURCE
MONTH	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	4.8	0.0	39.9	0.0	0.0	0.0	0.1	151.4	15.6	0.0	151.5	287.5	559.7
FEB	4.2	0.0	35.0	0.0	0.0	0.0	0.2	124.1	13.1	0.0	124.1	243.8	483.0
MAR	4.8	0.0	34.9	0.0	0.0	0.0	1.6	84.7	9.4	0.0	84.7	203.9	442.5
APR	4.9	0.0	32.4	0.0	0.0	0.0	6.2	39.5	3.1	0.0	39.5	150.1	371.3
MAY	5.2	0.0	33.6	0.0	0.0	0.0	9.4	25.0	1.2	0.0	25.0	139.5	368.6
JUN	5.4	0.0	40.8	0.0	0.0	0.0	16.9	9.0	0.5	0.0	9.0	148.1	426.4
JUL	6.0	0.0	50.7	0.0	0.0	0.0	25.3	8.7	0.4	0.0	8.7	181.8	528.0
AUG	6.1	0.0	46.8	0.0	0.0	0.0	21.7	8.9	0.4	0.0	8.9	168.5	487.6
SEP	5.7	0.0	33.7	0.0	0.0	0.0	10.8	19.7	0.7	0.0	19.7	134.7	364.6
OCT	5.6	0.0	29.8	0.0	0.0	0.0	5.0	37.2	2.3	0.0	37.2	138.9	342.5
NOV	5.1	0.0	32.4	0.0	0.0	0.0	2.1	73.3	7.9	0.0	73.3	184.0	405.4
DEC	4.9	0.0	37.2	0.0	0.0	0.0	0.1	121.1	13.6	0.0	121.1	248.0	502.0
TOTAL	62.7	0.0	447.2	0.0	0.0	0.0	99.3	702.7	68.1	0.0	702.7	2228.8	5281.6

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
DHW-HEATER	62.7	100.0
LOAD SATISFIED	62.7	100.0
TOTAL LOAD ON PLANT	62.7	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	447159.2	100.0
LOAD SATISFIED	447159.2	100.0
TOTAL LOAD ON PLANT	447161.8	

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	62.7	62.7	0.000	0.000	0
ELECTRICAL LOADS	1526.1	1526.1	0.000	0.000	0

ENERGY TYPE: ELECTRICITY NATURAL-GAS
UNITS: MBTU

CATEGORY OF USE

AREA LIGHTS	481.9	0.0
MISC EQUIPMT	294.2	0.0
SPACE HEAT	214.3	610.6
SPACE COOL	319.8	0.0
HEAT REJECT	19.2	0.0
PUMPS & MISC	69.0	0.0
VENT FANS	109.9	0.0
DOMHOT WATER	18.0	92.1
TOTAL	1526.1	702.7

TOTAL SITE ENERGY 2228.85 MBTU 82.8 KBTU/SQFT-YR GROSS-AREA 82.8 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY 5281.61 MBTU 196.2 KBTU/SQFT-YR GROSS-AREA 196.2 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 16.2
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APFORTIONED HOURLY TO ALL END-USE CATEGORIES.

MEDICAL OFFICE BUILDING, CHICAGO
 SAMP3.INP RUN 1
 REPORT- ES-D ENERGY COST SUMMARY

WATER LOOP HEAT PUMP WITH STORAGE

DOE-2.1E-001 Wed Nov 10 15:17:48 1993EDL RUN 1

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	447159. KWH	34256.	0.0766	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	7027. THERM	6324.	0.9000	YES
				=====		
				40580.		
ENERGY COST/GROSS BLDG AREA:				1.51		
ENERGY COST/NET BLDG AREA:				1.51		

UTILITY-RATE: ELEC-COST RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0 SUM-P-DEM
 MAX-ENERGY: 0.0 WIN-P-DEM
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	39867	39867	174.8	174.8	1452	1387	0	0	0	0	186	0.0712	2839
FEB	35049	35049	157.3	157.3	1279	1348	0	0	0	0	186	0.0749	2626
MAR	34936	34936	130.5	130.5	1274	1287	0	0	0	0	186	0.0733	2562
APR	32403	32403	118.1	118.1	1183	1259	0	0	0	0	186	0.0754	2443
MAY	33557	33557	150.2	150.2	1350	1458	0	0	0	0	186	0.0837	2808
JUN	40764	40764	165.3	165.3	1656	1569	0	0	0	0	186	0.0791	3224
JUL	50712	50712	176.8	176.8	2055	1645	0	0	0	0	186	0.0730	3700
AUG	46752	46752	172.7	172.7	1902	1619	0	0	0	0	186	0.0753	3521
SEP	33675	33675	151.6	151.6	1361	1461	0	0	0	0	186	0.0838	2823
OCT	29815	29815	100.2	100.2	1197	1329	0	0	0	0	186	0.0847	2526
NOV	32428	32428	140.9	140.9	1182	1311	0	0	0	0	186	0.0769	2493
DEC	37201	37201	151.7	151.7	1357	1335	0	0	0	0	186	0.0724	2692
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
TOTAL	447159	447159	176.8		17248	17007	0	0	0	0		0.0766	34256

UTILITY-RATE: ELEC-COST
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR
SUM-P-DEM USE: TIME-OF-USE													
METERED DEMAND:	0.0	0.0	0.0	0.0	150.2	163.2	169.9	167.6	142.5	95.7	0.0	0.0	
BILLING DEMAND:	0.0	0.0	0.0	0.0	152.9	163.2	169.9	167.6	152.9	152.9	0.0	0.0	
DEMAND CHGS(\$):	0	0	0	0	1070	1142	1189	1173	1070	1070	0	0	6715
WIN-P-DEM USE: TIME-OF-USE													
METERED DEMAND:	152.9	130.5	107.7	118.1	0.0	0.0	0.0	0.0	0.0	0.0	119.9	129.3	
BILLING DEMAND:	152.9	152.9	152.9	152.9	0.0	0.0	0.0	0.0	0.0	0.0	152.9	152.9	
DEMAND CHGS(\$):	994	994	994	994	0	0	0	0	0	0	994	994	5962
TOTAL CHARGES (\$):	994	994	994	994	1070	1142	1189	1173	1070	1070	994	994	12677

RATCHETS	TYPE	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
SUM-RATCH	HIGHEST	152.9	152.9	152.9	152.9	152.9	152.9	152.9	152.9	152.9	152.9	152.9	152.9

UTILITY-RATE: GAS-COST RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	1515	1515	14.8	14.8	1363	0	0	0	0	0	0	0.9000	1363
FEB	1241	1241	14.2	14.2	1117	0	0	0	0	0	0	0.9000	1117
MAR	847	847	14.0	14.0	762	0	0	0	0	0	0	0.9000	762
APR	395	395	3.9	3.9	355	0	0	0	0	0	0	0.9000	355
MAY	250	250	2.2	2.2	225	0	0	0	0	0	0	0.9000	225
JUN	90	90	1.1	1.1	81	0	0	0	0	0	0	0.9000	81
JUL	87	87	0.4	0.4	79	0	0	0	0	0	0	0.9000	79
AUG	89	89	0.4	0.4	80	0	0	0	0	0	0	0.9000	80
SEP	197	197	1.9	1.9	178	0	0	0	0	0	0	0.9000	178
OCT	372	372	3.0	3.0	334	0	0	0	0	0	0	0.9000	334
NOV	733	733	7.4	7.4	660	0	0	0	0	0	0	0.9000	660
DEC	1211	1211	13.4	13.4	1090	0	0	0	0	0	0	0.9000	1090
TOTAL	7027	7027	14.8		6324	0	0	0	0	0		0.9000	6324

Office Building and Atrium Flower Shop

LDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993LDL RUN 2

```
* 499 * TITLE LINE-1 * OFFICE BUILDING & FLOWER SHOP, CHICAGO *
* 500 * LINE-2 * VAV SYSTEM IN OFFICE & SZRH IN SHOP *
* 501 * LINE-3 * DIRECT FIRED ABSORPTION W/ HWG *
* 502 * LINE-4 * SAMP3.INP RUN 2 * ..
* 503 *
* 504 * ABORT ERRORS ..
* 505 * DIAGNOSTIC WARNINGS ..
* 506 * RUN-PERIOD JAN 1 1988 THRU DEC 31 1988 ..
* 507 * BUILDING-LOCATION LATITUDE=42 LONGITUDE=88
* 508 * TIME-ZONE=6 ALTITUDE=610 ..
* 509 *
* 510 * LOADS-REPORT SUMMARY=(LS-D) ..
* 511 *
* 512 * $ BUILDING DESCRIPTION
* 513 *
* 514 * $ THE MEDICAL OFFICE BUILDING ABOVE HAS BEEN REMODELED WITH
* 515 * $ DIFFERENT USAGES TO DEMONSTRATE NEW FEATURES OF DOE2.1D.
* 516 *
* 517 * $ STRUCTURE REINFORCED CONCRETE CONSTRUCTION WITH 4IN CONCRETE FLOORS AND ROOF
* 518 * $ 10FT FLOOR TO FLOOR HEIGHT, TWO STORIES HIGH. RETURN AIR PLENUMS
* 519 * $ ARE NOT DEFINED.
* 520 *
* 521 * $ WALLS USING CODE WORDS FROM THE DOE-2 LIBRARY (REFERENCE MANUAL PART 2)
* 522 * $ AND STARTING WITH THE OUTSIDE SURFACE AND MOVING INWARD:
* 523 * $ 2IN PRECAST CONCRETE PANEL (CC03); 2IN POLYSTRENE INSULATION
* 524 * $ R-8 (IN35); 3IN AIRSPACE (AL21); 5/8IN GYPSUM BOARD (GP04);
* 525 * $ 3/4IN FINISH PLASTER.
* 526 *
* 527 * $ ATRIUM ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
* 528 * $ 6IN CONCRETE (CC04); INSIDE FILM RESISTANCE .76
* 529 *
* 530 * $ OFFICE ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
* 531 * $ 2 FT AIR SPACE (AL33); 3/4IN LAY-IN ACCOUSTIC TILE (AC03);
* 532 * $ INSIDE-FILM-RESISTANCE .76.
* 533 *
* 534 * $ FLOORS FIRST FL IS SLAB-ON-GRADE EFFECTIVE U-VALUE OF ENTIRE AREA .05.
* 535 *
* 536 * $ WINDOWS OFFICE AREA 4FT HIGH AND FULL WIDTH OF EACH WALL, EXCEPT SOUTH
* 537 * $ WALL WHERE THERE ARE NO WINDOWS. GLASS IS DOUBLE PANE TINTED
* 538 * $ WITH A SOLAR TRANSMITTANCE OF .53. WINDOWS HAVE INSIDE DRAPES
* 539 * $ THAT HAVE A PROBABILITY OF .7 OF BEING PULLED WHEN TRANSMITTED
* 540 * $ DIRECT RADIATION IS GREATER THAN 40 BTUH. DRAPES ARE THEN REOPEN-
* 541 * $ ED WITH A PROBABILITY OF .2 WHENEVER SOLAR DROPS BELOW 40BTUH.
* 542 * $ ATRIUM GLASS IS THE SAME AS OFFICE GLASS EXCEPT THAT IT DOES NOT
* 543 * $ HAVE DRAPES. THERE ARE TWO MAIN SECTIONS OF GLASS 29' WIDE BY
* 544 * $ 30' HIGH WITH OVERHANGS AND SIDE FINS. NOTICE THAT THE SKETCH
* 545 * $ OF THE BUILDING INDICATES A LARGE OVERHANG WHICH WOULD BE VERY
* 546 * $ DIFFICULT TO BUILD. THIS WAS THE WAY IT WAS SIMULATED AS THIS
* 547 * $ METHOD IS EQUIVALENT TO MULTIPLE SURFACES THAT PROVIDE THE SAME
* 548 * $ SHADING GEOMETRY.
* 549 *
* 550 * $ INTERIORS CEILINGS ARE SIMULATED AS PART OF THE ROOF STRUCTURE ON THE TOP
* 551 * $ FLOOR. PARTITIONS SIMULATE A GLASS WALL BETWEEN ATRIUM AND
* 552 * $ OFFICE SPACES, BUT WALLS BETWEEN INTERIOR AND EXTERIOR OFFICES
* 553 * $ ARE NOT DEFINED. WALLS BETWEEN THE EQUIPMENT ROOM AND OFFICES
* 554 * $ HAVE A U-VALUE OF .28.
* 555 *
```

```

* 556 * $ SPACE LOADS LIGHTING IS RECESSED FLUORSCENT NON VENTED AT 1.5 WATTS/SQFT IN
* 557 * $ THE OFFICES AND 2.2 WATT/SQFT IN THE FLOWER SHOP/ATRIUM.
* 558 * $ PEOPLE IN OFFICES IS INPUT AT 150SQFT/PERSON.
* 559 * $ PEOPLE IN ATRIUM ARE 6.
* 560 * $ INFILTRATION IS SET AT .2 AIRCHANGES/HR WHEN FANS ARE OFF AND AT
* 561 * $ .1 AIRCHANGE WHEN FANS ARE ON.
* 562 * $ EQUIPMENT IN OFFICES IS SET AT 1 WATTS/SQFT AND 1.5 W/SQFT IN
* 563 * $ THE FLOWER SHOP/ATRIUM.
* 564 *
* 565 *           $ CONSTRUCTIONS
* 566 *
* 567 * ROOF-O           =LAYERS           MAT=(BR01,IN76,CC03,AL33,AC03) I-F-R=.76 ..
* 568 * ROOF-A           =LAYERS           MAT=(BR01,IN76,CC04) I-F-R .76 ..
* 569 * OFF-ROF          =CONSTRUCTION   LAYERS ROOF-O ..
* 570 * ATR-ROF          =CONSTRUCTION   LAYERS ROOF-A ..
* 571 * WALL-1           =LAYERS           MAT=(CC33,IN35,AL21,GP04,GP04) ..
* 572 * WL1              =CONSTRUCTION   LAYERS=WALL-1 ..
* 573 * BW1              =CONSTRUCTION   U=.05 ..
* 574 * BW2              =CONSTRUCTION   U=.0001 ..
* 575 * WL2              =CONSTRUCTION   U=1.05 $ ATRIUM GLASS PARTITIONS $ ..
* 576 * WL3              =CONSTRUCTION   U=.28 $ INTERIOR PARTITIONS $ ..
* 577 *
* 578 *           $ GLASS DESCRIPTION
* 579 *
* 580 * GT1              =GLASS-TYPE   GLASS-TYPE-CODE 5 PANES 2 ..
* 581 * GT2              =GLASS-TYPE   G-T-C 5 PANES 2 ..
* 582 *
* 583 *           $ This command calls the file containing schedules
* 584 *           $ for offices that is on the sample run input
* 585 *           $ tape. It MUST reside in a directory on your
* 586 *           $ computer system so that this demonstration
* 587 *           $ of a GENERALIZED LIBRARY can function. For users
* 588 *           $ with a large computer system the file name should
* 589 *           $ include the full path name, or as an alternative
* 590 *           $ use the ##fileprefix command.
* 591 * ##include /u3/dae2/21d/dev/SAMPLES/officsch.inc
1 * 1 *
1 * 2 * $ This is a demonstration of how to use the GENERAL LIBRARY FEATURE.
1 * 3 * $ We have created a file of the OFFICE LOADS SCHEDULES from the MEDICAL BLDG
1 * 4 * $ BDL file and named it OFFICSCH.INP We then called these same schedules
1 * 5 * $ using the term - ##include officsch.inp - in these two input files.
1 * 6 *
1 * 7 *           $ OFFICE SCHEDULES
1 * 8 *
1 * 9 * OC1              =DAY-SCHEDULE   (1,9) (0) (10,12) (1) (13,14) (.8,.4)
1 * 10 *                (15,18) (.7) (19,21) (.4) (22,24) (.2) ..
1 * 11 * OC2              =DAY-SCHEDULE   (1,24) (.2) ..
1 * 12 * OCCUPANCY        =WEEK-SCHEDULE   (MON,TUE) OC1 (WED) OC2
1 * 13 *                (THU,SAT) OC1 (SUN,HOL) OC2 ..
1 * 14 * OCCUP            =SCHEDULE        THRU DEC 31 OCCUPANCY ..
1 * 15 *
1 * 16 * L1              =DAY-SCHEDULE   (1,6) (.2) (7,12) (.9) (13,14) (.8,.4)
1 * 17 *                (15,18) (.7) (19,21) (.4) (22,24) (.2) ..
1 * 18 * L2              =DAY-SCHEDULE   (1,24) (.2) ..
1 * 19 * LIGHTS           =WEEK-SCHEDULE   (MON,TUE) L1 (WED) L2
1 * 20 *                (THU,SAT) L1 (SUN,HOL) L2 ..
1 * 21 * LT1            =SCHEDULE        THRU DEC 31 LIGHTS ..
1 * 22 *
1 * 23 * ES1              =DAY-SCHEDULE   (1,9) (0) (10,21) (.9) (22,24) (.4) ..
1 * 24 * ES2              =DAY-SCHEDULE   (1,9) (0) (10,24) (.4) ..
1 * 25 * EQUIPMENT        =WEEK-SCHEDULE   (MON,TUE) ES1 (WED) ES2
1 * 26 *                (THU,SAT) ES1 (SUN,HOL) ES2 ..
1 * 27 * EQ1            =SCHEDULE        THRU DEC 31 EQUIPMENT ..
1 * 28 *
1 * 29 * I1              =DAY-SCHEDULE   (1,9) (1) (10,21) (.5) (22,24) (1) ..

```

```

1 * 30 * INFILTRAT =WEEK-SCHEDULE (ALL) I1 ..
1 * 31 * INF1 =SCHEDULE THRU DEC 31 INFILTRAT ..
1 * 32 *
file : INPUT2.TMP
* 592 *
* 593 * $ FLOWER SHOP SCHEDULES $
* 594 *
* 595 * OC4 = D-SCH (1,7) (0) (8,11) (.1,.2,.5,.5) (12,15) (.7)
* 596 * (16,21) (.8,.7,.5,.5,.3,.3) (22,24) (0) ..
* 597 * OC5 = D-SCH (1,7) (0) (8,11) (.1,.2,.5,.6) (12,17) (.8)
* 598 * (18,22) (.6,.2,.2,.2,.1) (23,24) (0) ..
* 599 * OC6 = D-SCH (1,24) (0) ..
* 600 * OCCUP2 = SCH THRU DEC 31 (WD) OC4 (SAT) OC5 (SUN,HOL) OC6 ..
* 601 *
* 602 * L4 = D-SCH (1,7) (0) (8,9) (.2,.5) (10,18) (.9)
* 603 * (19,24) (.6,.6,.5,.2,0,0) ..
* 604 * L5 = D-SCH (1,7) (0) (8,10) (.1,.3,.6) (11,18) (.9)
* 605 * (19,24) (.5,.3,.3,.1,0,0) ..
* 606 * L6 = D-SCH (1,24) (0) ..
* 607 * LIGHTS2 = SCH THRU DEC 31 (WD) L4 (SAT) L5 (SUN,HOL) L6 ..
* 608 *
* 609 * IF4 = D-SCH (1,6) (1) (7,21) (0) (22,24) (1) ..
* 610 * IF5 = D-SCH (1,6) (1) (7,22) (0) (23,24) (1) ..
* 611 * IF6 = D-SCH (1,24) (1) ..
* 612 * INFIL = SCH THRU DEC 31 (WD) IF4 (SAT) IF5 (SUN,HOL) IF6 ..
* 613 *
* 614 * EQ2 = SCH THRU DEC 31 (ALL) (1,24) (1) .. $ REFRIGERATOR COMPRESSOR HEAT
* 615 * $ REJECTED TO SPACE
* 616 *
* 617 * SHADE-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.6) ..
* 618 * COND-MULT =SCHEDULE THRU DEC 31 (ALL) (1,24) (.90) ..
* 619 * CLOSE-SHADE =SCHEDULE THRU DEC 31 (ALL) (1,24) (40) ..
* 620 * REOPEN-PROB =SCHEDULE THRU DEC 31 (ALL) (1,24) (.2) ..
* 621 *
* 622 * $ SET DEFAULTS
* 623 *
* 624 * SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=10 AZIMUTH=180
* 625 * CONSTRUCTION=W1 ..
* 626 * SET-DEFAULT FOR WINDOW HEIGHT=4 Y=4 GLASS-TYPE=GT1
* 627 * MAX-SOLAR-SCH=CLOSE-SHADE SUN-CTRL-PROB .7
* 628 * WIN-SHADE-TYPE=MOVABLE-INTERIOR
* 629 * SHADING-SCHEDULE=SHADE-MULT
* 630 * CONDUCT-SCHEDULE=COND-MULT
* 631 * OPEN-SHADE-SCH=REOPEN-PROB ..
* 632 *
* 633 * $ SPACE DESCRIPTION
* 634 *
* 635 * OFFICE =SPACE-CONDITIONS TEMPERATURE=(74) FLOOR-WEIGHT=70
* 636 * EQUIPMENT-W/SQFT=1 EQUIP-SCHEDULE=EQ1
* 637 * LIGHTING-W/SQFT=1.5 LIGHTING-SCHEDULE=LT1
* 638 * INF-METHOD=AIR-CHANGE AIR-CHANGES/HR=.2
* 639 * LIGHTING-TYPE=SUS-FLUOR
* 640 * PEOPLE-HG-LAT=200 PEOPLE-HG-SENS=250
* 641 * PEOPLE-SCHEDULE=OCCUP ..
* 642 *
* 643 * ATRIUM =SPACE-CONDITIONS TEMPERATURE=(74) FLOOR-WEIGHT=100
* 644 * LIGHTING-SCHEDULE=LIGHTS2
* 645 * LIGHTING-TYPE=INCAND
* 646 * LIGHTING-W/SQFT=2.2
* 647 * EQUIP-SCHEDULE=EQ2
* 648 * EQUIPMENT-W/SQFT=1.5
* 649 * NUMBER-OF-PEOPLE=6
* 650 * PEOPLE-HEAT-GAIN= 550
* 651 * PEOPLE-SCHEDULE = OCCUP2
* 652 * INF-SCHEDULE=INFIL AIR-CHANGES/HR=.2

```

```

* 653 *                               INF-METHOD=AIR-CHANGE ..
* 654 *
* 655 * BZ1      =SPACE                S-C=OFFICE NUMBER-OF-PEOPLE=20
* 656 *                               AREA=3230 VOLUME=29070 AZ=90 Y=200 ..
* 657 *
* 658 *
* 659 * E1       =EXTERIOR-WALL        WIDTH=200 ..
* 660 * W1       =WINDOW                WIDTH=200 ..
* 661 *
* 662 * E1S      =EXTERIOR-WALL        W=17 AZ=90 X=200 ..
* 663 *
* 664 *          UNDERGROUND-FLOOR    AREA=3230 CONS=BW1 ..
* 665 *
* 666 * BZ2      =SPACE                S-C=OFFICE AREA=1660 VOLUME=14940
* 667 *                               NUMBER-OF-PEOPLE=10 AZ=180 X=100 Y=200 ..
* 668 *
* 669 * E2       =EXTERIOR-WALL        WIDTH=100 ..
* 670 * W2       =WINDOW                WIDTH=100 ..
* 671 *
* 672 *          UNDERGROUND-FLOOR    AREA=1660 CONS=BW1 ..
* 673 *
* 674 * BZ3      =SPACE                LIKE BZ1 AZ=-90 X=100 Y=0 ..
* 675 *
* 676 * E3       =EXTERIOR-WALL        LIKE E1 ..
* 677 * W3       =WINDOW                LIKE W1 ..
* 678 *
* 679 * E3S      =EXTERIOR-WALL        W=17 AZ=270 Y=17 ..
* 680 *
* 681 *          UNDERGROUND-FLOOR    AREA=3230 CONS=BW1 ..
* 682 *
* 683 * TZ1      =SPACE                LIKE BZ1 Z=10 ..
* 684 *
* 685 * R1       =ROOF                  H=17 W=200 AZ=180 TILT=0 Z=10
* 686 *                               CONS=OFF-ROF ..
* 687 *
* 688 *          EXTERIOR-WALL        LIKE E1 ..
* 689 *          WINDOW                LIKE W1 ..
* 690 *
* 691 *          EXTERIOR-WALL        LIKE E1S ..
* 692 *
* 693 * T22      =SPACE                LIKE BZ2 Z=10 ..
* 694 *
* 695 *          ROOF                  LIKE R1 H=20 W=83 ..
* 696 *
* 697 *          EXTERIOR-WALL        LIKE E2 ..
* 698 *          WINDOW                LIKE W2 ..
* 699 *
* 700 * T23      =SPACE                LIKE BZ3 Z=10 ..
* 701 *          ROOF                  LIKE R1 H=17 W=180 ..
* 702 *          EXTERIOR-WALL        LIKE E3 ..
* 703 *          WINDOW                LIKE W3 ..
* 704 *          EXTERIOR-WALL        LIKE E3S ..
* 705 *
* 706 * IZ1      =SPACE                S-C=OFFICE AREA=3540 VOLUME=70800
* 707 *                               NUMBER-OF-PEOPLE=40 AZ=90 X=17 Y=180 ..
* 708 *
* 709 * IN1      =INTERIOR-WALL        AREA=1200 NEXT-TO ATZ1 CONS=WL2 ..
* 710 * IN2      =INTERIOR-WALL        AREA=1200 NEXT-TO ATZ2 CONS=WL2 ..
* 711 * IN3      =INTERIOR-WALL        AREA=800 NEXT-TO EQUIP-RM CONS=WL3 ..
* 712 *          ROOF                  LIKE R1 H=18 W=180 Z=20 ..
* 713 *          ROOF                  LIKE R1 H=15 W=20 Y=18 Z=20 ..
* 714 *          EXTERIOR-WALL        H=20 W=18 AZ=90 X=180 ..
* 715 *          UNDERGROUND-FLOOR    AREA=3540 CONS=BW1 ..
* 716 *
* 717 * IZ2      =SPACE                LIKE IZ1 AZ=-90 X=83 Y=0 ..

```

```

* 718 *
* 719 *      INTERIOR-WALL      LIKE IN1 NEXT-TO ATZ1 ..
* 720 *      INTERIOR-WALL      LIKE IN2 NEXT-TO ATZ2 ..
* 721 *      INTERIOR-WALL      LIKE IN3 ..
* 722 *      EXTERIOR-WALL      H=20 W=18 AZ=270 Y=18 ..
* 723 *      ROOF                LIKE R1 H=18 W=180 Z=20 ..
* 724 *      ROOF                LIKE R1 H=15 W=20 X=160 Y=18 Z=20 ..
* 725 *      UNDERGROUND-FLOOR  AREA=3540 CONS=BW1 ..
* 726 *
* 727 * ATZ1      =SPACE        S-C=ATRIUM AREA=1800 VOLUME=16200
* 728 *          X=35 Y=40 ..
* 729 *
* 730 * ATROOF-1  =ROOF        HEIGHT=66.6 WIDTH=30
* 731 *          AZIMUTH=0 TILT=26 X=30 Y=60 Z=20
* 732 *          CONS=ATR-ROF ..
* 733 * E4        =EXTERIOR-WALL  H=14.5 W=60 AZ=270 Y=60 Z=20 ..
* 734 * E5        =EXTERIOR-WALL  LIKE E4 AZ=90 X=30 Y=0 ..
* 735 * F1        =UNDERGROUND-FLOOR  AREA=1800 CONS=BW2 ..
* 736 * FRAME-A   =EXTERIOR-WALL  HEIGHT=29 WIDTH=30 Z=20 ..
* 737 * WINDOW-A  =WINDOW        H=28.9 W=29.9 X=.05 Y=.05 GLASS-TYPE=GT2
* 738 *          OVERHANG-A=6 OH-B=0 OH-D=48.5 OH-W=42
* 739 *          OVERHANG-ANGLE=116 LEFT-FIN-A=0 L-F-B=0
* 740 *          L-F-H=30 L-F-D=3 RIGHT-FIN-A=0 R-F-B=0
* 741 *          R-F-H=30 R-F-D=3 ..
* 742 *          EXTERIOR-WALL    LIKE FRAME-A HEIGHT=10.7 W=30 Z=9.3 ..
* 743 *          WINDOW          LIKE WINDOW-A H=10.6 W=29.9 L-F-H=10.7
* 744 *          R-F-H=10.7 ..
* 745 *
* 746 * ATZ2      =SPACE        LIKE ATZ1 Y=100 ..
* 747 *
* 748 * ATROOF-2  =ROOF        LIKE ATROOF-1 ..
* 749 *          EXTERIOR-WALL    LIKE E4 ..
* 750 *          EXTERIOR-WALL    LIKE E5 ..
* 751 *          UNDERGROUND-FLOOR  LIKE F1 ..
* 752 * FRAME-B   =EXTERIOR-WALL  LIKE FRAME-A ..
* 753 * WINDOW-B  =WINDOW        LIKE WINDOW-A ..
* 754 *
* 755 * EQUIP-RM  =SPACE        ZONE-TYPE=UNCONDITIONED
* 756 *          AREA=1200 VOLUME=17580 X=35 ..
* 757 *
* 758 *          EXTERIOR-WALL    HEIGHT=20 WIDTH=30 ..
* 759 *
* 760 *          ROOF            H=41.2 W=30 CONS=OFF-ROF
* 761 *          TILT=15 Z=9.3 X=30 Y=40 AZIMUTH=0 ..
* 762 *
* 763 *          INTERIOR-WALL    AREA=279 CONS=WL3 NEXT-TO ATZ1 ..
* 764 *          UNDERGROUND-FLOOR  AREA=1200 CONS=BW1 ..
* 765 *
* 766 *
* 767 * END ..
* 768 * COMPUTE LOADS ..
* 769 * INPUT SYSTEMS ..

```

SDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993SDL RUN 2

```

* 770 * SYSTEMS-REPORT SUMMARY (SS-D,SS-A,SS-J) ..
* 771 * SUBR-FUNCTIONS DKTEMP-3="dktempF" ..
* 772 *
* 773 *           $ HVAC SYSTEMS DESCRIPTION
* 774 *
* 775 * $ DESIGN TEMPS ATRIUM COOLING 76F-SUMMER, 72F-WINTER HEATING SETBACK 65F
* 776 * $ OFFICE COOLING 76F HEATING 72F
* 777 * $ SYSTEM TYPE THE OFFICE IS SERVED BY A VAVS SYSTEM.
* 778 *
* 779 * $ THE ATRIUM/FLOWER SHOP IS SERVED BY A REHEAT SYSTEM CONVERTED
* 780 * $ TO A CONSTANT VOLUME-VARIABLE TEMPERATURE SYSTEM. THE FUNCTION
* 781 * $ FEATURE IS USED TO SIMULATE THE CONTROL OF THIS UNIT BY USING A
* 782 * $ RETURN AIR STAT RATHER THAN HOLDING THE SUPPLY TEMPERATURE
* 783 * $ CONSTANT. THIS IS A VERY COMMON MODELING REQUIREMENT AS MANY
* 784 * $ REHEAT SYSTEMS HAD BOILERS TURNED OFF IN THE SUMMER AND OVER-
* 785 * $ COOLED WITHOUT SOME WAY TO MODULATE THE SUPPLY AIR TEMPERATURE.
* 786 *
* 787 * $ BOTH SYSTEMS HAVE DRY BULB ECONOMIZERS WITH A 68F LIMIT ON THE
* 788 * $ VAV SYSTEM AND ON THE REHEAT SYSTEM.
* 789 *
* 790 *           $ AIR HANDLING UNIT SCHEDULES
* 791 *
* 792 * DAYS = WEEK-SCHEDULE (MON,SAT) (1,7)(0)(8,9)(-999)(10,21)(1)(22,24)(0)
* 793 * (SUN,HOL) (1,24)(0) ..
* 794 * AHU-SCHED = SCHEDULE THRU DEC 31 DAYS ..
* 795 *
* 796 *           $ HEATING THERMOSTAT SCHEDULE
* 797 *
* 798 * THEAT1 = SCHEDULE THRU DEC 31 (MON,SAT) (1,7)(65)(8,21)(72)(22,24)(65)
* 799 * (SUN,HOL) (1,24)(65) ..
* 800 *
* 801 *           $ COOLING THERMOSTAT SCHEDULE
* 802 *
* 803 * TCOOL1 = SCHEDULE THRU DEC 31 (MON,SAT) (1,7)(90)(8,21)(76)(22,24)(90)
* 804 * (SUN,HOL) (1,24)(90) ..
* 805 *
* 806 * MIN-OA = SCHEDULE THRU DEC 31 (ALL) (1,9)(0)(10,21)(-999)(22,24)(0) ..
* 807 *
* 808 * HEAT-OFF-SUM = SCHEDULE THRU MAY 15 (ALL) (1,24)(1)
* 809 * THRU OCT 15 (ALL) (1,24)(0)
* 810 * THRU DEC 31 (ALL) (1,24)(1) ..
* 811 *
* 812 *           $ ZONE DESCRIPTION
* 813 *
* 814 * ENV-ATR = ZONE-CONTROL D-H-T 72 D-C-T 74 H-T-SCH THEAT1 C-T-SCH TCOOL1
* 815 * T-TYPE PROPORTIONAL ..
* 816 * ENV-OFF = ZONE-CONTROL D-H-T 74 D-C-T 74 H-T-SCH THEAT1 C-T-SCH TCOOL1
* 817 * T-TYPE REVERSE-ACTION ..
* 818 * ATZ1 = ZONE Z-C ENV-ATR OUTSIDE-AIR-CFM 665 ..
* 819 * ATZ2 = ZONE LIKE ATZ1 ..
* 820 * EQUIP-RM = ZONE ZONE-TYPE=UNCONDITIONED ..
* 821 * BZ1 = ZONE Z-C ENV-OFF OA-CFM/PER=15 ..
* 822 * BZ2 = ZONE LIKE BZ1 ..
* 823 * BZ3 = ZONE LIKE BZ1 ..
* 824 * TZ1 = ZONE LIKE BZ1 ..
* 825 * TZ2 = ZONE LIKE BZ1 ..
* 826 * TZ3 = ZONE LIKE BZ1 ..

```



```

* 827 * IZ1          = ZONE LIKE BZ1 ..
* 828 * IZ2          = ZONE LIKE BZ1 ..
* 829 *
* 830 * FS-SYS       = SYSTEM      SYSTEM-TYPE=RHFS MAX-S-T=100 MIN-S-T=55
* 831 *              SUPPLY-STATIC=3 SUPPLY-EFF=.45 ECONO-LIMIT-T=68
* 832 *              FAN-SCHEDULE=AHU-SCHED REHEAT-DELTA-T=50
* 833 *              HEATING-SCHEDULE=HEAT-OFF-SUM
* 834 *              NIGHT-CYCLE-CTRL=CYCLE-ON-FIRST
* 835 *              ZONE-NAMES=(ATZ1,ATZ2,EQUIP-RM)
* 836 *              FUNCTION=(*sfn0*,*sfn1*) ..
* 837 *
* 838 * OFF-SYS      = SYSTEM      SYSTEM-TYPE=VAVS MAX-S-T=120 MIN-S-T=60
* 839 *              SUPPLY-STATIC=5 SUPPLY-EFF=.55 ECONO-LIMIT-T=68
* 840 *              FAN-SCHEDULE=AHU-SCHED MIN-CFM-RATIO=.3
* 841 *              FAN-CONTROL=SPEED HEAT-SET-T=100
* 842 *              RETURN-AIR-PATH=DUCT OA-CONTROL=TEMP
* 843 *              NIGHT-CYCLE-CTRL=CYCLE-ON-ANY
* 844 *              MIN-AIR-SCH=MIN-OA REHEAT-DELTA-T=55
* 845 *              ZONE-NAMES=(BZ1,BZ2,BZ3,TZ1,TZ2,TZ3,IZ1,IZ2) ..
* 846 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (FS-SYS,OFF-SYS)
* 847 *              DHW-SIZE      = 0
* 848 *              DHW-GAL/MIN  = 2.22
* 849 *              DHW-SCH      = DOMHW ..
* 850 *
* 851 * D1 = D-SCH (1,7) (0) (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.45,.4,.3,.3)
* 852 *              (22,24) (0) ..
* 853 * D2 = D-SCH (1,7) (0) (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.4,.35,
* 854 *              .25,.2) (23,24) (0) ..
* 855 * D3 = D-SCH (1,9) (0) (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
* 856 *              (20,24) (0) ..
* 857 * DOMHW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
* 858 * END ..
* 859 *
* 860 * $ THE FOLLOWING IS THE FUNCTION INPUT TO CONTROL THE SUPPLY AIR TEMPERATURE OF
* 861 * $ THE REHEAT UNIT WITH A RETURN AIR THERMOSTAT.
* 862 *
* 863 * FUNCTION NAME=dktempF ..
* 864 * ASSIGN IHR=IHR IDAY=IDAY IMO=IMO INILZE=INILZE ..
* 865 * ASSIGN TR=TR $ return air temp $
* 866 *          TC=TC $ supply temp $
* 867 *          TH=TH $ hot-deck temp $ ..
* 868 * ASSIGN TCTR=TABLE (70,70) (80,50) .. $ pwl function of tc vs tr $
* 869 * ASSIGN TRLAST = F-SYS-VAR1 ..
* 870 * CALCULATE ..
* 871 *          IF ( (IDAY.EQ. 7) .AND. (IMO.EQ. 7) )
* 872 *              1 PRINT 1, IMO, IDAY, IHR, TC, TH, TRLAST
* 873 *          1 FORMAT( ' dktempF-- IMO, IDAY, IHR=' ,3f3.0, ' TC='f7.2, ' TH='f7.2
* 874 *              ' TRLAST='f7.2 )
* 875 *          IF( TRLAST.EQ. 0. ) RETURN
* 876 *          TC = PWL( TCTR, TRLAST )
* 877 *          IF ( (IDAY.EQ. 7) .AND. (IMO.EQ. 7) )
* 878 *              1 PRINT 2, TC
* 879 *          2 FORMAT( ' new TC='f7.2 )
* 880 *          END

```

----- S Y M B O L T A B L E -----

IDAY	(GLOBAL)	IHR	(GLOBAL)	IMO	(GLOBAL)	TC	(GLOBAL)	TCTR	(TABLE)
TH	(GLOBAL)	TRLAST	(GLOBAL)						

```

* 881 * END-FUNCTION ..
* 882 * FUNCTION NAME=sfn0 LEVEL=BUILDING ..
* 883 * ASSIGN IHR=IHR IDAY=IDAY IMO=IMO INILZE=INILZE ..

```

```

* 884 * ASSIGN TR=TR $ return air temp $
* 885 *          TC=TC $ suppy temp $
* 886 *          TH=TH $ hot-deck temp $ ..
* 887 * CALCULATE ..
* 888 *       IF( INILZE .LT. 4 ) RETURN
* 889 *       IF( (IDAY .NE. 7) .OR. (IMO .NE. 7) ) RETURN
* 890 *       PRINT 9
* 891 * 9     FORMAT(1X)
* 892 *       PRINT 1, IMO, IDAY, IHR, TC, TH, TR
* 893 * 1     FORMAT( ' sfn0 -- IMO, IDAY, IHR=',3f3.0,' TC=',f7.2,
* 894 * 1     ' TH=',f7.2,' TR=',f7.2 )
* 895 *       END

```

----- S Y M B O L T A B L E -----

IDAY	(GLOBAL)	IHR	(GLOBAL)	IMO	(GLOBAL)	INILZE	(GLOBAL)	TC	(GLOBAL)
TH	(GLOBAL)	TR	(GLOBAL)						

```

* 896 * END-FUNCTION ..
* 897 * FUNCTION NAME=sfn1      LEVEL=BUILDING      ..
* 898 * ASSIGN IHR=IHR IDAY=IDAY IMO=IMO INILZE=INILZE ..
* 899 * ASSIGN TR=TR $ return air temp $
* 900 *          TC=TC $ suppy temp $
* 901 *          TH=TH $ hot-deck temp $ ..
* 902 * ASSIGN TRLAST = F-SYS-VAR1      ..
* 903 * CALCULATE ..
* 904 * C--- store TR for use by 'dktempF'
* 905 *       TRLAST = TR
* 906 *       IF( INILZE .LT. 4 ) RETURN
* 907 *       IF ( (IDAY .NE. 7) .OR. (IMO .NE. 7) ) RETURN
* 908 *       PRINT 1, IMO, IDAY, IHR, TC, TH, TR
* 909 * 1     FORMAT( ' sfn1 -- IMO, IDAY, IHR=',3f3.0,' TC=',f7.2,
* 910 * 1     ' TH=',f7.2,' TR=',f7.2 )
* 911 *       END

```

----- S Y M B O L T A B L E -----

IDAY	(GLOBAL)	IHR	(GLOBAL)	IMO	(GLOBAL)	INILZE	(GLOBAL)	TC	(GLOBAL)
TH	(GLOBAL)	TR	(GLOBAL)	TRLAST	(GLOBAL)				

```

* 912 * END-FUNCTION ..
* 913 *
* 914 * COMPUTE SYSTEMS ..
* 915 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993PDL RUN 2

```
* 916 * PLANT-REPORT SUMMARY (PS-A,PS-D,BEPS) ..
* 917 * PLANT1 = PLANT-ASSIGNMENT ..
* 918 *
* 919 *
* 920 *           $ PLANT DESCRIPTION
* 921 * $ THIS PLANT IS SERVED BY A DIRECT-FIRED ABSORPTION CHILLER/HWG COMBINATION
* 922 * $ UNIT WHERE THE CAPACITY OF THE HWG IS SET TO THE CAPACITY OF THE CHILLER,
* 923 * $ WHICH IS THE GREATER OF THE TWO REQUIREMENTS. OTHERWISE A HWG WOULD HAVE
* 924 * $ BEEN REQUIRED TO SUPPLEMENT THE CHLR/HTR. A DOMESTIC HOT WATER HEATER IS
* 925 * $ ALSO REQUIRED.
* 926 *
* 927 * CHL = PLANT-EQUIPMENT TYPE=ABSORG-CHLR SIZE -999 I-N 1 ..
* 928 * DHW = PLANT-EQUIPMENT TYPE=DHW-HEATER SIZE -999 I-N 1 ..
* 929 * CTR = PLANT-EQUIPMENT TYPE=COOLING-TWR SIZE -999 ..
* 930 *
* 931 * END ..
* 932 * COMPUTE PLANT ..
* 933 *
* 934 * INPUT ECONOMICS ..
```

EDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993EDL RUN 2

```

* 935 * DIAGNOSTIC WARNINGS ..
* 936 * ECONOMICS-REPORT SUMMARY (ES-D,ES-E) ..
* 937 *
* 938 *           $ ENERGY CHARGE DESCRIPTION
* 939 *
* 940 * $ THIS RATE STRUCTURE IS A TYPICAL SMALL COMMERCIAL TIME OF DAY TYPE WITH AND
* 941 * $ INVERTED RATE. IN OTHER WORDS ENERGY COSTS INCREASE AS CONSUMPTION RISES.
* 942 * $ THERE IS A BASE CHARGE OF 2 CENTS/KWH PLUS A FIXED MONTHLY CHARGE OF 200
* 943 * $ DOLLARS. ON TOP OF THESE CHARGES FALL THE KWH/KW ENERGY CHARGE FOR EACH
* 944 * $ SEASON. THERE IS A LIMITATION OF 15000 KWHS FOR THE FIRST BLOCK.
* 945 * $ NATURAL GAS IS A FLAT RATE OF 60 CENTS PER THERM.
* 946 *
* 947 * ELBC-COST = UTILITY-RATE   RESOURCE = ELECTRICITY
* 948 *                               MONTH-CHGS (200)
* 949 *                               BLOCK-CHARGES = (WIN-OFF-P,WIN-ON-P,
* 950 *                               SUM-OFF-P,SUM-ON-P)
* 951 *                               ENERGY-CHG = .02 ..
* 952 *
* 953 * WIN-OFF-P = BLOCK-CHARGE   BLOCK-SCH = TOU-CHGS
* 954 *                               SCH-FLAG = 1.1
* 955 *                               BLOCK1-TYPE = KWH/KW
* 956 *                               BLOCK1-DATA = (200,.025,15000,
* 957 *                               1,.035,0) ..
* 958 * WIN-ON-P = BLOCK-CHARGE   BLOCK-SCH = TOU-CHGS
* 959 *                               SCH-FLAG = 1.2
* 960 *                               BLOCK1-TYPE = KWH/KW
* 961 *                               BLOCK1-DATA = (200,.040,15000,
* 962 *                               1,.050,0) ..
* 963 * SUM-OFF-P = BLOCK-CHARGE  BLOCK-SCH = TOU-CHGS
* 964 *                               SCH-FLAG = 2.1
* 965 *                               BLOCK1-TYPE = KWH/KW
* 966 *                               BLOCK1-DATA = (200,.025,15000,
* 967 *                               1,.035,0) ..
* 968 * SUM-ON-P = BLOCK-CHARGE   BLOCK-SCH = TOU-CHGS
* 969 *                               SCH-FLAG = 2.2
* 970 *                               BLOCK1-TYPE = KWH/KW
* 971 *                               BLOCK1-DATA = (150,.045,15000,
* 972 *                               1,.055,0) ..
* 973 * TOU-CHGS = SCHEDULE THRU MAY 15 (ALL) (1,12) (1.1)
* 974 *                               (13,17) (1.2)
* 975 *                               (18,24) (1.1)
* 976 *                               THRU OCT 20 (ALL) (1,12) (2.1)
* 977 *                               (13,18) (2.2)
* 978 *                               (19,24) (2.1)
* 979 *                               THRU DEC 31 (ALL) (1,12) (1.1)
* 980 *                               (13,17) (1.2)
* 981 *                               (18,24) (1.1) ..
* 982 *
* 983 * GAS-COST = UTILITY-RATE   RESOURCE = NATURAL-GAS
* 984 *                               ENERGY-CHG = .60 ..
* 985 * END ..
* 986 * COMPUTE ECONOMICS ..
* 987 * INPUT LOADS ..

```

- - - - - C O O L I N G - - - - -						- - - - - H E A T I N G - - - - -						- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	6.53487	25 16	48.F	42.F	160.330	-104.325	1 7	-1.F	-1.F	-384.918	24148.	64.998	
FEB	8.31394	9 16	23.F	19.F	156.275	-87.265	4 6	7.F	6.F	-352.845	21865.	64.998	
MAR	22.44304	2 17	71.F	60.F	199.429	-54.049	24 6	8.F	7.F	-334.236	24734.	64.998	
APR	65.98293	27 16	84.F	61.F	392.264	-20.141	8 5	33.F	30.F	-227.469	24212.	64.998	
MAY	95.57850	20 15	77.F	68.F	400.208	-6.552	9 5	40.F	38.F	-122.989	24148.	64.998	
JUN	141.09129	4 15	85.F	67.F	461.995	-0.405	24 4	55.F	49.F	-22.741	23806.	64.998	
JUL	190.04869	9 17	97.F	73.F	500.535	0.000	6 4	60.F	54.F	-0.274	24639.	64.998	
AUG	166.02115	20 15	88.F	72.F	473.787	-0.017	5 5	55.F	54.F	-10.250	24649.	64.998	
SEP	99.29288	11 16	86.F	72.F	426.397	-3.526	22 6	35.F	31.F	-96.994	23316.	64.998	
OCT	57.07592	5 15	74.F	62.F	328.327	-15.240	21 5	30.F	29.F	-158.468	24148.	64.998	
NOV	22.53262	2 15	75.F	61.F	315.734	-52.045	15 6	28.F	26.F	-271.512	23231.	64.998	
DEC	5.56734	10 15	41.F	35.F	146.075	-90.844	9 6	14.F	13.F	-298.005	23753.	64.998	
TOTAL	880.483					-434.409					286650.		
MAX					500.535					-384.918		64.998	
sfn0	-- IMO, IDAY, IHR= 7. 7. 1. TC=				0.00 TH=	0.00 TR=	0.00						
sfn1	-- IMO, IDAY, IHR= 7. 7. 1. TC=				0.00 TH=	0.00 TR=	0.00						
sfn0	-- IMO, IDAY, IHR= 7. 7. 2. TC=				0.00 TH=	0.00 TR=	0.00						
sfn1	-- IMO, IDAY, IHR= 7. 7. 2. TC=				0.00 TH=	0.00 TR=	0.00						
sfn0	-- IMO, IDAY, IHR= 7. 7. 3. TC=				0.00 TH=	0.00 TR=	0.00						
sfn1	-- IMO, IDAY, IHR= 7. 7. 3. TC=				0.00 TH=	0.00 TR=	0.00						
sfn0	-- IMO, IDAY, IHR= 7. 7. 4. TC=				0.00 TH=	0.00 TR=	0.00						
sfn1	-- IMO, IDAY, IHR= 7. 7. 4. TC=				0.00 TH=	0.00 TR=	0.00						
sfn0	-- IMO, IDAY, IHR= 7. 7. 5. TC=				0.00 TH=	0.00 TR=	0.00						
sfn1	-- IMO, IDAY, IHR= 7. 7. 5. TC=				0.00 TH=	0.00 TR=	0.00						
sfn0	-- IMO, IDAY, IHR= 7. 7. 6. TC=				0.00 TH=	0.00 TR=	0.00						
sfn1	-- IMO, IDAY, IHR= 7. 7. 6. TC=				0.00 TH=	0.00 TR=	0.00						
sfn0	-- IMO, IDAY, IHR= 7. 7. 7. TC=				0.00 TH=	0.00 TR=	0.00						
dktempF	-- IMO, IDAY, IHR= 7. 7. 7. TC=				57.18 TH=	57.18 TRLAST=	0.00						

sfn1 -- IMO, IDAY, IHR= 7. 7. 7. TC= 54.66 TH= 57.18 TR= 78.65
dktempF-- IMO, IDAY, IHR= 7. 7. 7. TC= 62.00 TH= 62.00 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7. 8. TC= 0.00 TH= 0.00 TR= 0.00
sfn1 -- IMO, IDAY, IHR= 7. 7. 8. TC= 0.00 TH= 0.00 TR= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7. 9. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7. 9. TC= 57.90 TH= 57.90 TRLAST= 0.00
sfn1 -- IMO, IDAY, IHR= 7. 7. 9. TC= 55.37 TH= 57.90 TR= 78.60
dktempF-- IMO, IDAY, IHR= 7. 7. 9. TC= 62.00 TH= 62.00 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.10. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.10. TC= 57.22 TH= 57.22 TRLAST= 78.60
new TC= 52.79
sfn1 -- IMO, IDAY, IHR= 7. 7.10. TC= 50.26 TH= 57.22 TR= 74.63
dktempF-- IMO, IDAY, IHR= 7. 7.10. TC= 60.73 TH= 60.73 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.11. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.11. TC= 57.78 TH= 57.78 TRLAST= 74.63
new TC= 60.74
sfn1 -- IMO, IDAY, IHR= 7. 7.11. TC= 58.22 TH= 57.78 TR= 75.58
dktempF-- IMO, IDAY, IHR= 7. 7.11. TC= 60.83 TH= 60.83 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.12. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.12. TC= 56.94 TH= 56.94 TRLAST= 75.58
new TC= 58.84
sfn1 -- IMO, IDAY, IHR= 7. 7.12. TC= 56.30 TH= 56.94 TR= 76.69
dktempF-- IMO, IDAY, IHR= 7. 7.12. TC= 60.73 TH= 60.73 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.13. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.13. TC= 56.64 TH= 56.64 TRLAST= 76.69
new TC= 56.61
sfn1 -- IMO, IDAY, IHR= 7. 7.13. TC= 54.07 TH= 56.64 TR= 76.19
dktempF-- IMO, IDAY, IHR= 7. 7.13. TC= 60.68 TH= 60.68 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.14. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.14. TC= 56.95 TH= 56.95 TRLAST= 76.19
new TC= 57.61
sfn1 -- IMO, IDAY, IHR= 7. 7.14. TC= 55.06 TH= 56.95 TR= 76.33
dktempF-- IMO, IDAY, IHR= 7. 7.14. TC= 60.66 TH= 60.66 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.15. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.15. TC= 56.80 TH= 56.80 TRLAST= 76.33
new TC= 57.34
sfn1 -- IMO, IDAY, IHR= 7. 7.15. TC= 54.78 TH= 56.80 TR= 76.60
dktempF-- IMO, IDAY, IHR= 7. 7.15. TC= 60.71 TH= 60.71 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.16. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.16. TC= 56.83 TH= 56.83 TRLAST= 76.60
new TC= 56.80
sfn1 -- IMO, IDAY, IHR= 7. 7.16. TC= 54.24 TH= 56.83 TR= 76.19
dktempF-- IMO, IDAY, IHR= 7. 7.16. TC= 60.73 TH= 60.73 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.17. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.17. TC= 56.97 TH= 56.97 TRLAST= 76.19
new TC= 57.63
sfn1 -- IMO, IDAY, IHR= 7. 7.17. TC= 55.08 TH= 56.97 TR= 76.04
dktempF-- IMO, IDAY, IHR= 7. 7.17. TC= 60.63 TH= 60.63 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.18. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.18. TC= 56.81 TH= 56.81 TRLAST= 76.04
new TC= 57.92
sfn1 -- IMO, IDAY, IHR= 7. 7.18. TC= 55.37 TH= 56.81 TR= 76.09
dktempF-- IMO, IDAY, IHR= 7. 7.18. TC= 60.65 TH= 60.65 TRLAST= 0.00

```

sfn0 -- IMO, IDAY, IHR= 7. 7.19. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.19. TC= 56.77 TH= 56.77 TRLAST= 76.09
          new TC= 57.82
sfn1 -- IMO, IDAY, IHR= 7. 7.19. TC= 55.27 TH= 56.77 TR= 75.68
dktempF-- IMO, IDAY, IHR= 7. 7.19. TC= 60.60 TH= 60.60 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.20. TC= 0.00 TH= 0.00 TR= 0.00
dktempF-- IMO, IDAY, IHR= 7. 7.20. TC= 56.71 TH= 56.71 TRLAST= 75.68
          new TC= 58.63
sfn1 -- IMO, IDAY, IHR= 7. 7.20. TC= 56.09 TH= 56.71 TR= 75.40
dktempF-- IMO, IDAY, IHR= 7. 7.20. TC= 60.39 TH= 60.39 TRLAST= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.21. TC= 0.00 TH= 0.00 TR= 0.00
sfn1 -- IMO, IDAY, IHR= 7. 7.21. TC= 0.00 TH= 0.00 TR= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.22. TC= 0.00 TH= 0.00 TR= 0.00
sfn1 -- IMO, IDAY, IHR= 7. 7.22. TC= 0.00 TH= 0.00 TR= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.23. TC= 0.00 TH= 0.00 TR= 0.00
sfn1 -- IMO, IDAY, IHR= 7. 7.23. TC= 0.00 TH= 0.00 TR= 0.00

sfn0 -- IMO, IDAY, IHR= 7. 7.24. TC= 0.00 TH= 0.00 TR= 0.00
sfn1 -- IMO, IDAY, IHR= 7. 7.24. TC= 0.00 TH= 0.00 TR= 0.00

```

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
FS-SYS	RHFS	1.020	4800.0	12.									
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	
	5446.	4.178	2.4	0.	0.000	0.0	0.249	206.240	0.687	0.000	0.00	0.37	
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	AT21	2903.	0.	0.000	1.000	678.	0.00	0.00	59.57	-156.76	-87.78	1.0	
	AT22	2543.	0.	0.000	1.000	678.	0.00	0.00	52.19	-137.35	-76.91	1.0	
	EQUIP-RM	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE							
OFF-SYS	VAVS	1.020	23320.0	180.							
SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
30014.	31.397	3.3	0.	0.000	0.0	0.092	808.055	0.837	-941.658	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
BZ1	5163.	0.	0.000	0.300	306.	0.00	0.00	78.06	-306.65	-256.47	1.0
BZ2	1763.	0.	0.000	0.300	153.	0.00	0.00	26.66	-104.74	-87.60	1.0
BZ3	4903.	0.	0.000	0.300	306.	0.00	0.00	74.14	-291.26	-243.60	1.0
TZ1	5735.	0.	0.000	0.300	306.	0.00	0.00	86.71	-340.65	-284.91	1.0
TZ2	1949.	0.	0.000	0.300	153.	0.00	0.00	29.46	-115.75	-96.81	1.0
TZ3	5147.	0.	0.000	0.300	306.	0.00	0.00	77.82	-305.73	-255.70	1.0
IZ1	2677.	0.	0.000	0.300	612.	0.00	0.00	40.48	-159.03	-133.01	1.0
IZ2	2677.	0.	0.000	0.300	612.	0.00	0.00	40.48	-159.03	-133.01	1.0

MONTH	COOLING						HEATING						ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	6.47297	18 8	34.F	34.F	135.727	-158.150	2 8	4.F	3.F	-1010.874	27112.	73.337		
FEB	5.88716	8 8	7.F	6.F	154.133	-128.487	8 8	7.F	6.F	-955.868	24498.	73.207		
MAR	7.28078	3 15	76.F	65.F	247.892	-88.475	24 8	6.F	5.F	-808.530	27395.	72.836		
APR	27.41310	27 17	84.F	61.F	451.022	-24.973	8 8	31.F	28.F	-581.795	26815.	75.146		
MAY	35.59666	21 13	87.F	76.F	694.810	-5.386	10 8	42.F	40.F	-307.682	27141.	83.354		
JUN	125.21108	21 16	82.F	72.F	827.989	-0.044	23 21	56.F	48.F	-17.801	29037.	96.402		
JUL	216.83882	19 12	88.F	74.F	917.409	0.000				0.000	32227.	98.037		
AUG	179.60645	16 11	79.F	72.F	893.769	0.000				0.000	31000.	98.293		
SEP	59.81257	11 16	86.F	72.F	687.119	-2.724	23 8	36.F	34.F	-168.696	26608.	85.501		
OCT	18.27893	30 15	76.F	67.F	321.031	-19.526	21 8	30.F	29.F	-457.006	26484.	73.532		
NOV	10.53428	1 16	72.F	59.F	364.475	-78.558	26 8	25.F	22.F	-771.863	25760.	76.410		
DEC	5.15307	6 8	36.F	33.F	134.400	-131.351	25 8	20.F	19.F	-858.312	26483.	72.996		
TOTAL	698.087					-637.675					330556.			
MAX					917.409					-1010.874		98.293		

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 0.000 (KBTU)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 11798.153 (KBTU)

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-38.399	4 8	2.F	2.F	-268.052	7735.	16.706
FEB	0.00000				0.000	-29.289	8 8	7.F	6.F	-243.957	6991.	16.706
MAR	1.09500	3 15	76.F	65.F	92.816	-20.745	24 8	6.F	5.F	-214.600	7760.	16.706
APR	7.60837	28 10	67.F	62.F	135.049	-7.760	8 8	31.F	28.F	-163.310	7433.	16.706
MAY	9.05042	21 13	87.F	76.F	176.434	-2.021	10 8	42.F	40.F	-133.122	7401.	16.706
JUN	28.67369	21 18	83.F	73.F	179.473	0.000				0.000	7475.	16.706
JUL	49.28604	19 9	79.F	72.F	241.875	0.000				0.000	7594.	16.706
AUG	42.89882	9 8	67.F	66.F	207.568	0.000				0.000	7613.	16.706
SEP	15.29998	11 16	86.F	72.F	168.241	0.000				0.000	7286.	16.706
OCT	5.03324	30 10	63.F	62.F	120.714	-3.025	21 8	30.F	29.F	-152.072	7409.	16.706
NOV	2.03662	2 13	74.F	61.F	114.174	-17.735	26 8	25.F	22.F	-190.184	7251.	16.706
DEC	0.00000				0.000	-30.388	25 8	20.F	19.F	-217.818	7599.	16.706
TOTAL	160.982					-149.362					89541.	
MAX					241.875					-268.052		16.706

- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK				
JUL 19				JAN 4			JUL 19				
HOURLY	SENSIBLE	DRY-	WET-	HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-	
COOLING	HEAT	BULB	BULB	HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB	
LOAD	RATIO	TEMP	TEMP	LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP	
(KBTU)				(KBTU)			(KBTU)				
1	0.000	0.000	79.F	72.F	-165.847	6.F	6.F	0.000	0.000	79.F	72.F
2	0.000	0.000	79.F	72.F	0.000	5.F	5.F	0.000	0.000	79.F	72.F
3	0.000	0.000	78.F	72.F	-168.792	4.F	4.F	0.000	0.000	78.F	72.F
4	0.000	0.000	78.F	72.F	0.000	4.F	4.F	0.000	0.000	78.F	72.F
5	0.000	0.000	77.F	72.F	-171.086	3.F	3.F	0.000	0.000	77.F	72.F
6	0.000	0.000	78.F	72.F	0.000	3.F	3.F	0.000	0.000	78.F	72.F
7	185.909	0.782	77.F	72.F	-169.125	2.F	2.F	185.909	0.782	77.F	72.F
8	241.875	0.837	79.F	72.F	-268.052	2.F	2.F	241.875	0.837	79.F	72.F
9	150.501	0.791	82.F	72.F	0.000	4.F	3.F	150.501	0.791	82.F	72.F
10	171.847	0.780	85.F	73.F	-189.989	7.F	6.F	171.847	0.780	85.F	73.F
11	204.175	0.803	88.F	74.F	-115.248	11.F	9.F	204.175	0.803	88.F	74.F
12	193.439	0.806	89.F	74.F	-86.085	16.F	13.F	193.439	0.806	89.F	74.F
13	198.534	0.788	90.F	75.F	-58.999	18.F	15.F	198.534	0.788	90.F	75.F
14	201.486	0.784	89.F	75.F	-49.158	20.F	16.F	201.486	0.784	89.F	75.F
15	198.887	0.788	90.F	75.F	-42.409	20.F	16.F	198.887	0.788	90.F	75.F
16	202.992	0.775	91.F	76.F	-49.308	20.F	16.F	202.992	0.775	91.F	76.F
17	195.315	0.787	90.F	75.F	-71.201	19.F	15.F	195.315	0.787	90.F	75.F
18	186.240	0.775	86.F	74.F	-81.570	16.F	13.F	186.240	0.775	86.F	74.F
19	182.536	0.773	86.F	74.F	-94.455	13.F	11.F	182.536	0.773	86.F	74.F
20	166.842	0.763	80.F	72.F	-100.243	11.F	9.F	166.842	0.763	80.F	72.F
21	0.000	0.000	79.F	72.F	-106.730	10.F	8.F	0.000	0.000	79.F	72.F
22	0.000	0.000	77.F	71.F	0.000	11.F	9.F	0.000	0.000	77.F	71.F
23	0.000	0.000	76.F	71.F	0.000	7.F	6.F	0.000	0.000	76.F	71.F
24	0.000	0.000	74.F	70.F	0.000	6.F	5.F	0.000	0.000	74.F	70.F
SUM											
MAX	241.875				-268.052			2680.579			

SYSTEM-TYPE	RHFS	SQFT/TON	238.1
COOLING PEAK	50.39 (BTU/HR- SQFT)	HEATING PEAK	-55.84 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.13 (CFM/SQFT)	MIN-OA/PERSON	113.05 (CFM)
OA FRAC AT CLG PEAK	0.249	OA FRAC AT HTC PEAK	0.249

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	COOLING						HEATING						ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	6.47297	18	8	34.F	34.F	135.727	-119.751	2	8	4.F	3.F	-744.864	19377.	57.071
FEB	5.88716	8	8	7.F	6.F	154.133	-99.198	8	8	7.F	6.F	-711.911	17507.	56.501
MAR	6.18578	3	16	79.F	62.F	156.691	-67.731	24	8	6.F	5.F	-593.929	19635.	56.130
APR	19.80473	27	17	84.F	61.F	336.526	-17.213	8	8	31.F	28.F	-418.485	19382.	58.440
MAY	26.54624	21	13	87.F	76.F	518.376	-3.365	10	8	42.F	40.F	-174.560	19740.	66.648
JUN	96.53735	21	16	82.F	72.F	648.717	-0.044	23	21	56.F	48.F	-17.801	21562.	79.696
JUL	167.55283	19	12	88.F	74.F	713.234	0.000					0.000	24633.	81.331
AUG	136.70761	16	11	79.F	72.F	688.198	0.000					0.000	23387.	81.587
SEP	44.51254	11	16	86.F	72.F	518.878	-2.724	23	8	36.F	34.F	-168.696	19323.	68.795
OCT	13.24568	5	16	74.F	62.F	211.073	-16.501	20	8	42.F	36.F	-307.042	19075.	56.825
NOV	8.49765	1	16	72.F	59.F	257.496	-60.823	15	8	27.F	26.F	-588.034	18509.	59.704
DEC	5.15307	6	8	36.F	33.F	134.400	-100.963	25	8	20.F	19.F	-640.494	18884.	56.328
TOTAL	537.104						-488.313						241016.	
MAX						713.234						-744.864		81.587

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	JUL 19				JAN 2			JUL 19			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	79.F	72.F	0.000	1.F	0.F	0.000	0.000	79.F	72.F
2	0.000	0.000	79.F	72.F	-385.911	1.F	0.F	0.000	0.000	79.F	72.F
3	0.000	0.000	78.F	72.F	0.000	1.F	0.F	0.000	0.000	78.F	72.F
4	0.000	0.000	78.F	72.F	-393.807	2.F	1.F	0.000	0.000	78.F	72.F
5	0.000	0.000	77.F	72.F	0.000	2.F	1.F	0.000	0.000	77.F	72.F
6	0.000	0.000	78.F	72.F	-400.085	2.F	1.F	0.000	0.000	78.F	72.F
7	627.730 *	0.975	77.F	72.F	0.000	3.F	2.F	627.730 *	0.975	77.F	72.F
8	593.586 *	0.967	79.F	72.F	-744.864	4.F	3.F	593.586 *	0.967	79.F	72.F
9	694.163 *	0.861	82.F	72.F	0.000	4.F	3.F	694.163 *	0.861	82.F	72.F
10	704.871 *	0.863	85.F	73.F	-687.756	5.F	4.F	704.871 *	0.863	85.F	73.F
11	713.234 *	0.858	88.F	74.F	-603.659	6.F	5.F	713.234 *	0.858	88.F	74.F
12	681.856 *	0.872	89.F	74.F	-517.248	8.F	7.F	681.856 *	0.872	89.F	74.F
13	655.162 *	0.868	90.F	75.F	-480.878	9.F	9.F	655.162 *	0.868	90.F	75.F
14	691.558 *	0.850	89.F	75.F	-468.658	11.F	11.F	691.558 *	0.850	89.F	75.F
15	697.374 *	0.856	90.F	75.F	-432.760	12.F	12.F	697.374 *	0.856	90.F	75.F
16	681.689 *	0.849	91.F	76.F	-409.055	14.F	13.F	681.689 *	0.849	91.F	76.F
17	679.383	0.855	90.F	75.F	-380.839	15.F	14.F	679.383	0.855	90.F	75.F
18	610.759	0.856	86.F	74.F	-363.214	15.F	15.F	610.759	0.856	86.F	74.F
19	577.011	0.849	86.F	74.F	-371.009	17.F	16.F	577.011	0.849	86.F	74.F
20	509.164	0.840	80.F	72.F	-365.707	17.F	16.F	509.164	0.840	80.F	72.F
21	0.000	0.000	79.F	72.F	-346.082	18.F	18.F	0.000	0.000	79.F	72.F
22	0.000	0.000	77.F	71.F	0.000	17.F	17.F	0.000	0.000	77.F	71.F
23	0.000	0.000	76.F	71.F	0.000	17.F	17.F	0.000	0.000	76.F	71.F
24	0.000	0.000	74.F	70.F	0.000	17.F	17.F	0.000	0.000	74.F	70.F
SUM								9117.540			
MAX	713.234				-744.864						

SYSTEM-TYPE	VAVS	SQFT/TON	392.4
COOLING PEAK	30.58 (BTU/HR- SQFT)	HEATING PEAK	-31.94 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.29 (CFM/SQFT)	MIN-OA/PERSON	15.30 (CFM)
OA FRAC AT CLG PEAK	0.096	OA FRAC AT HTG PEAK	0.000

* ASTERISKS INDICATE HOURS LOADS NOT MET

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
DHW-HEATER	0.069	1 1								
ABSORG-CHLR	0.936	1 1								
COOLING-TWR	1.892	1 1								

MONTH	S I T E E N E R G Y												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	178.4	8.0	28.4	0.0	0.0	14.2	1.6	204.0	0.5	0.0	218.3	317.9	517.1
FEB	147.2	7.2	25.6	0.0	0.0	12.6	1.4	169.0	0.4	0.0	181.6	271.3	450.7
MAR	109.0	8.5	28.5	0.0	0.0	13.0	1.3	127.1	0.4	0.0	140.1	239.5	438.2
APR	43.1	30.7	28.8	0.0	0.0	38.4	2.1	53.5	0.3	0.0	91.9	191.7	391.2
MAY	21.5	39.5	29.4	0.0	0.0	48.4	2.4	29.2	0.1	0.0	77.6	178.7	381.1
JUN	14.2	131.6	32.8	0.0	0.0	133.9	3.8	20.7	0.0	0.0	154.6	266.6	490.8
JUL	13.3	223.6	36.7	0.0	0.0	212.4	4.5	19.6	0.0	0.0	232.0	357.4	608.2
AUG	12.9	186.1	35.1	0.0	0.0	178.6	4.1	19.1	0.0	0.0	197.7	317.6	557.5
SEP	16.0	64.7	29.4	0.0	0.0	72.8	2.8	22.4	0.1	0.0	95.3	196.0	397.5
OCT	35.3	21.3	28.4	0.0	0.0	29.9	2.0	44.3	0.3	0.0	74.2	172.4	368.8
NOV	95.4	12.1	27.0	0.0	0.0	16.7	1.4	111.1	0.4	0.0	127.8	221.7	409.7
DEC	150.4	6.3	27.5	0.0	0.0	11.0	1.3	172.7	0.4	0.0	183.7	279.9	472.5
TOTAL	836.7	739.7	357.8	0.0	0.0	781.9	28.7	992.8	2.9	0.0	1774.8	3010.8	5483.2

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
DHW-HEATER	181.1	21.6
ABSORG-CHLR	655.6	78.4
	*****	*****
LOAD SATISFIED	836.7	100.0
TOTAL LOAD ON PLANT	836.7	
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
ABSORG-CHLR	739.7	100.0
	*****	*****
LOAD SATISFIED	739.7	100.0
TOTAL LOAD ON PLANT	739.7	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	362157.2	101.2
	*****	*****
LOAD SATISFIED	362157.1	101.2
TOTAL LOAD ON PLANT	357782.6	

TOWER ABOVE DESIGN TEMPERATURE OF 85.F 0 HOURS

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	836.7	836.7	2.392	0.277	27
COOLING LOADS	739.7	739.7	0.000	0.000	0
ELECTRICAL LOADS	1221.1	1236.0	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		

AREA LIGHTS	522.7	0.0
MISC EQUIPMT	455.6	0.0
SPACE HEAT	0.0	728.4
SPACE COOL	28.7	781.9
HEAT REJECT	46.0	0.0
PUMPS & MISC	33.1	0.0
VENT FANS	149.9	0.0
DOMHOT WATER	0.0	264.4
	-----	-----
TOTAL	1236.0	1774.8

TOTAL SITE ENERGY	3010.77 MBTU	111.8 KBTU/SQFT-YR GROSS-AREA	111.8 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	5483.16 MBTU	203.7 KBTU/SQFT-YR GROSS-AREA	203.7 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 1.1
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.3

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	362157. KWH	21389.	0.0591	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	17748. THERM	10649.	0.6000	YES

				32038.		
ENERGY COST/GROSS BLDG AREA:				1.19		
ENERGY COST/NET BLDG AREA:				1.19		

UTILITY-RATE: ELEC-COST RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0 WIN-OFF-P
 MAX-ENERGY: 0.0 WIN-ON-P
 MIN-DEMAND: 0.0 SUM-OFF-P
 MAX-DEMAND: 0.0 SUM-ON-P
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	29186	29186	76.4	76.4	1498	0	0	0	0	200	0	0.0582	1698
FEB	26281	26281	76.3	76.3	1334	0	0	0	0	200	0	0.0584	1534
MAR	29116	29116	85.3	85.3	1496	0	0	0	0	200	0	0.0582	1696
APR	29222	29222	85.8	85.8	1503	0	0	0	0	200	0	0.0583	1703
MAY	29637	29637	96.1	96.1	1519	0	0	0	0	200	0	0.0580	1719
JUN	32831	32831	108.7	108.7	1785	0	0	0	0	200	0	0.0604	1985
JUL	36735	36735	112.2	112.2	2016	0	0	0	0	200	0	0.0603	2216
AUG	35129	35129	112.1	112.1	1921	0	0	0	0	200	0	0.0604	2121
SEP	29520	29520	97.1	97.1	1588	0	0	0	0	200	0	0.0606	1788
OCT	28768	28768	84.8	84.8	1482	0	0	0	0	200	0	0.0585	1682
NOV	27530	27530	86.8	86.8	1406	0	0	0	0	200	0	0.0583	1606
DEC	28201	28201	76.0	76.0	1443	0	0	0	0	200	0	0.0583	1643
TOTAL	362157	362157	112.2		18989	0	0	0	0	2400		0.0591	21389

UTILITY-RATE: ELEC-COST
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR
WIN-OFF-P	USE: TIME-OF-USE												
METERED ENERGY:	20636	18535	20233	20020	9864	0	0	0	0	7241	19174	19843	
BILLING ENERGY:	20636	18535	20233	20020	9864	0	0	0	0	7241	19174	19843	135546
KWH/KW DEMAND:	76.4	76.3	85.3	85.8	86.8	0.0	0.0	0.0	0.0	84.8	86.8	76.0	
ENERGY CHGS (\$):	572	499	558	551	247	0	0	0	0	181	521	544	3673
WIN-ON-P	USE: TIME-OF-USE												
METERED ENERGY:	8549	7746	8883	9202	4577	0	0	0	0	3422	8356	8359	
BILLING ENERGY:	8549	7746	8883	9202	4577	0	0	0	0	3422	8356	8359	59095
KWH/KW DEMAND:	72.0	71.9	80.5	83.7	82.2	0.0	0.0	0.0	0.0	81.7	83.7	71.9	
ENERGY CHGS (\$):	342	310	355	368	183	0	0	0	0	137	334	334	2364
SUN-OFF-P	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	9368	19945	22203	21279	18086	11313	0	0	
BILLING ENERGY:	0	0	0	0	9368	19945	22203	21279	18086	11313	0	0	102194
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	96.1	108.7	112.2	112.1	97.1	84.7	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	234	548	627	595	483	283	0	0	2770
SUN-ON-P	USE: TIME-OF-USE												
METERED ENERGY:	0	0	0	0	5829	12886	14532	13850	11433	6792	0	0	
BILLING ENERGY:	0	0	0	0	5829	12886	14532	13850	11433	6792	0	0	65322
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	94.1	105.2	107.5	107.5	95.4	80.7	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	262	580	654	623	514	306	0	0	2940

TOTAL ENERGY:	29186	26281	29116	29222	29637	32831	36735	35129	29520	28768	27530	28201	362157
TOTAL CHARGES (\$):	914	809	913	919	926	1128	1281	1218	998	906	855	879	11746

UTILITY-RATE: GAS-COST RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	2183	2183	10.8	10.8	1310	0	0	0	0	0	0	0.6000	1310
FEB	1816	1816	10.5	10.5	1090	0	0	0	0	0	0	0.6000	1090
MAR	1401	1401	10.2	10.2	841	0	0	0	0	0	0	0.6000	841
APR	919	919	8.7	8.7	552	0	0	0	0	0	0	0.6000	552
MAY	776	776	7.5	7.5	466	0	0	0	0	0	0	0.6000	466
JUN	1546	1546	8.5	8.5	928	0	0	0	0	0	0	0.6000	928
JUL	2320	2320	9.5	9.5	1392	0	0	0	0	0	0	0.6000	1392
AUG	1977	1977	9.0	9.0	1186	0	0	0	0	0	0	0.6000	1186
SEP	953	953	7.1	7.1	572	0	0	0	0	0	0	0.6000	572
OCT	742	742	7.3	7.3	445	0	0	0	0	0	0	0.6000	445
NOV	1278	1278	10.5	10.5	767	0	0	0	0	0	0	0.6000	767
DEC	1837	1837	10.5	10.5	1102	0	0	0	0	0	0	0.6000	1102
TOTAL	17748	17748	10.8		10649	0	0	0	0	0		0.6000	10649

Office Building and Atrium Deli/Restaurant

LDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993LDL RUN 3

```

* 988 * TITLE LINE-1 * OFFICE BUILDING & DELI/RESTAURANT*
* 989 * LINE-2 * ELECTROCHROMIC GLAZING IN ATRIUM *
* 990 * LINE-3 * VAV SYSTEM IN OFFICE & PSZ IN ATRIUM *
* 991 * LINE-4 * GAS ENGINE DRIVEN CHILLER & HEAT RECY*
* 992 * LINE-5 * SAMP3.INP RUN 3 * ..
* 993 *
* 994 *          ABORT          ERRORS ..
* 995 *          DIAGNOSTIC      WARNINGS ..
* 996 *          RUN-PERIOD      JAN 1 1988 THRU DEC 31 1988 ..
* 997 *          BUILDING-LOCATION LATITUDE=42 LONGITUDE=88
* 998 *                               TIME-ZONE=6 ALTITUDE=610 ..
* 999 *
*1000 *          LOADS-REPORT     SUMMARY=(LS-D) ..
*1001 *
*1002 *          $ BUILDING DESCRIPTION
*1003 *
*1004 * $          THE MEDICAL OFFICE BUILDING ABOVE HAS BEEN REMODELED WITH
*1005 * $          DIFFERENT USAGES TO DEMONSTRATE NEW FEATURES OF DOE-2.1D and E.
*1006 *
*1007 * $ STRUCTURE REINFORCED CONCRETE CONSTRUCTION WITH 4IN CONCRETE FLOORS AND ROOF
*1008 * $          10FT FLOOR TO FLOOR HEIGHT, TWO STORIES HIGH. RETURN AIR PLENUMS
*1009 * $          ARE NOT DEFINED.
*1010 *
*1011 * $ WALLS          USING CODE WORDS FROM THE DOE-2 LIBRARY (REFERENCE MANUAL PART 2)
*1012 * $          AND STARTING WITH THE OUTSIDE SURFACE AND MOVING INWARD:
*1013 * $          2IN PRECAST CONCRETE PANEL (CC03); 2IN POLYSTYRENE INSULATION
*1014 * $          R-8 (IN35); 3IN AIRSPACE (AL21); 5/8IN GYPSUM BOARD (GP04);
*1015 * $          3/4IN FINISH PLASTER.
*1016 *
*1017 * $ ATRIUM ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
*1018 * $          6IN CONCRETE (CC04); INSIDE FILM RESISTANCE .76
*1019 *
*1020 * $ OFFICE ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
*1021 * $          2 FT AIR SPACE (AL33); 3/4IN LAY-IN ACOUSTIC TILE (AC03);
*1022 * $          INSIDE-FILM-RESISTANCE .76.
*1023 *
*1024 * $ FLOORS        FIRST FL IS SLAB-ON-GRADE EFFECTIVE U-VALUE OF ENTIRE AREA .05.
*1025 *
*1026 * $ WINDOWS      OFFICE AREA 4FT HIGH AND FULL WIDTH OF EACH WALL, EXCEPT SOUTH
*1027 * $          WALL WHERE THERE ARE NO WINDOWS. EXCEPT FOR ATRIUM, GLASS IS
*1028 * $          DOUBLE-PANE TINTED WITH A SOLAR TRANSMITTANCE OF 0.53.
*1029 *
*1030 * $          ATRIUM GLAZING IS ELECTROCHROMIC, SWITCHING FROM CLEAR TO
*1031 * $          COLORED (TO REDUCE SOLAR GAIN) WHEN ATRIUM HAS A COOLING LOAD
*1032 * $          (AS DETERMINED BY THE LOADS PROGRAM) THE PREVIOUS HOUR.
*1033 * $          THERE ARE TWO MAIN SECTIONS OF GLASS 29' WIDE BY
*1034 * $          30' HIGH WITH NO OVERHANGS OR SIDE PINS.
*1035 *
*1036 * $ INTERIORS     CEILINGS ARE SIMULATED AS PART OF THE ROOF STRUCTURE ON THE TOP
*1037 * $          FLOOR. PARTITIONS SIMULATE A GLASS WALL BETWEEN ATRIUM AND
*1038 * $          OFFICE SPACES, BUT WALLS BETWEEN INTERIOR AND EXTERIOR OFFICES
*1039 * $          ARE NOT DEFINED. WALLS BETWEEN THE EQUIPMENT ROOM AND OFFICES
*1040 * $          HAVE A U-VALUE OF .28.
*1041 *
*1042 * $ SPACE LOADS  LIGHTING IS RECESSED FLUORSCENT NON VENTED AT 1.5 WATTS/SQFT
*1043 * $          IN THE OFFICES AND 2.2 WATT/SQFT IN THE ATRIUM.
*1044 * $          PEOPLE IN OFFICES IS INPUT AT 150SQFT/PERSON.

```



```

*1045 * $          PEOPLE IN ATRIUM ARE ZERO.
*1046 * $          INFILTRATION IS SET AT .2 AIRCHANGES/HR WHEN FANS ARE OFF AND AT
*1047 * $          .1 AIRCHANGE WHEN FANS ARE ON.
*1048 * $          EQUIPMENT IN OFFICES IS SET AT 1 WATTS/SQFT AND 1.5 WATTS/SQFT
*1049 * $          IN THE ATRIUM.
*1050 "
*1051 "          $ CONSTRUCTIONS
*1052 "
*1053 * ROOF-O      =LAYERS          MAT=(BR01,IN76,CC03,AL33,AC03) I-F-R=.76 ..
*1054 * ROOF-A      =LAYERS          MAT=(BR01,IN76,CC04) I-F-R .76 ..
*1055 * OFF-ROF     =CONSTRUCTION   LAYERS ROOF-O ..
*1056 * ATR-ROF     =CONSTRUCTION   LAYERS ROOF-A ..
*1057 * WALL-1      =LAYERS          MAT=(CC33,IN35,AL21,GP04,GP04) ..
*1058 * WL1         =CONSTRUCTION   LAYERS=WALL-1 ..
*1059 * BW1         =CONSTRUCTION   U=.05 ..
*1060 * BW2         =CONSTRUCTION   U=.0001 ..
*1061 * WL2         =CONSTRUCTION   U=1.05 $ ATRIUM GLASS PARTITIONS $ ..
*1062 * WL3         =CONSTRUCTION   U=.28 $ INTERIOR PARTITIONS $ ..
*1063 "
*1064 "          $ GLASS DESCRIPTION
*1065 "
*1066 * GT1         =GLASS-TYPE   GLASS-TYPE-CODE=5 PANES=2 ..
*1067 "
*1068 "          $ GLASS TYPES FOR SWITCHABLE GLAZING IN ATRIUM WINDOWS
*1069 "
*1070 * ELECTRO-CLEAR =GLASS-TYPE   GLASS-TYPE-CODE=2800 .. $ ELECTROCHROMIC ABSORBIN.

GLAZING SELECTED FROM WINDOW LIBRARY--
TYPE: DOUBLE ELECTROCHROMIC ABSORBING IG BLEACHED AIR 6.3

G-T-C LAYERS U-SI U-IP SC SHCG TSOL TVIS GAP(mm) GAS-FILL
2800      2 2.43 0.43 0.85 0.73 0.63 0.75 6.3 Air

*1071 *          $ BLEACHED STATE
*1072 *          $ SHADING COEF = .85
*1073 *
*1074 * ELECTRO-COLOR =GLASS-TYPE   GLASS-TYPE-CODE=2801 .. $ ELECTROCHROMIC ABSORBING.

GLAZING SELECTED FROM WINDOW LIBRARY--
TYPE: DOUBLE ELECTROCHROMIC ABSORBING IG COLORED AIR 6.3

G-T-C LAYERS U-SI U-IP SC SHCG TSOL TVIS GAP(mm) GAS-FILL
2801      2 2.43 0.43 0.21 0.18 0.09 0.12 6.3 Air

*1075 *          $ COLORED STATE
*1076 *          $ SHADING COEF = .21
*1077 *
*1078 *          $ The following command calls the file containing schedu
*1079 *          $ for offices that is on the sample run input
*1080 *          $ tape. It MUST reside in a directory on your
*1081 *          $ computer system so that this demonstration
*1082 *          $ of a GENERALIZED LIBRARY can function. For users
*1083 *          $ with a large computer system the file name should
*1084 *          $ include the full path name, or as an alternative
*1085 *          $ use the ##fileprefix command.
*1086 # ##include /u3/dae2/21d/dev/SAMPLES/officsch.inc
1 * 1 *
1 * 2 * $ This is a demonstration of how to use the GENERAL LIBRARY FEATURE.
1 * 3 * $ We have created a file of the OFFICE LOADS SCHEDULES from the MEDICAL BLDG
1 * 4 * $ BDL file and named it OFFICSCH.INP We then called these same schedules
1 * 5 * $ using the term - ##include officsch.inp - in these two input files.
1 * 6 *
1 * 7 *          $ OFFICE SCHEDULES
1 * 8 *
1 * 9 * OC1          =DAY-SCHEDULE   (1.9) (0) (10.12) (1) (13.14) (.8..4)

```

```

1 * 10 * (15,18) (.7) (19,21) (.4) (22,24) (.2) ..
1 * 11 * OC2 =DAY-SCHEDULE (1,24) (.2) ..
1 * 12 * OCCUPANCY =WEEK-SCHEDULE (MON,TUE) OC1 (WED) OC2
1 * 13 * (THU,SAT) OC1 (SUN,HOL) OC2 ..
1 * 14 * OCCUP =SCHEDULE THRU DEC 31 OCCUPANCY ..
1 * 15 *
1 * 16 * L1 =DAY-SCHEDULE (1,6) (.2) (7,12) (.9) (13,14) (.8,.4)
1 * 17 * (15,18) (.7) (19,21) (.4) (22,24) (.2) ..
1 * 18 * L2 =DAY-SCHEDULE (1,24) (.2) ..
1 * 19 * LIGHTS =WEEK-SCHEDULE (MON,TUE) L1 (WED) L2
1 * 20 * (THU,SAT) L1 (SUN,HOL) L2 ..
1 * 21 * LT1 =SCHEDULE THRU DEC 31 LIGHTS ..
1 * 22 *
1 * 23 * ES1 =DAY-SCHEDULE (1,9) (0) (10,21) (.9) (22,24) (.4) ..
1 * 24 * ES2 =DAY-SCHEDULE (1,9) (0) (10,24) (.4) ..
1 * 25 * EQUIPMENT =WEEK-SCHEDULE (MON,TUE) ES1 (WED) ES2
1 * 26 * (THU,SAT) ES1 (SUN,HOL) ES2 ..
1 * 27 * EQ1 =SCHEDULE THRU DEC 31 EQUIPMENT ..
1 * 28 *
1 * 29 * I1 =DAY-SCHEDULE (1,9) (1) (10,21) (.5) (22,24) (1) ..
1 * 30 * INFILTRAT =WEEK-SCHEDULE (ALL) I1 ..
1 * 31 * INF1 =SCHEDULE THRU DEC 31 INFILTRAT ..
1 * 32 *

```

file : INPUT2.TMP

```

*1087 *
*1088 *           $ DELI/RESTAURANT SCHEDULES $
*1089 *
*1090 * OC4 = D-SCH (1,7) (0) (8,11) (.1,.2,.5,.5) (12,15) (.7)
*1091 * (16,21) (.8,.7,.5,.5,.3,.3) (22,24) (0) ..
*1092 * OC5 = D-SCH (1,7) (0) (8,11) (.1,.2,.5,.6) (12,17) (.8)
*1093 * (18,22) (.6,.2,.2,.2,.1) (23,24) (0) ..
*1094 * OC6 = D-SCH (1,24) (0) ..
*1095 * OCCUP2 = SCH THRU DEC 31 (WD) OC4 (SAT) OC5 (SUN,HOL) OC6 ..
*1096 *
*1097 * L4 = D-SCH (1,7) (0) (8,9) (.2,.5) (10,18) (.9)
*1098 * (19,24) (.6,.6,.5,.2,0,0) ..
*1099 * L5 = D-SCH (1,7) (0) (8,10) (.1,.3,.6) (11,18) (.9)
*1100 * (19,24) (.5,.3,.3,.1,0,0) ..
*1101 * L6 = D-SCH (1,24) (0) ..
*1102 * LIGHTS2 = SCH THRU DEC 31 (WD) L4 (SAT) L5 (SUN,HOL) L6 ..
*1103 *
*1104 * IF4 = D-SCH (1,6) (1) (7,21) (0) (22,24) (1) ..
*1105 * IF5 = D-SCH (1,6) (1) (7,22) (0) (23,24) (1) ..
*1106 * IF6 = D-SCH (1,24) (1) ..
*1107 * INFIL = SCH THRU DEC 31 (WD) IF4 (SAT) IF5 (SUN,HOL) IF6 ..
*1108 *
*1109 * EQ2 = SCH THRU DEC 31 (ALL) (1,24) (1) .. $ REFRIGERATOR COMPRESSOR HEAT
*1110 *           $ REJECTED TO SPACE
*1111 *
*1112 *           $ SET DEFAULTS
*1113 *
*1114 * SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=10 AZIMUTH=180
*1115 * CONSTRUCTION=WL1 ..
*1116 * SET-DEFAULT FOR WINDOW HEIGHT=4 Y=4 GLASS-TYPE=GT1 ..
*1117 *
*1118 *           $ SPACE DESCRIPTION
*1119 *
*1120 * OFFICE =SPACE-CONDITIONS TEMPERATURE=(74) FLOOR-WEIGHT=70
*1121 * EQUIPMENT-W/SQFT=1 EQUIP-SCHEDULE=EQ1
*1122 * LIGHTING-W/SQFT=1.5 LIGHTING-SCHEDULE=LT1
*1123 * INF-METHOD=AIR-CHANGE AIR-CHANGES/HR=.2
*1124 * LIGHTING-TYPE=SUS-FLUOR
*1125 * PEOPLE-HG-LAT=200 PEOPLE-HG-SENS=250
*1126 * PEOPLE-SCHEDULE=OCCUP ..
*1127 *

```

*1128 *	ATRIUM	=SPACE-CONDITIONS	TEMPERATURE=(74) FLOOR-WEIGHT=100
*1129 *			LIGHTING-SCHEDULE=LIGHTS2
*1130 *			LIGHTING-TYPE=INCAND
*1131 *			LIGHTING-W/SQFT=2.2
*1132 *			EQUIP-SCHEDULE=EQ2
*1133 *			EQUIPMENT-W/SQFT=1.5
*1134 *			NUMBER-OF-PEOPLE=6
*1135 *			PEOPLE-HEAT-GAIN= 550
*1136 *			PEOPLE-SCHEDULE = OCCUP2
*1137 *			INF-SCHEDULE=INFIL AIR-CHANGES/HR=.2
*1138 *			INF-METHOD=AIR-CHANGE ..
*1139 *			.
*1140 *	BZ1	=SPACE	S-C=OFFICE NUMBER-OF-PEOPLE=20
*1141 *			AREA=3230 VOLUME=29070 AZ=90 Y=200 ..
*1142 *			
*1143 *			
*1144 *	E1	=EXTERIOR-WALL	WIDTH=200 ..
*1145 *	W1	=WINDOW	WIDTH=200 ..
*1146 *			
*1147 *	E1S	=EXTERIOR-WALL	W=17 AZ=90 X=200 ..
*1148 *			
*1149 *		UNDERGROUND-FLOOR	AREA=3230 CONS=BW1 ..
*1150 *			
*1151 *	BZ2	=SPACE	S-C=OFFICE AREA=1660 VOLUME=14940
*1152 *			NUMBER-OF-PEOPLE=10 AZ=180 X=100 Y=200 ..
*1153 *			
*1154 *	E2	=EXTERIOR-WALL	WIDTH=100 ..
*1155 *	W2	=WINDOW	WIDTH=100 ..
*1156 *			
*1157 *		UNDERGROUND-FLOOR	AREA=1660 CONS=BW1 ..
*1158 *			
*1159 *	BZ3	=SPACE	LIKE BZ1 AZ=-90 X=100 Y=0 ..
*1160 *			
*1161 *	E3	=EXTERIOR-WALL	LIKE E1 ..
*1162 *	W3	=WINDOW	LIKE W1 ..
*1163 *			
*1164 *	E3S	=EXTERIOR-WALL	W=17 AZ=270 Y=17 ..
*1165 *			
*1166 *		UNDERGROUND-FLOOR	AREA=3230 CONS=BW1 ..
*1167 *			
*1168 *	TZ1	=SPACE	LIKE BZ1 Z=10 ..
*1169 *			
*1170 *	R1	=ROOF	H=17 W=200 AZ=180 TILT=0 Z=10
*1171 *			CONS=OFF-ROF ..
*1172 *			
*1173 *		EXTERIOR-WALL	LIKE E1 ..
*1174 *		WINDOW	LIKE W1 ..
*1175 *			
*1176 *		EXTERIOR-WALL	LIKE E1S ..
*1177 *			
*1178 *	TZ2	=SPACE	LIKE BZ2 Z=10 ..
*1179 *			
*1180 *		ROOF	LIKE R1 H=20 W=83 ..
*1181 *			
*1182 *		EXTERIOR-WALL	LIKE E2 ..
*1183 *		WINDOW	LIKE W2 ..
*1184 *			
*1185 *	TZ3	=SPACE	LIKE BZ3 Z=10 ..
*1186 *		ROOF	LIKE R1 H=17 W=180 ..
*1187 *		EXTERIOR-WALL	LIKE E3 ..
*1188 *		WINDOW	LIKE W3 ..
*1189 *		EXTERIOR-WALL	LIKE E3S ..
*1190 *			
*1191 *	IZ1	=SPACE	S-C=OFFICE AREA=3540 VOLUME=70800
*1192 *			NUMBER-OF-PEOPLE=40 AZ=90 X=17 Y=180 ..

```

*1193 *
*1194 * IN1      =INTERIOR-WALL   AREA=1200 NEXT-TO ATZ1  CONS=WL2  ..
*1195 * IN2      =INTERIOR-WALL   AREA=1200 NEXT-TO ATZ2  CONS=WL2  ..
*1196 * IN3      =INTERIOR-WALL   AREA=800  NEXT-TO EQUIP-RM CONS=WL3  ..
*1197 *          ROOF          LIKE R1  H=18  W=180 Z=20  ..
*1198 *          ROOF          LIKE R1  H=15  W=20  Y=18  Z=20  ..
*1199 *          EXTERIOR-WALL   H=20  W=18  AZ=90  X=180  ..
*1200 *          UNDERGROUND-FLOOR AREA=3540 CONS=BW1  ..
*1201 *
*1202 * IZ2      =SPACE          LIKE IZ1  AZ=-90  X=83  Y=0  ..
*1203 *
*1204 *          INTERIOR-WALL   LIKE IN1  NEXT-TO ATZ1  ..
*1205 *          INTERIOR-WALL   LIKE IN2  NEXT-TO ATZ2  ..
*1206 *          INTERIOR-WALL   LIKE IN3  ..
*1207 *          EXTERIOR-WALL   H=20  W=18  AZ=270  Y=18  ..
*1208 *          ROOF          LIKE R1  H=18  W=180 Z=20  ..
*1209 *          ROOF          LIKE R1  H=15  W=20  X=160  Y=18  Z=20  ..
*1210 *          UNDERGROUND-FLOOR AREA=3540 CONS=BW1  ..
*1211 *
*1212 * ATZ1      =SPACE          S-C=ATRIUM AREA=1800 VOLUME=16200
*1213 *          X=35  Y=40  ..
*1214 *
*1215 * ATROOF-1  =ROOF          HEIGHT=66.6 WIDTH=30
*1216 *          AZIMUTH=0 TILT=26 X=30  Y=60  Z=20
*1217 *          CONS=ATR-ROF  ..
*1218 * E4         =EXTERIOR-WALL   H=14.5 W=60  AZ=270  Y=60  Z=20  ..
*1219 * E5         =EXTERIOR-WALL   LIKE E4  AZ=90  X=30  Y=0  ..
*1220 * F1         =UNDERGROUND-FLOOR AREA=1800 CONS=BW2  ..
*1221 * FRAME-A    =EXTERIOR-WALL   HEIGHT=29 WIDTH=30 Z=20  ..
*1222 * WINDOW-A   =WINDOW          H=28.9 W=29.9 X=.05  Y=.05
*1223 *          GLASS-TYPE    = ELECTRO-CLEAR
*1224 *          GLASS-TYPE-SW = ELECTRO-COLOR
*1225 *          SWITCH-CONTROL = SPACE-LOAD
*1226 *          SWITCH-SET-LO = 0
*1227 *          SWITCH-SET-HI = 0  ..
*1228 *
*1229 *          EXTERIOR-WALL   LIKE FRAME-A HEIGHT=10.7 W=30  Z=9.3  ..
*1230 *          WINDOW        LIKE WINDOW-A H=10.6 W=29.9  ..
*1231 *
*1232 * ATZ2      =SPACE          LIKE ATZ1  Y=100  ..
*1233 *
*1234 * ATROOF-2  =ROOF          LIKE ATROOF-1  ..
*1235 *          EXTERIOR-WALL   LIKE E4  ..
*1236 *          EXTERIOR-WALL   LIKE E5  ..
*1237 *          UNDERGROUND-FLOOR LIKE F1  ..
*1238 * FRAME-B    =EXTERIOR-WALL   LIKE FRAME-A  ..
*1239 * WINDOW-B   =WINDOW          LIKE WINDOW-A  ..
*1240 *
*1241 * EQUIP-RM    =SPACE          ZONE-TYPE=UNCONDITIONED
*1242 *          AREA=1200 VOLUME=17580 X=35  ..
*1243 *
*1244 *          EXTERIOR-WALL   HEIGHT=20 WIDTH=30  ..
*1245 *
*1246 *          ROOF          H=41.2 W=30  CONS=OFF-ROF
*1247 *          TILT=15  Z=9.3 X=30  Y=40  AZIMUTH=0  ..
*1248 *
*1249 *          INTERIOR-WALL   AREA=279  CONS=WL3  NEXT-TO ATZ1  ..
*1250 *          UNDERGROUND-FLOOR AREA=1200 CONS=BW1  ..
*1251 *
*1252 *
*1253 * END  ..
*1254 * COMPUTE LOADS  ..
*1255 * INPUT SYSTEMS  ..

```

S D L P R O C E S S O R I N P U T D A T A

Wed Nov 10 15:17:48 1993SDL RUN 3

```

*1256 * SYSTEMS-REPORT SUMMARY (SS-D,SS-A,SS-J) ..
*1257 *
*1258 *           $ HVAC SYSTEMS DESCRIPTION
*1259 *
*1260 * $ DESIGN TEMPS ATRIUM COOLING 76F-SUMMER, 72F-WINTER HEATING SETBACK 65F
*1261 * $ OFFICE COOLING 76F HEATING 72F
*1262 * $ SYSTEM TYPE THE OFFICE IS SERVED BY A VAVS SYSTEM WITH THE BASEBOARD RESET
*1263 * $ BY THE OUTSIDE AIR TEMPERATURE.
*1264 *
*1265 * $ THE RESTAURANT/DELI IS SERVED BY 2 PKG VARIABLE TEMPERATURE -
*1266 * $ CONSTANT VOLUME SYSTEMS (PSZ). THE UNIT SERVING THE DELI WHICH
*1267 * $ HAS OPEN CASEWORK FOR DISPLAY OF FOOD AND BEVERAGES RECOVERS
*1268 * $ REJECTED HEAT. THIS SIMULATION CAN ALSO BE USED FOR GROCERY
*1269 * $ STORES.
*1270 * $ , BOTH SYSTEMS HAVE DRY BULB ECONOMIZERS WITH A 68F LIMIT ON THE
*1271 * $ VAV SYSTEM AND A 25 BTUH/°DRY AIR ENTHALPY LIMIT AND A 74F
*1272 * $ DRYBULB LIMIT ON THE PKG DX UNITS REPRESENTATIVE OF PKG'D
*1273 * $ CONTROLLERS. THE UNITS ARE ALSO FITTED WITH AN ECONO LOCKOUT
*1274 * $ WHICH PROTECTS THE COMPRESSOR FROM BURNOUT ON LOW EVAPORATOR
*1275 * $ LOADING.
*1276 *
*1277 *           $ AIR HANDLING UNIT SCHEDULES
*1278 *
*1279 * DAYS = WEEK-SCHEDULE (MON,SAT) (1,7)(0)(8,21)(1)(22,24)(0)
*1280 * (SUN,HOL) (1,24)(0) ..
*1281 * AHU-SCHED = SCHEDULE THRU DEC 31 DAYS ..
*1282 * AHU-SCHED2 = SCHEDULE THRU DEC 31 (ALL) (1,24)(1) ..
*1283 *
*1284 *           $ HEATING THERMOSTAT SCHEDULE
*1285 *
*1286 * THEAT1 = SCHEDULE THRU DEC 31 (MON,SAT) (1,7)(65)(8,21)(72)(22,24)(65)
*1287 * (SUN,HOL) (1,24)(65) ..
*1288 *
*1289 *           $ COOLING THERMOSTAT SCHEDULES
*1290 *
*1291 * TCOOL1 = SCHEDULE THRU DEC 31 (MON,SAT) (1,7)(90)(8,21)(76)(22,24)(90)
*1292 * (SUN,HOL) (1,24)(90) ..
*1293 * TCOOL2 = SCHEDULE THRU DEC 31 (ALL) (1,24)(76) ..
*1294 *
*1295 *           $ BASEBOARD RESET SCHEDULE
*1296 *
*1297 * R1 = DAY-RESET-SCH SUPPLY-HI = 1 SUPPLY-LO = 0
*1298 * OUTSIDE-LO = 0 OUTSIDE-HI = 50 ..
*1299 * BASD-RESET = RESET-SCHEDULE THRU DEC 31 (ALL) R1 ..
*1300 *
*1301 *           $ REFRIGERATED CASEWORK SCHEDULES
*1302 *
*1303 * FOOD-S-S = SCHEDULE THRU DEC 31 (MON,SAT) (1,9)(.4) (10,21)(1) (22,24)(.4)
*1304 * (SUN,HOL) (1,24)(.4) ..
*1305 * FOOD-L-S = SCHEDULE THRU DEC 31 (MON,SAT) (1,9)(.7) (10,21)(1) (22,24)(.7)
*1306 * (SUN,HOL) (1,24)(.7) ..
*1307 * FOOD-AUX-S = SCHEDULE THRU DEC 31 (MON,SAT) (1,9)(.2) (10,21)(1) (22,24)(.2)
*1308 * (SUN,HOL) (1,24)(.2) ..
*1309 *
*1310 * MIN-OA = SCHEDULE THRU DEC 31 (ALL) (1,9)(0) (10,21)(-999) (22,24)(0) ..
*1311 *
*1312 *           $ ZONE DESCRIPTION

```

```

*1313 *
*1314 * ENV-ATR      = ZONE-CONTROL D-H-T 70 D-C-T 74 H-T-SCH THEAT1 C-T-SCH TCOOL2
*1315 *              T-TYPE PROPORTIONAL ..
*1316 * ENV-OFF     = ZONE-CONTROL D-H-T 74 D-C-T 74 H-T-SCH THEAT1 C-T-SCH TCOOL1
*1317 *              T-TYPE REVERSE-ACTION ..
*1318 *
*1319 * ATZ1        = ZONE          Z-C ENV-ATR OUTSIDE-AIR-CFM 665
*1320 *              REFG-ZONE-LOAD = (-10000,-5000,-6000)
*1321 *              REFG-ZONE-SHR = (.9,.8,.9)
*1322 *              REFG-DISCHARGE-T = (-10,23,30)
*1323 *              REFG-EVAP-T = (-25,20,25)
*1324 *              REFG-SENS-SCH = (FOOD-S-S,FOOD-S-S,FOOD-S-S)
*1325 *              REFG-LAT-SCH = (FOOD-L-S,FOOD-L-S,FOOD-L-S)
*1326 *              REFG-AUX-SCH = (FOOD-AUX-S,FOOD-AUX-S,FOOD-AUX-S)
*1327 *              REFG-DEF-MECH = (RESISTANCE,FRDON,FRDON)
*1328 *              REFG-DEF-EFF = (.95,.80,.85)
*1329 *              REFG-DEF-CTRL= (THERMOSTATIC,TIMER,TIMER) ..
*1330 *
*1331 * ATZ2        = ZONE          Z-C ENV-ATR OUTSIDE-AIR-CFM 665 ..
*1332 * EQUIP-RM   = ZONE          ZONE-TYPE=UNCONDITIONED ..
*1333 * BZ1        = ZONE          Z-C ENV-OFF OA-CFM/PER=15 B-R=-90000 ..
*1334 * BZ2        = ZONE LIKE BZ1 B-R=-37000 ..
*1335 * BZ3        = ZONE LIKE BZ1 B-R=-100000 ..
*1336 * TZ1        = ZONE LIKE BZ1 B-R=-94000 ..
*1337 * TZ2        = ZONE LIKE BZ1 B-R=-40000 ..
*1338 * TZ3        = ZONE LIKE BZ1 B-R=-104000 ..
*1339 * IZ1        = ZONE LIKE BZ1 B-R=-54000 ..
*1340 * IZ2        = ZONE LIKE BZ1 B-R=-54000 ..
*1341 *
*1342 * FS-SYS1    = SYSTEM        SYSTEM-TYPE=PS2 MAX-S-T=100 MIN-S-T=55
*1343 *              SUPPLY-STATIC=3 SUPPLY-EFF=.45 DRYBULB-LIMIT=74
*1344 *              ENTHALPY-LIMIT=25 ECONO-LOCKOUT=YES
*1345 *              HEAT-SOURCE=HOT-WATER
*1346 *              REFG-SIZING-RAT =1.3
*1347 *              REFG-COMP-GROUP (SEPARATE,COMMON,COMMON)
*1348 *              REFG-MAX-HTREC = 30000
*1349 *              REFG-HTREC-UNITS = (NO,YES)
*1350 *              ZONE-NAMES = (ATZ1) ..
*1351 *
*1352 * FS-SYS2    = SYSTEM        SYSTEM-TYPE=PS2 MAX-S-T=100 MIN-S-T=55
*1353 *              SUPPLY-STATIC=3 SUPPLY-EFF=.45
*1354 *              FAN-SCHEDULE=AHU-SCHED HEAT-SOURCE=HOT-WATER
*1355 *              NIGHT-CYCLE-CTRL=CYCLE-ON-FIRST
*1356 *              ZONE-NAMES=(ATZ2,EQUIP-RM) ..
*1357 *
*1358 * OFF-SYS    = SYSTEM        SYSTEM-TYPE=VAVS MAX-S-T=120 MIN-S-T=60
*1359 *              SUPPLY-STATIC=5 SUPPLY-EFF=.55 ECONO-LIMIT-T=68
*1360 *              FAN-SCHEDULE=AHU-SCHED MIN-CFM-RATIO=.3
*1361 *              FAN-CONTROL=SPEED HEAT-SET-T=100
*1362 *              RETURN-AIR-PATH=DUCT OA-CONTROL=TEMP
*1363 *              N-C-C=CYCLE-ON-ANY REHEAT-DELTA-T=55
*1364 *              MIN-AIR-SCH=MIN-OA BASEBOARD-SCH=BASD-RESET
*1365 *              ZONE-NAMES=(BZ1,BZ2,BZ3,TZ1,TZ2,TZ3,IZ1,IZ2) ..
*1366 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (FS-SYS1,FS-SYS2,OFF-SYS)
*1367 *              DHW-SIZE = 0
*1368 *              DHW-GAL/MIN = 4.44
*1369 *              DHW-SCH = DOMHW ..
*1370 *
*1371 * D1 = D-SCH (1,7) (0) (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.45,.4,.3,.3)
*1372 *              (22,24) (0) ..
*1373 * D2 = D-SCH (1,7) (0) (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.45,.4,.35,
*1374 *              .25,.2) (23,24) (0) ..
*1375 * D3 = D-SCH (1,9) (0) (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
*1376 *              (20,24) (0) ..
*1377 * DOMHW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..

```

*1378 * END ..
*1379 * COMPUTE SYSTEMS ..
*1380 * INPUT PLANT ..

PDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993PDL RUN 3

```
*1381 * PLANT1 = PLANT-ASSIGNMENT ..
*1382 * PLANT-REPORT SUMMARY (PS-A,PS-D,BEPS) ..
*1383 *
*1384 *           $ PLANT DESCRIPTION
*1385 *
*1386 * $ THIS PLANT IS SERVED BY A SINGLE GAS ENGINE DRIVEN PACKAGED CHILLER WITH
*1387 * $ HEAT RECOVERY FROM THE ENGINE THAT HEATS DOMESTIC HOT WATER (PROCESS) AND
*1388 * $ THE BUILDING. A HOT WATER GENERATOR SERVES TO HEAT THE BUILDING WHENEVER
*1389 * $ THE CHILLER IS NOT IN USE. THE DOMESTIC HOT WATER IS ALSO HEATED BY THE
*1390 * $ HWG WHENEVER THE CHILLER IS NOT IN USE.
*1391 *
*1392 * HWG = PLANT-EQUIPMENT TYPE=HW-BOILER SIZE -999 I-N 1 ..
*1393 * CHLR = PLANT-EQUIPMENT TYPE=ENG-CHLR SIZE -999 I-N 1 ..
*1394 *
*1395 * HEAT-RECOVERY SUPPLY-1 (ENG-CHLR)
*1396 *           DEMAND-1 (SPACE-HEAT,PROCESS-HEAT) ..
*1397 *
*1398 * PLANT-PARAMETERS ENG-CH-COP=1.1 ..
*1399 * END ..
*1400 * COMPUTE PLANT ..
*1401 * INPUT ECONOMICS ..
```


EDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993EDL RUN 3

```

*1402 * DIAGNOSTIC WARNINGS ..
*1403 * ECONOMICS-REPORT SUMMARY (ES-D,ES-E) ..
*1404 *
*1405 *           $ ENERGY CHARGE DESCRIPTION
*1406 *
*1407 * $ THIS RATE STRUCTURE IS A TYPICAL SMALL COMMERCIAL TIME OF DAY TYPE WITH AND
*1408 * $ INVERTED RATE.  IN OTHER WORDS ENERGY COSTS INCREASE AS CONSUMPTION RISES.
*1409 * $ THERE IS A BASE CHARGE OF 2 CENTS/KWH PLUS A FIXED MONTHLY CHARGE OF 200
*1410 * $ DOLLARS.  ON TOP OF THESE CHARGES FALL THE KWH/KW ENERGY CHARGE FOR EACH
*1411 * $ SEASON.  THERE IS A LIMITATION OF 15000 KWH FOR THE FIRST BLOCK.
*1412 * $ NATURAL GAS IS A FLAT RATE OF 60 CENTS PER THERM.
*1413 *
*1414 * ELEC-COST = UTILITY-RATE  RESOURCE = ELECTRICITY
*1415 *           MONTH-CHGS (200)
*1416 *           BLOCK-CHARGES = (WIN-OFF-P,WIN-ON-P,
*1417 *                               SUM-OFF-P,SUM-ON-P)
*1418 *           ENERGY-CHG = .02 ..
*1419 *
*1420 * WIN-OFF-P = BLOCK-CHARGE  BLOCK-SCH = TOU-CHGS
*1421 *           SCH-FLAG = 1.1
*1422 *           BLOCK1-TYPE = KWH/KW
*1423 *           BLOCK1-DATA = (200,.025,15000,
*1424 *                               1,.035,0) ..
*1425 * WIN-ON-P = BLOCK-CHARGE  BLOCK-SCH = TOU-CHGS
*1426 *           SCH-FLAG = 1.2
*1427 *           BLOCK1-TYPE = KWH/KW
*1428 *           BLOCK1-DATA = (200,.040,15000,
*1429 *                               1,.050,0) ..
*1430 * SUM-OFF-P = BLOCK-CHARGE  BLOCK-SCH = TOU-CHGS
*1431 *           SCH-FLAG = 2.1
*1432 *           BLOCK1-TYPE = KWH/KW
*1433 *           BLOCK1-DATA = (200,.025,15000,
*1434 *                               1,.035,0) ..
*1435 * SUM-ON-P = BLOCK-CHARGE  BLOCK-SCH = TOU-CHGS
*1436 *           SCH-FLAG = 2.2
*1437 *           BLOCK1-TYPE = KWH/KW
*1438 *           BLOCK1-DATA = (150,.045,15000,
*1439 *                               1,.055,0) ..
*1440 * TOU-CHGS = SCHEDULE THRU MAY 15 (ALL) (1.12) (1.1)
*1441 *           (13.17) (1.2)
*1442 *           (18.24) (1.1)
*1443 *           THRU OCT 20 (ALL) (1.12) (2.1)
*1444 *           (13.18) (2.2)
*1445 *           (19.24) (2.1)
*1446 *           THRU DEC 31 (ALL) (1.12) (1.1)
*1447 *           (13.17) (1.2)
*1448 *           (18.24) (1.1) ..
*1449 *
*1450 * GAS-COST = UTILITY-RATE  RESOURCE = NATURAL-GAS
*1451 *           ENERGY-CHG = .60 ..
*1452 * END ..
*1453 * COMPUTE ECONOMICS ..
*1454 * INPUT LOADS ..

```

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	7.20999	25 16	48.F	42.F	143.827	-101.398	1 7	-1.F	-1.F	-379.043	24148.	64.998
FEB	9.80719	9 16	23.F	19.F	184.981	-84.358	4 6	7.F	6.F	-345.886	21865.	64.998
MAR	23.84211	5 17	57.F	46.F	212.019	-52.775	24 6	8.F	7.F	-328.271	24734.	64.998
APR	69.42180	26 17	74.F	60.F	387.010	-19.922	8 5	33.F	30.F	-227.278	24212.	64.998
MAY	95.43662	21 12	87.F	76.F	412.119	-6.564	9 5	40.F	38.F	-123.827	24148.	64.998
JUN	141.87355	29 17	85.F	67.F	450.962	-0.391	1 5	48.F	47.F	-25.491	23806.	64.998
JUL	196.30849	9 17	97.F	73.F	532.357	0.000	6 4	60.F	54.F	-0.108	24639.	64.998
AUG	167.03616	19 17	90.F	71.F	505.317	-0.016	5 5	55.F	54.F	-10.219	24649.	64.998
SEP	106.53899	11 14	87.F	72.F	422.753	-3.346	23 5	36.F	33.F	-95.200	23316.	64.998
OCT	60.16368	5 15	74.F	62.F	320.579	-14.977	21 5	30.F	29.F	-159.590	24148.	64.998
NOV	23.76648	2 15	75.F	61.F	305.734	-50.568	15 6	28.F	26.F	-263.771	23231.	64.998
DEC	5.71840	10 15	41.F	35.F	139.875	-87.514	9 6	14.F	13.F	-291.999	23753.	64.998
TOTAL	907.123					-421.830					286650.	
MAX					532.357					-379.043		64.998

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE						
PS-SYS1	PSZ		1.020	1800.0		6.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	2037.	1.562	2.4	0.	0.000	0.0	0.333	82.133	0.624	-115.100	0.36	0.37
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
AT21		2037.	0.	0.000	1.000	678.	0.00	0.00	41.79	0.00	-65.98	1.0

REFRIGERATED EQUIP IN AT21

UNIT	ZONE				COMPRESSOR		CONDENSER		
	DISCHARGE TEMP (F)	SENSIBLE LOADS TEMP (KBTU/HR)	SENSIBLE HEAT TEMP (KBTU/HR)	SENSIBLE COOL TEMP (KBTU/HR)	COMPRESSOR CAPACITY (KBTU/HR)	COMPRESSOR EFFICIENCY (BTU/WATT)	DESIGN HEAT REJ (KBTU/HR)	FAN ENERGY (KW)	PUMP ENERGY (KW)
1	-10.0	-8.894	-8.471	-8.894	14.547	3.8	51.693	0.271	0.064
2	23.0	-3.923	-3.615	-3.923	16.390	7.0			
3	30.0	-5.280	-4.800	-5.280	0.000	7.3			

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
FS-SYS2	PSZ	1.020	3000.0	6.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/STU)	HEATING EIR (BTU/STU)
	2357.	1.808	2.4	0.	0.000	0.0	0.288	91.648	0.630	-124.146	0.36	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
AT22	2357.	0.	0.000	1.000	678.	0.00	0.00	48.36	0.00	-76.35	1.0	
EQUIP-RM	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
OFF-SYS	VAVS	1.020	23320.0	180.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	34360.	35.944	3.3	0.	0.000	0.0	0.080	914.790	0.842	-1044.564	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
B21	6244.	0.	0.000	0.300	306.	0.00	0.00	94.41	-370.88	-400.19	1.0	
B22	1763.	0.	0.000	0.300	153.	0.00	0.00	26.66	-104.74	-124.60	1.0	
B23	6046.	0.	0.000	0.300	306.	0.00	0.00	91.41	-359.13	-400.36	1.0	
T21	6570.	0.	0.000	0.300	306.	0.00	0.00	99.34	-390.26	-420.40	1.0	
T22	1949.	0.	0.000	0.300	153.	0.00	0.00	29.46	-115.75	-136.81	1.0	
T23	6434.	0.	0.000	0.300	306.	0.00	0.00	97.28	-382.18	-423.64	1.0	
I21	2677.	0.	0.000	0.300	612.	0.00	0.00	40.48	-159.03	-187.01	1.0	
I22	2677.	0.	0.000	0.300	612.	0.00	0.00	40.48	-159.03	-187.01	1.0	

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	28.06300	2 8	4.F	3.F	904.737	-246.882	12 8	-7.F	-7.F	-760.626	31535.	101.535
FEB	20.32421	8 8	7.F	6.F	650.254	-202.815	8 8	7.F	6.F	-676.419	28321.	102.189
MAR	15.78579	24 8	6.F	5.F	552.128	-135.528	24 8	6.F	5.F	-658.918	31184.	94.100
APR	30.51579	27 17	84.F	61.F	367.863	-45.265	8 8	31.F	28.F	-390.138	30517.	87.418
MAY	34.14484	21 13	87.F	76.F	526.504	-14.146	6 8	37.F	33.F	-231.873	30959.	99.177
JUN	103.27728	21 16	82.F	72.F	607.239	-0.330	1 7	47.F	46.F	-34.380	33937.	102.649
JUL	176.32637	19 12	88.F	74.F	733.177	0.000				0.000	40423.	117.664
AUG	140.24101	16 12	82.F	72.F	653.365	-0.007	4 21	67.F	62.F	-7.361	37726.	110.076
SEP	54.14698	11 16	86.F	72.F	509.824	-7.448	23 8	36.F	34.F	-216.228	31041.	97.821
OCT	22.50027	4 17	78.F	61.F	284.225	-36.683	21 8	30.F	29.F	-332.214	30045.	81.226
NOV	15.80578	26 8	25.F	22.F	432.624	-112.524	15 8	27.F	26.F	-444.431	29004.	90.030
DEC	14.23257	20 8	24.F	23.F	451.363	-190.934	9 8	13.F	12.F	-573.202	29858.	89.273
TOTAL	655.364					-992.565					384550.	
MAX					904.737					-760.626		117.664

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 0.000 (KBTU)
MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 911.102 (KBTU)

----- COOLING -----						----- HEATING -----					----- ELEC -----			
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY	TIME OF MAX HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000					0.000	-27.075	12	8	-7.F	-7.F	-104.956	6497.	13.011
FEB	0.00012	21	11	44.F	37.F	0.124	-21.999	4	8	7.F	6.F	-89.946	5868.	13.013
MAR	0.00045	3	17	78.F	61.F	0.450	-16.390	24	8	6.F	5.F	-83.091	6771.	13.649
APR	0.53489	28	15	78.F	68.F	22.995	-5.507	8	8	31.F	28.F	-61.313	6657.	15.933
MAY	1.70829	21	13	87.F	76.F	54.505	-2.497	10	8	42.F	40.F	-45.790	6918.	19.582
JUN	8.27777	20	16	90.F	77.F	72.588	-0.098	24	8	55.F	50.F	-10.712	7594.	18.450
JUL	23.14514	14	14	96.F	77.F	70.569	0.000	22	10	63.F	60.F	-0.169	9372.	21.825
AUG	17.48693	22	13	85.F	71.F	60.623	0.000	28	10	67.F	57.F	-0.081	8752.	20.459
SEP	4.76325	11	15	87.F	72.F	55.144	-0.925	23	8	36.F	34.F	-40.551	7072.	19.413
OCT	0.41688	31	14	76.F	66.F	24.270	-4.350	21	8	30.F	29.F	-55.855	6737.	15.704
NOV	0.31899	2	12	72.F	60.F	30.227	-13.475	26	8	25.F	22.F	-70.497	6439.	15.852
DEC	0.00000					0.000	-23.177	25	8	20.F	19.F	-84.624	6568.	12.987
TOTAL	56.653						-115.492						85245.	
MAX						72.588						-104.956		21.825

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY-BULB TEMP	WET-BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP
	JUN 20				JAN 12			JUL 14			
1	18.838	0.653	68.F	64.F	-39.978	5.F	4.F	53.800	0.675	83.F	72.F
2	16.845	0.648	68.F	64.F	-46.363	3.F	2.F	50.519	0.644	81.F	72.F
3	13.430	0.678	66.F	62.F	-51.193	1.F	0.F	48.529	0.658	80.F	71.F
4	11.366	0.678	66.F	62.F	-58.452	-2.F	-3.F	44.955	0.629	78.F	71.F
5	10.633	0.660	65.F	62.F	-59.337	-4.F	-5.F	43.271	0.642	77.F	70.F
6	10.977	0.658	65.F	62.F	-63.595	-5.F	-6.F	43.811	0.626	78.F	71.F
7	15.778	0.633	67.F	64.F	-62.290	-6.F	-7.F	48.364	0.647	79.F	71.F
8	21.321	0.683	73.F	65.F	-104.956	-7.F	-7.F	46.829	0.643	82.F	72.F
9	27.427	0.676	76.F	67.F	-81.039	-8.F	-8.F	44.817	0.624	86.F	74.F
10	46.646	0.646	80.F	71.F	-59.529	-7.F	-7.F	51.295	0.672	88.F	74.F
11	52.703	0.662	83.F	72.F	-49.512	-4.F	-5.F	62.013	0.661	91.F	76.F
12	60.836	0.637	84.F	74.F	-35.106	0.F	0.F	65.000	0.702	94.F	76.F
13	64.374	0.661	85.F	74.F	-35.167	4.F	2.F	70.569	0.703	96.F	77.F
14	66.430	0.665	88.F	75.F	-36.851	6.F	4.F	56.277	0.676	87.F	74.F
15	72.588	0.639	90.F	77.F	-41.328	4.F	2.F	51.033	0.628	76.F	71.F
16	66.081	0.604	90.F	78.F	-51.659	3.F	1.F	47.923	0.607	78.F	72.F
17	70.534	0.628	91.F	78.F	-67.385	1.F	0.F	45.617	0.604	78.F	72.F
18	62.084	0.629	90.F	77.F	-74.130	-2.F	-3.F	52.692	0.648	89.F	75.F
19	68.650	0.604	89.F	78.F	-76.864	-4.F	-5.F	49.233	0.626	87.F	75.F
20	48.722	0.567	79.F	74.F	-80.681	-4.F	-5.F	43.054	0.612	84.F	74.F
21	34.966	0.635	70.F	67.F	-82.165	-3.F	-4.F	51.427	0.629	84.F	74.F
22	30.040	0.634	69.F	66.F	0.000	-3.F	-4.F	54.179	0.615	82.F	74.F
23	29.703	0.675	70.F	65.F	-26.672	-2.F	-3.F	50.060	0.640	80.F	72.F
24	26.112	0.722	71.F	64.F	-30.368	-1.F	-2.F	47.530	0.605	78.F	72.F
SUM								1222.796			
MAX	72.588				-104.956						

SYSTEM-TYPE PSZ SQFT/TON 297.6
 COOLING PEAK 40.33 (BTU/HR- SQFT) HEATING PEAK -58.31 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 1.13 (CFM/SQFT) MIN-OA/PERSON 113.05 (CFM)
 OA FRAC AT CLG PEAK 0.333 OA FRAC AT HTG PEAK 0.333

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	- - - Z O N A L - - -		- C O N D E N S E R -		- - - - - E L E C T R I C - - - - -			
	SENSIBLE ENERGY (MBTU)	LATENT ENERGY (MBTU)	RECOVERED ENERGY (MBTU)	REJECTED ENERGY (MBTU)	COMPRESSOR ENERGY (KWH)	DEFROST ENERGY (KWH)	AUXILIARY ENERGY (KWH)	TOTAL ENERGY (KWH)
JAN	-8.051	-0.205	6.859	8.477	1794.660	35.590	424.873	2255.114
FEB	-7.339	-0.140	6.089	7.797	1623.904	28.054	363.958	2015.910
MAR	-8.394	-0.384	6.333	9.881	1877.289	58.976	507.071	2443.329
APR	-8.323	-0.608	2.903	13.327	1836.799	84.056	515.206	2436.051
MAY	-8.504	-0.894	1.824	15.136	1903.686	114.921	521.514	2540.107
JUN	-8.743	-1.098	0.094	17.618	1980.551	136.158	516.831	2633.526
JUL	-9.064	-1.264	0.000	18.889	2171.995	154.283	528.234	2854.497
AUG	-9.029	-1.287	0.000	18.744	2131.731	156.716	528.234	2816.669
SEP	-8.498	-0.886	0.654	16.179	1874.172	113.553	510.110	2497.823
OCT	-8.413	-0.701	2.680	13.814	1859.778	94.442	520.973	2475.178
NOV	-7.883	-0.458	5.307	10.014	1763.652	67.656	481.192	2312.487
DEC	-8.053	-0.262	6.923	8.522	1807.183	46.460	467.373	2321.008
TOTAL	-100.294	-8.186	39.665	158.397	22625.402	1090.864	5885.571	29601.697

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-11.293	12 8	-7.F	-7.F	-88.727	3721.	8.122
FEB	0.00000				0.000	-8.909	8 8	7.F	6.F	-74.332	3384.	8.122
MAR	0.11991	3 15	76.F	65.F	25.692	-6.079	24 8	6.F	5.F	-65.801	3861.	10.644
APR	1.87567	28 15	78.F	68.F	44.295	-1.443	8 8	31.F	28.F	-44.049	3900.	12.244
MAY	2.81333	21 13	87.F	76.F	74.494	-0.250	10 8	42.F	40.F	-26.371	4051.	15.756
JUN	11.61781	20 17	90.F	78.F	72.857	-0.002	23 8	53.F	49.F	-0.908	5015.	14.894
JUL	25.78890	14 14	96.F	77.F	88.337	0.000				0.000	6598.	17.637
AUG	20.56810	26 17	94.F	76.F	77.483	0.000				0.000	6022.	16.621
SEP	7.04253	11 15	87.F	72.F	71.332	-0.073	23 8	36.F	34.F	-21.685	4460.	15.511
OCT	1.46020	30 14	74.F	66.F	44.003	-0.762	21 8	30.F	29.F	-37.147	3870.	12.032
NOV	0.60799	2 12	72.F	60.F	42.775	-4.558	15 8	27.F	26.F	-53.540	3647.	11.922
DEC	0.00000				0.000	-9.773	25 8	20.F	19.F	-66.732	3717.	8.122
TOTAL	71.894					-43.141					52245.	
MAX					88.337					-88.727		17.637

----- COOLING -----				----- HEATING -----			DAY COOLING PEAK				
JUL 14				JAN 12			JUL 19				
HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY-BULB TEMP	WET-BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	
1	0.000	0.000	83.F	72.F	0.000	5.F	4.F	0.000	0.000	79.F	72.F
2	59.162	0.701	81.F	72.F	0.000	3.F	2.F	57.605	0.679	79.F	72.F
3	0.000	0.000	80.F	71.F	0.000	1.F	0.F	0.000	0.000	78.F	72.F
4	55.581	0.686	78.F	71.F	0.000	-2.F	-3.F	55.877	0.667	78.F	72.F
5	0.000	0.000	77.F	70.F	0.000	-4.F	-5.F	0.000	0.000	77.F	72.F
6	54.616	0.687	78.F	71.F	0.000	-5.F	-6.F	55.334	0.664	78.F	72.F
7	60.885	0.689	79.F	71.F	0.000	-6.F	-7.F	62.785	0.651	77.F	72.F
8	59.554	0.675	82.F	72.F	-88.727	-7.F	-7.F	57.064	0.646	79.F	72.F
9	68.720	0.676	86.F	74.F	-70.374	-8.F	-8.F	60.637	0.680	82.F	72.F
10	73.169	0.709	88.F	74.F	-45.139	-7.F	-7.F	72.009	0.703	85.F	73.F
11	82.488	0.697	91.F	76.F	-36.470	-4.F	-5.F	79.021	0.717	88.F	74.F
12	84.127	0.730	94.F	76.F	-24.549	0.F	0.F	83.623	0.734	89.F	74.F
13	88.337	0.729	96.F	77.F	-23.550	4.F	2.F	86.265	0.720	90.F	75.F
14	75.458	0.717	87.F	74.F	-24.438	6.F	4.F	84.224	0.712	89.F	75.F
15	70.399	0.677	76.F	71.F	-28.098	4.F	2.F	83.744	0.718	90.F	75.F
16	68.095	0.663	78.F	72.F	-35.547	3.F	1.F	81.588	0.699	91.F	76.F
17	66.924	0.658	78.F	72.F	-47.496	1.F	0.F	77.269	0.713	90.F	75.F
18	73.395	0.687	89.F	75.F	-53.029	-2.F	-3.F	73.102	0.698	86.F	74.F
19	70.625	0.671	87.F	75.F	-56.050	-4.F	-5.F	71.357	0.692	86.F	74.F
20	65.091	0.661	84.F	74.F	-58.963	-4.F	-5.F	63.081	0.675	80.F	72.F
21	0.000	0.000	84.F	74.F	-60.315	-3.F	-4.F	0.000	0.000	79.F	72.F
22	61.891	0.660	82.F	74.F	0.000	-3.F	-4.F	58.751	0.676	77.F	71.F
23	0.000	0.000	80.F	72.F	0.000	-2.F	-3.F	0.000	0.000	76.F	71.F
24	56.025	0.661	78.F	72.F	0.000	-1.F	-2.F	54.053	0.665	74.F	70.F
SUM					-88.727			1317.392			
MAX	88.337										

SYSTEM-TYPE PSZ SQFT/TON 407.5
COOLING PEAK 29.45 (BTU/HR- SQFT) HEATING PEAK -29.58 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW 0.79 (CFM/SQFT) MIN-OA/PERSON 113.05 (CFM)
OA FRAC AT CLG PEAK 0.288 OA FRAC AT HTG PEAK 0.288

* ASTERISKS INDICATE HOURS LOADS NOT MET

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	28.06300	2 8	4.F	3.F	904.737	-215.374	12 21	-3.F	-4.F	-573.000	21317.	82.906		
FEB	20.32421	8 8	7.F	6.F	650.254	-177.996	9 7	2.F	2.F	-550.080	19070.	81.677		
MAR	15.78579	24 8	6.F	5.F	552.128	-119.392	24 8	6.F	5.F	-516.134	20552.	73.602		
APR	30.51579	27 17	84.F	61.F	367.863	-41.217	8 8	31.F	28.F	-290.941	19960.	66.560		
MAY	34.14484	21 13	87.F	76.F	526.504	-13.223	7 7	33.F	30.F	-194.820	19989.	67.848		
JUN	103.27728	21 16	82.F	72.F	607.239	-0.324	1 7	47.F	46.F	-34.380	21329.	76.179		
JUL	176.32637	19 12	88.F	74.F	733.177	0.000				0.000	24454.	82.149		
AUG	140.24101	16 12	82.F	72.F	653.365	-0.007	4 21	67.F	62.F	-7.361	22952.	78.992		
SEP	54.14698	11 16	86.F	72.F	509.824	-7.105	22 8	34.F	31.F	-183.360	19509.	66.187		
OCT	22.50027	4 17	78.F	61.F	284.225	-34.251	2 7	28.F	25.F	-252.120	19438.	60.286		
NOV	15.80578	26 8	25.F	22.F	432.624	-99.798	15 8	27.F	26.F	-329.422	18918.	69.186		
DEC	14.23257	20 8	24.F	23.F	451.363	-164.908	22 7	11.F	11.F	-446.940	19572.	69.642		
TOTAL	655.364					-873.595					247062.			
MAX					904.737					-573.000		82.906		

HOUR	- - - - - COOLING - - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY-BULB TEMP	WET-BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP
1	0.000	0.000	1.F	0.F	-515.700	5.F	4.F	0.000	0.000	79.F	72.F
2	465.383	1.000	1.P	0.F	-538.620	3.P	2.F	0.000	0.000	79.F	72.F
3	0.000	0.000	1.P	0.F	-561.540	1.P	0.F	0.000	0.000	78.F	72.F
4	453.277	1.000	2.F	1.F	-573.000	-2.F	-3.F	0.000	0.000	78.F	72.F
5	0.000	0.000	2.F	1.F	-573.000	-4.F	-5.F	0.000	0.000	77.F	72.F
6	447.559	1.000	2.F	1.F	-573.000	-5.F	-6.F	0.000	0.000	78.F	72.F
7	0.000	0.000	3.P	2.F	-573.000	-6.F	-7.F	571.887	0.974	77.F	72.F
8	904.737 *	1.000	4.F	3.F	-573.000	-7.F	-7.F	552.179 *	0.965	79.F	72.F
9	687.237 *	1.000	4.F	3.F	-573.000	-8.F	-8.F	713.220 *	0.863	82.F	72.F
10	0.000	0.000	5.P	4.F	-573.000	-7.F	-7.F	728.420 *	0.867	85.F	73.F
11	0.000	0.000	6.P	5.F	-573.000	-4.F	-5.F	733.177 *	0.863	88.F	74.F
12	0.000	0.000	8.F	7.F	-573.000	0.F	0.F	683.416 *	0.874	89.F	74.F
13	0.000	0.000	9.F	9.F	-527.160	4.F	2.F	641.530	0.868	90.F	75.F
14	0.000	0.000	11.P	11.F	-504.240	6.F	4.F	686.142	0.850	89.F	75.F
15	0.000	0.000	12.F	12.F	-527.160	4.F	2.F	703.927	0.858	90.F	75.F
16	0.000	0.000	14.F	13.F	-538.620	3.P	1.F	700.279	0.854	91.F	76.F
17	0.000	0.000	15.P	14.F	-561.540	1.P	0.F	694.358	0.859	90.F	75.F
18	0.000	0.000	15.P	15.F	-573.000	-2.F	-3.F	621.562	0.860	86.F	74.F
19	0.000	0.000	17.P	16.F	-573.000	-4.F	-5.F	578.564	0.853	86.F	74.F
20	0.000	0.000	17.P	16.F	-573.000	-4.F	-5.F	506.435	0.843	80.F	72.F
21	0.000	0.000	18.P	18.F	-573.000	-3.F	-4.F	0.000	0.000	79.F	72.F
22	0.000	0.000	17.F	17.F	-573.000	-3.F	-4.F	0.000	0.000	77.F	71.F
23	0.000	0.000	17.F	17.F	-573.000	-2.F	-3.F	0.000	0.000	76.F	71.F
24	0.000	0.000	17.F	17.F	-573.000	-1.F	-2.F	0.000	0.000	74.F	70.F
SUM								9115.097			
MAX	904.737				-573.000						

SYSTEM-TYPE VAVS SQFT/TON 309.3
COOLING PEAK 38.80 (BTU/HR- SQFT) HEATING PEAK -24.57 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW 1.47 (CFM/SQFT) MIN-OA/PERSON 15.30 (CFM)
OA FRAC AT CLG PEAK 0.000 OA FRAC AT HTG PEAK 0.259

* ASTERISKS INDICATE HOURS LOADS NOT MET

MESSAGE LIST FROM PLANT PROGRAM

CAUTION.....
TOWER WILL BE DEFINED FOR CHILLERS THAT NEED IT

OFFICE BUILDING & DELI/RESTAURANT
 VAV SYSTEM IN OFFICE & PSZ IN ATRIUM
 REPORT- PV-A EQUIPMENT SIZES

ELECTROCHROMIC GLAZING IN ATRIUM
 GAS ENGINE DRIVEN CHILLER & HEAT RECY

DOE-2.1E-001 Wed Nov 10 15:17:48 1993PDL RUN 3
 SAMP3.INP RUN 3
 WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
HW-BOILER	0.903	1 1										
ENG-CHLR	0.923	1 1										
COOLING-TWR	1.778	1 1										

MONTH	SITE ENERGY												SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	285.0	29.6	37.0	12.5	0.0	23.9	0.7	392.7	4.7	0.0	416.6	542.9	795.7
FEB	238.4	21.4	33.1	8.8	0.0	16.8	0.5	335.2	4.2	0.0	352.1	465.0	690.9
MAR	175.1	17.2	35.9	8.3	0.0	15.9	0.7	257.0	4.0	0.0	273.0	395.4	640.4
APR	80.4	34.1	34.1	15.3	2.2	33.6	1.9	104.9	1.9	0.0	138.5	255.1	488.2
MAY	46.0	38.4	34.0	14.9	4.9	38.3	2.4	50.8	1.0	0.0	89.1	205.0	436.9
JUN	28.6	110.0	37.4	24.4	22.4	89.3	5.2	6.9	0.1	0.0	96.2	223.8	479.1
JUL	26.6	183.3	44.2	24.6	47.9	138.8	8.6	3.2	0.1	0.0	142.0	293.0	595.0
AUG	25.9	146.9	41.3	23.5	35.1	111.8	7.1	3.9	0.1	0.0	115.7	256.5	538.2
SEP	33.8	59.4	34.1	18.0	10.5	54.7	3.6	25.9	0.5	0.0	80.6	196.9	429.6
OCT	66.9	26.0	33.4	13.2	1.7	28.7	1.8	87.4	1.7	0.0	116.1	230.1	458.1
NOV	145.0	17.5	33.3	7.9	0.6	16.5	0.9	215.2	3.6	0.0	231.7	345.4	573.0
DEC	227.4	15.3	35.1	6.9	0.0	13.0	0.5	332.5	4.7	0.0	345.5	465.2	704.7
TOTAL	1379.1	699.2	432.9	178.2	125.2	581.3	34.0	1815.7	26.7	0.0	2397.1	3874.5	6829.9

HEATING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
HW-BOILER	1200.9	87.1
ENG-CHLR	178.2	12.9
LOAD SATISFIED	1379.1	100.0
TOTAL LOAD ON PLANT	1379.1	
COOLING LOADS	MBTU SUPPLIED	PCT OF TOTAL LOAD
ENG-CHLR	699.2	100.0
LOAD SATISFIED	699.2	100.0
TOTAL LOAD ON PLANT	699.2	
ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	432901.9	100.0
LOAD SATISFIED	432901.9	100.0
TOTAL LOAD ON PLANT	432901.2	

TOWER ABOVE DESIGN TEMPERATURE OF 85.F 0 HOURS

OFFICE BUILDING & DELI/RESTAURANT
VAV SYSTEM IN OFFICE & PSZ IN ATRIUM
REPORT- PS-D PLANT LOADS SATISFIED

ELECTROCHROMIC GLAZING IN ATRIUM
GAS ENGINE DRIVEN CHILLER & HEAT RECY

DOE-2.1E-001 Wed Nov 10 15:17:48 1993PDL RUN 3
SAMP3.INP RUN 3
WEATHER FILE- TRY CHICAGO
(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
HEATING LOADS	1379.1	1379.1	0.000	0.000	0
COOLING LOADS	699.2	699.2	0.000	0.000	0
ELECTRICAL LOADS	1477.5	1477.5	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS	RECOVERED
CATEGORY OF USE			
AREA LIGHTS	522.7	0.0	0.0
MISC EQUIPMT	455.6	0.0	0.0
SPACE HEAT	60.7	1442.8	57.6
SPACE COOL	53.7	581.3	0.0
HEAT REJECT	37.9	0.0	0.0
PUMPS & MISC	39.4	0.0	0.0
VENT FANS	189.5	0.0	0.0
REFRIGERATN	101.0	0.0	0.0
DOMHOT WATER	17.1	373.0	120.6
TOTAL	1477.5	2397.1	178.2

TOTAL SITE ENERGY 3874.52 MBTU 143.9 KBTU/SQFT-YR GROSS-AREA 143.9 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY 6829.89 MBTU 253.7 KBTU/SQFT-YR GROSS-AREA 253.7 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.7
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

OFFICE BUILDING & DELI/RESTAURANT
 VAV SYSTEM IN OFFICE & PSZ IN ATRIUM
 REPORT- ES-D ENERGY COST SUMMARY

ELECTROCHROMIC GLAZING IN ATRIUM
 GAS ENGINE DRIVEN CHILLER & HEAT RECY

DOE-2.1E-001 Wed Nov 10 15:17:48 1993EDL RUN 3
 SAMP3.INP RUN 3

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	432902. KWH	25362.	0.0586	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	23971. THERM	14382.	0.6000	YES

 39744.

ENERGY COST/GROSS BLDG AREA: 1.48
 ENERGY COST/NET BLDG AREA: 1.48

OFFICE BUILDING & DELI/RESTAURANT ELECTROCHROMIC GLAZING IN ATRIUM DOE-2.1E-001 Wed Nov 10 15:17:48 1993EDL RUN 3
 VAV SYSTEM IN OFFICE & PSZ IN ATRIUM GAS ENGINE DRIVEN CHILLER & HEAT RECY SAMP3.INP RUN 3
 REPORT - ES-E SUMMARY OF UTILITY-RATE: ELEC-COST

UTILITY-RATE: ELEC-COST RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS
 MIN-ENERGY: 0.0 WIN-OFF-P
 MAX-ENERGY: 0.0 WIN-ON-P
 MIN-DEMAND: 0.0 SUM-OFF-P
 MAX-DEMAND: 0.0 SUM-ON-P
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	37028	37028	108.2	108.2	1938	0	0	0	0	200	0	0.0577	2138
FEB	33090	33090	108.8	108.8	1716	0	0	0	0	200	0	0.0579	1916
MAR	35881	35881	100.7	100.7	1875	0	0	0	0	200	0	0.0578	2075
APR	34149	34149	94.1	94.1	1779	0	0	0	0	200	0	0.0580	1979
MAY	33969	33969	109.9	109.9	1733	0	0	0	0	200	0	0.0569	1933
JUN	37386	37386	112.4	112.4	2048	0	0	0	0	200	0	0.0601	2248
JUL	44243	44243	129.1	129.1	2469	0	0	0	0	200	0	0.0603	2669
AUG	41261	41261	120.3	120.3	2283	0	0	0	0	200	0	0.0602	2483
SEP	34085	34085	107.9	107.9	1852	0	0	0	0	200	0	0.0602	2052
OCT	33404	33404	91.0	91.0	1709	0	0	0	0	200	0	0.0571	1909
NOV	33329	33329	96.7	96.7	1731	0	0	0	0	200	0	0.0579	1931
DEC	35076	35076	95.9	95.9	1828	0	0	0	0	200	0	0.0578	2028
TOTAL	432902	432902	129.1		22962	0	0	0	0	2400		0.0586	25362

UTILITY-RATE: ELEC-COST
RESOURCE: ELECTRICITY
ENERGY-UNITS: KWH
DEMAND-UNITS: KW
DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR

WIN-OFF-P USE: TIME-OF-USE													
METERED ENERGY:	26684	23815	25548	23950	11619	0	0	0	0	8506	23753	25255	
BILLING ENERGY:	26684	23815	25548	23950	11619	0	0	0	0	8506	23753	25255	169131
KWH/KW DEMAND:	108.2	108.8	100.7	94.1	89.1	0.0	0.0	0.0	0.0	91.0	96.7	95.9	
ENERGY CHGS (\$):	784	684	744	688	290	0	0	0	0	213	681	734	4818
WIN-ON-P USE: TIME-OF-USE													
METERED ENERGY:	10344	9275	10332	10199	4998	0	0	0	0	3734	9576	9821	
BILLING ENERGY:	10344	9275	10332	10199	4998	0	0	0	0	3734	9576	9821	68280
KWH/KW DEMAND:	103.1	93.0	90.1	92.9	85.9	0.0	0.0	0.0	0.0	90.0	90.9	86.9	
ENERGY CHGS (\$):	414	371	413	408	200	0	0	0	0	149	383	393	2731
SUM-OFF-P USE: TIME-OF-USE													
METERED ENERGY:	0	0	0	0	10899	23216	27481	25564	21309	13683	0	0	
BILLING ENERGY:	0	0	0	0	10899	23216	27481	25564	21309	13683	0	0	122151
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	109.9	112.4	129.1	120.3	107.9	89.1	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	272	663	812	745	596	342	0	0	3429
SUM-ON-P USE: TIME-OF-USE													
METERED ENERGY:	0	0	0	0	6452	14171	16762	15697	12777	7481	0	0	
BILLING ENERGY:	0	0	0	0	6452	14171	16762	15697	12777	7481	0	0	73340
KWH/KW DEMAND:	0.0	0.0	0.0	0.0	108.9	111.3	124.0	115.8	107.2	87.0	0.0	0.0	
ENERGY CHGS (\$):	0	0	0	0	290	638	772	713	575	337	0	0	3325

TOTAL ENERGY:	37028	33090	35881	34149	33969	37386	44243	41261	34085	33404	33329	35076	432902
TOTAL CHARGES (\$):	1198	1055	1157	1096	1053	1300	1584	1458	1171	1041	1064	1127	14304

UTILITY-RATE: GAS-COST RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGE: DEMAND-RATCHETS MIN-MON-RATCHETS
 MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	4166	4166	12.8	12.8	2499	0	0	0	0	0	0	0.6000	2499
FEB	3521	3521	11.3	11.3	2112	0	0	0	0	0	0	0.6000	2112
MAR	2730	2730	10.7	10.7	1638	0	0	0	0	0	0	0.6000	1638
APR	1385	1385	6.8	6.8	831	0	0	0	0	0	0	0.6000	831
MAY	891	891	4.5	4.5	535	0	0	0	0	0	0	0.6000	535
JUN	962	962	4.7	4.7	577	0	0	0	0	0	0	0.6000	577
JUL	1420	1420	6.0	6.0	852	0	0	0	0	0	0	0.6000	852
AUG	1157	1157	5.2	5.2	694	0	0	0	0	0	0	0.6000	694
SEP	806	806	4.2	4.2	484	0	0	0	0	0	0	0.6000	484
OCT	1161	1161	6.0	6.0	697	0	0	0	0	0	0	0.6000	697
NOV	2317	2317	7.8	7.8	1390	0	0	0	0	0	0	0.6000	1390
DEC	3455	3455	9.2	9.2	2073	0	0	0	0	0	0	0.6000	2073
TOTAL	23971	23971	12.8		14382	0	0	0	0	0		0.6000	14382

Office Building and Open Atrium

LDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993LDL RUN 4

```

*1455 * TITLE LINE-1 * OFFICE BUILDING & OPEN ATRIA *
*1456 * LINE-2 * VAV SYSTEM IN OFFICE & PSZ IN ATRIA *
*1457 * LINE-3 * ICE THERMAL ENERGY STORAGE FOR OFFICE *
*1458 * LINE-4 * STORAGE PRIORITY *
*1459 * LINE-5 * SAMP3.INP RUN 4 * ..
*1460 *
*1461 * ABORT ERRORS ..
*1462 * DIAGNOSTIC WARNINGS ..
*1463 * RUN-PERIOD JUL 4 1986 THRU JUL 11 1986 $ JUL 4TH
*1464 * $ FALLS ON A FRIDAY PROVIDING A 3DAY
*1465 * $ HOLIDAY WEEKEND
*1466 * JAN 1 1986 THRU JAN 5 1986
*1467 * JAN 1 1986 THRU DEC 31 1986 ..
*1468 * BUILDING-LOCATION LATITUDE=42 LONGITUDE=88
*1469 * TIME-ZONE=6 ALTITUDE=610 ..
*1470 *
*1471 * LOADS-REPORT SUMMARY=(LS-D) ..
*1472 *
*1473 * $ BUILDING DESCRIPTION
*1474 *
*1475 * $ STRUCTURE REINFORCED CONCRETE CONSTRUCTION WITH 4IN CONCRETE FLOORS AND ROOF
*1476 * $ 10FT FLOOR TO FLOOR HEIGHT, TWO STORIES HIGH. RETURN AIR PLENUMS
*1477 * $ ARE NOT DEFINED.
*1478 *
*1479 * $ WALLS USING CODE WORDS FROM THE DOE-2 LIBRARY (REFERENCE MANUAL PART 2)
*1480 * $ AND STARTING WITH THE OUTSIDE SURFACE AND MOVING INWARD:
*1481 * $ 2IN PRECAST CONCRETE PANEL (CC03); 2IN POLYSTYRENE INSULATION
*1482 * $ R-8 (IN35); 3IN AIRSPACE (AL21); 5/8IN GYPSUM BOARD (GP04);
*1483 * $ 3/4IN FINISH PLASTER.
*1484 *
*1485 * $ ATRIUM ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
*1486 * $ 6IN CONCRETE (CC04); INSIDE FILM RESISTANCE .76
*1487 *
*1488 * $ OFFICE ROOF BUILT-UP ROOFING (BR01); 3IN ROOF INSULATION R-8 (IN76);
*1489 * $ 2 FT AIR SPACE (AL33); 3/4IN LAY-IN ACCOUSTIC TILE (AC03);
*1490 * $ INSIDE-FILM-RESISTANCE .76.
*1491 *
*1492 * $ FLOORS FIRST FL IS SLAB-ON-GRADE EFFECTIVE U-VALUE OF ENTIRE AREA .05.
*1493 *
*1494 * $ WINDOWS OFFICE AREA 4FT HIGH AND FULL WIDTH OF EACH WALL, EXCEPT SOUTH
*1495 * $ WALL WHERE THERE ARE NO WINDOWS. GLASS IS DOUBLE PANE TINTED
*1496 * $ WITH A SOLAR TRANSMITTANCE OF .53. WINDOWS HAVE INSIDE DRAPES
*1497 * $ THAT HAVE A PROBABILITY OF .7 OF BEING PULLED WHEN TRANSMITTED
*1498 * $ DIRECT RADIATION IS GREATER THAN 40 BTUH. DRAPES ARE THEN REOPEN-
*1499 * $ ED WITH A PROBABILITY OF .2 WHENEVER SOLAR DROPS BELOW 40BTUH.
*1500 * $ ATRIUM GLASS IS THE SAME AS OFFICE GLASS EXCEPT THAT IT DOES NOT
*1501 * $ HAVE DRAPES. THERE ARE TWO MAIN SECTIONS OF GLASS 29' WIDE BY
*1502 * $ 30' HIGH WITH OVERHANGS AND SIDE FINS. NOTICE THAT THE SKETCH
*1503 * $ OF THE BUILDING INDICATES A LARGE OVERHANG WHICH WOULD BE VERY
*1504 * $ DIFFICULT TO BUILD. THIS WAS THE WAY IT WAS SIMULATED AS THIS
*1505 * $ METHOD IS EQUIVALENT TO MULTIPLE SURFACES THAT PROVIDE THE SAME
*1506 * $ SHADING GEOMETRY.
*1507 *
*1508 * $ INTERIORS CEILINGS ARE SIMULATED AS PART OF THE ROOF STRUCTURE ON THE TOP
*1509 * $ FLOOR. PARTITIONS SIMULATE A GLASS WALL BETWEEN ATRIUM AND
*1510 * $ OFFICE SPACES, BUT WALLS BETWEEN INTERIOR AND EXTERIOR OFFICES
*1511 * $ ARE NOT DEFINED. WALLS BETWEEN THE EQUIPMENT ROOM AND OFFICES

```



```

*1512 * $           HAVE A U-VALUE OF .28.
*1513 *
*1514 * $ SPACE LOADS LIGHTING IS RECESSED FLUORSCENT NON VENTED AT 1.5 WATTS/SQFT
*1515 * $           IN THE OFFICES AND 1 WATT/SQFT IN THE ATRIUM.
*1516 * $           PEOPLE IN OFFICES IS INPUT AT 150SQFT/PERSON.
*1517 * $           PEOPLE IN ATRIUM ARE SIX.
*1518 * $           INFILTRATION IS SET AT 1 AIRCHANGES/HR WHEN FANS ARE OFF AND AT
*1519 * $           .1 AIRCHANGE WHEN FANS ARE ON.
*1520 * $           EQUIPMENT IN OFFICES IS SET AT 1 WATTS/SQFT.
*1521 *
*1522 * $ CHICAGO DESIGN DAY - WORST CASE FOR TES SYSTEM - JULY 4TH WEEKEND THAT SPANS
*1523 * $           A 7 DAY HOT SPELL - HEAVY SMOG - 10F DROP IN TEMPERATURE AT NIGHT
*1524 * $           WHICH COMPARES TO 20F NORMALLY AND MINIMIZES RELEASE OF HEAT BY
*1525 * $           CONVECTION AND RERADIATION.
*1526 *
*1527 *   HOT-SMOG-SUMMER = DESIGN-DAY
*1528 *   DRYBULB-HI   = 98   DRYBULB-LO = 86
*1529 *   HOUR-HI     = 15   HOUR-LO   = 7
*1530 *   DEWPT-HI    = 65.5 DEWPT-LO  = 60
*1531 *   DHOUR-HI     = 16   DHOUR-LO  = 8
*1532 *   WIND-SPEED  = 7.5   WIND-DIR  = 10
*1533 *   CLOUD-AMOUNT = 0     CLOUD-TYPE = 0
*1534 *   CLEARNESS   = 1     GROUND-T   = 61 ..
*1535 *
*1536 *   COLD-CLOUDY-WINTER = DESIGN-DAY
*1537 *   DRYBULB-HI   = 6     DRYBULB-LO = -4
*1538 *   HOUR-HI     = 15   HOUR-LO   = 2
*1539 *   DEWPT-HI    = 6     DEWPT-LO  = -4
*1540 *   DHOUR-HI     = 16   DHOUR-LO  = 3
*1541 *   WIND-SPEED  = 15   WIND-DIR  = 14
*1542 *   CLOUD-AMOUNT = 5     CLOUD-TYPE = 2
*1543 *   CLEARNESS   = 1     GROUND-T   = 46 ..
*1544 *
*1545 *
*1546 *           $ CONSTRUCTIONS
*1547 *
*1548 * ROOF-O       =LAYERS           MAT=(BR01,IN76,CC03,AL33,AC03) I-F-R=.76 ..
*1549 * ROOF-A       =LAYERS           MAT=(BR01,IN76,CC04) I-F-R .76 ..
*1550 * OFF-ROF      =CONSTRUCTION    LAYERS ROOF-O ..
*1551 * ATR-ROF      =CONSTRUCTION    LAYERS ROOF-A ..
*1552 * WALL-1       =LAYERS           MAT=(CC33,IN35,AL21,GP04,GP04) ..
*1553 * WL1          =CONSTRUCTION    LAYERS=WALL-1 ..
*1554 * BW1          =CONSTRUCTION    U=.05 ..
*1555 * BW2          =CONSTRUCTION    U=.0001 ..
*1556 * WL2          =CONSTRUCTION    U=1.05 $ ATRIUM GLASS PARTITIONS $ ..
*1557 * WL3          =CONSTRUCTION    U=.28 $ INTERIOR PARTITIONS $ ..
*1558 *
*1559 *           $ GLASS DESCRIPTION
*1560 *
*1561 * GT1          =GLASS-TYPE   GLASS-TYPE-CODE 5 PANES 2 ..
*1562 * GT2          =GLASS-TYPE   G-T-C 5 PANES 2 ..
*1563 *
*1564 *           $ SCHEDULES
*1565 *
*1566 * OC1          =DAY-SCHEDULE   (1,9) (0) (10,12) (1) (13,14) (.8)
*1567 *              (15,18) (.9) (19,24) (.1) ..
*1568 * OC2          =DAY-SCHEDULE   (1,24) (.1) ..
*1569 * OCCUP       =SCHEDULE     THRU DEC 31 (WD) OC1 (WEH) OC2 ..
*1570 *
*1571 * L1           =DAY-SCHEDULE   (1,6) (.05) (7,12) (.9) (13,14) (.8)
*1572 *              (15,18) (.9) (19,21) (.2) (22,24) (.05) ..
*1573 * L2           =DAY-SCHEDULE   (1,24) (.05) ..
*1574 * LT1         =SCHEDULE     THRU DEC 31 (WD) L1 (WEH) L2 ..
*1575 *
*1576 * ES1         =DAY-SCHEDULE   (1,9) (0) (10,21) (.9) (22,24) (0) ..

```

```

*1577 * ES2          =DAY-SCHEDULE      (1,24) (0) ..
*1578 * EQ1          =SCHEDULE          THRU DEC 31 (WD) ES1 (WEH) ES2 ..
*1579 *
*1580 * I1           =DAY-SCHEDULE      (1,9) (1) (10,21) (.1) (22,24) (1) ..
*1581 * I2           =DAY-SCHEDULE      (1,24) (1) ..
*1582 * INFIL        =SCHEDULE          THRU DEC 31 (WD) I1 (WEH) I2 ..
*1583 *
*1584 *
*1585 * SHADE-MULT    =SCHEDULE          THRU DEC 31 (ALL) (1,24) (.6) ..
*1586 * COND-MULT    =SCHEDULE          THRU DEC 31 (ALL) (1,24) (.90) ..
*1587 * CLOSE-SHADE  =SCHEDULE          THRU DEC 31 (ALL) (1,24) (40) ..
*1588 * REOPEN-PROB  =SCHEDULE          THRU DEC 31 (ALL) (1,24) (.2) ..
*1589 *
*1590 *
*1591 *
*1592 *
*1593 *
*1594 *
*1595 *
*1596 *
*1597 *
*1598 *
*1599 *
*1600 *
*1601 *
*1602 *
*1603 * OFFICE       =SPACE-CONDITIONS  TEMPERATURE=(74) FLOOR-WEIGHT=70
*1604 *
*1605 *
*1606 *
*1607 *
*1608 *
*1609 *
*1610 *
*1611 * ATRIUM      =SPACE-CONDITIONS  TEMPERATURE=(74) FLOOR-WEIGHT=100
*1612 *
*1613 *
*1614 *
*1615 *
*1616 *
*1617 *
*1618 *
*1619 *
*1620 *
*1621 * BZ1         =SPACE              S-C=OFFICE AREA=3230 VOLUME=29070
*1622 *
*1623 *
*1624 * E1          =EXTERIOR-WALL      WIDTH=200 ..
*1625 * W1          =WINDOW              WIDTH=200 ..
*1626 *
*1627 * E1S         =EXTERIOR-WALL      W=17 AZ=90 X=200 ..
*1628 *
*1629 *
*1630 *
*1631 * BZ2         =SPACE              S-C=OFFICE AREA=1660 VOLUME=14940
*1632 *
*1633 *
*1634 * E2          =EXTERIOR-WALL      WIDTH=100 ..
*1635 * W2          =WINDOW              WIDTH=100 ..
*1636 *
*1637 *
*1638 *
*1639 * BZ3         =SPACE              LIKE BZ1 AZ=-90 X=100 Y=0 ..
*1640 *
*1641 * E3          =EXTERIOR-WALL      LIKE E1 ..

```

\$ SET DEFAULTS

```

SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=10 AZIMUTH=180
CONSTRUCTION=W1 ..
SET-DEFAULT FOR WINDOW HEIGHT=4 Y=4 GLASS-TYPE=GT1
MAX-SOLAR-SCH=CLOSE-SHADE SUN-CTRL-PROB .7
WIN-SHADE-TYPE=MOVABLE-INTERIOR
SHADING-SCHEDULE=SHADE-MULT
CONDUCT-SCHEDULE=COND-MULT
OPEN-SHADE-SCH=REOPEN-PROB ..

```

\$ SPACE DESCRIPTION

*1642 * W3	=WINDOW	LIKE W1 ..
*1643 *		
*1644 * E3S	=EXTERIOR-WALL	W=17 AZ=270 Y=17 ..
*1645 *		
*1646 *	UNDERGROUND-FLOOR	AREA=3230 CONS=BW1 ..
*1647 *		
*1648 * TZ1	=SPACE	LIKE BZ1 Z=10 ..
*1649 *		
*1650 * R1	=ROOF	H=17 W=200 AZ=180 TILT=0 Z=10
*1651 *		CONS=OFF-ROF ..
*1652 *		
*1653 *	EXTERIOR-WALL	LIKE E1 ..
*1654 *	WINDOW	LIKE W1 ..
*1655 *		
*1656 *	EXTERIOR-WALL	LIKE E1S ..
*1657 *		
*1658 * TZ2	=SPACE	LIKE BZ2 Z=10 ..
*1659 *		
*1660 *	ROOF	LIKE R1 H=20 W=83 ..
*1661 *		
*1662 *	EXTERIOR-WALL	LIKE E2 ..
*1663 *	WINDOW	LIKE W2 ..
*1664 *		
*1665 *		
*1666 * TZ3	=SPACE	LIKE BZ3 Z=10 ..
*1667 *	ROOF	LIKE R1 H=17 W=180 ..
*1668 *	EXTERIOR-WALL	LIKE E3 ..
*1669 *	WINDOW	LIKE W3 ..
*1670 *	EXTERIOR-WALL	LIKE E3S ..
*1671 *		
*1672 * IZ1	=SPACE	S-C=OFFICE AREA=3540 VOLUME=70800
*1673 *		AZ=90 X=17 Y=180 ..
*1674 *		
*1675 * IN1	=INTERIOR-WALL	AREA=1200 NEXT-TO ATZ1 CONS=WL2 ..
*1676 * IN2	=INTERIOR-WALL	AREA=1200 NEXT-TO ATZ2 CONS=WL2 ..
*1677 * IN3	=INTERIOR-WALL	AREA=586 NEXT-TO EQUIP-RM CONS=WL3 ..
*1678 *	ROOF	LIKE R1 H=18 W=180 Z=20 ..
*1679 *	ROOF	LIKE R1 H=15 W=20 Y=18 Z=20 ..
*1680 *	EXTERIOR-WALL	H=20 W=18 AZ=90 X=180 ..
*1681 *	UNDERGROUND-FLOOR	AREA=3540 CONS=BW1 ..
*1682 *		
*1683 * IZ2	=SPACE	LIKE IZ1 AZ=-90 X=83 Y=0 ..
*1684 *		
*1685 *	INTERIOR-WALL	LIKE IN1 NEXT-TO ATZ1 ..
*1686 *	INTERIOR-WALL	LIKE IN2 NEXT-TO ATZ2 ..
*1687 *	INTERIOR-WALL	LIKE IN3 ..
*1688 *	EXTERIOR-WALL	H=20 W=18 AZ=270 Y=18 ..
*1689 *	ROOF	LIKE R1 H=18 W=180 Z=20 ..
*1690 *	ROOF	LIKE R1 H=15 W=20 X=160 Y=18 Z=20 ..
*1691 *	UNDERGROUND-FLOOR	AREA=3540 CONS=BW1 ..
*1692 *		
*1693 * ATZ1	=SPACE	S-C=ATRIUM AREA=1800 VOLUME=16200
*1694 *		X=35 Y=40 ..
*1695 *		
*1696 * ATROOF-1	=ROOF	HEIGHT=66.6 WIDTH=30
*1697 *		AZIMUTH=0 TILT=26 X=30 Y=60 Z=20
*1698 *		CONS=ATR-ROF ..
*1699 * E4	=EXTERIOR-WALL	H=14.5 W=60 AZ=270 Y=60 Z=20 ..
*1700 * E5	=EXTERIOR-WALL	LIKE E4 AZ=90 X=30 Y=0 ..
*1701 * F1	=UNDERGROUND-FLOOR	AREA=1800 CONS=BW2 ..
*1702 * FRAME-A	=EXTERIOR-WALL	HEIGHT=29 WIDTH=30 Z=20 ..
*1703 * WINDOW-A	=WINDOW	H=28.9 W=29.9 X=.05 Y=.05 GLASS-TYPE=GT2
*1704 *		OVERHANG-A=6 OH-B=0 OH-D=48.5 OH-W=42
*1705 *		OVERHANG-ANGLE=116 LEFT-FIN-A=0 L-F-B=0
*1706 *		L-F-H=30 L-F-D=3 RIGHT-FIN-A=0 R-F-B=0

```

*1707 *
*1708 *      EXTERIOR-WALL      R-F-H=30 R-F-D=3 ..
*1709 *      WINDOW          LIKE FRAME-A HEIGHT=10.7 W=30 Z=9.3 ..
*1710 *                               LIKE WINDOW-A H=10.6 W=29.9 L-F-H=10.7
*1711 *                               R-F-H=10.7 ..
*1712 * ATZ2                =SPACE          LIKE ATZ1  SOURCE-BTU/HR=0.0 Y=100 ..
*1713 *
*1714 * ATROOF-2           =ROOF           LIKE ATROOF-1 ..
*1715 *      EXTERIOR-WALL      LIKE E4 ..
*1716 *      EXTERIOR-WALL      LIKE E5 ..
*1717 *      UNDERGROUND-FLOOR  LIKE F1 ..
*1718 * FRAME-B            =EXTERIOR-WALL  LIKE FRAME-A ..
*1719 * WINDOW-B           =WINDOW        LIKE WINDOW-A ..
*1720 *
*1721 * EQUIP-RM            =SPACE          ZONE-TYPE=UNCONDITIONED
*1722 *                               AREA=1200 VOLUME=17580 X=35 ..
*1723 *
*1724 *      EXTERIOR-WALL      HEIGHT=20 WIDTH=30 ..
*1725 *
*1726 *      ROOF              H=41.2 W=30 CONS=OFF-ROF
*1727 *                               TILT=15 Z=9.3 X=30 Y=40 AZIMUTH=0 ..
*1728 *
*1729 *      INTERIOR-WALL      AREA=279 CONS=WL3 NEXT-TO ATZ1 ..
*1730 *      UNDERGROUND-FLOOR  AREA=1200 CONS=BW1 ..
*1731 *
*1732 *
*1733 * END ..
*1734 * COMPUTE LOADS ..
*1735 * INPUT SYSTEMS ..

```

SDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993SDL RUN 4

```

*1736 * SYSTEMS-REPORT SUMMARY (SS-D,SS-A,SS-J) ..
*1737 *
*1738 *           $ ALL ELECTRIC HVAC SYSTEMS DESCRIPTION
*1739 *
*1740 * $ DESIGN TEMPS ATRIUM COOLING 80F-SUMMER, 68F-WINTER HEATING SETBACK 65F
*1741 * $ OFFICE COOLING 76F HEATING 72F
*1742 *
*1743 * $ SYSTEM TYPE THE OFFICE IS SERVED BY A VAVS SYSTEM WITH THE BASEBOARD
*1744 * $ THERMOSTATICALLY CONTROLLED AND HAS AN DRYBULB ECONOMIZER
*1745 * $ WITH A 68F DRYBULB-LIMIT. THIS SYSTEM OPERATES FROM 7AM
*1746 * $ TO 6PM ON WEEKDAYS DURING SPRING, FALL, AND WINTER. HOWEVER,
*1747 * $ IN SUMMER IT OPERATES ON SUNDAY AFTERNOON TO MITIGATE THE
*1748 * $ MONDAY MORNING STARTUP LOAD, ESPECIALLY AFTER A HOT WEEKEND.
*1749 *
*1750 * $ THE OPEN ATRIA IS SERVED BY 1 PKG VARIABLE TEMPERATURE -
*1751 * $ CONSTANT VOLUME SYSTEM (PSZ) WITH AIR/AIR HEAT PUMP. THE
*1752 * $ PSZ SYSTEM HAS AN ECONOMIZER WITH ENTHALPY-LIMIT, PLUS
*1753 * $ A DRYBULB-LIMIT AND AN ECONO-LOCKOUT WHICH PROTECTS
*1754 * $ THE COMPRESSOR FROM BURNOUT ON LOW EVAPORATOR LOADING.
*1755 * $ THE HEAT PUMP DEFROST-TYPE IS REVERSE-CYCLE AND CONTROLLED
*1756 * $ BY ON-DEMAND.
*1757 *
*1758 *           $ AIR HANDLING UNIT SCHEDULES
*1759 *
*1760 * NORM-DAYS = WEEK-SCHEDULE (WD) (1,5)(0)(6,7)(-999)(8,21)(1)(22,24)(0)
*1761 * (WEH) (1,24)(0) ..
*1762 * PSZ-SCHED = SCHEDULE THRU DEC 31 NORM-DAYS ..
*1763 *
*1764 * SUMM-DAYS = WEEK-SCHEDULE (WD) (1,7)(0)(8,18)(1)(19,24)(0)
*1765 * (SAT) (1,24)(0)
*1766 * (SUN) (1,14)(0)(15,18)(1)(19,24)(0)
*1767 * (HOL) (1,24)(0) ..
*1768 *
*1769 * VAVS-SCHED = SCHEDULE THRU MAY 15 NORM-DAYS
*1770 * THRU OCT 20 SUMM-DAYS
*1771 * THRU DEC 31 NORM-DAYS ..
*1772 *
*1773 * NORM-OA = WEEK-SCHEDULE (WD) (1,7)(0)(8,21)(-999)(22,24)(0)
*1774 * (WEH) (1,24)(0) ..
*1775 *
*1776 * SUMM-OA = WEEK-SCHEDULE (WD) (1,7)(0)(8,18)(-999)(19,24)(0)
*1777 * (SAT) (1,24)(0)
*1778 * (SUN) (1,15)(0)(16,19)(-999)(20,24)(0)
*1779 * (HOL) (1,24)(0) ..
*1780 *
*1781 * MIN-OA = SCHEDULE THRU MAY 15 NORM-OA
*1782 * THRU OCT 20 SUMM-OA
*1783 * THRU DEC 31 NORM-OA ..
*1784 *
*1785 *
*1786 *           $ HEATING THERMOSTAT SCHEDULE
*1787 *
*1788 * THEAT1 = SCHEDULE THRU DEC 31 (WD) (1,7)(60)(8,9)(64)(10,21)(68)(22,24)(60)
*1789 * (WEH) (1,24)(60) ..
*1790 *
*1791 * THEAT2 = SCHEDULE THRU DEC 31 (ALL) (1,24)(72) ..
*1792 *

```

```

*1793 *           $ COOLING THERMOSTAT SCHEDULES
*1794 *
*1795 * TCOOL1   = SCHEDULE THRU DEC 31 (WD) (1,7) (90) (8,21) (80) (22,24) (90)
*1796 *           (WEH) (1,24) (90) ..
*1797 *
*1798 * TCOOL2   = SCHEDULE THRU DEC 31 (ALL) (1,24) (76) ..
*1799 *
*1800 *
*1801 *           $ ZONE DESCRIPTION
*1802 *
*1803 * ENV-ATR   = ZONE-CONTROL DESIGN-HEAT-T=68 DESIGN-COOL-T=74
*1804 *           HEAT-TEMP-SCH=THEAT1 COOL-TEMP-SCH=TCOOL2
*1805 *           T-TYPE PROPORTIONAL ..
*1806 *
*1807 * ENV-OFF   = ZONE-CONTROL DESIGN-HEAT-T=72 DESIGN-COOL-T=74
*1808 *           HEAT-TEMP-SCH=THEAT1 COOL-TEMP-SCH=TCOOL1
*1809 *           T-TYPE=REVERSE-ACTION
*1810 *           BASEBOARD-CTRL=THERMOSTATIC ..
*1811 *
*1812 * ATZ1     = ZONE           Z-C ENV-ATR  OUTSIDE-AIR-CFM 250 ..
*1813 *
*1814 * ATZ2     = ZONE           Z-C ENV-ATR  OUTSIDE-AIR-CFM 250 ..
*1815 *
*1816 * EQUIP-RM = ZONE           ZONE-TYPE=UNCONDITIONED ..
*1817 *
*1818 * BZ1       = ZONE           Z-C ENV-OFF  OA-CFM/PER=15 B-R=-90000 ..
*1819 * BZ2       = ZONE LIKE BZ1 B-R=-37000 ..
*1820 * BZ3       = ZONE LIKE BZ1 B-R=-100000 ..
*1821 * TZ1      = ZONE LIKE BZ1 B-R=-94000 ..
*1822 * TZ2      = ZONE LIKE BZ1 B-R=-40000 ..
*1823 * TZ3      = ZONE LIKE BZ1 B-R=-104000 ..
*1824 * IZ1      = ZONE LIKE BZ1 B-R=-54000 ..
*1825 * IZ2      = ZONE LIKE BZ1 B-R=-54000 ..
*1826 *
*1827 * FS-SYS1   = SYSTEM        SYSTEM-TYPE=PS2 MAX-S-T=100 MIN-S-T=55
*1828 *           SUPPLY-STATIC=3 SUPPLY-EFF=.45 ECONO-LOCKOUT=YES
*1829 *           ENTHALPY-LIMIT=25 DRYBULB-LIMIT=74
*1830 *           HEAT-SOURCE=HEAT-PUMP
*1831 *           FAN-SCHEDULE=PS2-SCHED
*1832 *           MIN-AIR-SCH =MIN-OA
*1833 *           DEFROST-TYPE=REVERSE-CYCLE
*1834 *           DEFROST-CTRL=ON-DEMAND
*1835 *           ZONE-NAMES = (ATZ1,ATZ2,EQUIP-RM) ..
*1836 *
*1837 * OFF-SYS   = SYSTEM        SYSTEM-TYPE=VAVS MAX-S-T=120 MIN-S-T=60
*1838 *           SUPPLY-STATIC=5 SUPPLY-EFF=.55 ECONO-LIMIT-T=68
*1839 *           FAN-SCHEDULE=VAVS-SCHED MIN-CFM-RATIO=.3
*1840 *           FAN-CONTROL=SPEED HEAT-SET-T=100
*1841 *           RETURN-AIR-PATH=DUCT OA-CONTROL=TEMP
*1842 *           N-C-C=STAY-OFF REHEAT-DELTA-T=55
*1843 *           ZONE-HEAT-SOURCE=ELECTRIC
*1844 *           PREHEAT-SOURCE=ELECTRIC HEAT-SOURCE=ELECTRIC
*1845 *           MIN-AIR-SCH=MIN-OA BASEBOARD-SOURCE=ELECTRIC
*1846 *           ZONE-NAMES=(BZ1,BZ2,BZ3,TZ1,TZ2,TZ3,IZ1,IZ2) ..
*1847 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (FS-SYS1,OFF-SYS)
*1848 *           DHW-SIZE      = 0
*1849 *           DHW-GAL/MIN = .888
*1850 *           DHW-SCH     = DOMHW ..
*1851 *
*1852 * D1 = D-SCH (1,7) (0) (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.4,.3,.3)
*1853 *           (22,24) (0) ..
*1854 * D2 = D-SCH (1,7) (0) (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.4,.35,
*1855 *           .25,.2) (23,24) (0) ..
*1856 * D3 = D-SCH (1,9) (0) (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
*1857 *           (20,24) (0) ..

```

*1858 * DOMMW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
*1859 * END ..
*1860 * COMPUTE SYSTEMS ..
*1861 * INPUT PLANT ..

PDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993PDL RUN 4

```

*1862 * PLANT1 = PLANT-ASSIGNMENT ..
*1863 * PLANT-REPORT SUMMARY=(PS-A,PS-B,PS-C,PS-G,BEPS) ..
*1864 *
*1865 * $ EQUIPMENT DESCRIPTION
*1866 *
*1867 *
*1868 * $ THIS PLANT IS AN ICE STORAGE PLANT WITH A SINGLE RECIPROCATING
*1869 * $ COMPRESSOR WHICH CAN MAKE ICE AT NIGHT BUT OPERATES DURING THE DAY
*1870 * $ AT NORMAL EVAPORATOR TEMPERATURES. THE COMPRESSOR'S RATED CAPACITY
*1871 * $ IS AUTOMATICALLY SIZED BY THE PROGRAM AS WELL AS THE STORAGE CAPACITY
*1872 * $ (WHICH IS IN MBTU - NOT TON HOURS). THE TES SYSTEM IS STORAGE PRIORITY
*1873 * $ AND THE TANK IS SIZED TO HOLD 65% OF THE PEAK DAILY INTEGRATED LOAD
*1874 * $ BASED ON THE RESULTS OF THE WEATHER TAPE RUN.
*1875 *
*1876 * ICEM =PLANT-EQUIPMENT TYPE=OPEN-REC-CHLR SIZE=-999 1-N=1 ..
*1877 *
*1878 * DHWH =PLANT-EQUIPMENT TYPE=ELEC-DHW-HEATER SIZE -999 ..
*1879 *
*1880 * CTANK =PLANT-EQUIPMENT TYPE=CTANK-STORAGE SIZE=-999 1-N=1 ..
*1881 *
*1882 * ENERGY-STORAGE COOL-STORE-RATE=-999
*1883 * COOL-SUPPLY-RATE=-999
*1884 * COOL-STORE-SCH=TANK-CHG
*1885 * CTANK-LOSS-COEF=100
*1886 * CTANK-BASE-T=44
*1887 * CTANK-T-RANGE=10 ..
*1888 *
*1889 * PLANT-PARAMETERS TES-TYPE = BRINE $ TO SIMULATE A REACTOL FLUID
*1890 * HOURS-CHARGING = 13
*1891 * HOURS-DISCHARGING = 11
*1892 * PERCENT-STORED = 65
*1893 * TES-PRIORITY = STORAGE
*1894 * COMP-MODE-DCHG = RATED-T
*1895 * COMP-KW/TON-START = .96
*1896 * REFRIG-T-AT-PC = 20
*1897 * TWR-CAP-CTRL = TWO-SPEED
*1898 * TWR-PUMP-HEAD = 20
*1899 * PLANT-SIZING-BY = WEATHER ..
*1900 *
*1901 * TANK-CHG=SCHEDULE THRU JUN 1 (ALL) (1,24) (0)
*1902 * THRU SEP 1 (ALL) (1,7) (1) (8,18) (0) (19,24) (1)
*1903 * THRU DEC 31 (ALL) (1,24) (0) ..
*1904 *
*1905 * TANK-CHARGE LOAD-ASSIGNMENT TYPE=COOLING
*1906 * LOAD-RANGE=99
*1907 * PLANT-EQUIPMENT=ICEM NUMBER=1 ..
*1908 *
*1909 * RELEASE-CHG LOAD-ASSIGNMENT TYPE=COOLING
*1910 * LOAD-RANGE=99
*1911 * PLANT-EQUIPMENT=CTANK NUMBER=1
*1912 * PLANT-EQUIPMENT=ICEM NUMBER=1 ..
*1913 *
*1914 * NO-STORAGE LOAD-ASSIGNMENT TYPE=COOLING
*1915 * LOAD-RANGE=99
*1916 * PLANT-EQUIPMENT=ICEM NUMBER=1 ..
*1917 *
*1918 * CHW-CTRL =DAY-ASSIGN-SCH (1,7) (TANK-CHARGE)

```



```

*1919 *                (8,18) (RELEASE-CHG)
*1920 *                (19,24) (TANK-CHARGE) ..
*1921 *
*1922 * WEH-CTRL =DAY-ASSIGN-SCH (1,14) (TANK-CHARGE)
*1923 *                (15,18) (RELEASE-CHG)
*1924 *                (19,24) (TANK-CHARGE) ..
*1925 *
*1926 * STD-OPER =DAY-ASSIGN-SCH (1,24) (NO-STORAGE) ..
*1927 *
*1928 * CHILLER-CTRL=SCHEDULE THRU JUN 1 (ALL) STD-OPER
*1929 *                THRU OCT 1 (WD) CHW-CTRL (WEH) WEH-CTRL
*1930 *                THRU DEC 31 (ALL) STD-OPER ..
*1931 *
*1932 * LOAD-MANAGEMENT PRED-LOAD-RANGE=999
*1933 *                ASSIGN-SCHEDULE=(DEFAULT,CHILLER-CTRL,DEFAULT) ..
*1934 *
*1935 * $                HOURLY-REPORT INPUT
*1936 *
*1937 * R-SCHED=SCHEDULE THRU JUL 12 (ALL) (1,24) (0)
*1938 *                THRU JUL 15 (ALL) (1,24) (1)
*1939 *                THRU DEC 31 (ALL) (1,24) (0) ..
*1940 * $
*1941 * RB5 = REPORT-BLOCK VARIABLE-TYPE=OPEN-REC-CHLR
*1942 *                VARIABLE-LIST=(1,8,10,16) ..
*1943 * RB7 = REPORT-BLOCK VARIABLE-TYPE=CTANK-STORAGE
*1944 *                VARIABLE-LIST=(1,4,14) ..
*1945 * REPORT1 = HOURLY-REPORT REPORT-SCHEDULE=R-SCHED
*1946 *                REPORT-BLOCK=(RB5,RB7) ..
*1947 *
*1948 * END ..
*1949 * COMPUTE PLANT ..
*1950 * INPUT ECONOMICS ..

```

EDL PROCESSOR INPUT DATA

Wed Nov 10 15:17:48 1993EDL RUN 4

```

*1951 * DIAGNOSTIC WARNINGS ..
*1952 * ECONOMICS-REPORT SUMMARY (ES-D,ES-E) ..
*1953 *
*1954 *           $ ENERGY CHARGE DESCRIPTION
*1955 *
*1956 * $ THIS ELECTRIC RATE IS A TIME-OF-USE RATE WITH SEPARATE SUMMER/WINTER MINIMUM
*1957 * $ DEMAND CHARGES BUT IN ADDITION HAS S/W DEMAND CHARGES THAT APPLY ONLY TO THE
*1958 * $ ON-PEAK HOURS. THE TWO DEMANDS ARE ADDITIVE, APPLY TO THE HIGHEST PEAK, BUT
*1959 * $ ONLY THE ON-PEAK CARRIES A RATCHET OF 90%. THE ENERGY CHARGES ARE
*1960 * $ DOLLARS/KWH FOR THREE PERIODS (I.E. ON-PEAK, INTERMEDIATE-PEAK, AND OFF-PEAK).
*1961 *
*1962 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
*1963 * MIN-MON-CHGS = (186)
*1964 * DEMAND-CHGS = (2.25,2.25,2.25,2.25,2.58,
*1965 *                2.58,2.58,2.58,2.58,2.25)
*1966 * BLOCK-CHARGES = (SUM-P-DEM,WIN-P-DEM)
*1967 * ENERGY-CHG-SCH = TOU-SCH ..
*1968 *
*1969 * TOU-SCH = SCHEDULE THRU APR 30 (WD) (1,8)(.0324)
*1970 *                (9,12)(.0354)
*1971 *                (13,18)(.0394)
*1972 *                (19,21)(.0354)
*1973 *                (22,24)(.0354)
*1974 *                (WEH)(1,24)(.0354)
*1975 *                THRU OCT 31 (WD) (1,8)(.0374)
*1976 *                (9,12)(.0394)
*1977 *                (13,18)(.0444)
*1978 *                (19,21)(.0394)
*1979 *                (22,24)(.0374)
*1980 *                (WEH)(1,24)(.0374)
*1981 *                THRU DEC 31 (WD) (1,8)(.0324)
*1982 *                (9,12)(.0354)
*1983 *                (13,18)(.0394)
*1984 *                (19,21)(.0354)
*1985 *                (22,24)(.0354)
*1986 *                (WEH)(1,24)(.0354) ..
*1987 *
*1988 * SUM-P-DEM = BLOCK-CHARGE BLOCK-SCH = DEM-SCH
*1989 *                SCH-FLAG = 2
*1990 *                BLOCK1-TYPE = DEMAND
*1991 *                BLOCK1-DATA = (1,7.00)
*1992 *                DEMAND-RATCHETS = (SUM-RATCH) ..
*1993 *
*1994 * WIN-P-DEM = BLOCK-CHARGE BLOCK-SCH = DEM-SCH
*1995 *                SCH-FLAG = 1
*1996 *                BLOCK1-TYPE = DEMAND
*1997 *                BLOCK1-DATA = (1,6.50)
*1998 *                DEMAND-RATCHETS = (SUM-RATCH) ..
*1999 *
*2000 * SUM-RATCH = RATCHET NUM-MONTHS = 12
*2001 *                RATCHET-SCH = DEM-SCH
*2002 *                SCH-FLAG = 2
*2003 *                TYPE = HIGHEST-PEAK
*2004 *                FRACTION = .90 ..
*2005 *
*2006 * DEM-SCH = SCHEDULE THRU APR 30 (WD) (1,12)(0)
*2007 *                (13,18)(1)

```

```
*2008 * (19,24) (0)
*2009 * (WEH) (1,24) (0)
*2010 * THRU OCT 31 (WD) (1,12) (0)
*2011 * (13,18) (2)
*2012 * (19,24) (0)
*2013 * (WEH) (1,24) (0)
*2014 * THRU DEC 31 (WD) (1,12) (0)
*2015 * (13,18) (1)
*2016 * (19,24) (0)
*2017 * (WEH) (1,24) (0) ..
*2018 *
*2019 * END ..
*2020 * COMPUTE ECONOMICS ..
*2021 * STOP ..
```

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.03641	3 16	6.F	6.F	7.843	-43.032	2 6	-2.F	-2.F	-481.413	1542.	55.710
FEB	0.00000				0.000	0.000				0.000	0.	0.000
MAR	0.00000				0.000	0.000				0.000	0.	0.000
APR	0.00000				0.000	0.000				0.000	0.	0.000
MAY	0.00000				0.000	0.000				0.000	0.	0.000
JUN	0.00000				0.000	0.000				0.000	0.	0.000
JUL	58.44080	11 17	98.F	75.F	521.270	0.000				0.000	3645.	55.710
AUG	0.00000				0.000	0.000				0.000	0.	0.000
SEP	0.00000				0.000	0.000				0.000	0.	0.000
OCT	0.00000				0.000	0.000				0.000	0.	0.000
NOV	0.00000				0.000	0.000				0.000	0.	0.000
DEC	0.00000				0.000	0.000				0.000	0.	0.000
TOTAL	58.477					-43.032					5187.	
MAX					521.270					-481.413		55.710

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	7.94325	31 16	30.F	23.F	177.351	-129.777	1 7	-1.F	-1.F	-429.312	15846.	55.710
FEB	9.50615	28 15	52.F	42.F	176.826	-111.003	4 6	7.F	6.F	-379.896	13742.	55.710
MAR	22.15135	3 17	78.F	61.F	265.525	-82.148	24 6	8.F	7.F	-398.359	15191.	55.710
APR	54.60360	28 15	74.F	66.F	333.988	-34.529	8 6	32.F	29.F	-266.356	15799.	55.710
MAY	76.50200	20 15	77.F	68.F	390.407	-16.854	9 5	40.F	38.F	-167.472	15191.	55.710
JUN	112.52828	20 17	91.F	78.F	448.687	-2.786	23 5	52.F	48.F	-80.445	15144.	55.710
JUL	156.99287	9 17	97.F	73.F	470.385	-0.050	23 5	61.F	60.F	-8.847	15846.	55.710
AUG	132.43343	19 17	90.F	71.F	452.372	-0.304	5 5	55.F	54.F	-28.938	15191.	55.710
SEP	78.25076	11 16	86.F	72.F	408.915	-11.132	22 5	35.F	31.F	-158.603	15144.	55.710
OCT	46.67908	10 16	68.F	53.F	302.121	-32.728	20 5	41.F	35.F	-207.489	15846.	55.710
NOV	17.92756	6 15	52.F	43.F	231.861	-78.601	15 6	28.F	26.F	-290.311	13179.	55.710
DEC	8.82741	10 15	41.F	35.F	148.787	-116.382	26 6	15.F	15.F	-342.215	15846.	55.710
TOTAL	724.346					-616.292					181962.	
MAX					470.385					-429.312		55.710

OFFICE BUILDING & OPEN ATRIA
 ICE THERMAL ENERGY STORAGE FOR OFFICE
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

VAV SYSTEM IN OFFICE & PSZ IN ATRIA
 STORAGE PRIORITY

DOE-2.1E-001 Wed Nov 10 15:17:48 1993SDL RUN 4
 SAMP3.INP RUN 4
 WEATHER FILE- TRY CHICAGO

FS-SYS1

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE							
FS-SYS1	PSZ		1.020	4800.0		12.							
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
	4243.	3.255	2.4	0.	0.000	0.0	0.120	139.776	0.673	-135.998	0.36	0.37	-173.352
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	AT21	2289.	0.	0.000	1.000	255.	0.00	0.00	46.97	0.00	-79.11	1.0	
	AT22	1954.	0.	0.000	1.000	255.	0.00	0.00	40.09	0.00	-67.52	1.0	
	EQUIP-RM	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER		FLOOR AREA (SQFT)		MAX PEOPLE						
OFF-SYS	VAVS	1.020		23320.0		155.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	32377.	33.869	3.3	0.	0.000	0.0	0.073	866.688	0.839	-1035.494	0.00	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
BZ1	5815.	0.	0.000	0.300	329.	0.00	0.00	87.93	-345.42	-391.46	1.0	
BZ2	1723.	0.	0.000	0.300	169.	0.00	0.00	26.05	-102.35	-126.32	1.0	
BZ3	5017.	0.	0.000	0.300	329.	0.00	0.00	75.86	-298.01	-360.08	1.0	
TZ1	6078.	0.	0.000	0.300	329.	0.00	0.00	91.90	-361.02	-409.07	1.0	
TZ2	2120.	0.	0.000	0.300	169.	0.00	0.00	32.06	-125.94	-149.91	1.0	
TZ3	6458.	0.	0.000	0.300	329.	0.00	0.00	97.65	-383.63	-438.81	1.0	
I21	2583.	0.	0.000	0.300	361.	0.00	0.00	39.05	-153.40	-187.88	1.0	
I22	2583.	0.	0.000	0.300	361.	0.00	0.00	39.05	-153.40	-187.88	1.0	

----- COOLING -----							----- HEATING -----					----- ELEC -----		
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX		DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX		DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	1.16159	22	7	33.F	32.F	60.873	0.000					0.000	52225.	269.396
FEB	0.74904	27	7	36.F	33.F	57.332	0.000					0.000	41544.	229.415
MAR	1.96008	3	15	76.F	65.F	149.336	0.000					0.000	31667.	235.856
APR	9.87502	28	16	74.F	66.F	250.646	0.000					0.000	20138.	139.090
MAY	19.43415	21	14	85.F	75.F	394.489	0.000					0.000	17821.	87.521
JUN	53.79815	20	18	91.F	78.F	523.800	0.000					0.000	18965.	83.203
JUL	104.17480	14	10	86.F	74.F	700.977	0.000					0.000	22494.	94.172
AUG	80.33379	11	16	88.F	74.F	506.352	0.000					0.000	20519.	83.822
SEP	33.28735	11	17	86.F	72.F	429.160	0.000					0.000	18039.	79.677
OCT	12.85266	30	17	74.F	67.F	190.136	0.000					0.000	19236.	148.039
NOV	0.50577	18	7	36.F	35.F	60.861	0.000					0.000	28055.	177.065
DEC	1.04643	12	7	33.F	33.F	59.792	0.000					0.000	46214.	228.922
TOTAL	319.179						0.000						336899.	
MAX						700.977						0.000		269.396

MAXIMUM DAILY INTEGRATED COOLING LOAD (DES DAY) 10405.387 (KBTU)
 MAXIMUM DAILY INTEGRATED COOLING LOAD (WTH FILE) 7001.286 (KBTU)

OFFICE BUILDING & OPEN ATRIA
 ICE THERMAL ENERGY STORAGE FOR OFFICE
 REPORT- SS-Q HEAT PUMP COOLING SUMMARY FOR PLANT1

VAV SYSTEM IN OFFICE & PSZ IN ATRIA
 STORAGE PRIORITY

DOE-2.1E-001 Wed Nov 10 15:17:48 1993SDL RUN 4
 SAMP3.INP RUN 4
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	0.	0.000	0.000	0.038	0.000	0.000	0.000	0.000	2.091
FEB	0.	0.000	0.000	0.034	0.000	0.000	0.000	0.000	1.708
MAR	0.	0.000	0.000	0.034	0.000	0.000	0.000	0.000	1.958
APR	8.	1.022	0.317	0.020	0.000	0.000	0.000	0.000	2.832
MAY	39.	5.301	1.650	0.011	0.000	0.000	0.000	0.000	3.735
JUN	110.	15.345	4.876	0.000	0.000	0.000	0.000	0.000	5.351
JUL	222.	30.666	10.100	0.000	0.000	0.000	0.000	0.000	8.118
AUG	185.	25.769	8.328	0.000	0.000	0.000	0.000	0.000	6.623
SEP	70.	9.454	3.064	0.004	0.000	0.000	0.000	0.000	4.163
OCT	9.	0.890	0.294	0.020	0.000	0.000	0.000	0.000	2.914
NOV	0.	0.000	0.000	0.033	0.000	0.000	0.000	0.000	1.649
DEC	0.	0.000	0.000	0.036	0.000	0.000	0.000	0.000	1.929
ANNUAL	643.	88.449	28.628	0.230	0.000	0.000	0.000	0.000	43.071

CSPF (WITH PARASITICS) = 1.23 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 3.09 (BTU/BTU)

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	224.	-15.095	9.700	0.041	-104.548	104.548	0.000	0.000	-0.280	5.368
FEB	187.	-12.908	8.084	0.038	-79.102	79.102	0.000	0.000	-0.198	4.685
MAR	112.	-8.836	5.670	0.040	-42.846	42.846	0.000	0.000	-0.109	5.035
APR	22.	-1.858	1.639	0.029	-5.738	5.738	0.000	0.000	-0.034	4.220
MAY	1.	-0.158	0.250	0.016	-0.237	0.237	0.000	0.000	0.000	3.080
JUN	0.	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000	2.808
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	4.474
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	3.235
SEP	0.	-0.006	0.094	0.005	-0.009	0.009	0.000	0.000	-0.002	2.542
OCT	9.	-0.930	0.932	0.025	-3.609	3.609	0.000	0.000	-0.014	3.769
NOV	104.	-8.553	5.183	0.041	-39.418	39.418	0.000	0.000	-0.118	4.270
DEC	247.	-17.471	11.009	0.038	-84.450	84.450	0.000	0.000	-0.367	5.506
ANNUAL	906.	-65.815	42.564	0.274	-359.957	359.957	0.000	0.000	-1.123	48.992

HSPF (WITH PARASITICS) = 1.05 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 1.05 (BTU/BTU)

----- COOLING -----						----- HEATING -----					----- ELEC -----	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-21.459	2 10	5.F	4.F	-165.825	6848.	55.132
FEB	0.00000				0.000	-16.224	24 10	20.F	18.F	-147.473	5183.	43.515
MAR	0.00000				0.000	-9.905	24 10	7.F	5.F	-138.640	3968.	47.166
APR	1.02246	29 16	68.F	63.F	60.729	-1.824	8 10	32.F	28.F	-70.516	2560.	17.327
MAY	5.30144	21 14	85.F	75.F	97.036	-0.158	9 10	43.F	39.F	-36.426	2449.	16.120
JUN	15.34491	20 16	90.F	77.F	129.905	0.000	24 9	57.F	51.F	-0.258	3333.	19.952
JUL	30.66633	14 12	91.F	76.F	134.876	0.000				0.000	4995.	20.528
AUG	25.76921	11 16	88.F	74.F	127.902	0.000				0.000	4386.	19.913
SEP	9.45394	11 15	87.F	72.F	118.094	-0.005	22 8	34.F	31.F	-0.541	2814.	18.704
OCT	0.89038	31 14	76.F	66.F	50.796	-0.916	20 10	42.F	36.F	-64.854	2343.	16.009
NOV	0.00000				0.000	-8.508	14 10	29.F	28.F	-93.171	3221.	25.407
DEC	0.00000				0.000	-18.745	22 10	22.F	22.F	-149.223	5764.	45.257
TOTAL	88.449					-77.743					47862.	
MAX					134.876					-165.825		55.132

HOUR	COOLING				HEATING			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY-BULB TEMP	WET-BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY-BULB TEMP	WET-BULB TEMP
	JUL 7				JAN 2			JUL 7			
1	0.000	0.000	89.F	70.F	0.000	-4.F	-4.F	0.000	0.000	89.F	70.F
2	0.000	0.000	88.F	70.F	0.000	-4.F	-4.F	0.000	0.000	88.F	70.F
3	0.000	0.000	87.F	69.F	0.000	-4.F	-4.F	0.000	0.000	87.F	69.F
4	0.000	0.000	87.F	69.F	0.000	-4.F	-4.F	0.000	0.000	87.F	69.F
5	123.831 *	0.998	86.F	68.F	0.000	-3.F	-3.F	123.831 *	0.998	86.F	68.F
6	118.760 *	0.996	86.F	68.F	-151.031	-2.F	-2.F	118.760 *	0.996	86.F	68.F
7	131.640 *	0.952	86.F	68.F	-165.150	-1.F	-1.F	131.640 *	0.952	86.F	68.F
8	128.995 *	0.948	86.F	68.F	-170.566	0.F	0.F	128.995 *	0.948	86.F	68.F
9	132.718 *	0.926	87.F	69.F	-164.103	1.F	1.F	132.718 *	0.926	87.F	69.F
10	135.400 *	0.922	89.F	69.F	-162.829	2.F	2.F	135.400 *	0.922	89.F	69.F
11	136.128 *	0.917	92.F	71.F	-150.740	3.F	3.F	136.128 *	0.917	92.F	71.F
12	135.450 *	0.915	94.F	72.F	-134.592	4.F	4.F	135.450 *	0.915	94.F	72.F
13	135.096 *	0.910	96.F	73.F	-110.465	5.F	5.F	135.096 *	0.910	96.F	73.F
14	134.813 *	0.903	97.F	74.F	-99.900	5.F	5.F	134.813 *	0.903	97.F	74.F
15	133.828 *	0.899	98.F	74.F	-97.127	6.F	6.F	133.828 *	0.899	98.F	74.F
16	132.562 *	0.898	97.F	74.F	-101.290	5.F	5.F	132.562 *	0.898	97.F	74.F
17	131.434 *	0.898	97.F	74.F	-111.211	5.F	5.F	131.434 *	0.898	97.F	74.F
18	111.545 *	0.996	97.F	74.F	-113.314	4.F	4.F	111.545 *	0.996	97.F	74.F
19	119.696 *	0.996	96.F	74.F	-119.721	3.F	3.F	119.696 *	0.996	96.F	74.F
20	123.418 *	0.996	95.F	73.F	-122.178	1.F	2.F	123.418 *	0.996	95.F	73.F
21	0.000	0.000	94.F	73.F	-124.294	0.F	0.F	0.000	0.000	94.F	73.F
22	0.000	0.000	93.F	72.F	0.000	-1.F	-1.F	0.000	0.000	93.F	72.F
23	0.000	0.000	92.F	71.F	0.000	-3.F	-2.F	0.000	0.000	92.F	71.F
24	0.000	0.000	90.F	71.F	0.000	-4.F	-3.F	0.000	0.000	90.F	71.F
SUM								2065.312			
MAX	136.128				-170.566						

SYSTEM-TYPE PSZ SQFT/TON 423.1
 COOLING PEAK 28.36 (BTU/HR- SQFT) HEATING PEAK -35.53 (BTU/HR- SQFT)
 SUPPLY AIR PEAK FLOW 0.88 (CFM/SQFT) MIN-OA/PERSON 42.50 (CFM)
 OA FRAC AT CLG PEAK 0.120 OA FRAC AT HTG PEAK 0.120

* ASTERISKS INDICATE HOURS LOADS NOT MET

HOUR	- - - - - COOLING - - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	JUL 14				JAN 2			JUL 14			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	83.F	72.F	0.000	1.F	0.F	0.000	0.000	83.F	72.F
2	0.000	0.000	81.F	72.F	0.000	1.F	0.F	0.000	0.000	81.F	72.F
3	0.000	0.000	80.F	71.F	0.000	1.F	0.F	0.000	0.000	80.F	71.F
4	0.000	0.000	78.F	71.F	0.000	2.F	1.F	0.000	0.000	78.F	71.F
5	0.000	0.000	77.F	70.F	0.000	2.F	1.F	0.000	0.000	77.F	70.F
6	109.579 *	0.989	78.F	71.F	0.000	2.F	1.F	109.579 *	0.989	78.F	71.F
7	128.128 *	0.860	79.F	71.F	-143.108	3.F	2.F	128.128 *	0.860	79.F	71.F
8	127.680	0.858	82.F	72.F	-144.668	4.F	3.F	127.680	0.858	82.F	72.F
9	130.021	0.836	86.F	74.F	-137.546	4.F	3.F	130.021	0.836	86.F	74.F
10	130.956 *	0.845	88.F	74.F	-165.825	5.F	4.F	130.956 *	0.845	88.F	74.F
11	134.876 *	0.832	91.F	76.F	-148.196	6.F	5.F	134.876 *	0.832	91.F	76.F
12	131.300 *	0.848	94.F	76.F	-135.541	8.F	7.F	131.300 *	0.848	94.F	76.F
13	132.375 *	0.845	96.F	77.F	-129.628	9.F	9.F	132.375 *	0.845	96.F	77.F
14	128.703 *	0.844	87.F	74.F	-122.642	11.F	11.F	128.703 *	0.844	87.F	74.F
15	128.116 *	0.837	76.F	71.F	-120.576	12.F	12.F	128.116 *	0.837	76.F	71.F
16	128.461 *	0.831	78.F	72.F	-117.240	14.F	13.F	128.461 *	0.831	78.F	72.F
17	126.874	0.830	78.F	72.F	-113.889	15.F	14.F	126.874	0.830	78.F	72.F
18	104.379	0.994	89.F	75.F	-111.489	15.F	15.F	104.379	0.994	89.F	75.F
19	105.273	0.995	87.F	75.F	-112.612	17.F	16.F	105.273	0.995	87.F	75.F
20	104.677	0.996	84.F	74.F	-111.856	17.F	16.F	104.677	0.996	84.F	74.F
21	0.000	0.000	84.F	74.F	-108.783	18.F	18.F	0.000	0.000	84.F	74.F
22	0.000	0.000	82.F	74.F	0.000	17.F	17.F	0.000	0.000	82.F	74.F
23	0.000	0.000	80.F	72.F	0.000	17.F	17.F	0.000	0.000	80.F	72.F
24	0.000	0.000	78.F	72.F	0.000	17.F	17.F	0.000	0.000	78.F	72.F
SUM								1851.399			
MAX	134.876				-165.825						

SYSTEM-TYPE	PSZ	SQFT/TON	427.1
COOLING PEAK	28.10 (BTU/HR- SQFT)	HEATING PEAK	-34.55 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	0.88 (CFM/SQFT)	MIN-OA/PERSON	42.50 (CFM)
OA FRAC AT CLG PEAK	0.120	OA FRAC AT HTG PEAK	0.120

* ASTERISKS INDICATE HOURS LOADS NOT MET

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	0.	0.000	0.000	0.038	0.000	0.000	0.000	0.000	0.194
FEB	0.	0.000	0.000	0.034	0.000	0.000	0.000	0.000	0.094
MAR	0.	0.000	0.000	0.034	0.000	0.000	0.000	0.000	0.194
APR	8.	1.022	0.317	0.020	0.000	0.000	0.000	0.000	1.039
MAY	39.	5.301	1.650	0.011	0.000	0.000	0.000	0.000	1.966
JUN	110.	15.345	4.876	0.000	0.000	0.000	0.000	0.000	2.949
JUL	222.	30.666	10.100	0.000	0.000	0.000	0.000	0.000	3.655
AUG	185.	25.769	8.328	0.000	0.000	0.000	0.000	0.000	3.438
SEP	70.	9.454	3.064	0.004	0.000	0.000	0.000	0.000	2.460
OCT	9.	0.890	0.294	0.020	0.000	0.000	0.000	0.000	1.294
NOV	0.	0.000	0.000	0.033	0.000	0.000	0.000	0.000	0.144
DEC	0.	0.000	0.000	0.036	0.000	0.000	0.000	0.000	0.044
ANNUAL	643.	88.449	28.628	0.230	0.000	0.000	0.000	0.000	17.473

CSPF (WITH PARASITICS) = 1.91 (BTU/BTU)
 CSPF (WITHOUT PARASITICS) = 3.09 (BTU/BTU)

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	224.	-15.095	9.700	0.041	-6.644	6.644	0.000	0.000	-0.280	3.471
FEB	187.	-12.908	8.084	0.038	-3.514	3.514	0.000	0.000	-0.198	3.071
MAR	112.	-8.836	5.670	0.040	-1.178	1.178	0.000	0.000	-0.109	3.271
APR	22.	-1.858	1.639	0.029	0.000	0.000	0.000	0.000	-0.034	2.427
MAY	1.	-0.158	0.250	0.016	0.000	0.000	0.000	0.000	0.000	1.311
JUN	0.	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.405
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.011
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.050
SEP	0.	-0.006	0.094	0.005	0.000	0.000	0.000	0.000	-0.002	0.839
OCT	9.	-0.930	0.932	0.025	0.000	0.000	0.000	0.000	-0.014	2.149
NOV	104.	-8.553	5.183	0.041	-0.073	0.073	0.000	0.000	-0.118	2.766
DEC	247.	-17.471	11.009	0.038	-1.641	1.641	0.000	0.000	-0.367	3.621
ANNUAL	906.	-65.815	42.564	0.274	-13.051	13.051	0.000	0.000	-1.120	23.394

HSPF (WITH PARASITICS) = 1.28 (BTU/BTU)
 HSPF (WITHOUT PARASITICS) = 1.40 (BTU/BTU)

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	1.16159	22 7	33.F	32.F	60.873	-100.279	2 10	5.F	4.F	-540.671	45377.	214.264
FEB	0.74904	27 7	36.F	33.F	57.332	-76.824	24 7	20.F	18.F	-452.024	36361.	185.900
MAR	1.96008	3 15	76.F	65.F	149.336	-42.317	24 10	7.F	5.F	-453.387	27699.	188.690
APR	9.87502	28 16	74.F	66.F	250.646	-5.752	7 10	49.F	44.F	-238.333	17578.	125.679
MAY	19.43415	21 14	85.F	75.F	394.489	-0.237	9 10	43.F	39.F	-69.098	15373.	76.093
JUN	53.79815	20 18	91.F	78.F	523.800	0.000				0.000	15632.	65.407
JUL	104.17480	14 10	86.F	74.F	700.977	0.000				0.000	17500.	74.731
AUG	80.33379	11 16	88.F	74.F	506.352	0.000				0.000	16133.	64.852
SEP	33.28735	11 17	86.F	72.F	429.160	-0.009	23 10	46.F	40.F	-3.974	15225.	61.356
OCT	12.85266	30 17	74.F	67.F	190.136	-3.618	20 10	42.F	36.F	-265.856	16893.	133.743
NOV	0.50577	18 7	36.F	35.F	60.861	-39.520	28 7	26.F	24.F	-352.569	24833.	156.303
DEC	1.04643	12 7	33.F	33.F	59.792	-83.487	22 10	22.F	22.F	-436.236	40450.	183.665
TOTAL	319.179					-352.043					289056.	
MAX					700.977					-540.671		214.264

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	JUL 7				JAN 2			JUL 7			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	89.F	70.F	-311.526	-4.F	-4.F	0.000	0.000	89.F	70.F
2	0.000	0.000	88.F	70.F	-314.872	-4.F	-4.F	0.000	0.000	88.F	70.F
3	0.000	0.000	87.F	69.F	-317.335	-4.F	-4.F	0.000	0.000	87.F	69.F
4	0.000	0.000	87.F	69.F	-319.004	-4.F	-4.F	0.000	0.000	87.F	69.F
5	0.000	0.000	86.F	68.F	-319.910	-3.F	-3.F	0.000	0.000	86.F	68.F
6	0.000	0.000	86.F	68.F	-320.118	-2.F	-2.F	0.000	0.000	86.F	68.F
7	1169.802 *	0.987	86.F	68.F	-590.608	-1.F	-1.F	1169.802 *	0.987	86.F	68.F
8	894.386 *	0.987	86.F	68.F	-642.232	0.F	0.F	894.386 *	0.987	86.F	68.F
9	970.268 *	0.960	87.F	69.F	-576.015	1.F	1.F	970.268 *	0.960	87.F	69.F
10	961.957 *	0.955	89.F	69.F	-593.530	2.F	2.F	961.957 *	0.955	89.F	69.F
11	956.382 *	0.949	92.F	71.F	-519.670	3.F	3.F	956.382 *	0.949	92.F	71.F
12	932.543 *	0.949	94.F	72.F	-466.235	4.F	4.F	932.543 *	0.949	94.F	72.F
13	919.971 *	0.943	96.F	73.F	-432.169	5.F	5.F	919.971 *	0.943	96.F	73.F
14	920.658 *	0.934	97.F	74.F	-389.804	5.F	5.F	920.658 *	0.934	97.F	74.F
15	910.681 *	0.930	98.F	74.F	-343.544	6.F	6.F	910.681 *	0.930	98.F	74.F
16	894.139 *	0.928	97.F	74.F	-320.297	5.F	5.F	894.139 *	0.928	97.F	74.F
17	874.522 *	0.927	97.F	74.F	-317.586	5.F	5.F	874.522 *	0.927	97.F	74.F
18	0.000	0.000	97.F	74.F	-309.581	4.F	4.F	0.000	0.000	97.F	74.F
19	0.000	0.000	96.F	74.F	-365.914	3.F	3.F	0.000	0.000	96.F	74.F
20	0.000	0.000	95.F	73.F	-369.110	1.F	2.F	0.000	0.000	95.F	73.F
21	0.000	0.000	94.F	73.F	-372.566	0.F	0.F	0.000	0.000	94.F	73.F
22	0.000	0.000	93.F	72.F	0.000	-1.F	-1.F	0.000	0.000	93.F	72.F
23	0.000	0.000	92.F	71.F	-20.463	-3.F	-2.F	0.000	0.000	92.F	71.F
24	0.000	0.000	90.F	71.F	-60.780	-4.F	-3.F	0.000	0.000	90.F	71.F
SUM								10405.312			
MAX	1169.802				-642.232						

SYSTEM-TYPE	VAVS	SQFT/TON	239.2
COOLING PEAK	50.16 (BTU/HR- SQFT)	HEATING PEAK	-27.54 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.39 (CFM/SQFT)	MIN-OA/PERSON	15.30 (CFM)
OA FRAC AT CLG PEAK	0.075	OA FRAC AT HTG PEAK	0.243

* ASTERISKS INDICATE HOURS LOADS NOT MET

- - - - - C O O L I N G - - - - -				- - - H E A T I N G - - -			D A Y C O O L I N G P E A K				
JUL 14				JAN 2			JUL 14				
HOURLY	HOURLY	SENSIBLE	DRY-	WET-	HOURLY	DRY-	WET-	HOURLY	SENSIBLE	DRY-	WET-
COOLING	COOLING	HEAT	BULB	BULB	HEATING	BULB	BULB	COOLING	HEAT	BULB	BULB
LOAD	LOAD	RATIO	TEMP	TEMP	LOAD	TEMP	TEMP	LOAD	RATIO	TEMP	TEMP
(KBTU)	(KBTU)				(KBTU)			(KBTU)			
1	0.000	0.000	83.F	72.F	-231.415	1.F	0.F	0.000	0.000	83.F	72.F
2	0.000	0.000	81.F	72.F	-234.666	1.F	0.F	0.000	0.000	81.F	72.F
3	0.000	0.000	80.F	71.F	-237.541	1.F	0.F	0.000	0.000	80.F	71.F
4	0.000	0.000	78.F	71.F	-239.997	2.F	1.F	0.000	0.000	78.F	71.F
5	0.000	0.000	77.F	70.F	-256.413	2.F	1.F	0.000	0.000	77.F	70.F
6	0.000	0.000	78.F	71.F	-243.484	2.F	1.F	0.000	0.000	78.F	71.F
7	635.572	0.924	79.F	71.F	-483.920	3.F	2.F	635.572	0.924	79.F	71.F
8	631.693	0.908	82.F	72.F	-478.866	4.F	3.F	631.693	0.908	82.F	72.F
9	700.977	0.878	86.F	74.F	-448.579	4.F	3.F	700.977	0.878	86.F	74.F
10	687.604	0.885	88.F	74.F	-540.671	5.F	4.F	687.604	0.885	88.F	74.F
11	685.648	0.869	91.F	76.F	-475.001	6.F	5.F	685.648	0.869	91.F	76.F
12	645.526	0.882	94.F	76.F	-410.687	8.F	7.F	645.526	0.882	94.F	76.F
13	651.644	0.876	96.F	77.F	-379.031	9.F	9.F	651.644	0.876	96.F	77.F
14	627.237	0.873	87.F	74.F	-339.156	11.F	11.F	627.237	0.873	87.F	74.F
15	597.162	0.870	76.F	71.F	-309.246	12.F	12.F	597.162	0.870	76.F	71.F
16	577.640	0.860	78.F	72.F	-285.797	14.F	13.F	577.640	0.860	78.F	72.F
17	560.584	0.856	78.F	72.F	-265.645	15.F	14.F	560.584	0.856	78.F	72.F
18	0.000	0.000	89.F	75.F	-250.790	15.F	15.F	0.000	0.000	89.F	75.F
19	0.000	0.000	87.F	75.F	-294.339	17.F	16.F	0.000	0.000	87.F	75.F
20	0.000	0.000	84.F	74.F	-290.969	17.F	16.F	0.000	0.000	84.F	74.F
21	0.000	0.000	84.F	74.F	-281.007	18.F	18.F	0.000	0.000	84.F	74.F
22	0.000	0.000	82.F	74.F	0.000	17.F	17.F	0.000	0.000	82.F	74.F
23	0.000	0.000	80.F	72.F	0.000	17.F	17.F	0.000	0.000	80.F	72.F
24	0.000	0.000	78.F	72.F	0.000	17.F	17.F	0.000	0.000	78.F	72.F
SUM								7001.287			
MAX	700.977				-540.671						

SYSTEM-TYPE	VAVS	SQFT/TON	399.2
COOLING PEAK	30.06 (BTU/HR- SQFT)	HEATING PEAK	-23.18 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.39 (CFM/SQFT)	MIN-OA/PERSON	15.30 (CFM)
OA FRAC AT CLG PEAK	0.092	OA FRAC AT HTG PEAK	0.245

* ASTERISKS INDICATE HOURS LOADS NOT MET

MESSAGE LIST FROM PLANT PROGRAM

CAUTION***
TOWER WILL BE DEFINED FOR CHILLERS THAT NEED IT

OFFICE BUILDING & OPEN ATRIA
 ICE THERMAL ENERGY STORAGE FOR OFFICE
 REPORT- PV-A EQUIPMENT SIZES

VAV SYSTEM IN OFFICE & PSZ IN ATRIA
 STORAGE PRIORITY

DOE-2.1E-001 Wed Nov 10 15:17:48 1993PDL RUN 4
 SAMP3.INP RUN 4
 WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL	SIZE (MBTU/H)	INSTD AVAIL
ELEC-DHW-HEATER	0.027	1 1								
OPEN-REC-CHLR	0.582	1 1								
COOLING-TWR	0.736	1 1								
CTANK-STORAGE	4.842	1 1								
COOL-STORE-RATE =	0.372	(MBTU/H)								
COOL-SUPPLY-RATE=	0.440	(MBTU/H)								

S I T E E N E R G Y													* SOURCE
	2	3	4	5	6	7	8	9	10	11	12	13	14
MONTH	TOTAL HEAT LOAD (MBTU)	TOTAL COOLING LOAD (MBTU)	TOTAL ELECTR LOAD (MWH)	RCVRED ENERGY (MBTU)	WASTED RCVRABL ENERGY (MBTU)	FUEL INPUT COOLING (MBTU)	ELEC INPUT COOLING (MWH)	FUEL INPUT HEATING (MBTU)	ELEC INPUT HEATING (MWH)	FUEL INPUT ELECT (MBTU)	TOTAL FUEL INPUT (MBTU)	TOTAL SITE ENERGY (MBTU)	TOTAL SOURCE ENERGY (MBTU)
JAN	7.0	1.5	54.8	0.0	0.0	0.0	0.2	0.0	36.5	0.0	0.0	186.9	560.7
FEB	6.4	0.9	43.8	0.0	0.0	0.0	0.1	0.0	28.0	0.0	0.0	149.5	448.5
MAR	7.1	2.4	34.3	0.0	0.0	0.0	0.3	0.0	16.7	0.0	0.0	117.0	351.1
APR	6.6	11.6	23.8	0.0	0.0	0.0	1.7	0.0	4.3	0.0	0.0	81.3	243.9
MAY	6.2	21.6	22.4	0.0	0.0	0.0	3.0	0.0	2.1	0.0	0.0	76.3	228.9
JUN	5.5	62.3	26.4	0.0	0.0	0.0	7.0	0.0	1.8	0.0	0.0	90.0	270.0
JUL	5.3	111.2	34.3	0.0	0.0	0.0	13.1	0.0	1.7	0.0	0.0	117.2	351.6
AUG	5.2	87.7	30.2	0.0	0.0	0.0	10.4	0.0	1.7	0.0	0.0	103.0	308.9
SEP	5.1	31.4	23.1	0.0	0.0	0.0	4.3	0.0	1.7	0.0	0.0	78.9	236.8
OCT	5.2	14.9	23.1	0.0	0.0	0.0	2.1	0.0	3.2	0.0	0.0	78.8	236.3
NOV	5.7	0.6	30.0	0.0	0.0	0.0	0.1	0.0	15.0	0.0	0.0	102.5	307.6
DEC	6.6	1.3	48.6	0.0	0.0	0.0	0.2	0.0	30.4	0.0	0.0	166.0	498.1
TOTAL	72.5	347.5	394.8	0.0	0.0	0.0	42.5	0.0	143.1	0.0	0.0	1347.4	4042.5

MONTH	BTU/UNIT:	ELECTRICITY	
		METER-1	3413./KWH

JAN			
	ENERGY CONSUMPTION (UNITS/MO)		54754.3
	PEAK DEMAND (UNITS/HR OR DAY)		273.5
	PEAK DAY/HR		2/10
FEB			
	ENERGY CONSUMPTION (UNITS/MO)		43796.5
	PEAK DEMAND (UNITS/HR OR DAY)		233.9
	PEAK DAY/HR		24/10
MAR			
	ENERGY CONSUMPTION (UNITS/MO)		34288.5
	PEAK DEMAND (UNITS/HR OR DAY)		240.0
	PEAK DAY/HR		24/10
APR			
	ENERGY CONSUMPTION (UNITS/MO)		23822.9
	PEAK DEMAND (UNITS/HR OR DAY)		143.1
	PEAK DAY/HR		7/10
MAY			
	ENERGY CONSUMPTION (UNITS/MO)		22355.1
	PEAK DEMAND (UNITS/HR OR DAY)		117.1
	PEAK DAY/HR		21/14
JUN			
	ENERGY CONSUMPTION (UNITS/MO)		26371.9
	PEAK DEMAND (UNITS/HR OR DAY)		108.1
	PEAK DAY/HR		20/18
JUL			
	ENERGY CONSUMPTION (UNITS/MO)		34337.2
	PEAK DEMAND (UNITS/HR OR DAY)		126.5
	PEAK DAY/HR		14/12
AUG			
	ENERGY CONSUMPTION (UNITS/MO)		30167.7
	PEAK DEMAND (UNITS/HR OR DAY)		107.5
	PEAK DAY/HR		20/15
SEP			
	ENERGY CONSUMPTION (UNITS/MO)		23124.0
	PEAK DEMAND (UNITS/HR OR DAY)		123.7
	PEAK DAY/HR		11/17
OCT			
	ENERGY CONSUMPTION (UNITS/MO)		23074.4
	PEAK DEMAND (UNITS/HR OR DAY)		151.4
	PEAK DAY/HR		20/10
NOV			
	ENERGY CONSUMPTION (UNITS/MO)		30037.5
	PEAK DEMAND (UNITS/HR OR DAY)		181.0
	PEAK DAY/HR		28/10
DEC			
	ENERGY CONSUMPTION (UNITS/MO)		48645.5
	PEAK DEMAND (UNITS/HR OR DAY)		233.5
	PEAK DAY/HR		22/10

TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)		394775.5
	PEAK DEMAND (UNITS/HR OR DAY)		273.5

EQUIPMENT	HOURS AT PERCENT PART LOAD RATIO													TOTAL HOURS	ANNUAL LOAD (MBTU)	FALSE LOAD (MBTU)	ELEC USED (KWH)	THERMAL USED (MBTU)
	0 --	10 --	20 --	30 --	40 --	50 --	60 --	70 --	80 --	90 --	100 -	110+						
ELEC-DHW-HEATER	3842	334	291	702	883	882	787	588	212	201	38	8760	72.5	0.0	23371.	0.0		
	3842	334	291	702	883	882	787	588	212	201	38							
OPEN-REC-CHLR	154	265	271	94	52	51	29	7	9	585	0	1517	347.5	0.0	29064.	0.0		
	154	265	271	94	52	51	29	7	9	585	0							
COOLING-TWR	481	334	209	376	103	11	3	0	0	0	0	1517	440.4	0.0	1776.	0.0		
	481	334	209	376	103	11	3	0	0	0	0							
CTANK-STORAGE	28	70	53	19	23	49	120	163	124	120	16	785	222.1	0.0	0.	0.0		
	785	0	0	0	0	0	0	0	0	0	0							

HOT LOOP CIRCULATION PUMP ELECTRICAL USE = 0. KWH
 COLD LOOP CIRCULATION PUMP ELECTRICAL USE = 3320. KWH
 CONDENSER WATER PUMP ELECTRICAL USE = 1200. KWH
 TOWER OR CONDENSER FAN ELECTRICAL USE = 576. KWH

NOTES TO TABLE

- 1) THE FIRST PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE HOURLY OPERATING CAPACITY
- 2) THE SECOND PART LOAD ENTRY FOR EACH PIECE OF EQUIPMENT IS THE HOURLY LOAD DIVIDED BY THE TOTAL INSTALLED CAPACITY

TOTAL HOURS AT HOURLY DEMAND AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
	327	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	301	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	276	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	
	251	0	0	0	0	0	2	1	0	5	2	1	0	0	0	0	0	0	0	0	0	0	0	0	11	
D	226	0	0	0	0	0	5	3	2	13	4	2	1	0	0	0	0	0	0	0	0	0	0	0	30	
E	201	0	0	0	0	0	5	5	5	14	15	7	4	2	1	1	1	0	0	0	0	0	0	0	60	
M K	176	0	0	0	0	0	18	12	9	26	14	17	15	11	6	2	3	3	2	2	1	0	0	0	141	
A W	150	0	0	0	0	0	10	14	17	31	40	37	23	20	17	20	17	16	9	8	10	0	0	0	289	
N	125	0	0	0	0	0	26	15	14	23	45	57	67	65	74	72	72	72	23	25	27	0	0	0	677	
D	100	1	0	2	2	3	2	14	44	45	64	78	91	81	96	108	105	109	121	60	63	54	0	0	1143	
	75	10	11	9	10	12	13	8	61	79	78	58	44	64	61	48	54	53	43	91	87	90	5	6	8	1003
	50	73	72	67	60	39	36	182	117	99	15	15	13	13	12	23	21	20	20	101	101	103	80	76	76	1434
	25	281	282	287	293	311	314	95	93	95	94	94	96	97	98	88	90	90	90	79	79	80	280	283	281	3970
PERCENT TOTAL DEMAND	1.0	1.0	1.0	1.0	0.9	0.8	4.8	5.1	5.1	7.6	7.3	7.1	6.7	6.5	6.6	6.4	6.5	6.5	5.1	5.1	5.1	1.0	1.0	0.9		

PEAK ELECTRICAL LOAD BREAKDOWN

SOURCE	KW	PCT
SYSTEMS LOAD	269.396	98.5
ELEC-DHW-HEATER	4.148	1.5
=====		
TOTAL	273.544	

ENERGY TYPE:	ELECTRICITY
UNITS:	MBTU
CATEGORY OF USE	

AREA LIGHTS	404.4
MISC EQUIPMT	216.6
SPACE HEAT	388.3
SPACE COOL	127.8
HEAT REJECT	6.1
PUMPS & MISC	11.8
VENT FANS	92.1
SUPPLMT HEAT	20.5
DOMHOT WATER	79.8

TOTAL	1347.4

TOTAL SITE ENERGY	1347.37 MBTU	50.1 KBTU/SQFT-YR GROSS-AREA	50.1 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	4042.51 MBTU	150.2 KBTU/SQFT-YR GROSS-AREA	150.2 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.2
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

MDDHH	OPEN-REC -CHLR LOAD BTU/HR	OPEN-REC -CHLR AVAL CAP RATIO FRAC.OR MULT.	OPEN-REC -CHLR OPER PT LD RATIO FRAC.OR MULT.	OPEN-REC -CHLR ADJUSTED EIR BTU/BTU	CTANK-ST ORAGE ENERGY RELEASED BTU/HR	CTANK-ST ORAGE ENERGY STORED BTU/HR	CTANK-ST ORAGE TOTAL IN STORAGE BTU/HR
	----(1)	----(8)	----(10)	----(16)	----(1)	----(4)	----(14)
713 1	0.	0.000	0.000	0.000	0.	0.	4753928.
713 2	0.	0.000	0.000	0.000	0.	0.	4749946.
713 3	0.	0.000	0.000	0.000	0.	0.	4745965.
713 4	0.	0.000	0.000	0.000	0.	0.	4742085.
713 5	0.	0.000	0.000	0.000	0.	0.	4738306.
713 6	0.	0.000	0.000	0.000	0.	0.	4734527.
713 7	0.	0.000	0.000	0.000	0.	0.	4730649.
713 8	0.	0.000	0.000	0.000	0.	0.	4726472.
713 9	0.	0.000	0.000	0.000	0.	0.	4721696.
71310	0.	0.000	0.000	0.000	0.	0.	4716521.
71311	0.	0.000	0.000	0.000	0.	0.	4711047.
71312	0.	0.000	0.000	0.000	0.	0.	4705174.
71313	0.	0.000	0.000	0.000	0.	0.	4699102.
71314	0.	0.000	0.000	0.000	320621.	0.	4692932.
71315	0.	0.000	0.000	0.000	374187.	0.	4366110.
71316	0.	0.000	0.000	0.000	380172.	0.	3985800.
71317	0.	0.000	0.000	0.000	370997.	0.	3599384.
71318	372489.	0.660	0.970	0.250	0.	372489.	3222420.
71319	372489.	0.650	0.985	0.261	0.	372489.	3589068.
71320	372489.	0.651	0.984	0.260	0.	372489.	3955840.
71321	372489.	0.651	0.984	0.260	0.	372489.	4322836.
71322	152306.	0.652	0.402	0.133	0.	152306.	4690055.
71323	0.	0.000	0.000	0.000	0.	0.	4837162.
71324	0.	0.000	0.000	0.000	0.	0.	4832063.
DAILY SUMMARY (JUL 13)							
MN	0.	0.000	0.000	0.000	0.	0.	3222420.
MX	372489.	0.660	0.985	0.261	380172.	372489.	4837162.
SM	1642264.	3.263	4.324	1.164	1445976.	1642264.	107569088.
AV	68428.	0.136	0.180	0.049	60249.	68428.	4482046.

	OPEN-REC -CHLR LOAD BTU/HR	OPEN-REC -CHLR AVAL CAP RATIO FRAC.OR MULT.	OPEN-REC -CHLR OPER PT LD RATIO FRAC.OR MULT.	OPEN-REC -CHLR ADJUSTED EIR BTU/HR	CTANK-ST ORAGE ENERGY RELEASED BTU/HR	CTANK-ST ORAGE ENERGY STORED BTU/HR	CTANK-ST ORAGE TOTAL IN STORAGE BTU/HR
	----(1)	----(8)	----(10)	----(16)	----(1)	----(4)	----(14)
714 1	0.	0.000	0.000	0.000	0.	0.	4827165.
714 2	0.	0.000	0.000	0.000	0.	0.	4822468.
714 3	0.	0.000	0.000	0.000	0.	0.	4817872.
714 4	0.	0.000	0.000	0.000	0.	0.	4813477.
714 5	0.	0.000	0.000	0.000	0.	0.	4809183.
714 6	0.	0.000	0.000	0.000	0.	0.	4804790.
714 7	209385.	1.054	0.341	0.109	440215.	0.	4800298.
714 8	205506.	1.054	0.335	0.107	440215.	0.	4355384.
714 9	274790.	1.059	0.446	0.133	440215.	0.	3910162.
71410	261418.	1.055	0.426	0.129	440215.	0.	3464832.
71411	259462.	1.055	0.422	0.128	440215.	0.	3019294.
71412	219340.	1.049	0.359	0.114	440215.	0.	2573548.
71413	225458.	1.051	0.369	0.116	440215.	0.	2127694.
71414	201051.	1.045	0.330	0.108	440215.	0.	1682832.
71415	170976.	1.049	0.280	0.095	440215.	0.	1239162.
71416	152779.	1.050	0.250	0.087	438890.	0.	795384.
71417	221592.	1.048	0.363	0.114	353020.	0.	353020.
71418	372489.	0.655	0.977	0.255	0.	372489.	0.
71419	372489.	0.651	0.983	0.260	0.	372489.	363614.
71420	372489.	0.651	0.984	0.260	0.	372489.	731952.
71421	372489.	0.652	0.982	0.259	0.	372489.	1100214.
71422	372489.	0.652	0.982	0.259	0.	372489.	1468600.
71423	372489.	0.652	0.982	0.259	0.	372489.	1837110.
71424	372489.	0.653	0.980	0.257	0.	372489.	2205744.
DAILY SUMMARY (JUL 14)							
MN	0.	0.000	0.000	0.000	0.	0.	0.
MX	372489.	1.059	0.984	0.260	440215.	372489.	4827165.
SM	5009183.	16.134	10.793	3.049	4753842.	2607425.	64923800.
AV	208716.	0.672	0.450	0.127	198077.	108643.	2705158.

	OPEN-REC -CHLR LOAD BTU/HR	OPEN-REC -CHLR AVAL CAP RATIO FRAC.OR MULT.	OPEN-REC -CHLR OPER PT LD RATIO FRAC.OR MULT.	OPEN-REC -CHLR ADJUSTED EIR BTU/BTU	CTANK-ST ORAGE ENERGY RELEASED BTU/HR	CTANK-ST ORAGE ENERGY STORED BTU/HR	CTANK-ST ORAGE TOTAL IN STORAGE BTU/HR
	---- (1)	---- (8)	---- (10)	---- (16)	---- (1)	---- (4)	---- (14)
715 1	372489.	0.653	0.980	0.257	0.	372489.	2574402.
715 2	372489.	0.653	0.980	0.257	0.	372489.	2942984.
715 3	372489.	0.653	0.980	0.257	0.	372489.	3311590.
715 4	372489.	0.654	0.979	0.257	0.	372489.	3680220.
715 5	372489.	0.654	0.979	0.257	0.	372489.	4048974.
715 6	372489.	0.654	0.978	0.256	0.	372489.	4417750.
715 7	150460.	1.034	0.250	0.088	314756.	0.	4786450.
715 8	151176.	1.039	0.250	0.087	318539.	0.	4467670.
715 9	152171.	1.046	0.250	0.087	385909.	0.	4145076.
71510	152117.	1.045	0.250	0.087	377169.	0.	3754992.
71511	152036.	1.045	0.250	0.087	371602.	0.	3373526.
71512	151541.	1.041	0.250	0.087	343196.	0.	2997604.
71513	151583.	1.042	0.250	0.087	345961.	0.	2650060.
71514	151649.	1.042	0.250	0.087	356291.	0.	2299724.
71515	151666.	1.042	0.250	0.087	351536.	0.	1939330.
71516	151442.	1.041	0.250	0.087	331388.	0.	1583866.
71517	151590.	1.042	0.250	0.087	341273.	0.	1248720.
71518	372489.	0.657	0.974	0.253	0.	372489.	903958.
71519	372489.	0.655	0.977	0.255	0.	372489.	1272984.
71520	372489.	0.655	0.977	0.255	0.	372489.	1642134.
71521	372489.	0.656	0.976	0.254	0.	372489.	2011508.
71522	372489.	0.656	0.976	0.254	0.	372489.	2381006.
71523	372489.	0.656	0.975	0.254	0.	372489.	2750628.
71524	372489.	0.657	0.975	0.254	0.	372489.	3120174.
DAILY SUMMARY (JUL 15)							
MN	150460.	0.653	0.250	0.087	0.	0.	903958.
MX	372489.	1.046	0.980	0.257	385909.	372489.	4786450.
SM	6509795.	19.973	15.455	4.278	3837620.	4842361.	68305328.
AV	271241.	0.832	0.644	0.178	159901.	201765.	2846055.
MONTHLY SUMMARY (JUL)							
MN	0.	0.000	0.000	0.000	0.	0.	0.
MX	372489.	1.059	0.985	0.261	440215.	372489.	4837162.
SM	13161242.	39.369	30.572	8.491	10037438.	9092050.	240798224.
AV	182795.	0.547	0.425	0.118	139409.	126278.	3344420.
YEARLY SUMMARY							
MN	0.	0.000	0.000	0.000	0.	0.	0.
MX	372489.	1.059	0.985	0.261	440215.	372489.	4837162.
SM	13161242.	39.369	30.572	8.491	10037438.	9092050.	240798224.
AV	182795.	0.547	0.425	0.118	139409.	126278.	3344420.

OFFICE BUILDING & OPEN ATRIA
 ICE THERMAL ENERGY STORAGE FOR OFFICE
 REPORT- ES-D ENERGY COST SUMMARY

VAV SYSTEM IN OFFICE & PSZ IN ATRIA
 STORAGE PRIORITY

DOE-2.1E-001 Wed Nov 10 15:17:48 1993EDL RUN 4
 SAMP3.INP RUN 4

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	394776. KWH	31197.	0.0790	YES

=====.

31197.

ENERGY COST/GROSS BLDG AREA: 1.16
 ENERGY COST/NET BLDG AREA: 1.16

OFFICE BUILDING & OPEN ATRIA VAV SYSTEM IN OFFICE & PS2 IN ATRIA DJE-2.1E-001 Wed Nov 10 15:17:48 1993EDL RUN 4
 ICE THERMAL ENERGY STORAGE FOR OFFICE STORAGE PRIORITY SAMP3.INP RUN 4
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-COST

UTILITY-RATE: ELEC-COST RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0 SUM-P-DEM
 MAX-ENERGY: 0.0 WIN-P-DEM
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	54754	54754	273.5	273.5	1981	2017	0	0	0	0	186	0.0730	3998
FEB	43796	43796	233.9	233.9	1584	1681	0	0	0	0	186	0.0746	3265
MAR	34288	34288	240.0	240.0	1246	1703	0	0	0	0	186	0.0860	2950
APR	23823	23823	143.1	143.1	877	1045	0	0	0	0	186	0.0807	1923
MAY	22355	22355	117.1	117.1	927	1122	0	0	0	0	186	0.0916	2048
JUN	26372	26372	108.1	108.1	1076	1058	0	0	0	0	186	0.0809	2134
JUL	34337	34337	126.5	126.5	1399	1160	0	0	0	0	186	0.0745	2559
AUG	30168	30168	107.5	107.5	1230	1057	0	0	0	0	186	0.0758	2287
SEP	23124	23124	123.7	123.7	961	1185	0	0	0	0	186	0.0928	2146
OCT	23074	23074	151.4	151.4	954	1182	0	0	0	0	186	0.0926	2136
NOV	30037	30037	181.0	181.0	1094	1300	0	0	0	0	186	0.0797	2395
DEC	48645	48645	233.5	233.5	1763	1595	0	0	0	0	186	0.0690	3357
TOTAL	394776	394776	273.5		15092	16105	0	0	0	0		0.0790	31197

UTILITY-RATE: ELEC-COST
 RESOURCE: ELECTRICITY
 ENERGY-UNITS: KWH
 DEMAND-UNITS: KW
 DEMAND-WINDOW: HOUR

BLOCK-CHARGES	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	YEAR
SUM-P-DEM	USE: TIME-OF-USE												
METERED DEMAND:	0.0	0.0	0.0	0.0	117.1	108.1	119.1	107.5	123.7	113.0	0.0	0.0	
BILLING DEMAND:	0.0	0.0	0.0	0.0	117.1	111.3	119.1	111.3	123.7	113.0	0.0	0.0	
DEMAND CHGS (\$):	0	0	0	0	820	779	834	779	866	791	0	0	4869
WIN-P-DEM	USE: TIME-OF-USE												
METERED DEMAND:	215.6	177.7	179.0	106.5	0.0	0.0	0.0	0.0	0.0	0.0	137.4	164.5	
BILLING DEMAND:	215.6	177.7	179.0	111.3	0.0	0.0	0.0	0.0	0.0	0.0	137.4	164.5	
DEMAND CHGS (\$):	1402	1155	1163	724	0	0	0	0	0	0	893	1069	6406
TOTAL CHARGES (\$):	1402	1155	1163	724	820	779	834	779	866	791	893	1069	11274

RATCHETS	TYPE	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
SUM-RATCH	HIGHEST	111.3	111.3	111.3	111.3	111.3	111.3	111.3	111.3	111.3	111.3	111.3	111.3

Bar/Lounge

LDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993LDL RUN 1

```
* 2 * TITLE LINE-1 * SMALL BAR/LOUGE *
* 3 *   LINE-2 * DEMO DESICCANT & EVAPORATIVE COOLING *
* 4 *   LINE-3 * NEW FEATURES IN DOE2.1E RUN 1 * ..
* 5 *
* 6 * ABORT ERRORS .. LIST WARNINGS ..
* 7 * RUN-PERIOD   JAN 1 1988 THRU DEC 31 1988 ..
* 8 *
* 9 * BUILDING-LOCATION  LAT 42  LON 88  ALT 610  T-2 6  AZ 0  ..
* 10 *
* 11 *   $ OCCUPANCY $
* 12 *
* 13 * OC1 = D-SCH (1,24) (.2,.2,0,0,0,0,.4,.4,.2,.2,.2,.3,.6,.1,.1,.1,
* 14 *   .5,.7,.5,.5,.7,.8,.8,.6) ..
* 15 * OC2 = D-SCH (1,24) (.4,.4,0,0,0,0,.2,.2,.1,.1,.1,.2,.4,.2,.2,.2,
* 16 *   .5,.7,.8,.8,.9,.9,.9,.5) ..
* 17 * OC3 = D-SCH (1,24) (.4,.4,0,0,0,0,0,0,.2,.3,.4,.5,.5,.6,.7,.7,
* 18 *   .8,.8,.6,.5,.5,.6,.6) ..
* 19 * OCCUP = SCH THRU DEC 31 (WD) OC1 (SAT) OC2 (SUN,HOL) OC3 ..
* 20 *
* 21 *   $ LIGHTING $
* 22 *
* 23 * L1 = D-SCH (1,2) (.5) (3,6) (.1) (7,9) (.5) (10,18) (.4)
* 24 *   (19,24) (1) ..
* 25 * L2 = D-SCH (1,2) (.5) (3,6) (.1) (7,12) (.5) (13,18) (.8)
* 26 *   (19,24) (1) ..
* 27 * L3 = D-SCH (1,2) (.5) (3,9) (.1) (10,12) (.4) (13,17) (.6)
* 28 *   (18,19) (1) (20,24) (.5) ..
* 29 * LIGHTS = SCH THRU DEC 31 (WD) L1 (SAT) L2 (SUN,HOL) L3 ..
* 30 *
* 31 *   $ CONSTRUCTIONS $
* 32 * WA1=LAYERS MAT (WS01,PW03,IN32,GP03) ..
* 33 * RF1=LAYERS MAT (BR01,PW04,IN33,AL33,AC02) I-F-R .61 ..
* 34 *
* 35 * S-WALL  CONS LA WA1 ..
* 36 * ROF     CONS LA RF1 ..
* 37 * FOUND   CONS U .26 ..
* 38 * DR1     CONS U .59 ..   $ BACK DOOR
* 39 * GLASS1  G-T  G-T-C 3  PANES 1 .. $ CLEAR 1/4" PLATE
* 40 *
* 41 * SET-DEFAULT FOR EXTERIOR-WALL H 16  CONS S-WALL ..
* 42 * SET-DEFAULT FOR WINDOW  G-T  GLASS1  H 12  Y=2 ..
* 43 *
* 44 * BLDG=   SPACE  A=2160  V=25920  L-W=1.06
* 45 *         E-W=.5  AREA/PERSON=45  E-SCH=LIGHTS
* 46 *         P-H-G=550  L-SCH=LIGHTS  P-SCH=OCCUP  I-M=AIR-CHANGE
* 47 *         A-C=.3  I-SCH=OCCUP  L-T=REC-FLUOR-NV  L-T-S=1 ..
* 48 *         E-W  W 40  AZ 0  X 40  Y 54  ..
* 49 *         E-W  W 54  AZ 90  X 40  ..  DOOR  H 7  W 3  X 7  CONS DR1 ..
* 50 *         E-W  W 40  AZ 180  ..  WI  W 30  X 5  OH-W 50  OH-D 10  OH-A 10
* 51 *                   OH-B 2  ..
* 52 *   $ WEST WALL ABUTS AJOINING BUILDING $
* 53 *   U-W  A 170  CONS FOUND ..
* 54 *   ROOF  H 54  W 40  CONS ROF  AZ 180  TILT 0  G-R 0  ..
* 55 *
* 56 * LOADS-REPORT  S (LS-A,LS-C,LS-D) ..
* 57 * END ..
* 58 * COMPUTE LOADS ..
```


SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 1
 REPORT- LS-A SPACE PEAK LOADS SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING

DOE-2.1E-001 Thu Nov 11 09:03:47 1993LDL RUN 1

WEATHER FILE- TRY CHICAGO

SPACE NAME	MULTIPLIER SPACE FLOOR	COOLING LOAD (KBTU/HR)	TIME OF PEAK	DRY- BULB	WET- BULB	HEATING LOAD (KBTU/HR)	TIME OF PEAK	DRY- BULB	WET- BULB
BLDG	1. 1.	55.224	JUN 20 4 PM	90.F	77.F	-55.857	JAN 12 6 AM	-5.F	-6.F
SUM		55.224				-55.857			
BUILDING PEAK		55.224	JUN 20 4 PM	90.F	77.F	-55.857	JAN 12 6 AM	-5.F	-6.F

*** BUILDING ***

FLOOR AREA 2160 SQFT 201 SQMT
 VOLUME 25920 CUFT 734 CUMT

TIME	COOLING LOAD		HEATING LOAD	
	JUN 20	4PM	JAN 12	6AM
DRY-BULB TEMP	90F	32C	-5F	-21C
WET-BULB TEMP	77F	25C	-6F	-21C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	8.056	2.360	0.000	0.000	-19.553	-5.729
ROOF CONDUCTION	15.163	4.443	0.000	0.000	-19.291	-5.652
WINDOW GLASS+FRM COND	5.603	1.642	0.000	0.000	-21.140	-6.194
WINDOW GLASS SOLAR	10.591	3.103	0.000	0.000	1.840	0.539
DOOR CONDUCTION	0.335	0.098	0.000	0.000	-0.718	-0.210
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-0.530	-0.155	0.000	0.000	-1.326	-0.389
OCCUPANTS TO SPACE	8.351	2.447	8.966	2.627	1.323	0.388
LIGHT TO SPACE	4.127	1.209	0.000	0.000	2.189	0.641
EQUIPMENT TO SPACE	2.032	0.595	0.000	0.000	0.819	0.240
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	1.497	0.439	2.815	0.825	0.000	0.000
TOTAL	55.224	16.181	11.781	3.452	-55.857	-16.366
TOTAL LOAD	67.005 KBTU/H		19.632 KW		-55.857 KBTU/H	-16.366 KW
TOTAL LOAD / AREA	31.02BTU/H.SQFT		97.834 W /SQMT		25.860BTU/H.SQFT	81.557 W /SQMT

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 * *****

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	0.55628	25 13	45.F	40.F	24.590	-16.395	12 6	-5.F	-6.F	-55.857	1309.	3.370		
FEB	0.69640	17 13	40.F	33.F	24.807	-13.867	4 6	7.F	6.F	-49.212	1180.	3.370		
MAR	0.99907	3 17	78.F	61.F	25.923	-9.111	24 6	8.F	7.F	-48.669	1314.	3.370		
APR	5.16373	27 17	85.F	62.F	37.526	-3.772	9 5	26.F	25.F	-30.873	1272.	3.370		
MAY	8.18692	21 12	87.F	76.F	46.495	-1.679	7 5	33.F	29.F	-25.098	1309.	3.370		
JUN	13.56395	20 15	90.F	77.F	55.224	-0.369	1 5	48.F	47.F	-11.998	1272.	3.370		
JUL	19.79075	13 17	99.F	77.F	53.571	-0.026	6 5	61.F	55.F	-4.635	1316.	3.370		
AUG	16.95852	22 14	83.F	70.F	50.452	-0.047	5 5	55.F	54.F	-6.686	1307.	3.370		
SEP	9.02880	19 15	86.F	65.F	44.072	-1.182	23 5	36.F	33.F	-23.403	1265.	3.370		
OCT	5.62650	10 15	68.F	54.F	38.057	-3.019	21 5	30.F	29.F	-28.739	1309.	3.370		
NOV	2.15443	2 13	74.F	61.F	44.681	-8.354	15 6	28.F	26.F	-35.472	1258.	3.370		
DEC	0.25199	10 15	41.F	35.F	21.429	-14.608	26 7	15.F	15.F	-44.958	1300.	3.370		
TOTAL	82.977					-72.430					15408.			
MAX					55.224					-55.857		3.370		

Bar/Lounge — System 1

SDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993SDL RUN 1

```

* 60 *
* 61 * TITLE LINE-4 * SYSTEM 1: PKG ROOFTOP DESICCANT COOLER *
* 62 * LINE-5 * 100% OUTSIDE AIR UNIT ALLYEAR * ..
* 63 *
* 64 * SYSTEMS-REPORT S (SS-A,SS-J,SS-I,SS-N,SS-O) ..
* 65 *
* 66 * FANSON= SCH THRU DEC 31 (MON,SAT) (1,24) (1)
* 67 * (SUN,HOL) (1,2) (1) (3,9) (0) (10,24) (1) ..
* 68 * C-SETPT= SCH THRU DEC 31 (ALL) (1,24) (76) ..
* 69 * H-SETPT= SCH THRU DEC 31 (ALL) (1,24) (72) ..
* 70 * ENV= Z-C D-H-T=72 D-C-T=74 H-T-SCH=H-SETPT C-T-SCH=C-SETPT ..
* 71 *
* 72 * BLDG= Z Z-C=ENV O-CFM/P=20 CFM/SQFT=.7 ..
* 73 *
* 74 * SYS1= SYSTEM S-TYPE=PTGSD
* 75 * SUPPLY-CFM=2500 MIN-CFM-RATIO=.4 HEATING-CAPACITY=-120000
* 76 * SUPPLY-STATIC=2.5 SUPPLY-EFF=.47 MAX-HUMIDITY=60
* 77 * F-SCH=FANSON Z-N=(BLDG) ..
* 78 *
* 79 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (SYS1)
* 80 * DHW-GAL/MIN = .666
* 81 * DHW-SCH = DOMHW ..
* 82 *
* 83 * D1 = D-SCH (1,7) (0) (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.45,.4,.3,.3)
* 84 * (22,24) (0) ..
* 85 * D2 = D-SCH (1,7) (0) (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.4,.35,
* 86 * .25,.2) (23,24) (0) ..
* 87 * D3 = D-SCH (1,9) (0) (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
* 88 * (20,24) (0) ..
* 89 * DOMHW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
* 90 * END ..
* 91 * COMPUTE SYSTEMS ..
* 92 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993PDL RUN 1

- 93 • PLANT1 = PLANT-ASSIGNMENT ..
- 94 • PLANT-REPORT S (BEPS) ..
- 95 • END ..
- 96 • COMPUTE PLANT ..
- 97 • INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993EDL RUN 1

```

* 98 *
* 99 * ECONOMICS-REPORT S (ES-D,ES-E) ..
* 100 *
* 101 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 102 * MONTH-CHGS = (21.75)
* 103 * DEMAND-CHGS = (.81)
* 104 * BLOCK-CHARGES = (E-SM,E-WN) ..
* 105 *
* 106 * E-SM      = BLOCK-CHARGE BLOCK-SCH  = SEASON
* 107 * SCH-FLAG  = 2
* 108 * BLOCK1-TYPE = ENERGY
* 109 * BLOCK1-DATA = (1250,.0829)
* 110 * BLOCK2-TYPE = KWH/KW
* 111 * BLOCK2-DATA = (125,.0829,0
* 112 *                1,.0514,0) ..
* 113 *
* 114 * E-WN      = BLOCK-CHARGE BLOCK-SCH  = SEASON
* 115 * SCH-FLAG  = 1
* 116 * BLOCK1-TYPE = ENERGY
* 117 * BLOCK1-DATA = (1250,.0778)
* 118 * BLOCK2-TYPE = KWH/KW
* 119 * BLOCK2-DATA = (125,.0778,0
* 120 *                1,.0514,0) ..
* 121 *
* 122 * SEASON    = SCHEDULE THRU APR 30 (ALL) (1,24) (1)
* 123 * THRU OCT 31 (ALL) (1,24) (2)
* 124 * THRU DEC 31 (ALL) (1,24) (1) ..
* 125 *
* 126 * GAS-COST  = UTILITY-RATE RESOURCE = NATURAL-GAS
* 127 * MONTH-CHGS = (10.73)
* 128 * BLOCK-CHARGES = (GAS-CH) ..
* 129 *
* 130 * GAS-CH    = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 131 * BLOCK1-DATA = (400,.643
* 132 *                1,.4943) ..
* 133 *
* 134 * END ..
* 135 * COMPUTE ECONOMICS ..
* 136 * INPUT SYSTEMS ..

```

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE						
SYS1	PTSGD		1.020	2160.0		48.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	2550.	1.561	1.9	0.	0.000	0.0	0.384	0.000	0.000	-120.000	0.00	0.37
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
BLDG		2550.	0.	0.000	0.400	979.	0.00	0.00	45.16	0.00	-45.99	1.0

SMALL BAR/LOUGE DEMO DESICCANT & EVAPORATIVE COOLING DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 1
 NEW FEATURES IN DOE2.1E RUN 1 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER 100% OUTSIDE AIR UNIT ALLYEAR
 REPORT- SS-P LOAD, ENERGY AND PART LOAD DHW TANK OPERATION FOR PLANT1 WEATHER FILE- TRY CHICAGO

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.666 (GAL/MIN) PUMP = 0.000 (KW)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (MBTU) (KBTU/HR)	RCV EN USE (MBTU) (KBTU/HR)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM 5.160 PEAK 19.998 DAY/HR 29/14	8.354 28.991 29/14	0.000 0.000 31/24	0.000 0.000 31/24	329	26	41	16	107	70	85	30	40	0	0	744
FEB	SUM 4.837 PEAK 20.598 DAY/HR 26/14	7.807 29.837 26/14	0.000 0.000 28/24	0.000 0.000 28/24	296	24	36	13	96	65	77	27	38	0	0	672
MAR	SUM 5.390 PEAK 20.198 DAY/HR 31/14	8.675 29.273 31/14	0.000 0.000 31/24	0.000 0.000 31/24	322	27	39	12	101	77	89	31	46	0	0	744
APR	SUM 4.947 PEAK 19.198 DAY/HR 30/14	7.993 27.862 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	312	26	38	12	98	156	4	74	0	0	0	720
MAY	SUM 4.592 PEAK 17.799 DAY/HR 28/14	7.499 25.886 28/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	329	31	36	100	93	80	35	40	0	0	0	744
JUN	SUM 4.225 PEAK 16.399 DAY/HR 30/14	6.909 23.911 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	312	30	46	98	74	86	74	0	0	0	0	720
JUL	SUM 3.990 PEAK 15.199 DAY/HR 30/14	6.582 22.218 30/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	325	31	51	103	156	36	42	0	0	0	0	744
AUG	SUM 3.882 PEAK 14.799 DAY/HR 31/14	6.420 21.654 31/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	326	31	48	105	156	78	0	0	0	0	0	744
SEP	SUM 3.848 PEAK 15.199 DAY/HR 30/14	6.351 22.218 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	316	30	47	102	150	33	42	0	0	0	0	720
OCT	SUM 4.179 PEAK 16.199 DAY/HR 29/14	6.877 23.629 29/14	0.000 0.000 31/24	0.000 0.000 31/24	329	31	52	107	150	35	40	0	0	0	0	744
NOV	SUM 4.376 PEAK 17.599 DAY/HR 30/14	7.158 25.604 30/14	0.000 0.000 30/24	0.000 0.000 30/24	320	30	34	98	90	80	28	40	0	0	0	720
DEC	SUM 4.898 PEAK 18.998 DAY/HR 30/14	7.961 27.580 30/14	0.000 0.000 31/24	0.000 0.000 31/24	330	27	39	101	22	150	4	71	0	0	0	744
YR	SUM 54.324 PEAK 20.598 MON/DAY 2/26	88.587 29.837 2/26	0.000 0.000 12/31	0.000 0.000 12/31	3846	344	507	867	1293	946	520	313	124	0	0	8760

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 1
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 1
 100% OUTSIDE AIR UNIT ALLYEAR
 WEATHER FILE- TRY CHICAGO

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-48.379	12 5	-4.F	-5.F	-120.007	1615.	3.805
FEB	0.00000				0.000	-41.778	8 6	5.F	4.F	-110.684	1458.	3.805
MAR	0.02939	3 15	76.F	65.F	18.945	-33.378	24 6	8.F	7.F	-107.694	1626.	3.805
APR	0.62103	28 15	78.F	68.F	44.721	-16.073	9 6	26.F	25.F	-75.526	1597.	5.848
MAY	2.64819	21 13	87.F	76.F	108.573	-8.962	7 6	33.F	29.F	-63.324	1650.	5.810
JUN	8.30279	20 18	91.F	78.F	161.118	-2.133	1 6	48.F	47.F	-35.103	1654.	5.542
JUL	27.75812	13 17	97.F	78.F	145.972	-0.167	6 6	61.F	55.F	-12.520	1758.	5.417
AUG	18.81185	26 18	93.F	75.F	109.2	-0.428	5 6	55.F	54.F	-22.176	1703.	5.836
SEP	3.66166	11 15	87.F	72.F	85.873	-6.178	23 6	36.F	33.F	-58.722	1616.	5.481
OCT	0.63547	30 19	73.F	67.F	33.535	-13.554	21 6	30.F	29.F	-69.355	1643.	5.852
NOV	0.06847	1 12	69.F	61.F	26.724	-28.486	14 10	29.F	28.F	-86.666	1561.	4.902
DEC	0.00000				0.000	-42.858	22 6	12.F	12.F	-98.674	1605.	3.805
TOTAL	62.537					-242.376					19485.	
MAX					161.118					-120.007		5.852

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 1
 REPORT- SS-I SYSTEM MONTHLY SENSIBLE LATENT SUMMARY FOR

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM : PKG ROOFTOP DESICCANT COOLER
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SEL RUN 1
 100% OUTSIDE AIR UNIT ALLYEAR
 WEATHER FILE- TRY CHICAGO

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	0.00000	0.00616	0.000			-48.37899	0.00000	-120.00713
FEB	0.00000	0.00265	0.000			-41.77792	0.00000	-110.68431
MAR	0.00000	0.04787	18.945	0.993	3 15	-33.37807	0.00000	-107.694
APR	0.52540	0.09563	44.721	0.992	28 15	-16.07310	0.00000	-75.526
MAY	2.45069	0.19749	108.573	0.991	21 13	-8.96229	0.00000	-63.324
JUN	8.06560	0.23719	161.118	0.991	20 18	-2.13270	0.00000	-35.103
JUL	27.44247	0.31565	145.972	0.993	13 17	-0.16679	0.00000	-12.520
AUG	18.50900	0.30285	109.287	0.993	26 18	-0.42839	0.00000	-22.176
SEP	3.47176	0.18989	85.873	0.993	11 15	-6.17842	0.00000	-58.722
OCT	0.50613	0.12934	33.535	0.991	30 19	-13.55433	0.00000	-69.355
NOV	0.00541	0.06307	26.724	0.992	1 12	-28.48648	0.00000	-86.666
DEC	0.00000	0.00408	0.000			-42.85814	0.00000	-98.67354
TOTAL	60.945	1.592				-242.376	0.000	
MAX			161.118	0.991				-120.007

HOUR	----- COOLING -----				--- HEATING ---			DAY COOLING PEAK			
	JUN 20				JAN 12			JUL 13			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	68.F	64.F	-103.826	5.F	4.F	30.538	0.993	76.F	66.F
2	0.000	0.000	68.F	64.F	-107.950	3.F	2.F	18.680	0.992	74.F	66.F
3	0.000	0.000	66.F	62.F	-114.279	1.F	0.F	15.222	0.992	74.F	65.F
4	0.000	0.000	66.F	62.F	-118.998	-2.F	-3.F	0.000	0.000	73.F	62.F
5	0.000	0.000	65.F	62.F	-120.007	-4.F	-5.F	0.000	0.000	72.F	62.F
6	0.000	0.000	65.F	62.F	-120.007	-5.F	-6.F	14.287	0.993	72.F	63.F
7	0.000	0.000	67.F	64.F	-119.991	-6.F	-7.F	21.575	0.992	73.F	65.F
8	0.000	0.000	73.F	65.F	-120.002	-7.F	-7.F	36.749	0.991	76.F	69.F
9	32.467	0.991	76.F	67.F	-119.271	-8.F	-8.F	57.927	0.992	82.F	72.F
10	58.579	0.992	80.F	71.F	-111.181	-7.F	-7.F	79.720	0.992	86.F	74.F
11	82.219	0.992	83.F	72.F	-97.790	-4.F	-5.F	101.353	0.992	89.F	76.F
12	103.466	0.991	84.F	74.F	-84.417	0.F	0.F	134.434	0.992	93.F	78.F
13	109.751	0.992	85.F	74.F	-73.982	4.F	2.F	136.262	0.992	95.F	78.F
14	126.316	0.992	88.F	75.F	-71.538	6.F	4.F	130.711	0.993	96.F	77.F
15	148.153	0.992	90.F	77.F	-72.750	4.F	2.F	131.647	0.993	97.F	77.F
16	154.535	0.991	90.F	78.F	-77.609	3.F	1.F	145.972	0.993	97.F	78.F
17	161.118	0.991	91.F	78.F	-87.100	1.F	0.F	144.801	0.994	99.F	77.F
18	146.005	0.992	90.F	77.F	-96.349	-2.F	-3.F	136.317	0.994	97.F	76.F
19	128.684	0.991	89.F	78.F	-94.597	-4.F	-5.F	122.701	0.994	95.F	75.F
20	91.020	0.990	79.F	74.F	-100.752	-4.F	-5.F	116.821	0.993	93.F	75.F
21	49.576	0.990	70.F	67.F	-99.767	-3.F	-4.F	105.717	0.993	90.F	74.F
22	37.594	0.990	69.F	66.F	-97.856	-3.F	-4.F	94.249	0.993	87.F	73.F
23	31.923	0.991	70.F	65.F	-97.832	-2.F	-3.F	85.562	0.992	86.F	73.F
24	25.428	0.992	71.F	64.F	-99.095	-1.F	-2.F	66.463	0.992	85.F	73.F
SUN MAX	161.118				-120.007			1927.708			

SYSTEM-TYPE	PTSGD	SQFT/TON	160.9
COOLING PEAK	74.59 (BTU/HR- SQFT)	HEATING PEAK	-55.56 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.18 (CFM/SQFT)	MIN-OA/PERSON	20.40 (CFM)
OA FRAC AT CLG PEAK	1.000	OA FRAC AT HTG PEAK	0.960

* ASTERISKS INDICATE HOURS LOADS NOT MET

SMALL BAR/LOUGE DEMO DESICCANT & EVAPORATIVE COOLING DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 1
 NEW FEATURES IN DOE2.1E RUN 1 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER 100% OUTSIDE AIR UNIT ALLYEAR
 REPORT- SS-N RELATIVE HUMIDITY SCATTER PLOT FOR SYS1 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
80-100	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	3
70-80	3	5	4	4	5	10	9	1	0	3	1	3	0	0	0	1	2	1	2	3	3	5	4	2	71	
60-70	30	26	29	28	33	40	37	28	23	17	14	9	4	3	2	3	3	6	9	13	17	23	23	26	446	
50-60	63	48	42	40	36	42	45	51	63	50	43	55	58	57	59	60	71	60	54	50	62	73	66	73	1321	
40-50	54	35	31	31	31	28	32	42	57	80	88	94	63	57	55	95	102	108	100	102	97	76	77	43	1578	
30-40	47	45	43	44	39	37	49	46	45	46	55	62	95	84	91	55	67	75	73	84	89	95	94	86	1546	
0-30	168	172	154	155	158	146	131	135	149	169	164	142	145	164	158	150	120	115	127	113	97	93	101	135	3361	
***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	*****

SMALL BAR/LOUGE DEMO DESICCANT & EVAPORATIVE COOLING DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 1
 NEW FEATURES IN DOE2.1E RUN 1 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER 100% OUTSIDE AIR UNIT ALLYEAR
 REPORT- SS-0 TEMPERATURE SCATTER PLOT SYS1 FOR BLDG WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	70	37	29	25	22	32	32	43	76	93	114	133	138	146	146	151	151	144	136	124	116	111	103	84	2256
70-75	295	294	274	278	281	270	270	259	261	271	251	232	227	219	219	214	214	221	229	241	249	254	262	281	6066
65-70	0	0	0	0	0	1	1	1	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 1
 REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 1
 100% OUTSIDE AIR UNIT ALLYEAR
 WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413./KWH	METER-1 100000./THERM
JAN			
	ENERGY CONSUMPTION (UNITS/MO)	1614.6	652.7
	PEAK DEMAND (UNITS/HR OR DAY)	3.8	1.5
	PEAK DAY/HR	1/18	1/11
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	1457.9	569.6
	PEAK DEMAND (UNITS/HR OR DAY)	3.8	1.3
	PEAK DAY/HR	1/19	4/9
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	1625.7	479.7
	PEAK DEMAND (UNITS/HR OR DAY)	3.8	1.3
	PEAK DAY/HR	1/19	24/8
APR			
	ENERGY CONSUMPTION (UNITS/MO)	1597.1	275.3
	PEAK DEMAND (UNITS/HR OR DAY)	5.8	0.9
	PEAK DAY/HR	13/19	8/11
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	1650.1	201.5
	PEAK DEMAND (UNITS/HR OR DAY)	5.8	0.8
	PEAK DAY/HR	20/22	7/6
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	1653.6	155.8
	PEAK DEMAND (UNITS/HR OR DAY)	5.5	0.9
	PEAK DAY/HR	15/20	20/18
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	1757.7	251.3
	PEAK DEMAND (UNITS/HR OR DAY)	5.4	0.8
	PEAK DAY/HR	23/22	13/18
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	1703.2	209.1
	PEAK DEMAND (UNITS/HR OR DAY)	5.8	0.8
	PEAK DAY/HR	5/24	21/18
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	1616.0	164.9
	PEAK DEMAND (UNITS/HR OR DAY)	5.5	0.7
	PEAK DAY/HR	15/21	23/6
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	1642.5	234.6
	PEAK DEMAND (UNITS/HR OR DAY)	5.9	0.8
	PEAK DAY/HR	5/22	2/8
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	1561.0	407.6
	PEAK DEMAND (UNITS/HR OR DAY)	4.9	1.1
	PEAK DAY/HR	2/20	14/11
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	1605.5	583.8
	PEAK DEMAND (UNITS/HR OR DAY)	3.8	1.2
	PEAK DAY/HR	1/19	26/10
TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	19485.0	4185.9
	PEAK DEMAND (UNITS/HR OR DAY)	5.9	1.5

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 1
REPORT- PS-D PLANT LOADS SATISFIED

DEMO DESICCANT & EVAPORATIVE COOLING
SYSTEM 1: PKG ROOFTOP DESICCANT COOLER

DOE-2.1E-001 Thu Nov 11 09.03:47 1993PDL RUN 1
100% OUTSIDE AIR UNIT ALLYEAR
WEATHER FILE- TRY CHICAGO

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	19485.0	100.0
	*****	*****
LOAD SATISFIED	19485.0	100.0
TOTAL LOAD ON PLANT	19485.2	

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 1
REPORT- PS-D PLANT LOADS SATISFIED

DEMO DESICCANT & EVAPORATIVE COOLING
SYSTEM 1: PKG ROOFTOP DESICCANT COOLER

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 1
100% OUTSIDE AIR UNIT ALLYEAR
WEATHER FILE- TRY CHICAGO
(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	66.5	66.5	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		
AREA LIGHTS	35.7	0.0
MISC EQUIPMT	16.9	0.0
SPACE HEAT	0.0	285.1
SPACE COOL	0.0	44.9
VENT FANS	13.9	0.0
DOMHOT WATER	0.0	88.6
TOTAL	66.5	418.6

TOTAL SITE ENERGY 485.09 MBTU 224.6 KBTU/SQFT-YR GROSS-AREA 224.6 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 618.12 MBTU 286.2 KBTU/SQFT-YR GROSS-AREA 286.2 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.0
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SMALL BAR/LOUZE
 NEW FEATURES IN DOE2.1E RUN 1
 REPORT- ES-D ENERGY COST SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING DOE-2.1E-001 Thu Nov 11 09:01:47 1993EDL RUN 1
 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER 100% OUTSIDE AIR UNIT ALLYEAR

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	19485. KWH	1877.	0.0963	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	4186. THERM	2717.	0.6491	YES

				4594.		
ENERGY COST/GROSS BLDG AREA:				2.13		
ENERGY COST/NET BLDG AREA:				2.13		

SMALL BAR/LOUGE DEMO DESICCANT & EVAPORATIVE COOLING DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 1
 NEW FEATURES IN DOE2.1E RUN 1 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER 100% OUTSIDE AIR UNIT ALLYEAR
 REPORT- ES-E SUMMARY OF UTILITY-RATE: ELEC-COST

UTILITY-RATE: ELEC-COST RESOURCE: ELECTRICITY DEMAND-WINDOW: HOUR 3413. BTU/KWH
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000
 POWER-FACTOR: 0.80 EXCESS-KVAR-FRAC: 0.30 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

MIN-ENERGY: 0.0 E-SH
 MAX-ENERGY: 0.0 E-WN
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	1615	1615	3.8	3.8	126	3	0	0	0	22	0	0.0932	150
FEB	1458	1458	3.8	3.8	113	3	0	0	0	22	0	0.0948	138
MAR	1626	1626	3.8	3.8	126	3	0	0	0	22	0	0.0931	151
APR	1597	1597	5.8	5.8	124	5	0	0	0	22	0	0.0944	151
MAY	1650	1650	5.8	5.8	137	5	0	0	0	22	0	0.0989	163
JUN	1654	1654	5.5	5.5	137	4	0	0	0	22	0	0.0988	163
JUL	1758	1758	5.4	5.4	146	4	0	0	0	22	0	0.0978	172
AUG	1703	1703	5.8	5.8	141	5	0	0	0	22	0	0.0984	168
SEP	1616	1616	5.5	5.5	134	4	0	0	0	22	0	0.0991	160
OCT	1643	1643	5.9	5.9	136	5	0	0	0	22	0	0.0990	163
NOV	1561	1561	4.9	4.9	121	4	0	0	0	22	0	0.0943	147
DEC	1605	1605	3.8	3.8	125	3	0	0	0	22	0	0.0933	150
TOTAL	19485	19485	5.9		1567	49	0	0	0	261		0.0963	1877

SMALL BAR/LOUVE DEMO DESICCANT & EVAPORATIVE COOLING DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 1
 NEW FEATURES IN DOE2.1E RUN 1 SYSTEM 1: PKG ROOFTOP DESICCANT COOLER 100% OUTSIDE AIR UNIT ALLYEAR
 REPORT- ES-E SUMMARY OF UTILITY-RATE: GAS-COST

UTILITY-RATE: GAS-COST RESOURCE: NATURAL-GAS DEMAND-WINDOW: HOUR 100000. BTU/THERM
 METERS: 1 2 3 4 5 BILLING-DAY: 31 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS BLOCK-CHARGES DEMAND-RATCHETS MIN-MON-RATCHETS

 MIN-ENERGY: 0.0 GAS-CH
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	653	653	1.5	1.5	382	0	0	0	0	11	0	0.6019	393
FEB	570	570	1.3	1.3	341	0	0	0	0	11	0	0.6176	352
MAR	480	480	1.3	1.3	297	0	0	0	0	11	0	0.6407	307
APR	275	275	0.9	0.9	177	0	0	0	0	11	0	0.6820	188
MAY	201	201	0.8	0.8	130	0	0	0	0	11	0	0.6963	140
JUN	156	156	0.9	0.9	100	0	0	0	0	11	0	0.7119	111
JUL	251	251	0.8	0.8	162	0	0	0	0	11	0	0.6857	172
AUG	209	209	0.8	0.8	134	0	0	0	0	11	0	0.6943	145
SEP	165	165	0.7	0.7	106	0	0	0	0	11	0	0.7081	117
OCT	235	235	0.8	0.8	151	0	0	0	0	11	0	0.6887	162
NOV	408	408	1.1	1.1	261	0	0	0	0	11	0	0.6666	272
DEC	584	584	1.2	1.2	348	0	0	0	0	11	0	0.6146	359

TOTAL	4186	4186	1.5		2588	0	0	0	0	129		0.6491	2717

Bar/Lounge — System 2

SDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993SDL RUN 2

```

* 137 *
* 138 * TITLE LINE-3 * NEW FEATURES IN DOE2.1E RUN 2 *
* 139 * LINE-4 * SYSTEM 2: PKG ROOFTOP PSZ AC UNIT *
* 140 * LINE-5 * DESICCANT COOLING OF MIN OA * ..
* 141 *
* 142 * SYSTEMS-REPORT S (SS-A,SS-J,SS-I,SS-N,SS-O) ..
* 143 *
* 144 * FANSON SCH THRU DEC 31 (MON,SAT) (1,24) (1)
* 145 * (SUN,HOL) (1,2) (1) (3,9) (0) (10,24) (1) ..
* 146 * C-SETPT SCH THRU DEC 31 (ALL) (1,24) (76) ..
* 147 * H-SETPT SCH THRU DEC 31 (ALL) (1,24) (72) ..
* 148 * ENV Z-C D-H-T 72 D-C-T 74 H-T-SCH H-SETPT C-T-SCH C-SETPT ..
* 149 *
* 150 * BLDG Z Z-C ENV O-CFM/P 20 CFM/SQFT .7 ..
* 151 *
* 152 * SYS1 SYSTEM S-TYPE PSZ DRYBULB-LIMIT=60
* 153 * SUPPLY-CFM=2500 HEATING-CAPACITY=-120000
* 154 * MAX-SUPPLY-T =100 MIN-SUPPLY-T=55
* 155 * SUPPLY-STATIC=2.5 SUPPLY-EFF=.47
* 156 * DESICCANT=LIQ-VENT-AIR-1
* 157 * DESC-DEW-SET=45 DESC-CTRL-MODE = 1
* 158 * DESICCANT-AIR=.29 REG-HEAT-SOURCE=GAS-HYDRONIC
* 159 * F-SCH=FANSON ZONE-NAMES (BLDG) ..
* 160 *
* 161 *
* 162 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (SYS1)
* 163 * DHW-CAL/MIN = .666
* 164 * DHW-SCH = DOMHW ..
* 165 *
* 166 * D1 = D-SCH (1,7) (0) (8,21) (.1..2..3..4..55..6..6..45..4..45..45..4..3..3)
* 167 * (22,24) (0) ..
* 168 * D2 = D-SCH (1,7) (0) (8,22) (.15..2..25..4..5..55..55..45..45..45..45..4..35.
* 169 * .25..2) (23,24) (0) ..
* 170 * D3 = D-SCH (1,9) (0) (10,19) (.1..25..3..35..35..3..3..35..3..2)
* 171 * (20,24) (0) ..
* 172 * DOMHW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
* 173 * END ..
* 174 * COMPUTE SYSTEMS ..
* 175 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993PDL RUN 2

- * 176 * PLANT1 = PLANT-ASSIGNMENT ..
- * 177 * PLANT-REPORT S (BEPS) ..
- * 178 * END ..
- * 179 * COMPUTE PLANT ..
- * 180 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993EDL RUN 2

```

* 181 *
* 182 * ECONOMICS-REPORT S (ES-D,ES-E) ..
* 183 *
* 184 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 185 * MONTH-CHGS = (21.75)
* 186 * DEMAND-CHGS = (.81)
* 187 * BLOCK-CHARGES = (E-SM,E-WN) ..
* 188 *
* 189 * E-SM = BLOCK-CHARGE BLOCK-SCH = SEASON
* 190 * SCH-FLAG = 2
* 191 * BLOCK1-TYPE = ENERGY
* 192 * BLOCK1-DATA = (1250,.0829)
* 193 * BLOCK2-TYPE = KWH/KW
* 194 * BLOCK2-DATA = (125,.0829,0
* 195 * 1,.0514,0) ..
* 196 *
* 197 * E-WN = BLOCK-CHARGE BLOCK-SCH = SEASON
* 198 * SCH-FLAG = 1
* 199 * BLOCK1-TYPE = ENERGY
* 200 * BLOCK1-DATA = (1250,.0778)
* 201 * BLOCK2-TYPE = KWH/KW
* 202 * BLOCK2-DATA = (125,.0778,0
* 203 * 1,.0514,0) ..
* 204 *
* 205 * SEASON = SCHEDULE THRU APR 30 (ALL) (1.24)(1)
* 206 * THRU OCT 31 (ALL) (1.24)(2)
* 207 * THRU DEC 31 (ALL) (1.24)(1) ..
* 208 *
* 209 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 210 * MONTH-CHGS = (10.73)
* 211 * BLOCK-CHARGES = (GAS-CH) ..
* 212 *
* 213 * GAS-CH = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 214 * BLOCK1-DATA = (400,.643
* 215 * 1,.4943) ..
* 216 *
* 217 * END ..
* 218 * COMPUTE ECONOMICS ..
* 219 * INPUT SYSTEMS ..

```

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE						
SYS1	PSZ		1.020	2160.0		48.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	2550.	1.561	1.9	0.	0.000	0.0	0.384	116.904	0.639	-120.000	0.36	0.37
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER
BLDG		2550.	0.	0.000	1.000	979.	0.00	0.00	52.33	0.00	-45.22	1.0

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- SS-P LOAD, ENERGY AND PART LOAD

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT
 DHW TANK OPERATION FOR PLANT1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.666 (GAL/MIN) PUMP = 0.000 (KW)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (MBTU) (KBTU/HR)	RCV EN USE (MBTU) (KBTU/HR)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM 5.160 PEAK 19.998 DAY/HR 29/14	8.354 28.991 29/14	0.000 0.000 31/24	0.000 0.000 31/24	329	26	41	16	107	70	85	30	40	0	0	744
FEB	SUM 4.837 PEAK 20.598 DAY/HR 26/14	7.807 29.837 26/14	0.000 0.000 28/24	0.000 0.000 28/24	296	24	36	13	96	65	77	27	38	0	0	672
MAR	SUM 5.390 PEAK 20.198 DAY/HR 31/14	8.675 29.273 31/14	0.000 0.000 31/24	0.000 0.000 31/24	322	27	39	12	101	77	89	31	46	0	0	744
APR	SUM 4.947 PEAK 19.198 DAY/HR 30/14	7.993 27.862 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	312	26	38	12	98	156	4	74	0	0	0	720
MAY	SUM 4.592 PEAK 17.799 DAY/HR 28/14	7.499 25.886 28/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	329	31	36	100	93	80	35	40	0	0	0	744
JUN	SUM 4.225 PEAK 16.399 DAY/HR 30/14	6.909 23.911 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	312	30	46	98	74	86	74	0	0	0	0	720
JUL	SUM 3.990 PEAK 15.199 DAY/HR 30/14	6.582 22.218 30/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	325	31	51	103	156	36	42	0	0	0	0	744
AUG	SUM 3.882 PEAK 14.799 DAY/HR 31/14	6.420 21.654 31/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	326	31	48	105	156	78	0	0	0	0	0	744
SEP	SUM 3.848 PEAK 15.199 DAY/HR 30/14	6.351 22.218 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	316	30	47	102	150	33	42	0	0	0	0	720
OCT	SUM 4.179 PEAK 16.199 DAY/HR 29/14	6.877 23.629 29/14	0.000 0.000 31/24	0.000 0.000 31/24	329	31	52	107	150	35	40	0	0	0	0	744
NOV	SUM 4.376 PEAK 17.599 DAY/HR 30/14	7.158 25.604 30/14	0.000 0.000 30/24	0.000 0.000 30/24	320	30	34	98	90	80	28	40	0	0	0	720
DEC	SUM 4.898 PEAK 18.998 DAY/HR 30/14	7.961 27.580 30/14	0.000 0.000 31/24	0.000 0.000 31/24	330	27	39	101	22	150	4	71	0	0	0	744
YR	SUM 54.324 PEAK 20.598 MON/DAY 2/26	88.587 29.837 2/26	0.000 0.000 12/31	0.000 0.000 12/31	3846	344	507	867	1293	946	520	313	124	0	0	8760

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-47.991	12 4	-2.F	-3.F	-121.226	2441.	4.980
FEB	0.00000				0.000	-41.015	8 6	5.F	4.F	-114.770	2208.	4.980
MAR	0.05082	3 15	76.F	65.F	14.347	-31.583	24 6	8.F	7.F	-111.923	2487.	5.518
APR	1.01274	28 15	78.F	68.F	32.255	-15.106	9 6	26.F	25.F	-75.362	2586.	8.214
MAY	2.66587	21 13	87.F	76.F	74.001	-7.767	7 6	33.F	29.F	-61.595	2814.	11.256
JUN	8.79381	20 18	91.F	78.F	93.640	-2.232	1 6	48.F	47.F	-30.591	3534.	15.643
JUL	21.95020	13 17	97.F	78.F	86.927	-0.350	6 6	61.F	55.F	-14.631	5070.	14.872
AUG	16.24917	26 18	93.F	75.F	72.370	-0.586	5 6	55.F	54.F	-17.116	4421.	12.881
SEP	3.91798	11 17	86.F	72.F	59.689	-5.825	23 6	36.F	33.F	-57.178	2936.	11.036
OCT	0.77089	30 19	73.F	67.F	29.478	-12.626	21 6	30.F	29.F	-69.521	2624.	8.454
NOV	0.32590	2 13	74.F	61.F	27.770	-26.657	14 10	29.F	28.F	-86.688	2398.	6.606
DEC	0.00000				0.000	-41.597	9 6	14.F	13.F	-101.200	2433.	4.980
TOTAL	55.737					-233.334					35952.	
MAX					93.640					-121.226		15.643

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- SS-1 SYSTEM MONTHLY SENSIBLE LATENT SUMMARY FOR

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	0.00000	0.00000	0.000			-47.99058	0.00000	-121.22570
FEB	0.00000	0.00000	0.000			-41.01462	0.00000	-114.77034
MAR	0.04704	0.00378	14.347	0.919	3 15	-31.58274	0.00000	-111.923
APR	0.91411	0.09863	32.255	0.913	28 15	-15.10616	0.00000	-75.362
MAY	2.30483	0.36104	74.001	0.787	21 13	-7.76678	0.00000	-61.595
JUN	7.79127	1.00253	93.640	0.755	20 18	-2.23162	0.00000	-30.591
JUL	19.30195	2.64825	86.927	0.801	13 17	-0.34957	0.00000	-14.631
AUG	14.34881	1.90036	72.370	0.813	26 18	-0.58622	0.00000	-17.116
SEP	3.17811	0.43986	59.689	0.870	11 17	-5.82491	0.00000	-57.178
OCT	0.67051	0.10038	29.478	0.819	30 19	-12.62613	0.00000	-69.521
NOV	0.30953	0.01637	27.770	0.928	2 13	-26.65744	0.00000	-86.688
DEC	0.00000	0.00000	0.000			-41.59677	0.00000	-101.20022
TOTAL	49.166	6.571				-233.334	0.000	
MAX			93.640	0.755				-121.226

HOUR	- - - - - COOLING - - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	JUN 20				JAN 12			JUL 14			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	15.209	0.869	68.F	64.F	-107.961	5.F	4.F	43.987	0.873	83.F	72.F
2	0.000	0.000	68.F	64.F	-112.781	3.F	2.F	36.373	0.879	81.F	72.F
3	0.000	0.000	66.F	62.F	-120.168	1.F	0.F	31.874	0.893	80.F	71.F
4	0.000	0.000	66.F	62.F	-121.226	-2.F	-3.F	29.731	0.882	78.F	71.F
5	0.000	0.000	65.F	62.F	-121.125	-4.F	-5.F	25.271	0.887	77.F	70.F
6	0.000	0.000	65.F	62.F	-120.862	-5.F	-6.F	36.054	0.840	78.F	71.F
7	0.000	0.000	67.F	64.F	-120.203	-6.F	-7.F	39.829	0.847	79.F	71.F
8	0.000	0.000	73.F	65.F	-120.577	-7.F	-7.F	45.173	0.865	82.F	72.F
9	22.093	0.946	76.F	67.F	-118.961	-8.F	-8.F	54.919	0.844	86.F	74.F
10	44.616	0.868	80.F	71.F	-116.338	-7.F	-7.F	58.808	0.858	88.F	74.F
11	56.471	0.862	83.F	72.F	-104.770	-4.F	-5.F	70.498	0.826	91.F	76.F
12	68.240	0.828	84.F	74.F	-89.410	0.F	0.F	79.721	0.817	94.F	76.F
13	69.922	0.833	85.F	74.F	-77.366	4.F	2.F	75.991	0.847	96.F	77.F
14	77.760	0.822	88.F	75.F	-74.479	6.F	4.F	66.073	0.875	87.F	74.F
15	88.683	0.785	90.F	77.F	-75.663	4.F	2.F	53.496	0.896	76.F	71.F
16	90.463	0.763	90.F	78.F	-80.911	3.F	1.F	60.736	0.839	78.F	72.F
17	93.640	0.755	91.F	78.F	-91.464	1.F	0.F	60.330	0.817	78.F	72.F
18	87.033	0.769	90.F	77.F	-101.802	-2.F	-3.F	69.155	0.818	89.F	75.F
19	80.527	0.753	89.F	78.F	-99.693	-4.F	-5.F	67.523	0.814	87.F	75.F
20	62.136	0.781	79.F	74.F	-106.646	-4.F	-5.F	65.174	0.807	84.F	74.F
21	36.452	0.846	70.F	67.F	-105.348	-3.F	-4.F	64.599	0.798	84.F	74.F
22	30.215	0.839	69.F	66.F	-103.151	-3.F	-4.F	62.962	0.788	82.F	74.F
23	25.895	0.846	70.F	65.F	-102.972	-2.F	-3.F	53.098	0.828	80.F	72.F
24	19.546	0.886	71.F	64.F	-104.326	-1.F	-2.F	42.011	0.848	78.F	72.F
SUM								1293.387			
MAX	93.640				-121.226						

SYSTEM-TYPE	PSZ	SQFT/TON	276.8
COOLING PEAK	43.35 (BTU/HR- SQFT)	HEATING PEAK	-56.12 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.18 (CFM/SQFT)	MIN-OA/PERSON	20.40 (CFM)
OA FRAC AT CLG PEAK	0.384	OA FRAC AT HTG PEAK	0.384

* ASTERISKS INDICATE HOURS LOADS NOT MET

SMALL BAR/LOUGE

NEW FEATURES IN DOE2.1E RUN 2

REPORT- SS-N RELATIVE HUMIDITY SCATTER PLOT FOR

DEMO DESICCANT & EVAPORATIVE COOLING

SYSTEM 2: PKG ROOFTOP PSZ AC UNIT

SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2

DESICCANT COOLING OF MIN OA

WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY

HR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
80-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
70-80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	
60-70	1	0	0	0	1	4	3	0	0	1	0	0	0	0	0	0	1	3	2	3	1	2	2	3	27	
50-60	7	9	6	10	13	23	23	9	7	3	5	11	3	2	1	6	12	7	10	10	14	26	14	9	240	
40-50	131	57	59	61	67	93	97	98	105	100	109	151	66	53	54	148	168	164	152	159	169	156	157	118	2692	
30-40	59	94	84	77	64	37	52	62	77	94	93	65	158	152	158	69	71	84	78	80	87	93	92	101	2081	
0-30	167	171	154	155	158	146	128	134	148	167	158	138	138	158	152	142	113	107	123	113	93	88	100	134	3285	
***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	*****

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- SUPL SYSTEM SUPPLEMENTAL EVAPORATIVE OR DESICCANT COOLING FOR SYS1

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PS2 AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

MONTH	TOTAL COOLING ENERGY (MBTU)	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	HOURS ON	ELECTRIC ENERGY (KWH)	GAS OIL ENERGY (MBTU)
JAN	0.00000	0.00000	0.00000	0	0.	0.00000
FEB	0.00000	0.00000	0.00000	0	0.	0.00000
MAR	0.44183	0.12643	0.31541	29	17.	1.15190
APR	2.96209	1.60152	1.36056	204	116.	6.79351
MAY	3.90973	0.96668	2.94304	249	144.	9.95194
JUN	8.92682	2.58435	6.34247	533	307.	20.52970
JUL	13.88187	0.88956	12.99232	705	411.	31.03108
AUG	12.53177	0.90114	11.63064	671	391.	29.44832
SEP	5.70114	2.40156	3.29958	360	205.	12.66627
OCT	3.29700	1.76097	1.53603	226	128.	7.46790
NOV	0.52543	0.22485	0.30058	34	19.	1.22540
DEC	0.00000	0.00000	0.00000	0	0.	0.00000
TOTAL	52.17781	11.45708	40.72067	3011	1739.	120.26609

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- SS-Q HEAT PUMP COOLING SUMMARY FOR SYS1

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PS2 AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	0.	0.000	0.000	0.126	0.000	0.000	0.000	0.000	0.000
FEB	0.	0.000	0.000	0.114	0.000	0.000	0.000	0.000	0.000
MAR	2.	0.051	0.018	0.113	0.000	0.000	0.000	0.000	0.040
APR	20.	1.013	0.346	0.058	0.000	0.000	0.000	0.000	0.554
MAY	40.	2.666	0.878	0.030	0.000	0.000	0.000	0.000	1.095
JUN	114.	8.794	2.986	0.001	0.000	0.000	0.000	0.000	2.272
JUL	217.	21.950	7.634	0.000	0.000	0.000	0.000	0.000	3.337
AUG	174.	16.249	5.518	0.000	0.000	0.000	0.000	0.000	3.111
SEP	57.	3.918	1.339	0.016	0.000	0.000	0.000	0.000	1.273
OCT	18.	0.771	0.261	0.052	0.000	0.000	0.000	0.000	0.551
NOV	8.	0.326	0.109	0.104	0.000	0.000	0.000	0.000	0.240
DEC	0.	0.000	0.000	0.127	0.000	0.000	0.000	0.000	0.000
ANNUAL	649.	55.737	19.090	0.741	0.000	0.000	0.000	0.000	12.473

CSPP (WITH PARASITICS) = 1.73 (BTU/BTU)

CSPP (WITHOUT PARASITICS) = 2.92 (BTU/BTU)

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- 99-Q HEAT PUMP HEATING SUMMARY FOR SYS1

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	400.	-47.991	68.272	0.275	0.000	0.000	0.000	0.000	3.740
FEB	342.	-41.015	58.748	0.264	0.000	0.000	0.000	0.000	3.393
MAR	263.	-31.583	46.600	0.385	0.000	0.000	0.000	0.000	3.774
APR	126.	-15.106	23.259	0.475	0.000	0.000	0.000	0.000	3.132
MAY	65.	-7.767	12.535	0.543	0.000	0.000	0.000	0.000	2.645
JUN	19.	-2.232	3.982	0.561	0.000	0.000	0.000	0.000	1.414
JUL	3.	-0.350	0.736	0.593	0.000	0.000	0.000	0.000	0.439
AUG	5.	-0.586	1.189	0.591	0.000	0.000	0.000	0.000	0.666
SEP	49.	-5.825	9.678	0.537	0.000	0.000	0.000	0.000	2.376
OCT	105.	-12.626	19.817	0.511	0.000	0.000	0.000	0.000	3.188
NOV	222.	-26.657	39.537	0.398	0.000	0.000	0.000	0.000	3.372
DEC	347.	-41.597	60.247	0.318	0.000	0.000	0.000	0.000	3.740
ANNUAL	1944.	-233.334	344.601	5.452	0.000	0.000	0.000	0.000	31.879

HSPF (WITH PARASITICS) = 0.69 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 0.68 (BTU/BTU)

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- 88-0 TEMPERATURE SCATTER PLOT

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2; PKG ROOFTOP PSZ AC UNIT
 FOR BLDG

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	81	52	40	36	32	37	41	58	88	102	124	145	155	162	166	163	161	159	153	137	133	124	120	95	2564
70-75	284	279	263	266	270	265	261	244	248	261	239	220	210	203	199	202	204	206	212	228	232	241	245	270	5752
65-70	0	0	0	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0	0	10
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- PS-8 MONTHLY UTILITY AND FUEL USE SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PS2 AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413./KWH	METER-1 100000./THERM

JAN			
	ENERGY CONSUMPTION (UNITS/MO)	2441.4	769.0
	PEAK DEMAND (UNITS/HR OR DAY)	5.0	1.7
	PEAK DAY/HR	1/18	12/10
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	2208.0	668.2
	PEAK DEMAND (UNITS/HR OR DAY)	5.0	1.6
	PEAK DAY/HR	1/19	4/ 9
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	2486.5	568.1
	PEAK DEMAND (UNITS/HR OR DAY)	5.5	1.6
	PEAK DAY/HR	2/22	24/ 8
APR			
	ENERGY CONSUMPTION (UNITS/MO)	2586.2	385.2
	PEAK DEMAND (UNITS/HR OR DAY)	8.2	1.1
	PEAK DAY/HR	27/19	9/ 6
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	2814.4	305.3
	PEAK DEMAND (UNITS/HR OR DAY)	11.3	0.9
	PEAK DAY/HR	21/13	7/ 6
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	3533.7	319.8
	PEAK DEMAND (UNITS/HR OR DAY)	15.6	0.8
	PEAK DAY/HR	20/18	9/13
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	5070.3	389.4
	PEAK DEMAND (UNITS/HR OR DAY)	14.9	0.8
	PEAK DAY/HR	13/19	2/12
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	4421.3	376.5
	PEAK DEMAND (UNITS/HR OR DAY)	12.9	0.8
	PEAK DAY/HR	15/18	11/13
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	2936.1	292.3
	PEAK DEMAND (UNITS/HR OR DAY)	11.0	0.9
	PEAK DAY/HR	11/17	23/ 6
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	2624.5	346.7
	PEAK DEMAND (UNITS/HR OR DAY)	8.5	1.0
	PEAK DAY/HR	30/19	2/ 8
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	2397.6	483.2
	PEAK DEMAND (UNITS/HR OR DAY)	6.6	1.3
	PEAK DAY/HR	2/19	14/11
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	2432.5	685.3
	PEAK DEMAND (UNITS/HR OR DAY)	5.0	1.4
	PEAK DAY/HR	1/19	26/10

TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	35952.6	5589.1
	PEAK DEMAND (UNITS/HR OR DAY)	15.6	1.7

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 2
REPORT- PS-D PLANT LOADS SATISFIED

DEMO DESICCANT & EVAPORATIVE COOLING
SYSTEM 2: PKG ROOFTOP PSZ AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 2
DESICCANT COOLING OF MIN OA
WEATHER FILE- TRY CHICAGO

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	35952.6	100.0
LOAD SATISFIED	35952.6	100.0
TOTAL LOAD ON PLANT	35953.1	

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 2
REPORT- PS-D PLANT LOADS SATISFIED

DEMO DESICCANT & EVAPORATIVE COOLING
SYSTEM 2: PKG ROOFTOP PSZ AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 2
DESICCANT COOLING OF MIN OA
WEATHER FILE- TRY CHICAGO
(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	122.7	122.7	0.000	0.000	0

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- BEPS BUILDING ENERGY PERFORMANCE SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PS2 AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 2
 DESICCANT COOLING OF MIN OA
 WEATHER FILE- TRY CHICAGO

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE -----		
AREA LIGHTS	35.7	0.0
MISC EQUIPMT	16.9	0.0
SPACE HEAT	0.0	350.1
SPACE COOL	25.0	120.3
PUMPS & MISC	0.7	0.0
VENT FANS	44.3	0.0
DOMHOT WATER	0.0	88.6
	-----	-----
TOTAL	122.7	558.9

TOTAL SITE ENERGY	681.61 MBTU	315.6 KBTU/SQFT-YR GROSS-AREA	315.6 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	927.05 MBTU	429.2 KBTU/SQFT-YR GROSS-AREA	429.2 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.1
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- ES-D ENERGY COST SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 2
 DESICCANT COOLING OF MIN OA

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	35953. KWH	3040.	0.0846	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	5589. THERM	3548.	0.6348	YES

				6588.		
ENERGY COST/GROSS BLDG AREA:				3.05		
ENERGY COST/NET BLDG AREA:				3.05		

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT
 ELEC-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 2
 DESICCANT COOLING OF MIN OA

UTILITY-RATE: ELEC-COST

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

BLOCK-CHARGES

E-SM
 E-WN

DEMAND-RATCHETS

MIN-NON-RATCHETS

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	2441	2441	5.0	5.0	175	4	0	0	0	22	0	0.0822	201
FEB	2208	2208	5.0	5.0	163	4	0	0	0	22	0	0.0855	189
MAR	2487	2487	5.5	5.5	179	4	0	0	0	22	0	0.0825	205
APR	2586	2586	8.2	8.2	193	7	0	0	0	22	0	0.0856	221
MAY	2814	2814	11.3	11.3	228	9	0	0	0	22	0	0.0921	259
JUN	3534	3534	15.6	15.6	283	13	0	0	0	22	0	0.0897	317
JUL	5070	5070	14.9	14.9	359	12	0	0	0	22	0	0.0774	392
AUG	4421	4421	12.9	12.9	317	10	0	0	0	22	0	0.0791	350
SEP	2936	2936	11.0	11.0	234	9	0	0	0	22	0	0.0901	264
OCT	2624	2624	8.5	8.5	208	7	0	0	0	22	0	0.0900	236
NOV	2398	2398	6.6	6.6	178	5	0	0	0	22	0	0.0856	205
DEC	2433	2433	5.0	5.0	174	4	0	0	0	22	0	0.0823	200

TOTAL	35953	35953	15.6		2691	89	0	0	0	261		0.0846	3040

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 2
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 2: PKG ROOFTOP PSZ AC UNIT
 GAS-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 2
 DESICCANT COOLING OF MIN OA

UTILITY-RATE: GAS-COST

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31

100000. BTU/THERM
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

BLOCK-CHARGES

GAS-CH

DEMAND-RATCHETS

MIN-MON-RATCHETS

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	769	769	1.7	1.7	440	0	0	0	0	11	0	0.5856	450
FEB	668	668	1.6	1.6	390	0	0	0	0	11	0	0.5994	400
MAR	568	568	1.6	1.6	340	0	0	0	0	11	0	0.6179	351
APR	385	385	1.1	1.1	248	0	0	0	0	11	0	0.6709	258
MAY	305	305	0.9	0.9	196	0	0	0	0	11	0	0.6781	207
JUN	320	320	0.8	0.8	206	0	0	0	0	11	0	0.6766	216
JUL	389	389	0.8	0.8	250	0	0	0	0	11	0	0.6706	261
AUG	376	376	0.8	0.8	242	0	0	0	0	11	0	0.6715	253
SEP	292	292	0.9	0.9	188	0	0	0	0	11	0	0.6797	199
OCT	347	347	1.0	1.0	223	0	0	0	0	11	0	0.6739	234
NOV	483	483	1.3	1.3	298	0	0	0	0	11	0	0.6396	309
DEC	685	685	1.4	1.4	398	0	0	0	0	11	0	0.5968	409
TOTAL	5589	5589	1.7		3419	0	0	0	0	129		0.6348	3548

Bar/Lounge — System 3

SDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993SDL RUN 3

```

* 220 *
* 221 * TITLE LINE-3 * NEW FEATURES IN DOE2.1E RUN 3 *
* 222 * LINE-4 * SYSTEM 3: STAND-ALONE EVAP COOLER *
* 223 * LINE-5 * 100% OUTSIDE AIR FOR SUMMER * ..
* 224 *
* 225 * SYSTEMS-REPORT S (SS-A,SS-J,SS-I,SS-N,SS-O) ..
* 226 *
* 227 * FANSON SCH THRU DEC 31 (MON,SAT) (1,24) (1)
* 228 * (SUN,HOL) (1,2) (1) (3,9) (0) (10,24) (1) ..
* 229 * C-SETPT SCH THRU DEC 31 (ALL) (1,24) (76) ..
* 230 * H-SETPT SCH THRU DEC 31 (ALL) (1,24) (72) ..
* 231 * ENV Z-C D-H-T 72 D-C-T 74 H-T-SCH H-SETPT C-T-SCH-C-SETPT ..
* 232 *
* 233 * BLDG 2 Z-C ENV O-CFM/P 20 CFM/SQFT .7 ..
* 234 *
* 235 * SYS1 SYSTEM S-TYPE=EVAP-COOL $ NOT A GOOD CHOICE FOR CHICAGO WEATHER
* 236 * EVAP-CL-TYPE=INDIRECT-DIRECT
* 237 * SUPPLY-CFM=3500 $ MUST BE SIZED BY THE USER
* 238 * HEATING-CAPACITY=-120000 $ MUST BE SIZED BY USER
* 239 * SUPPLY-STATIC=2.5 SUPPLY-EFF=.47
* 240 * F-SCH=FANSON Z-N=(BLDG) ..
* 241 *
* 242 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (SYS1)
* 243 * DHW-GAL/MIN = .666
* 244 * DHW-SCH = DOMHW ..
* 245 *
* 246 * D1 = D-SCH (1,7) (0) (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.45,.4,.3,.3)
* 247 * (22,24) (0) ..
* 248 * D2 = D-SCH (1,7) (0) (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.45,.4,.15,
* 249 * .25,.2) (23,24) (0) ..
* 250 * D3 = D-SCH (1,9) (0) (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
* 251 * (20,24) (0) ..
* 252 * DOMHW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
* 253 * END ..
* 254 * COMPUTE SYSTEMS ..
* 255 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993PDL RUN 3

- * 256 * PLANT1 = PLANT-ASSIGNMENT ..
- * 257 * PLANT-REPORT S (BEPS) ..
- * 258 * END ..
- * 259 * COMPUTE PLANT ..
- * 260 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993EDL RUN 3

```

* 261 *
* 262 * ECONOMICS-REPORT S (ES-D,ES-E) ..
* 263 *
* 264 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 265 * MONTH-CHGS = (21.75)
* 266 * DEMAND-CHGS = (.81)
* 267 * BLOCK-CHARGES = (E-SM,E-WN) ..
* 268 *
* 269 * E-SM = BLOCK-CHARGE BLOCK-SCH = SEASON
* 270 * SCH-FLAG = 2
* 271 * BLOCK1-TYPE = ENERGY
* 272 * BLOCK1-DATA = (1250,.0829)
* 273 * BLOCK2-TYPE = KWH/KW
* 274 * BLOCK2-DATA = (125,.0829,0
* 275 * 1,.0514,0) ..
* 276 *
* 277 * E-WN = BLOCK-CHARGE BLOCK-SCH = SEASON
* 278 * SCH-FLAG = 1
* 279 * BLOCK1-TYPE = ENERGY
* 280 * BLOCK1-DATA = (1250,.0778)
* 281 * BLOCK2-TYPE = KWH/KW
* 282 * BLOCK2-DATA = (125,.0778,0
* 283 * 1,.0514,0) ..
* 284 *
* 285 * SEASON = SCHEDULE THRU APR 30 (ALL) (1,24)(1)
* 286 * THRU OCT 31 (ALL) (1,24)(2)
* 287 * THRU DEC 31 (ALL) (1,24)(1) ..
* 288 *
* 289 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 290 * MONTH-CHGS = (10.73)
* 291 * BLOCK-CHARGES = (GAS-CH) ..
* 292 *
* 293 * GAS-CH = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 294 * BLOCK1-DATA = (400,.643
* 295 * 1,.4943) ..
* 296 * END ..
* 297 * COMPUTE ECONOMICS ..
* 298 * INPUT SYSTEMS ..

```

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 3
 100% OUTSIDE AIR FOR SUMMER
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE							
SYE1	EVAP-COOL		1.020	2160.0		48.							
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	
	3570.	2.185	1.9	0.	0.000	0.0	0.274	53.418	1.655	-120.000	0.00	0.37	
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	BLDG	3570.	0.	0.000	1.000	979.	0.00	0.00	7.43	0.00	-46.62	1.0	

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.666 (GAL/MIN) PUMP = 0.000 (KW)

MONTH		UNIT LOAD SUM (MBTU) PEAK (KBTU/HR)	ENERGY USE (MBTU) (KBTU/HR)	RCV EN USE (MBTU) (KBTU/HR)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range										TOTAL RUN HOURS	
						00	10	20	30	40	50	60	70	80	90		100
						10	20	30	40	50	60	70	80	90	100		
JAN	SUM	5.160	8.354	0.000	0.000	329	26	41	16	107	70	85	30	40	0	0	744
	PEAK	19.998	28.991	0.000	0.000												
	DAY/HR	29/14	29/14	31/24	31/24												
FEB	SUM	4.837	7.807	0.000	0.000	296	24	36	13	96	65	77	27	38	0	0	672
	PEAK	20.598	29.837	0.000	0.000												
	DAY/HR	26/14	26/14	28/24	28/24												
MAR	SUM	5.390	8.675	0.000	0.000	322	27	39	12	101	77	89	31	46	0	0	744
	PEAK	20.198	29.273	0.000	0.000												
	DAY/HR	31/14	31/14	31/24	31/24												
APR	SUM	4.947	7.993	0.000	0.000	312	26	38	12	98	156	4	74	0	0	0	720
	PEAK	19.198	27.862	0.000	0.000												
	DAY/HR	30/14	30/14	30/ 1	30/ 1												
MAY	SUM	4.592	7.499	0.000	0.000	329	31	36	100	93	80	35	40	0	0	0	744
	PEAK	17.799	25.886	0.000	0.000												
	DAY/HR	28/14	28/14	31/ 1	31/ 1												
JUN	SUM	4.225	6.909	0.000	0.000	312	30	46	98	74	86	74	0	0	0	0	720
	PEAK	16.399	23.911	0.000	0.000												
	DAY/HR	30/14	30/14	30/ 1	30/ 1												
JUL	SUM	3.990	6.582	0.000	0.000	325	31	51	103	156	36	42	0	0	0	0	744
	PEAK	15.199	22.218	0.000	0.000												
	DAY/HR	30/14	30/14	31/ 1	31/ 1												
AUG	SUM	3.882	6.420	0.000	0.000	326	31	48	105	156	78	0	0	0	0	0	744
	PEAK	14.799	21.654	0.000	0.000												
	DAY/HR	31/14	31/14	31/ 1	31/ 1												
SEP	SUM	3.848	6.351	0.000	0.000	316	30	47	102	150	33	42	0	0	0	0	720
	PEAK	15.199	22.218	0.000	0.000												
	DAY/HR	30/14	30/14	30/ 1	30/ 1												
OCT	SUM	4.179	6.877	0.000	0.000	329	31	52	107	150	35	40	0	0	0	0	744
	PEAK	16.199	23.629	0.000	0.000												
	DAY/HR	29/14	29/14	31/24	31/24												
NOV	SUM	4.376	7.158	0.000	0.000	320	30	34	98	90	80	28	40	0	0	0	720
	PEAK	17.599	25.604	0.000	0.000												
	DAY/HR	30/14	30/14	30/24	30/24												
DEC	SUM	4.898	7.961	0.000	0.000	330	27	39	101	22	150	4	71	0	0	0	744
	PEAK	18.998	27.580	0.000	0.000												
	DAY/HR	30/14	30/14	31/24	31/24												
YR	SUM	54.324	88.587	0.000	0.000	3846	344	507	867	1293	946	520	313	124	0	0	8760
	PEAK	20.598	29.837	0.000	0.000												
	MON/DAY	2/26	2/26	12/31	12/31												

MONTH	COOLING						HEATING						ELEC	
	COOLING ENERGY (KBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (KBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	0.00000				0.000	-46.346	12 6	-5.F	-6.F	-128.215	2843.	5.555		
FEB	0.00000				0.000	-39.509	8 6	5.F	4.F	-111.860	2572.	5.555		
MAR	0.04588	3 16	79.F	62.F	16.799	-29.981	24 6	8.F	7.F	-109.149	2884.	5.555		
APR	0.53425	27 18	85.F	62.F	42.204	-13.091	9 6	26.F	25.F	-72.920	2832.	7.823		
MAY	0.42676	21 13	87.F	76.F	28.965	-6.220	7 6	33.F	29.F	-59.447	2972.	9.125		
JUN	3.60564	4 16	85.F	67.F	43.629	-1.158	1 6	48.F	47.F	-28.508	3328.	9.125		
JUL	11.41452	9 18	97.F	73.F	66.965	-0.051	15 7	72.F	70.F	-6.681	4316.	9.125		
AUG	6.90245	19 15	90.F	71.F	57.125	-0.139	5 6	55.F	54.F	-14.753	3874.	9.125		
SEP	2.06907	19 16	86.F	65.F	46.036	-4.028	23 6	36.F	33.F	-55.116	3020.	9.125		
OCT	0.33634	4 17	78.F	61.F	19.307	-10.528	21 6	30.F	29.F	-67.169	2890.	7.339		
NOV	0.13317	2 16	77.F	62.F	20.356	-25.296	14 10	29.F	28.F	-84.111	2755.	5.753		
DEC	0.00000				0.000	-40.022	9 6	14.F	13.F	-98.636	2834.	5.555		
TOTAL	25.468					-216.368					37120.			
MAX					66.965					-128.215		9.125		

SMALL BAR/LOUVER
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- 88-1 SYSTEM MONTHLY SENSIBLE LATENT SUMMARY FOR

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 3
 100% OUTSIDE AIR FOR SUMMER
 WEATHER FILE- TRY CHICAGO

MONTH	SENSIBLE COOLING ENERGY (MBTU)	LATENT COOLING ENERGY (MBTU)	MAX TOTAL COOLING ENERGY (KBTU/HR)	SENSIBLE HEAT RATIO AT MAX	TIME OF MAX DY HR	SENSIBLE HEATING ENERGY (MBTU)	LATENT HEATING ENERGY (MBTU)	MAX TOTAL HEATING ENERGY (KBTU/HR)
JAN	0.00000	0.00000	0.000			-46.34553	0.00000	-128.21483
FEB	0.00000	0.00000	0.000			-39.50898	0.00000	-111.86038
MAR	0.08810	-0.04222	16.799	1.794	3 16	-29.98132	0.00000	-109.149
APR	0.91638	-0.38213	42.204	1.572	27 18	-13.09060	0.00000	-72.920
MAY	1.07030	-0.64355	28.965	1.564	21 13	-6.22016	0.00000	-59.447
JUN	7.12562	-3.51998	43.629	1.544	4 16	-1.15800	0.00000	-28.508
JUL	19.94967	-8.53515	66.965	1.488	9 18	-0.05131	0.00000	-6.681
AUG	12.60560	-5.70314	57.125	1.439	19 15	-0.13865	0.00000	-14.753
SEP	3.71848	-1.64941	46.036	1.593	19 16	-4.02763	0.00000	-55.116
OCT	0.62705	-0.29070	19.307	1.656	4 17	-10.52815	0.00000	-67.169
NOV	0.24850	-0.11533	20.356	1.679	2 16	-25.29569	0.00000	-84.111
DEC	0.00000	0.00000	0.000			-40.02211	0.00000	-98.63554
TOTAL	46.350	-20.882				-216.368	0.000	
MAX			66.965	1.488				-128.215

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- 88-J SYSTEM PEAK HEATING AND COOLING DAYS FOR

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 3
 100% OUTSIDE AIR FOR SUMMER
 WEATHER FILE- TRY CHICAGO

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
	JUL 9				JAN 12			JUL 13			
1	18.586	1.893	70.F	68.F	-105.199	5.F	4.F	13.156	1.735	76.F	66.F
2	10.921	1.994	76.F	68.F	-109.870	3.F	2.F	6.103	1.805	74.F	66.F
3	7.535	2.129	75.F	68.F	-117.055	1.F	0.F	6.024	1.759	74.F	65.F
4	2.947	2.498	73.F	67.F	-122.936	-2.F	-3.F	3.880	1.749	73.F	62.F
5	1.161	2.497	72.F	66.F	-127.213	-4.F	-5.F	1.176	1.780	72.F	62.F
6	1.330	3.219	71.F	65.F	-128.215	-5.F	-6.F	3.219	1.936	72.F	63.F
7	8.812	2.257	75.F	68.F	-127.528	-6.F	-7.F	5.452	1.953	73.F	65.F
8	14.393	2.027	77.F	69.F	-128.084	-7.F	-7.F	12.232	1.756	76.F	69.F
9	25.005 *	1.666	82.F	72.F	-123.421	-8.F	-8.F	28.616	1.505	82.F	72.F
10	28.507 *	1.604	85.F	74.F	-113.909	-7.F	-7.F	35.691 *	1.440	86.F	74.F
11	34.209 *	1.569	88.F	75.F	-98.700	-4.F	-5.F	38.948 *	1.423	89.F	76.F
12	39.769 *	1.547	91.F	76.F	-83.480	0.F	0.F	44.518 *	1.409	93.F	78.F
13	45.301 *	1.516	92.F	75.F	-71.690	4.F	2.F	50.876 *	1.390	95.F	78.F
14	49.808 *	1.537	91.F	72.F	-69.016	6.F	4.F	56.770 *	1.391	96.F	77.F
15	57.876 *	1.449	94.F	74.F	-70.299	4.F	2.F	59.700 *	1.404	97.F	77.F
16	60.383 *	1.505	95.F	73.F	-75.851	3.F	1.F	55.700 *	1.416	97.F	78.F
17	66.965 *	1.488	97.F	73.F	-86.667	1.F	0.F	62.883 *	1.432	99.F	77.F
18	64.296 *	1.488	96.F	73.F	-97.191	-2.F	-3.F	59.928 *	1.446	97.F	76.F
19	57.884 *	1.511	94.F	73.F	-95.165	-4.F	-5.F	56.467 *	1.466	95.F	75.F
20	31.683 *	1.772	84.F	70.F	-102.361	-4.F	-5.F	50.045 *	1.493	93.F	75.F
21	11.533 *	2.629	78.F	70.F	-101.305	-3.F	-4.F	41.965 *	1.568	90.F	74.F
22	1.559 *	10.802	76.F	71.F	-99.099	-3.F	-4.F	34.590 *	1.651	87.F	73.F
23	0.000	0.000	70.F	67.F	-99.160	-2.F	-3.F	32.306 *	1.647	86.F	73.F
24	0.000	0.000	70.F	67.F	-100.653	-1.F	-2.F	30.531 *	1.616	85.F	73.F
SUM								790.774			
MAX	66.965				-128.215						

SYSTEM-TYPE	EVAP-COOL	SOFT/TON	387.1
COOLING PEAK	31.00 (BTU/HR- SOFT)	HEATING PEAK	-59.36 (BTU/HR- SOFT)
SUPPLY AIR PEAK FLOW	1.65 (CFM/SOFT)	MIN-OA/PERSON	20.40 (CFM)
OA FRAC AT CLG PEAK	1.000	OA FRAC AT HTG PEAK	0.274

* ASTERISKS INDICATE HOURS LOADS NOT MET

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- SS-N RELATIVE HUMIDITY SCATTER PLOT FOR

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 3
 100% OUTSIDE AIR FOR SUMMER
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
80-100	0	1	1	2	2	2	2	0	3	3	2	0	0	0	0	0	1	1	1	1	1	2	0	1	26
70-80	16	12	12	11	9	9	10	15	19	23	25	26	28	22	25	29	23	17	16	18	19	20	23	19	446
60-70	44	32	30	31	29	30	34	28	32	33	34	37	30	38	36	33	45	50	47	44	41	39	35	37	869
50-60	46	41	36	34	36	35	30	35	40	34	38	39	39	37	37	36	32	28	39	40	41	45	49	50	917
40-50	44	37	38	36	38	41	43	41	48	47	42	45	46	50	49	50	50	52	41	43	52	52	55	50	1090
30-40	85	62	51	43	41	37	40	42	48	54	56	52	65	55	55	60	66	74	82	84	94	94	100	93	1533
0-30	130	146	135	146	148	149	144	12	147	171	168	166	157	163	163	157	148	143	139	135	117	113	103	115	3445
***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	*****

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	1	1	6	10	12	13	13	15	15	14	10	9	6	5	2	0	132
75-80	90	65	55	45	39	45	52	64	93	107	122	145	153	153	156	154	152	151	146	137	133	127	125	101	2610
70-75	275	266	248	258	264	258	251	239	243	256	237	210	200	199	196	196	198	200	209	219	226	233	238	264	5583
65-70	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 3
 100% OUTSIDE AIR FOR SUMMER
 WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413./KWH	METER-1 100000./THERM

JAN			
	ENERGY CONSUMPTION (UNITS/MO)	2042.7	747.6
	PEAK DEMAND (UNITS/HR OR DAY)	5.6	1.8
	PEAK DAY/HR	1/18	12/ 8
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	2572.3	648.5
	PEAK DEMAND (UNITS/HR OR DAY)	5.6	1.6
	PEAK DAY/HR	1/19	4/ 9
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	2883.7	534.2
	PEAK DEMAND (UNITS/HR OR DAY)	5.6	1.5
	PEAK DAY/HR	1/19	24/ 8
APR			
	ENERGY CONSUMPTION (UNITS/MO)	2832.3	284.5
	PEAK DEMAND (UNITS/HR OR DAY)	7.8	1.1
	PEAK DAY/HR	27/19	9/ 6
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	2972.1	180.2
	PEAK DEMAND (UNITS/HR OR DAY)	9.1	0.9
	PEAK DAY/HR	16/18	7/ 6
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	3328.2	95.0
	PEAK DEMAND (UNITS/HR OR DAY)	9.1	0.5
	PEAK DAY/HR	6/18	1/ 6
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	4316.4	73.2
	PEAK DEMAND (UNITS/HR OR DAY)	9.1	0.3
	PEAK DAY/HR	2/24	10/12
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	3873.8	73.6
	PEAK DEMAND (UNITS/HR OR DAY)	9.1	0.3
	PEAK DAY/HR	10/21	10/18
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	3019.8	134.8
	PEAK DEMAND (UNITS/HR OR DAY)	9.1	0.8
	PEAK DAY/HR	10/21	23/ 6
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	2889.6	237.7
	PEAK DEMAND (UNITS/HR OR DAY)	7.3	1.0
	PEAK DAY/HR	30/19	2/ 8
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	2755.1	451.9
	PEAK DEMAND (UNITS/HR OR DAY)	5.8	1.3
	PEAK DAY/HR	2/19	14/11
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	2833.6	664.5
	PEAK DEMAND (UNITS/HR OR DAY)	5.6	1.4
	PEAK DAY/HR	1/19	26/10

TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	37119.7	4125.7
	PEAK DEMAND (UNITS/HR OR DAY)	9.1	1.8

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 3
REPORT- PS-D PLANT LOADS SATISFIED

DEMO DESICCANT & EVAPORATIVE COOLING
SYSTEM 3: STAND-ALONE EVAP COOLER

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 3
100% OUTSIDE AIR FOR SUMMER
WEATHER FILE- TRY CHICAGO

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	37119.7	100.0
LOAD SATISFIED	37119.7	100.0
TOTAL LOAD ON PLANT	37120.1	

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 3
REPORT- PS-D PLANT LOADS SATISFIED

DEMO DESICCANT & EVAPORATIVE COOLING
SYSTEM 3: STAND-ALONE EVAP COOLER

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 3
100% OUTSIDE AIR FOR SUMMER
WEATHER FILE- TRY CHICAGO
(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	126.7	126.7	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		

AREA LIGHTS	35.7	0.0
MISC EQUIPMT	16.9	0.0
SPACE HEAT	0.0	324.0
SPACE COOL	12.0	0.0
VENT FANS	62.1	0.0
DOMHOT WATER	0.0	88.6
	-----	-----
TOTAL	126.7	412.6

TOTAL SITE ENERGY 539.27 MBTU 249.7 KBTU/SQFT-YR GROSS-AREA 249.7 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 792.70 MBTU 367.0 KBTU/SQFT-YR GROSS-AREA 367.0 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 3.7
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- ES-D ENERGY COST SUMMARY

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 3
 100% OUTSIDE AIR FOR SUMMER

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	37120. KWH	3002.	0.0809	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	4126. THERM	2626.	0.6365	YES

5628.

ENERGY COST/GROSS BLDG AREA: 2.61
 ENERGY COST/NET BLDG AREA: 2.61

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER
 ELEC-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 3
 100% OUTSIDE AIR FOR SUMMER

UTILITY-RATE: ELEC-COST

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

E-SM
 E-WN

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	2843	2843	5.6	5.6	197	4	0	0	0	22	0	0.0787	224
FEB	2572	2572	5.6	5.6	184	4	0	0	0	22	0	0.0816	210
MAR	2884	2884	5.6	5.6	200	4	0	0	0	22	0	0.0783	226
APR	2832	2832	7.8	7.8	204	6	0	0	0	22	0	0.0821	232
MAY	2972	2972	9.1	9.1	228	7	0	0	0	22	0	0.0865	257
JUN	3328	3328	9.1	9.1	246	7	0	0	0	22	0	0.0828	276
JUL	4316	4316	9.1	9.1	297	7	0	0	0	22	0	0.0756	326
AUG	3874	3874	9.1	9.1	274	7	0	0	0	22	0	0.0784	304
SEP	3020	3020	9.1	9.1	231	7	0	0	0	22	0	0.0860	260
OCT	2890	2890	7.3	7.3	217	6	0	0	0	22	0	0.0846	244
NOV	2755	2755	5.8	5.8	194	5	0	0	0	22	0	0.0799	220
DEC	2834	2834	5.6	5.6	197	4	0	0	0	22	0	0.0788	223
TOTAL	37120	37120	9.1		2669	72	0	0	0	261		0.0809	3002

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 3
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

DEMO DESICCANT & EVAPORATIVE COOLING
 SYSTEM 3: STAND-ALONE EVAP COOLER
 GAS-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993ED: RUN 3
 100% OUTSIDE AIR FOR SUMMER

UTILITY-RATE: GAS-COST

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31

100000. BTU/THERM
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

GAS-CH

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	748	748	1.8	1.8	429	0	0	0	0	11	0	0.5882	440
FEB	649	649	1.6	1.6	380	0	0	0	0	11	0	0.6026	391
MAR	534	534	1.5	1.5	324	0	0	0	0	11	0	0.6257	334
APR	285	285	1.1	1.1	183	0	0	0	0	11	0	0.6807	194
MAY	180	180	0.9	0.9	116	0	0	0	0	11	0	0.7025	127
JUN	95	95	0.5	0.5	61	0	0	0	0	11	0	0.7559	72
JUL	73	73	0.3	0.3	47	0	0	0	0	11	0	0.7896	58
AUG	74	74	0.3	0.3	47	0	0	0	0	11	0	0.7889	58
SEP	135	135	0.8	0.8	87	0	0	0	0	11	0	0.7226	97
OCT	238	238	1.0	1.0	153	0	0	0	0	11	0	0.6881	164
NOV	452	452	1.3	1.3	283	0	0	0	0	11	0	0.6497	294
DEC	664	664	1.4	1.4	388	0	0	0	0	11	0	0.6000	399
TOTAL	4126	4126	1.8		2497	0	0	0	0	129		0.6365	2626

Bar/Lounge — System 4

SDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993SDL RUN 4

```

* 299 *
* 300 * TITLE LINE-2 * CONVENTIONAL SYSTEM FOR COMPARISON *
* 301 * LINE-3 * NEW FEATURES IN DOE2.1E RUN 4 *
* 302 * LINE-4 * SYSTEM 4: PKG PSZ WATER COOLED UNIT *
* 303 * LINE-5 * WITH WATER SIDE ECONOMIZER * ..
* 304 *
* 305 * SYSTEMS-REPORT S (SS-A,SS-J,SS-N,SS-O) ..
* 306 *
* 307 * FANSON SCH THRU DEC 31 (MON,SAT) (1,24) (1)
* 308 * (SUN,HOL) (1,2) (1) (3,9) (0) (10,24) (1) ..
* 309 * C-SETPT SCH THRU DEC 31 (ALL) (1,24) (76) ..
* 310 * H-SETPT SCH THRU DEC 31 (ALL) (1,24) (72) ..
* 311 * ENV Z-C D-H-T 72 D-C-T 74 H-T-SCH H-SETPT C-T-SCH C-SETPT ..
* 312 *
* 313 * BLDG Z Z-C ENV O-CFM/P 20 CFM/SQFT .7 ..
* 314 *
* 315 * SYS1 SYSTEM S-TYPE=PSZ OA-CONTROL=FIXED
* 316 * SUPPLY-CFM=2500 HEATING-CAPACITY=-120000
* 317 * MAX-SUPPLY-T=100 MIN-SUPPLY-T =55
* 318 * SUPPLY-STATIC=2.5 SUPPLY-EFF=.47
* 319 * SIZING-RATIO=1.2 COOL-SIZING-RAT=.833
* 320 * HEAT-SIZING-RAT=.75
* 321 * F-SCH=FANSON ZONE-NAMES (BLDG)
* 322 * WS-ECONO = YES CONDENSER-TYPE=WATER-COOLED ..
* 323 *
* 324 * WS-ECON PLANT-ASSIGNMENT
* 325 * SYSTEM-NAMES = (SYS1)
* 326 * CIRC-PUMP-TYPE = VARIABLE-FLOW
* 327 * TWR-SET-POINT = 55 MIN-TWR-WTR-T = 55
* 328 * DHW-GAL/MIN = .666
* 329 * DHW-SCH = DOMHW ..
* 330 *
* 331 * D1 = D-SCH (1,7) (0) (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.45,.4,.3,.3)
* 332 * (22,24) (0) ..
* 333 * D2 = D-SCH (1,7) (0) (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.45,.4,.35,
* 334 * .25,.2) (23,24) (0) ..
* 335 * D3 = D-SCH (1,9) (0) (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
* 336 * (20,24) (0) ..
* 337 * DOMHW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
* 338 * END ..
* 339 * COMPUTE SYSTEMS ..
* 340 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993PDL RUN 4

* 341 *
* 342 * WS-ECON PLANT-ASSIGNMENT ..
* 343 * PLANT-REPORT S (BEPS) ..
* 344 * END ..
* 345 * COMPUTE PLANT ..
* 346 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993EDL RUN 4

```

* 347 *
* 348 * ECONOMICS-REPORT S (ES-D,ES-E) ..
* 349 *
* 350 * ELBEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 351 * MONTH-CHGS = (21.75)
* 352 * DEMAND-CHGS = (.81)
* 353 * BLOCK-CHARGES = (E-SM,E-WN) ..
* 354 *
* 355 * E-SM = BLOCK-CHARGE BLOCK-SCH = SEASON
* 356 * SCH-FLAG = 2
* 357 * BLOCK1-TYPE = ENERGY
* 358 * BLOCK1-DATA = (1250,.0829)
* 359 * BLOCK2-TYPE = KWH/KW
* 360 * BLOCK2-DATA = (125,.0829,0
* 361 * 1,.0514,0) ..
* 362 *
* 363 * E-WN = BLOCK-CHARGE BLOCK-SCH = SEASON
* 364 * SCH-FLAG = 1
* 365 * BLOCK1-TYPE = ENERGY
* 366 * BLOCK1-DATA = (1250,.0778)
* 367 * BLOCK2-TYPE = KWH/KW
* 368 * BLOCK2-DATA = (125,.0778,0
* 369 * 1,.0514,0) ..
* 370 *
* 371 * SEASON = SCHEDULE THRU APR 30 (ALL) (1,24) (1)
* 372 * THRU OCT 31 (ALL) (1,24) (2)
* 373 * THRU DEC 31 (ALL) (1,24) (1) ..
* 374 *
* 375 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 376 * MONTH-CHGS = (10.73)
* 377 * BLOCK-CHARGES = (GAS-CH) ..
* 378 *
* 379 * GAS-CH = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 380 * BLOCK1-DATA = (400,.643
* 381 * 1,.4943) ..
* 382 *
* 383 * END ..
* 384 * COMPUTE ECONOMICS ..
* 385 * INPUT SYSTEMS ..

```

SMALL BAR/LOUVE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:01:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
SYS1	PSZ	1.020	2160.0	48.									
SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)		
3060.	1.873	1.9	0.	0.000		0.320	108.735	0.792	-90.000	0.24	0.20		
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER		
BLDG	3060.	0.	0.000	1.000	979.	0.00	0.00	62.79	0.00	-45.86	1.0		

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-P LOAD, ENERGY AND PART LOAD

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PS2 WATER COOLED UNIT
 PUMP OPERATION IN WS-ECON

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

CIRC PUMP SIZE is 32.6 (GAL/MIN) POWER = 0.52 (KW) HEAT GAIN = 1612. (BTU/HR) or 0.1 (DEG F) MIN PLR = 0.50

MONTH		HEAT GAIN SUM (KBTU) PEAK (KBTU/HR)	ENERGY USE (KWH) (KW)	HEAT MODE (KWH) (KW)	COOL MODE (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
						00	10	20	30	40	50	60	70	80	90	100	
						10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM	0.320	104.160	0.000	104.160	0	0	0	0	0	744	0	0	0	0	0	744
	PEAK	0.430	0.140	0.000	0.140												
	DAY/HR	31/24	31/24	31/24	31/24												
FEB	SUM	0.289	94.080	0.000	94.080	0	0	0	0	0	672	0	0	0	0	0	672
	PEAK	0.430	0.140	0.000	0.140												
	DAY/HR	28/24	28/24	28/24	28/24												
MAR	SUM	0.323	105.313	0.000	105.313	0	0	0	0	0	741	0	0	0	0	3	744
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	3/17	3/17	31/24	3/17												
APR	SUM	0.352	114.636	0.000	114.636	0	0	0	0	0	684	0	0	0	0	36	720
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	29/21	29/21	30/1	29/21												
MAY	SUM	0.371	120.822	0.000	120.822	0	0	0	0	0	699	1	1	1	0	42	744
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	31/13	31/13	31/1	31/13												
JUN	SUM	0.524	170.429	0.000	170.429	0	0	0	0	0	528	12	3	2	4	171	720
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	30/23	30/23	30/1	30/23												
JUL	SUM	0.666	216.732	0.000	216.732	0	0	0	0	0	369	61	51	29	3	231	744
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	31/24	31/24	31/1	31/24												
AUG	SUM	0.712	199.099	0.000	199.099	0	0	0	0	0	450	44	24	4	0	222	744
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	31/13	31/13	31/1	31/13												
SEP	SUM	0.391	127.194	0.000	127.194	0	0	0	0	0	647	7	0	0	0	66	720
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	26/19	26/19	30/1	26/19												
OCT	SUM	0.347	113.000	0.000	113.000	0	0	0	0	0	721	0	0	0	0	23	744
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	31/20	31/20	31/24	31/20												
NOV	SUM	0.326	106.180	0.000	106.180	0	0	0	0	0	706	0	0	0	0	14	720
	PEAK	1.611	0.524	0.000	0.524												
	DAY/HR	2/19	2/19	30/24	2/19												
DEC	SUM	0.320	104.160	0.000	104.160	0	0	0	0	0	744	0	0	0	0	0	744
	PEAK	0.430	0.140	0.000	0.140												
	DAY/HR	31/24	31/24	31/24	31/24												
YR	SUM	4.840	1575.895	0.000	1575.895	0	0	0	0	0	7705	125	79	36	7	808	8760
	PEAK	1.611	0.524	0.000	0.524												
	MON/DAY	11/2	11/2	12/31	11/2												

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-P LOAD, ENERGY AND PART LOAD

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PS2 WATER COOLED UNIT
 COOLING TOWER FOR WS-ECON

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

TOWER SIZE is 0.131 (MBTU/HR) FAN = 0.43 (KW) PUMP = 0.18 (KW) PUMP = 32.63 (GAL/MIN)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR)	ENERGY USE (KWH) (KW)	FAN ENERGY (KWH) (KW)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS	
					00	10	20	30	40	50	60	70	80	90	100		
					10	20	30	40	50	60	70	80	90	100	+		
JAN	SUM 0.320 PEAK 0.437 DAY/HR 26/24	266.200 0.499 30/16	134.188 0.322 30/16	132.012 0.177 31/24	744	0	0	0	0	0	0	0	0	0	0	0	744
FEB	SUM 0.289 PEAK 0.437 DAY/HR 28/14	237.945 0.478 28/13	118.709 0.301 28/13	119.237 0.177 28/24	672	0	0	0	0	0	0	0	0	0	0	0	672
MAR	SUM 0.390 PEAK 12.142 DAY/HR 9/14	296.007 0.612 9/15	163.996 0.434 9/15	132.012 0.177 31/24	720	13	3	3	1	0	1	0	0	1	2	744	
APR	SUM 1.712 PEAK 3.010 DAY/HR 30/21	344.443 0.612 30/20	217.438 0.434 30/20	127.003 0.177 30/ 1	615	41	12	9	1	0	0	0	2	20	20	720	
MAY	SUM 3.770 PEAK 2.696 DAY/HR 31/22	400.941 0.612 31/23	272.418 0.434 31/23	128.522 0.177 31/ 1	596	53	11	6	0	1	0	1	6	37	33	744	
JUN	SUM 13.370 PEAK 60.142 DAY/HR 30/17	426.133 0.612 30/ 1	306.926 0.434 30/ 1	119.205 0.177 30/ 1	368	72	15	0	0	0	0	0	9	126	130	720	
JUL	SUM 34.662 PEAK -0.035 DAY/HR 31/ 1	432.348 0.612 31/ 1	322.987 0.434 31/ 1	109.357 0.177 31/ 1	170	30	7	4	0	0	0	0	15	245	273	744	
AUG	SUM 24.834 PEAK -0.701 DAY/HR 31/ 1	434.350 0.612 31/ 1	322.949 0.434 31/ 1	111.398 0.177 31/ 1	226	53	11	2	1	1	0	1	10	203	236	744	
SEP	SUM 5.836 PEAK 9.048 DAY/HR 29/ 2	402.971 0.612 28/ 1	279.971 0.434 28/ 1	122.999 0.177 30/ 1	525	66	10	3	2	0	1	1	4	46	62	720	
OCT	SUM 1.207 PEAK 40.450 DAY/HR 31/15	372.422 0.612 31/24	241.035 0.434 31/24	131.386 0.177 31/24	665	43	3	3	1	0	0	1	0	14	14	744	
NOV	SUM 0.780 PEAK 5.029 DAY/HR 24/ 2	299.540 0.612 24/ 3	171.787 0.434 24/ 3	127.753 0.177 30/24	688	14	3	1	0	0	0	0	0	5	9	720	
DEC	SUM 0.320 PEAK 0.433 DAY/HR 15/14	267.713 0.422 15/12	135.702 0.244 15/12	132.012 0.177 31/24	744	0	0	0	0	0	0	0	0	0	0	744	
YR	SUM 87.495 PEAK 5.029 MON/DAY 11/24	4181.049 0.612 11/24	2687.974 0.434 11/24	1493.013 0.177 12/31	6733	385	75	31	6	2	2	4	46	697	779	8760	

WSE TOWER SIZE is 0.0000 (MBTU/HR) POWER = 0.00 (KW) PUMP = 12.63 (GAL/MIN)

MONTH	UNIT LOAD		ENERGY USE		Number of hours within each PART LOAD range										TOTAL RUN HOURS		
	SUM (MBTU)	PEAK (KBTU/HR)	(KWH)	(KW)	00	10	20	30	40	50	60	70	80	90		100	
					10	20	30	40	50	60	70	80	90	100		+	
JAN	SUM	0.000	0.000		0	0	0	0	0	0	0	0	0	0	0		
	PEAK	0.000	0.000														
	DAY/HR	31/24	31/24														
FEB	SUM	0.000	0.000		0	0	0	0	0	0	0	0	0	0	0		
	PEAK	0.000	0.000														
	DAY/HR	28/24	28/24														
MAR	SUM	0.100	0.000		2	1	0	0	0	1	1	0	1	0	3	9	
	PEAK	22.366	0.000														
	DAY/HR	3/17	31/24														
APR	SUM	1.333	0.000		20	16	12	9	3	13	13	4	3	1	36	130	
	PEAK	24.376	0.000														
	DAY/HR	26/15	30/ 1														
MAY	SUM	1.534	0.000		26	37	17	16	15	16	7	5	4	2	42	187	
	PEAK	24.512	0.000														
	DAY/HR	23/15	31/ 1														
JUN	SUM	4.829	0.000		29	21	22	20	24	25	19	20	13	17	171	381	
	PEAK	29.525	0.000														
	DAY/HR	26/20	30/ 1														
JUL	SUM	4.173	0.000		6	10	11	6	13	11	15	9	13	13	231	338	
	PEAK	23.922	0.000														
	DAY/HR	12/12	31/ 1														
AUG	SUM	4.534	0.000		9	12	9	15	15	13	15	17	22	16	222	365	
	PEAK	25.767	0.000														
	DAY/HR	31/13	31/ 1														
SEP	SUM	2.764	0.000		22	22	18	15	20	23	17	12	8	15	66	238	
	PEAK	24.713	0.000														
	DAY/HR	6/18	30/ 1														
OCT	SUM	1.344	0.000		13	9	17	18	10	8	10	9	4	3	23	124	
	PEAK	23.806	0.000														
	DAY/HR	4/17	31/24														
NOV	SUM	0.461	0.000		3	2	3	3	5	0	2	0	3	0	14	35	
	PEAK	23.395	0.000														
	DAY/HR	1/17	30/24														
DEC	SUM	0.000	0.000		0	0	0	0	0	0	0	0	0	0	0	0	
	PEAK	0.000	0.000														
	DAY/HR	31/24	31/24														
YR	SUM	21.073	0.000		130	130	109	102	105	110	99	76	71	67	808	1807	
	PEAK	29.525	0.000														
	MON/DAY	6/26	12/31														

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1R RUN 4
 REPORT- SS-P LOAD, ENERGY AND PART LOAD

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT
 TANK OPERATION FOR WS-ECON

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.666 (GAL/MIN) PUMP = 0.000 (KW)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (MBTU) (KBTU/HR)	RCV EN USE (MBTU) (KBTU/HR)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM 5.160 PEAK 19.998 DAY/HR 29/14	8.354 28.991 29/14	0.000 0.000 31/24	0.000 0.000 31/24	329	26	41	16	107	70	85	30	40	0	0	744
FEB	SUM 4.837 PEAK 20.598 DAY/HR 26/14	7.807 29.837 26/14	0.000 0.000 28/24	0.000 0.000 28/24	296	24	36	13	96	65	77	27	38	0	0	672
MAR	SUM 5.390 PEAK 20.198 DAY/HR 31/14	8.675 29.273 31/14	0.000 0.000 31/24	0.000 0.000 31/24	322	27	39	12	101	77	89	31	46	0	0	744
APR	SUM 4.947 PEAK 19.198 DAY/HR 30/14	7.993 27.862 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	312	26	38	12	98	156	4	74	0	0	0	720
MAY	SUM 4.592 PEAK 17.799 DAY/HR 28/14	7.499 25.886 28/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	329	31	36	100	93	80	35	40	0	0	0	744
JUN	SUM 4.225 PEAK 16.399 DAY/HR 30/14	6.909 23.911 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	312	30	46	98	74	86	74	0	0	0	0	720
JUL	SUM 3.990 PEAK 15.199 DAY/HR 30/14	6.582 22.218 30/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	325	31	51	103	156	36	42	0	0	0	0	744
AUG	SUM 3.882 PEAK 14.799 DAY/HR 31/14	6.420 21.654 31/14	0.000 0.000 31/ 1	0.000 0.000 31/ 1	326	31	48	105	156	78	0	0	0	0	0	744
SEP	SUM 3.848 PEAK 15.199 DAY/HR 30/14	6.351 22.218 30/14	0.000 0.000 30/ 1	0.000 0.000 30/ 1	316	30	47	102	150	33	42	0	0	0	0	720
OCT	SUM 4.179 PEAK 16.199 DAY/HR 29/14	6.877 23.629 29/14	0.000 0.000 31/24	0.000 0.000 31/24	329	31	52	107	150	35	40	0	0	0	0	744
NOV	SUM 4.376 PEAK 17.599 DAY/HR 30/14	7.158 25.604 30/14	0.000 0.000 30/24	0.000 0.000 30/24	320	30	34	98	90	80	28	40	0	0	0	720
DEC	SUM 4.898 PEAK 18.998 DAY/HR 30/14	7.961 27.580 30/14	0.000 0.000 31/24	0.000 0.000 31/24	330	27	39	101	22	150	4	71	0	0	0	744
YR	SUM 54.324 PEAK 20.598 MON/DAY 2/26	88.587 29.837 2/26	0.000 0.000 12/31	0.000 0.000 12/31	3846	344	507	867	1293	946	520	313	124	0	0	8760

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	0.00000				0.000	-45.309	12 18	-2.F	-3.F	-92.450	2661.	5.293		
FEB	0.00000				0.000	-39.493	8 3	9.F	8.F	-91.980	2407.	5.293		
MAR	0.00639	3 15	76.F	65.F	3.853	-30.343	24 5	9.F	8.F	-91.648	2688.	5.293		
APR	0.58648	28 15	78.F	68.F	44.883	-13.491	9 6	26.F	25.F	-72.588	2627.	7.425		
MAY	2.28592	21 13	87.F	76.F	93.760	-6.579	7 6	33.F	29.F	-59.385	2787.	9.728		
JUN	8.11245	20 18	91.F	78.F	112.399	-1.245	1 6	48.F	47.F	-29.239	3127.	12.925		
JUL	24.90770	13 17	97.F	78.F	110.030	-0.030	6 6	61.F	55.F	-6.280	4365.	12.357		
AUG	17.07346	26 17	94.F	76.F	93.576	-0.144	5 6	55.F	54.F	-16.026	3809.	11.558		
SEP	3.56490	11 17	86.F	72.F	77.527	-4.315	23 6	36.F	33.F	-55.146	2798.	9.945		
OCT	0.43696	30 19	73.F	67.F	39.738	-10.944	21 6	30.F	29.F	-66.940	2670.	7.836		
NOV	0.13079	2 13	74.F	61.F	22.670	-25.690	14 11	29.F	27.F	-81.603	2567.	5.293		
DEC	0.00000				0.000	-40.307	22 5	12.F	12.F	-91.038	2652.	5.293		
TOTAL	57.105					-217.890					35157.			
MAX					112.399					-92.450		12.925		

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-J SYSTEM PEAK HEATING AND COOLING DAYS FOR

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

HOUR	- - - - COOLING - - - -				- - - HEATING - - -			DAY COOLING PEAK			
	JUN 20				JAN 12			JUL 14			
	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KBTU)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KBTU)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
1	0.000	0.000	68.F	64.F	-92.321	5.F	4.F	57.778	0.629	83.F	72.F
2	0.000	0.000	68.F	64.F	-91.678	3.F	2.F	46.946	0.598	81.F	72.F
3	0.000	0.000	66.F	62.F	-92.169	1.F	0.F	41.182	0.602	80.F	71.F
4	0.000	0.000	66.F	62.F	-92.120	-2.F	-3.F	36.757	0.567	78.F	71.F
5	0.000	0.000	65.F	62.F	-91.835	-4.F	-5.F	31.531	0.575	77.F	70.F
6	0.000	0.000	65.F	62.F	-91.519	-5.F	-6.F	45.209	0.554	78.F	71.F
7	0.000	0.000	67.F	64.F	-90.621	-6.F	-7.F	50.389	0.581	79.F	71.F
8	0.000	0.000	73.F	65.F	-91.059	-7.F	-7.F	58.645	0.616	82.F	72.F
9	13.632	0.601	76.F	67.F	-89.166	-8.F	-8.F	71.819	0.622	86.F	74.F
10	58.000	0.612	80.F	71.F	-88.107	-7.F	-7.F	76.722	0.656	88.F	74.F
11	73.067	0.641	83.F	72.F	-86.549	-4.F	-5.F	91.147	0.642	91.F	76.F
12	86.662	0.617	84.F	74.F	-85.944	0.F	0.F	101.045	0.669	94.F	76.F
13	88.746	0.630	85.F	74.F	-86.327	4.F	2.F	97.068	0.694	96.F	77.F
14	98.444	0.639	88.F	75.F	-85.853	6.F	4.F	84.631	0.676	87.F	74.F
15	111.039	0.612	90.F	77.F	-85.468	4.F	2.F	66.646	0.625	76.F	71.F
16	111.027	0.595	90.F	78.F	-89.107	3.F	1.F	75.863	0.595	78.F	72.F
17	112.399	0.605	91.F	78.F	-91.800	1.F	0.F	75.282	0.577	78.F	72.F
18	104.465	0.617	90.F	77.F	-92.450	-2.F	-3.F	88.265	0.634	89.F	75.F
19	97.823	0.577	89.F	78.F	-90.242	-4.F	-5.F	85.882	0.616	87.F	75.F
20	73.346	0.553	79.F	74.F	-91.445	-4.F	-5.F	82.119	0.599	84.F	74.F
21	44.626	0.588	70.F	67.F	-90.104	-3.F	-4.F	81.383	0.591	84.F	74.F
22	38.037	0.578	69.F	66.F	-89.718	-3.F	-4.F	78.451	0.568	82.F	74.F
23	18.430	0.543	70.F	65.F	-89.955	-2.F	-3.F	66.057	0.594	80.F	72.F
24	12.885	0.594	71.F	64.F	-90.298	-1.F	-2.F	52.171	0.561	78.F	72.F
SUM								1642.990			
MAX	112.399				-92.450						

SYSTEM-TYPE	PSZ	SQFT/TON	230.6
COOLING PEAK	52.04 (BTU/HR- SQFT)	HEATING PEAK	-42.80 (BTU/HR- SQFT)
SUPPLY AIR PEAK FLOW	1.42 (CFM/SQFT)	MIN-OA/PERSON	20.40 (CFM)
OA FRAC AT CLG PEAK	0.320	OA FRAC AT HTG PEAK	0.320

* ASTERISKS INDICATE HOURS LOADS NOT MET

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-N RELATIVE HUMIDITY SCATTER PLOT FOR

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
80-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
70-80	3	2	4	3	4	11	4	1	0	2	1	2	0	0	0	0	2	1	1	4	5	10	8	2	70	
60-70	39	30	35	32	33	39	42	33	34	22	18	13	8	1	3	8	9	11	15	22	26	31	33	29	566	
50-60	57	45	34	37	38	41	43	47	61	68	65	76	40	41	42	58	85	69	71	84	87	85	76	73	1423	
40-50	49	36	31	30	31	30	34	41	47	59	68	76	102	106	101	95	78	93	75	58	62	54	52	41	1449	
30-40	51	47	45	46	39	36	52	49	47	49	49	56	75	56	61	57	74	79	77	83	92	98	96	85	1499	
0-30	166	171	154	155	158	146	128	132	148	165	164	142	140	161	158	147	117	112	126	114	93	87	100	135	3319	
*** **																										

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-Q HEAT PUMP COOLING SUMMARY FOR SYS1

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	0.	0.000	0.000	0.126	0.000	0.000	0.000	0.000	0.000
FEB	0.	0.000	0.000	0.114	0.000	0.000	0.000	0.000	0.000
MAR	1.	0.006	0.002	0.113	0.000	0.000	0.000	0.000	0.089
APR	11.	0.586	0.144	0.058	0.000	0.000	0.000	0.000	0.908
MAY	26.	2.286	0.528	0.030	0.000	0.000	0.000	0.000	1.409
JUN	92.	8.112	1.906	0.001	0.000	0.000	0.000	0.000	2.733
JUL	242.	24.908	5.874	0.000	0.000	0.000	0.000	0.000	3.938
AUG	174.	17.073	4.008	0.000	0.000	0.000	0.000	0.000	3.618
SEP	39.	3.565	0.837	0.016	0.000	0.000	0.000	0.000	1.732
OCT	7.	0.437	0.106	0.052	0.000	0.000	0.000	0.000	0.911
NOV	4.	0.131	0.033	0.104	0.000	0.000	0.000	0.000	0.275
DEC	0.	0.000	0.000	0.127	0.000	0.000	0.000	0.000	0.000
ANNUAL	595.	57.105	13.438	0.741	0.000	0.000	0.000	0.000	15.613

CSPF (WITH PARASITICS) = 1.92 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 4.25 (BTU/BTU)

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-Q HEAT PUMP HEATING SUMMARY FOR SYS1

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	503.	-45.309	63.041	0.192	0.000	0.000	0.000	0.000	4.487
FEB	439.	-39.493	55.190	0.187	0.000	0.000	0.000	0.000	4.072
MAR	337.	-30.343	43.695	0.325	0.000	0.000	0.000	0.000	4.487
APR	150.	-13.491	20.031	0.456	0.000	0.000	0.000	0.000	3.516
MAY	73.	-6.579	10.175	0.537	0.000	0.000	0.000	0.000	3.078
JUN	14.	-1.245	2.037	0.565	0.000	0.000	0.000	0.000	1.691
JUL	0.	-0.030	0.066	0.595	0.000	0.000	0.000	0.000	0.594
AUG	2.	-0.144	0.272	0.594	0.000	0.000	0.000	0.000	0.914
SEP	48.	-4.315	6.771	0.538	0.000	0.000	0.000	0.000	2.646
OCT	122.	-10.944	16.527	0.498	0.000	0.000	0.000	0.000	3.576
NOV	285.	-25.690	37.196	0.348	0.000	0.000	0.000	0.000	4.059
DEC	448.	-40.307	56.987	0.237	0.000	0.000	0.000	0.000	4.487
ANNUAL	2421.	-217.890	311.987	5.071	0.000	0.000	0.000	0.000	37.609

HSPF (WITH PARASITICS) = 0.72 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 0.70 (BTU/BTU)

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- SS-O TEMPERATURE SCATTER PLOT

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT
 FOR BLDG

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	84	54	43	37	34	41	45	60	89	105	124	151	160	164	166	167	165	163	156	140	136	129	122	98	2633
70-75	270	263	246	251	253	244	242	228	236	243	230	207	201	197	196	195	196	198	205	220	225	232	240	261	5479
65-70	8	10	11	10	11	13	11	10	7	12	6	4	2	3	3	3	4	3	3	4	3	3	2	4	150
60-65	3	4	3	4	4	4	4	5	5	4	4	3	2	1	0	0	0	1	1	1	1	1	1	2	58
BELOW 60	0	0	0	1	1	1	1	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	6

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 4
 WITH WATER SIDE ECONOMIZER
 WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413./KWH	METER-1 100000./THERM

JAN			
	ENERGY CONSUMPTION (UNITS/MO)	3030.9	715.9
	PEAK DEMAND (UNITS/HR OR DAY)	5.9	1.5
	PEAK DAY/HR	30/19	8/14
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	2738.9	631.8
	PEAK DEMAND (UNITS/HR OR DAY)	5.9	1.5
	PEAK DAY/HR	27/21	11/12
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	3089.8	527.0
	PEAK DEMAND (UNITS/HR OR DAY)	6.0	1.5
	PEAK DAY/HR	2/19	24/13
APR			
	ENERGY CONSUMPTION (UNITS/MO)	3086.0	284.8
	PEAK DEMAND (UNITS/HR OR DAY)	8.0	1.0
	PEAK DAY/HR	28/20	9/ 6
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	3308.8	182.1
	PEAK DEMAND (UNITS/HR OR DAY)	10.7	0.9
	PEAK DAY/HR	21/13	7/ 6
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	3723.2	95.1
	PEAK DEMAND (UNITS/HR OR DAY)	14.0	0.5
	PEAK DAY/HR	20/18	1/ 6
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	5013.9	72.4
	PEAK DEMAND (UNITS/HR OR DAY)	13.4	0.2
	PEAK DAY/HR	13/19	1/13
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	4442.3	72.9
	PEAK DEMAND (UNITS/HR OR DAY)	12.5	0.3
	PEAK DAY/HR	15/18	5/ 6
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	3327.8	136.6
	PEAK DEMAND (UNITS/HR OR DAY)	10.8	0.8
	PEAK DAY/HR	11/17	23/ 6
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	3155.1	239.0
	PEAK DEMAND (UNITS/HR OR DAY)	8.5	1.0
	PEAK DAY/HR	30/19	2/ 8
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	2973.1	447.0
	PEAK DEMAND (UNITS/HR OR DAY)	6.4	1.2
	PEAK DAY/HR	2/19	14/11
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	3023.5	651.9
	PEAK DEMAND (UNITS/HR OR DAY)	5.8	1.3
	PEAK DAY/HR	13/19	25/11

TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	40913.4	4056.4
	PEAK DEMAND (UNITS/HR OR DAY)	14.0	1.5

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 4
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL SYSTEM FOR COMPARISON
SYSTEM 4: PKG PS2 WATER COOLED UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 4
WITH WATER SIDE ECONOMIZER
WEATHER FILE- TRY CHICAGO

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	40913.4	100.0
LOAD SATISFIED	40913.4	100.0
TOTAL LOAD ON PLANT	40912.7	

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 4
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL SYSTEM FOR COMPARISON
SYSTEM 4: PKG PSZ WATER COOLED UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 4
WITH WATER SIDE ECONOMIZER
WEATHER FILE- TRY CHICAGO
----- (CONTINUED) -----

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	139.6	139.6	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		

AREA LIGHTS	35.7	0.0
MISC EQUIPMT	16.9	0.0
SPACE HEAT	0.0	317.1
SPACE COOL	13.4	0.0
HEAT REJECT	14.3	0.0
PUMPS & MISC	6.1	0.0
VENT FANS	53.2	0.0
DOMHOT WATER	0.0	88.6
	-----	-----
TOTAL	139.6	405.6

TOTAL SITE ENERGY	545.28 MBTU	252.4 KBTU/SQFT-YR GROSS-AREA	252.4 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	824.61 MBTU	381.8 KBTU/SQFT-YR GROSS-AREA	381.8 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 2.6
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SMALL BAR/LOUVE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- ES-D ENERGY COST SUMMARY

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PS2 WATER COOLED UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 4
 WITH WATER SIDE ECONOMIZER

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	40913. KWH	3286.	0.0803	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	4056. THERM	2592.	0.6391	YES

5878.

ENERGY COST/GROSS BLDG AREA: 2.72
 ENERGY COST/NET BLDG AREA: 2.72

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PS2 WATER COOLED UNIT
 ELEC-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 4
 WITH WATER SIDE ECONOMIZER

UTILITY-RATE: ELEC-COST

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

BLOCK-CHARGES

E-SM
 E-WN

DEMAND-RATCHETS

MIN-MON-RATCHETS

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHR (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	3031	3031	5.9	5.9	208	5	0	0	0	22	0	0.0775	235
FEB	2739	2739	5.9	5.9	193	5	0	0	0	22	0	0.0802	220
MAR	3090	3090	6.0	6.0	212	5	0	0	0	22	0	0.0771	238
APR	3086	3086	8.0	8.0	218	7	0	0	0	22	0	0.0799	246
MAY	3309	3309	10.7	10.7	252	9	0	0	0	22	0	0.0852	282
JUN	3723	3723	14.0	14.0	286	11	0	0	0	22	0	0.0857	319
JUL	5014	5014	13.4	13.4	350	11	0	0	0	22	0	0.0763	382
AUG	4442	4442	12.5	12.5	317	10	0	0	0	22	0	0.0785	349
SEP	3328	3328	10.8	10.8	253	9	0	0	0	22	0	0.0851	283
OCT	3155	3155	8.5	8.5	235	7	0	0	0	22	0	0.0835	264
NOV	2973	2973	6.4	6.4	207	5	0	0	0	22	0	0.0787	234
DEC	3024	3024	5.8	5.8	208	5	0	0	0	22	0	0.0774	234
TOTAL	40913	40913	14.0		2938	87	0	0	0	261		0.0803	3286

SMALL BAR/LOUOE
 NEW FEATURES IN DOE2.1E RUN 4
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

CONVENTIONAL SYSTEM FOR COMPARISON
 SYSTEM 4: PKG PSZ WATER COOLED UNIT
 GAS-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 4
 WITH WATER SIDE ECONOMIZER

UTILITY-RATE: GAS-COST

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31

100000. BTU/THERM
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

BLOCK-CHARGES

GAS-CH

DEMAND-RATCHETS

MIN-MON-RATCHETS

MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	716	716	1.5	1.5	413	0	0	0	0	11	0	0.5924	424
FEB	632	632	1.5	1.5	372	0	0	0	0	11	0	0.6054	383
MAR	527	527	1.5	1.5	320	0	0	0	0	11	0	0.6275	331
APR	285	285	1.0	1.0	183	0	0	0	0	11	0	0.6807	194
MAY	182	182	0.9	0.9	117	0	0	0	0	11	0	0.7019	128
JUN	95	95	0.5	0.5	61	0	0	0	0	11	0	0.7558	72
JUL	72	72	0.2	0.2	47	0	0	0	0	11	0	0.7911	57
AUG	73	73	0.3	0.3	47	0	0	0	0	11	0	0.7903	58
SEP	137	137	0.8	0.8	88	0	0	0	0	11	0	0.7215	99
OCT	239	239	1.0	1.0	154	0	0	0	0	11	0	0.6879	164
NOV	447	447	1.2	1.2	280	0	0	0	0	11	0	0.6514	291
DEC	652	652	1.3	1.3	382	0	0	0	0	11	0	0.6020	392
TOTAL	4056	4056	1.5		2464	0	0	0	0	129		0.6391	2592

Bar/Lounge — System 5

SDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993SDL RUN 5

```

* 386 *
* 387 * TITLE LINE-2 * CONVENTIONAL VS PVVT COMPARISON *
* 388 * LINE-3 * NEW FEATURES IN DOE2.1E RUN 5 *
* 389 * LINE-4 * SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT*
* 390 * LINE-5 * EVAPORATIVE PRECOOLED CONDENSER * ..
* 391 *
* 392 * SYSTEMS-REPORT  S (SS-A,SS-J,SS-N,SS-O) ..
* 393 *
* 394 * FANSON  SCH THRU DEC 31 (MON,SAT) (1,24) (1)
* 395 *                (SUN,HOL) (1,2) (1) (3,9) (0) (10,24) (1) ..
* 396 * C-SETPT SCH THRU DEC 31 (ALL) (1,24) (76) ..
* 397 * H-SETPT SCH THRU DEC 31 (ALL) (1,24) (72) ..
* 398 * ENV  Z-C  D-H-T 72  D-C-T 74  H-T-SCH H-SETPT  C-T-SCH C-SETPT  ..
* 399 *
* 400 * BLDG 2  Z-C ENV  O-CFM/P 20  CFM/SQFT .7  ..
* 401 *
* 402 * SYS1  SYSTEM  S-TYPE=PVVT      OA-CONTROL=FIXED
* 403 *                SUPPLY-CFM=2500  HEATING-CAPACITY=-120000
* 404 *                MAX-SUPPLY-T=100  MIN-SUPPLY-T =55
* 405 *                SUPPLY-STATIC=2.5  SUPPLY-EFF=.47
* 406 *                F-SCH=FANSON     ZONE-NAMES (BLDG)
* 407 *                HEAT-SOURCE = GAS-HEAT-PUMP
* 408 *                ZONE-HEAT-SOURCE = GAS-HEAT-PUMP
* 409 *                CONDENSER-TYPE = EVAP-PRECOOLED
* 410 *                EVAP-PCC-SCH = SUMMER-ONLY
* 411 *                EVAP-PCC-EFF = .6
* 412 *                EVAP-PCC-ELEC = .01  ..
* 413 *
* 414 * WS-ECON  PLANT-ASSIGNMENT
* 415 *                SYSTEM-NAMES = (SYS1)
* 416 *                DHW-GAL/MIN = .666
* 417 *                DHW-SCH      = DOMHW  ..
* 418 *
* 419 * D1 = D-SCH (1.7) (0) (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.45,.4,.3,.3)
* 420 *                (22,24) (0) ..
* 421 * D2 = D-SCH (1.7) (0) (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.45,.4,.35,
* 422 *                .25,.2) (23,24) (0) ..
* 423 * D3 = D-SCH (1.9) (0) (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
* 424 *                (20,24) (0) ..
* 425 * DOMHW = SCH THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
* 426 *
* 427 * SUMMER-ONLY = SCHEDULE THRU JUN 1 (ALL) (1,24) (0)
* 428 *                THRU OCT 1 (ALL) (1,24) (1)
* 429 *                THRU DEC 31 (ALL) (1,24) (0) ..
* 430 * END ..
* 431 * COMPUTE SYSTEMS ..
* 432 * INPUT PLANT ..

```

PDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993PDL RUN 5

* 433 *
* 434 * WS-ECON PLANT-ASSIGNMENT ..
* 435 * PLANT-REPORT S (BEPS) ..
* 436 * END ..
* 437 * COMPUTE PLANT ..
* 438 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 11 09:03:47 1993EDL RUN 5

```

* 439 *
* 440 * ECONOMICS-REPORT S (ES-D,ES-E) ..
* 441 *
* 442 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 443 * MONTH-CHGS = (21.75)
* 444 * DEMAND-CHGS = (.81)
* 445 * BLOCK-CHARGES = (E-SM,E-WN) ..
* 446 *
* 447 * E-SM = BLOCK-CHARGE BLOCK-SCH = SEASON
* 448 * SCH-FLAG = 2
* 449 * BLOCK1-TYPE = ENERGY
* 450 * BLOCK1-DATA = (1250,.0829)
* 451 * BLOCK2-TYPE = KWH/KW
* 452 * BLOCK2-DATA = (125,.0829,0
* 453 * 1,.0514,0) ..
* 454 *
* 455 * E-WN = BLOCK-CHARGE BLOCK-SCH = SEASON
* 456 * SCH-FLAG = 1
* 457 * BLOCK1-TYPE = ENERGY
* 458 * BLOCK1-DATA = (1250,.0778)
* 459 * BLOCK2-TYPE = KWH/KW
* 460 * BLOCK2-DATA = (125,.0778,0
* 461 * 1,.0514,0) ..
* 462 *
* 463 * SEASON = SCHEDULE THRU APR 30 (ALL) (1,24) (1)
* 464 * THRU OCT 31 (ALL) (1,24) (2)
* 465 * THRU DEC 31 (ALL) (1,24) (1) ..
* 466 *
* 467 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 468 * MONTH-CHGS = (10.73)
* 469 * BLOCK-CHARGES = (GAS-CH) ..
* 470 *
* 471 * GAS-CH = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 472 * BLOCK1-DATA = (400,.643
* 473 * 1,.4943) ..
* 474 *
* 475 * END ..
* 476 * COMPUTE ECONOMICS ..
* 477 * STOP ..

```

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE							
SYS1	PVVT		1.020	2160.0		48.							
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
	2550.	1.561	1.9	0.	0.000	0.0	0.384	70.995	0.951	-120.000	1.15	0.68	-140.629
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
BLDG		2550.	0.	0.000	0.724	979.	0.00	0.00	52.33	0.00	-58.87	1.0	

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- SS-P LOAD, ENERGY AND PART LOAD

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT
 DHW TANK OPERATION FOR WS-ECON

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER
 WEATHER FILE- TRY CHICAGO

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.666 (GAL/MIN) PUMP = 0.000 (KW)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (MBTU) (KBTU/HR)	RCV EN USE (MBTU) (KBTU/HR)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM 5.160 PEAK 19.998 DAY/HR 29/14	2.680 27.532 25/14	4.175 18.459 8/12	0.000 0.000 31/24	564	47	46	40	23	18	4	2	0	0	0	744
FEB	SUM 4.837 PEAK 20.598 DAY/HR 26/14	2.758 27.215 17/13	3.714 18.567 5/12	0.000 0.000 28/24	491	38	46	39	30	18	6	4	0	0	0	672
MAR	SUM 5.390 PEAK 20.198 DAY/HR 31/14	4.828 29.131 3/13	2.830 18.038 24/14	0.000 0.000 31/24	437	45	57	74	51	47	22	8	3	0	0	744
APR	SUM 4.947 PEAK 19.198 DAY/HR 30/14	6.129 27.712 2/14	1.371 11.336 8/11	0.000 0.000 30/ 1	360	36	49	81	62	75	26	31	0	0	0	720
MAY	SUM 4.592 PEAK 17.799 DAY/HR 28/14	6.112 25.850 18/13	1.021 18.111 21/13	0.000 0.000 31/ 1	365	48	63	82	75	58	31	22	0	0	0	744
JUN	SUM 4.225 PEAK 16.399 DAY/HR 30/14	4.599 23.753 24/14	1.699 12.915 21/18	0.000 0.000 30/ 1	378	76	86	73	77	10	20	0	0	0	0	720
JUL	SUM 3.990 PEAK 15.199 DAY/HR 30/14	2.190 20.336 22/12	3.231 15.769 19/14	0.000 0.000 31/ 1	564	90	55	25	6	4	0	0	0	0	0	744
AUG	SUM 3.882 PEAK 14.799 DAY/HR 31/14	3.004 21.499 4/14	2.513 15.354 26/13	0.000 0.000 31/ 1	475	124	80	49	13	3	0	0	0	0	0	744
SEP	SUM 3.848 PEAK 15.199 DAY/HR 30/14	4.753 22.192 13/14	1.176 12.431 11/13	0.000 0.000 30/ 1	383	60	75	79	74	34	15	0	0	0	0	720
OCT	SUM 4.179 PEAK 16.199 DAY/HR 29/14	5.361 23.583 29/13	1.115 8.476 21/10	0.000 0.000 31/24	381	47	71	101	86	39	19	0	0	0	0	744
NOV	SUM 4.376 PEAK 17.599 DAY/HR 30/14	3.894 25.435 9/14	2.401 12.393 26/11	0.000 0.000 30/24	443	61	67	64	46	29	7	3	0	0	0	720
DEC	SUM 4.898 PEAK 18.998 DAY/HR 30/14	2.701 24.106 10/14	3.870 18.128 25/13	0.000 0.000 31/24	546	66	56	39	24	10	3	0	0	0	0	744
YR	SUM 54.324 PEAK 20.598 MON/DAY 2/26	49.006 29.131 3/ 3	29.116 18.567 2/ 5	0.000 0.000 12/31	5387	738	751	746	567	345	153	70	3	0	0	8760

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT
 SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER
 WEATHER FILE- TRY CHICAGO

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-50.075	1 10	0.F	0.F	-143.692	2260.	4.776
FEB	0.00000				0.000	-42.753	9 6	2.F	2.F	-119.511	2035.	4.760
MAR	0.07690	3 17	78.F	61.F	20.507	-33.224	24 7	6.F	5.F	-116.309	2213.	4.761
APR	1.43384	27 18	85.F	62.F	37.856	-15.428	9 6	26.F	25.F	-77.908	2026.	4.744
MAY	2.94594	21 13	87.F	76.F	86.838	-8.219	7 6	33.F	29.F	-63.805	2020.	4.744
JUN	10.82261	20 18	91.F	78.F	114.659	-1.877	1 6	48.F	47.F	-32.892	2119.	5.842
JUL	25.55632	13 17	97.F	78.F	107.632	-0.164	6 6	61.F	55.F	-9.658	2462.	5.710
AUG	18.50516	26 18	93.F	75.F	86.287	-0.390	5 6	55.F	54.F	-19.542	2321.	5.520
SEP	5.11988	11 17	86.F	72.F	69.586	-5.586	23 6	36.F	33.F	-59.327	2017.	5.454
OCT	1.32972	30 19	73.F	67.F	29.656	-12.910	21 6	30.F	29.F	-71.804	2046.	4.683
NOV	0.47445	2 13	74.F	61.F	35.694	-28.141	14 10	29.F	28.F	-89.584	2093.	4.744
DEC	0.00000				0.000	-43.341	9 6	14.F	13.F	-104.890	2252.	4.755
TOTAL	66.265					-242.109					25864.	
MAX					114.659					-143.692		5.842

SMALL BAR/LOUGE

NEW FEATURES IN DOE2.1E RUN 5

REPORT- SS-N RELATIVE HUMIDITY SCATTER PLOT FOR

CONVENTIONAL VS PVVT COMPARISON

SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT

SYS1

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 5

EVAPORATIVE PRECOOLED CONDENSER

WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT RELATIVE HUMIDITY LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
80-100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
70-80	2	3	3	4	5	11	8	2	2	1	1	1	0	0	0	1	2	2	2	3	4	5	4	2	68
60-70	44	29	32	31	33	41	43	36	33	29	21	20	7	3	4	10	21	16	22	32	41	47	45	44	684
50-60	58	46	38	37	36	40	41	47	61	64	69	80	56	58	55	73	82	75	74	77	74	76	68	58	1443
40-50	44	36	34	33	32	29	31	37	47	57	62	68	89	89	88	78	70	82	64	57	62	55	54	41	1339
30-40	51	46	42	43	39	36	52	50	46	48	49	55	74	55	60	56	73	79	77	82	91	94	94	85	1477
0-30	166	171	154	155	158	146	128	131	148	166	163	141	139	160	158	147	117	111	126	114	93	88	100	135	3315
===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	===	=====

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- SS-Q HEAT PUMP COOLING SUMMARY FOR SYS1

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)		
JAN	0.	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	
FEB	0.	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	
MAR	2.	0.077	0.061	0.005	0.000	0.000	-0.015	0.000	0.000	0.023
APR	33.	1.434	1.090	0.066	0.000	0.000	-0.273	0.000	0.000	0.292
MAY	63.	2.938	2.089	0.122	0.008	0.000	-0.522	0.000	0.000	0.474
JUN	222.	10.690	7.679	0.815	0.132	0.000	-1.920	0.000	0.000	1.225
JUL	456.	25.262	18.932	1.839	0.294	0.000	-4.733	0.000	0.000	1.800
AUG	363.	18.495	13.294	1.390	0.010	0.000	-3.324	0.000	0.000	1.641
SEP	109.	5.120	3.653	0.396	0.000	0.000	-0.913	0.000	0.000	0.720
OCT	31.	1.330	0.990	0.063	0.000	0.000	-0.248	0.000	0.000	0.330
NOV	11.	0.474	0.365	0.023	0.000	0.000	-0.091	0.000	0.000	0.095
DEC	0.	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000
ANNUAL	1289.	65.821	48.152	4.724	0.444	0.000	-12.038	0.000	0.000	6.601

CSPF (WITH PARASITICS) = 1.11 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 1.38 (BTU/BTU)

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- SS-Q HEAT PUMP HEATING SUMMARY FOR SYS1

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993SDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	661.	-44.591	35.930	1.214	-6.556	9.471	-8.982	0.000	-1.071	2.030
FEB	587.	-41.006	32.679	1.073	-2.684	4.094	-8.170	0.000	-0.937	1.842
MAR	537.	-33.086	22.624	0.995	-0.909	1.379	-5.656	0.000	-0.771	2.047
APR	261.	-15.718	9.708	0.506	0.000	0.000	-2.427	0.000	-0.290	1.709
MAY	131.	-8.254	4.684	0.277	0.000	0.000	-1.171	0.000	-0.035	1.556
JUN	27.	-1.877	0.983	0.070	0.000	0.000	-0.246	0.000	0.000	0.781
JUL	2.	-0.164	0.079	0.011	0.000	0.000	-0.020	0.000	0.000	0.263
AUG	5.	-0.390	0.193	0.021	0.000	0.000	-0.048	0.000	0.000	0.411
SEP	87.	-5.615	3.118	0.190	0.000	0.000	-0.780	0.000	-0.029	1.261
OCT	212.	-13.048	7.749	0.424	0.000	0.000	-1.937	0.000	-0.138	1.700
NOV	467.	-28.766	18.971	0.867	0.000	0.000	-4.743	0.000	-0.625	1.865
DEC	672.	-43.802	31.763	1.219	-0.731	1.183	-7.941	0.000	-1.193	2.030
ANNUAL	3649.	-236.317	168.481	6.866	-10.880	16.127	-42.120	0.000	-5.090	17.492

HSPF (WITH PARASITICS) = 1.24 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 1.31 (BTU/BTU)

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- SS-O TEMPERATURE SCATTER PLOT

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT
 SYS1 FOR BLDG

DOE-2.1E-001 Thu Nov 11 09:03:47 1993DL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
75-80	75	42	35	29	25	35	37	48	82	93	118	136	144	153	154	155	155	153	137	128	120	116	106	82	2358	
70-75	290	289	268	274	278	268	266	255	255	272	247	229	221	212	211	210	210	212	228	237	245	249	259	283	5968	
65-70	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
60-65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
*** ** ** ** **																										

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER
 WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413. /KWH	METER-1 100000. /THERM

JAN			
	ENERGY CONSUMPTION (UNITS/MO)	2259.6	480.8
	PEAK DEMAND (UNITS/HR OR DAY)	4.8	1.7
	PEAK DAY/HR	12/20	1/10
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	2034.7	395.3
	PEAK DEMAND (UNITS/HR OR DAY)	4.8	1.4
	PEAK DAY/HR	3/24	9/ 6
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	2213.3	288.9
	PEAK DEMAND (UNITS/HR OR DAY)	4.8	1.4
	PEAK DAY/HR	24/24	24/ 7
APR			
	ENERGY CONSUMPTION (UNITS/MO)	2025.6	169.3
	PEAK DEMAND (UNITS/HR OR DAY)	4.7	0.7
	PEAK DAY/HR	8/20	9/ 6
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	2020.3	128.9
	PEAK DEMAND (UNITS/HR OR DAY)	4.7	0.7
	PEAK DAY/HR	16/19	21/13
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	2118.6	132.6
	PEAK DEMAND (UNITS/HR OR DAY)	5.8	0.7
	PEAK DAY/HR	20/18	20/15
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	2462.5	212.0
	PEAK DEMAND (UNITS/HR OR DAY)	5.7	0.8
	PEAK DAY/HR	13/19	9/18
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	2321.4	164.9
	PEAK DEMAND (UNITS/HR OR DAY)	5.5	0.7
	PEAK DAY/HR	15/18	15/16
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	2016.6	115.2
	PEAK DEMAND (UNITS/HR OR DAY)	5.5	0.6
	PEAK DAY/HR	10/19	11/17
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	2046.1	141.0
	PEAK DEMAND (UNITS/HR OR DAY)	4.7	0.6
	PEAK DAY/HR	20/23	21/ 6
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	2092.7	232.3
	PEAK DEMAND (UNITS/HR OR DAY)	4.7	0.8
	PEAK DAY/HR	12/21	14/10
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	2252.1	356.5
	PEAK DEMAND (UNITS/HR OR DAY)	4.8	1.2
	PEAK DAY/HR	25/24	22/ 6

TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	25863.5	2817.7
	PEAK DEMAND (UNITS/HR OR DAY)	5.8	1.7

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 5
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL VS PVVT COMPARISON
SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 5
EVAPORATIVE PRECOOLED CONDENSER
WEATHER FILE- TRY CHICAGO

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	25863.5	100.0
LOAD SATISFIED	25863.5	100.0
TOTAL LOAD ON PLANT	25863.5	

SMALL BAR/LOUGE
NEW FEATURES IN DOE2.1E RUN 5
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL VS PVVT COMPARISON
SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993PDL RUN 5
EVAPORATIVE PRECOOLED CONDENSER
WEATHER FILE- TRY CHICAGO
(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	88.3	88.3	0.000	0.000	0

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		

AREA LIGHTS	35.7	0.0
MISC EQUIPMT	16.9	0.0
SPACE HEAT	0.0	168.5
SPACE COOL	0.0	48.2
HEAT REJECT	8.3	0.0
PUMPS & MISC	3.3	0.0
VENT FANS	24.1	0.0
SUPPLMT HEAT	0.0	16.1
DOMHOT WATER	0.0	49.0
	-----	-----
TOTAL	88.3	281.8

TOTAL SITE ENERGY 370.04 MBTU 171.3 KBTU/SQFT-YR GROSS-AREA 171.3 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 546.61 MBTU 253.1 KBTU/SQFT-YR GROSS-AREA 253.1 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.0
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- ES-D ENERGY COST SUMMARY

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	25863. KWH	2294.	0.0887	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	2818. THERM	1929.	0.6844	YES

=====
 4222.

ENERGY COST/GROSS BLDG AREA: 1.95
 ENERGY COST/NET BLDG AREA: 1.95

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT
 ELEC-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER

UTILITY-RATE: ELEC-COST

RESOURCE: ELECTRICITY
 METERS: 1 2 3 4 5
 POWER-FACTOR: 0.80

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31
 EXCESS-KVAR-FRAC: 0.30

3413. BTU/KWH
 RATE-LIMITATION: 0.0000
 EXCESS-KVAR-CHG: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

E-SM
 E-WN

MONTH	METERED ENERGY KWH	BILLING ENERGY KWH	METERED DEMAND KW	BILLING DEMAND KW	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	2260	2260	4.8	4.8	165	4	0	0	0	22	0	0.0843	191
FEB	2035	2035	4.8	4.8	153	4	0	0	0	22	0	0.0879	179
MAR	2213	2213	4.8	4.8	162	4	0	0	0	22	0	0.0850	188
APR	2026	2026	4.7	4.7	153	4	0	0	0	22	0	0.0881	178
MAY	2020	2020	4.7	4.7	162	4	0	0	0	22	0	0.0928	187
JUN	2119	2119	5.8	5.8	171	5	0	0	0	22	0	0.0933	198
JUL	2462	2462	5.7	5.7	188	5	0	0	0	22	0	0.0872	215
AUG	2321	2321	5.5	5.5	180	4	0	0	0	22	0	0.0890	207
SEP	2017	2017	5.5	5.5	165	4	0	0	0	22	0	0.0946	191
OCT	2046	2046	4.7	4.7	163	4	0	0	0	22	0	0.0921	189
NOV	2093	2093	4.7	4.7	156	4	0	0	0	22	0	0.0869	182
DEC	2252	2252	4.8	4.8	164	4	0	0	0	22	0	0.0844	190
TOTAL	25863	25863	5.8		1984	49	0	0	0	261		0.0887	2294

SMALL BAR/LOUGE
 NEW FEATURES IN DOE2.1E RUN 5
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

CONVENTIONAL VS PVVT COMPARISON
 SYSTEM 5: PKG PVVT GAS HEAT PUMP UNIT
 GAS-COST

DOE-2.1E-001 Thu Nov 11 09:03:47 1993EDL RUN 5
 EVAPORATIVE PRECOOLED CONDENSER

UTILITY-RATE: GAS-COST

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31

100000. BTU/THERM
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

BLOCK-CHARGES

GAS-CH


DEMAND-RATCHETS

MIN-MON-RATCHETS


MONTH	METERED ENERGY THERM	BILLING ENERGY THERM	METERED DEMAND THERMS	BILLING DEMAND THERMS	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	481	481	1.7	1.7	297	0	0	0	0	11	0	0.6403	308
FEB	395	395	1.4	1.4	254	0	0	0	0	11	0	0.6701	265
MAR	289	289	1.4	1.4	186	0	0	0	0	11	0	0.6801	196
APR	169	169	0.7	0.7	109	0	0	0	0	11	0	0.7064	120
MAY	129	129	0.7	0.7	83	0	0	0	0	11	0	0.7263	94
JUN	133	133	0.7	0.7	85	0	0	0	0	11	0	0.7239	96
JUL	212	212	0.8	0.8	136	0	0	0	0	11	0	0.6736	147
AUG	165	165	0.7	0.7	106	0	0	0	0	11	0	0.7081	117
SEP	115	115	0.6	0.6	74	0	0	0	0	11	0	0.7361	85
OCT	141	141	0.6	0.6	91	0	0	0	0	11	0	0.7191	101
NOV	232	232	0.8	0.8	149	0	0	0	0	11	0	0.6892	160
DEC	356	356	1.2	1.2	229	0	0	0	0	11	0	0.6731	240
TOTAL	2818	2818	1.7		1800	0	0	0	0	129		0.6844	1929

Single Family Residence


Elevation views and floor plan.




REAR ELEVATION OF RANCH HOUSE




FRONT ELEVATION OF RANCH HOUSE



xBL 803 6673




FLOOR PLAN OF RANCH HOUSE



xBL 803 6675

Single Family Residence


Floor plan. The house is modeled as two zones divided by an interior wall shown as the dashed line A-A in the floor plan. The other interior walls have not been explicitly modeled.



803-6675AA

Single Family Residence

Section. In this analysis, the attic is not modeled as a separate zone. Instead, the roof, insulated ceiling, and air space combination are treated as an exterior wall. For the building coordinate system, $Z = 0$ is at slab level, not ground level.




SECTION THRU RANCH HOUSE



XBL 803-6671

Single Family Residence

DrawBDL axonometric wire frame view of surfaces as input into BDL. In this analysis, the attic is not modeled as a separate zone. Instead, the combination of roof, airspace, and insulated ceiling is treated as tilted exterior wall sections that are constrained to have a total area equal to the ceiling area (1176 sq.ft.). Because of this constraint, the roof sections in the drawing do not meet. Note also that the triangular gable ends have been neglected, and that the exterior walls and roofs have been divided into insulated and stud sections. Interior surfaces are not shown.



803-6671AA

Single Family Residence — System 1

LDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993LDL RUN 1

```

* 2 *
* 3 * TITLE      LINE-1 *SINGLE FAMILY RESIDENCE *
* 4 *           LINE-2 *CONVENTIONAL DESIGN *
* 5 *           LINE-3 *CUSTOM WEIGHTING FACTORS*
* 6 *           LINE-4 *2 zones - living & sleeping * ..
* 7 *
* 8 *           ABORT          ERRORS ..
* 9 *           DIAGNOSTIC     WARNINGS ..
* 10 *          RUN-PERIOD      JAN 1 1974 THRU DEC 31 1974 ..
* 11 *          BUILDING-LOCATION LAT=41.88  LON=87.63  T-Z=6 ..
* 12 *          LOADS-REPORT    SUMMARY=(LS-A,LS-D) ..
* 13 *
* 14 * $          This input describes a small (1176 sq ft) conventional ranch style
* 15 * $          house. The house is modeled as 2 zones: the living area and the
* 16 * $          sleeping quarters. The attic is not modeled as a separate zone.
* 17 * $          Instead, the roof, insulated ceiling, and airspace are treated as a
* 18 * $          single construction. All internal heat gains are lumped into a single
* 19 * $          schedule.
* 20 *
* 21 *
* 22 *           $ -----SCHEDULE----- $
* 23 *
* 24 * SCH-1      =DAY-SCHEDULE      (1,5) (.1) (6,9) (.17,.22,.44,.26)
* 25 *                                     (10,11) (.16) (12,14) (.20,.15,.13)
* 26 *                                     (15,16) (.13) (17,19) (.19,.21,.23)
* 27 *                                     (20,24) (.37) ..
* 28 * INT-LDS-1 =SCHEDULE            THRU DEC 31 (ALL) SCH-1 ..
* 29 *
* 30 *           $ -----MATERIALS----- $
* 31 *
* 32 * STUD-1      =MAT              TH=.2917 COND=.0667 DENS=32 S-H=.33 $2X4STUDS ..
* 33 * DRYWALL-1   =MAT              TH=.0417 COND=.0925 DENS=50 S-H=.26 $1/2 IN DRYWALL$ ..
* 34 * WALL-INS-1  =MAT              TH=.2618 COND=.0238 DENS=6 S-H=.2 $R11 INSULATIONS ..
* 35 * SHEATH-1    =MAT              TH=.0417 COND=.0342 DENS=22 S-H=.31 $1/2-IN SHEATHINGS ..
* 36 * AL-SIDE-1   =MAT              TH=.0104 COND=.0171 DENS=170 S-H=.29 $ALUM SIDINGS ..
* 37 * AS-SHG-1    =MAT              TH=.0208 COND=.0473 DENS=70 S-H=.30 $ASPHALT SHINGLESS ..
* 38 * PLYW-1      =MAT              TH=.0417 COND=.0667 DENS=34 S-H=.29 $1/2-IN PLYWOOD$ ..
* 39 * CEIL-INS-1  =MAT              TH=.4522 COND=.0238 DENS=6 S-H=.2 $R19 INSULATIONS ..
* 40 * AT-AIR-1    =MAT              RES=3.1 $ATTIC AIR SPACES ..
* 41 * WALL-AIR-1  =MAT              RES=0.90 $WALL AIR SPACES ..
* 42 * EXP-POLY-1  =MAT              TH=.0833 COND=.0167 DENS=2.2 S-H=.29 $1-IN POLYSTYRENES ..
* 43 * CONCRETE-1  =MAT              TH=.3333 COND=.7576 DENS=140 S-H=.2 $4-IN CONCRETES ..
* 44 * CARP/PAD-1 =MAT              RES=2.08 $CARPET AND PAD$ ..
* 45 *
* 46 *           $ -----GLAZING----- $
* 47 *
* 48 * GT-WIN-1    =GLASS-TYPE      P=1 S-C=.60 ..
* 49 *
* 50 *           $ -----CONSTRUCTIONS----- $
* 51 *
* 52 * LAY-1        =LAYERS          MAT=(AL-SIDE-1,SHEATH-1,WALL-INS-1,DRYWALL-1) ..
* 53 * INS-WL-1     =CONS            LAYERS=LAY-1 ..
* 54 *
* 55 * LAY-2        =LAYERS          MAT=(AL-SIDE-1,SHEATH-1,STUD-1,DRYWALL-1) ..
* 56 * STUD-WL-1    =CONS            LAYERS=LAY-2 ..

```

```

* 57 *
* 58 * LAY-3      =LAYERS      MAT=(AS-SHG-1,PLYW-1,AT-AIR-1,CEIL-INS-1,
* 59 *              =CONS      DRYWALL-1) I-F-R=.61 ..
* 60 * INS-RF-1  =CONS      LAYERS=LAY-3  ABS=.86 ..
* 61 *
* 62 * LAY-4      =LAYERS      MAT=(AS-SHG-1,PLYW-1,STUD-1,AT-AIR-1,STUD-1,
* 63 *              =CONS      DRYWALL-1) I-F-R=.92 ..
* 64 * STUD-RF-1 =CONS      LAYERS=LAY-4  ABS=.86 ..
* 65 *
* 66 * LAY-5      =LAYERS      MAT=(EXP-POLY-1,CONCRETE-1,CARP/PAD-1)
* 67 *              =CONS      I-F-R=0.92 ..
* 68 * SLAB-1     =CONS      LAYERS=LAY-5 ..
* 69 * DR-1       =CONS      U=.629  ABS=.78 ..
* 70 * LAY-6      =LAYERS      MAT=(DRYWALL-1,WALL-AIR-1,DRYWALL-1) ..
* 71 * PARTITION =CONS      LAYERS=LAY-6 ..
* 72 *
* 73 *          $ -----BUILDING SHADE----- $
* 74 *
* 75 *          BUILDING-SHADE      X=0  Y=0  Z=8  H=1.5  W=42  $FRONT OVERHANGS
* 76 *          AZ=180  TILT=180 ..
* 77 *
* 78 *          BUILDING-SHADE      X=0  Y=28  Z=8  H=1.5  W=42  $REAR OVERHANGS
* 79 *          AZ=180  TILT=0 ..
* 80 *
* 81 *          $ -----SPACE DESCRIPTION----- $
* 82 *
* 83 * LIVING      =SPACE-CONDITIONS  SOURCE-SCHEDULE=INT-LDS-1
* 84 *          SOURCE-TYPE=ELECTRIC  SOURCE-BTU/HR=7252
* 85 *          INF-METHOD=RESIDENTIAL  FLOOR-WEIGHT = 0 ..
* 86 *
* 87 * SLEEPING   =SPACE-CONDITIONS  SOURCE-SCHEDULE=INT-LDS-1
* 88 *          SOURCE-TYPE=ELECTRIC  SOURCE-BTU/HR=3000
* 89 *          INF-METHOD=RESIDENTIAL  FLOOR-WEIGHT = 0 ..
* 90 *
* 91 *          $ -----Living zone----- $
* 92 *
* 93 * ZONE-1     =SPACE      A=532  V=4256  S-C=LIVING ..
* 94 *
* 95 * FRONT-WL-1=E-W      H=8      W=13.7  AZ=180  X=25  CONS=INS-WL-1 ..
* 96 * WIN-1            =WI      H=5.2   W=5.3  G-T=GT-WIN-1  X=8  Y=2
* 97 *          FRAME-WIDTH=.25 ..
* 98 * DOOR-1          =DOOR     H=6.67  W=3    CONS=DR-1  X=2 ..
* 99 *
* 100 * FRONT-WL-2=E-W      H=8      W=3.3   AZ=180  X=38.7  CONS=STUD-WL-1 ..
* 101 *
* 102 * RIGHT-WL-1=E-W      H=8      W=23.7  AZ=90   X=42   Y=0    CONS=INS-WL-1 ..
* 103 *
* 104 * RIGHT-WL-2=E-W      H=8      W=4.3   AZ=90   X=42   Y=23.7  CONS=STUD-WL-1 ..
* 105 *
* 106 * REAR-WL-1 =E-W      LIKE FRONT-WL-1  W=16.9  X=42   Y=28   AZ=0 ..
* 107 * WIN-2            =WI      H=6.67  W=6.0  X=4     Y=0    G-T=GT-WIN-1 ..
* 108 * WIN-3            =WI      H=4.0   W=2.7  X=13.5  Y=2    G-T=GT-WIN-1 ..
* 109 *          FRAME-WIDTH=.25 ..
* 110 *
* 111 * REAR-WL-2 =E-W      LIKE FRONT-WL-2  W=4.1   X=25.1  Y=28   AZ=0 ..
* 112 *
* 113 * FRONT-RF-1=ROOF      H=14     W=15.3  X=25   Y=0    Z=8
* 114 *          AZ=180  TILT=22.62
* 115 *          CONS=INS-RF-1 ..
* 116 *
* 117 * FRONT-RF-2=ROOF      H=14     W=1.7   X=40.3  Y=0    Z=8
* 118 *          AZ=180  TILT=22.62
* 119 *          CONS=STUD-RF-1 ..

```

* 120 *		
* 121 *	REAR-RF-1 =ROOF	LIKE FRONT-RF-1 W=18.9 X=42 Y=28 AZ=0 ..
* 122 *		
* 123 *	REAR-RF-2 =ROOF	LIKE FRONT-RF-2 W=2.1 X=23.1 Y=28 AZ=0 ..
* 124 *		
* 125 *	U-F	CONS=SLAB-1 A=532 \$PERIMETER AREA = 66\$
* 126 *		U-EFFECTIVE = .036 TILT = 180 ..
* 127 *		
* 128 *	SEPARATION=I-W	AREA=264 CONS=PARTITION NEXT-TO ZONE-2 ..
* 129 *		
* 130 *		\$ -----Sleeping zone----- \$
* 131 *		
* 132 *	ZONE-2 =SPACE	A=644 V=5154 S-C=SLEEPING ..
* 133 *		
* 134 *	FRONT-WL-3=E-W	H=8 W=20.2 AZ=180 CONS=INS-WL-1 ..
* 135 *	WIN-4 =WI	LIKE WIN-1 X=10 ..
* 136 *		
* 137 *	FRONT-WL-4=E-W	H=8 W=4.8 AZ=180 X=20.2 CONS=STUD-WL-1 ..
* 138 *		
* 139 *	REAR-WL-3 =E-W	LIKE REAR-WL-1 X=16.9 ..
* 140 *	WIN-5 =WI	H=4.0 W=5.3 X=5 Y=2 G-T=GT-WIN-1
* 141 *		FRAME-WIDTH=.25 ..
* 142 *		
* 143 *	REAR-WL-4 =E-W	LIKE REAR-WL-2 X=21 ..
* 144 *		
* 145 *	LEFT-WL-1 =E-W	LIKE RIGHT-WL-1 X=0 Y=28 AZ=270 ..
* 146 *		
* 147 *	LEFT-WL-2 =E-W	LIKE RIGHT-WL-2 X=0 Y=4.3 AZ=270 ..
* 148 *		
* 149 *	FRONT-RF-3=ROOF	H=14 W=22.5 X=0 Y=0 Z=8
* 150 *		AZ=180 TILT=22.62
* 151 *		CONS=INS-RF-1 ..
* 152 *		
* 153 *	FRONT-RF-4=ROOF	H=14 W=2.5 X=22.5 Y=0 Z=8
* 154 *		AZ=180 TILT=22.62
* 155 *		CONS=STUD-RF-1 ..
* 156 *		
* 157 *	REAR-RF-3 =ROOF	LIKE REAR-RF-1 X=21 ..
* 158 *		
* 159 *	REAR-RF-4 =ROOF	LIKE REAR-RF-2 X=2.1 ..
* 160 *		
* 161 *	U-F	CONS=SLAB-1 A=644 \$PERIMETER AREA = 74\$
* 162 *		U-EFFECTIVE = .036 TILT = 180 ..
* 163 *		
* 164 *	END ..	
* 165 *	COMPUTE LOADS ..	
* 166 *		
* 167 *	INPUT SYSTEMS ..	

SDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993SDL RUN 1

```

* 168 *
* 169 * TITLE      LINE-5 *RUN 1; RESYS with on/off heat pump* ..
* 170 *
* 171 *          SYSTEMS-REPORT      SUMMARY=(SS-A,SS-H,SS-F,SS-O) ..
* 172 *
* 173 * $          The house is heated and cooled by a central on/off 2 ton heat pump.
* 174 * $          The heat pump is controlled by a thermostat located in the living
* 175 * $          area. Electric baseboards are located in the bedrooms to provide the
* 176 * $          heat needed in addition to that provided by the central unit.
* 177 *
* 178 *
* 179 *          $ -----SCHEDULES----- $
* 180 *
* 181 * HEAT-1      =SCHEDULE      THRU DEC 31 (ALL) (1,7)(60)
* 182 *                                     (8,22)(70)
* 183 *                                     (23,24)(60) ..
* 184 * HEAT-2      =SCHEDULE      THRU DEC 31 (ALL) (1,24)(60) .. $bedroom basebrd sched
* 185 *
* 186 * COOL-1      =SCHEDULE      THRU DEC 31 (ALL) (1,24) (78) ..
* 187 *
* 188 *          $ -----Living zone----- $
* 189 *
* 190 * ZONE-1      =ZONE          DESIGN-HEAT-T=70 DESIGN-COOL-T=78
* 191 *                                     ZONE-TYPE=CONDITIONED
* 192 *                                     ASSIGNED-CFM=350
* 193 *                                     HEAT-TEMP-SCH=HEAT-1
* 194 *                                     COOL-TEMP-SCH=COOL-1 ..
* 195 *
* 196 *          $ -----Sleeping zone----- $
* 197 *
* 198 * ZONE-2      =ZONE          LIKE ZONE-1 HEAT-TEMP-SCH=HEAT-2
* 199 *                                     BASEBOARD-CTRL=THERMOSTATIC
* 200 *                                     BASEBOARD-RATING=-5000
* 201 *                                     ASSIGNED-CFM=350 ..
* 202 *
* 203 *          $ -----HEAT PUMP AND CENTRAL SYSTEM PARAMETERS----- $
* 204 *
* 205 * SYS-1      =SYSTEM          SYSTEM-TYPE=RESYS          ZONE-NAMES=(ZONE-1,ZONE-2)
* 206 *                                     HEAT-SOURCE=HEAT-PUMP      SUPPLY-CFM=700
* 207 *                                     COOLING-CAPACITY=24000      HP-SUPP-HT-CAP=-24000.
* 208 *                                     COOL-SH-CAP=16000
* 209 *                                     MAX-SUPPLY-T=105          MIN-SUPPLY-T=57
* 210 *                                     COOLING-EIR=.343          HEATING-EIR=.306
* 211 *                                     HP-SUPP-SOURCE=ELECTRIC      MAX-HP-SUPP-T=40.
* 212 *                                     DEFROST-TYPE=REVERSE-CYCLE DEFROST-CTRL=ON-DEMAND ..
* 213 *
* 214 * PLANT1 = PLANT-ASSIGNMENT SYSTEM-NAMES = (SYS-1)
* 215 *                                     DHW-TYPE=ELECTRIC
* 216 *                                     DHW-GAL/MIN = .375
* 217 *                                     DHW-SCH = DHWSCH-1 ..
* 218 *
* 219 * DHWSCH-1    =SCHEDULE      THRU DEC 31 (ALL)
* 220 *                                     (1,7) (0) (8,9) (1,0) (10,12) (0) (13,14) (.05)
* 221 *                                     (15,17) (0) (18,21) (.67) (22,24) (0) ..
* 222 *

```


- 223 • END ..
- 224 • COMPUTE SYSTEMS ..
- 225 •
- 226 • INPUT PLANT ..

P D L P R O C E S S O R I N P U T D A T A

Thu Nov 4 15:07:28 1993PDL RUN 1

* 227 * PLANT1 = PLANT-ASSIGNMENT ..
* 228 *
* 229 * PLANT-REPORT SUMMARY=(BEPS,PS-B) ..
* 230 *
* 231 * END ..
* 232 * COMPUTE PLANT ..
* 233 *
* 234 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993EDL RUN 1

* 235 * ECONOMICS-REPORT SUMMARY=(ES-D) ..
* 236 *
* 237 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 238 * BLOCK-CHARGES = (ELCOST) ..
* 239 *
* 240 * ELCOST = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 241 * BLOCK1-DATA = (800,.065,400,.080,1,.10) ..
* 242 *
* 243 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 244 * ENERGY-CHG = .55 ..
* 245 * END ..
* 246 * COMPUTE ECONOMICS ..
* 247 * INPUT SYSTEMS ..

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- LS-A SPACE PEAK LOADS SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993LDL RUN 1

WEATHER FILE- TRY CHICAGO

SPACE NAME	MULTIPLIER SPACE FLOOR	COOLING LOAD (KBTU/HR)	TIME OF PEAK	DRY- BULB	WET- BULB	HEATING LOAD (KBTU/HR)	TIME OF PEAK	DRY- BULB	WET- BULB
ZONE-1	1. 1.	7.949	JUL 13 6 PM	99.F	77.F	-13.552	JAN 12 5 AM	-4.F	-5.F
ZONE-2	1. 1.	7.003	JUL 13 6 PM	99.F	77.F	-14.212	JAN 12 7 AM	-6.F	-7.F
SUM		14.952				-27.764			
BUILDING PEAK		14.952	JUL 13 6 PM	99.F	77.F	-27.616	JAN 12 7 AM	-6.F	-7.F

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- LS-D BUILDING MONTHLY LOADS SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993LDL RUN 1

WEATHER FILE- TRY CHICAGO

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-9.902	12 7	-6.F	-7.F	-27.616	478.	1.322
FEB	0.00162	28 14	53.F	42.F	0.648	-8.479	4 6	7.F	6.F	-23.509	431.	1.322
MAR	0.04061	3 16	79.F	62.F	4.756	-6.260	24 5	9.F	8.F	-23.768	478.	1.322
APR	0.56535	27 16	84.F	61.F	7.920	-2.738	9 5	26.F	25.F	-13.905	462.	1.322
MAY	0.99990	21 13	85.F	75.F	10.497	-1.404	7 4	34.F	29.F	-10.352	478.	1.322
JUN	2.47810	20 17	91.F	78.F	12.484	-0.330	25 4	53.F	47.F	-4.581	462.	1.322
JUL	4.35998	13 17	99.F	77.F	14.952	-0.026	6 4	60.F	54.F	-1.638	478.	1.322
AUG	3.52976	26 16	94.F	76.F	12.184	-0.059	5 5	55.F	54.F	-2.592	478.	1.322
SEP	1.64506	11 14	87.F	72.F	11.165	-0.862	22 5	35.F	31.F	-9.458	462.	1.322
OCT	0.60126	10 15	68.F	54.F	6.179	-2.157	2 4	31.F	28.F	-12.149	478.	1.322
NOV	0.15103	2 13	74.F	61.F	7.251	-5.302	15 3	26.F	25.F	-15.920	462.	1.322
DEC	0.00000				0.000	-8.310	26 5	14.F	14.F	-19.821	478.	1.322
TOTAL	14.373					-45.829					5625.	
MAX					14.952					-27.616		1.322

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE									
SYS-1	RESYS	1.000	1176.0	0.									
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
	700.	0.090	0.4	0.	0.000	0.0	0.000	24.000	0.667	-26.902	0.34	0.31	-24.000
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	ZONE-1	350.	0.	0.000	1.000	0.	0.00	0.00	7.82	0.00	-13.23	1.0	
	ZONE-2	350.	0.	0.000	1.000	0.	0.00	0.00	7.82	0.00	-18.23	1.0	

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.375 (GAL/MIN) PUMP = 0.000 (KW)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR)	ENERGY USE (KWH) (KW)	RCV EN USE (KWH) (KW)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range										TOTAL RUN HOURS	
					00 10	10 20	20 30	30 40	40 50	50 60	60 70	70 80	80 90	90 100		
JAN	SUM 2.781 PEAK 18.767 DAY/HR 31/ 9	978.461 5.719 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	0	124	0	62	0	0	0	744
FEB	SUM 2.587 PEAK 19.330 DAY/HR 28/ 9	910.286 5.890 28/ 9	0.000 0.000 28/24	0.000 0.000 28/24	504	0	0	0	0	112	0	56	0	0	0	672
MAR	SUM 2.809 PEAK 18.955 DAY/HR 31/ 9	988.242 5.776 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	0	124	0	62	0	0	0	744
APR	SUM 2.584 PEAK 18.017 DAY/HR 30/ 9	909.023 5.490 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	0	120	0	0	60	0	0	0	720
MAY	SUM 2.475 PEAK 16.703 DAY/HR 31/ 9	870.824 5.090 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	0	124	0	62	0	0	0	0	744
JUN	SUM 2.207 PEAK 15.389 DAY/HR 30/ 9	776.454 4.689 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	0	120	0	60	0	0	0	0	720
JUL	SUM 2.114 PEAK 14.263 DAY/HR 31/ 9	743.631 4.346 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	124	0	62	0	0	0	0	0	744
AUG	SUM 2.058 PEAK 13.888 DAY/HR 31/ 9	724.058 4.232 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	124	0	62	0	0	0	0	0	744
SEP	SUM 2.045 PEAK 14.263 DAY/HR 30/ 9	719.643 4.346 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	120	0	60	0	0	0	0	0	720
OCT	SUM 2.253 PEAK 15.201 DAY/HR 31/ 9	792.550 4.632 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	124	0	62	0	0	0	0	744
NOV	SUM 2.368 PEAK 16.515 DAY/HR 30/ 9	833.267 5.033 30/ 9	0.000 0.000 30/24	0.000 0.000 30/24	540	0	0	0	120	0	60	0	0	0	0	720
DEC	SUM 2.642 PEAK 17.829 DAY/HR 31/ 9	929.540 5.433 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	124	0	0	62	0	0	0	744
YR	SUM 28.922 PEAK 19.330 MON/DAY 2/28	10175.467 5.890 2/28	0.000 0.000 12/31	0.000 0.000 12/31	6570	0	0	368	732	544	244	302	0	0	0	8760

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	0.00000				0.000	-8.435	5 8	11.F	10.F	-26.016	2340.	8.443		
FEB	0.00000				0.000	-7.162	25 8	10.F	9.F	-25.750	1758.	8.443		
MAR	0.00000				0.000	-4.952	25 8	14.F	12.F	-26.144	1363.	8.443		
APR	0.11742	28 15	78.F	68.F	5.487	-1.741	8 8	30.F	27.F	-19.285	801.	4.486		
MAY	0.31259	21 14	85.F	75.F	10.998	-0.603	6 8	37.F	33.F	-14.396	633.	3.223		
JUN	1.49268	20 18	91.F	78.F	13.441	-0.024	1 8	50.F	49.F	-3.626	675.	2.508		
JUL	3.61637	13 17	97.F	78.F	15.402	0.000				0.000	937.	2.752		
AUG	2.67579	26 17	94.F	76.F	12.303	0.000				0.000	828.	2.329		
SEP	0.75126	11 15	87.F	72.F	10.882	-0.273	22 8	34.F	31.F	-14.430	624.	3.486		
OCT	0.05083	5 16	74.F	62.F	2.916	-1.252	21 8	30.F	29.F	-17.532	726.	4.411		
NOV	0.03497	2 13	74.F	61.F	4.121	-4.124	26 8	25.F	22.F	-20.693	1191.	5.330		
DEC	0.00000				0.000	-6.934	9 8	13.F	12.F	-25.461	1801.	7.695		
TOTAL	9.052					-35.500					13676.			
MAX					15.402					-26.144		8.443		

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-H SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

MONTH	-FAN ELEC-		-FUEL HEAT-		-FUEL COOL-		-ELEC HEAT-		-ELEC COOL-	
	FAN ENERGY (KWH)	MAXIMUM FAN LOAD (KW)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)
JAN	40.	0.090	0.000	0.000	0.000	0.000	1776.	7.031	1.	0.025
FEB	35.	0.090	0.000	0.000	0.000	0.000	1253.	7.031	1.	0.025
MAR	21.	0.090	0.000	0.000	0.000	0.000	833.	7.031	1.	0.025
APR	7.	0.080	0.000	0.000	0.000	0.000	292.	3.084	23.	0.678
MAY	4.	0.052	0.000	0.000	0.000	0.000	97.	1.849	49.	1.165
JUN	8.	0.058	0.000	0.000	0.000	0.000	5.	0.544	200.	1.442
JUL	18.	0.072	0.000	0.000	0.000	0.000	0.	0.000	441.	1.743
AUG	13.	0.057	0.000	0.000	0.000	0.000	0.	0.000	337.	1.393
SEP	5.	0.056	0.000	0.000	0.000	0.000	48.	2.111	108.	1.182
OCT	5.	0.074	0.000	0.000	0.000	0.000	218.	3.016	16.	0.468
NOV	17.	0.090	0.000	0.000	0.000	0.000	680.	3.919	8.	0.556
DEC	31.	0.090	0.000	0.000	0.000	0.000	1255.	6.284	1.	0.025
TOTAL	204.		0.000		0.000		6457.		1186.	
MAX		0.090		0.000		0.000		7.031		1.743

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-P LOAD, ENERGY AND PART LOAD HEATING IN SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

UNIT TYPE is RESYS HEATING-CAPACITY = -26.902 (KBTU/HR) HEATING-EIR = 0.306 (BTU/BTU) SUPPLY-FLOW = 700. (CFM)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	COMPRESSOR (KWH) (KW)	FAN ENERGY (KWH) (KW)	Number of hours within each PART LOAD range												TOTAL RUN + HOURS
					00	10	20	30	40	50	60	70	80	90	100		
					10	20	30	40	50	60	70	80	90	100			
JAN	SUM -8.435 PEAK -26.016 DAY/HR 5/ 8	1776.244 7.031 0/ 0	936.988 2.611 18/ 8	40.019 0.090 0/ 0	CMP 14 FAN 16	23 31	47 93	87 87	58 77	54 83	79 29	38 34	21 35	34 21	138 213	593 719	
FEB	SUM -7.162 PEAK -25.750 DAY/HR 25/ 8	1252.991 7.071 0/ 0	949.996 2.520 22/ 8	35.432 0.090 0/ 0	CMP 17 FAN 21	32 36	68 83	43 56	48 62	63 56	37 59	45 67	58 55	61 51	152 105	624 651	
MAR	SUM -4.952 PEAK -26.144 DAY/HR 25/ 8	833.268 7.031 0/ 0	711.649 2.533 29/ 8	21.055 0.090 0/ 0	CMP 54 FAN 52	78 78	97 145	101 154	118 90	71 35	29 14	11 10	13 8	7 6	48 43	627 635	
APR	SUM -1.741 PEAK -19.285 DAY/HR 8/ 8	292.476 3.084 0/ 0	277.148 2.210 9/ 8	7.099 0.080 0/ 0	CMP 100 FAN 94	69 88	71 88	48 39	27 25	19 8	1 2	7 2	2 1	1 0	2 0	347 347	
MAY	SUM -0.603 PEAK -14.396 DAY/HR 6/ 8	97.248 1.849 0/ 0	90.321 1.837 6/ 8	3.514 0.052 0/ 0	CMP 97 FAN 90	45 53	24 23	4 7	3 3	3 2	0 0	2 0	0 0	0 0	0 0	178 178	
JUN	SUM -0.024 PEAK -3.626 DAY/HR 1/ 8	5.123 0.544 0/ 0	4.955 0.501 1/ 8	7.585 0.058 0/ 0	CMP 10 FAN 10	4 4	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	14 14	
JUL	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 0/ 0	0.000 0.000 0/ 0	17.734 0.072 0/ 0	CMP 0 FAN 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	
AUG	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 0/ 0	0.000 0.000 0/ 0	13.182 0.057 0/ 0	CMP 0 FAN 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	
SEP	SUM -0.273 PEAK -14.430 DAY/HR 22/ 8	47.516 2.111 0/ 0	44.323 2.102 23/ 8	4.816 0.056 0/ 0	CMP 37 FAN 36	27 27	7 8	2 4	2 1	1 1	0 1	0 1	2 0	0 0	0 0	78 78	
OCT	SUM -1.252 PEAK -17.532 DAY/HR 21/ 8	217.553 3.016 0/ 0	205.063 2.380 21/ 8	4.778 0.074 0/ 0	CMP 112 FAN 110	93 104	40 41	23 21	8 11	8 5	4 2	4 1	1 2	1 0	3 0	297 297	
NOV	SUM -4.124 PEAK -20.693 DAY/HR 26/ 8	679.801 3.919 0/ 0	648.998 2.495 30/ 8	17.037 0.090 0/ 0	CMP 58 FAN 58	91 105	102 127	82 102	69 81	75 54	42 28	23 13	15 3	5 3	15 3	577 577	
DEC	SUM -6.934 PEAK -25.461 DAY/HR 9/ 8	1254.878 6.284 0/ 0	1154.847 2.611 13/ 8	31.495 0.090 0/ 0	CMP 11 FAN 15	19 28	48 107	102 136	90 109	100 125	109 53	76 47	39 29	29 19	86 41	709 709	
YR	SUM -35.500 PEAK -26.144 MON/DAY 0/ 0	6457.068 7.031 0/ 0	5024.282 2.611 12/13	203.749 0.090 0/ 0	CMP 510 FAN 502	481 554	504 715	492 606	423 459	394 369	301 188	206 174	151 133	138 100	444 405	4044 4205	

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-P LOAD, ENERGY AND PART LOAD COOLING IN SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

UNIT TYPE is RESYS COOLING-CAPACITY = 24.000 (KBTU/HR) COOLING-EIR = 0.343 (BTU/BTU) SUPPLY-FLOW = 700. (CFM)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	COMPRESSOR (KWH) (KW)	FAN ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS	
					00	10	20	30	40	50	60	70	80	90	100		
					10	20	30	40	50	60	70	80	90	100			
JAN	SUM 0.000 PEAK 0.000 DAY/HR 31/24	0.600 0.025 0/0	0.000 0.000 0/0	40.019 0.090 0/0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
FEB	SUM 0.000 PEAK 0.000 DAY/HR 28/24	0.500 0.025 0/0	0.000 0.000 0/0	35.432 0.090 0/0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
MAR	SUM 0.000 PEAK 0.000 DAY/HR 31/24	1.475 0.025 0/0	0.000 0.000 0/0	21.055 0.090 0/0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
APR	SUM 0.117 PEAK 5.487 DAY/HR 28/15	22.790 0.678 0/0	21.440 0.678 28/15	7.099 0.080 0/0	CMP 27 FAN 18	27	21	2	0	0	0	0	0	0	0	0	50
MAY	SUM 0.313 PEAK 10.998 DAY/HR 21/14	49.293 1.165 0/0	47.693 1.165 21/14	3.514 0.052 0/0	CMP 43 FAN 32	43	32	18	3	2	0	0	0	0	0	0	98
JUN	SUM 1.493 PEAK 13.441 DAY/HR 20/18	200.083 1.442 0/0	199.958 1.442 20/18	7.585 0.058 0/0	CMP 87 FAN 63	87	112	96	38	4	5	0	0	0	0	0	342
JUL	SUM 3.616 PEAK 15.402 DAY/HR 13/17	441.365 1.743 0/0	441.365 1.743 13/18	17.734 0.072 0/0	CMP 104 FAN 76	104	118	141	133	62	25	7	0	0	0	0	590
AUG	SUM 2.676 PEAK 12.303 DAY/HR 26/17	336.878 1.393 0/0	336.878 1.393 26/17	13.182 0.057 0/0	CMP 104 FAN 80	104	130	145	87	43	3	0	0	0	0	0	512
SEP	SUM 0.751 PEAK 10.882 DAY/HR 11/15	108.297 1.182 0/0	107.197 1.182 11/15	4.816 0.056 0/0	CMP 69 FAN 54	69	68	37	18	6	0	0	0	0	0	0	198
OCT	SUM 0.051 PEAK 2.916 DAY/HR 5/16	16.477 0.468 0/0	14.752 0.468 5/16	4.778 0.074 0/0	CMP 42 FAN 36	42	2	0	0	0	0	0	0	0	0	0	44
NOV	SUM 0.035 PEAK 4.121 DAY/HR 2/13	7.546 0.556 0/0	6.046 0.556 2/13	17.037 0.090 0/0	CMP 6 FAN 4	6	8	0	0	0	0	0	0	0	0	0	14
DEC	SUM 0.000 PEAK 0.000 DAY/HR 31/24	0.775 0.025 0/0	0.000 0.000 0/0	31.495 0.090 0/0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
YR	SUM 9.052 PEAK 15.402 MON/DAY 0/0	1186.083 1.743 0/0	1175.328 1.743 7/13	203.749 0.090 0/0	CMP 482 FAN 363	482	491	439	279	117	33	7	0	0	0	0	1848

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-Q HEAT PUMP COOLING SUMMARY FOR SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	0.	0.000	0.000	0.002	0.000	0.000	0.000	0.019
FEB	0.	0.000	0.000	0.002	0.000	0.000	0.000	0.004
MAR	0.	0.000	0.000	0.005	0.000	0.000	0.000	0.001
APR	5.	0.117	0.073	0.005	0.000	0.000	0.000	0.002
MAY	13.	0.313	0.163	0.005	0.000	0.000	0.000	0.005
JUN	62.	1.493	0.682	0.000	0.000	0.000	0.000	0.026
JUL	151.	3.616	1.506	0.000	0.000	0.000	0.000	0.061
AUG	111.	2.676	1.150	0.000	0.000	0.000	0.000	0.045
SEP	31.	0.751	0.366	0.004	0.000	0.000	0.000	0.013
OCT	2.	0.051	0.050	0.006	0.000	0.000	0.000	0.001
NOV	1.	0.035	0.021	0.005	0.000	0.000	0.000	0.001
DEC	0.	0.000	0.000	0.003	0.000	0.000	0.000	0.000
ANNUAL	377.	9.052	4.011	0.037	0.000	0.000	0.000	0.177

CSPF (WITH PARASITICS) = 2.14 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 2.26 (BTU/BTU)

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-Q HEAT PUMP HEATING SUMMARY FOR SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	405.	-5.578	3.198	0.046	-2.974	2.812	0.000	0.000	-0.117	0.118
FEB	433.	-6.132	3.242	0.039	-1.123	0.991	0.000	0.000	-0.093	0.117
MAR	280.	-4.557	2.429	0.064	-0.452	0.340	0.000	0.000	-0.058	0.071
APR	91.	-1.695	0.946	0.040	-0.067	0.004	0.000	0.000	-0.021	0.022
MAY	24.	-0.583	0.308	0.021	-0.021	0.000	0.000	0.000	-0.001	0.007
JUN	1.	-0.024	0.017	0.001	0.000	0.000	0.000	0.000	0.000	0.000
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SEP	12.	-0.270	0.151	0.010	-0.004	0.000	0.000	0.000	-0.002	0.003
OCT	62.	-1.228	0.700	0.037	-0.038	0.004	0.000	0.000	-0.014	0.015
NOV	244.	-4.068	2.215	0.062	-0.125	0.036	0.000	0.000	-0.069	0.057
DEC	475.	-6.693	3.941	0.052	-0.411	0.278	0.000	0.000	-0.170	0.107
ANNUAL	2027.	-30.828	17.148	0.372	-5.217	4.464	0.000	0.000	-0.545	0.518

HSPF (WITH PARASITICS) = 1.60 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 1.64 (BTU/BTU)

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT - SS-F ZONE DEMAND SUMMARY IN

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

---DEMANDS--- --BASEBOARDS-- --TEMPERATURES-- --LOADS NOT MET--

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.00000	-4.135	0.00000	0.000	70.2	59.8	10	0
FEB	0.00000	-3.511	0.00000	0.000	70.3	59.9	3	0
MAR	0.00000	-2.412	0.00000	0.000	77.7	59.9	1	0
APR	0.05158	-0.831	0.00000	0.000	77.9	60.1	0	0
MAY	0.12686	-0.285	0.00000	0.000	78.0	60.2	0	0
JUN	0.63479	-0.012	0.00000	0.000	78.1	64.1	0	0
JUL	1.50851	0.000	0.00000	0.000	78.2	71.7	0	0
AUG	1.12160	0.000	0.00000	0.000	78.1	68.9	0	0
SEP	0.32901	-0.131	0.00000	0.000	78.0	60.2	0	0
OCT	0.02248	-0.599	0.00000	0.000	77.8	60.2	0	0
NOV	0.01657	-2.010	0.00000	0.000	77.9	60.1	0	0
DEC	0.00000	-3.397	0.00000	0.000	70.2	60.0	0	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-O TEMPERATURE SCATTER PLOT

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	LAM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
75-80	77	65	49	42	42	48	73	77	87	97	119	133	149	153	160	159	159	149	149	146	140	133	128	100	2634	
70-75	59	61	66	61	56	52	103	180	204	212	207	204	191	185	178	177	178	184	181	190	195	170	36	49	3379	
65-70	37	37	42	41	44	47	17	105	74	56	39	28	25	27	27	29	28	32	35	29	30	60	58	46	993	
60-65	183	193	198	210	210	205	160	3	0	0	0	0	0	0	0	0	0	0	0	0	0	2	143	168	1675	
BELOW 60	9	9	10	11	13	13	12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	79	
*** ** ** ** **																										

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-F ZONE DEMAND SUMMARY IN

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-2

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

- - - - DEMANDS - - - - BASEBOARDS - - - - TEMPERATURES - - - - LOADS NOT MET - -

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.00000	-4.276	-0.16217	-1.402	69.7	60.1	0	0
FEB	0.00000	-3.631	-0.13177	-1.245	70.0	60.1	0	0
MAR	0.00000	-2.512	-0.11287	-1.254	74.4	60.1	0	0
APR	0.04350	-0.870	-0.06374	-1.141	75.9	60.1	0	0
MAY	0.10750	-0.303	-0.02104	-0.883	75.5	60.2	0	0
JUN	0.54882	-0.013	0.00000	0.000	76.2	63.1	0	0
JUL	1.33571	0.000	0.00000	0.000	76.8	70.0	0	0
AUG	0.98452	0.000	0.00000	0.000	76.8	67.3	0	0
SEP	0.28617	-0.138	-0.00436	-0.634	76.7	60.2	0	0
OCT	0.01912	-0.628	-0.03434	-0.666	76.0	60.2	0	0
NOV	0.01396	-2.088	-0.08962	-1.106	75.8	60.1	0	0
DEC	0.00000	-3.517	-0.13335	-1.208	69.4	60.1	0	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-0 TEMPERATURE SCATTER PLOT

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-2

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	44	36	30	26	26	26	0	5	8	7	0	17	37	68	95	115	120	119	107	90	78	58	40	54	1206
70-75	78	71	68	64	61	55	86	86	88	100	129	124	123	102	80	62	53	51	60	70	75	88	103	78	1955
65-70	40	48	47	47	46	51	105	264	267	257	236	224	205	195	190	188	192	195	198	205	212	206	44	39	3701
60-65	203	210	220	228	232	233	174	10	2	1	0	0	0	0	0	0	0	0	0	0	0	13	178	194	1898
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT- PV-A EQUIPMENT SIZES

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 1
RUN 1: RESYS with on/off heat pump
WEATHER FILE- TRY CHICAGO

EQUIPMENT NUMBER NUMBER NUMBER NUMBER NUMBER NUMBER
 SIZE INSTD SIZE INSTD SIZE INSTD SIZE INSTD SIZE INSTD SIZE INSTD SIZE INSTD
 (MBTU/H) AVAIL (MBTU/H) AVAIL (MBTU/H) AVAIL (MBTU/H) AVAIL (MBTU/H) AVAIL (MBTU/H) AVAIL

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

		ELECTRICITY
		METER-1
NORTH	BTU/UNIT:	3413./KWH

JAN		
	ENERGY CONSUMPTION (UNITS/MO)	3352.9
	PEAK DEMAND (UNITS/HR OR DAY)	14.2
	PEAK DAY/HR	12 / 8
FEB		
	ENERGY CONSUMPTION (UNITS/MO)	2695.4
	PEAK DEMAND (UNITS/HR OR DAY)	14.3
	PEAK DAY/HR	4 / 8
MAR		
	ENERGY CONSUMPTION (UNITS/MO)	2368.2
	PEAK DEMAND (UNITS/HR OR DAY)	14.2
	PEAK DAY/HR	24 / 8
APR		
	ENERGY CONSUMPTION (UNITS/MO)	1716.0
	PEAK DEMAND (UNITS/HR OR DAY)	10.0
	PEAK DAY/HR	8 / 8
MAY		
	ENERGY CONSUMPTION (UNITS/MO)	1504.5
	PEAK DEMAND (UNITS/HR OR DAY)	8.3
	PEAK DAY/HR	6 / 8
JUN		
	ENERGY CONSUMPTION (UNITS/MO)	1451.5
	PEAK DEMAND (UNITS/HR OR DAY)	6.7
	PEAK DAY/HR	30 / 8
JUL		
	ENERGY CONSUMPTION (UNITS/MO)	1680.4
	PEAK DEMAND (UNITS/HR OR DAY)	6.5
	PEAK DAY/HR	3 / 8
AUG		
	ENERGY CONSUMPTION (UNITS/MO)	1551.8
	PEAK DEMAND (UNITS/HR OR DAY)	6.1
	PEAK DAY/HR	16 / 8
SEP		
	ENERGY CONSUMPTION (UNITS/MO)	1344.2
	PEAK DEMAND (UNITS/HR OR DAY)	7.9
	PEAK DAY/HR	23 / 8
OCT		
	ENERGY CONSUMPTION (UNITS/MO)	1522.7
	PEAK DEMAND (UNITS/HR OR DAY)	9.1
	PEAK DAY/HR	21 / 8
NOV		
	ENERGY CONSUMPTION (UNITS/MO)	2044.1
	PEAK DEMAND (UNITS/HR OR DAY)	10.5
	PEAK DAY/HR	14 / 8
DEC		
	ENERGY CONSUMPTION (UNITS/MO)	2780.0
	PEAK DEMAND (UNITS/HR OR DAY)	13.2
	PEAK DAY/HR	9 / 8

TOTAL		
	ENERGY CONSUMPTION (UNITS/YR)	24011.8
	PEAK DEMAND (UNITS/HR OR DAY)	14.3

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 1
RUN 1: RESYS with on/off heat pump
WEATHER FILE- TRY CHICAGO

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	24011.8	100.0
LOAD SATISFIED	24011.8	100.0
TOTAL LOAD ON PLANT	24011.7	

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 1
RUN 1: RESYS with on/off heat pump
WEATHER FILE- TRY CHICAGO
----- (CONTINUED) -----

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	82.0	82.0	0.000	0.000	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- BEPS BUILDING ENERGY PERFORMANCE SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 1
 RUN 1: RESYS with on/off heat pump
 WEATHER FILE- TRY CHICAGO

ENERGY TYPE: UNITS: MBTU	ELECTRICITY
CATEGORY OF USE -----	
SOURCE USES	19.2
SPACE HEAT	14.4
SPACE COOL	4.0
PUMPS & MISC	0.4
VENT FANS	0.7
SUPPLMT HEAT	0.5
DOMHOT WATER	34.7

TOTAL	81.9

TOTAL SITE ENERGY	81.95 MBTU	69.7 KBTU/SQFT-YR GROSS-AREA	69.7 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY	245.87 MBTU	209.1 KBTU/SQFT-YR GROSS-AREA	209.1 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.2
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- ES-D ENERGY COST SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993EDL RUN 1
 RUN 1: RESYS with on/off heat pump

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	24012. KWH	1969.	0.0820	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	0. THERM	0.	0.0000	YES

 1969.

ENERGY COST/GROSS BLDG AREA: 1.67
 ENERGY COST/NET BLDG AREA: 1.67

Single Family Residence — System 2

SDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993SDL RUN 2

```

* 248 *
* 249 * TITLE      LINE-5 'RUM 2: RESVVT with var spd ht pump' ..
* 250 *
* 251 *          SYSTEMS-REPORT      SUMMARY=(SS-A,SS-N,SS-F,SS-O) ..
* 252 *
* 253 * $          The house is conditioned by a central 2 ton variable speed heat pump.
* 254 * $          Thermostats in each zone control individual zone air dampers. The
* 255 * $          thermostat set points in each zone are set to take advantage of the
* 256 * $          occupancy patterns in the house. A heat exchanger downstream from
* 257 * $          the compressor allows part of the refrigerant superheat to be used for
* 258 * $          heating domestic hot water.
* 259 *
* 260 *          $ -----SCHEDULES----- $
* 261 *
* 262 * HEAT-1      =SCHEDULE      THRU DEC 31 (ALL) (1,7)(60) $ living area heating
* 263 *              (8,22)(70) $ set point
* 264 *              (23,24)(60) ..
* 265 * HEAT-2      =SCHEDULE      THRU DEC 31 (ALL) (1,24)(60) .. $ bedroom heat setpt
* 266 *
* 267 * COOL-1      =SCHEDULE      THRU DEC 31 (ALL) (1,7)(85) $ living area cooling
* 268 *              (8,22)(78) $ set point
* 269 *              (23,24)(85) ..
* 270 * COOL-2      =SCHEDULE      THRU DEC 31 (ALL) (1,7)(78) $ bedroom cooling set
* 271 *              (8,22)(80) $ point
* 272 *              (23,24)(78) ..
* 273 *
* 274 *          $ -----Living zone----- $
* 275 *
* 276 * ZONE-1      =ZONE          DESIGN-HEAT-T=70 DESIGN-COOL-T=78
* 277 *              THROTTLING-RANGE=0.2
* 278 *              ZONE-TYPE=CONDITIONED
* 279 *              ASSIGNED-CFM=700 $ Each zone can receive the
* 280 *              HEAT-TEMP-SCH=HEAT-1 $ full system cfm.
* 281 *              COOL-TEMP-SCH=COOL-1 ..
* 282 *
* 283 *          $ -----Sleeping zone----- $
* 284 *
* 285 * ZONE-2      =ZONE          LIKE ZONE-1 HEAT-TEMP-SCH=HEAT-2
* 286 *              COOL-TEMP-SCH=COOL-2 ..
* 287 *
* 288 *          $ -----HEAT PUMP AND CENTRAL SYSTEM PARAMETERS----- $
* 289 *
* 290 * SYS-1      =SYSTEM          SYSTEM-TYPE=RESVVT          ZONE-NAMES=(ZONE-1,ZONE-2)
* 291 *              HEAT-SOURCE=HEAT-PUMP          SUPPLY-CFM=700
* 292 *              COOLING-CAPACITY=24000          HP-SUPP-MT-CAP=-24000.
* 293 *              COOL-SH-CAP=16000
* 294 *              MAX-SUPPLY-T=105          MIN-SUPPLY-T=57
* 295 *              COOLING-EIR=.143          HEATING-EIR=.306
* 296 *              HP-SUPP-SOURCE=ELECTRIC          MAX-HP-SUPP-T=40.
* 297 *              HEAT-WASTE-HEAT=0. .. $ no heat recovery in heating
* 298 *              $ mode
* 299 *
* 300 * PLANT1 = PLANT-ASSIGNMENT  SYSTEM-NAMES = (SYS-1)
* 301 *              DHW-TYPE=ELECTRIC
* 302 *              DHW-GAL/MIN = .375

```



```
• 303 •
• 304 •
• 305 • DHWSCH-1 =SCHEDULE      THRU DEC 31 (ALL)
• 306 •                          (1,7) (0) (8,9) (1,0) (10,12) (0) (13,14) (.05)
• 307 •                          (15,17) (0) (18,21) (.67) (22,24) (0) ..
• 308 •
• 309 • END ..
• 310 • COMPUTE SYSTEMS ..
• 311 • INPUT PLANT ..
```

PDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993PDL RUN 2

* 312 * PLANT1 = PLANT-ASSIGNMENT ..
* 313 *
* 314 * PLANT-REPORT SUMMARY=(BEPS, PS-B) ..
* 315 *
* 316 * END ..
* 317 * COMPUTE PLANT ..
* 318 *
* 319 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993EDL RUN 2

* 320 * ECONOMICS-REPORT SUMMARY=(ES-D) ..
* 321 *
* 322 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 323 * BLOCK-CHARGES = (ELCOST) ..
* 324 *
* 325 * ELCOST = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 326 * BLOCK1-DATA = (800,.065,400,.080,1,.10) ..
* 327 *
* 328 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 329 * ENERGY-CHG = .55 ..
* 330 * END ..
* 331 * COMPUTE ECONOMICS ..
* 332 *
* 333 * INPUT SYSTEMS ..

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:20 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)			MAX PEOPLE						
SYS-1	RESVVT		1.000	1176.0			0.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)	HEAT PUMP SUPP-HEAT (KBTU/HR)
	700.	0.112	0.4	0.	0.000	0.0	0.000	24.000	0.667	-26.902	0.34	0.31	-24.000
	ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	EXTRACTION SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
	ZONE-1	700.	0.	0.000	0.001	0.	0.00	0.00	15.66	0.00	-26.46	1.0	
	ZONE-2	700.	0.	0.000	0.001	0.	0.00	0.00	15.66	0.00	-26.46	1.0	

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-P LOAD, ENERGY AND PART LOAL DHW TANK OPERATION FOR PLANT1

CONVENTIONAL DESIGN

2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2

RUN 2: RESVVT with var spd ht pump

WEATHER FILE- TRY CHICAGO

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.375 (GAL/MIN) PUMP = 0.000 (KW)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	RCV EN USE (KWH) (KW)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS	
					00	10	20	30	40	50	60	70	80	90	100		
					10	20	30	40	50	60	70	80	90	100	+		
JAN	SUM PEAK DAY/HR	2.781 18.767 31/ 9	978.461 5.719 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	0	124	0	62	0	0	0	744
FEB	SUM PEAK DAY/HR	2.587 19.330 28/ 9	910.286 5.890 28/ 9	0.000 0.000 28/24	0.000 0.000 28/24	504	0	0	0	0	112	0	56	0	0	0	672
MAR	SUM PEAK DAY/HR	2.809 18.955 31/ 9	988.242 5.776 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	0	124	0	62	0	0	0	744
APR	SUM PEAK DAY/HR	2.584 18.017 30/ 9	909.023 5.490 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	0	120	0	0	60	0	0	0	720
MAY	SUM PEAK DAY/HR	2.475 16.703 31/ 9	870.824 5.090 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	0	124	0	62	0	0	0	0	744
JUN	SUM PEAK DAY/HR	2.207 15.389 30/ 9	776.454 4.689 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	0	120	0	60	0	0	0	0	720
JUL	SUM PEAK DAY/HR	2.114 14.263 31/ 9	743.631 4.346 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	124	0	62	0	0	0	0	0	744
AUG	SUM PEAK DAY/HR	2.058 13.888 31/ 9	724.058 4.232 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	124	0	62	0	0	0	0	0	744
SEP	SUM PEAK DAY/HR	2.045 14.263 30/ 9	719.643 4.346 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	120	0	60	0	0	0	0	0	720
OCT	SUM PEAK DAY/HR	2.253 15.201 31/ 9	792.550 4.632 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	124	0	62	0	0	0	0	744
NOV	SUM PEAK DAY/HR	2.368 16.515 30/ 9	833.267 5.033 30/ 9	0.000 0.000 30/24	0.000 0.000 30/24	540	0	0	0	120	0	60	0	0	0	0	720
DEC	SUM PEAK DAY/HR	2.642 17.829 31/ 9	929.540 5.433 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	124	0	62	0	0	0	0	744
YR	SUM PEAK MON/DAY	28.922 19.330 2/28	10175.467 5.890 2/28	0.000 0.000 12/31	0.000 0.000 12/31	6570	0	0	368	732	544	244	302	0	0	0	8760

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-7.629	12 8	-7.F	-7.F	-22.671	1822.	8.123
FEB	0.00000				0.000	-6.413	4 8	7.F	6.F	-20.592	1314.	7.505
MAR	0.00000				0.000	-4.252	24 8	6.F	5.F	-20.654	992.	7.524
APR	0.05743	28 15	78.F	68.F	2.671	-1.407	8 8	30.F	27.F	-12.513	616.	2.657
MAY	0.16748	21 14	85.F	75.F	7.676	-0.423	6 8	37.F	33.F	-8.230	532.	2.143
JUN	0.93065	20 18	91.F	78.F	11.261	-0.011	1 8	50.F	49.F	-1.595	512.	1.713
JUL	2.57592	13 17	97.F	78.F	13.634	0.000				0.000	623.	2.014
AUG	1.80715	26 17	94.F	76.F	10.031	0.000				0.000	573.	1.604
SEP	0.46676	11 15	87.F	72.F	8.689	-0.169	23 8	36.F	34.F	-8.489	507.	2.173
OCT	0.01972	5 16	74.F	62.F	1.380	-0.940	21 8	30.F	29.F	-11.251	580.	2.517
NOV	0.01912	2 13	74.F	61.F	2.095	-3.477	14 8	27.F	26.F	-13.339	831.	2.867
DEC	0.00000				0.000	-6.139	9 8	13.F	12.F	-18.121	1173.	5.013
TOTAL	6.044					-30.860					10075.	
MAX					13.634					-22.671		8.123

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-H SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

MONTH	- FAN ELEC - - -		- FUEL HEAT - -		- FUEL COOL - -		- ELEC HEAT - -		- ELEC COOL - -	
	FAN ENERGY (KWH)	MAXIMUM FAN LOAD (KW)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)
JAN	38.	0.111	0.000	0.000	0.000	0.000	1303.	6.668	3.	0.025
FEB	34.	0.111	0.000	0.000	0.000	0.000	848.	6.058	1.	0.025
MAR	14.	0.111	0.000	0.000	0.000	0.000	500.	6.077	0.	0.025
APR	3.	0.071	0.000	0.000	0.000	0.000	147.	1.264	3.	0.167
MAY	1.	0.027	0.000	0.000	0.000	0.000	44.	0.797	9.	0.405
JUN	2.	0.044	0.000	0.000	0.000	0.000	1.	0.178	46.	0.685
JUL	7.	0.063	0.000	0.000	0.000	0.000	0.	0.000	138.	1.044
AUG	5.	0.036	0.000	0.000	0.000	0.000	0.	0.000	90.	0.640
SEP	1.	0.030	0.000	0.000	0.000	0.000	19.	0.824	25.	0.474
OCT	2.	0.058	0.000	0.000	0.000	0.000	99.	1.137	2.	0.066
NOV	9.	0.095	0.000	0.000	0.000	0.000	358.	1.450	1.	0.102
DEC	24.	0.111	0.000	0.000	0.000	0.000	672.	3.585	0.	0.000
TOTAL	141.		0.000		0.000		3991.		319.	
MAX		0.111		0.000		0.000		6.668		1.044

UNIT TYPE is RESVVT HEATING-CAPACITY = -26.902 (KBTU/HR) HEATING-EIR = 0.306 (BTU/BTU) SUPPLY-FLOW = 700. (CFM)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	COMPRESSOR (KWH) (KW)	FAN ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN + HOURS
					00	10	20	30	40	50	60	70	80	90	100	
JAN	SUM -7.629 PEAK -22.671 DAY/HR 12/ 8	1303.220 6.668 0/ 0	592.846 1.777 8/12	38.354 0.111 0/ 0	CMP 15 FAN 14	52	52	109	135	62	25	27	19	30	92	618
FEB	SUM -6.413 PEAK -20.592 DAY/HR 4/ 8	847.956 6.058 0/ 0	661.552 1.824 6/ 8	33.792 0.111 0/ 0	CMP 24 FAN 19	60	48	65	74	61	77	67	66	29	73	644
MAR	SUM -4.252 PEAK -20.654 DAY/HR 24/ 8	500.242 6.077 0/ 0	426.469 1.778 23/ 8	13.923 0.111 0/ 0	CMP 91 FAN 90	148	108	140	103	31	16	5	8	7	31	688
APR	SUM -1.407 PEAK -12.513 DAY/HR 8/ 8	146.960 1.264 0/ 0	140.038 1.264 8/ 8	3.031 0.071 0/ 0	CMP 149 FAN 141	99	66	35	29	6	1	1	0	0	0	386
MAY	SUM -0.423 PEAK -8.230 DAY/HR 6/ 8	43.890 0.797 0/ 0	38.829 0.797 6/ 8	1.072 0.027 0/ 0	CMP 123 FAN 120	47	14	3	2	0	0	0	0	0	0	189
JUN	SUM -0.011 PEAK -1.595 DAY/HR 1/ 8	1.073 0.178 0/ 0	0.908 0.137 1/ 8	2.280 0.044 0/ 0	CMP 11 FAN 11	0	0	0	0	0	0	0	0	0	0	11
JUL	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 0/ 0	0.000 0.000 0/ 0	7.440 0.063 0/ 0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0
AUG	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 0/ 0	0.000 0.000 0/ 0	4.629 0.036 0/ 0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0
SEP	SUM -0.169 PEAK -8.489 DAY/HR 23/ 8	18.503 0.824 0/ 0	15.942 0.824 23/ 8	1.413 0.030 0/ 0	CMP 46 FAN 43	19	5	1	2	0	0	0	0	0	0	73
OCT	SUM -0.940 PEAK -11.251 DAY/HR 21/ 8	98.617 1.137 0/ 0	90.816 1.137 21/ 8	1.877 0.058 0/ 0	CMP 165 FAN 151	81	38	19	13	1	2	0	0	0	0	319
NOV	SUM -3.477 PEAK -13.339 DAY/HR 14/ 8	358.398 1.450 0/ 0	350.825 1.450 26/ 8	9.388 0.095 0/ 0	CMP 114 FAN 111	131	98	106	91	60	22	4	2	0	0	628
DEC	SUM -6.139 PEAK -18.121 DAY/HR 9/ 8	671.799 3.585 0/ 0	650.033 1.805 18/ 8	23.754 0.111 0/ 0	CMP 3 FAN 10	54	69	175	177	103	56	31	27	14	35	744
YR	SUM -30.860 PEAK -22.671 MON/DAY 0/ 0	3990.640 6.668 0/ 0	2968.259 1.824 2/ 6	140.953 0.111 0/ 0	CMP 741 FAN 710	691	498	653	626	324	199	135	122	80	231	4300

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-P LOAD, ENERGY AND PART LOAD COOLING IN SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

UNIT TYPE is RESVVT COOLING-CAPACITY = 24.000 (KBTU/HR) COOLING-EIR = 0.343 (BTU/BTU) SUPPLY-FLOW = 700. (CFM)

MONTH	UNIT LOAD		ENERGY USE		COMPRESSOR		FAN ENERGY		Number of hours within each PART LOAD range										TOTAL RUN HOURS
	SUM (MBTU)	(KWH)	(KWH)	(KWH)	(KWH)	(KWH)	(KWH)	00	10	20	30	40	50	60	70	80	90	100	
	PEAK (KBTU/HR)	(KW)	(KW)	(KW)	(KW)	(KW)	(KW)	10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM	0.000	3.150	0.000	38.354	CMP	0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK	0.000	0.025	0.000	0.111	FAN	0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR	31/24	0/0	0/0	0/0														
FEB	SUM	0.000	0.675	0.000	33.792	CMP	0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK	0.000	0.025	0.000	0.111	FAN	0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR	28/24	0/0	0/0	0/0														
MAR	SUM	0.000	0.475	0.000	13.923	CMP	0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK	0.000	0.025	0.000	0.111	FAN	0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR	31/24	0/0	0/0	0/0														
APR	SUM	0.057	3.366	2.816	3.031	CMP	39	5	0	0	0	0	0	0	0	0	0	0	44
	PEAK	2.671	0.167	0.167	0.071	FAN	32	12	0	0	0	0	0	0	0	0	0	0	44
	DAY/HR	28/15	0/0	27/17	0/0														
MAY	SUM	0.167	8.939	7.614	1.072	CMP	61	17	5	0	0	0	0	0	0	0	0	0	83
	PEAK	7.676	0.405	0.405	0.027	FAN	46	23	9	4	1	0	0	0	0	0	0	0	83
	DAY/HR	21/14	0/0	21/14	0/0														
JUN	SUM	0.931	46.431	46.306	2.280	CMP	172	104	42	3	3	0	0	0	0	0	0	0	324
	PEAK	11.261	0.685	0.685	0.044	FAN	109	106	61	35	7	5	1	0	0	0	0	0	324
	DAY/HR	20/18	0/0	20/18	0/0														
JUL	SUM	2.576	137.547	137.547	7.440	CMP	208	139	132	65	29	8	0	0	0	0	0	0	581
	PEAK	13.634	1.044	1.044	0.063	FAN	141	120	89	96	74	43	15	3	0	0	0	0	581
	DAY/HR	13/17	0/0	13/18	0/0														
AUG	SUM	1.807	90.252	90.252	4.629	CMP	208	145	101	41	1	0	0	0	0	0	0	0	496
	PEAK	10.031	0.640	0.640	0.036	FAN	136	128	92	76	52	12	0	0	0	0	0	0	496
	DAY/HR	26/17	0/0	26/17	0/0														
SEP	SUM	0.467	24.540	23.465	1.413	CMP	127	37	23	3	0	0	0	0	0	0	0	0	190
	PEAK	8.689	0.474	0.474	0.030	FAN	89	51	27	17	6	0	0	0	0	0	0	0	190
	DAY/HR	11/15	0/0	11/15	0/0														
OCT	SUM	0.020	2.171	0.921	1.877	CMP	31	0	0	0	0	0	0	0	0	0	0	0	31
	PEAK	1.380	0.066	0.066	0.058	FAN	31	0	0	0	0	0	0	0	0	0	0	0	31
	DAY/HR	5/16	0/0	5/16	0/0														
NOV	SUM	0.019	1.232	0.907	9.388	CMP	15	0	0	0	0	0	0	0	0	0	0	0	15
	PEAK	2.095	0.102	0.102	0.095	FAN	10	5	0	0	0	0	0	0	0	0	0	0	15
	DAY/HR	2/13	0/0	2/13	0/0														
DEC	SUM	0.000	0.000	0.000	23.754	CMP	0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK	0.000	0.000	0.000	0.111	FAN	0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR	31/24	0/0	0/0	0/0														
YR	SUM	6.044	318.778	309.828	140.953	CMP	861	447	303	112	33	8	0	0	0	0	0	0	1764
	PEAK	13.634	1.044	1.044	0.111	FAN	594	445	278	228	140	60	16	3	0	0	0	0	1764
	MON/DAY	0/0	0/0	7/13	0/0														

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-Q HEAT PUMP COOLING SUMMARY FOR SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	0.	0.000	0.000	0.011	0.000	0.000	0.000	0.023
FEB	0.	0.000	0.000	0.002	0.000	0.000	0.000	0.005
MAR	0.	0.000	0.000	0.002	0.000	0.000	0.000	0.001
APR	7.	0.057	0.010	0.002	0.000	0.000	0.000	0.000
MAY	20.	0.167	0.026	0.005	0.000	0.000	0.000	0.001
JUN	111.	0.931	0.158	0.000	0.000	0.000	0.000	0.008
JUL	294.	2.576	0.469	0.000	0.000	0.000	0.000	0.025
AUG	214.	1.807	0.308	0.000	0.000	0.000	0.000	0.016
SEP	57.	0.467	0.080	0.004	0.000	0.000	0.000	0.004
OCT	2.	0.020	0.003	0.004	0.000	0.000	0.000	0.000
NOV	2.	0.019	0.003	0.001	0.000	0.000	0.000	0.000
DEC	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ANNUAL	708.	6.044	1.057	0.031	0.000	0.000	0.000	0.084

CSPF (WITH PARASITICS) = 5.16 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 5.72 (BTU/BTU)

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-Q HEAT PUMP HEATING SUMMARY FOR SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	573.	-5.573	2.023	0.018	-2.407	2.407	0.000	0.000	-0.351	0.108
FEB	589.	-6.128	2.258	0.011	-0.625	0.625	0.000	0.000	-0.340	0.110
MAR	521.	-4.324	1.456	0.024	-0.228	0.228	0.000	0.000	-0.300	0.046
APR	201.	-1.506	0.478	0.024	0.000	0.000	0.000	0.000	-0.100	0.010
MAY	57.	-0.433	0.133	0.017	0.000	0.000	0.000	0.000	-0.009	0.002
JUN	1.	-0.011	0.003	0.001	0.000	0.000	0.000	0.000	0.000	0.000
JUL	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
AUG	0.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SEP	23.	-0.176	0.054	0.009	0.000	0.000	0.000	0.000	-0.007	0.001
OCT	131.	-0.987	0.310	0.027	0.000	0.000	0.000	0.000	-0.047	0.006
NOV	457.	-3.729	1.197	0.026	0.000	0.000	0.000	0.000	-0.252	0.032
DEC	706.	-6.546	2.219	0.006	-0.068	0.068	0.000	0.000	-0.475	0.081
ANNUAL	3260.	-29.413	10.131	0.162	-3.327	3.327	0.000	0.000	-1.880	0.397

HSPF (WITH PARASITICS) = 2.23 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 2.29 (BTU/BTU)

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-F ZONE DEMAND SUMMARY IN

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

---DEMANDS--- --BASEBOARDS--- --TEMPERATURES--- --LOADS NOT MET---

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.00000	-4.406	0.00000	0.000	70.1	59.9	10	0
FEB	0.00000	-3.746	0.00000	0.000	70.1	59.9	2	0
MAR	0.00000	-2.637	0.00000	0.000	70.1	59.9	1	0
APR	0.05470	-0.920	0.00000	0.000	77.9	60.0	0	0
MAY	0.13653	-0.321	0.00000	0.000	80.1	60.0	0	0
JUN	0.67623	-0.011	0.00000	0.000	83.3	70.1	0	0
JUL	1.50671	0.000	0.00000	0.000	85.0	77.9	0	0
AUG	1.16795	0.000	0.00000	0.000	84.1	77.9	0	0
SEP	0.35392	-0.143	0.00000	0.000	81.9	60.1	0	0
OCT	0.01906	-0.673	0.00000	0.000	77.9	60.0	0	0
NOV	0.01900	-2.213	0.00000	0.000	77.9	60.0	1	0
DEC	0.00000	-3.657	0.00000	0.000	70.1	59.9	2	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- 99-0 TEMPERATURE SCATTER PLOT

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-1

DOB-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	24	15	13	8	9	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	68	63	31	241
75-80	0	4	0	1	0	0	44	48	60	78	93	110	120	121	122	124	123	118	116	114	107	7	4	9	1523
70-75	0	0	0	0	0	0	59	105	133	139	131	128	130	129	132	130	135	139	133	142	144	120	0	0	2029
65-70	0	0	0	0	0	0	6	132	95	75	58	45	42	36	38	42	40	42	50	43	44	45	2	1	836
60-65	141	144	147	152	144	149	124	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	151	140	1297
BELOW 60	31	35	38	38	48	44	43	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	22	299

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT - SS-F ZONE DEMAND SUMMARY IN

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-2

DOB-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

- - - DEMANDS - - - - BASEBOARDS - - - TEMPERATURES - - - LOADS NOT MET - -

MONTH	HEAT EXTRACTION ENERGY (KBTU)	HEAT ADDITION ENERGY (KBTU)	BASEBOARD ENERGY (KBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.00000	-3.330	0.00000	0.000	63.1	57.8	4	0
FEB	0.00000	-2.763	0.00000	0.000	65.0	59.9	0	0
MAR	0.00000	-1.656	0.00000	0.000	65.6	59.9	0	0
APR	0.00011	-0.496	0.00000	0.000	79.9	59.9	0	0
MAY	0.01646	-0.106	0.00000	0.000	80.0	60.0	0	0
JUN	0.18752	0.000	0.00000	0.000	80.0	64.1	0	0
JUL	0.83125	0.000	0.00000	0.000	80.0	75.0	0	0
AUG	0.49567	0.000	0.00000	0.000	80.0	73.3	0	0
SEP	0.08770	-0.027	0.00000	0.000	80.0	60.0	0	0
OCT	0.00000	-0.274	0.00000	0.000	77.0	60.0	0	0
NOV	0.00000	-1.291	0.00000	0.000	78.8	59.9	0	0
DEC	0.00000	-2.550	0.00000	0.000	61.9	59.9	0	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- 55-0 TEMPERATURE SCATTER PLOT

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-2

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 2
 RUN 2: RESVVT with var spd hc pump
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOURL	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	1	5	7	12	14	11	10	9	8	2	0	0	0	0	79
75-80	24	19	13	9	9	10	44	48	60	71	85	93	104	107	107	111	112	108	105	111	106	75	67	40	1638
70-75	0	0	0	0	0	0	0	0	0	7	7	12	9	2	1	2	1	1	3	1	1	0	0	0	47
65-70	0	0	0	0	0	0	9	15	12	4	0	0	3	6	6	11	10	12	10	9	9	2	0	0	118
60-65	141	144	147	152	144	149	176	99	123	136	133	129	128	123	126	122	126	128	126	134	138	124	142	139	3229
BELOW 60	31	35	38	38	48	44	47	123	93	74	56	44	41	36	38	39	39	41	47	42	41	44	11	24	1114
***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***	***

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOB-2.1E-001 Thu Nov 4 15:07:20 1993PDL RUN 2
 RUN 2: RESVVT with var spd ht pump
 WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	
		METER-1	3413./KWH

JAN			
	ENERGY CONSUMPTION (UNITS/MO)	2800.9	
	PEAK DEMAND (UNITS/HR OR DAY)	13.8	
	PEAK DAY/HR	12/ 8	
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	2224.2	
	PEAK DEMAND (UNITS/HR OR DAY)	13.4	
	PEAK DAY/HR	4/ 8	
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	1980.6	
	PEAK DEMAND (UNITS/HR OR DAY)	13.3	
	PEAK DAY/HR	24/ 8	
APR			
	ENERGY CONSUMPTION (UNITS/MO)	1524.7	
	PEAK DEMAND (UNITS/HR OR DAY)	8.1	
	PEAK DAY/HR	8/ 8	
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	1402.4	
	PEAK DEMAND (UNITS/HR OR DAY)	7.2	
	PEAK DAY/HR	6/ 8	
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	1288.5	
	PEAK DEMAND (UNITS/HR OR DAY)	6.2	
	PEAK DAY/HR	1/ 8	
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	1366.3	
	PEAK DEMAND (UNITS/HR OR DAY)	6.0	
	PEAK DAY/HR	3/ 8	
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	1296.6	
	PEAK DEMAND (UNITS/HR OR DAY)	5.7	
	PEAK DAY/HR	27/ 8	
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	1226.4	
	PEAK DEMAND (UNITS/HR OR DAY)	6.5	
	PEAK DAY/HR	23/ 8	
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	1372.9	
	PEAK DEMAND (UNITS/HR OR DAY)	7.1	
	PEAK DAY/HR	21/ 8	
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	1664.6	
	PEAK DEMAND (UNITS/HR OR DAY)	7.9	
	PEAK DAY/HR	26/ 8	
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	2102.8	
	PEAK DEMAND (UNITS/HR OR DAY)	10.4	
	PEAK DAY/HR	9/ 8	

TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	20250.9	
	PEAK DEMAND (UNITS/HR OR DAY)	13.8	

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 2
RUN 2: RESVVT with var spd ht pump
WEATHER FILE- TRY CHICAGO

ELECTRICAL LOADS	KWH SUPPLIED	PCT OF TOTAL LOAD
ELECTRICITY	20250.9	100.0
LOAD SATISFIED	20250.9	100.0
TOTAL LOAD ON PLANT	20250.8	

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 2
RUN 2: RESVVT with var spd ht pump
WEATHER FILE- TRY CHICAGO
(CONTINUED)

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	69.1	69.1	0.000	0.000	0

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT - BEPS BUILDING ENERGY PERFORMANCE SUMMARY

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 2
RUN 2: RESVVT with var spd ht pump
WEATHER FILE- TRY CHICAGO

ENERGY TYPE: ELECTRICITY
UNITS: MBTU

CATEGORY OF USE

SOURCE USES	19.2
SPACE HEAT	10.1
SPACE COOL	1.1
PUMPS & MISC	0.2
VENT FANS	0.5
SUPPLMT HEAT	3.3
DOMHOT WATER	34.7

TOTAL	69.1

TOTAL SITE ENERGY 69.11 MBTU 58.8 KBTU/SQFT-YR GROSS-AREA 58.8 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY 207.36 MBTU 176.3 KBTU/SQFT-YR GROSS-AREA 176.3 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.2
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- ES-D ENERGY COST SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993EDL RUN 2
 RUN 2: RESVVT with var spd ht pump

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	20251. KWH	1593.	0.0787	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	0. THERM	0.	0.0000	YES

 1593.

ENERGY COST/GROSS BLDG AREA: 1.35
 ENERGY COST/NET BLDG AREA: 1.35

Single Family Residence — System 3

SDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993SDL RUN 3

```

* 334 *
* 335 * TITLE      LINE-5 *RUN 3: RESYS with central AC and gas furnace* ..
* 336 *
* 337 *           SYSTEMS-REPORT      SUMMARY=(SS-A,SS-H,SS-F,SS-O) ..
* 338 *
* 339 * $           The house cooled by a conventional central air
* 340 * $           conditioner and heated by a gas furnace.
* 341 * $           The hot water heater is also gas.
* 342 * $           In this climate the furnace is a more
* 343 * $           reasonable choice than a heat pump for heating.
* 344 *
* 345 *           $ -----SCHEDULES----- $
* 346 *
* 347 * HEAT-1      =SCHEDULE      THRU DEC 31 (ALL) (1,7) (60)
* 348 *                                     (8,22) (70)
* 349 *                                     (23,24) (60) ..
* 350 * HEAT-2      =SCHEDULE      THRU DEC 31 (ALL) (1,24) (60) ..
* 351 *
* 352 * COOL-1      =SCHEDULE      THRU DEC 31 (ALL) (1,24) (78) ..
* 353 *
* 354 *           $ -----Living zone----- $
* 355 *
* 356 * ZONE-1      =ZONE           DESIGN-HEAT-T=70 DESIGN-COOL-T=78
* 357 *                                     ZONE-TYPE=CONDITIONED
* 358 *                                     ASSIGNED-CFM=350
* 359 *                                     HEAT-TEMP-SCH=HEAT-1
* 360 *                                     COOL-TEMP-SCH=COOL-1 ..
* 361 *
* 362 *           $ -----Sleeping zone----- $
* 363 *
* 364 * ZONE-2      =ZONE           LIKE ZONE-1 HEAT-TEMP-SCH=HEAT-2
* 365 *                                     BASEBOARD-CTRL=THERMOSTATIC
* 366 *                                     BASEBOARD-RATING=-5000
* 367 *                                     ASSIGNED-CFM=350 ..
* 368 *
* 369 *           $ -----AIR CONDITIONER AND GAS FURNACE PARAMETERS----- $
* 370 *
* 371 * SYS-1      =SYSTEM          SYSTEM-TYPE=RESYS           ZONE-NAMES=(ZONE-1,ZONE-2)
* 372 *                                     HEAT-SOURCE=FURNACE       SUPPLY-CFM=700
* 373 *                                     COOLING-CAPACITY=24000     HEATING-CAPACITY=-50000
* 374 *                                     COOL-SH-CAP=16000
* 375 *                                     MAX-SUPPLY-T=140           MIN-SUPPLY-T=57
* 376 *                                     COOLING-EIR=.343           FURNACE-AUX=100 ..
* 377 *
* 378 * PLANT1 = PLANT-ASSIGNMENT  SYSTEM-NAMES = (SYS-1)
* 379 *                                     DHW-TYPE=ELECTRIC
* 380 *                                     DHW-GAL/MIN = .375
* 381 *                                     DHW-SCH = DHWSCH-1 ..
* 382 *
* 383 * DHWSCH-1    =SCHEDULE      THRU DEC 31 (ALL)
* 384 *                                     (1,7) (0) (8,9) (1,0) (10,12) (0) (13,14) (.05)
* 385 *                                     (15,17) (0) (18,21) (.67) (22,24) (0) ..
* 386 * END ..
* 387 * COMPUTE SYSTEMS ..
* 388 *

```

* 389 * INPUT PLANT ..

P D L P R O C E S S O R I N P U T D A T A

Thu Nov 4 15:07:28 1993PDL RUN 3

* 390 * PLANT1 = PLANT-ASSIGNMENT ..
* 391 *
* 392 * PLANT-REPORT SUMMARY=(BEPS,PS-B) ..
* 393 *
* 394 * END ..
* 395 * COMPUTE PLANT ..
* 396 *
* 397 * INPUT ECONOMICS ..

EDL PROCESSOR INPUT DATA

Thu Nov 4 15:07:28 1993EDL RUN 3

```
* 398 * ECONOMICS-REPORT SUMMARY=(ES-D) ..
* 399 *
* 400 * ELBC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 401 *          BLOCK-CHARGES = (ELCOST) ..
* 402 *
* 403 * ELCOST    = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 404 *          BLOCK1-DATA = (800,.065,400,.080,1,.10) ..
* 405 *
* 406 * GAS-COST  = UTILITY-RATE RESOURCE = NATURAL-GAS
* 407 *          ENERGY-CHG = .55 ..
* 408 * END      ..
* 409 * COMPUTE ECONOMICS ..
* 410 * STOP     ..
```


SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE		ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)		MAX PEOPLE						
SYS-1	RESYS		1.000	1176.0		0.						
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	700.	0.090	0.4	0.	0.000	0.0	0.000	24.000	0.667	-50.000	0.34	0.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
ZONE-1	350.	0.	0.000	1.000	0.	0.00	0.00	7.82	0.00	-25.12	1.0	
ZONE-2	350.	0.	0.000	1.000	0.	0.00	0.00	7.82	0.00	-30.12	1.0	

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-P LOAD, ENERGY AND PART LOAD DHW TANK OPERATION FOR PLANT1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

TANK SIZE is 30.0 (GAL) HEATER CAP = 25.774 (KBTU/HR) FLOW RATE = 0.375 (GAL/MIN) PUMP = 0.000 (KW)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	RCV EN USE (KWH) (KW)	PUMP ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
					00	10	20	30	40	50	60	70	80	90	100	
					10	20	30	40	50	60	70	80	90	100	+	
JAN	SUM 2.781 PEAK 18.767 DAY/HR 31/ 9	978.461 5.719 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	0	124	0	62	0	0	0	744
FEB	SUM 2.587 PEAK 19.330 DAY/HR 28/ 9	910.286 5.890 28/ 9	0.000 0.000 28/24	0.000 0.000 28/24	504	0	0	0	0	112	0	56	0	0	0	672
MAR	SUM 2.809 PEAK 18.955 DAY/HR 31/ 9	988.242 5.776 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	0	124	0	62	0	0	0	744
APR	SUM 2.584 PEAK 18.017 DAY/HR 30/ 9	909.023 5.490 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	0	120	0	0	60	0	0	0	720
MAY	SUM 2.475 PEAK 16.703 DAY/HR 31/ 9	870.824 5.090 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	0	124	0	62	0	0	0	0	744
JUN	SUM 2.207 PEAK 15.389 DAY/HR 30/ 9	776.454 4.689 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	0	120	0	60	0	0	0	0	720
JUL	SUM 2.114 PEAK 14.263 DAY/HR 31/ 9	743.631 4.346 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	124	0	62	0	0	0	0	0	744
AUG	SUM 2.058 PEAK 13.888 DAY/HR 31/ 9	724.058 4.232 31/ 9	0.000 0.000 31/ 1	0.000 0.000 31/ 1	558	0	0	124	0	62	0	0	0	0	0	744
SEP	SUM 2.045 PEAK 14.263 DAY/HR 30/ 9	719.643 4.346 30/ 9	0.000 0.000 30/ 1	0.000 0.000 30/ 1	540	0	0	120	0	60	0	0	0	0	0	720
OCT	SUM 2.253 PEAK 15.201 DAY/HR 31/ 9	792.550 4.632 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	124	0	62	0	0	0	0	744
NOV	SUM 2.368 PEAK 16.515 DAY/HR 30/ 9	833.267 5.033 30/ 9	0.000 0.000 30/24	0.000 0.000 30/24	540	0	0	0	120	0	60	0	0	0	0	720
DEC	SUM 2.642 PEAK 17.829 DAY/HR 31/ 9	929.540 5.433 31/ 9	0.000 0.000 31/24	0.000 0.000 31/24	558	0	0	0	124	0	0	62	0	0	0	744
YR	SUM 28.922 PEAK 19.330 MON/DAY 2/28	10175.467 5.890 2/28	0.000 0.000 12/31	0.000 0.000 12/31	6570	0	0	368	732	544	244	302	0	0	0	8760

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

MONTH	COOLING					HEATING					ELEC	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-8.508	12 8	-7.F	-7.F	-34.310	577.	1.595
FEB	0.00000				0.000	-7.208	4 8	7.F	6.F	-28.366	516.	1.543
MAR	0.00000				0.000	-4.982	24 8	6.F	5.F	-28.403	553.	1.544
APR	0.11741	28 15	78.F	68.F	5.487	-1.745	8 8	30.F	27.F	-18.675	523.	1.670
MAY	0.31255	21 14	85.F	75.F	10.998	-0.599	6 8	37.F	33.F	-13.952	543.	1.773
JUN	1.49266	20 18	91.F	78.F	13.441	-0.024	1 8	50.F	49.F	-3.564	670.	2.508
JUL	3.61637	13 17	97.F	78.F	15.402	0.000				0.000	937.	2.752
AUG	2.67579	26 17	94.F	76.F	12.303	0.000				0.000	828.	2.329
SEP	0.75123	11 15	87.F	72.F	10.882	-0.269	22 8	34.F	31.F	-13.994	580.	1.895
OCT	0.05092	5 16	74.F	62.F	2.916	-1.251	21 8	30.F	29.F	-16.991	520.	1.506
NOV	0.03497	2 13	74.F	61.F	4.121	-4.144	26 8	25.F	22.F	-20.043	533.	1.502
DEC	0.00000				0.000	-6.976	9 8	13.F	12.F	-24.634	567.	1.534
TOTAL	9.052					-35.706					7348.	
MAX					15.402					-34.310		2.752

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-H SYSTEM MONTHLY LOADS SUMMARY FOR

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993DL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

MONTH	- FAN ELEC - -		- FUEL HEAT - -		- FUEL COOL - -		- ELEC HEAT - -		- ELEC COOL - -	
	FAN ENERGY (KWH)	MAXIMUM FAN LOAD (KW)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)
JAN	15.	0.061	12.924	48.384	0.000	0.000	47.	0.412	37.	0.050
FEB	13.	0.051	11.039	40.750	0.000	0.000	39.	0.382	33.	0.050
MAR	9.	0.051	7.899	40.799	0.000	0.000	34.	0.383	33.	0.050
APR	4.	0.033	2.944	27.843	0.000	0.000	19.	0.350	39.	0.678
MAY	3.	0.049	1.132	21.345	0.000	0.000	6.	0.260	56.	1.165
JUN	8.	0.058	0.123	6.575	0.000	0.000	0.	0.000	200.	1.442
JUL	18.	0.072	0.074	0.100	0.000	0.000	0.	0.000	441.	1.743
AUG	13.	0.057	0.074	0.100	0.000	0.000	0.	0.000	337.	1.393
SEP	4.	0.053	0.546	21.403	0.000	0.000	1.	0.186	112.	1.182
OCT	2.	0.030	2.210	25.542	0.000	0.000	10.	0.194	30.	0.468
NOV	7.	0.036	6.656	29.699	0.000	0.000	27.	0.340	36.	0.556
DEC	12.	0.044	10.813	35.848	0.000	0.000	40.	0.373	37.	0.050
TOTAL	107.		56.437		0.000		223.		1393.	
MAX		0.072		48.384		0.000		0.412		1.743

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-P LOAD, ENERGY AND PART LOAD HEATING IN SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 HEATING-CAPACITY = -50.000 (KBTU/HR) HEATING-EIR = 0.370 (BTU/BTU) SUPPLY-FLOW = 700. (CFM)

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

MONTH	UNIT LOAD		ENERGY USE (KWH)	COMPRESSOR (KWH)	FAN ENERGY (KWH)	Number of hours within each PART LOAD range											TOTAL RUN HOURS
	SUM (MBTU)	PEAK (KBTU/HR)				00	10	20	30	40	50	60	70	80	90	100	
	(KWH)	(KW)	(KW)	(KW)	10	20	30	40	50	60	70	80	90	100	+		
JAN	SUM	-8.508	47.232	0.000	14.957	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-34.310	0.412	0.000	0.061	FAN	57	237	204	169	40	6	3	0	0	0	0
	DAY/HR	12/ 8	0/ 0	0/ 0	0/ 0												716
FEB	SUM	-7.208	38.912	0.000	12.679	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-28.366	0.382	0.000	0.051	FAN	72	213	236	109	16	3	0	0	0	0	0
	DAY/HR	4/ 8	0/ 0	0/ 0	0/ 0												649
MAR	SUM	-4.982	33.644	0.000	8.723	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-28.403	0.383	0.000	0.051	FAN	141	368	70	45	4	2	0	0	0	0	0
	DAY/HR	24/ 8	0/ 0	0/ 0	0/ 0												630
APR	SUM	-1.745	18.924	0.000	3.620	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-18.675	0.350	0.000	0.033	FAN	186	134	19	3	0	0	0	0	0	0	0
	DAY/HR	8/ 8	0/ 0	0/ 0	0/ 0												342
MAY	SUM	-0.599	6.205	0.000	2.538	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-13.952	0.260	0.000	0.049	FAN	136	27	8	0	0	0	0	0	0	0	0
	DAY/HR	6/ 8	0/ 0	0/ 0	0/ 0												171
JUN	SUM	-0.024	0.000	0.000	7.552	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-3.564	0.000	0.000	0.058	FAN	13	0	0	0	0	0	0	0	0	0	0
	DAY/HR	1/ 8	0/ 0	0/ 0	0/ 0												13
JUL	SUM	0.000	0.000	0.000	17.734	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	0.000	0.000	0.000	0.072	FAN	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR	31/ 1	0/ 0	0/ 0	0/ 0												0
AUG	SUM	0.000	0.000	0.000	13.182	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	0.000	0.000	0.000	0.057	FAN	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR	31/ 1	0/ 0	0/ 0	0/ 0												0
SEP	SUM	-0.269	1.284	0.000	4.351	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-13.994	0.186	0.000	0.053	FAN	54	15	2	0	0	0	0	0	0	0	0
	DAY/HR	22/ 8	0/ 0	0/ 0	0/ 0												71
OCT	SUM	-1.251	10.115	0.000	2.442	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-16.991	0.194	0.000	0.030	FAN	207	66	15	3	0	0	0	0	0	0	0
	DAY/HR	21/ 8	0/ 0	0/ 0	0/ 0												291
NOV	SUM	-4.144	26.828	0.000	7.457	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-20.043	0.340	0.000	0.036	FAN	170	288	96	15	1	0	0	0	0	0	0
	DAY/HR	26/ 8	0/ 0	0/ 0	0/ 0												570
DEC	SUM	-6.976	40.045	0.000	12.255	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-24.634	0.373	0.000	0.044	FAN	62	322	256	58	6	0	0	0	0	0	0
	DAY/HR	9/ 8	0/ 0	0/ 0	0/ 0												704
YR	SUM	-35.706	223.187	0.000	107.491	CMP	0	0	0	0	0	0	0	0	0	0	0
	PEAK	-34.310	0.412	0.000	0.072	FAN1098	1670	906	402	67	11	3	0	0	0	0	0
	MON/DAY	0/ 0	0/ 0	0/ 0	0/ 0												4157

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-P LOAD, ENERGY AND PART LOAD COOLING IN SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

UNIT TYPE is RESYS COOLING-CAPACITY = 24.000 (KBTU/HR) COOLING-EIR = 0.343 (BTU/STU) SUPPLY-FLOW = 700. (CFM)

MONTH	UNIT LOAD ENERGY USE COMPRESSOR FAN ENERGY				Number of hours within each PART LOAD range												TOTAL RUN HOURS
	SUM (KBTU)	(KWH)	(KWH)	(KWH)	00	10	20	30	40	50	60	70	80	90	100		
	PEAK (KBTU/HR)	(KW)	(KW)	(KW)	10	20	30	40	50	60	70	80	90	100	+		
JAN	SUM 0.000	37.000	0.000	14.957	CMP 0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK 0.000	0.050	0.000	0.061	FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR 31/24	0/0	0/0	0/0													
FEB	SUM 0.000	33.400	0.000	12.679	CMP 0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK 0.000	0.050	0.000	0.051	FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR 28/24	0/0	0/0	0/0													
MAR	SUM 0.000	33.200	0.000	8.723	CMP 0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK 0.000	0.050	0.000	0.051	FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR 31/24	0/0	0/0	0/0													
APR	SUM 0.117	38.539	21.439	3.620	CMP 27	21	2	0	0	0	0	0	0	0	0	0	50
	PEAK 5.487	0.678	0.678	0.033	FAN 18	22	10	0	0	0	0	0	0	0	0	0	50
	DAY/HR 28/15	0/0	28/15	0/0													
MAY	SUM 0.313	56.440	47.690	2.538	CMP 43	32	18	3	2	0	0	0	0	0	0	0	98
	PEAK 10.998	1.165	1.165	0.049	FAN 32	32	18	11	3	2	0	0	0	0	0	0	98
	DAY/HR 21/14	0/0	21/14	0/0													
JUN	SUM 1.493	200.257	199.957	7.552	CMP 87	112	96	38	4	5	0	0	0	0	0	0	342
	PEAK 13.441	1.442	1.442	0.058	FAN 63	68	98	67	36	5	5	0	0	0	0	0	342
	DAY/HR 20/18	0/0	20/18	0/0													
JUL	SUM 3.616	441.365	441.365	17.734	CMP 104	118	141	133	62	25	7	0	0	0	0	0	590
	PEAK 15.402	1.743	1.743	0.072	FAN 76	87	88	113	105	76	33	11	1	0	0	0	590
	DAY/HR 13/17	0/0	13/18	0/0													
AUG	SUM 2.676	336.878	336.878	13.182	CMP 104	130	145	87	43	3	0	0	0	0	0	0	512
	PEAK 12.303	1.393	1.393	0.057	FAN 80	88	100	102	83	51	8	0	0	0	0	0	512
	DAY/HR 26/17	0/0	26/17	0/0													
SEP	SUM 0.751	111.845	107.195	4.351	CMP 69	68	37	18	6	0	0	0	0	0	0	0	198
	PEAK 10.882	1.182	1.182	0.053	FAN 54	44	47	27	19	7	0	0	0	0	0	0	198
	DAY/HR 11/15	0/0	11/15	0/0													
OCT	SUM 0.051	29.901	14.751	2.442	CMP 42	2	0	0	0	0	0	0	0	0	0	0	44
	PEAK 2.916	0.468	0.468	0.030	FAN 36	8	0	0	0	0	0	0	0	0	0	0	44
	DAY/HR 5/16	0/0	5/16	0/0													
NOV	SUM 0.035	36.396	6.046	7.457	CMP 6	8	0	0	0	0	0	0	0	0	0	0	14
	PEAK 4.121	0.556	0.556	0.036	FAN 4	5	5	0	0	0	0	0	0	0	0	0	14
	DAY/HR 2/13	0/0	2/13	0/0													
DEC	SUM 0.000	37.200	0.000	12.255	CMP 0	0	0	0	0	0	0	0	0	0	0	0	0
	PEAK 0.000	0.050	0.000	0.044	FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
	DAY/HR 31/24	0/0	0/0	0/0													
YR	SUM 9.052	1392.511	1175.322	107.491	CMP 482	491	439	279	117	33	7	0	0	0	0	0	1848
	PEAK 15.402	1.743	1.743	0.072	FAN 363	354	366	320	246	141	46	11	1	0	0	0	1848
	MON/DAY 0/0	0/0	7/13	0/0													

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-Q HEAT PUMP COOLING SUMMARY FOR SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)	
JAN	0.	0.000	0.000	0.126	0.000	0.000	0.000	0.000	0.000
FEB	0.	0.000	0.000	0.114	0.000	0.000	0.000	0.000	0.000
MAR	0.	0.000	0.000	0.113	0.000	0.000	0.000	0.000	0.000
APR	5.	0.117	0.073	0.058	0.000	0.000	0.000	0.000	0.002
MAY	13.	0.313	0.163	0.030	0.000	0.000	0.000	0.000	0.005
JUN	62.	1.493	0.682	0.001	0.000	0.000	0.000	0.000	0.026
JUL	151.	3.616	1.506	0.000	0.000	0.000	0.000	0.000	0.061
AUG	111.	2.676	1.150	0.000	0.000	0.000	0.000	0.000	0.045
SEP	31.	0.751	0.366	0.016	0.000	0.000	0.000	0.000	0.013
OCT	2.	0.051	0.050	0.052	0.000	0.000	0.000	0.000	0.001
NOV	1.	0.035	0.021	0.104	0.000	0.000	0.000	0.000	0.001
DEC	0.	0.000	0.000	0.127	0.000	0.000	0.000	0.000	0.000
ANNUAL	377.	9.052	4.011	0.741	0.000	0.000	0.000	0.000	0.153

CSPF (WITH PARASITICS) = 1.85 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 2.26 (BTU/BTU)

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-Q HEAT PUMP HEATING SUMMARY FOR SYS-1

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	167.	-8.346	12.866	0.058	-0.161	0.000	0.000	0.000	0.051
FEB	142.	-7.075	10.986	0.053	-0.133	0.000	0.000	0.000	0.043
MAR	97.	-4.868	7.835	0.065	-0.115	0.000	0.000	0.000	0.030
APR	34.	-1.680	2.876	0.069	-0.065	0.000	0.000	0.000	0.010
MAY	12.	-0.578	1.059	0.073	-0.021	0.000	0.000	0.000	0.004
JUN	0.	-0.024	0.051	0.072	0.000	0.000	0.000	0.000	0.000
JUL	0.	0.000	0.000	0.074	0.000	0.000	0.000	0.000	0.000
AUG	0.	0.000	0.000	0.074	0.000	0.000	0.000	0.000	0.000
SEP	5.	-0.264	0.475	0.071	-0.004	0.000	0.000	0.000	0.002
OCT	24.	-1.216	2.138	0.072	-0.035	0.000	0.000	0.000	0.007
NOV	81.	-4.053	6.592	0.064	-0.092	0.000	0.000	0.000	0.025
DEC	137.	-6.839	10.753	0.061	-0.137	0.000	0.000	0.000	0.042
ANNUAL	699.	-34.944	55.631	0.806	-0.762	0.000	0.000	0.000	0.214

HSPF (WITH PARASITICS) = 0.63 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 0.64 (BTU/BTU)

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-F ZONE DEMAND SUMMARY IN

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

- - - DEMANDS - - - -		- BASEBOARDS - - -		- TEMPERATURES - -		- LOADS NOT MET - -		
MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.00000	-4.173	0.00000	0.000	70.2	60.0	0	0
FEB	0.00000	-3.536	0.00000	0.000	70.3	60.1	0	0
MAR	0.00000	-2.430	0.00000	0.000	77.7	60.1	0	0
APR	0.05157	-0.837	0.00000	0.000	77.9	60.2	0	0
MAY	0.12684	-0.288	0.00000	0.000	78.0	60.2	0	0
JUN	0.63479	-0.012	0.00000	0.000	78.1	64.1	0	0
JUL	1.50851	0.000	0.00000	0.000	78.2	71.7	0	0
AUG	1.12160	0.000	0.00000	0.000	78.1	68.9	0	0
SEP	0.32900	-0.132	0.00000	0.000	78.0	60.2	0	0
OCT	0.02248	-0.604	0.00000	0.000	77.8	60.2	0	0
NOV	0.01657	-2.023	0.00000	0.000	77.9	60.2	0	0
DEC	0.00000	-3.418	0.00000	0.000	70.2	60.1	0	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-0 TEMPERATURE SCATTER PLOT

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-1

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
75-80	77	65	49	42	42	48	73	77	87	97	119	133	149	153	160	159	159	149	149	146	140	133	128	100	2634	
70-75	59	61	66	61	56	52	112	276	276	268	246	232	216	212	205	206	206	216	216	219	225	201	36	49	3972	
65-70	37	37	42	41	44	47	8	12	2	0	0	0	0	0	0	0	0	0	0	0	0	29	59	46	404	
60-65	192	202	208	221	223	218	172	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	142	170	1750	
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-F ZONE DEMAND SUMMARY IN

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-2

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

- - - - DEMANDS - - - - - BASEBOARDS - - - - TEMPERATURES - - - - LOADS NOT MET - -

MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.00000	-4.258	-0.16120	-1.406	69.7	60.1	0	0
FEB	0.00000	-3.608	-0.13281	-1.302	69.9	60.1	0	0
MAR	0.00000	-2.488	-0.11482	-1.306	74.3	60.1	0	0
APR	0.04349	-0.859	-0.06459	-1.193	75.9	60.1	0	0
MAY	0.10747	-0.297	-0.02118	-0.888	75.5	60.2	0	0
JUN	0.54881	-0.012	0.00000	0.000	76.2	63.1	0	0
JUL	1.33571	0.000	0.00000	0.000	76.8	70.0	0	0
AUG	0.98452	0.000	0.00000	0.000	76.8	67.3	0	0
SEP	0.28614	-0.136	-0.00438	-0.635	76.7	60.2	0	0
OCT	0.01911	-0.620	-0.03452	-0.662	76.0	60.2	0	0
NOV	0.01396	-2.068	-0.09156	-1.161	75.8	60.1	0	0
DEC	0.00000	-3.489	-0.13667	-1.272	69.4	60.1	0	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- SS-0 TEMPERATURE SCATTER PLOT

CONVENTIONAL DESIGN
 2 zones - living & sleeping
 SYS-1 FOR ZONE-2

DOE-2.1E-001 Thu Nov 4 15:07:28 1993SDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL	
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
75-80	44	36	30	26	26	26	0	5	8	7	0	17	37	68	95	115	120	119	107	90	78	58	40	54	1206	
70-75	78	71	68	64	61	55	86	86	88	100	129	124	123	102	79	62	53	51	60	70	75	88	103	78	1954	
65-70	40	48	46	47	46	51	105	274	269	258	236	224	205	195	191	188	192	195	198	205	212	206	44	39	3714	
60-65	203	210	221	228	232	233	174	0	0	0	0	0	0	0	0	0	0	0	0	0	0	13	178	194	1886	
BELOW 60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
*** **																										

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- PS-B MONTHLY UTILITY AND FUEL USE SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

MONTH	BTU/UNIT:	ELECTRICITY	NATURAL-GAS
		METER-1 3413./KWH	METER-1 100000./THERM

JAN			
	ENERGY CONSUMPTION (UNITS/MO)	1555.3	129.2
	PEAK DEMAND (UNITS/HR OR DAY)	7.2	0.5
	PEAK DAY/HR	12/ 8	12/ 8
FEB			
	ENERGY CONSUMPTION (UNITS/MO)	1426.7	110.4
	PEAK DEMAND (UNITS/HR OR DAY)	7.3	0.4
	PEAK DAY/HR	4/ 8	4/ 8
MAR			
	ENERGY CONSUMPTION (UNITS/MO)	1541.5	79.0
	PEAK DEMAND (UNITS/HR OR DAY)	7.2	0.4
	PEAK DAY/HR	24/ 8	24/ 8
APR			
	ENERGY CONSUMPTION (UNITS/MO)	1432.4	29.4
	PEAK DEMAND (UNITS/HR OR DAY)	6.9	0.3
	PEAK DAY/HR	8/ 8	8/ 8
MAY			
	ENERGY CONSUMPTION (UNITS/MO)	1413.7	11.3
	PEAK DEMAND (UNITS/HR OR DAY)	6.5	0.2
	PEAK DAY/HR	6/ 8	6/ 8
JUN			
	ENERGY CONSUMPTION (UNITS/MO)	1446.6	1.2
	PEAK DEMAND (UNITS/HR OR DAY)	6.7	0.1
	PEAK DAY/HR	30/ 8	1/ 8
JUL			
	ENERGY CONSUMPTION (UNITS/MO)	1680.4	0.7
	PEAK DEMAND (UNITS/HR OR DAY)	6.5	0.0
	PEAK DAY/HR	3/ 8	1/ 2
AUG			
	ENERGY CONSUMPTION (UNITS/MO)	1551.8	0.7
	PEAK DEMAND (UNITS/HR OR DAY)	6.1	0.0
	PEAK DAY/HR	16/ 8	1/ 2
SEP			
	ENERGY CONSUMPTION (UNITS/MO)	1299.4	5.5
	PEAK DEMAND (UNITS/HR OR DAY)	6.1	0.2
	PEAK DAY/HR	11/ 8	22/ 8
OCT			
	ENERGY CONSUMPTION (UNITS/MO)	1312.7	22.1
	PEAK DEMAND (UNITS/HR OR DAY)	6.0	0.3
	PEAK DAY/HR	21/ 8	21/ 8
NOV			
	ENERGY CONSUMPTION (UNITS/MO)	1366.2	66.6
	PEAK DEMAND (UNITS/HR OR DAY)	6.4	0.3
	PEAK DAY/HR	26/ 8	26/ 8
DEC			
	ENERGY CONSUMPTION (UNITS/MO)	1496.7	108.1
	PEAK DEMAND (UNITS/HR OR DAY)	6.8	0.4
	PEAK DAY/HR	9/ 8	9/ 8

TOTAL			
	ENERGY CONSUMPTION (UNITS/YR)	17523.6	564.4
	PEAK DEMAND (UNITS/HR OR DAY)	7.3	0.5

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 3
RUN 3: RESYS with central AC and gas fur
WEATHER FILE- TRY CHICAGO

<u>ELECTRICAL LOADS</u>	<u>KWH SUPPLIED</u>	<u>PCT OF TOTAL LOAD</u>
ELECTRICITY	17523.6	100.0
	*****	*****
LOAD SATISFIED	17523.6	100.0
TOTAL LOAD ON PLANT	17523.5	

SINGLE FAMILY RESIDENCE
CUSTOM WEIGHTING FACTORS
REPORT- PS-D PLANT LOADS SATISFIED

CONVENTIONAL DESIGN
2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 3
RUN 3: RESYS with central AC and gas fur
WEATHER FILE- TRY CHICAGO
----- (CONTINUED) -----

SUMMARY OF LOADS MET

TYPE OF LOAD	TOTAL LOAD (MBTU)	LOAD SATISFIED (MBTU)	TOTAL OVERLOAD (MBTU)	PEAK OVERLOAD (MBTU)	HOURS OVERLOADED
ELECTRICAL LOADS	59.8	59.8	0.000	0.000	0

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- BEPS BUILDING ENERGY PERFORMANCE SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993PDL RUN 3
 RUN 3: RESYS with central AC and gas fur
 WEATHER FILE- TRY CHICAGO

ENERGY TYPE: UNITS: MBTU	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE		
SOURCE USES	19.2	0.0
SPACE HEAT	0.8	56.4
SPACE COOL	4.0	0.0
PUMPS & MISC	0.7	0.0
VENT FANS	0.4	0.0
DOMHOT WATER	34.7	0.0
TOTAL	59.8	56.4

TOTAL SITE ENERGY 116.24 MBTU 98.8 KBTU/SQFT-YR GROSS-AREA 98.8 KBTU/SQFT-YR NET-AREA
 TOTAL SOURCE ENERGY 235.87 MBTU 200.6 KBTU/SQFT-YR GROSS-AREA 200.6 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.0
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

SINGLE FAMILY RESIDENCE
 CUSTOM WEIGHTING FACTORS
 REPORT- ES-D ENERGY COST SUMMARY

CONVENTIONAL DESIGN
 2 zones - living & sleeping

DOE-2.1E-001 Thu Nov 4 15:07:28 1993EDL RUN 3
 RUN 3: RESYS with central AC and gas fur


UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	17524. KWH	1320.	0.0753	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	564. THERM	310.	0.5500	YES

 1631.

ENERGY COST/GROSS BLDG AREA: 1.39
 ENERGY COST/NET BLDG AREA: 1.39

Daylighting Example

DrawBDL axonometric view of surfaces of the floor of an office building as input into BDL. For daylighting simulation, each 20-ft-wide office on the perimeter of all four exposures is input as a separate zone with a multiplier of 7. Only the exterior wall and associated window for each representative perimeter office are shown; the interior surfaces are not shown.



791-8075AA


LDL PROCESSOR INPUT DATA

Fri Nov 5 21:58:52 1993LDL RUN 1


```

* 2 * ABORT ERRORS ..
* 3 * DIAGNOSTIC CAUTIONS ..
* 4 * TITLE LINE-1 = *DAYLIGHTING EXAMPLE*
* 5 * LINE-2 = *FLOOR OF OFFICE BUILDING IN CHICAGO*
* 6 * LINE-3 = *30-FT DEEP PERIM OFFS DAYLIT TO 15 FT*
* 7 * LINE-4 = *AUTO SHADE MANAGEMENT FOR SUN CONTROL* ..
* 8 *

```



PLAN -- FLOOR OF MULTISTORY OFFICE BUILDING



PLAN -- PERIMETER OFFICE


```

* 120 *           (6,20) (0.1)
* 121 *           (21,24) (1.0)
* 122 *   (SAT)   (1,5) (1)
* 123 *           (6,17) (0.1)
* 124 *           (18,24) (1)
* 125 *   (SUN,HOL) (1,24) (1) ..
* 126 *
* 127 *   OCC-SCH = SCHEDULE THRU DEC 31
* 128 *   (MON,FRI) (1,4) (0)
* 129 *           (5,8) (0,0,.10,.20)
* 130 *           (9,12) (.95)
* 131 *           (13,16) (.50,.95,.95,.95)
* 132 *           (17,20) (.95,.30,.10,.10)
* 133 *           (21,24) (.05,.05,.05,0.)
* 134 *   (SAT)   (1,4) (0)
* 135 *           (5,8) (0,0,.10,.10)
* 136 *           (9,12) (.30)
* 137 *           (13,16) (.10)
* 138 *           (17,20) (.10,.05,.05,0)
* 139 *           (21,24) (0)
* 140 *   (SUN,HOL) (1,24) (0) ..
* 141 *
* 142 *   CORE-LITE-SCH = SCHEDULE THRU DEC 31
* 143 *   (MON,FRI) (1,4) (.05)
* 144 *           (5,8) (.05,.05,.10,.30)
* 145 *           (9,12) (1.0)
* 146 *           (13,16) (.80,1.0,1.0,1.0)
* 147 *           (17,20) (1.0,.50,.30,.30)
* 148 *           (21,24) (.20,.20,.20,.05)
* 149 *   (SAT)   (1,4) (.05)
* 150 *           (5,8) (.05,.05,.10,.10)
* 151 *           (9,17) (.30)
* 152 *           (18,20) (.05,.05,.05)
* 153 *           (21,24) (.05)
* 154 *   (SUN,HOL) (1,24) (.05) ..
* 155 *
* 156 *   $-----MAX DIRECT SOLAR GAIN (BTUH/SF) FOR DRAPE CONTROL-----$
* 157 *
* 158 *   SOLGAIN-SCH-1 =SCHEDULE THRU DEC 31 (ALL) (1,24) (20.) .. $$
* 159 *
* 160 *   $-----VIS TRANS MULTIPLIER FOR LIGHT-COLOR TRANSLUCENT DRAPES---$
* 161 *
* 162 *   TVIS-SCH-1 =SCHEDULE THRU DEC 31 (ALL) (1,24) (.35) .. $$
* 163 *
* 164 *   $-----SHADING COEFF MULTIPLIER FOR DRAPES-----$
* 165 *
* 166 *   SHADSC-1 =SCHEDULE THRU DEC 31 (ALL) (1,24) (0.6) ..
* 167 *
* 168 *   $-----DAYLIGHTING REPORT SCHEDULE-----$
* 169 *
* 170 *   DAYREP-SCH-1 =SCHEDULE THRU DEC 31 (ALL) (1,8) (0) (9,17) (1) (18,24) (0) .. $$
* 171 *
* 172 *   $-----CONSTRUCTIONS-----$
* 173 *
* 174 *   EXTWALL = CONS U = .10 ABS = .5 ..
* 175 *   PARTITION = CONS U = 0.5 ..
* 176 *
* 177 *   $-----SET DEFAULTS-----$
* 178 *
* 179 *   SET-DEFAULT FOR E-W H=10 X=0 Y=0 A2=180 CONS=EXTWALL ..
* 180 *   SET-DEFAULT FOR I-W CONS = PARTITION ..
* 181 *   SET-DEFAULT FOR WINDOW SHADING-SCHEDULE = SHADSC-1
* 182 *   Y = 4 $$

```

```

* 183 *          VIS-TRANS-SCH = TVIS-SCH-1          $$
* 184 *          MAX-SOLAR-SCH = SOLGAIN-SCH-1      $$
* 185 *          WIN-SHADE-TYPE = MOVABLE-INTERIOR  $$
* 186 *          ..
* 187 *          SET-DEFAULT FOR SPACE AREA = PERIM-OFF-AREA
* 188 *          DAYLIGHTING = YES                    $$
* 189 *          LIGHT-REF-POINT1 = (10,10,2.5)      $$
* 190 *          ZONE-FRACTION1 = 0.5              $$
* 191 *          LIGHT-SET-POINT1 = 50             $$
* 192 *          LIGHT-CTRL-TYPE1 = CONTINUOUS      $$
* 193 *          DAYLIGHT-REP-SCH = DAYREP-SCH-1   $$
* 194 *          ..
* 195 *
* 196 * $-----SPACE CONDITIONS-----$
* 197 *
* 198 *          CORESPACE = S-C          T = (75)
* 199 *          P-SCH = OCC-SCH
* 200 *          I-SCH = INF-SCH
* 201 *          AREA/PERSON = 100
* 202 *          P-H-G = 450
* 203 *          L-SCH = CORE-LITE-SCH
* 204 *          LIGHTING-W/SQFT = 2
* 205 *          L-T-S = .75
* 206 *          L-T-R = .25
* 207 *          E-W = 1.0
* 208 *          INF-METHOD = AIR-CHANGE
* 209 *          AIR-CHANGES/HR = 0.6
* 210 *          FLOOR-WEIGHT = 70
* 211 *          Z-TYPE = CONDITIONED ..
* 212 *
* 213 *          PERIMSPACE = S-C          LIKE CORESPACE ..
* 214 *
* 215 * $-----GLASS-TYPE-----$
* 216 *
* 217 *          PERINGLASS = GLASS-TYPE PANES=2 S-C=.83
* 218 *          VIS-TRANS=.68          ..          $$
* 219 *
* 220 * $-----SPACES-----$
* 221 *
* 222 *          COREZONE = SPACE          DAYLIGHTING = NO          $$
* 223 *          AREA = CORE-AREA
* 224 *          V = CORE-AREA TIMES 10.0
* 225 *          S-C = CORESPACE          ..
* 226 *
* 227 *          NORTHZONE = SPACE          M=7
* 228 *          DAYL-LTCTRL-FN = (*NONE*,*LTCTRL-FN-1*)          $$
* 229 *          X=110 Y=200 AZ=180
* 230 *          V = PERIM-OFF-AREA TIMES 10
* 231 *          S-C = PERIMSPACE          ..
* 232 *
* 233 *          N-LEFTPART = I-W          AREA=300 INT-WALL-TYPE = ADIABATIC ..
* 234 *          N-RIGHTPART = I-W          LIKE N-LEFTPART ..
* 235 *          NORTHPART = I-W          AREA=200 NEXT-TO = COREZONE ..
* 236 *          N-INTFLR = I-W          INT-WALL-TYPE = ADIABATIC
* 237 *          AREA=PERIM-OFF-AREA TILT=180 ..          $$
* 238 *          N-INTCEIL = I-W          INT-WALL-TYPE = ADIABATIC
* 239 *          AREA=PERIM-OFF-AREA TILT=0 ..          $$
* 240 *          NORTHWALL = E-W          W = PERIM-OFF-WIDTH          ..
* 241 *          NORTHWIND = WI          W = PERIM-OFF-WIDTH H = WWR TIMES 10.0
* 242 *          GLASS-TYPE = PERINGLASS
* 243 *          ..
* 244 *
* 245 *          SOUTHZONE = SPACE          M=7

```

```

* 246 *           X=90 Y=0 AZ=0
* 247 *           V = PERIM-OFF-AREA TIMES 10.0
* 248 *           S-C = PERIMSPACE ..
* 249 *
* 250 *           S-LEFTPART =I-W     LIKE N-LEFTPART ..
* 251 *           S-RIGHTPART=I-W    LIKE S-LEFTPART ..
* 252 *           SOUTHPART = I-W    LIKE NORTHPART ..
* 253 *           SOUTHWALL = E-W    LIKE NORTHWALL ..
* 254 *           SOUTHWIND = WI      W = PERIM-OFF-WIDTH H = WWR TIMES 10.0
* 255 *           GLASS-TYPE = PERIMGLASS
* 256 *           ..
* 257 *           S-INTFLR = I-W     LIKE N-INTFLR ..
* 258 *           S-INTCEIL = I-W   LIKE N-INTCEIL ..
* 259 *
* 260 * EASTZONE = SPACE           M=7
* 261 *                               X=200 Y=90 AZ=270
* 262 *                               V = PERIM-OFF-AREA TIMES 10.0
* 263 *                               S-C = PERIMSPACE ..
* 264 *
* 265 *           E-LEFTPART=I-W     LIKE N-LEFTPART ..
* 266 *           E-RIGHTPART=I-W    LIKE E-LEFTPART ..
* 267 *           EASTPART = I-W    LIKE NORTHPART ..
* 268 *           E-INTFLR = I-W    LIKE N-INTFLR ..
* 269 *           E-INTCEIL= I-W    LIKE N-INTCEIL ..
* 270 *           EASTWALL = E-W    W = PERIM-OFF-WIDTH ..
* 271 *           EASTWIND = WI      W = PERIM-OFF-WIDTH H = WWR TIMES 10.0
* 272 *           GLASS-TYPE = PERIMGLASS
* 273 *           ..
* 274 *
* 275 * WESTZONE = SPACE           M=7
* 276 *                               X=0 Y=110 AZ=90
* 277 *                               V = PERIM-OFF-AREA TIMES 10.0
* 278 *                               S-C = PERIMSPACE ..
* 279 *
* 280 *           W-LEFTPART=I-W     LIKE N-LEFTPART ..
* 281 *           W-RIGHTPART=I-W    LIKE W-LEFTPART ..
* 282 *           WESTPART = I-W    LIKE NORTHPART ..
* 283 *           W-INTFLR = I-W    LIKE N-INTFLR ..
* 284 *           W-INTCEIL= I-W    LIKE N-INTCEIL ..
* 285 *
* 286 *           WESTWALL = E-W     LIKE EASTWALL ..
* 287 *           WESTWIND = WI      W = PERIM-OFF-WIDTH H = WWR TIMES 10.0
* 288 *           GLASS-TYPE = PERIMGLASS
* 289 *           ..
* 290 *
* 291 *
* 292 * LOADS-REPORT   S=(LS-C,LS-G,LS-H,LS-I,LS-J) V=(LV-L)
* 293 *               ..
* 294 *
* 295 * $-----HOURLY REPORTS-----$
* 296 *
* 297 * SCH-1   =SCHEDULE THRU JAN 1 (ALL) (1,24) (0)
* 298 *               THRU JAN 2 (ALL) (1,24) (1)
* 299 *               THRU DEC 31 (ALL) (1,24) (0)
* 300 *               ..
* 301 * BG      =R-B      V-T=GLOBAL
* 302 *               V-L=(4,6,21,22,15,48,49,50,51,52,53,54,55,56,57,58,59) ..
* 303 * BSN     =R-B      V-T=NORTHZONE
* 304 *               V-L=(49,51,53,55,57,45) ..
* 305 * BSS     =R-B      LIKE BSN V-T=SOUTHZONE ..
* 306 * BSE     =R-B      LIKE BSN V-T=EASTZONE ..
* 307 * BSW     =R-B      LIKE BSN V-T=WESTZONE ..
* 308 *

```

```

* 309 * BWN      =R-B      V-T=NORTHWIND
* 310 *          =R-B      V-L=(1,2,4,10,11,12,15,17,23,16,19,21,22,20,23,26) ..
* 311 * BWS      =R-B      LIKE BWN  V-T=SOUTHWIND ..
* 312 * BWE      =R-B      LIKE BWN  V-T=EASTWIND ..
* 313 * BWV      =R-B      LIKE BWN  V-T=WESTWIND ..
* 314 *
* 315 * REP1     =H-R      R-SCH=SCH-1  R-B=(BG) ..
* 316 * REP2     =H-R      R-SCH=SCH-1  R-B=(BSN,BSS,BSE,BSW) ..
* 317 * REP3     =H-R      R-SCH=SCH-1  R-B=(BWN,BWS) ..
* 318 * REP4     =H-R      R-SCH=SCH-1  R-B=(BWE,BWV) ..
* 319 *
* 320 * PLTSCH  = SCHEDULE THRU JAN 1 (ALL) (1,24) (0)
* 321 *          THRU JAN 2 (ALL) (1,6) (0) (7,19) (1) (20,24) (0)
* 322 *          THRU DEC 31 (ALL) (1,24) (0) ..
* 323 * PLOTER1 = REPORT-BLOCK
* 324 *          VARIABLE-TYPE = GLOBAL
* 325 *          VARIABLE-LIST = (15) .. $GLOBAL HORIZONTAL SOLAR
* 326 *
* 327 * PLOTER2 = REPORT-BLOCK
* 328 *          VARIABLE-TYPE = SOUTHZONE
* 329 *          VARIABLE-LIST = (49) .. $DAYL ILLUM, REF PT 1
* 330 *
* 331 * PLOTD  = HOURLY-REPORT
* 332 *          REPORT-SCHEDULE=PLTSCH
* 333 *          REPORT-BLOCK   = (PLOTER1,PLOTER2)
* 334 *          OPTION         = PLOT
* 335 *          AXIS-ASSIGN    = (1,2)
* 336 *          AXIS-TITLES    = (*EXTERIOR SOLAR*,*INTERIOR DAYLITE*)
* 337 *          AXIS-MAX       = (500,100)
* 338 *          AXIS-MIN       = (0,0)
* 339 *          DIVIDE         = (1,1) ..
* 340 * END ..
* 341 *
* 342 *
* 343 * $ NORTHZONE DIMMING SYSTEM HAS NON-LINEAR POWER CURVE --
* 344 * $ APPROXIMATE THE CURVE WITH THREE STRAIGHT SEGMENTS CONNECTING THE
* 345 * $ (LIGHT OUT, POWER IN) POINTS (0,0), (.3,.5), (.6,.8), (1.1)
* 346 *
* 347 *
* 348 *          FUNCTION NAME=LTCTRL-FN-1 LEVEL=SPACE ..          $$
* 349 *          ASSIGN  ILLUM=DAYLIGHT-ILLUM1                    $$
* 350 *                  PMUL1=FPHRP1                             $$
* 351 *                  PMUL=POWER-RED-FAC                       $$
* 352 *                  ZF1=ZONE-FRACTION1                      $$
* 353 *                  SETPT=LIGHT-SET-POINT1 ..              $$
* 354 *          ASSIGN  POWCRV=TABLE (0,0) (0.3,0.5) (0.6,0.8) (1.0,1.0) .. $$
* 355 *          CALCULATE ..                                     $$
* 356 *          FLTOUT = (SETPT - ILLUM)/SETPT                  $$
* 357 *          IF (FLTOUT.LT.0.0) FLTOUT = 0.0                 $$
* 358 *          PMUL1 = PWL(POWCRV,FLTOUT)                       $$
* 359 *          PMUL = PMUL1*ZF1 + (1.0-ZF1)                     $$
* 360 *          END                                             $$

```

----- S Y M B O L T A B L E -----

FLTOUT	**LOCAL*	ILLUM	(GLOBAL)	PMUL	(GLOBAL)	PMUL1	(GLOBAL)	POWCRV	(TABLE)
SETPT	(GLOBAL)	ZF1	(GLOBAL)						

```

* 361 *          END-FUNCTION ..          $$
* 362 *
* 363 * COMPUTE LOADS ..

```


SPACE--NORTHZONE WINDOW--NORTHWIND REF PT NO.--1
 AREA(SQFT) 600.0 SC 0.83 GTC 1 VIS-TRANS 0.68 X(FT) 10.0 Y(FT) 10.0 Z(FT) 2.5
 AV REFL 0.46 H(FT) 3.0 W(FT) 20.0 ZONE-FRACTION 0.50
 MAX-GLARE 100.0 AZIM(DEG) 0.0 TILT(DEG) 90.0 LTG-SET-POINT(FC) 50.0
 VW-AZ(DEG) 90.0 DAY-X-DIV 8 DAY-Y-DIV 8 LTG-CTRL-TYPE CONTINUOUS
 X(FT) 0.0 Y(FT) 0.0 Z(FT) 4.0
 WIN-SHADE-TYPE MOVABLE-INTERIOR

SUN	WIN	SUN	SUN	EXT	EXT	DIR	REFL	DIR	REFL	DAY	DAY	WIN	WIN	BACKG	BACKG	GLARE	
POS	DAY	SHD	SUN	ILL	ILL	ILL	ILL	ILL	ILL	ILL	ILL	LUM	LUM	LUM	LUM	INDEX	
NO.	TYP	IND	ALT	-SKY	-SUN	-SKY	-SKY	-SUN	-SUN	-SKY	-SKY	-SKY	-SUN	-SKY	-SUN		
			DEG)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)		
1	1	1	10.	290.	1331.8	164.6	63.3	21.0	0.0	4.5	0.0633	0.0273	1.7388	0.0000	0.0073	0.0126	15.2
1	1	2	10.	290.	1331.8	164.6	35.7	27.9	7.9	6.2	0.0477	0.0860	0.8656	1.5607	0.0097	0.0175	13.4
1	2	1	10.	290.	366.9	0.0	7.5	3.2	0.0	0.0	0.0291	0.0000	0.6355	0.0000	0.0041	0.0000	4.9
1	2	2	10.	290.	366.9	0.0	5.1	4.0	0.0	0.0	0.0246	0.0000	0.4461	0.0000	0.0050	0.0000	2.9
2	1	1	10.	235.	1331.8	164.6	43.6	13.8	0.0	0.5	0.0431	0.0029	1.1225	0.0000	0.0048	0.0013	13.6
2	1	2	10.	235.	1331.8	164.6	22.3	17.4	0.5	0.4	0.0299	0.0050	0.5417	0.0909	0.0061	0.0010	10.7
3	1	1	10.	180.	1331.8	164.6	49.0	14.0	0.0	0.5	0.0473	0.0029	1.2276	0.0000	0.0049	0.0013	14.0
3	1	2	10.	180.	1331.8	164.6	22.6	17.7	0.5	0.4	0.0303	0.0050	0.5491	0.0909	0.0062	0.0010	10.8
4	1	1	10.	125.	1331.8	164.6	43.6	13.8	0.0	0.5	0.0431	0.0029	1.1225	0.0000	0.0048	0.0013	13.6
4	1	2	10.	125.	1331.8	164.6	22.3	17.4	0.5	0.4	0.0299	0.0050	0.5417	0.0909	0.0061	0.0010	10.7
5	1	1	10.	70.	1331.8	164.6	63.3	21.0	0.0	4.5	0.0633	0.0273	1.7388	0.0000	0.0073	0.0126	15.2
5	1	2	10.	70.	1331.8	164.6	35.7	27.9	7.9	6.2	0.0477	0.0860	0.8656	1.5607	0.0097	0.0175	13.4
6	1	1	31.	290.	2104.9	2160.2	85.4	28.9	0.0	20.8	0.0543	0.0096	1.4371	0.0000	0.0064	0.0045	16.1
6	1	2	31.	290.	2104.9	2160.2	48.5	37.9	33.2	25.9	0.0411	0.0274	0.7447	0.4965	0.0083	0.0056	15.4
7	1	1	31.	235.	2104.9	2160.2	55.9	19.2	0.0	6.2	0.0357	0.0029	0.9123	0.0000	0.0042	0.0013	14.6
7	1	2	31.	235.	2104.9	2160.2	30.4	23.8	6.1	4.7	0.0257	0.0050	0.4668	0.0909	0.0052	0.0010	12.7
8	1	1	31.	180.	2104.9	2160.2	59.2	18.7	0.0	6.2	0.0370	0.0029	0.9448	0.0000	0.0041	0.0013	14.7
8	1	2	31.	180.	2104.9	2160.2	29.5	23.0	6.1	4.7	0.0249	0.0050	0.4525	0.0909	0.0051	0.0010	12.6
9	1	1	31.	125.	2104.9	2160.2	55.9	19.2	0.0	6.2	0.0357	0.0029	0.9123	0.0000	0.0042	0.0013	14.6
9	1	2	31.	125.	2104.9	2160.2	30.4	23.8	6.1	4.7	0.0257	0.0050	0.4668	0.0909	0.0052	0.0010	12.7
10	1	1	31.	70.	2104.9	2160.2	85.4	28.9	0.0	20.8	0.0543	0.0096	1.4371	0.0000	0.0064	0.0045	16.1
10	1	2	31.	70.	2104.9	2160.2	48.5	37.9	33.2	25.9	0.0411	0.0274	0.7447	0.4965	0.0083	0.0056	15.4
11	1	1	51.	290.	2565.4	4622.3	84.2	29.8	0.0	25.3	0.0444	0.0055	1.1134	0.0000	0.0054	0.0025	15.8
11	1	2	51.	290.	2565.4	4622.3	48.9	38.2	35.3	27.6	0.0339	0.0136	0.6155	0.2465	0.0069	0.0028	15.5
12	1	1	51.	235.	2565.4	4622.3	59.8	21.9	0.0	13.3	0.0319	0.0029	0.7948	0.0000	0.0040	0.0013	14.8
12	1	2	51.	235.	2565.4	4622.3	34.3	26.8	13.0	10.2	0.0238	0.0050	0.4317	0.0909	0.0048	0.0010	13.7
13	1	1	51.	180.	2565.4	4622.3	58.9	20.8	0.0	13.3	0.0310	0.0029	0.7744	0.0000	0.0037	0.0013	14.7
13	1	2	51.	180.	2565.4	4622.3	32.1	25.1	13.0	10.2	0.0223	0.0050	0.4042	0.0909	0.0045	0.0010	13.5
14	1	1	51.	125.	2565.4	4622.3	59.8	21.9	0.0	13.3	0.0319	0.0029	0.7948	0.0000	0.0040	0.0013	14.8
14	1	2	51.	125.	2565.4	4622.3	34.3	26.8	13.0	10.2	0.0238	0.0050	0.4317	0.0909	0.0048	0.0010	13.7
15	1	1	51.	70.	2565.4	4622.3	84.2	29.8	0.0	25.3	0.0444	0.0055	1.1134	0.0000	0.0054	0.0025	15.8
15	1	2	51.	70.	2565.4	4622.3	48.9	38.2	35.3	27.6	0.0339	0.0136	0.6155	0.2465	0.0069	0.0028	15.5
16	1	1	72.	290.	3143.7	6245.4	86.1	31.7	0.0	21.8	0.0375	0.0035	0.9082	0.0000	0.0047	0.0016	15.9
16	1	2	72.	290.	3143.7	6245.4	51.0	39.9	24.5	19.2	0.0289	0.0070	0.5244	0.1270	0.0059	0.0014	15.2
17	1	1	72.	235.	3143.7	6245.4	71.6	27.1	0.0	18.0	0.0314	0.0029	0.7654	0.0000	0.0040	0.0013	15.3
17	1	2	72.	235.	3143.7	6245.4	42.4	33.1	17.6	13.7	0.0240	0.0050	0.4357	0.0909	0.0049	0.0010	14.6
18	1	1	72.	180.	3143.7	6245.4	68.2	25.7	0.0	18.0	0.0299	0.0029	0.7292	0.0000	0.0038	0.0013	15.2
18	1	2	72.	180.	3143.7	6245.4	39.9	31.2	17.6	13.7	0.0226	0.0050	0.4099	0.0909	0.0046	0.0010	14.4
19	1	1	72.	125.	3143.7	6245.4	71.6	27.1	0.0	18.0	0.0314	0.0029	0.7654	0.0000	0.0040	0.0013	15.3
19	1	2	72.	125.	3143.7	6245.4	42.4	33.1	17.6	13.7	0.0240	0.0050	0.4357	0.0909	0.0049	0.0010	14.6
20	1	1	72.	70.	3143.7	6245.4	86.1	31.7	0.0	21.8	0.0375	0.0035	0.9082	0.0000	0.0047	0.0016	15.9
20	1	2	72.	70.	3143.7	6245.4	51.0	39.9	24.5	19.2	0.0289	0.0070	0.5244	0.1270	0.0059	0.0014	15.2

NOTE -- ABOVE VALUES ASSUME VISIBLE TRANSMITTANCE = 1.0 FOR WINDOW GLASS AND SHADING DEVICE.
 ACTUAL TRANSMITTANCES ARE USED IN THE HOURLY CALCULATION.

SPACE--SOUTHZONE WINDOW--SOUTHWIND REF PT NO.--1
 AREA(SQFT) 600.0 SC 0.83 GTC 1 VIS-TRANS 0.68 X(FT) 10.0 Y(FT) 10.0 Z(FT) 2.5
 AV REFL 0.46 H(FT) 3.0 W(FT) 20.0 ZONE-FRACTION 0.50
 MAX-GLARE 100.0 AZIM(DEG) 180.0 TILT(DEG) 90.0 LTG-SET-POINT(FC) 50.0
 VW-AZ(DEG) 270.0 DAY-X-DIV 8 DAY-Y-DIV 8 LTG-CTRL-TYPE CONTINUOUS
 X(FT) 0.0 Y(FT) 0.0 Z(FT) 4.0
 WIN-SHADE-TYPE MOVABLE-INTERIOR

SUN POS NO.	WIN DAY TYP	SUN SHD IND	SUN ALT (DEG)	SUN AZIM (DEG)	EXT ILL -SKY (FC)	EXT ILL -SUN (FC)	DIR ILL -SKY (FC)	REFL ILL -SKY (FC)	DIR ILL -SUN (FC)	REFL ILL -SUN (FC)	DAY ILL -SKY (FC)	DAY ILL -SUN (FC)	WIN ILL -SKY (FC)	WIN ILL -SUN (FC)	BACKG ILL -SKY (FC)	BACKG ILL -SUN (FC)	GLARE INDEX
1	1	1	10.	290.	1331.8	164.6	43.1	14.3	0.0	0.5	0.0431	0.0029	1.1282	0.0000	0.0050	0.0013	13.7
1	1	2	10.	290.	1331.8	164.6	23.2	18.1	0.5	0.4	0.0311	0.0050	0.5635	0.0909	0.0063	0.0010	10.9
1	2	1	10.	290.	366.9	0.0	7.5	3.2	0.0	0.0	0.0291	0.0000	0.6355	0.0000	0.0041	0.0000	4.9
1	2	2	10.	290.	366.9	0.0	5.1	4.0	0.0	0.0	0.0246	0.0000	0.4461	0.0000	0.0050	0.0000	2.9
2	1	1	10.	235.	1331.8	164.6	90.7	25.7	0.0	8.8	0.0874	0.0535	2.5584	0.0000	0.0089	0.0248	16.5
2	1	2	10.	235.	1331.8	164.6	44.5	34.8	16.0	12.5	0.0595	0.1731	1.0793	3.1409	0.0121	0.0352	14.6
3	1	1	10.	180.	1331.8	164.6	197.8	36.4	164.1	15.9	0.1758	1.0938	4.4036	0.0000	0.0126	0.0448	18.1
3	1	2	10.	180.	1331.8	164.6	64.3	50.3	29.3	22.9	0.0860	0.3167	1.5609	5.7454	0.0175	0.0643	15.8
4	1	1	10.	125.	1331.8	164.6	90.7	25.7	0.0	8.8	0.0874	0.0535	2.5584	0.0000	0.0089	0.0248	16.5
4	1	2	10.	125.	1331.8	164.6	44.5	34.8	16.0	12.5	0.0595	0.1731	1.0793	3.1409	0.0121	0.0352	14.6
5	1	1	10.	70.	1331.8	164.6	43.1	14.3	0.0	0.5	0.0431	0.0029	1.1282	0.0000	0.0050	0.0013	13.7
5	1	2	10.	70.	1331.8	164.6	23.2	18.1	0.5	0.4	0.0311	0.0050	0.5635	0.0909	0.0063	0.0010	10.9
6	1	1	31.	290.	2104.9	2160.2	57.2	20.2	0.0	6.2	0.0367	0.0029	0.9412	0.0000	0.0044	0.0013	14.7
6	1	2	31.	290.	2104.9	2160.2	32.2	25.2	6.1	4.7	0.0273	0.0050	0.4949	0.0909	0.0055	0.0010	12.9
7	1	1	31.	235.	2104.9	2160.2	115.1	34.5	0.0	37.7	0.0711	0.0175	1.9308	0.0000	0.0076	0.0081	16.8
7	1	2	31.	235.	2104.9	2160.2	58.8	46.0	64.7	50.6	0.0498	0.0534	0.9034	0.9679	0.0101	0.0108	16.5
8	1	1	31.	180.	2104.9	2160.2	229.9	47.0	0.0	66.1	0.1316	0.0306	3.1907	0.0000	0.0103	0.0142	18.2
8	1	2	31.	180.	2104.9	2160.2	82.1	64.2	117.5	91.8	0.0695	0.0969	1.2605	1.7581	0.0141	0.0197	17.8
9	1	1	31.	125.	2104.9	2160.2	115.1	34.5	0.0	37.7	0.0711	0.0175	1.9308	0.0000	0.0076	0.0081	16.8
9	1	2	31.	125.	2104.9	2160.2	58.8	46.0	64.7	50.6	0.0498	0.0534	0.9034	0.9679	0.0101	0.0108	16.5
10	1	1	31.	70.	2104.9	2160.2	57.2	20.2	0.0	6.2	0.0367	0.0029	0.9412	0.0000	0.0044	0.0013	14.7
10	1	2	31.	70.	2104.9	2160.2	32.2	25.2	6.1	4.7	0.0273	0.0050	0.4949	0.0909	0.0055	0.0010	12.9
11	1	1	51.	290.	2565.4	4622.3	62.4	23.1	0.0	13.3	0.0333	0.0029	0.8317	0.0000	0.0042	0.0013	14.9
11	1	2	51.	290.	2565.4	4622.3	36.4	28.4	13.0	10.2	0.0253	0.0050	0.4585	0.0909	0.0051	0.0010	13.9
12	1	1	51.	235.	2565.4	4622.3	99.4	33.4	0.0	41.3	0.0518	0.0089	1.2972	0.0000	0.0060	0.0041	16.1
12	1	2	51.	235.	2565.4	4622.3	55.7	43.5	65.1	50.9	0.0387	0.0251	0.7013	0.4550	0.0079	0.0051	16.5
13	1	1	51.	180.	2565.4	4622.3	145.2	41.7	0.0	72.7	0.0729	0.0157	1.7541	0.0000	0.0075	0.0073	16.8
13	1	2	51.	180.	2565.4	4622.3	71.2	55.6	123.6	96.6	0.0494	0.0477	0.8964	0.8645	0.0100	0.0097	17.7
14	1	1	51.	125.	2565.4	4622.3	99.4	33.4	0.0	41.3	0.0518	0.0089	1.2972	0.0000	0.0060	0.0041	16.1
14	1	2	51.	125.	2565.4	4622.3	55.7	43.5	65.1	50.9	0.0387	0.0251	0.7013	0.4550	0.0079	0.0051	16.5
15	1	1	51.	70.	2565.4	4622.3	62.4	23.1	0.0	13.3	0.0333	0.0029	0.8317	0.0000	0.0042	0.0013	14.9
15	1	2	51.	70.	2565.4	4622.3	36.4	28.4	13.0	10.2	0.0253	0.0050	0.4585	0.0909	0.0051	0.0010	13.9
16	1	1	72.	290.	3143.7	6245.4	74.3	28.0	0.0	18.0	0.0325	0.0029	0.7923	0.0000	0.0041	0.0013	15.5
16	1	2	72.	290.	3143.7	6245.4	44.1	34.5	17.6	13.7	0.0250	0.0050	0.4534	0.0909	0.0051	0.0010	14.7
17	1	1	72.	235.	3143.7	6245.4	91.7	33.3	0.0	27.8	0.0398	0.0044	0.9617	0.0000	0.0049	0.0021	16.0
17	1	2	72.	235.	3143.7	6245.4	54.0	42.2	35.7	27.9	0.0306	0.0102	0.5556	0.1850	0.0062	0.0021	15.7
18	1	1	72.	180.	3143.7	6245.4	105.0	36.8	0.0	43.2	0.0451	0.0069	1.0806	0.0000	0.0054	0.0032	16.1
18	1	2	72.	180.	3143.7	6245.4	60.6	47.3	64.4	50.3	0.0343	0.0184	0.6226	0.3333	0.0070	0.0037	16.6
19	1	1	72.	125.	3143.7	6245.4	91.7	33.3	0.0	27.8	0.0398	0.0044	0.9617	0.0000	0.0049	0.0021	16.0
19	1	2	72.	125.	3143.7	6245.4	54.0	42.2	35.7	27.9	0.0306	0.0102	0.5556	0.1850	0.0062	0.0021	15.7
20	1	1	72.	70.	3143.7	6245.4	74.3	28.0	0.0	18.0	0.0325	0.0029	0.7923	0.0000	0.0041	0.0013	15.5
20	1	2	72.	70.	3143.7	6245.4	44.1	34.5	17.6	13.7	0.0250	0.0050	0.4534	0.0909	0.0051	0.0010	14.7

NOTE -- ABOVE VALUES ASSUME VISIBLE TRANSMITTANCE = 1.0 FOR WINDOW GLASS AND SHADING DEVICE.
 ACTUAL TRANSMITTANCES ARE USED IN THE HOURLY CALCULATION.

SPACE--EASTZONE WINDOW--EASTWIND REF PT NO.--1
 AREA (SQFT) 600.0 SC 0.83 GTC 1 VIS-TRANS 0.68 X(FT) 10.0 Y(FT) 10.0 Z(FT) 2.5
 AV REFL 0.46 H(FT) 3.0 W(FT) 20.0 ZONE-FRACTION 0.50
 MAX-GLARE 100.0 AZIM(DEG) 90.0 TILT(DEG) 90.0 LTG-SET-POINT(FC) 50.0
 VW-AZ(DEG) 180.0 DAY-X-DIV 8 DAY-Y-DIV 8 LTG-CTRL-TYPE CONTINUOUS
 X(FT) 0.0 Y(FT) 0.0 Z(FT) 4.0
 WIN-SHADE-TYPE MOVABLE-INTERIOR

SUN	WIN	SUN	SUN	EXT	EXT	DIR	REFL	DIR	REFL	DAY	DAY	WIN	WIN	BACKG	BACKG		
POS	DAY	SHD	ALT	AZIM	-SKY	-SUN	-SKY	-SUN	-SUN	ILL	ILL	LUM	LUM	LUM	LUM	GLARE	
NO.	TYP	IND	(DEG)	(DEG)	(FC)	(FC)	(FC)	(FC)	(FC)	-SKY	-SUN	-SKY	-SUN	-SKY	-SUN	INDEX	
1	1	1	10.	290.	1331.8	164.6	47.9	13.9	0.0	0.5	0.0464	0.0029	1.2053	0.0000	0.0048	0.0013	13.9
1	1	2	10.	290.	1331.8	164.6	22.5	17.6	0.5	0.4	0.0301	0.0050	0.5453	0.0909	0.0061	0.0010	10.8
1	2	1	10.	290.	366.9	0.0	7.5	3.2	0.0	0.0	0.0291	0.0000	0.6355	0.0000	0.0041	0.0000	4.9
1	2	2	10.	290.	366.9	0.0	5.1	4.0	0.0	0.0	0.0246	0.0000	0.4461	0.0000	0.0050	0.0000	2.9
2	1	1	10.	235.	1331.8	164.6	46.1	13.8	0.0	0.5	0.0449	0.0029	1.1676	0.0000	0.0048	0.0013	13.8
2	1	2	10.	235.	1331.8	164.6	22.3	17.4	0.5	0.4	0.0298	0.0050	0.5402	0.0909	0.0060	0.0010	10.7
3	1	1	10.	180.	1331.8	164.6	47.5	16.4	0.0	0.5	0.0479	0.0029	1.2688	0.0000	0.0057	0.0013	14.1
3	1	2	10.	180.	1331.8	164.6	27.1	21.1	0.5	0.4	0.0362	0.0050	0.6565	0.0909	0.0074	0.0010	11.6
4	1	1	10.	125.	1331.8	164.6	154.0	31.4	161.4	12.9	0.1392	1.0592	4.2159	99.0000	0.0109	0.0364	21.9
4	1	2	10.	125.	1331.8	164.6	55.1	43.1	23.7	18.5	0.0737	0.2561	1.3370	4.6464	0.0150	0.0520	15.4
5	1	1	10.	70.	1331.8	164.6	186.2	34.8	162.7	14.9	0.1660	1.0791	4.4863	0.0000	0.0121	0.0419	18.2
5	1	2	10.	70.	1331.8	164.6	61.5	48.0	27.3	21.3	0.0822	0.2955	1.4912	5.3599	0.0167	0.0600	15.7
6	1	1	31.	290.	2104.9	2160.2	58.4	18.7	0.0	6.2	0.0366	0.0029	0.9348	0.0000	0.0041	0.0013	14.6
6	1	2	31.	290.	2104.9	2160.2	29.5	23.0	6.1	4.7	0.0249	0.0050	0.4523	0.0909	0.0051	0.0010	12.6
7	1	1	31.	235.	2104.9	2160.2	57.1	18.8	0.0	6.2	0.0360	0.0029	0.9197	0.0000	0.0041	0.0013	14.6
7	1	2	31.	235.	2104.9	2160.2	29.6	23.1	6.1	4.7	0.0250	0.0050	0.4539	0.0909	0.0051	0.0010	12.6
8	1	1	31.	180.	2104.9	2160.2	64.8	23.2	0.0	6.2	0.0418	0.0029	1.0804	0.0000	0.0051	0.0013	15.1
8	1	2	31.	180.	2104.9	2160.2	37.8	29.6	6.1	4.7	0.0320	0.0050	0.5807	0.0909	0.0065	0.0010	13.4
9	1	1	31.	125.	2104.9	2160.2	172.3	41.3	0.0	54.7	0.1015	0.0253	2.7318	0.0000	0.0091	0.0117	17.8
9	1	2	31.	125.	2104.9	2160.2	71.5	55.9	96.3	75.3	0.0605	0.0794	1.0980	1.4408	0.0123	0.0161	17.3
10	1	1	31.	70.	2104.9	2160.2	209.8	45.1	0.0	62.3	0.1211	0.0288	3.0729	0.0000	0.0099	0.0134	18.1
10	1	2	31.	70.	2104.9	2160.2	78.7	61.5	110.5	86.3	0.0666	0.0911	1.2081	1.6530	0.0135	0.0185	17.6
11	1	1	51.	290.	2565.4	4622.3	58.7	20.9	0.0	13.3	0.0310	0.0029	0.7742	0.0000	0.0038	0.0013	14.7
11	1	2	51.	290.	2565.4	4622.3	32.3	25.2	13.0	10.2	0.0224	0.0050	0.4067	0.0909	0.0046	0.0010	13.6
12	1	1	51.	235.	2565.4	4622.3	58.7	21.1	0.0	13.3	0.0311	0.0029	0.7766	0.0000	0.0038	0.0013	14.7
12	1	2	51.	235.	2565.4	4622.3	32.8	25.6	13.0	10.2	0.0228	0.0050	0.4129	0.0909	0.0046	0.0010	13.6
13	1	1	51.	180.	2565.4	4622.3	70.0	25.7	0.0	13.3	0.0373	0.0029	0.9328	0.0000	0.0046	0.0013	15.3
13	1	2	51.	180.	2565.4	4622.3	41.3	32.3	13.0	10.2	0.0287	0.0050	0.5199	0.0909	0.0058	0.0010	14.2
14	1	1	51.	125.	2565.4	4622.3	122.6	37.9	0.0	59.8	0.0626	0.0129	1.5491	0.0000	0.0068	0.0060	16.5
14	1	2	51.	125.	2565.4	4622.3	64.1	50.1	99.5	77.7	0.0445	0.0383	0.8074	0.6955	0.0090	0.0078	17.3
15	1	1	51.	70.	2565.4	4622.3	137.1	40.5	0.0	68.5	0.0692	0.0148	1.6859	0.0000	0.0073	0.0069	16.7
15	1	2	51.	70.	2565.4	4622.3	68.8	53.8	115.8	90.5	0.0478	0.0446	0.8670	0.8094	0.0097	0.0091	17.6
16	1	1	72.	290.	3143.7	6245.4	68.6	25.9	0.0	18.0	0.0300	0.0029	0.7334	0.0000	0.0038	0.0013	15.2
16	1	2	72.	290.	3143.7	6245.4	40.2	31.4	17.6	13.7	0.0228	0.0050	0.4131	0.0909	0.0046	0.0010	14.4
17	1	1	72.	235.	3143.7	6245.4	69.4	26.3	0.0	18.0	0.0304	0.0029	0.7426	0.0000	0.0039	0.0013	15.2
17	1	2	72.	235.	3143.7	6245.4	40.8	31.9	17.6	13.7	0.0231	0.0050	0.4199	0.0909	0.0047	0.0010	14.5
18	1	1	72.	180.	3143.7	6245.4	79.3	29.7	0.0	18.0	0.0347	0.0029	0.8429	0.0000	0.0044	0.0013	15.7
18	1	2	72.	180.	3143.7	6245.4	47.2	36.9	17.6	13.7	0.0267	0.0050	0.4851	0.0909	0.0054	0.0010	14.8
19	1	1	72.	125.	3143.7	6245.4	98.9	35.3	0.0	36.2	0.0427	0.0058	1.0269	0.0000	0.0052	0.0027	16.0
19	1	2	72.	125.	3143.7	6245.4	57.7	45.1	51.3	40.1	0.0327	0.0146	0.5927	0.2657	0.0066	0.0030	16.2
20	1	1	72.	70.	3143.7	6245.4	102.9	36.3	0.0	40.8	0.0443	0.0065	1.0622	0.0000	0.0053	0.0030	16.1
20	1	2	72.	70.	3143.7	6245.4	59.6	46.6	59.9	46.8	0.0338	0.0171	0.6124	0.3102	0.0069	0.0035	16.4

NOTE -- ABOVE VALUES ASSUME VISIBLE TRANSMITTANCE = 1.0 FOR WINDOW GLASS AND SHADING DEVICE.
 ACTUAL TRANSMITTANCES ARE USED IN THE HOURLY CALCULATION.

DAYLIGHTING EXAMPLE FLOOR OF OFFICE BUILDING IN CHICAGO
 30-FT DEEP PERIM OFFS DAYLIT TO 15 FT AUTO SHADE MANAGEMENT FOR SUN CONTROL
 REPORT- LV-L DAYLIGHT FACTOR SUMMARY FOR WESTZONE

Fri Nov 5 21:58:52 1993LDL RUN 1

SPACE--WESTZONE WINDOW--WESTWIND REF PT NO.--1
 AREA(SQFT) 600.0 SC 0.83 GTC 1 VIS-TRANS 0.68 X(FT) 10.0 Y(FT) 10.0 Z(FT) 2.5
 AV REFL 0.46 H(FT) 3.0 W(FT) 20.0 ZONE-FRACTION 0.50
 MAX-GLARE 100.0 AZIM(DEG) 270.0 TILT(DEG) 90.0 LTG-SET-POINT(FC) 50.0
 VW-AZ(DEG) 0.0 DAY-X-DIV 8 DAY-Y-DIV 8 LTG-CTRL-TYPE CONTINUOUS
 X(FT) 0.0 Y(FT) 0.0 Z(FT) 4.0
 WIN-SHADE-TYPE MOVABLE-INTERIOR

SUN	WIN	SUN	SUN	EXT	EXT	DIR	REFL	DIR	REFL	DAY	DAY	WIN	WIN	BACKG	BACKG	GLARE	
POS	DAY	SHD	ALT	ILL	ILL	ILL	ILL	ILL	ILL	ILL	ILL	LUM	LUM	LUM	LUM	INDEX	
NO.	TYP	IND	(DEG)	(FC)	(FC)	(FC)	(FC)	(FC)	(FC)	-SKY	-SUN	-SKY	-SUN	-SKY	-SUN		
1	1	1	10.	290.	1331.8	164.6	186.2	34.8	162.7	14.9	0.1660	1.0791	4.4863	99.0000	0.0121	0.0419	21.9
1	1	2	10.	290.	1331.8	164.6	61.5	48.0	27.3	21.3	0.0822	0.2955	1.4912	5.3599	0.0167	0.0600	15.7
1	2	1	10.	290.	366.9	0.0	7.5	3.2	0.0	0.0	0.0291	0.0000	0.6355	0.0000	0.0041	0.0000	4.9
1	2	2	10.	290.	366.9	0.0	5.1	4.0	0.0	0.0	0.0246	0.0000	0.4461	0.0000	0.0050	0.0000	2.9
2	1	1	10.	235.	1331.8	164.6	154.0	31.4	161.4	12.9	0.1392	1.0592	4.2159	0.0000	0.0109	0.0364	18.0
2	1	2	10.	235.	1331.8	164.6	55.1	43.1	23.7	18.5	0.0737	0.2561	1.3370	4.6464	0.0150	0.0520	15.4
3	1	1	10.	180.	1331.8	164.6	47.5	16.4	0.0	0.5	0.0479	0.0029	1.2688	0.0000	0.0057	0.0013	14.1
3	1	2	10.	180.	1331.8	164.6	27.1	21.1	0.5	0.4	0.0362	0.0050	0.6565	0.0909	0.0074	0.0010	11.6
4	1	1	10.	125.	1331.8	164.6	46.1	13.8	0.0	0.5	0.0449	0.0029	1.1676	0.0000	0.0048	0.0013	13.8
4	1	2	10.	125.	1331.8	164.6	22.3	17.4	0.5	0.4	0.0298	0.0050	0.5402	0.0909	0.0060	0.0010	10.7
5	1	1	10.	70.	1331.8	164.6	47.9	13.9	0.0	0.5	0.0464	0.0029	1.2053	0.0000	0.0048	0.0013	13.9
5	1	2	10.	70.	1331.8	164.6	22.5	17.6	0.5	0.4	0.0301	0.0050	0.5453	0.0909	0.0061	0.0010	10.8
6	1	1	31.	290.	2104.9	2160.2	209.8	45.1	0.0	62.3	0.1211	0.0288	3.0729	0.0000	0.0099	0.0134	18.1
6	1	2	31.	290.	2104.9	2160.2	78.7	61.5	110.5	86.3	0.0666	0.0911	1.2081	1.6530	0.0135	0.0185	17.6
7	1	1	31.	235.	2104.9	2160.2	172.3	41.3	0.0	54.7	0.1015	0.0253	2.7318	0.0000	0.0091	0.0117	17.8
7	1	2	31.	235.	2104.9	2160.2	71.5	55.9	96.3	75.3	0.0605	0.0794	1.0980	1.4408	0.0123	0.0161	17.3
8	1	1	31.	180.	2104.9	2160.2	64.8	23.2	0.0	6.2	0.0418	0.0029	1.0804	0.0000	0.0051	0.0013	15.1
8	1	2	31.	180.	2104.9	2160.2	37.8	29.6	6.1	4.7	0.0320	0.0050	0.5807	0.0909	0.0065	0.0010	13.4
9	1	1	31.	125.	2104.9	2160.2	57.1	18.8	0.0	6.2	0.0360	0.0029	0.9197	0.0000	0.0041	0.0013	14.6
9	1	2	31.	125.	2104.9	2160.2	29.6	23.1	6.1	4.7	0.0250	0.0050	0.4539	0.0909	0.0051	0.0010	12.6
10	1	1	31.	70.	2104.9	2160.2	58.4	18.7	0.0	6.2	0.0366	0.0029	0.9348	0.0000	0.0041	0.0013	14.6
10	1	2	31.	70.	2104.9	2160.2	29.5	23.0	6.1	4.7	0.0249	0.0050	0.4523	0.0909	0.0051	0.0010	12.6
11	1	1	51.	290.	2565.4	4622.3	137.1	40.5	0.0	68.5	0.0692	0.0148	1.6859	0.0000	0.0073	0.0069	16.7
11	1	2	51.	290.	2565.4	4622.3	68.8	53.8	115.8	90.5	0.0478	0.0446	0.8670	0.8094	0.0097	0.0091	17.6
12	1	1	51.	235.	2565.4	4622.3	122.6	37.9	0.0	59.8	0.0626	0.0129	1.5491	0.0000	0.0068	0.0060	16.5
12	1	2	51.	235.	2565.4	4622.3	64.1	50.1	99.5	77.7	0.0445	0.0383	0.8074	0.6955	0.0090	0.0078	17.3
13	1	1	51.	180.	2565.4	4622.3	70.0	25.7	0.0	13.3	0.0373	0.0029	0.9328	0.0000	0.0046	0.0013	15.3
13	1	2	51.	180.	2565.4	4622.3	41.3	32.3	13.0	10.2	0.0287	0.0050	0.5199	0.0909	0.0058	0.0010	14.2
14	1	1	51.	125.	2565.4	4622.3	58.7	21.1	0.0	13.3	0.0311	0.0029	0.7766	0.0000	0.0038	0.0013	14.7
14	1	2	51.	125.	2565.4	4622.3	32.8	25.6	13.0	10.2	0.0228	0.0050	0.4129	0.0909	0.0046	0.0010	13.6
15	1	1	51.	70.	2565.4	4622.3	58.7	20.9	0.0	13.3	0.0310	0.0029	0.7742	0.0000	0.0038	0.0013	14.7
15	1	2	51.	70.	2565.4	4622.3	32.3	25.2	13.0	10.2	0.0224	0.0050	0.4067	0.0909	0.0046	0.0010	13.6
16	1	1	72.	290.	3143.7	6245.4	102.9	36.3	0.0	40.8	0.0443	0.0065	1.0622	0.0000	0.0053	0.0030	16.1
16	1	2	72.	290.	3143.7	6245.4	59.6	46.6	59.9	46.8	0.0338	0.0171	0.6124	0.3102	0.0069	0.0035	16.4
17	1	1	72.	235.	3143.7	6245.4	98.9	35.3	0.0	36.2	0.0427	0.0058	1.0269	0.0000	0.0052	0.0027	16.0
17	1	2	72.	235.	3143.7	6245.4	57.7	45.1	51.3	40.1	0.0327	0.0146	0.5927	0.2657	0.0066	0.0030	16.2
18	1	1	72.	180.	3143.7	6245.4	79.3	29.7	0.0	18.0	0.0347	0.0029	0.8429	0.0000	0.0044	0.0013	15.7
18	1	2	72.	180.	3143.7	6245.4	47.2	36.9	17.6	13.7	0.0267	0.0050	0.4851	0.0909	0.0054	0.0010	14.8
19	1	1	72.	125.	3143.7	6245.4	69.4	26.3	0.0	18.0	0.0304	0.0029	0.7426	0.0000	0.0039	0.0013	15.2
19	1	2	72.	125.	3143.7	6245.4	40.8	31.9	17.6	13.7	0.0231	0.0050	0.4199	0.0909	0.0047	0.0010	14.5
20	1	1	72.	70.	3143.7	6245.4	68.6	25.9	0.0	18.0	0.0300	0.0029	0.7334	0.0000	0.0038	0.0013	15.2
20	1	2	72.	70.	3143.7	6245.4	40.2	31.4	17.6	13.7	0.0228	0.0050	0.4131	0.0909	0.0046	0.0010	14.4

NOTE -- ABOVE VALUES ASSUME VISIBLE TRANSMITTANCE = 1.0 FOR WINDOW GLASS AND SHADING DEVICE.
 ACTUAL TRANSMITTANCES ARE USED IN THE HOURLY CALCULATION.

*** BUILDING ***

FLOOR AREA 36400 SQFT 3382 SQMT
 VOLUME 364000 CUFT 10308 CUMT

TIME	COOLING LOAD				HEATING LOAD	
	JUL 17 5PM				FEB 22 1PM	
DRY-BULB TEMP	90F	32C			31F	-1C
WET-BULB TEMP	71F	22C			29F	-2C
	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	7.739	2.267	0.000	0.000	-15.713	-4.604
ROOF CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
WINDOW GLASS+FRM COND	8.479	2.484	0.000	0.000	-35.593	-10.429
WINDOW GLASS SOLAR	65.900	19.309	0.000	0.000	17.016	4.986
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	0.000	0.000	0.000	0.000	0.000	0.000
OCCUPANTS TO SPACE	83.021	24.325	61.289	17.958	0.365	0.107
LIGHT TO SPACE	133.559	39.133	0.000	0.000	9.628	2.821
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	6.560	1.922	6.118	1.792	-314.172	-92.052
TOTAL	305.258	89.441	67.406	19.750	-338.469	-99.171
TOTAL LOAD	372.664 KBTU/H		109.191 KW		-338.469 KBTU/H -99.171 KW	
TOTAL LOAD / AREA	10.24BTU/H.SQFT		32.289 W /SQMT		9.299BTU/H.SQFT 29.326 W /SQMT	

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *

SPACE NORTHZONE

-----REPORT SCHEDULE HOURS WITH SUN UP-----

MONTH	PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (ALL HOURS)			PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (REPORT SCHEDULE HOURS)			AVERAGE DAYLIGHT ILLUMINANCE (FOOTCANDLES)		PERCENT HOURS DAYLIGHT ILLUMINANCE ABOVE SETPOINT		AVERAGE GLARE INDEX		PERCENT HOURS GLARE TOO HIGH	
	TOTAL ZONE	REF PT 1	REF PT 2	TOTAL ZONE	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2
	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
JAN	10.1	20.2	0.0	13.1	26.1	0.0	19.8	0.0	1.1	0.0	7.2	0.0	0.0	0.0
FEB	16.7	33.4	0.0	21.6	43.1	0.0	28.0	0.0	6.0	0.0	8.8	0.0	0.0	0.0
MAR	25.4	50.7	0.0	32.3	64.7	0.0	45.4	0.0	35.1	0.0	11.1	0.0	0.0	0.0
APR	30.2	60.4	0.0	37.6	75.2	0.0	61.1	0.0	49.3	0.0	12.0	0.0	0.0	0.0
MAY	37.8	75.6	0.0	46.1	92.2	0.0	82.9	0.0	75.3	0.0	13.7	0.0	0.0	0.0
JUN	40.0	80.0	0.0	47.4	94.8	0.0	79.8	0.0	72.6	0.0	13.6	0.0	0.0	0.0
JUL	39.3	78.7	0.0	46.0	92.0	0.0	70.9	0.0	66.7	0.0	12.8	0.0	0.0	0.0
AUG	36.5	73.0	0.0	44.2	88.4	0.0	75.1	0.0	68.1	0.0	13.3	0.0	0.0	0.0
SEP	25.9	51.9	0.0	32.3	64.7	0.0	49.0	0.0	33.7	0.0	11.1	0.0	0.0	0.0
OCT	16.6	33.1	0.0	21.2	42.4	0.0	29.3	0.0	9.3	0.0	8.7	0.0	0.0	0.0
NOV	10.9	21.8	0.0	14.1	28.2	0.0	21.6	0.0	1.9	0.0	7.5	0.0	0.0	0.0
DEC	8.7	17.5	0.0	11.3	22.6	0.0	18.5	0.0	0.7	0.0	6.8	0.0	0.0	0.0
ANNUAL	25.0	50.0	0.0	30.8	61.6	0.0	48.6	0.0	35.2	0.0	10.6	0.0	0.0	0.0

SPACE SOUTHZONE

-----REPORT SCHEDULE HOURS WITH SUN UP-----

MONTH	PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (ALL HOURS)			PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (REPORT SCHEDULE HOURS)			AVERAGE DAYLIGHT ILLUMINANCE (FOOTCANDLES)		PERCENT HOURS DAYLIGHT ILLUMINANCE ABOVE SETPOINT		AVERAGE GLARE INDEX		PERCENT HOURS GLARE TOO HIGH	
	TOTAL ZONE	REF PT 1	REF PT 2	TOTAL ZONE	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2
	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
JAN	15.9	31.7	0.0	20.5	41.1	0.0	33.6	0.0	22.2	0.0	8.6	0.0	0.0	0.0
FEB	21.6	43.1	0.0	27.7	55.4	0.0	40.6	0.0	26.2	0.0	10.3	0.0	0.0	0.0
MAR	24.7	49.4	0.0	31.1	62.2	0.0	48.2	0.0	38.4	0.0	11.5	0.0	0.0	0.0
APR	27.4	54.7	0.0	33.4	66.7	0.0	67.4	0.0	65.2	0.0	12.7	0.0	0.0	0.0
MAY	29.0	58.1	0.0	34.4	68.9	0.0	87.0	0.0	77.8	0.0	13.8	0.0	0.0	0.0
JUN	29.9	59.7	0.0	34.7	69.5	0.0	84.4	0.0	70.0	0.0	13.5	0.0	0.0	0.0
JUL	29.7	59.3	0.0	34.3	68.6	0.0	72.5	0.0	60.2	0.0	12.6	0.0	0.0	0.0
AUG	29.2	58.5	0.0	34.6	69.1	0.0	81.2	0.0	84.2	0.0	13.6	0.0	0.0	0.0
SEP	27.7	55.4	0.0	33.7	67.3	0.0	59.4	0.0	62.2	0.0	12.2	0.0	0.0	0.0
OCT	24.0	48.1	0.0	30.4	60.9	0.0	47.8	0.0	38.7	0.0	11.1	0.0	0.0	0.0
NOV	17.2	34.4	0.0	22.1	44.2	0.0	37.9	0.0	28.9	0.0	9.0	0.0	0.0	0.0
DEC	14.1	28.2	0.0	18.2	36.4	0.0	26.3	0.0	14.0	0.0	7.5	0.0	0.0	0.0
ANNUAL	24.3	48.5	0.0	29.7	59.4	0.0	57.3	0.0	49.1	0.0	11.4	0.0	0.0	0.0

DAYLIGHTING EXAMPLE
 30-FT DEEP PERIM OFFS DAYLIT TO 15 FT
 REPORT- LS-G SPACE DAYLIGHTING SUMMARY

FLOOR OF OFFICE BUILDING IN CHICAGO
 AUTO SHADE MANAGEMENT FOR SUN CONTROL

DOE-2.1E-001 Fri Nov 5 21:58:52 1993LDL RUN 1

WEATHER FILE- TRY CHICAGO

SPACE EASTZONE

-----REPORT SCHEDULE HOURS WITH SUN UP-----

MONTH	PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (ALL HOURS)			PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (REPORT SCHEDULE HOURS)			AVERAGE DAYLIGHT ILLUMINANCE (FOOTCANDLES)		PERCENT HOURS DAYLIGHT ILLUMINANCE ABOVE SETPOINT		AVERAGE GLARE INDEX		PERCENT HOURS GLARE TOO HIGH	
	TOTAL ZONE	REF PT 1	REF PT 2	TOTAL ZONE	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2
JAN	14.8	29.5	0.0	19.1	38.2	0.0	24.9	0.0	7.9	0.0	8.0	0.0	0.0	0.0
FEB	20.2	40.4	0.0	26.0	52.0	0.0	32.8	0.0	11.1	0.0	9.6	0.0	0.0	0.0
MAR	23.9	47.9	0.0	30.1	60.3	0.0	49.2	0.0	39.8	0.0	11.4	0.0	0.0	0.0
APR	26.7	53.4	0.0	32.5	64.9	0.0	65.6	0.0	56.3	0.0	12.4	0.0	0.0	0.0
MAY	29.0	57.9	0.0	34.4	68.7	0.0	84.6	0.0	78.5	0.0	13.9	0.0	0.0	0.0
JUN	29.9	59.7	0.0	34.6	69.2	0.0	83.1	0.0	75.2	0.0	13.6	0.0	0.0	0.0
JUL	29.5	59.0	0.0	34.1	68.2	0.0	74.4	0.0	74.9	0.0	13.0	0.0	0.0	0.0
AUG	28.7	57.5	0.0	34.1	68.2	0.0	79.8	0.0	76.0	0.0	13.5	0.0	0.0	0.0
SEP	26.0	52.1	0.0	31.9	63.7	0.0	59.6	0.0	53.0	0.0	12.0	0.0	0.0	0.0
OCT	21.2	42.3	0.0	26.8	53.5	0.0	38.8	0.0	24.0	0.0	10.0	0.0	0.0	0.0
NOV	16.2	32.4	0.0	20.7	41.3	0.0	28.1	0.0	11.5	0.0	8.4	0.0	0.0	0.0
DEC	13.5	27.0	0.0	17.4	34.7	0.0	22.3	0.0	5.7	0.0	7.4	0.0	0.0	0.0
ANNUAL	23.4	46.7	0.0	28.5	57.1	0.0	53.7	0.0	43.0	0.0	11.1	0.0	0.0	0.0

SPACE WESTZONE

-----REPORT SCHEDULE HOURS WITH SUN UP-----

MONTH	PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (ALL HOURS)			PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHTING (REPORT SCHEDULE HOURS)			AVERAGE DAYLIGHT ILLUMINANCE (FOOTCANDLES)		PERCENT HOURS DAYLIGHT ILLUMINANCE ABOVE SETPOINT		AVERAGE GLARE INDEX		PERCENT HOURS GLARE TOO HIGH	
	TOTAL ZONE	REF PT 1	REF PT 2	TOTAL ZONE	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2	REF PT 1	REF PT 2
JAN	15.0	29.9	0.0	19.4	38.7	0.0	25.5	0.0	6.5	0.0	7.6	0.0	0.0	0.0
FEB	19.5	38.9	0.0	25.0	50.1	0.0	32.5	0.0	12.3	0.0	9.3	0.0	0.0	0.0
MAR	23.9	47.9	0.0	30.2	60.4	0.0	48.9	0.0	35.5	0.0	11.4	0.0	0.0	0.0
APR	26.7	53.4	0.0	32.7	65.4	0.0	66.6	0.0	61.5	0.0	12.5	0.0	0.0	0.0
MAY	28.6	57.3	0.0	33.8	67.6	0.0	81.9	0.0	74.6	0.0	13.6	0.0	0.0	0.0
JUN	30.1	60.1	0.0	34.5	68.9	0.0	79.0	0.0	70.0	0.0	13.4	0.0	0.0	0.0
JUL	29.7	59.4	0.0	34.0	68.0	0.0	69.5	0.0	64.2	0.0	12.8	0.0	0.0	0.0
AUG	28.8	57.6	0.0	33.8	67.6	0.0	77.4	0.0	69.2	0.0	13.3	0.0	0.0	0.0
SEP	25.6	51.3	0.0	31.0	62.0	0.0	57.5	0.0	49.6	0.0	11.8	0.0	0.0	0.0
OCT	20.5	41.1	0.0	26.0	51.9	0.0	36.7	0.0	21.5	0.0	9.7	0.0	0.0	0.0
NOV	15.3	30.6	0.0	19.7	39.4	0.0	26.7	0.0	9.6	0.0	8.0	0.0	0.0	0.0
DEC	13.0	26.1	0.0	16.9	33.7	0.0	23.9	0.0	6.5	0.0	7.1	0.0	0.0	0.0
ANNUAL	23.2	46.3	0.0	28.2	56.3	0.0	52.3	0.0	40.2	0.0	10.9	0.0	0.0	0.0

SPACE NORTHZONE

MONTH	HOUR OF DAY																								ALL HOURS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
JAN	0	0	0	0	0	0	0	1	5	11	17	23	24	19	13	6	1	0	0	0	0	0	0	0	10
FEB	0	0	0	0	0	0	0	4	10	18	28	32	34	32	24	13	5	0	0	0	0	0	0	0	17
MAR	0	0	0	0	0	0	2	11	22	34	39	44	43	42	37	23	10	2	0	0	0	0	0	0	25
APR	0	0	0	0	0	2	10	25	32	39	41	43	45	44	40	34	20	7	0	0	0	0	0	0	30
MAY	0	0	0	0	0	7	25	35	44	47	49	50	50	50	40	28	13	2	0	0	0	0	0	0	38
JUN	0	0	0	0	1	10	29	43	48	49	47	49	49	49	45	36	27	6	0	0	0	0	0	0	40
JUL	0	0	0	0	0	7	34	43	46	47	47	48	48	49	49	39	42	33	7	0	0	0	0	0	39
AUG	0	0	0	0	0	3	19	36	42	45	47	47	48	48	45	41	33	16	2	0	0	0	0	0	37
SEP	0	0	0	0	0	0	8	21	23	32	41	44	40	37	31	24	14	3	0	0	0	0	0	0	26
OCT	0	0	0	0	0	0	2	10	15	25	28	29	28	28	20	10	3	0	0	0	0	0	0	0	17
NOV	0	0	0	0	0	0	0	4	9	15	22	25	23	18	11	4	0	0	0	0	0	0	0	0	11
DEC	0	0	0	0	0	0	0	1	5	10	17	19	23	16	9	3	0	0	0	0	0	0	0	0	9
ANNUAL	0	0	0	0	0	3	15	26	25	31	35	37	39	36	32	24	13	7	1	0	0	0	0	0	25

NOTE- THE ENTRIES IN THIS REPORT ARE NOT SUBJECT TO THE DAYLIGHTING REPORT SCHEDULE

SPACE SOUTHZONE

MONTH	HOUR OF DAY																								ALL HOURS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
JAN	0	0	0	0	0	0	0	1	11	21	28	30	31	28	24	13	1	0	0	0	0	0	0	0	16
FEB	0	0	0	0	0	0	0	8	22	30	33	34	34	33	30	24	10	0	0	0	0	0	0	0	22
MAR	0	0	0	0	0	0	4	19	28	33	34	35	35	34	33	30	19	3	0	0	0	0	0	0	25
APR	0	0	0	0	0	2	17	30	33	34	35	35	35	35	34	33	26	11	0	0	0	0	0	0	27
MAY	0	0	0	0	0	9	26	32	34	35	35	35	35	35	34	29	17	3	0	0	0	0	0	0	29
JUN	0	0	0	0	1	13	26	35	35	34	35	35	35	35	35	34	31	23	8	0	0	0	0	0	30
JUL	0	0	0	0	0	10	28	33	35	34	35	35	35	35	35	34	32	27	9	0	0	0	0	0	30
AUG	0	0	0	0	0	3	23	33	34	35	35	35	35	35	34	32	20	2	0	0	0	0	0	0	29
SEP	0	0	0	0	0	0	16	31	32	35	35	35	35	35	34	32	26	5	0	0	0	0	0	0	28
OCT	0	0	0	0	0	0	5	23	31	33	34	35	35	33	30	25	7	0	0	0	0	0	0	0	24
NOV	0	0	0	0	0	0	0	8	23	28	30	32	31	27	20	10	0	0	0	0	0	0	0	0	17
DEC	0	0	0	0	0	0	0	2	13	21	26	28	28	25	18	6	0	0	0	0	0	0	0	0	14
ANNUAL	0	0	0	0	0	4	16	27	28	31	33	33	34	33	30	26	15	7	2	0	0	0	0	0	24

NOTE- THE ENTRIES IN THIS REPORT ARE NOT
 SUBJECT TO THE DAYLIGHTING REPORT SCHEDULE

DAYLIGHTING EXAMPLE
 30-FT DEEP PERIM OFFS DAYLIT TO 15 FT
 REPORT- LS-H PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHT EASTZONE

FLOOR OF OFFICE BUILDING IN CHICAGO
 AUTO SHADE MANAGEMENT FOR SUN CONTROL

DOE-2.1E-001 Fri Nov 5 21:58:52 1993LDL RUN 1

WEATHER FILE- TRY CHICAGO

SPACE EASTZONE

MONTH	HOUR OF DAY																								ALL HOURS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
JAN	0	0	0	0	0	0	0	2	11	22	27	30	27	25	19	11	1	0	0	0	0	0	0	0	15
FEB	0	0	0	0	0	0	0	6	23	30	33	33	31	31	27	19	8	0	0	0	0	0	0	0	20
MAR	0	0	0	0	0	0	4	19	30	33	33	34	33	32	33	27	15	3	0	0	0	0	0	0	24
APR	0	0	0	0	0	4	19	31	35	35	35	35	35	35	34	30	31	22	10	0	0	0	0	0	27
MAY	0	0	0	0	0	14	27	33	35	35	35	35	35	35	35	32	27	15	3	0	0	0	0	0	29
JUN	0	0	0	0	2	22	31	34	35	35	35	35	35	35	35	33	28	22	9	0	0	0	0	0	30
JUL	0	0	0	0	1	18	30	34	35	35	35	35	35	35	35	28	30	24	9	0	0	0	0	0	29
AUG	0	0	0	0	0	11	25	32	35	35	35	35	35	35	33	32	28	16	2	0	0	0	0	0	29
SEP	0	0	0	0	0	1	21	30	34	35	34	35	33	31	30	25	17	4	0	0	0	0	0	0	26
OCT	0	0	0	0	0	0	8	27	31	34	31	29	27	28	25	16	4	0	0	0	0	0	0	0	21
NOV	0	0	0	0	0	0	0	13	23	28	29	30	28	24	18	8	0	0	0	0	0	0	0	0	16
DEC	0	0	0	0	0	0	0	2	14	21	26	27	27	23	15	6	0	0	0	0	0	0	0	0	13
ANNUAL	0	0	0	0	0	7	18	27	28	32	32	33	32	31	28	22	13	7	2	0	0	0	0	0	23

NOTE- THE ENTRIES IN THIS REPORT ARE NOT
 SUBJECT TO THE DAYLIGHTING REPORT SCHEDULE

DAYLIGHTING EXAMPLE FLOOR OF OFFICE BUILDING IN CHICAGO
 30-FT DEEP PERIM OFFS DAYLIT TO 15 FT AUTO SHADE MANAGEMENT FOR SUN CONTROL
 REPORT- LS-H PERCENT LIGHTING ENERGY REDUCTION BY DAYLIGHT WESTZONE

DOE-2.1E-001 Fri Nov 5 21:58:52 1993LDL RUN 1

WEATHER FILE- TRY CHICAGO

SPACE WESTZONE

MONTH	HOUR OF DAY																								ALL HOURS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
JAN	0	0	0	0	0	0	0	1	9	18	23	28	31	28	24	14	1	0	0	0	0	0	0	0	15
FEB	0	0	0	0	0	0	0	6	16	22	29	30	33	33	30	23	11	0	0	0	0	0	0	0	19
MAR	0	0	0	0	0	0	3	15	26	32	31	33	34	33	33	30	20	4	0	0	0	0	0	0	24
APR	0	0	0	0	0	2	14	25	28	32	33	34	35	35	35	34	27	12	1	0	0	0	0	0	27
MAY	0	0	0	0	0	9	21	29	32	35	35	35	35	35	35	34	29	21	6	0	0	0	0	0	29
JUN	0	0	0	0	1	13	23	32	34	35	35	35	35	35	35	35	32	28	19	0	0	0	0	0	30
JUL	0	0	0	0	0	10	23	30	32	35	35	35	35	35	35	34	33	29	20	0	0	0	0	0	30
AUG	0	0	0	0	0	3	18	29	32	34	35	35	35	35	35	34	31	26	8	0	0	0	0	0	29
SEP	0	0	0	0	0	0	10	21	24	30	33	35	33	35	35	33	27	9	0	0	0	0	0	0	26
OCT	0	0	0	0	0	0	3	14	21	27	26	28	31	34	31	26	8	0	0	0	0	0	0	0	21
NOV	0	0	0	0	0	0	0	6	15	22	27	29	30	27	20	10	1	0	0	0	0	0	0	0	15
DEC	0	0	0	0	0	0	0	1	9	17	23	25	29	24	19	8	0	0	0	0	0	0	0	0	13
ANNUAL	0	0	0	0	0	4	13	22	24	28	30	32	33	32	31	26	16	9	5	0	0	0	0	0	23

NOTE- THE ENTRIES IN THIS REPORT ARE NOT
 SUBJECT TO THE DAYLIGHTING REPORT SCHEDULE

*** BUILDING ***

MONTH	HOUR OF DAY																								ALL HOURS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
JAN	0	0	0	0	0	0	0	0	4	8	11	13	13	12	9	5	1	0	0	0	0	0	0	0	6
FEB	0	0	0	0	0	0	0	3	8	12	14	15	15	15	13	9	4	0	0	0	0	0	0	0	9
MAR	0	0	0	0	0	0	2	7	12	15	16	17	17	16	16	13	7	1	0	0	0	0	0	0	11
APR	0	0	0	0	0	1	7	13	15	16	17	17	17	17	16	15	11	5	0	0	0	0	0	0	13
MAY	0	0	0	0	0	5	12	15	17	18	18	18	18	18	18	16	13	8	2	0	0	0	0	0	14
JUN	0	0	0	0	0	7	13	17	17	18	17	18	18	18	18	17	15	12	5	0	0	0	0	0	15
JUL	0	0	0	0	0	5	13	16	17	17	18	18	18	18	18	15	16	13	5	0	0	0	0	0	15
AUG	0	0	0	0	0	2	10	15	17	17	18	18	18	18	17	16	14	9	2	0	0	0	0	0	14
SEP	0	0	0	0	0	0	6	12	13	15	16	17	16	16	15	13	10	2	0	0	0	0	0	0	12
OCT	0	0	0	0	0	0	2	8	11	14	14	14	14	14	12	9	3	0	0	0	0	0	0	0	9
NOV	0	0	0	0	0	0	0	4	8	11	12	13	13	11	8	4	0	0	0	0	0	0	0	0	7
DEC	0	0	0	0	0	0	0	1	5	8	11	11	12	10	7	3	0	0	0	0	0	0	0	0	6
ANNUAL	0	0	0	0	0	2	7	12	12	14	15	16	16	15	14	11	6	3	1	0	0	0	0	0	11

NOTE- THE ENTRIES IN THIS REPORT ARE NOT SUBJECT TO THE DAYLIGHTING REPORT SCHEDULE

SPACE NORTHZONE

		PERCENT OF HOURS IN ILLUMINANCE RANGE										PERCENT OF HOURS ILLUMINANCE LEVEL EXCEEDED								
		ILLUMINANCE RANGE (FOOTCANDLES)										ILLUMINANCE LEVEL (FOOTCANDLES)								
MONTH	REF PT	0	10	20	30	40	50	60	70	80	ABOVE	0	10	20	30	40	50	60	70	80
JAN	-1-	22	25	32	17	2	1	0	0	0	0	100	78	52	20	3	1	0	0	0
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
FEB	-1-	11	19	29	17	17	3	3	0	0	0	100	89	69	40	23	6	3	0	0
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
MAR	-1-	2	11	18	20	15	13	6	4	11	0	100	98	87	70	50	35	22	15	11
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
APR	-1-	1	3	7	29	11	11	1	3	34	0	100	99	96	89	60	49	38	37	34
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
MAY	-1-	0	1	2	7	14	9	5	5	57	0	100	100	99	97	90	75	67	62	57
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
JUN	-1-	0	0	0	6	21	14	10	0	48	0	100	100	100	100	94	73	58	48	48
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
JUL	-1-	0	3	1	5	25	15	12	5	35	0	100	100	97	97	92	67	51	39	35
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
AUG	-1-	0	1	2	14	15	13	5	3	47	0	100	100	99	97	83	68	55	50	47
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SEP	-1-	2	4	12	37	11	9	3	2	20	0	100	98	94	82	44	34	25	22	20
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
OCT	-1-	11	16	32	16	17	7	2	0	0	0	100	89	73	42	26	9	2	0	0
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NOV	-1-	21	22	33	19	4	1	0	0	0	0	100	79	57	25	6	2	0	0	0
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DEC	-1-	27	25	29	16	3	1	0	0	0	0	100	73	48	19	3	1	0	0	0
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ANNUAL	-1-	8	11	16	17	13	8	4	2	21	0	100	92	81	65	48	35	27	23	21
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

NOTE- THE HOURS CONSIDERED IN THIS REPORT ARE THOSE WITH SUN UP AND DAYLIGHTING REPORT SCHEDULE ON

SPACE SOUTHZONE

		PERCENT OF HOURS IN ILLUMINANCE RANGE										PERCENT OF HOURS ILLUMINANCE LEVEL EXCEEDED								
		ILLUMINANCE RANGE (FOOTCANDLES)										ILLUMINANCE LEVEL (FOOTCANDLES)								
MONTH	REF PT	0	10	20	30	40	50	60	70	80	ABOVE	0	10	20	30	40	50	60	70	80
JAN	-1-	20	15	25	16	3	3	7	3	10	100	80	66	41	25	22	19	13	10	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
FEB	-1-	7	11	16	19	21	6	9	5	6	100	93	83	66	47	26	20	11	6	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
MAR	-1-	0	6	11	26	18	13	9	5	11	100	100	93	82	56	38	25	16	11	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
APR	-1-	0	1	9	12	14	18	12	5	30	100	100	99	91	79	65	47	35	30	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
MAY	-1-	0	1	2	8	12	12	9	4	53	100	100	99	97	90	78	66	57	53	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
JUN	-1-	0	0	0	13	17	11	10	6	43	100	100	100	100	87	70	59	49	43	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
JUL	-1-	0	0	2	11	26	17	10	4	29	100	100	100	97	86	60	43	33	29	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AUG	-1-	0	0	1	7	8	20	17	6	40	100	100	100	99	92	84	64	47	40	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SEP	-1-	0	1	7	13	17	16	20	13	14	100	100	99	92	80	62	46	26	14	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
OCT	-1-	3	7	10	21	20	9	13	9	9	100	97	91	80	59	39	30	18	9	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
NOV	-1-	19	11	21	16	5	4	7	4	14	100	81	70	50	34	29	24	18	14	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DEC	-1-	24	21	24	15	2	4	3	2	5	100	76	56	31	16	14	10	7	5	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ANNUAL	-1-	6	6	11	15	13	11	10	5	22	100	94	88	77	63	49	38	28	22	
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

NOTE- THE HOURS CONSIDERED IN THIS REPORT ARE THOSE WITH SUN UP AND DAYLIGHTING REPORT SCHEDULE ON

SPACE EASTZONE

		PERCENT OF HOURS IN ILLUMINANCE RANGE										PERCENT OF HOURS ILLUMINANCE LEVEL EXCEEDED																
		ILLUMINANCE RANGE (FOOTCANDLES)										ILLUMINANCE LEVEL (FOOTCANDLES)																
MONTH	REF PT	0	--	10	--	20	--	30	--	40	--	50	--	60	--	70	--	80	-ABOVE	0	10	20	30	40	50	60	70	80
JAN	-1-	20		19		29		18		6		4		1		1		2		100	80	60	32	14	8	4	3	2
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
FEB	-1-	8		17		21		21		22		4		5		0		2		100	92	75	54	33	11	7	2	2
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
MAR	-1-	1		10		11		22		16		13		7		5		15		100	99	88	77	56	40	27	20	15
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
APR	-1-	3		1		8		14		18		11		2		9		34		100	97	97	89	74	56	46	43	34
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
MAY	-1-	0		0		3		9		10		10		6		7		55		100	100	100	97	89	78	68	62	55
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
JUN	-1-	0		0		0		10		14		13		7		4		51		100	100	100	99	89	75	62	55	51
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
JUL	-1-	2		0		1		6		16		16		13		8		38		100	98	98	97	91	75	59	46	38
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
AUG	-1-	0		0		3		9		12		13		7		8		48		100	100	100	96	88	76	63	56	48
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
SEP	-1-	1		3		11		18		14		10		6		7		29		100	99	96	85	67	53	43	36	29
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
OCT	-1-	6		13		19		20		18		8		7		3		6		100	94	80	61	42	24	16	9	6
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
NOV	-1-	20		14		28		20		6		3		3		2		3		100	80	66	38	18	11	8	5	3
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
DEC	-1-	26		20		27		19		2		3		0		1		2		100	74	54	27	8	6	3	3	2
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0
ANNUAL	-1-	7		8		13		15		13		9		5		5		24		100	93	85	71	56	43	34	28	24
	-2-	0		0		0		0		0		0		0		0		0		0	0	0	0	0	0	0	0	0

NOTE- THE HOURS CONSIDERED IN THIS REPORT ARE THOSE WITH SUN UP AND DAYLIGHTING REPORT SCHEDULE ON

SPACE WESTZONE

		PERCENT OF HOURS IN ILLUMINANCE RANGE										PERCENT OF HOURS ILLUMINANCE LEVEL EXCEEDED									
		ILLUMINANCE RANGE (FOOTCANDLES)										ILLUMINANCE LEVEL (FOOTCANDLES)									
MONTH	REF PT	0	10	20	30	40	50	60	70	80	ABOVE	0	10	20	30	40	50	60	70	80	
JAN	-1-	21	19	29	18	6	1	1	1	3	100	79	60	30	13	6	5	4	3		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
FEB	-1-	8	15	23	23	19	7	4	0	2	100	92	77	54	31	12	6	2	2		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
MAR	-1-	1	8	15	24	17	11	4	5	16	100	99	91	76	52	35	25	20	16		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
APR	-1-	1	1	9	19	9	19	3	6	34	100	99	99	90	71	61	43	40	34		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
MAY	-1-	1	1	2	11	10	11	4	5	54	100	99	98	96	85	75	63	59	54		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
JUN	-1-	0	0	2	10	18	15	10	1	44	100	100	100	98	88	70	55	45	44		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
JUL	-1-	1	0	2	15	18	17	13	4	31	100	99	99	97	82	64	47	34	31		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
AUG	-1-	0	1	3	17	10	14	4	5	46	100	100	99	96	80	69	55	51	46		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SEP	-1-	1	3	15	21	10	14	5	5	26	100	99	96	81	60	50	35	30	26		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
OCT	-1-	8	11	23	19	17	9	5	3	4	100	92	81	58	38	22	12	7	4		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
NOV	-1-	18	19	27	21	5	4	2	2	1	100	82	63	36	15	10	6	3	1		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
DEC	-1-	24	24	28	15	3	1	1	1	4	100	76	52	25	9	6	6	5	4		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
ANNUAL	-1-	7	9	15	18	12	10	5	3	22	100	93	85	70	52	40	30	25	22		
	-2-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		

NOTE- THE HOURS CONSIDERED IN THIS REPORT ARE THOSE WITH SUN UP AND DAYLIGHTING REPORT SCHEDULE ON

DAYLIGHTING EXAMPLE

30-FT DEEP PERIM OFFS DAYLIT TO 15 FT
REPI = HOURLY-REPORT

FLOOR OF OFFICE BUILDING IN CHICAGO
AUTO SHADE MANAGEMENT FOR SUN CONTROL

DOE-2.1E-001 Fri Nov 5 21:58:52 1993LDL RUN 1

PAGE 1 - 1

MMDH	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL											
	DRY BULB TEMP F	CLOUD AMOUNT	DIR SOL X CLDCOV BTU/HR- SQFT	DIF SOL X CLDCOV BTU/HR- SQFT	GLOBAL SOLAR BTU/HR- SQFT	ATM TURBIDTY	ATM MOISTURE IN	SOLAR ALTITUDE DEGREES	SOLAR AZIMUTH DEGREES	DAYLIGHT CLD FAC	EXT ILL CLR SKY FOOTCAND LES	EXT ILL OVR SKY FOOTCAND LES												
	----	(4)	----	(6)	----	(21)	----	(22)	----	(15)	----	(48)	----	(49)	----	(50)	----	(51)	----	(52)	----	(53)	----	(54)
1 2 1	1.0	4.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 2 2	1.0	2.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 2 3	1.0	2.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 2 4	2.0	0.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 2 5	2.0	7.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 2 6	2.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 2 7	3.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 2 8	4.0	10.0	0.0	1.0	1.0	0.150	0.36	2.8	124.7	0.00	0.0	33.0												
1 2 9	4.0	10.0	0.0	15.1	15.1	0.150	0.36	9.8	133.4	0.00	0.0	485.0												
1 210	5.0	10.0	0.0	31.9	31.9	0.150	0.36	17.1	145.4	0.00	0.0	1030.0												
1 211	6.0	10.0	0.0	44.3	44.3	0.150	0.36	22.3	159.0	0.00	0.0	1426.0												
1 212	8.0	10.0	0.0	50.3	50.3	0.150	0.36	24.9	173.8	0.00	0.0	1622.0												
1 213	9.0	10.0	0.0	49.7	49.7	0.150	0.36	24.6	189.0	0.00	0.0	1602.0												
1 214	11.0	10.0	0.0	42.4	42.4	0.150	0.36	21.5	203.7	0.00	0.0	1366.0												
1 215	12.0	10.0	0.0	29.0	29.0	0.150	0.36	15.9	217.0	0.00	0.0	934.0												
1 216	14.0	10.0	0.0	11.5	11.5	0.150	0.36	8.2	228.8	0.00	0.0	372.0												
1 217	15.0	10.0	0.0	0.3	0.3	0.150	0.36	2.0	236.3	0.00	0.0	11.0												
1 218	15.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 219	17.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 220	17.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 221	18.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 222	17.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 223	17.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
1 224	17.0	10.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
DAILY SUMMARY (JAN 2)																								
MN	1.0	0.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
MX	18.0	10.0	0.0	50.3	50.3	0.150	0.36	24.9	236.3	0.00	0.0	1622.0												
SM	218.0	205.0	0.0	275.6	275.6	1.500	3.60	149.2	1811.1	0.00	0.0	8882.0												
AV	9.1	8.5	0.0	11.5	11.5	0.062	0.15	6.2	75.5	0.00	0.0	370.0												
MONTHLY SUMMARY (JAN)																								
MN	1.0	0.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
MX	18.0	10.0	0.0	50.3	50.3	0.150	0.36	24.9	236.3	0.00	0.0	1622.0												
SM	218.0	205.0	0.0	275.6	275.6	1.500	3.60	149.2	1811.1	0.00	0.0	8882.0												
AV	9.1	8.5	0.0	11.5	11.5	0.062	0.15	6.2	75.5	0.00	0.0	370.0												
YEARLY SUMMARY																								
MN	1.0	0.0	0.0	0.0	0.0	0.000	0.00	0.0	0.0	0.00	0.0	0.0												
MX	18.0	10.0	0.0	50.3	50.3	0.150	0.36	24.9	236.3	0.00	0.0	1622.0												
SM	218.0	205.0	0.0	275.6	275.6	1.500	3.60	149.2	1811.1	0.00	0.0	8882.0												
AV	9.1	8.5	0.0	11.5	11.5	0.062	0.15	6.2	75.5	0.00	0.0	370.0												

MMDDHH	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL
	EXT ILL DIR SOL FOOTCAND LES	MES/PRED SKY ILL	LUM EFF CLR DIR LUMEN / WATT	LUM EFF CLR DIF LUMEN / WATT	LUM EFF CLDY DIF LUMEN / WATT
	----(55)	----(56)	----(57)	----(58)	----(59)
1 2 1	0.	0.00	0.0	0.0	0.0
1 2 2	0.	0.00	0.0	0.0	0.0
1 2 3	0.	0.00	0.0	0.0	0.0
1 2 4	0.	0.00	0.0	0.0	0.0
1 2 5	0.	0.00	0.0	0.0	0.0
1 2 6	0.	0.00	0.0	0.0	0.0
1 2 7	0.	0.00	0.0	0.0	0.0
1 2 8	0.	0.27	18.7	125.4	110.0
1 2 9	0.	1.35	50.5	125.4	110.0
1 210	0.	1.71	69.7	125.4	110.0
1 211	0.	1.86	78.2	125.4	110.0
1 212	0.	1.91	81.3	125.4	110.0
1 213	0.	1.91	81.0	125.4	110.0
1 214	0.	1.85	77.0	125.4	110.0
1 215	0.	1.68	66.9	125.4	110.0
1 216	0.	1.23	44.3	125.4	110.0
1 217	0.	0.12	13.0	125.4	110.0
1 218	0.	0.00	0.0	0.0	0.0
1 219	0.	0.00	0.0	0.0	0.0
1 220	0.	0.00	0.0	0.0	0.0
1 221	0.	0.00	0.0	0.0	0.0
1 222	0.	0.00	0.0	0.0	0.0
1 223	0.	0.00	0.0	0.0	0.0
1 224	0.	0.00	0.0	0.0	0.0
DAILY SUMMARY (JAN 2)					
MN	0.	0.00	0.0	0.0	0.0
MX	0.	1.91	81.3	125.4	110.0
SM	0.	13.87	580.5	1254.0	1100.0
AV	0.	0.58	24.2	52.3	45.8
MONTHLY SUMMARY (JAN)					
MN	0.	0.00	0.0	0.0	0.0
MX	0.	1.91	81.3	125.4	110.0
SM	0.	13.87	580.5	1254.0	1100.0
AV	0.	0.58	24.2	52.3	45.8
YEARLY SUMMARY					
MN	0.	0.00	0.0	0.0	0.0
MX	0.	1.91	81.3	125.4	110.0
SM	0.	13.87	580.5	1254.0	1100.0
AV	0.	0.58	24.2	52.3	45.8

MDDHH	NORTHZON E DAYL ILL REF PT 1 FOOTCAND LES	NORTHZON E BAC LUM REF PT 1 FOOTLAMB ERT	NORTHZON E GLR INDX REF PT 1	NORTHZON E LTPW MUL REF PT 1	NORTHZON E LTPW MUL TOTAL	NORTHZON E SPACE LT ELEC BTU/HR	SOUTHZON E DAYL ILL REF PT 1 FOOTCAND LES	SOUTHZON E BAC LUM REF PT 1 FOOTLAMB ERT	SOUTHZON E GLR INDX REF PT 1	SOUTHZON E LTPW MUL REF PT 1	SOUTHZON E LTPW MUL TOTAL
	----(49)	----(51)	----(53)	----(55)	----(57)	----(45)	----(49)	----(51)	----(53)	----(55)	----(57)
1 2 1	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00	1.00
1 2 2	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00	1.00
1 2 3	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00	1.00
1 2 4	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00	1.00
1 2 5	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00	1.00
1 2 6	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00	1.00
1 2 7	0.0	0.0	0.0	1.00	1.00	409.56	0.0	0.0	0.0	1.00	1.00
1 2 8	0.7	0.1	0.0	0.99	1.00	1224.64	0.7	0.1	0.0	0.99	1.00
1 2 9	9.6	1.3	4.3	0.90	0.95	3899.60	9.6	1.3	4.3	0.83	0.92
1 210	20.3	2.8	8.4	0.79	0.90	3673.46	20.3	2.8	8.4	0.64	0.82
1 211	28.1	3.9	9.9	0.64	0.82	3353.06	28.1	3.9	9.9	0.51	0.75
1 212	32.0	4.4	10.5	0.56	0.78	3194.87	32.0	4.4	10.5	0.44	0.72
1 213	31.6	4.4	10.5	0.57	0.78	2569.30	31.6	4.4	10.5	0.45	0.72
1 214	26.9	3.7	9.7	0.66	0.83	3402.04	26.9	3.7	9.7	0.53	0.76
1 215	18.4	2.5	7.9	0.82	0.91	3718.23	18.4	2.5	7.9	0.68	0.84
1 216	7.3	1.0	2.8	0.93	0.96	3945.26	7.3	1.0	2.8	0.87	0.94
1 217	0.2	0.0	0.0	1.00	1.00	4091.04	0.2	0.0	0.0	1.00	1.00
1 218	0.0	0.0	0.0	1.00	1.00	2047.78	0.0	0.0	0.0	1.00	1.00
1 219	0.0	0.0	0.0	1.00	1.00	1228.67	0.0	0.0	0.0	1.00	1.00
1 220	0.0	0.0	0.0	1.00	1.00	1228.67	0.0	0.0	0.0	1.00	1.00
1 221	0.0	0.0	0.0	1.00	1.00	819.11	0.0	0.0	0.0	1.00	1.00
1 222	0.0	0.0	0.0	1.00	1.00	819.11	0.0	0.0	0.0	1.00	1.00
1 223	0.0	0.0	0.0	1.00	1.00	819.11	0.0	0.0	0.0	1.00	1.00
1 224	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00	1.00
DAILY SUMMARY (JAN 2)											
MN	0.0	0.0	0.0	0.56	0.78	204.78	0.0	0.0	0.0	0.44	0.72
MX	32.0	4.4	10.5	1.00	1.00	4091.04	32.0	4.4	10.5	1.00	1.00
SM	175.2	24.2	64.0	21.86	22.93	41876.95	175.2	24.2	64.0	20.94	22.47
AV	7.3	1.0	2.7	0.91	0.96	1744.87	7.3	1.0	2.7	0.87	0.94
MONTHLY SUMMARY (JAN)											
MN	0.0	0.0	0.0	0.56	0.78	204.78	0.0	0.0	0.0	0.44	0.72
MX	32.0	4.4	10.5	1.00	1.00	4091.04	32.0	4.4	10.5	1.00	1.00
SM	175.2	24.2	64.0	21.86	22.93	41876.95	175.2	24.2	64.0	20.94	22.47
AV	7.3	1.0	2.7	0.91	0.96	1744.87	7.3	1.0	2.7	0.87	0.94
YEARLY SUMMARY											
MN	0.0	0.0	0.0	0.56	0.78	204.78	0.0	0.0	0.0	0.44	0.72
MX	32.0	4.4	10.5	1.00	1.00	4091.04	32.0	4.4	10.5	1.00	1.00
SM	175.2	24.2	64.0	21.86	22.93	41876.95	175.2	24.2	64.0	20.94	22.47
AV	7.3	1.0	2.7	0.91	0.96	1744.87	7.3	1.0	2.7	0.87	0.94

MDDHH	SOUTHZONE E SPACE LT ELEC BTU/HR	EASTZONE DAYL ILL REF PT 1 FOOTCAND LES	EASTZONE BAC LUM REF PT 1 FOOTLAMB ERT	EASTZONE GLR INDX REF PT 1	EASTZONE LTPW MUL REF PT 1	EASTZONE LTPW MUL TOTAL	EASTZONE SPACE LT ELEC BTU/HR	WESTZONE DAYL ILL REF PT 1 FOOTCAND LES	WESTZONE BAC LUM REF PT 1 FOOTLAMB ERT	WESTZONE GLR INDX REF PT 1	WESTZONE LTPW MUL REF PT 1
	---- (45)	---- (49)	---- (51)	---- (53)	---- (55)	---- (57)	---- (45)	---- (49)	---- (51)	---- (53)	---- (55)
1 2 1	204.78	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00
1 2 2	204.78	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00
1 2 3	204.78	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00
1 2 4	204.78	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00
1 2 5	204.78	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00
1 2 6	204.78	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00
1 2 7	409.56	0.0	0.0	0.0	1.00	1.00	409.56	0.0	0.0	0.0	1.00
1 2 8	1224.39	0.7	0.1	0.0	0.99	1.00	1224.39	0.7	0.1	0.0	0.99
1 2 9	3752.62	9.6	1.3	4.3	0.83	0.92	3752.62	9.6	1.3	4.3	0.83
1 210	3367.86	20.3	2.8	8.4	0.64	0.82	3367.86	20.3	2.8	8.4	0.64
1 211	3087.51	28.1	3.9	9.9	0.51	0.75	3087.51	28.1	3.9	9.9	0.51
1 212	2949.09	32.0	4.4	10.5	0.44	0.72	2949.09	32.0	4.4	10.5	0.44
1 213	2371.01	31.6	4.4	10.5	0.45	0.72	2371.01	31.6	4.4	10.5	0.45
1 214	3130.37	26.9	3.7	9.7	0.53	0.76	3130.37	26.9	3.7	9.7	0.53
1 215	3435.23	18.4	2.5	7.9	0.68	0.84	3435.23	18.4	2.5	7.9	0.68
1 216	3832.53	7.3	1.0	2.8	0.87	0.94	3832.53	7.3	1.0	2.8	0.87
1 217	4092.25	0.2	0.0	0.0	1.00	1.00	4092.25	0.2	0.0	0.0	1.00
1 218	2047.78	0.0	0.0	0.0	1.00	1.00	2047.78	0.0	0.0	0.0	1.00
1 219	1228.67	0.0	0.0	0.0	1.00	1.00	1228.67	0.0	0.0	0.0	1.00
1 220	1228.67	0.0	0.0	0.0	1.00	1.00	1228.67	0.0	0.0	0.0	1.00
1 221	819.11	0.0	0.0	0.0	1.00	1.00	819.11	0.0	0.0	0.0	1.00
1 222	819.11	0.0	0.0	0.0	1.00	1.00	819.11	0.0	0.0	0.0	1.00
1 223	819.11	0.0	0.0	0.0	1.00	1.00	819.11	0.0	0.0	0.0	1.00
1 224	204.78	0.0	0.0	0.0	1.00	1.00	204.78	0.0	0.0	0.0	1.00
DAILY SUMMARY (JAN 2)											
MN	204.78	0.0	0.0	0.0	0.44	0.72	204.78	0.0	0.0	0.0	0.44
MX	4092.25	32.0	4.4	10.5	1.00	1.00	4092.25	32.0	4.4	10.5	1.00
SM	40048.32	175.2	24.2	64.0	20.94	22.47	40048.32	175.2	24.2	64.0	20.94
AV	1668.68	7.3	1.0	2.7	0.87	0.94	1668.68	7.3	1.0	2.7	0.87
MONTHLY SUMMARY (JAN)											
MN	204.78	0.0	0.0	0.0	0.44	0.72	204.78	0.0	0.0	0.0	0.44
MX	4092.25	32.0	4.4	10.5	1.00	1.00	4092.25	32.0	4.4	10.5	1.00
SM	40048.32	175.2	24.2	64.0	20.94	22.47	40048.32	175.2	24.2	64.0	20.94
AV	1668.68	7.3	1.0	2.7	0.87	0.94	1668.68	7.3	1.0	2.7	0.87
YEARLY SUMMARY											
MN	204.78	0.0	0.0	0.0	0.44	0.72	204.78	0.0	0.0	0.0	0.44
MX	4092.25	32.0	4.4	10.5	1.00	1.00	4092.25	32.0	4.4	10.5	1.00
SM	40048.32	175.2	24.2	64.0	20.94	22.47	40048.32	175.2	24.2	64.0	20.94
AV	1668.68	7.3	1.0	2.7	0.87	0.94	1668.68	7.3	1.0	2.7	0.87

MMDDHH WESTZONE WESTZONE

	LTPW MUL TOTAL	SPACE LT ELEC BTU/HR
	----(57)	----(45)
1 2 1	1.00	204.78
1 2 2	1.00	204.78
1 2 3	1.00	204.78
1 2 4	1.00	204.78
1 2 5	1.00	204.78
1 2 6	1.00	204.78
1 2 7	1.00	409.56
1 2 8	1.00	1224.39
1 2 9	0.92	3752.62
1 210	0.82	3367.86
1 211	0.75	3087.51
1 212	0.72	2949.09
1 213	0.72	2371.01
1 214	0.76	3130.37
1 215	0.84	3435.23
1 216	0.94	3832.53
1 217	1.00	4092.25
1 218	1.00	2047.78
1 219	1.00	1228.67
1 220	1.00	1228.67
1 221	1.00	819.11
1 222	1.00	819.11
1 223	1.00	819.11
1 224	1.00	204.78

DAILY SUMMARY (JAN 2)

MN	0.72	204.78
MX	1.00	4092.25
SM	22.47	40048.32
AV	0.94	1668.68

MONTHLY SUMMARY (JAN)

MN	0.72	204.78
MX	1.00	4092.25
SM	22.47	40048.32
AV	0.94	1668.68

YEARLY SUMMARY

MN	0.72	204.78
MX	1.00	4092.25
SM	22.47	40048.32
AV	0.94	1668.68

MMDDHH	NORTHWIN D U-VALUE GLAS+FRM BTU/HR-S QFT-F	NORTHWIN D TMN COEF DIRECT	NORTHWIN D TMN COEF DIFFUSE	NORTHWIN D SHADED FRACTION	NORTHWIN D DIRECT SOLAR BTU/HR- SQFT	NORTHWIN D DIFFUSE SOLAR BTU/HR- SQFT	NORTHWIN D SOL GAIN GLAS+FRM BTU/HR	NORTHWIN D CONDUCTN GLAS+FRM BTU/HR	NORTHWIN D SHADING FLAG	NORTHWIN D SHADING COEFF	NORTHWIN D SH COEFF MULT
	---(1)	---(2)	---(4)	---(10)	---(11)	---(12)	---(15)	---(17)	---(23)	---(16)	---(19)
1 2 1	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1696.58	1.	0.830	0.00
1 2 2	0.359	0.000	0.000	0.000	0.0	0.0	0.0	-1726.49	1.	0.830	0.00
1 2 3	0.358	0.000	0.000	0.000	0.0	0.0	0.0	-1723.39	1.	0.830	0.00
1 2 4	0.358	0.000	0.000	0.000	0.0	0.0	0.0	-1714.29	1.	0.830	0.00
1 2 5	0.398	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00
1 2 6	0.355	0.000	0.000	0.000	0.0	0.0	0.0	-1642.58	1.	0.830	0.00
1 2 7	0.399	0.000	0.000	0.000	0.0	0.0	0.0	-1793.45	1.	0.830	0.00
1 2 8	0.355	0.000	0.799	0.000	0.0	0.6	24.0	-1599.51	1.	0.830	1.00
1 2 9	0.361	0.000	0.799	0.000	0.0	7.9	320.5	-1624.74	1.	0.830	1.00
1 210	0.360	0.000	0.799	0.000	0.0	16.1	656.8	-1597.22	1.	0.830	1.00
1 211	0.395	0.000	0.799	0.000	0.0	22.0	893.8	-1704.36	1.	0.830	1.00
1 212	0.357	0.000	0.799	0.000	0.0	24.9	1015.7	-1514.27	1.	0.830	1.00
1 213	0.362	0.000	0.799	0.000	0.0	24.6	1002.6	-1508.89	1.	0.830	1.00
1 214	0.361	0.000	0.799	0.000	0.0	21.1	860.7	-1462.54	1.	0.830	1.00
1 215	0.396	0.000	0.799	0.000	0.0	14.7	595.9	-1561.53	1.	0.830	1.00
1 216	0.407	0.000	0.799	0.000	0.0	6.1	247.3	-1550.29	1.	0.830	1.00
1 217	0.395	0.000	0.799	0.000	0.0	0.2	8.1	-1483.40	1.	0.830	1.00
1 218	0.395	0.000	0.000	0.000	0.0	0.0	0.0	-1485.00	1.	0.830	0.00
1 219	0.408	0.000	0.000	0.000	0.0	0.0	0.0	-1477.76	1.	0.830	0.00
1 220	0.419	0.000	0.000	0.000	0.0	0.0	0.0	-1512.79	1.	0.830	0.00
1 221	0.408	0.000	0.000	0.000	0.0	0.0	0.0	-1450.48	1.	0.830	0.00
1 222	0.419	0.000	0.000	0.000	0.0	0.0	0.0	-1511.53	1.	0.830	0.00
1 223	0.357	0.000	0.000	0.000	0.0	0.0	0.0	-1316.61	1.	0.830	0.00
1 224	0.398	0.000	0.000	0.000	0.0	0.0	0.0	-1444.03	1.	0.830	0.00
DAILY SUMMARY (JAN 2)											
MN	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00
MX	0.419	0.000	0.799	0.000	0.0	24.9	1015.7	-1316.61	1.	0.830	1.00
SM	9.133	0.000	7.990	0.000	0.0	138.1	5625.4	-37940.43	24.	19.920	10.00
AV	0.381	0.000	0.333	0.000	0.0	5.8	234.4	-1580.85	1.	0.830	0.42
MONTHLY SUMMARY (JAN)											
MN	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00
MX	0.419	0.000	0.799	0.000	0.0	24.9	1015.7	-1316.61	1.	0.830	1.00
SM	9.133	0.000	7.990	0.000	0.0	138.1	5625.4	-37940.43	24.	19.920	10.00
AV	0.381	0.000	0.333	0.000	0.0	5.8	234.4	-1580.85	1.	0.830	0.42
YEARLY SUMMARY											
MN	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00
MX	0.419	0.000	0.799	0.000	0.0	24.9	1015.7	-1316.61	1.	0.830	1.00
SM	9.133	0.000	7.990	0.000	0.0	138.1	5625.4	-37940.43	24.	19.920	10.00
AV	0.381	0.000	0.333	0.000	0.0	5.8	234.4	-1580.85	1.	0.830	0.42

MMDDHH	NORTHWIN D GLASS VIS TRAN	NORTHWIN D VIS TRAN MULT	NORTHWIN D MAX SOL GAIN BTU/HR- SQFT	NORTHWIN D SHADING FLAG	NORTHWIN D ILL W/SH REF PT 1 FOOTCAND LES	SOUTHWIN D U-VALUE GLAS+FRM BTU/HR-S QFT-F	SOUTHWIN D TMN COEF DIRECT	SOUTHWIN D TMN COEF DIFFUSE	SOUTHWIN D SHADED FRACTION FRAC.OR MULT.	SOUTHWIN D DIRECT SOLAR BTU/HR- SQFT	SOUTHWIN D DIFFUSE SOLAR BTU/HR- SQFT
	----	----	----	----	----	----	----	----	----	----	----
	(21)	(22)	(20)	(23)	(26)	(1)	(2)	(4)	(10)	(11)	(12)
1 2 1	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
1 2 2	0.00	1.00	0.0	1.	0.0	0.359	0.000	0.000	0.000	0.0	0.0
1 2 3	0.00	1.00	0.0	1.	0.0	0.358	0.000	0.000	0.000	0.0	0.0
1 2 4	0.00	1.00	0.0	1.	0.0	0.358	0.000	0.000	0.000	0.0	0.0
1 2 5	0.00	1.00	0.0	1.	0.0	0.393	0.000	0.000	0.000	0.0	0.0
1 2 6	0.00	1.00	0.0	1.	0.0	0.355	0.000	0.000	0.000	0.0	0.0
1 2 7	0.00	1.00	0.0	1.	0.0	0.394	0.000	0.000	0.000	0.0	0.0
1 2 8	0.00	1.00	20.0	1.	0.2	0.356	0.825	0.799	0.000	0.0	0.3
1 2 9	0.00	1.00	20.0	1.	2.8	0.361	0.850	0.799	0.000	0.0	8.6
1 210	0.00	1.00	20.0	1.	6.0	0.360	0.860	0.799	0.000	0.0	21.1
1 211	0.00	1.00	20.0	1.	8.3	0.400	0.864	0.799	0.000	0.0	30.7
1 212	0.00	1.00	20.0	1.	9.5	0.356	0.867	0.799	0.000	0.0	35.7
1 213	0.00	1.00	20.0	1.	9.3	0.362	0.866	0.799	0.000	0.0	35.1
1 214	0.00	1.00	20.0	1.	8.0	0.362	0.864	0.799	0.000	0.0	29.2
1 215	0.00	1.00	20.0	1.	5.4	0.401	0.859	0.799	0.000	0.0	18.8
1 216	0.00	1.00	20.0	1.	2.2	0.409	0.846	0.799	0.000	0.0	6.2
1 217	0.00	1.00	20.0	1.	0.1	0.400	0.820	0.799	0.000	0.0	0.1
1 218	0.00	1.00	0.0	1.	0.0	0.400	0.000	0.000	0.000	0.0	0.0
1 219	0.00	1.00	0.0	1.	0.0	0.409	0.000	0.000	0.000	0.0	0.0
1 220	0.00	1.00	0.0	1.	0.0	0.417	0.000	0.000	0.000	0.0	0.0
1 221	0.00	1.00	0.0	1.	0.0	0.409	0.000	0.000	0.000	0.0	0.0
1 222	0.00	1.00	0.0	1.	0.0	0.417	0.000	0.000	0.000	0.0	0.0
1 223	0.00	1.00	0.0	1.	0.0	0.357	0.000	0.000	0.000	0.0	0.0
1 224	0.00	1.00	0.0	1.	0.0	0.402	0.000	0.000	0.000	0.0	0.0

DAILY SUMMARY (JAN 2)

MN	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
MX	0.00	1.00	20.0	1.	9.5	0.417	0.867	0.799	0.000	0.0	35.7
SM	0.00	24.00	200.0	24.	51.8	9.152	8.521	7.990	0.000	0.0	186.0
AV	0.00	1.00	8.3	1.	2.2	0.381	0.355	0.333	0.000	0.0	7.7

MONTHLY SUMMARY (JAN)

MN	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
MX	0.00	1.00	20.0	1.	9.5	0.417	0.867	0.799	0.000	0.0	35.7
SM	0.00	24.00	200.0	24.	51.8	9.152	8.521	7.990	0.000	0.0	186.0
AV	0.00	1.00	8.3	1.	2.2	0.381	0.355	0.333	0.000	0.0	7.7

YEARLY SUMMARY

MN	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
MX	0.00	1.00	20.0	1.	9.5	0.417	0.867	0.799	0.000	0.0	35.7
SM	0.00	24.00	200.0	24.	51.8	9.152	8.521	7.990	0.000	0.0	186.0
AV	0.00	1.00	8.3	1.	2.2	0.381	0.355	0.333	0.000	0.0	7.7

MMDDHH	SOUTHWIN D SOL GAIN GLAS+FRM BTU/HR	SOUTHWIN D CONDUCTN GLAS+FRM BTU/HR	SOUTHWIN D SHADING FLAG	SOUTHWIN D SHADING COEFF	SOUTHWIN D SH COEFF MULT	SOUTHWIN D GLASS VIS TRAN	SOUTHWIN D VIS TRAN MULT	SOUTHWIN D MAX SOL GAIN	SOUTHWIN D SHADING FLAG	SOUTHWIN D ILL W/SH REF PT 1 FOOTCAND LES
	---- (15)	---- (17)	---- (23)	---- (16)	---- (19)	---- (21)	---- (22)	---- (20)	---- (23)	---- (26)
1 2 1	0.0	-1698.99	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 2	0.0	-1726.25	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 3	0.0	-1723.41	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 4	0.0	-1714.29	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 5	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 6	0.0	-1645.01	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 7	0.0	-1773.38	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 8	13.9	-1601.95	1.	0.830	1.00	0.64	1.00	20.0	1.	0.2
1 2 9	350.4	-1624.45	1.	0.830	1.00	0.66	1.00	20.0	1.	2.8
1 210	860.1	-1597.34	1.	0.830	1.00	0.67	1.00	20.0	1.	6.0
1 211	1248.6	-1723.60	1.	0.830	1.00	0.67	1.00	20.0	1.	8.3
1 212	1455.5	-1512.94	1.	0.830	1.00	0.67	1.00	20.0	1.	9.5
1 213	1433.0	-1510.33	1.	0.830	1.00	0.67	1.00	20.0	1.	9.3
1 214	1192.9	-1463.66	1.	0.830	1.00	0.67	1.00	20.0	1.	8.0
1 215	764.2	-1579.05	1.	0.830	1.00	0.67	1.00	20.0	1.	5.4
1 216	253.3	-1555.22	1.	0.830	1.00	0.66	1.00	20.0	1.	2.2
1 217	4.1	-1500.24	1.	0.830	1.00	0.63	1.00	20.0	1.	0.1
1 218	0.0	-1501.09	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 219	0.0	-1482.34	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 220	0.0	-1506.99	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 221	0.0	-1455.77	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 222	0.0	-1505.72	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 223	0.0	-1317.27	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 224	0.0	-1459.62	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
DAILY SUMMARY (JAN 2)										
MN	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
MX	1455.5	-1317.27	1.	0.830	1.00	0.67	1.00	20.0	1.	9.5
SM	7576.1	-37997.83	24.	19.920	10.00	6.60	24.00	200.0	24.	51.8
AV	315.7	-1583.24	1.	0.830	0.42	0.27	1.00	8.3	1.	2.2
MONTHLY SUMMARY (JAN)										
MN	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
MX	1455.5	-1317.27	1.	0.830	1.00	0.67	1.00	20.0	1.	9.5
SM	7576.1	-37997.83	24.	19.920	10.00	6.60	24.00	200.0	24.	51.8
AV	315.7	-1583.24	1.	0.830	0.42	0.27	1.00	8.3	1.	2.2
YEARLY SUMMARY										
MN	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
MX	1455.5	-1317.27	1.	0.830	1.00	0.67	1.00	20.0	1.	9.5
SM	7576.1	-37997.83	24.	19.920	10.00	6.60	24.00	200.0	24.	51.8
AV	315.7	-1583.24	1.	0.830	0.42	0.27	1.00	8.3	1.	2.2

DAYLIGHTING EXAMPLE

FLOOR OF OFFICE BUILDING IN CHICAGO
 AUTO SHADE MANAGEMENT FOR SUN CONTROL

DOE-2.1E-001 Fri Nov 5 21:58:52 1993LDL RUN 1

30-FT DEEP PERIM OFFS DAYLIT TO 15 FT
 REPA = HOURLY-REPORT

PAGE 1 - 1

MMDDHH	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND
	U-VALUE GLAS+FRM BTU/HR-S QFT-F	TMN COEF DIRECT	TMN COEF DIFFUSE	SHADED FRACTION FRAC.OR MULT.	DIRECT SOLAR BTU/HR- SQFT	DIFFUSE SOLAR BTU/HR- SQFT	SOL GAIN GLAS+FRM BTU/HR	CONDUCTN GLAS+FRM BTU/HR	SHADING FLAG	SHADING COEFF	SH COEFF MULT	
	----(1)	----(2)	----(4)	----(10)	----(11)	----(12)	----(15)	----(17)	----(23)	----(16)	----(19)	
1 2 1	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1696.58	1.	0.830	0.00	
1 2 2	0.359	0.000	0.000	0.000	0.0	0.0	0.0	-1726.49	1.	0.830	0.00	
1 2 3	0.358	0.000	0.000	0.000	0.0	0.0	0.0	-1723.39	1.	0.830	0.00	
1 2 4	0.358	0.000	0.000	0.000	0.0	0.0	0.0	-1714.29	1.	0.830	0.00	
1 2 5	0.398	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00	
1 2 6	0.355	0.000	0.000	0.000	0.0	0.0	0.0	-1642.58	1.	0.830	0.00	
1 2 7	0.399	0.000	0.000	0.000	0.0	0.0	0.0	-1793.45	1.	0.830	0.00	
1 2 8	0.355	0.862	0.799	0.000	0.0	0.2	9.4	-1599.51	1.	0.830	1.00	
1 2 9	0.361	0.855	0.799	0.000	0.0	8.6	352.1	-1624.69	1.	0.830	1.00	
1 210	0.360	0.815	0.799	0.000	0.0	19.5	796.8	-1597.32	1.	0.830	1.00	
1 211	0.400	0.659	0.799	0.000	0.0	25.4	1030.9	-1723.52	1.	0.830	1.00	
1 212	0.356	0.254	0.799	0.000	0.0	26.8	1094.5	-1512.32	1.	0.830	1.00	
1 213	0.362	0.000	0.799	0.000	0.0	25.2	1026.1	-1509.32	1.	0.830	1.00	
1 214	0.361	0.000	0.799	0.000	0.0	21.1	861.4	-1462.57	1.	0.830	1.00	
1 215	0.396	0.000	0.799	0.000	0.0	14.7	595.9	-1561.53	1.	0.830	1.00	
1 216	0.407	0.000	0.799	0.000	0.0	6.1	247.3	-1550.29	1.	0.830	1.00	
1 217	0.395	0.000	0.799	0.000	0.0	0.2	8.1	-1483.40	1.	0.830	1.00	
1 218	0.395	0.000	0.000	0.000	0.0	0.0	0.0	-1485.00	1.	0.830	0.00	
1 219	0.408	0.000	0.000	0.000	0.0	0.0	0.0	-1477.76	1.	0.830	0.00	
1 220	0.419	0.000	0.000	0.000	0.0	0.0	0.0	-1512.79	1.	0.830	0.00	
1 221	0.409	0.000	0.000	0.000	0.0	0.0	0.0	-1455.57	1.	0.830	0.00	
1 222	0.417	0.000	0.000	0.000	0.0	0.0	0.0	-1505.73	1.	0.830	0.00	
1 223	0.357	0.000	0.000	0.000	0.0	0.0	0.0	-1317.27	1.	0.830	0.00	
1 224	0.402	0.000	0.000	0.000	0.0	0.0	0.0	-1459.62	1.	0.830	0.00	
DAILY SUMMARY (JAN 2)												
MN	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00	
MX	0.419	0.862	0.799	0.000	0.0	26.8	1094.5	-1317.27	1.	0.830	1.00	
SM	9.143	3.446	7.990	0.000	0.0	147.8	6022.6	-37973.70	24.	19.920	10.00	
AV	0.381	0.144	0.333	0.000	0.0	6.2	250.9	-1582.24	1.	0.830	0.42	
MONTHLY SUMMARY (JAN)												
MN	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00	
MX	0.419	0.862	0.799	0.000	0.0	26.8	1094.5	-1317.27	1.	0.830	1.00	
SM	9.143	3.446	7.990	0.000	0.0	147.8	6022.6	-37973.70	24.	19.920	10.00	
AV	0.381	0.144	0.333	0.000	0.0	6.2	250.9	-1582.24	1.	0.830	0.42	
YEARLY SUMMARY												
MN	0.353	0.000	0.000	0.000	0.0	0.0	0.0	-1838.71	1.	0.830	0.00	
MX	0.419	0.862	0.799	0.000	0.0	26.8	1094.5	-1317.27	1.	0.830	1.00	
SM	9.143	3.446	7.990	0.000	0.0	147.8	6022.6	-37973.70	24.	19.920	10.00	
AV	0.381	0.144	0.333	0.000	0.0	6.2	250.9	-1582.24	1.	0.830	0.42	


MDDHH	EASTWIND	EASTWIND	EASTWIND	EASTWIND	EASTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND
	GLASS VIS TRAN	VIS TRAN MULT	MAX SOL GAIN BTU/HR- SQFT	SHADING FLAG	ILL W/SH REF PT 1 FOOTCAND LES	U-VALUE GLAS+FRM BTU/HR-S QFT-F	TMN COEF DIRECT	TMN COEF DIFFUSE	SHADED FRACTION FRAC.OR MULT.	DIRECT SOLAR BTU/HR- SQFT	DIFFUSE SOLAR BTU/HR- SQFT
	----(21)	----(22)	----(20)	----(23)	----(26)	----(1)	----(2)	----(4)	----(10)	----(11)	----(12)
1 2 1	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
1 2 2	0.00	1.00	0.0	1.	0.0	0.359	0.000	0.000	0.000	0.0	0.0
1 2 3	0.00	1.00	0.0	1.	0.0	0.358	0.000	0.000	0.000	0.0	0.0
1 2 4	0.00	1.00	0.0	1.	0.0	0.358	0.000	0.000	0.000	0.0	0.0
1 2 5	0.00	1.00	0.0	1.	0.0	0.393	0.000	0.000	0.000	0.0	0.0
1 2 6	0.00	1.00	0.0	1.	0.0	0.355	0.000	0.000	0.000	0.0	0.0
1 2 7	0.00	1.00	0.0	1.	0.0	0.394	0.000	0.000	0.000	0.0	0.0
1 2 8	0.67	1.00	20.0	1.	0.2	0.356	0.000	0.799	0.000	0.0	0.6
1 2 9	0.66	1.00	20.0	1.	2.8	0.361	0.000	0.799	0.000	0.0	7.9
1 2 10	0.63	1.00	20.0	1.	6.0	0.360	0.000	0.799	0.000	0.0	16.1
1 2 11	0.51	1.00	20.0	1.	8.3	0.395	0.000	0.799	0.000	0.0	22.1
1 2 12	0.20	1.00	20.0	1.	9.5	0.357	0.000	0.799	0.000	0.0	25.7
1 2 13	0.00	1.00	20.0	1.	9.3	0.362	0.357	0.799	0.000	0.0	26.8
1 2 14	0.00	1.00	20.0	1.	8.0	0.361	0.704	0.799	0.000	0.0	24.7
1 2 15	0.00	1.00	20.0	1.	5.4	0.401	0.828	0.799	0.000	0.0	17.8
1 2 16	0.00	1.00	20.0	1.	2.2	0.409	0.858	0.799	0.000	0.0	6.3
1 2 17	0.00	1.00	20.0	1.	0.1	0.400	0.863	0.799	0.000	0.0	0.1
1 2 18	0.00	1.00	0.0	1.	0.0	0.400	0.000	0.000	0.000	0.0	0.0
1 2 19	0.00	1.00	0.0	1.	0.0	0.409	0.000	0.000	0.000	0.0	0.0
1 2 20	0.00	1.00	0.0	1.	0.0	0.417	0.000	0.000	0.000	0.0	0.0
1 2 21	0.00	1.00	0.0	1.	0.0	0.408	0.000	0.000	0.000	0.0	0.0
1 2 22	0.00	1.00	0.0	1.	0.0	0.419	0.000	0.000	0.000	0.0	0.0
1 2 23	0.00	1.00	0.0	1.	0.0	0.357	0.000	0.000	0.000	0.0	0.0
1 2 24	0.00	1.00	0.0	1.	0.0	0.398	0.000	0.000	0.000	0.0	0.0
DAILY SUMMARY (JAN 2)											
MN	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
MX	0.67	1.00	20.0	1.	9.5	0.419	0.863	0.799	0.000	0.0	26.8
SM	2.67	24.00	200.0	24.	51.8	9.141	3.609	7.990	0.000	0.0	147.9
AV	0.11	1.00	8.3	1.	2.2	0.381	0.150	0.333	0.000	0.0	6.2
MONTHLY SUMMARY (JAN)											
MN	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
MX	0.67	1.00	20.0	1.	9.5	0.419	0.863	0.799	0.000	0.0	26.8
SM	2.67	24.00	200.0	24.	51.8	9.141	3.609	7.990	0.000	0.0	147.9
AV	0.11	1.00	8.3	1.	2.2	0.381	0.150	0.333	0.000	0.0	6.2
YEARLY SUMMARY											
MN	0.00	1.00	0.0	1.	0.0	0.354	0.000	0.000	0.000	0.0	0.0
MX	0.67	1.00	20.0	1.	9.5	0.419	0.863	0.799	0.000	0.0	26.8
SM	2.67	24.00	200.0	24.	51.8	9.141	3.609	7.990	0.000	0.0	147.9
AV	0.11	1.00	8.3	1.	2.2	0.381	0.150	0.333	0.000	0.0	6.2

MMDDHH	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND	WESTWIND
	SOL GAIN GLAS+FRM BTU/HR	CONDUCTN GLAS+FRM BTU/HR	SHADING FLAG	SHADING COEFF	SH COEFF MULT	GLASS VIS TRAN	VIS TRAN MULT	MAX SOL GAIN BTU/HR- SQFT	SHADING FLAG	ILL W/SH REF PT 1 FOOTCAND LES
1 2 1	0.0	-1698.99	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 2	0.0	-1726.25	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 3	0.0	-1723.41	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 4	0.0	-1714.29	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 5	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 6	0.0	-1645.01	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 7	0.0	-1773.38	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 2 8	23.9	-1601.95	1.	0.830	1.00	0.00	1.00	20.0	1.	0.2
1 2 9	320.5	-1624.49	1.	0.830	1.00	0.00	1.00	20.0	1.	2.8
1 210	656.8	-1597.24	1.	0.830	1.00	0.00	1.00	20.0	1.	6.0
1 211	896.1	-1704.35	1.	0.830	1.00	0.00	1.00	20.0	1.	8.3
1 212	1047.6	-1514.27	1.	0.830	1.00	0.00	1.00	20.0	1.	9.5
1 213	1093.6	-1508.98	1.	0.830	1.00	0.28	1.00	20.0	1.	9.3
1 214	1006.4	-1462.80	1.	0.830	1.00	0.54	1.00	20.0	1.	8.0
1 215	722.6	-1578.87	1.	0.830	1.00	0.64	1.00	20.0	1.	5.4
1 216	254.2	-1555.19	1.	0.830	1.00	0.66	1.00	20.0	1.	2.2
1 217	2.1	-1500.24	1.	0.830	1.00	0.67	1.00	20.0	1.	0.1
1 218	0.0	-1501.09	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 219	0.0	-1482.34	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 220	0.0	-1506.99	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 221	0.0	-1450.68	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 222	0.0	-1511.52	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 223	0.0	-1316.61	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
1 224	0.0	-1444.03	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
DAILY SUMMARY (JAN 2)										
MN	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
MX	1093.6	-1316.61	1.	0.830	1.00	0.67	1.00	20.0	1.	9.5
SM	6023.9	-37961.89	24.	19.920	10.00	2.79	24.00	200.0	24.	51.8
AV	251.0	-1581.75	1.	0.830	0.42	0.12	1.00	8.3	1.	2.2
MONTHLY SUMMARY (JAN)										
MN	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
MX	1093.6	-1316.61	1.	0.830	1.00	0.67	1.00	20.0	1.	9.5
SM	6023.9	-37961.89	24.	19.920	10.00	2.79	24.00	200.0	24.	51.8
AV	251.0	-1581.75	1.	0.830	0.42	0.12	1.00	8.3	1.	2.2
YEARLY SUMMARY										
MN	0.0	-1818.91	1.	0.830	0.00	0.00	1.00	0.0	1.	0.0
MX	1093.6	-1316.61	1.	0.830	1.00	0.67	1.00	20.0	1.	9.5
SM	6023.9	-37961.89	24.	19.920	10.00	2.79	24.00	200.0	24.	51.8
AV	251.0	-1581.75	1.	0.830	0.42	0.12	1.00	8.3	1.	2.2

SYMBOL	COMPONENT NAME	(NO.)	DESCRIPTION	AXIS	UNIT
1	GLOBAL	(15)	GLOBAL SOLAR	1	BTU/HR- SQFT
2	SOUTHZONE	(49)	DAYL ILLREF PT 1 2		FOOTCANDLES
INTERIOR DAYLITE					
0.00000E+00	0.20000E+02		0.40000E+02	0.60000E+02	0.80000E+02 0.10000E+03
I.....	I.....		I.....	I.....	I.....
EXTERIOR SOLAR					
0.00000E+00	0.10000E+03		0.20000E+03	0.30000E+03	0.40000E+03 0.50000E+03
I.....	I.....		I.....	I.....	I.....
1 2 7 *					.
1 2 8 12					.
1 2 9 . 1 2					.
1 2 10 . 1 2					.
1 2 11 . 1 2					.
1 2 12 . 1 2					.
1 2 13 . 1 2					.
1 2 14 . 1 2					.
1 2 15 . 1 2					.
1 2 16 . 1 2					.
1 2 17 *					.
1 2 18 *					.
1 2 19 *					.
I.....	I.....		I.....	I.....	I.....


Sunspace Example

Single Family Residence. Floor plan and section for ranch house with an attached sunspace.




XBL803-6675A

XBL803-6671A



Sunspace Example

DrawBDL axonometric view of surfaces as input into BDL. In this analysis, the attic is not modeled as a separate zone. Instead, the combination of roof, air-space, and insulated ceiling is treated as two tilted exterior wall sections that are constrained to have a total area equal to the ceiling area (1176 sq.ft.). Because of this area constraint, the roof sections in the drawing do not meet. The triangular gable ends and the section between the top of the sunspace and the main roof have been neglected. The house is modeled as two zones — the main part of the house and the sunspace.



803-6675AAA


LDL PROCESSOR INPUT DATA

Thu Nov 11 10:51:11 1993LDL RUN 1

```

* 2 * TITLE      LINE-1 *SINGLE FAMILY RESIDENCE *
* 3 *           LINE-2 *===WITH ATTACHED SUNSPACE===* ..
* 4 *
* 5 * $ A SUNSPACE HAS BEEN ADDED TO THE SINGLE-FAMILY
* 6 * $ RESIDENCE, RUN 1. THE HOUSE HAS BEEN ROTATED SO THAT THE
* 7 * $ THE BACK OF THE HOUSE, TO WHICH THE SUNSPACE IS ATTACHED,
* 8 * $ FACES SOUTH. THE SUNSPACE IS 21 FEET WIDE AND 8 FEET DEEP.
* 9 * $ ITS FRONT WALL AND SLOPING ROOF ARE DOUBLE GLAZED.
* 10 * $ TO CONTROL SOLAR RADIATION IN THE SUMMER, MOVABLE SHADES ARE
* 11 * $ DEPLOYED FROM MID-MAY TO MID-SEPTEMBER WHEN TRANSMITTED
* 12 * $ DIRECT SOLAR GAIN EXCEEDS 20 BTUH PER SQFT OF GLASS.
* 13 * $ THE INTERIOR WALL SEPARATING THE SUNSPACE FROM THE MAIN HOUSE HAS
* 14 * $ THE SAME CONSTRUCTION AS THE EXTERIOR WALLS OF THE HOUSE.
* 15 * $ THIS INTERIOR WALL HAS A DOUBLE-GLAZED WINDOW AND SLIDING GLASS DOOR.
* 16 * $ AIR IS CIRCULATED BY A FAN FROM SUNSPACE TO HOUSE AT 200 CFM FROM
* 17 * $ MID-SEPTEMBER TO MID-MAY IF THE SUNSPACE AIR TEMPERATURE EXCEEDS THE
* 18 * $ HOUSE AIR TEMPERATURE BY 4F OR MORE. TO CONTROL OVERHEATING, THE
* 19 * $ SUNSPACE IS VENTED WITH OUTSIDE AIR DURING THE DAY AT 20 ACH
* 20 * $ IF THE SUNSPACE TEMPERATURE EXCEEDS 90F DURING THE WINTER
* 21 * $ OR 80F DURING THE SUMMER.
* 22 * $

```



PLAN OF RANCH-STYLE HOUSE WITH ATTACHED SUNSPACE

```

* 43 * $
* 44 * $
* 45 * $
* 46 * $
* 47 * $
* 48 * $ NOTE THAT THE LOADS INPUT RESULTS IN THE CAUTION MESSAGE --
* 49 * $ SUNSPACE INTERIOR WALL SSINTWAL HAS X=0, Y=0 AND THEREFORE MAY NOT
* 50 * $ BE CORRECTLY POSITIONED. THIS MAY CAUSE AN INACCURATE CALCULATION
* 51 * $ OF SOLAR RADIATION ABSORBED BY THE WALL.
* 52 * $ THIS IS SIMPLY A REMINDER THAT THE USER MAY HAVE NEGLECTED TO
* 53 * $ GEOMETRICALLY LOCATE THE INTERIOR WALL OF THE SUNSPACE, IN WHICH
* 54 * $ CASE X AND Y WOULD DEFAULT TO ZERO. SINCE THE WALL IN THIS EXAMPLE
* 55 * $ HAS BEEN INTENTIONALLY LOCATED AT X=0 AND Y=0, THIS MESSAGE CAN BE
* 56 * $ IGNORED. (IN DOE-2.1B AND EARLIER VERSIONS OF THE PROGRAM, THE
* 57 * $ X, Y, Z, AND AZIMUTH KEYWORDS FOR INTERIOR WALLS WERE NOT USED.)
* 58 * $

```

```

* 59 * $ SUNSPACE-RELATED INPUT IS INDICATED BY A DOUBLE DOLLAR SIGN.
* 60 * $
* 61 * $ (TO SIMPLIFY THE INPUT, THE EXTERIOR SURFACES IN THIS EXAMPLE HAVE
* 62 * $ NOT BEEN DIVIDED INTO SEPARATE STUD AND INSULATED PORTIONS AS WAS
* 63 * $ DONE IN SINGLE FAMILY RESIDENCE RUN 1. INSTEAD, THE ENTIRE OPAQUE
* 64 * $ AREA OF THE EXTERIOR WALLS AND ROOFS IS ASSUMED TO BE INSULATED.)
* 65 *
* 66 *
* 67 *
* 68 * $ -----HEADING----- $
* 69 *
* 70 * DIAGNOSTIC CAUTIONS ..
* 71 * ABORT ERRORS ..
* 72 * RUN-PERIOD JAN 1 1974 THRU DEC 31 1974 ..
* 73 * BUILDING-LOCATION LAT=42 LON=88 T-Z=6 ALT=610 AZ=180 ..
* 74 * LOADS-REPORT SUMMARY=(LS-B,LS-D,LS-E)
* 75 * VERIFICATION=(LV-D,LV-F,LV-H,LV-I,LV-J) ..
* 76 *
* 77 * $ -----SCHEDULES----- $
* 78 * SCH-1 =DAY-SCHEDULE (1,5) (.1) (6,9) (.17,.22,.44,.26)
* 79 * (10,11) (.16) (12,14) (.20,.15,.13)
* 80 * (15,16) (.13) (17,19) (.19,.21,.23)
* 81 * (20,24) (.37) ..
* 82 * INT-LDS-1 =SCHEDULE THRU DEC 31 (ALL) SCH-1 ..
* 83 *
* 84 * MAXSOL-1 =SCHEDULE THRU MAY 15 (ALL) (1,24) (1000.) $$
* 85 * THRU SEP 15 (ALL) (1,24) (20.) $$
* 86 * THRU DEC 31 (ALL) (1,24) (1000.) .. $$
* 87 *
* 88 * SOLTRN-1 =SCHEDULE THRU DEC 31 (ALL) (1,24) (0.15) .. $$
* 89 * SHSCH-1 =SCHEDULE THRU DEC 31 (ALL) (1,24) (0.20) .. $$
* 90 *
* 91 * $ -----MATERIALS----- $
* 92 *
* 93 * DRYWALL-1 =MAT TH=.0417 COND=.0925 DENS=50 S-H=.26 $1/2 IN DRYWALLS ..
* 94 * WALL-INS-1 =MAT TH=.2618 COND=.0238 DENS=6 S-H=.2 $R11 INSULATIONS ..
* 95 * SHEATH-1 =MAT TH=.0417 COND=.0342 DENS=22 S-H=.31 $1/2-IN SHEATHINGS ..
* 96 * AL-SIDE-1 =MAT TH=.0104 COND=.0171 DENS=170 S-H=.29 $ALUM SIDINGS ..
* 97 * AS-SHG-1 =MAT TH=.0208 COND=.0473 DENS=70 S-H=.30 $ASPHALT SHINGLES ..
* 98 * PLYW-1 =MAT TH=.0417 COND=.0667 DENS=34 S-H=.29 $1/2-IN PLYWOODS ..
* 99 * CEIL-INS-1 =MAT TH=.4522 COND=.0238 DENS=6 S-H=.2 $R19 INSULATIONS ..
* 100 * AT-AIR-1 =MAT RES=3.1 $ATTIC AIR SPACES ..
* 101 * EXP-POLY-1 =MAT TH=.0833 COND=.0167 DENS=2.2 S-H=.29 $1-IN POLYSTYRENES ..
* 102 * CONCRETE-1 =MAT TH=.3333 COND=.7576 DENS=140 S-H=.2 $4-IN CONCRETES ..
* 103 * CARP/PAD-1 =MAT RES=2.08 $CARPET AND PADS ..
* 104 *
* 105 * $ -----GLAZING----- $
* 106 *
* 107 * GT-WIN-1 =GLASS-TYPE P=2 S-C=.83 ..
* 108 * GTSS-1 =GLASS-TYPE P=2 GLASS-TYPE-CODE=1 .. $$
* 109 *
* 110 * $ -----CONSTRUCTIONS----- $
* 111 *
* 112 * LAY-1 =LAYERS MAT=(AL-SIDE-1,SHEATH-1,WALL-INS-1,DRYWALL-1) ..
* 113 * INS-WL-1 =CONS LAYERS=LAY-1 ..
* 114 * LAY-3 =LAYERS MAT=(AS-SHG-1,PLYW-1,AT-AIR-1,CEIL-INS-1,
* 115 * DRYWALL-1) I-F-R=.61 ..
* 116 * INS-RF-1 =CONS LAYERS=LAY-3 ABS=.86 ..
* 117 * LAY-5 =LAYERS MAT=(EXP-POLY-1,CONCRETE-1,CARP/PAD-1)
* 118 * I-F-R=0.92 ..
* 119 * SLAB-1 =CONS LAYERS=LAY-5 ..
* 120 * LAY-6 =LAYERS MAT=(EXP-POLY-1,CONCRETE-1) $$
* 121 * I-F-R=0.92 .. $$
* 122 * SLAB-SS =CONS LAYERS=LAY-6 .. $$
* 123 * DR-1 =CONS U=.629 ABS=.78 ..

```

```

* 124 *
* 125 *      $ -----WALL PARAMETERS FOR SUNSPACE INTERIOR WALL----- $
* 126 *
* 127 * SSIWPAR  =WALL-PARAMETERS  FOR INTERIOR-WALL          $$
* 128 *          AIR-FLOW-TYPE=FORCED-RECIRC          $$
* 129 *          AIR-FLOW-CTRL-DT=4                  $$
* 130 *          AIR-FLOW-RATE=200                   $$
* 131 *          FAN-KW=0.00005                       $$
* 132 *          ..
* 133 *
* 134 * CONSSIW  =CONS          LAYERS=LAY-1                $$
* 135 *          WALL-PARAMETERS=SSIWPAR ..          $$
* 136 *
* 137 *      $ -----BUILDING SHADE----- $
* 138 *
* 139 * BUILDING-SHADE  X=0 Y=0 Z=8 H=1.5 W=42
* 140 *                AZ=180 TILT=180 ..
* 141 *
* 142 * BUILDING-SHADE  X=0 Y=28 Z=8 H=1.5 W=21
* 143 *                AZ=180 TILT=0 ..
* 144 *
* 145 *      $ -----SPACE DESCRIPTION----- $
* 146 *
* 147 *
* 148 * HOUSE-1  =SPACE          A=1176 V=9408
* 149 *          SOURCE-SCHEDULE=INT-LDS-1
* 150 *          SOURCE-TYPE=ELECTRIC SOURCE-BTU/HR=10252
* 151 *          FLOOR-WEIGHT=0
* 152 *          INF-METHOD=RESIDENTIAL ..
* 153 *
* 154 * FRONT-WL-1=EXTERIOR-WALL  H=8 W=42 AZ=180 CONS=INS-WL-1 ..
* 155 * WIN-1      =WINDOW        H=5.17 W=10.68 G-T=GT-WIN-1 X=7 Y=2 ..
* 156 * DOOR-1    =DOOR          H=6.67 W=3 CONS=DR-1 X=26 ..
* 157 *
* 158 *
* 159 * RIGHT-WL-1=EXTERIOR-WALL  H=8 W=28 AZ=90 X=42 Y=0 CONS=INS-WL-1 ..
* 160 *
* 161 *
* 162 * REAR-WL-1 =EXTERIOR-WALL  LIKE FRONT-WL-1 W=21 X=21 Y=28 AZ=0 ..
* 163 * WIN-3      =WINDOW        H=4 W=5 X=12 Y=2 G-T=GT-WIN-1 ..
* 164 *
* 165 *
* 166 * LEFT-WL-1 =EXTERIOR-WALL  LIKE RIGHT-WL-1 X=0 Y=28 AZ=270 ..
* 167 *
* 168 * FRONT-RF-1=ROOF          H=14 W=42 Z=8 AZ=180 TILT=22.62
* 169 *          CONS=INS-RF-1 ..
* 170 *
* 171 * REAR-RF-1 =ROOF          LIKE FRONT-RF-1 X=42 Y=28 AZ=0 ..
* 172 *
* 173 * UP-1      =UNDERGROUND-FLOOR  CONS=SLAB-1 A=1176
* 174 *          U-EFFECTIVE=.014 $ =(PERIM AREA/TOTAL AREA) X $
* 175 *          $ OVERALL U = (140/1176)X.12 $
* 176 *          ..
* 177 *
* 178 * SUNSP-1  =SPACE          SUNSPACE=YES                $$
* 179 *          AREA=168 VOLUME=1428                $$
* 180 *          X=21 Y=28 AZIMUTH=0                $$
* 181 *          FLOOR-WEIGHT=0                     $$
* 182 *          INF-METHOD=RESIDENTIAL ..         $$
* 183 *
* 184 * SSLEFT   =EXTERIOR-WALL  H=8.5 W=8 X=0 Y=8 AZ=270 Z=-1.5 $$
* 185 *          CONS=INS-WL-1 ..                    $$
* 186 *
* 187 * SSRIGHT  =EXTERIOR-WALL  H=8.5 W=8 X=21 Y=0 AZ=90 Z=-1.5 $$
* 188 *          CONS=INS-WL-1 ..                    $$

```

```

* 189 *
* 190 * SSFRONT  =EXTERIOR-WALL      H=7.5 W=21 X=21 Y=8 AZ=0 Z=-1.5  $$
* 191 *                                     CONS=INS-WL-1 ..                $$
* 192 *
* 193 * SSFRONTWIN =WINDOW          H=6.5 W=20 X=.5 Y=.5              $$
* 194 *                                     GLASS-TYPE=GTSS-1                $$
* 195 *                                     MAX-SOLAR-SCH=MAXSOL-1            $$
* 196 *                                     SHADING-SCHEDULE=SHSCH-1        $$
* 197 *                                     SOL-TRANS-SCH=SOLTRN-1 ..        $$
* 198 *
* 199 * SSROOF    =ROOF              H=6.8 W=21 X=21 Y=8 Z=6           $$
* 200 *                                     AZ=0 TILT=17                      $$
* 201 *                                     CONS=INS-WL-1 ..                $$
* 202 *
* 203 * SSROOFWIN =WINDOW            LIKE SSFRONTWIN H=5.5 ..         $$
* 204 *
* 205 * SSINTWAL  =INTERIOR-WALL     H=8 W=21 X=0 Y=0 AZ=180          $$
* 206 *                                     CONS=CONSSIW NEXT-TO HOUSE-1 ..  $$
* 207 *
* 208 * SSINTWIN-1 =WINDOW           H=6.67 W=6 X=11.5 Y=0           $$
* 209 *                                     GLASS-TYPE=GTSS-1 ..           $$
* 210 *
* 211 * SSINTWIN-2 =WINDOW            LIKE SSINTWIN-1 H=4 W=3 X=2.5 Y=3 $$
* 212 *
* 213 * SSFLOOR   =UNDERGROUND-FLOOR AREA=168 CONS=SLAB-SS                $$
* 214 *                                     U-EFFECTIVE=.055 ..            $$
* 215 *
* 216 *           $ -----HOURLY REPORTS----- $
* 217 *
* 218 * HR-SCH-1  =SCHEDULE           THRU JAN 24 (ALL) (1,24) (0)
* 219 *                                     THRU JAN 25 (ALL) (1,24) (1)
* 220 *                                     THRU JUL  5 (ALL) (1,24) (0)
* 221 *                                     THRU JUL  6 (ALL) (1,24) (1)
* 222 *                                     THRU DEC 31 (ALL) (1,24) (0) ..
* 223 *
* 224 * OUT-1     =REPORT-BLOCK       VARIABLE-TYPE=GLOBAL
* 225 *                                     VARIABLE-LIST=(4,3,2,16,6,21,22,50,51) ..
* 226 * OUT-2     =REPORT-BLOCK       V-T=HOUSE-1
* 227 *                                     V-L=(19,20,18,14,33,22,37,39,41,42) ..
* 228 * OUT-3     =REPORT-BLOCK       LIKE OUT-2 V-T=SUNSP-1 ..
* 229 * OUT-4     =REPORT-BLOCK       V-T=SSFRONTWIN
* 230 *                                     V-L=(1,2,10,11,12,13,14,15,16,17,19,20,23) ..
* 231 * LDS-REP-1 =HOURLY-REPORT     REPORT-SCHEDULE=HR-SCH-1
* 232 *                                     REPORT-BLOCK=(OUT-1,OUT-2,OUT-3,OUT-4) ..
* 233 * END ..

```

```

-----CAUTION-----
ALL DIAGNOSTICS FOR THE WEIGHTING-FACTOR
CALCULATION SECTION ARE GIVEN IN ENGLISH UNITS
* 234 * COMPUTE LOADS ..
* 235 * INPUT SYSTEMS ..

```

SDL PROCESSOR INPUT DATA

Thu Nov 11 10:51:11 1993SDL RUN 1

```

* 236 *
* 237 *      SYSTEMS-REPORT      SUMMARY=(SS-A,SS-B,SS-C,SS-F,SS-H,SS-O)
* 238 *
* 239 *
* 240 *      $ -----SCHEDULES----- $
* 241 *
* 242 * HEAT-1      =SCHEDULE      THRU DEC 31 (ALL)(1,8) (55) (9,22) (70)
* 243 *
* 244 *
* 245 * COOL-1      =SCHEDULE      THRU DEC 31 (ALL)(1,24) (78) ..
* 246 *
* 247 * HOUSEVENT-1=SCHEDULE      THRU DEC 31 (ALL)(1,8) (0) (9,22) (1)
* 248 *
* 249 *
* 250 * HOUSEVTEMP-1=SCHEDULE      THRU DEC 31 (ALL)(1,24) (75) ..
* 251 *
* 252 * SSVENT-1     =SCHEDULE      THRU DEC 31 (ALL)(1,8) (0) (9,22) (1)  $$
* 253 *
* 254 *
* 255 * SSVENTEMP-1=SCHEDULE      THRU MAY 15 (ALL)(1,24) (90)  $$
* 256 *
* 257 *
* 258 *
* 259 * SSFLOWSCH-1=SCHEDULE      THRU MAY 15 (ALL)(1,24) (1)  $$
* 260 *
* 261 *
* 262 *
* 263 *      $ -----ZONE DATA----- $
* 264 *
* 265 * HOUSE-1      =ZONE          DESIGN-HEAT-T=70 DESIGN-COOL-T=78
* 266 *
* 267 *
* 268 *
* 269 *
* 270 *
* 271 *
* 272 * SUNSP-1      =ZONE          DESIGN-HEAT-T=70 DESIGN-COOL-T=78  $$
* 273 *
* 274 *
* 275 *
* 276 *
* 277 *
* 278 *
* 279 *
* 280 *
* 281 *      $ -----AIR CONDITIONER AND GAS FURNACE PARAMETERS----- $
* 282 *
* 283 * SYS-1        =SYSTEM          SYSTEM-TYPE=RESYS
* 284 *
* 285 *
* 286 *
* 287 *
* 288 *
* 289 *
* 290 *
* 291 *
* 292 *

```

```

* 293 *
* 294 * PLANT-1 =PLANT-ASSIGNMENT SYSTEM-NAMES=(SYS-1) ..
* 295 *
* 296 *          $ -----HOURLY REPORTS----- $
* 297 *
* 298 * HR-SCH-1 =SCHEDULE          THRU JAN 24 (ALL) (1,24) (0.)
* 299 *          THRU JAN 25 (ALL) (1,24) (1.)
* 300 *          THRU JUL  5 (ALL) (1,24) (0.)
* 301 *          THRU JUL  6 (ALL) (1,24) (1.)
* 302 *          THRU DEC 31 (ALL) (1,24) (0.) ..
* 303 *
* 304 * OUT-1   =R-B          V-T=GLOBAL V-L=(8) ..
* 305 * OUT-2   =R-B          V-T=HOUSE-1 V-L=(6,21,7,8,61) ..
* 306 * OUT-3   =R-B          V-T=SUNSP-1 V-L=(6,21,8,61,64) ..
* 307 * OUT-4   =R-B          V-T=HOUSE-1 V-L=(1,17,18,62,56,57,58,59,60) ..
* 308 * OUT-5   =R-B          V-T=SUNSP-1 V-L=(1,17,18,62,58,59,60,63) ..
* 309 * OUT-6   =R-B          V-T=SYS-1   V-L=(2,3,5,6,32,33,49,45,47,48,61,
* 310 *          62,63,64,66,67,68,70,71) ..
* 311 * OUT-7   =R-B          V-T=PLANT-1
* 312 *          V-L=(1,2,3) ..
* 313 *
* 314 * SYS-REP-1=H-R          R-SCH=HR-SCH-1 R-B=(OUT-1,OUT-2,OUT-3,OUT-4,OUT-5) ..
* 315 * SYS-REP-2=H-R          R-SCH=HR-SCH-1 R-B=(OUT-6,OUT-7) ..
* 316 *
* 317 * END ..
* 318 * COMPUTE SYSTEMS ..
* 319 * STOP ..

```

NUMBER OF EXTERIOR SURFACES 10 RECTANGULAR 10 OTHER 0
 (U-VALUE INCLUDES OUTSIDE AIR FILM; WINDOW INCLUDES FRAME, IF DEFINED)

SURFACE	SPACE	- - - W I N D O W S - - -		- - - - W A L L - - - -		- W A L L + W I N D O W S -		AZIMUTH
		U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	
FRONT-WL-1	HOUSE-1	0.467	55.22	0.070	280.78	0.135	336.00	NORTH
LEPT-WL-1	HOUSE-1	0.000	0.00	0.070	224.00	0.070	224.00	EAST
SSLEFT	SUNSP-1	0.000	0.00	0.070	68.00	0.070	68.00	EAST
REAR-WL-1	HOUSE-1	0.467	20.00	0.070	148.00	0.117	168.00	SOUTH
SSFRONT	SUNSP-1	0.467	130.00	0.070	27.50	0.397	157.50	SOUTH
SSRIGHT	SUNSP-1	0.000	0.00	0.070	68.00	0.070	68.00	WEST
RIGHT-WL-1	HOUSE-1	0.000	0.00	0.070	224.00	0.070	224.00	WEST
REAR-RF-1	HOUSE-1	0.000	0.00	0.041	588.00	0.041	588.00	ROOF
FRONT-RF-1	HOUSE-1	0.000	0.00	0.041	588.00	0.041	588.00	ROOF
SSROOF	SUNSP-1	0.467	110.00	0.070	32.80	0.376	142.80	ROOF
UF-1	HOUSE-1	0.000	0.00	0.119	1176.00	0.119	1176.00	UNDERGRND
SSFLOOR	SUNSP-1	0.000	0.00	0.158	168.00	0.158	168.00	UNDERGRND

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993LDL RUN 1

REPORT- LV-D DETAILS OF EXTERIOR SURFACES IN THE PROJECT

WEATHER FILE- TRY CHICAGO

----- (CONTINUED) -----

	AVERAGE U-VALUE/WINDOWS (BTU/HR-SQFT-F)	AVERAGE U-VALUE/WALLS (BTU/HR-SQFT-F)	AVERAGE U-VALUE WALLS+WINDOWS (BTU/HR-SQFT-F)	WINDOW AREA (SQFT)	WALL AREA (SQFT)	WINDOW+WALL AREA (SQFT)
NORTH	0.467	0.070	0.135	55.22	280.78	336.00
EAST	0.000	0.070	0.070	0.00	292.00	292.00
SOUTH	0.467	0.070	0.253	150.00	175.50	325.50
WEST	0.000	0.070	0.070	0.00	292.00	292.00
ROOF	0.467	0.041	0.077	110.00	1208.80	1318.80
ALL WALLS	0.467	0.070	0.135	205.22	1040.28	1245.50
WALLS+ROOFS	0.467	0.054	0.105	315.22	2249.08	2564.30
UNDERGRND	0.000	0.124	0.124	0.00	1344.00	1344.00
BUILDING	0.467	0.080	0.111	315.22	3593.08	3908.30

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993LDL RUN 1

REPORT- LV-F DETAILS OF INTERIOR SURFACES IN THE PROJECT

WEATHER FILE- TRY CHICAGO

NUMBER OF INTERIOR SURFACES 1
(U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE NAME	AREA (SQFT)	CONSTRUCTION NAME	SURFACE TYPE	U-VALUE (BTU/HR-SQFT-F)	ADJACENT SPACES	
					SPACE-1	SPACE-2
SSINTWAL	168.00	CONSSIW	DELAYED STANDARD	0.072	SUNSP-1	HOUSE-1

NUMBER OF WINDOWS 6 RECTANGULAR 6 OTHER 0

RECTANGULAR WINDOWS (U-VALUES INCLUDE OUTSIDE AIR FILM)

WINDOW NAME	MULTIPLIER	GLASS AREA (SQFT)	GLASS HEIGHT (FT)	GLASS WIDTH (FT)	LOCATION OF ORIGIN IN SURFACE COORDINATES		FRAME AREA (SQFT)	FRAME U-VALUE (BTU/HR-SQFT-F)
					X (FT)	Y (FT)		
WIN-1	1.0	55.22	5.17	10.68	7.00	2.00	0.00	0.384
WIN-3	1.0	20.00	4.00	5.00	12.00	2.00	0.00	0.384
SSFRONTWIN	1.0	130.00	6.50	20.00	0.50	0.50	0.00	0.384
SSROOFWIN	1.0	110.00	5.50	20.00	0.50	0.50	0.00	0.384
SSINTWIN-1	1.0	40.02	6.67	6.00	11.50	0.00	0.00	0.384
SSINTWIN-2	1.0	12.00	4.00	3.00	2.50	3.00	0.00	0.384

WINDOW NAME	SETBACK (FT)	X-DIVISIONS	GLASS SHADING COEFF	NUMBER OF PANES	GLASS TYPE CODE	INFILTRATION FLOW COEFF	CENTER-OF-GLASS U-VALUE (BTU/HR-SQFT-F)	GLASS
								VISIBLE TRANS
WIN-1	0.00	10	0.83	2	1	0.0	0.490	0.900
WIN-3	0.00	10	0.83	2	1	0.0	0.490	0.900
SSFRONTWIN	0.00	10	1.00	2	1	0.0	0.490	0.900
SSROOFWIN	0.00	10	1.00	2	1	0.0	0.490	0.900
SSINTWIN-1	0.00	10	1.00	2	1	0.0	0.490	0.900
SSINTWIN-2	0.00	10	1.00	2	1	0.0	0.490	0.900

NUMBER OF CONSTRUCTIONS 6 DELAYED 5 QUICK 1

CONSTRUCTION NAME	U-VALUE (BTU/HR-SQFT-F)	SURFACE ABSORPTANCE	SURFACE ROUGHNESS INDEX	SURFACE TYPE	NUMBER OF RESPONSE FACTORS
INS-WL-1	0.072	0.70	3	DELAYED	8
INS-RF-1	0.041	0.86	3	DELAYED	8
SLAB-1	0.119	0.70	3	DELAYED	6
SLAB-SS	0.158	0.70	3	DELAYED	6
DR-1	0.629	0.78	3	QUICK	0
CONSSIW	0.072	0.70	3	DELAYED	8

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993LDL RUN 1

REPORT- LV-J DETAILS OF BUILDING SHADES IN THE PROJECT

WEATHER FILE- TRY CHICAGO

NUMBER OF BUILDING SHADES 2 RECTANGULAR 2 OTHER 0

RECTANGULAR SHADES

SHADE NAME	TRANSMITTANCE	HEIGHT (FT)	WIDTH (FT)	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN BUILDING COORDINATES		
						XB (FT)	YB (FT)	ZB (FT)
	0.00	1.5	42.0	180.	180.	0.0	0.0	8.0
	0.00	1.5	21.0	180.	0.	0.0	28.0	8.0

SPACE HOUSE-1

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0
 FLOOR AREA 1176 SQFT 109 M2
 VOLUME 9408 CUFT 266 M3

TIME	COOLING LOAD		HEATING LOAD	
	JUL 13	6PM	JAN 12	7AM
DRY-BULB TEMP	99F	37C	-6F	-21C
WET-BULB TEMP	77F	25C	-7F	-22C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	2.047	0.600	0.000	0.000	-3.859	-1.131
ROOF CONDUCTION	3.253	0.953	0.000	0.000	-3.129	-0.917
WINDOW GLASS+FRM COND	0.796	0.233	0.000	0.000	-2.205	-0.646
WINDOW GLASS SOLAR	2.027	0.594	0.000	0.000	0.171	0.050
DOOR CONDUCTION	0.321	0.094	0.000	0.000	-0.665	-0.195
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-0.087	-0.026	0.000	0.000	-0.437	-0.128
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	1.796	0.526	0.000	0.000	1.829	0.536
INFILTRATION	3.171	0.929	2.862	0.839	-12.565	-3.682
TOTAL	13.325	3.904	2.862	0.839	-20.860	-6.112
TOTAL LOAD	16.187 KBTU/H	4.743 KW	-20.860 KBTU/H	-6.112 KW		
TOTAL LOAD / AREA	13.76BTU/H.SQFT	43.411 W / M2	17.738BTU/H.SQFT	55.944 W / M2		

```

*****
*
* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR
* ---- LOADS
*
* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION
*
* IN CONSIDERATION
*
*****
    
```

SPACE SUNSP-1

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0
 FLOOR AREA 168 SQFT 16 M2
 VOLUME 1428 CUFT 40 M3

TIME	COOLING LOAD		HEATING LOAD	
	SEP 26	3PM	JAN 12	7AM
DRY-BULB TEMP	81F	27C	-6F	-21C
WET-BULB TEMP	62F	17C	-7F	-22C

	SENSIBLE		LATENT		SENSIBLE	
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)
WALL CONDUCTION	0.153	0.045	0.000	0.000	-0.644	-0.189
ROOF CONDUCTION	0.066	0.019	0.000	0.000	-0.137	-0.040
WINDOW GLASS+FRM COND	1.830	0.536	0.000	0.000	-6.378	-1.869
WINDOW GLASS SOLAR	13.529	3.964	0.000	0.000	0.478	0.140
DOOR CONDUCTION	0.000	0.000	0.000	0.000	0.000	0.000
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000
UNDERGROUND SURF COND	-0.043	-0.013	0.000	0.000	-0.216	-0.063
OCCUPANTS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
LIGHT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
EQUIPMENT TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000
INFILTRATION	0.167	0.049	0.000	0.000	-1.910	-0.560
TOTAL	15.703	4.601	0.000	0.000	-8.806	-2.580
TOTAL LOAD	15.703 KBTU/H	4.601 KW			-8.806 KBTU/H	-2.580 KW
TOTAL LOAD / AREA	93.47BTU/H.SQFT	294.783 W / M2			52.417BTU/H.SQFT	165.315 W / M2

 *
 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * ---- LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *
 *

MONTH	C O O L I N G						H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELECTRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)	
JAN	0.24593	25 14	46.F	41.F	11.013	-9.321	12 7	-6.F	-7.F	-29.666	478.	1.322	
FEB	0.40769	28 14	53.F	42.F	14.304	-7.600	4 6	7.F	6.F	-24.794	431.	1.322	
MAR	0.68412	7 13	52.F	45.F	15.121	-4.963	24 5	9.F	8.F	-24.603	478.	1.322	
APR	2.74543	26 14	76.F	60.F	22.524	-1.951	9 5	26.F	25.F	-13.900	462.	1.322	
MAY	3.03801	1 14	59.F	49.F	17.811	-0.948	7 4	34.F	29.F	-9.866	478.	1.322	
JUN	4.26877	4 14	84.F	67.F	20.190	-0.278	25 4	53.F	47.F	-4.875	462.	1.322	
JUL	6.00847	13 17	99.F	77.F	19.806	-0.032	6 4	60.F	54.F	-2.054	478.	1.322	
AUG	5.28856	20 14	89.F	73.F	21.674	-0.059	5 5	55.F	54.F	-2.691	478.	1.322	
SEP	3.49293	26 14	81.F	62.F	25.791	-0.703	22 5	35.F	31.F	-9.492	462.	1.322	
OCT	2.50061	10 14	66.F	53.F	21.365	-1.683	21 4	31.F	30.F	-12.787	478.	1.322	
NOV	0.85150	2 12	72.F	60.F	21.135	-4.713	15 3	26.F	25.F	-16.566	462.	1.322	
DEC	0.13931	10 14	40.F	35.F	9.873	-7.934	26 5	14.F	14.F	-21.264	478.	1.322	
TOTAL	29.671					-40.184					5625.		
MAX					25.791					-29.666		1.322	

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993LDL RUN 1

REPORT- LS-E SPACE MONTHLY LOAD COMPONENTS IN MBTU FOR

HOUSE-1

WEATHER FILE- TRY CHICAGO

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATING	-1.930	-1.376	0.000	-0.319	-4.072	-0.958	0.702	0.000	0.000	0.000	1.413	-6.541
	SEN CL	-0.017	-0.013	0.000	-0.006	-0.042	-0.012	0.090	0.000	0.000	0.000	0.019	0.020
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATING	-1.615	-1.094	0.000	-0.311	-3.493	-0.843	0.689	0.000	0.000	0.000	1.257	-5.411
	SEN CL	-0.028	-0.018	0.000	-0.012	-0.072	-0.022	0.165	0.000	0.000	0.000	0.037	0.048
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATING	-1.270	-0.776	0.000	-0.308	-2.632	-0.701	0.804	0.000	0.000	0.000	1.320	-3.564
	SEN CL	-0.023	-0.001	0.000	-0.028	-0.078	-0.028	0.191	0.000	0.000	0.000	0.112	0.146
	LAT CL					0.016			0.000		0.000	0.000	0.016
APR	HEATING	-0.568	-0.343	0.000	-0.144	-1.093	-0.317	0.329	0.000	0.000	0.000	0.716	-1.420
	SEN CL	-0.032	0.140	0.000	-0.129	-0.268	-0.108	0.835	0.000	0.000	0.000	0.671	1.110
	LAT CL					0.066			0.000		0.000	0.000	0.066
MAY	HEATING	-0.314	-0.202	0.000	-0.075	-0.517	-0.173	0.160	0.000	0.000	0.000	0.466	-0.655
	SEN CL	0.004	0.258	0.000	-0.131	-0.360	-0.142	0.987	0.000	0.000	0.000	0.966	1.582
	LAT CL					0.180			0.000		0.000	0.000	0.180
JUN	HEATING	-0.088	-0.059	0.000	-0.019	-0.119	-0.049	0.040	0.000	0.000	0.000	0.145	-0.150
	SEN CL	0.254	0.489	0.000	-0.107	-0.035	-0.040	0.997	0.000	0.000	0.000	1.241	2.800
	LAT CL					0.389			0.000		0.000	0.000	0.389
JUL	HEATING	-0.011	-0.008	0.000	-0.002	-0.012	-0.006	0.006	0.000	0.000	0.000	0.025	-0.007
	SEN CL	0.614	0.803	0.000	-0.063	0.367	0.094	0.964	0.000	0.000	0.000	1.407	4.185
	LAT CL					0.805			0.000		0.000	0.000	0.805
AUG	HEATING	-0.021	-0.016	0.000	-0.002	-0.025	-0.012	0.009	0.000	0.000	0.000	0.046	-0.021
	SEN CL	0.423	0.578	0.000	-0.041	0.158	0.027	0.978	0.000	0.000	0.000	1.386	3.509
	LAT CL					0.665			0.000		0.000	0.000	0.665
SEP	HEATING	-0.219	-0.170	0.000	-0.021	-0.371	-0.133	0.100	0.000	0.000	0.000	0.393	-0.440
	SEN CL	0.086	0.237	0.000	-0.042	-0.152	-0.083	0.858	0.000	0.000	0.000	0.993	1.897
	LAT CL					0.182			0.000		0.000	0.000	0.182
OCT	HEATING	-0.529	-0.366	0.000	-0.062	-0.895	-0.284	0.249	0.000	0.000	0.000	0.730	-1.156
	SEN CL	-0.079	0.000	0.000	-0.057	-0.239	-0.107	0.820	0.000	0.000	0.000	0.701	1.040
	LAT CL					0.093			0.000		0.000	0.000	0.093
NOV	HEATING	-1.166	-0.802	0.000	-0.166	-2.163	-0.608	0.473	0.000	0.000	0.000	1.226	-3.206
	SEN CL	-0.028	-0.017	0.000	-0.022	-0.093	-0.037	0.317	0.000	0.000	0.000	0.160	0.279
	LAT CL					0.012			0.000		0.000	0.000	0.012
DEC	HEATING	-1.694	-1.187	0.000	-0.269	-3.271	-0.853	0.498	0.000	0.000	0.000	1.423	-5.351
	SEN CL	-0.008	-0.007	0.000	-0.002	-0.019	-0.006	0.044	0.000	0.000	0.000	0.009	0.010
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATING	-9.444	-6.398	0.000	-1.697	-18.663	-4.939	4.058	0.000	0.000	0.000	9.161	-27.922
	SEN CL	1.167	2.449	0.000	-0.641	-0.832	-0.463	7.245	0.000	0.000	0.000	7.702	16.627
	LAT CL					2.407			0.000		0.000	0.000	2.407

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993LDL RUN 1

REPORT- LS-E SPACE MONTHLY LOAD COMPONENTS IN MBTU FOR

SUNSP-1

WEATHER FILE- TRY CHICAGO

(UNITS=MBTU)		WALLS	ROOFS	INT SUR	UND SUR	INFIL	WIN CON	WIN SOL	OCCUP	LIGHTS	EQUIP	SOURCE	TOTAL
JAN	HEATING	-0.259	-0.055	0.000	-0.145	-0.566	-2.530	0.774	0.000	0.000	0.000	0.000	-2.780
	SEN CL	-0.018	-0.003	0.000	-0.016	-0.060	-0.198	0.520	0.000	0.000	0.000	0.000	0.226
	LAT CL					0.000			0.000		0.000	0.000	0.000
FEB	HEATING	-0.211	-0.045	0.000	-0.137	-0.485	-2.169	0.857	0.000	0.000	0.000	0.000	-2.190
	SEN CL	-0.018	-0.002	0.000	-0.023	-0.057	-0.214	0.673	0.000	0.000	0.000	0.000	0.359
	LAT CL					0.000			0.000		0.000	0.000	0.000
MAR	HEATING	-0.152	-0.031	0.000	-0.124	-0.326	-1.617	0.850	0.000	0.000	0.000	0.000	-1.398
	SEN CL	-0.027	-0.003	0.000	-0.042	-0.087	-0.341	1.039	0.000	0.000	0.000	0.000	0.539
	LAT CL					0.002			0.000		0.000	0.000	0.002
APR	HEATING	-0.067	-0.015	0.000	-0.057	-0.133	-0.737	0.477	0.000	0.000	0.000	0.000	-0.531
	SEN CL	-0.009	0.003	0.000	-0.078	-0.075	-0.311	2.105	0.000	0.000	0.000	0.000	1.635
	LAT CL					0.011			0.000		0.000	0.000	0.011
MAY	HEATING	-0.042	-0.010	0.000	-0.037	-0.073	-0.489	0.357	0.000	0.000	0.000	0.000	-0.293
	SEN CL	0.006	0.007	0.000	-0.065	-0.060	-0.287	1.855	0.000	0.000	0.000	0.000	1.456
	LAT CL					0.028			0.000		0.000	0.000	0.028
JUN	HEATING	-0.015	-0.004	0.000	-0.014	-0.025	-0.220	0.150	0.000	0.000	0.000	0.000	-0.128
	SEN CL	0.049	0.017	0.000	-0.048	0.001	0.003	1.447	0.000	0.000	0.000	0.000	1.469
	LAT CL					0.059			0.000		0.000	0.000	0.059
JUL	HEATING	-0.003	-0.001	0.000	-0.003	-0.004	-0.060	0.046	0.000	0.000	0.000	0.000	-0.025
	SEN CL	0.104	0.029	0.000	-0.029	0.058	0.301	1.360	0.000	0.000	0.000	0.000	1.823
	LAT CL					0.119			0.000		0.000	0.000	0.119
AUG	HEATING	-0.005	-0.002	0.000	-0.002	-0.007	-0.084	0.063	0.000	0.000	0.000	0.000	-0.038
	SEN CL	0.075	0.022	0.000	-0.019	0.028	0.163	1.511	0.000	0.000	0.000	0.000	1.779
	LAT CL					0.099			0.000		0.000	0.000	0.099
SEP	HEATING	-0.031	-0.008	0.000	-0.011	-0.054	-0.406	0.247	0.000	0.000	0.000	0.000	-0.262
	SEN CL	0.024	0.009	0.000	-0.020	-0.025	-0.142	1.751	0.000	0.000	0.000	0.000	1.596
	LAT CL					0.028			0.000		0.000	0.000	0.028
OCT	HEATING	-0.066	-0.015	0.000	-0.027	-0.117	-0.729	0.428	0.000	0.000	0.000	0.000	-0.527
	SEN CL	-0.011	0.000	0.000	-0.031	-0.055	-0.270	1.829	0.000	0.000	0.000	0.000	1.461
	LAT CL					0.012			0.000		0.000	0.000	0.012
NOV	HEATING	-0.153	-0.032	0.000	-0.075	-0.300	-1.592	0.644	0.000	0.000	0.000	0.000	-1.507
	SEN CL	-0.012	-0.002	0.000	-0.018	-0.043	-0.183	0.830	0.000	0.000	0.000	0.000	0.572
	LAT CL					0.001			0.000		0.000	0.000	0.001
DEC	HEATING	-0.231	-0.048	0.000	-0.125	-0.470	-2.316	0.608	0.000	0.000	0.000	0.000	-2.583
	SEN CL	-0.011	-0.002	0.000	-0.009	-0.030	-0.119	0.300	0.000	0.000	0.000	0.000	0.130
	LAT CL					0.000			0.000		0.000	0.000	0.000
TOT	HEATING	-1.234	-0.266	0.000	-0.755	-2.560	-12.949	5.502	0.000	0.000	0.000	0.000	-12.262
	SEN CL	0.152	0.076	0.000	-0.399	-0.406	-1.599	15.220	0.000	0.000	0.000	0.000	13.044
	LAT CL					0.357			0.000		0.000	0.000	0.357

MMDDHH	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	HOUSE-1	HOUSE-1
	DRY BULB TEMP F	WET BULB TEMP F	GROUND ABS TEMP R	CLOUD TYPE	CLOUD AMOUNT	DIR SOL X CLDCOV BTU/HR- SQFT	DIF SOL X CLDCOV BTU/HR- SQFT	SOLAR ALTITUDE DEGREES	SOLAR AZIMUTH DEGREES	DELAY WL LOAD BTU/HR	DELAY RF LOAD BTU/HR
	----(4)	----(3)	----(2)	----(16)	----(6)	----(21)	----(22)	----(50)	----(51)	----(19)	----(20)
125 1	30.0	29.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-2086.59	-1803.34
125 2	31.0	30.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-2143.76	-1885.85
125 3	32.0	31.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-2166.11	-1945.97
125 4	33.0	32.0	500.0	2.	4.0	0.0	0.0	0.0	0.0	-2156.04	-1974.92
125 5	33.0	31.0	500.0	2.	2.0	0.0	0.0	0.0	0.0	-2124.23	-1974.43
125 6	32.0	30.0	500.0	2.	1.0	0.0	0.0	0.0	0.0	-2095.68	-1954.19
125 7	33.0	31.0	500.0	2.	1.0	0.0	0.0	0.0	0.0	-2090.22	-1931.60
125 8	32.0	30.0	500.0	2.	0.0	40.5	2.4	3.5	119.8	-2082.13	-1915.93
125 9	33.0	30.0	500.0	2.	0.0	191.0	11.3	11.4	129.2	-2000.66	-1903.04
12510	36.0	33.0	500.0	2.	0.0	249.5	14.7	19.2	141.4	-1689.28	-1852.19
12511	39.0	35.0	500.0	2.	0.0	274.4	16.2	25.1	155.4	-1300.14	-1680.38
12512	43.0	38.0	500.0	2.	0.0	284.3	16.8	28.3	170.8	-1014.74	-1390.60
12513	45.0	40.0	500.0	0.	1.0	256.4	5.8	28.6	186.9	-842.40	-1030.82
12514	46.0	41.0	500.0	0.	2.0	221.2	17.6	25.7	202.6	-781.68	-680.13
12515	47.0	42.0	500.0	0.	2.0	203.5	15.4	20.2	216.7	-708.67	-435.76
12516	48.0	42.0	500.0	0.	3.0	142.2	15.6	12.6	229.2	-620.48	-308.12
12517	48.0	42.0	500.0	0.	0.0	61.4	3.6	4.2	239.4	-602.95	-300.42
12518	44.0	40.0	500.0	0.	0.0	0.0	0.0	0.0	0.0	-731.30	-398.78
12519	41.0	38.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-990.78	-587.25
12520	38.0	36.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-1261.13	-821.57
12521	37.0	35.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-1480.85	-1046.02
12522	36.0	34.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-1640.26	-1237.35
12523	35.0	33.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-1747.96	-1390.42
12524	35.0	33.0	500.0	2.	0.0	0.0	0.0	0.0	0.0	-1825.53	-1505.65
DAILY SUMMARY (JAN 25)											
MN	30.0	29.0	500.0	0.	0.0	0.0	0.0	0.0	0.0	-2166.11	-1974.92
MX	48.0	42.0	500.0	2.	4.0	284.3	17.6	28.6	239.4	-602.95	-300.42
SM	907.0	836.0	12000.0	36.	16.0	1924.4	119.4	178.9	1791.5	-36183.58	-31954.74
AV	37.8	34.8	500.0	2.	0.7	80.2	5.0	7.5	74.6	-1507.65	-1331.45
MONTHLY SUMMARY (JAN)											
MN	30.0	29.0	500.0	0.	0.0	0.0	0.0	0.0	0.0	-2166.11	-1974.92
MX	48.0	42.0	500.0	2.	4.0	284.3	17.6	28.6	239.4	-602.95	-300.42
SM	907.0	836.0	12000.0	36.	16.0	1924.4	119.4	178.9	1791.5	-36183.58	-31954.74
AV	37.8	34.8	500.0	2.	0.7	80.2	5.0	7.5	74.6	-1507.65	-1331.45

	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	GLOBAL	HOUSE-1	HOUSE-1
	DRY BULB TEMP F	WET BULB TEMP F	GROUND ABS TEMP R	CLOUD TYPE	CLOUD AMOUNT	DIR SOL X CLDCOV BTU/HR- SQFT	DIF SOL X CLDCOV BTU/HR- SQFT	SOLAR ALTITUDE DEGREES	SOLAR AZIMUTH DEGREES	DELAY WL LOAD BTU/HR	DELAY RF LOAD BTU/HR
	----	----	----	----	----	----	----	----	----	----	----
7 6 1	62.0	54.0	524.0	0.	2.0	0.0	0.0	0.0	0.0	-328.91	-88.24
7 6 2	62.0	54.0	524.0	0.	0.0	0.0	0.0	0.0	0.0	-428.26	-278.25
7 6 3	61.0	54.0	524.0	0.	0.0	0.0	0.0	0.0	0.0	-508.39	-445.38
7 6 4	60.0	54.0	524.0	2.	0.0	0.0	0.0	0.0	0.0	-573.74	-596.92
7 6 5	61.0	55.0	524.0	2.	0.0	6.0	0.9	2.7	61.2	-612.44	-714.97
7 6 6	61.0	55.0	524.0	2.	0.0	111.2	15.9	10.5	68.6	-592.03	-785.45
7 6 7	64.0	58.0	524.0	0.	0.0	189.6	27.2	21.1	77.7	-249.61	-794.49
7 6 8	69.0	61.0	524.0	0.	0.0	228.2	32.7	32.2	87.0	331.98	-611.76
7 6 9	73.0	62.0	524.0	0.	0.0	249.0	35.7	43.3	97.4	779.31	-159.97
7 6 10	76.0	64.0	524.0	0.	0.0	260.8	37.4	54.1	110.6	1007.47	437.24
7 6 11	78.0	64.0	524.0	0.	1.0	240.6	62.5	63.7	130.0	1167.23	1072.09
7 6 12	79.0	65.0	524.0	0.	1.0	243.2	64.4	70.1	162.0	1294.76	1725.84
7 6 13	80.0	66.0	524.0	0.	0.0	270.1	38.7	69.6	202.8	1337.28	2335.61
7 6 14	80.0	65.0	524.0	0.	2.0	213.4	85.3	62.7	232.9	1295.69	2799.47
7 6 15	81.0	66.0	524.0	0.	3.0	181.8	99.2	52.8	251.3	1336.90	3054.30
7 6 16	81.0	66.0	524.0	0.	3.0	172.9	50.3	41.9	263.9	1446.97	3162.21
7 6 17	81.0	67.0	524.0	0.	2.0	179.8	30.6	30.8	274.2	1487.89	3099.70
7 6 18	81.0	66.0	524.0	0.	3.0	127.8	29.5	19.8	283.4	1474.81	2864.57
7 6 19	78.0	64.0	524.0	0.	3.0	67.5	13.4	9.2	292.6	1423.57	2524.41
7 6 20	75.0	63.0	524.0	0.	1.0	2.4	0.3	2.0	299.4	1236.35	2107.30
7 6 21	72.0	61.0	524.0	0.	1.0	0.0	0.0	0.0	0.0	888.69	1630.23
7 6 22	71.0	61.0	524.0	0.	1.0	0.0	0.0	0.0	0.0	534.58	1153.92
7 6 23	71.0	61.0	524.0	0.	0.0	0.0	0.0	0.0	0.0	282.71	744.13
7 6 24	69.0	61.0	524.0	0.	0.0	0.0	0.0	0.0	0.0	134.95	432.61
DAILY SUMMARY (JUL 6)											
MN	60.0	54.0	524.0	0.	0.0	0.0	0.0	0.0	0.0	-612.44	-794.49
MX	81.0	67.0	524.0	2.	3.0	270.1	99.2	70.1	299.4	1487.89	3162.21
SM	1726.0	1467.0	12576.0	6.	23.0	2744.3	623.8	586.5	2895.1	14167.76	24668.21
AV	71.9	61.1	524.0	0.	1.0	114.3	26.0	24.4	120.6	590.32	1027.84
MONTHLY SUMMARY (JUL)											
MN	60.0	54.0	524.0	0.	0.0	0.0	0.0	0.0	0.0	-612.44	-794.49
MX	81.0	67.0	524.0	2.	3.0	270.1	99.2	70.1	299.4	1487.89	3162.21
SM	1726.0	1467.0	12576.0	6.	23.0	2744.3	623.8	586.5	2895.1	14167.76	24668.21
AV	71.9	61.1	524.0	0.	1.0	114.3	26.0	24.4	120.6	590.32	1027.84
YEARLY SUMMARY											
MN	30.0	29.0	500.0	0.	0.0	0.0	0.0	0.0	0.0	-2166.11	-1974.92
MX	81.0	67.0	524.0	2.	4.0	284.3	99.2	70.1	299.4	1487.89	3162.21
SM	2633.0	2303.0	24576.0	42.	39.0	4668.7	743.3	765.3	4686.6	-22015.82	-7286.53
AV	54.9	48.0	512.0	1.	0.8	97.3	15.5	15.9	97.6	-458.66	-151.80

MMDDHH	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1
	GLS COND LOAD BTU/HR	GLS SOL GAIN BTU/HR	GLS SOL LOAD BTU/HR	UG FLOOR LOAD BTU/HR	INFILTRN SENS GN BTU/HR	INFILTRN FLOWRT CFM	SPACE CONDUCT BTU/HR-F	SPACE SENS LD BTU/HR
	----(18)	----(14)	----(33)	----(22)	----(37)	----(39)	----(41)	----(42)
125 1	-1177.53	0.00	421.94	-436.97	-4257.98	102.28	144.05	-8169.36
125 2	-1175.04	0.00	400.84	-436.97	-4200.38	103.48	145.07	-8548.12
125 3	-1167.06	0.00	381.23	-436.97	-4140.27	104.69	145.95	-8700.28
125 4	-1123.94	0.00	362.77	-436.97	-3883.53	100.85	145.09	-8481.25
125 5	-1133.00	0.00	345.28	-436.97	-3980.59	103.37	146.01	-8604.19
125 6	-1164.94	0.00	328.67	-436.97	-4239.95	107.21	146.74	-8454.43
125 7	-1149.79	0.00	312.88	-436.97	-4077.65	105.89	146.71	-7886.12
125 8	-1139.75	857.85	647.83	-436.97	-3940.90	99.65	144.10	-5924.48
125 9	-1119.10	5537.00	2653.02	-436.97	-3980.59	103.37	146.00	-4672.45
12510	-1068.45	9614.49	4956.71	-436.97	-3785.59	106.98	147.97	-2430.35
12511	-997.98	12779.73	7063.50	-436.97	-3405.40	105.55	148.52	582.06
12512	-892.80	14105.46	8394.13	-436.97	-2747.12	97.76	148.09	3480.49
12513	-842.48	12070.73	8118.02	-436.97	-2606.25	100.17	149.07	3633.32
12514	-799.76	10566.80	7528.45	-436.97	-2406.14	96.33	148.66	3547.65
12515	-778.22	7562.24	6157.56	-436.97	-2395.03	100.05	149.50	2482.97
12516	-752.71	3626.65	4132.90	-436.97	-2203.03	96.22	149.12	871.82
12517	-767.48	973.80	2380.11	-436.97	-2203.03	96.22	149.13	-529.82
12518	-832.14	0.00	1352.32	-436.97	-2336.92	86.36	145.50	-1829.18
12519	-910.54	0.00	943.74	-436.97	-2877.97	95.35	146.95	-3161.59
12520	-989.95	0.00	751.76	-436.97	-3391.23	101.83	147.51	-3562.91
12521	-1013.69	0.00	653.06	-436.97	-3369.31	98.10	146.11	-3946.19
12522	-1054.66	0.00	594.99	-436.97	-3696.40	104.46	147.46	-4658.31
12523	-1077.43	0.00	555.01	-436.97	-3761.28	103.26	146.80	-5014.68
12524	-1076.90	0.00	523.49	-436.97	-3669.47	100.74	146.03	-5123.64
DAILY SUMMARY (JAN 25)								
MN	-1177.53	0.00	312.88	-436.97	-4257.98	86.36	144.05	-8700.28
MX	-752.71	14105.46	8394.13	-436.97	-2203.03	107.21	149.50	3633.32
SM	-24205.36	77694.75	59960.18	-10487.38	-81556.02	2420.15	3526.14	-85099.05
AV	-1008.56	3237.28	2498.34	-436.97	-3398.17	100.84	146.92	-3545.79
MONTHLY SUMMARY (JAN)								
MN	-1177.53	0.00	312.88	-436.97	-4257.98	86.36	144.05	-8700.28
MX	-752.71	14105.46	8394.13	-436.97	-2203.03	107.21	149.50	3633.32
SM	-24205.36	77694.75	59960.18	-10487.38	-81556.02	2420.15	3526.14	-85099.05
AV	-1008.56	3237.28	2498.34	-436.97	-3398.17	100.84	146.92	-3545.79

	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1
	GLS COND LOAD BTU/HR	GLS SOL GAIN BTU/HR	GLS SOL LOAD BTU/HR	UG FLOOR LOAD BTU/HR	INFILTRN SENS GN BTU/HR	INFILTRN FLOWRT CFM	SPACE CONDUCT BTU/HR-F	SPACE SENS LD BTU/HR
	----(18)	----(14)	----(33)	----(22)	----(37)	----(39)	----(41)	----(42)
7 6 1	-296.65	0.00	277.80	-87.40	-415.31	50.05	136.98	223.71
7 6 2	-317.21	0.00	260.72	-87.40	-415.31	50.05	136.88	-230.79
7 6 3	-338.33	0.00	246.61	-87.40	-479.52	51.37	136.27	-640.12
7 6 4	-357.30	0.00	234.09	-87.39	-624.89	60.25	143.63	-1068.70
7 6 5	-344.18	176.39	294.52	-87.39	-479.52	51.37	137.19	-569.89
7 6 6	-306.81	2338.42	1188.48	-87.39	-479.52	51.37	136.86	893.16
7 6 7	-253.59	2205.47	1413.05	-87.39	-295.09	47.42	138.58	3154.63
7 6 8	-152.35	2216.48	1524.26	-87.39	-52.99	50.91	145.27	3460.64
7 6 9	-43.71	2642.69	1749.15	-87.39	190.80	61.11	147.71	4257.12
7 610	34.47	2965.82	1961.55	-87.39	374.79	60.02	146.46	5452.06
7 611	107.42	3282.11	2172.18	-87.39	521.66	62.65	146.55	6903.53
7 612	148.28	3510.32	2347.57	-87.39	599.20	63.97	146.60	7698.59
7 613	192.09	3151.82	2273.62	-87.39	784.41	75.37	149.46	8316.25
7 614	207.52	3489.50	2404.45	-87.39	731.95	70.33	148.23	8814.86
7 615	243.35	4022.71	2668.97	-87.39	874.96	76.69	148.94	9550.63
7 616	247.24	2595.67	2183.12	-87.39	874.96	76.69	149.47	9615.20
7 617	241.61	1942.38	1783.42	-87.39	846.20	74.17	148.88	9325.43
7 618	250.87	2216.03	1756.92	-87.39	846.20	74.17	148.88	9264.43
7 619	190.03	1723.65	1532.21	-87.39	603.55	72.74	149.37	9222.33
7 620	89.03	68.60	784.45	-87.39	330.58	63.74	148.04	7569.98
7 621	-0.24	0.00	511.13	-87.39	113.58	54.75	146.28	6201.83
7 622	-37.94	0.00	389.27	-87.39	55.42	53.43	146.25	5175.88
7 623	-43.95	0.00	329.04	-87.39	63.27	60.99	148.61	4475.32
7 624	-98.86	0.00	295.51	-87.39	-55.42	53.43	146.19	2124.57
DAILY SUMMARY (JUL 6)								
MN	-357.30	0.00	234.09	-87.40	-624.89	47.42	136.27	-1068.70
MX	250.87	4022.71	2668.97	-87.39	874.96	76.69	149.47	9615.20
SM	-639.20	38548.06	30582.09	-2097.48	4513.93	1467.02	3477.60	119190.63
AV	-26.63	1606.17	1274.25	-87.39	188.08	61.13	144.90	4966.28
MONTHLY SUMMARY (JUL)								
MN	-357.30	0.00	234.09	-87.40	-624.89	47.42	136.27	-1068.70
MX	250.87	4022.71	2668.97	-87.39	874.96	76.69	149.47	9615.20
SM	-639.20	38548.06	30582.09	-2097.48	4513.93	1467.02	3477.60	119190.63
AV	-26.63	1606.17	1274.25	-87.39	188.08	61.13	144.90	4966.28
YEARLY SUMMARY								
MN	-1177.53	0.00	234.09	-436.97	-4257.98	47.42	136.27	-8700.28
MX	250.87	14105.46	8394.13	-87.39	874.96	107.21	149.50	9615.20
SM	-24844.56	116242.81	90542.28	-12584.86	-77042.09	3887.18	7003.74	34091.58
AV	-517.60	2421.73	1886.30	-262.18	-1605.04	80.98	145.91	710.24

LDS-REP-1 = HOURLY-REPORT

PAGE 1 - 3

MDDHH	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1
	DELAY WL LOAD BTU/HR	DELAY RF LOAD BTU/HR	GLS COND LOAD BTU/HR	GLS SOL GAIN BTU/HR	GLS SOL LOAD BTU/HR	UG FLOOR LOAD BTU/HR	INFILTRN SENS GN BTU/HR	INFILTRN FLOWRT CFM
	----(19)	----(20)	----(18)	----(14)	----(33)	----(22)	----(37)	----(39)
125 1	-346.32	-80.59	-3542.85	0.00	1625.51	-215.74	-647.08	15.54
125 2	-356.06	-82.90	-3535.46	0.00	1478.88	-215.74	-638.50	15.73
125 3	-359.78	-83.38	-3515.17	0.00	1345.73	-215.74	-629.54	15.92
125 4	-358.17	-82.43	-3361.21	0.00	1224.65	-215.74	-590.36	15.33
125 5	-353.17	-80.72	-3409.55	0.00	1114.51	-215.74	-605.28	15.72
125 6	-349.03	-79.32	-3514.61	0.00	1014.29	-215.74	-644.86	16.31
125 7	-348.88	-78.89	-3471.15	0.00	923.08	-215.74	-620.19	16.11
125 8	-347.62	-78.63	-3360.15	1798.81	1163.35	-215.74	-598.91	15.14
125 9	-328.44	-77.35	-2708.00	12078.91	3081.14	-215.74	-605.28	15.72
12510	-257.90	-66.01	-2135.17	20613.19	5463.30	-215.74	-576.08	16.28
12511	-177.89	-45.73	-1650.25	25821.93	7563.28	-215.74	-518.40	16.07
12512	-129.45	-24.06	-1175.46	28003.69	9085.81	-215.74	-418.15	14.88
12513	-110.34	-4.36	-1213.21	23970.37	9286.38	-215.74	-396.93	15.26
12514	-111.20	5.04	-1178.77	22306.23	9332.75	-215.74	-366.38	14.67
12515	-100.32	6.37	-1311.10	18411.48	8855.83	-215.74	-364.87	15.24
12516	-80.25	1.72	-1573.73	11201.63	7509.87	-215.74	-335.56	14.66
12517	-74.91	-8.03	-2056.74	2960.48	5529.49	-215.74	-335.56	14.66
12518	-101.39	-21.89	-2489.34	0.00	4123.26	-215.74	-355.34	13.13
12519	-153.88	-36.93	-2730.93	0.00	3410.47	-215.74	-437.82	14.51
12520	-205.29	-48.60	-2960.44	0.00	2969.47	-215.74	-515.98	15.49
12521	-244.15	-56.47	-3039.22	0.00	2649.71	-215.74	-512.38	14.92
12522	-270.98	-62.05	-3150.93	0.00	2390.74	-215.74	-562.38	15.89
12523	-288.60	-65.64	-3223.78	0.00	2167.64	-215.74	-572.10	15.71
12524	-301.36	-68.25	-3233.57	0.00	1969.54	-215.74	-557.99	15.32
DAILY SUMMARY (JAN 25)								
MN	-359.78	-83.38	-3542.85	0.00	923.08	-215.74	-647.08	13.13
MX	-74.91	6.37	-1175.46	28003.69	9332.75	-215.74	-335.56	16.31
SM	-5755.40	-1219.09	-63540.79	167166.73	95278.68	-5177.77	-12405.93	368.18
AV	-239.81	-50.80	-2647.53	6965.28	3969.95	-215.74	-516.91	15.34
MONTHLY SUMMARY (JAN)								
MN	-359.78	-83.38	-3542.85	0.00	923.08	-215.74	-647.08	13.13
MX	-74.91	6.37	-1175.46	28003.69	9332.75	-215.74	-335.56	16.31
SM	-5755.40	-1219.09	-63540.79	167166.73	95278.68	-5177.77	-12405.93	368.18
AV	-239.81	-50.80	-2647.53	6965.28	3969.95	-215.74	-516.91	15.34

	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1
	DELAY WL LOAD BTU/HR	DELAY RF LOAD BTU/HR	GLS COND LOAD BTU/HR	GLS SOL GAIN BTU/HR	GLS SOL LOAD BTU/HR	UG FLOOR LOAD BTU/HR	INFILTRN SENS GN BTU/HR	INFILTRN FLOWRT CFM
	----(19)	----(20)	----(18)	----(14)	----(33)	----(22)	----(37)	----(39)
7 6 1	-46.13	-18.23	-1166.30	0.00	807.63	-43.15	-63.04	7.60
7 6 2	-63.31	-23.60	-1282.69	0.00	733.86	-43.15	-63.04	7.60
7 6 3	-77.54	-29.45	-1348.35	0.00	667.42	-43.15	-72.78	7.80
7 6 4	-89.33	-34.27	-1330.68	0.00	607.23	-43.15	-95.00	9.16
7 6 5	-96.34	-35.73	-1363.51	90.00	568.73	-43.15	-72.78	7.80
7 6 6	-93.07	-36.69	-1259.33	1614.13	800.23	-43.15	-72.78	7.80
7 6 7	-30.74	-33.05	-1062.61	2304.96	1006.92	-43.15	-44.79	7.20
7 6 8	74.88	-13.99	-584.50	3864.34	1375.69	-43.15	-8.06	7.75
7 6 9	157.51	15.27	-127.58	5701.72	1877.29	-43.15	29.06	9.31
7 610	203.16	43.53	232.31	8547.09	2637.00	-43.15	57.03	9.13
7 611	238.78	72.34	209.92	5258.86	2430.38	-43.15	79.37	9.53
7 612	262.89	99.11	315.83	5651.51	2477.84	-43.15	91.17	9.73
7 613	263.97	118.32	450.40	5550.35	2518.62	-43.15	119.50	11.48
7 614	250.56	122.41	486.38	5193.72	2508.17	-43.15	111.44	10.71
7 615	260.14	121.11	873.07	9044.29	3226.04	-43.15	133.29	11.68
7 616	284.62	114.65	713.63	5000.54	2847.21	-43.15	133.29	11.68
7 617	295.45	99.67	596.60	3226.13	2416.53	-43.15	128.87	11.29
7 618	295.84	82.11	679.52	4282.20	2431.75	-43.15	128.87	11.29
7 619	282.83	64.04	356.86	1273.43	1894.20	-43.15	91.96	11.08
7 620	238.53	44.73	5.44	32.77	1431.28	-43.15	50.35	9.71
7 621	167.01	27.13	-263.94	0.00	1189.09	-43.15	17.29	8.33
7 622	100.68	13.74	-359.27	0.00	1037.77	-43.15	8.44	8.13
7 623	56.64	4.96	-358.10	0.00	927.02	-43.15	9.64	9.30
7 624	31.83	0.21	-543.84	0.00	836.81	-43.15	-8.44	8.13
DAILY SUMMARY (JUL 6)								
MN	-96.34	-36.69	-1363.51	0.00	568.73	-43.15	-95.00	7.20
MX	295.84	122.41	873.07	9044.29	3226.04	-43.15	133.29	11.68
SM	2968.85	818.33	-6130.70	66636.04	39254.71	-1035.55	688.84	223.22
AV	123.70	34.10	-255.45	2776.50	1635.61	-43.15	28.70	9.30
MONTHLY SUMMARY (JUL)								
MN	-96.34	-36.69	-1363.51	0.00	568.73	-43.15	-95.00	7.20
MX	295.84	122.41	873.07	9044.29	3226.04	-43.15	133.29	11.68
SM	2968.85	818.33	-6130.70	66636.04	39254.71	-1035.55	688.84	223.22
AV	123.70	34.10	-255.45	2776.50	1635.61	-43.15	28.70	9.30
YEARLY SUMMARY								
MN	-359.78	-83.38	-3542.85	0.00	568.73	-215.74	-647.08	7.20
MX	295.84	122.41	873.07	28003.69	9332.75	-43.15	133.29	16.31
SM	-2786.54	-400.76	-69671.49	233802.78	134533.39	-6213.32	-11717.09	591.41
AV	-58.05	-8.35	-1451.49	4870.89	2802.78	-129.44	-244.11	12.32

LDS-REP-1 = HOURLY-REPORT

PAGE 1 - 4

MMDDHH	SUNSP-1 SPACE CONDUCT BTU/HR-F	SUNSP-1 SPACE SENS LD BTU/HR	SSFRONTW IN U-VALUE GLAS+FRM BTU/HR-S QFT-F	SSFRONTW IN TMN COEF DIRECT	SSFRONTW IN SHADED FRACTION FRAC.OR MULT.	SSFRONTW IN DIRECT SOLAR BTU/HR- SQFT	SSFRONTW IN DIFFUSE SOLAR BTU/HR- SQFT	SSFRONTW IN SOL TRAN THRU GLS BTU/HR- SQFT	SSFRONTW IN SOL ABS BY GLS BTU/HR- SQFT	SSFRONTW IN SOL GAIN GLAS+FRM BTU/HR	SSFRONTW IN SHADING COEFF
	----(41)	----(42)	----(1)	----(2)	----(10)	----(11)	----(12)	----(13)	----(14)	----(15)	----(16)
125 1	93.83	-3207.07	0.408	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
125 2	95.87	-3349.78	0.419	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
125 3	97.72	-3457.89	0.429	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
125 4	95.86	-3383.26	0.419	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
125 5	97.90	-3549.96	0.429	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
125 6	99.46	-3789.27	0.437	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
125 7	99.36	-3811.76	0.437	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
125 8	93.88	-3437.70	0.408	0.652	0.000	20.1	5.1	16.6	1.3	2326.5	1.000
125 9	97.81	-853.67	0.429	0.722	0.000	118.3	23.6	101.5	6.9	14082.8	1.000
12510	102.19	2212.39	0.452	0.759	0.000	184.2	34.0	162.9	9.5	22422.7	1.000
12511	103.39	4955.27	0.458	0.769	0.000	225.9	39.6	200.6	11.1	27522.8	1.000
12512	102.37	7122.94	0.453	0.769	0.000	247.0	41.3	218.1	12.0	29909.1	1.000
12513	104.59	7345.81	0.464	0.769	0.000	223.5	22.8	187.4	9.9	25647.5	1.000
12514	103.63	7465.70	0.459	0.770	0.000	184.0	39.3	168.3	9.3	23084.5	1.000
12515	105.51	6870.17	0.469	0.762	0.000	153.1	33.8	139.6	7.7	19150.5	1.000
12516	104.63	5306.31	0.465	0.730	0.000	90.7	28.7	85.7	5.1	11812.0	1.000
12517	104.62	2838.51	0.465	0.659	0.000	31.2	7.5	25.6	1.7	3551.5	1.000
12518	96.64	939.56	0.423	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
12519	99.77	-164.83	0.439	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
12520	101.06	-976.59	0.446	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
12521	97.96	-1418.24	0.430	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
12522	100.94	-1871.34	0.445	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
12523	99.49	-2198.22	0.438	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
12524	97.83	-2407.38	0.429	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
DAILY SUMMARY (JAN 25)											
MN	93.83	-3811.76	0.408	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
MX	105.51	7465.70	0.469	0.770	0.000	247.0	41.3	218.1	12.0	29909.1	1.000
SM	2396.29	7179.70	10.553	7.361	0.000	1477.8	275.8	1306.4	74.4	179509.9	24.000
AV	99.85	299.15	0.440	0.307	0.000	61.6	11.5	54.4	3.1	7479.6	1.000
MONTHLY SUMMARY (JAN)											
MN	93.83	-3811.76	0.408	0.000	0.000	0.0	0.0	0.0	0.0	0.0	1.000
MX	105.51	7465.70	0.469	0.770	0.000	247.0	41.3	218.1	12.0	29909.1	1.000
SM	2396.29	7179.70	10.553	7.361	0.000	1477.8	275.8	1306.4	74.4	179509.9	24.000
AV	99.85	299.15	0.440	0.307	0.000	61.6	11.5	54.4	3.1	7479.6	1.000

	SUNSP-1	SUNSP-1	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN	SSFRONTW IN
	SPACE CONDUCT BTU/HR-F	SPACE SENS LD BTU/HR	U-VALUE GLAS+FRM BTU/HR-S QFT-F	TMN COEF DIRECT	SHADED FRACTION FRAC.OR MULT.	DIRECT SOLAR BTU/HR- SQFT	DIFFUSE SOLAR BTU/HR- SQFT	SOL TRAN THRU GLS BTU/HR- SQFT	SOL ABS BY GLS BTU/HR- SQFT	SOL GAIN GLAS+FRM BTU/HR	SHADING COEFF	
	----	----	----	----	----	----	----	----	----	----	----	----
	(41)	(42)	(1)	(2)	(10)	(11)	(12)	(13)	(14)	(15)	(16)	
7 6 1	83.65	-529.22	0.357	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
7 6 2	83.59	-741.93	0.356	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
7 6 3	83.27	-903.86	0.353	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
7 6 4	92.59	-985.19	0.402	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
7 6 5	83.74	-1042.78	0.358	0.000	0.000	0.0	0.8	0.6	0.0	0.0	77.5	1.000
7 6 6	83.54	-704.79	0.356	0.000	0.000	0.0	12.9	8.8	0.7	1233.2	1.000	1.000
7 6 7	84.78	-207.41	0.365	0.000	0.000	0.0	25.4	17.2	1.4	2421.1	1.000	1.000
7 6 8	95.92	800.88	0.421	0.000	0.000	0.0	35.1	23.9	1.7	3319.5	1.000	1.000
7 6 9	100.95	1908.41	0.445	0.144	0.000	23.5	42.4	32.2	2.6	4529.5	1.000	1.000
7 6 10	98.09	3129.89	0.431	0.332	0.000	53.8	47.6	50.2	4.6	7130.5	1.000	1.000
7 6 11	98.21	2987.64	0.431	0.441	0.000	68.5	63.0	73.0	6.2	2058.2	1.000	1.000
7 6 12	98.27	3203.70	0.431	0.489	0.000	78.7	65.7	83.1	6.8	2338.9	1.000	1.000
7 6 13	102.61	3427.66	0.449	0.486	0.000	86.7	52.1	77.6	6.2	2178.5	1.000	1.000
7 6 14	100.68	3435.80	0.441	0.431	0.000	59.1	71.7	74.2	5.9	2083.1	1.000	1.000
7 6 15	103.68	4570.50	0.460	0.313	0.000	35.3	72.1	60.1	4.4	8388.1	1.000	1.000
7 6 16	102.66	4050.25	0.449	0.114	0.000	13.6	43.8	31.3	2.3	4372.8	1.000	1.000
7 6 17	101.75	3493.98	0.446	0.000	0.000	0.0	30.9	21.0	1.4	2907.9	1.000	1.000
7 6 18	101.74	3574.93	0.446	0.000	0.000	0.0	22.4	15.2	1.0	2110.5	1.000	1.000
7 6 19	102.52	2646.74	0.449	0.000	0.000	0.0	10.4	7.1	0.5	980.4	1.000	1.000
7 6 20	100.42	1727.19	0.440	0.000	0.000	0.0	0.3	0.2	0.0	28.0	1.000	1.000
7 6 21	97.70	1093.43	0.428	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
7 6 22	97.64	758.20	0.428	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
7 6 23	101.26	597.01	0.443	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
7 6 24	97.52	273.43	0.427	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
DAILY SUMMARY (JUL 6)												
MN	83.27	-1042.78	0.353	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
MX	103.68	4570.50	0.460	0.489	0.000	86.7	72.1	83.1	6.8	8388.1	1.000	1.000
SM	2296.82	36564.48	10.011	2.750	0.000	419.1	596.7	575.7	45.8	46157.7	24.000	1.000
AV	95.70	1523.52	0.417	0.115	0.000	17.5	24.9	24.0	1.9	1923.2	1.000	1.000
MONTHLY SUMMARY (JUL)												
MN	83.27	-1042.78	0.353	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
MX	103.68	4570.50	0.460	0.489	0.000	86.7	72.1	83.1	6.8	8388.1	1.000	1.000
SM	2296.82	36564.48	10.011	2.750	0.000	419.1	596.7	575.7	45.8	46157.7	24.000	1.000
AV	95.70	1523.52	0.417	0.115	0.000	17.5	24.9	24.0	1.9	1923.2	1.000	1.000
YEARLY SUMMARY												
MN	83.27	-3811.76	0.353	0.000	0.000	0.0	0.0	0.0	0.0	0.0	0.0	1.000
MX	105.51	7465.70	0.469	0.770	0.000	247.0	72.1	218.1	12.0	29909.1	1.000	1.000
SM	4693.11	43744.18	20.564	10.111	0.000	1896.9	872.4	1882.1	120.2	225667.5	48.000	1.000
AV	97.77	911.34	0.428	0.211	0.000	39.5	18.2	39.2	2.5	4701.4	1.000	1.000

LDS-REP-1 = HOURLY-REPORT

PAGE 1 - 5

MMDDHH	SSFRONTW IN CONDUCTN GLAS+FRM BTU/HR	SSFRONTW IN SH COEFF MULT	SSFRONTW IN MAX SOL GAIN BTU/HR- SQFT	SSFRONTW IN SHADING FLAG
	----(17)	----(19)	----(20)	----(23)
125 1	-2364.86	0.00	0.0	1.
125 2	-2352.14	0.00	0.0	1.
125 3	-2332.78	0.00	0.0	1.
125 4	-2203.41	0.00	0.0	1.
125 5	-2255.24	0.00	0.0	1.
125 6	-2351.17	0.00	0.0	1.
125 7	-2294.74	0.00	0.0	1.
125 8	-2266.11	1.00	1000.0	1.
125 9	-2283.92	1.00	1000.0	1.
12510	-2186.21	1.00	1000.0	1.
12511	-2027.92	1.00	1000.0	1.
12512	-1781.25	1.00	1000.0	1.
12513	-1669.63	1.00	1000.0	1.
12514	-1591.12	1.00	1000.0	1.
12515	-1546.36	1.00	1000.0	1.
12516	-1475.04	1.00	1000.0	1.
12517	-1503.80	1.00	1000.0	1.
12518	-1662.53	0.00	0.0	1.
12519	-1860.93	0.00	0.0	1.
12520	-2046.73	0.00	0.0	1.
12521	-2061.03	0.00	0.0	1.
12522	-2160.72	0.00	0.0	1.
12523	-2195.40	0.00	0.0	1.
12524	-2171.49	0.00	0.0	1.

DAILY SUMM RY (JAN 25)

MN	-2364.86	0.00	0.0	1.
MX	-1475.04	1.00	1000.0	1.
SM	-48644.54	10.00	10000.0	24.
AV	-2026.86	0.42	416.7	1.

MONTHLY SUMMARY (JAN)

MN	-2364.86	0.00	0.0	1.
MX	-1475.04	1.00	1000.0	1.
SM	-48644.54	10.00	10000.0	24.
AV	-2026.86	0.42	416.7	1.

	SSFRONTW IN CONDUCTN GLAS*FRM BTU/HR	SSFRONTW IN SH COEFF MULT	SSFRONTW IN MAX SOL GAIN BTU/HR- SQFT	SSFRONTW IN SHADING FLAG
	----(17)	----(19)	----(20)	----(23)
7 6 1	-671.69	0.00	0.0	1.
7 6 2	-722.06	0.00	0.0	1.
7 6 3	-764.82	0.00	0.0	1.
7 6 4	-793.02	0.00	0.0	1.
7 6 5	-757.11	1.00	20.0	1.
7 6 6	-757.99	1.00	20.0	1.
7 6 7	-610.81	1.00	20.0	1.
7 6 8	-298.65	1.00	20.0	1.
7 6 9	-38.43	1.00	20.0	1.
7 610	97.62	1.00	20.0	1.
7 611	226.47	0.20	20.0	2.
7 612	284.17	0.20	20.0	2.
7 613	372.92	0.20	20.0	2.
7 614	379.57	0.20	20.0	2.
7 615	500.96	1.00	20.0	1.
7 616	472.85	1.00	20.0	1.
7 617	455.40	1.00	20.0	1.
7 618	462.21	1.00	20.0	1.
7 619	295.98	1.00	20.0	1.
7 620	81.33	1.00	20.0	1.
7 621	-109.67	0.00	0.0	1.
7 622	-162.51	0.00	0.0	1.
7 623	-156.39	0.00	0.0	1.
7 624	-289.73	0.00	0.0	1.
DAILY SUMMARY (JUL 6)				
MN	-793.02	0.00	0.0	1.
MX	500.96	1.00	20.0	2.
SM	-2503.39	12.80	320.0	28.
AV	-104.31	0.53	13.3	1.
MONTHLY SUMMARY (JUL)				
MN	-793.02	0.00	0.0	1.
MX	500.96	1.00	20.0	2.
SM	-2503.39	12.80	320.0	28.
AV	-104.31	0.53	13.3	1.
YEARLY SUMMARY				
MN	-2364.86	0.00	0.0	1.
MX	500.96	1.00	1000.0	2.
SM	-51147.93	22.80	10320.0	52.
AV	-1065.58	0.47	215.0	1.

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993SDL RUN 1

REPORT- SV-A SYSTEM DESIGN PARAMETERS

SYS-1

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (SQFT)	MAX PEOPLE								
SYS-1	RESYS	1.020	1344.0	0.								
	SUPPLY FAN (CFM)	ELEC (KW)	DELTA-T (F)	RETURN FAN (CFM)	ELEC (KW)	DELTA-T (F)	OUTSIDE AIR RATIO	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	HEATING CAPACITY (KBTU/HR)	COOLING EIR (BTU/BTU)	HEATING EIR (BTU/BTU)
	714.	0.090	0.4	0.	0.000	0.0	0.000	24.000	0.667	-50.000	0.43	6.37
ZONE NAME	SUPPLY FLOW (CFM)	EXHAUST FLOW (CFM)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (CFM)	COOLING CAPACITY (KBTU/HR)	SENSIBLE (SHR)	EXTRACTION RATE (KBTU/HR)	HEATING CAPACITY (KBTU/HR)	ADDITION RATE (KBTU/HR)	MULTIPLIER	
HOUSE-1	714.	0.	0.000	1.000	0.	0.00	0.00	20.79	0.00	-49.13	1.0	
SUNSP-1	0.	0.	0.000	0.000	0.	0.00	0.00	0.00	0.00	0.00	1.0	

SINGLE FAMILY RESIDENCE

==WITH ATTACHED SUNSPACE==

DOE-2.1E-001 Thu Nov 11 10:51:11 1993SDL RUN 1

REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

SYS-1

WEATHER FILE- TRY CHICAGO

MONTH	C O O L I N G					H E A T I N G					E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY-BULB TEMP	WET-BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC-TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-5.336	12 9	-8.F	-8.F	-29.541	525.	1.395
FEB	0.00000				0.000	-4.227	4 9	7.F	6.F	-25.742	473.	1.387
MAR	0.00628	3 16	79.F	62.F	2.269	-2.449	24 9	7.F	6.F	-25.196	518.	1.386
APR	0.09467	27 15	82.F	61.F	6.883	-0.558	8 9	32.F	28.F	-16.896	501.	1.876
MAY	0.13108	21 14	85.F	75.F	10.377	-0.143	7 9	44.F	38.F	-11.270	513.	1.947
JUN	0.97545	20 17	90.F	78.F	12.957	0.000				0.000	627.	2.744
JUL	3.00949	13 17	97.F	78.F	14.197	0.000				0.000	964.	2.999
AUG	1.83279	20 15	89.F	73.F	12.113	0.000				0.000	782.	2.515
SEP	0.45465	11 15	87.F	72.F	9.355	-0.092	23 9	39.F	36.F	-12.245	544.	2.068
OCT	0.01026	4 16	77.F	61.F	4.021	-0.453	21 9	31.F	29.F	-16.253	499.	1.457
NOV	0.00397	2 16	77.F	62.F	3.968	-2.244	26 9	25.F	23.F	-19.119	499.	1.376
DEC	0.00000				0.000	-4.247	22 9	17.F	17.F	-22.840	523.	1.383
TOTAL	6.519					-19.748					6968.	
MAX					14.197					-29.541		2.999

 -- ZONE COOLING -- -- ZONE HEATING -- -- BASEBOARDS -- -- PREHEAT OR FURN PAN ELEC --

MONTH	COOLING BY ZONE COILS OR NAT VENTIL (MBTU)	MAXIMUM COOLING BY ZONE COILS OR NAT VENTIL (KBTU/HR)	HEATING BY ZONE COILS OR FURNACE (MBTU)	MAXIMUM HEATING BY ZONE COILS OR FURNACE (KBTU/HR)	BASEBOARD HEATING ENERGY (MBTU)	MAXIMUM BASEBOARD HEATING ENERGY (KBTU/HR)	PREHEAT COIL ENERGY OR ELEC FOR FURN PAN (MBTU)	MAXIMUM PREHEAT COIL ENERGY OR ELEC FOR FURN PAN (KBTU/HR)
JAN	0.00000	0.000	-5.33561	-29.541	0.00000	0.000	0.03263	0.181
FEB	0.00262	1.891	-4.22719	-25.742	0.00000	0.000	0.02585	0.157
MAR	0.01581	2.977	-2.44867	-25.196	0.00000	0.000	0.01498	0.154
APR	0.37852	5.965	-0.55775	-16.896	0.00000	0.000	0.00341	0.103
MAY	0.70320	8.583	-0.14315	-11.270	0.00000	0.000	0.00088	0.069
JUN	0.97776	7.597	0.00000	0.000	0.00000	0.000	0.00000	0.000
JUL	0.56267	7.672	0.00000	0.000	0.00000	0.000	0.00000	0.000
AUG	0.93378	7.577	0.00000	0.000	0.00000	0.000	0.00000	0.000
SEP	0.70545	7.715	-0.09156	-12.245	0.00000	0.000	0.00056	0.075
OCT	0.40865	6.300	-0.45299	-16.253	0.00000	0.000	0.00277	0.099
NOV	0.12187	6.381	-2.24423	-19.119	0.00000	0.000	0.01373	0.117
DEC	0.00000	0.000	-4.24668	-22.840	0.00000	0.000	0.02597	0.140
TOTAL	4.810		-19.748		0.000		0.121	
MAX		8.583		-29.541		0.000		0.181

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993SDL RUN 1

REPORT- 99-C SYSTEM MONTHLY LOAD HOURS FOR

SYS-1

WEATHER FILE- TRY CHICAGO

----- NUMBER OF HOURS -----											--COINCIDENT LOADS--	
MONTH	HOURS COOLING LOAD	HOURS HEATING LOAD	HOURS COINCIDENT COOL-HEAT LOAD	HOURS FLOATING	HOURS HEATING FAIL.	HOURS COOLING AVAIL.	HOURS FANS ON	HOURS FANS CYCLE ON	HOURS NIGHT VENTING	HOURS FLOATING WHEN FANS ON	HEATING LOAD AT COOLING PEAK (KBTU/HR)	ELECTRIC LOAD AT COOLING PEAK (KW)
JAN	0	623	0	121	744	744	744	0	0	121	0.000	1.161
FEB	0	543	0	129	672	672	672	0	0	129	0.000	1.161
MAR	3	456	0	285	744	744	744	0	0	285	0.000	0.956
APR	22	137	0	561	720	720	720	0	0	561	0.000	1.471
MAY	28	39	0	677	744	744	744	0	0	677	0.000	1.860
JUN	180	0	0	540	720	720	720	0	0	540	0.000	2.390
JUL	481	0	0	263	744	744	744	0	0	263	0.000	2.681
AUG	322	0	0	422	744	744	744	0	0	422	0.000	2.115
SEP	79	27	0	614	720	720	720	0	0	614	0.000	1.766
OCT	5	114	0	625	744	744	744	0	0	625	0.000	1.141
NOV	1	417	0	302	720	720	720	0	0	302	0.000	1.120
DEC	0	610	0	134	744	744	744	0	0	134	0.000	1.161
ANNUAL	1121	2966	0	4673	8760	8760	8760	0	0	4673		

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993SDL RUN 1

REPORT- SS-H SYSTEM MONTHLY LOADS SUMMARY FOR

SYS-1

WEATHER FILE- TRY CHICAGO

MONTH	-FAN ELEC-		-FUEL HEAT-		-FUEL COOL-		-ELEC HEAT-		-ELEC COOL-	
	FAN ENERGY (KWH)	MAXIMUM FAN LOAD (KW)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	GAS OIL ENERGY (MBTU)	MAXIMUM GAS OIL LOAD (KBTU/HR)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)	ELECTRIC ENERGY (KWH)	MAXIMUM ELECTRIC LOAD (KW)
JAN	10.	0.053	8.540	42.277	0.000	0.000	0.	0.000	37.	0.050
FEB	8.	0.046	6.851	37.311	0.000	0.000	0.	0.000	33.	0.050
MAR	5.	0.045	4.198	36.591	0.000	0.000	0.	0.000	35.	0.541
APR	3.	0.048	1.056	25.412	0.000	0.000	0.	0.000	33.	1.014
MAY	3.	0.060	0.332	17.594	0.000	0.000	0.	0.000	30.	1.391
JUN	8.	0.067	0.072	0.100	0.000	0.000	0.	0.000	153.	1.742
JUL	19.	0.072	0.074	0.100	0.000	0.000	0.	0.000	459.	2.038
AUG	14.	0.065	0.074	0.100	0.000	0.000	0.	0.000	284.	1.641
SEP	4.	0.053	0.239	18.962	0.000	0.000	0.	0.000	75.	1.318
OCT	2.	0.034	0.876	24.528	0.000	0.000	0.	0.000	18.	0.697
NOV	5.	0.034	3.854	28.447	0.000	0.000	0.	0.000	31.	0.692
DEC	8.	0.041	6.985	33.461	0.000	0.000	0.	0.000	37.	0.050
TOTAL	89.		33.153		0.000		0.		1225.	
MAX		0.072		42.277		0.000		0.000		2.038

UNIT TYPE is RESYS HEATING-CAPACITY = -50.000 (KBTU/HR) HEATING-EIR = 0.370 (BTU/BTU) SUPPLY-FLOW = 714. (CFM)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	COMPRESSOR (KWH) (KW)	FAN ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN + HOURS	
					00	10	20	30	40	50	60	70	80	90	100		
					10	20	30	40	50	60	70	80	90	100			
JAN	SUM -5.336 PEAK -29.541 DAY/HR 12/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	9.887 0.053 0/ 0	CMP 0 FAN 159	0 235	0 167	0 47	0 10	0 5	0 0	0 0	0 0	0 0	0 0	0 0	0 623
FEB	SUM -4.227 PEAK -25.742 DAY/HR 4/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	8.063 0.046 0/ 0	CMP 0 FAN 170	0 217	0 120	0 24	0 11	0 1	0 0	0 0	0 0	0 0	0 0	0 0	0 543
MAR	SUM -2.449 PEAK -25.196 DAY/HR 24/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	5.214 0.045 0/ 0	CMP 0 FAN 252	0 148	0 39	0 14	0 2	0 1	0 0	0 0	0 0	0 0	0 0	0 0	0 456
APR	SUM -0.558 PEAK -16.896 DAY/HR 8/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	3.193 0.048 0/ 0	CMP 0 FAN 102	0 24	0 9	0 2	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 137
MAY	SUM -0.143 PEAK -11.270 DAY/HR 7/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	2.890 0.060 0/ 0	CMP 0 FAN 28	0 9	0 2	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 39
JUN	SUM 0.000 PEAK 0.000 DAY/HR 30/ 1	0.000 0.000 0/ 0	0.000 0.000 0/ 0	8.178 0.067 0/ 0	CMP 0 FAN 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
JUL	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 0/ 0	0.000 0.000 0/ 0	19.171 0.072 0/ 0	CMP 0 FAN 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
AUG	SUM 0.000 PEAK 0.000 DAY/HR 31/ 1	0.000 0.000 0/ 0	0.000 0.000 0/ 0	13.572 0.065 0/ 0	CMP 0 FAN 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0
SEP	SUM -0.092 PEAK -12.245 DAY/HR 23/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	4.303 0.053 0/ 0	CMP 0 FAN 21	0 4	0 2	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 27
OCT	SUM -0.453 PEAK -16.253 DAY/HR 21/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	2.381 0.034 0/ 0	CMP 0 FAN 88	0 18	0 6	0 2	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 114
NOV	SUM -2.244 PEAK -19.119 DAY/HR 26/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	4.696 0.034 0/ 0	CMP 0 FAN 215	0 168	0 21	0 13	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 417
DEC	SUM -4.247 PEAK -22.840 DAY/HR 22/ 9	0.000 0.000 0/ 0	0.000 0.000 0/ 0	7.771 0.041 0/ 0	CMP 0 FAN 182	0 323	0 74	0 26	0 5	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 610
YR	SUM -19.748 PEAK -29.541 MON/DAY 0/ 0	0.000 0.000 0/ 0	0.000 0.000 0/ 0	89.319 0.072 0/ 0	CMP 0 FAN1217	0 1146	0 440	0 128	0 28	0 7	0 0	0 0	0 0	0 0	0 0	0 0	0 2966

UNIT TYPE is RESYS COOLING-CAPACITY = 24.000 (KBTU/HR) COOLING-EIR = 0.427 (BTU/BTU) SUPPLY-FLOW = 714. (CFM)

MONTH	UNIT LOAD SUM (MBTU) PEAK (KBTU/HR) DAY/HR	ENERGY USE (KWH) (KW)	COMPRESSOR (KWH) (KW)	FAN ENERGY (KWH) (KW)	Number of hours within each PART LOAD range											TOTAL RUN HOURS	
					00	10	20	30	40	50	60	70	80	90	100		
					10	20	30	40	50	60	70	80	90	100	+		
JAN	SUM 0.000 PEAK 0.000 DAY/HR 31/24	37.000 0.050 0/0	0.000 0.000 0/0	9.887 0.053 0/0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
FEB	SUM 0.000 PEAK 0.000 DAY/HR 28/24	33.400 0.050 0/0	0.000 0.000 0/0	8.063 0.046 0/0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
MAR	SUM 0.006 PEAK 2.269 DAY/HR 3/16	34.756 0.541 0/0	1.557 0.541 3/16	5.214 0.045 0/0	CMP 3 FAN 2	0	1	0	0	0	0	0	0	0	0	0	3
APR	SUM 0.095 PEAK 6.883 DAY/HR 27/15	33.248 1.014 0/0	16.148 1.014 27/15	3.193 0.048 0/0	CMP 4 FAN 3	8	8	10	1	0	0	0	0	0	0	0	22
MAY	SUM 0.131 PEAK 10.377 DAY/HR 21/14	30.220 1.391 0/0	21.470 1.391 21/14	2.890 0.060 0/0	CMP 9 FAN 8	6	6	6	8	1	0	0	0	0	0	0	28
JUN	SUM 0.975 PEAK 12.957 DAY/HR 20/17	152.585 1.742 0/0	152.285 1.742 20/18	8.178 0.067 0/0	CMP 42 FAN 40	22	23	58	49	6	3	0	0	0	0	0	180
JUL	SUM 3.009 PEAK 14.197 DAY/HR 13/17	459.262 2.038 0/0	459.262 2.038 13/18	19.171 0.072 0/0	CMP 98 FAN 94	61	60	98	128	77	16	3	0	0	0	0	481
AUG	SUM 1.833 PEAK 12.113 DAY/HR 20/15	284.092 1.641 0/0	284.092 1.641 26/17	13.572 0.065 0/0	CMP 80 FAN 75	38	39	72	87	43	2	0	0	0	0	0	322
SEP	SUM 0.455 PEAK 9.355 DAY/HR 11/15	74.856 1.318 0/0	70.206 1.318 11/15	4.303 0.053 0/0	CMP 12 FAN 9	10	9	28	29	0	0	0	0	0	0	0	79
OCT	SUM 0.010 PEAK 4.021 DAY/HR 4/16	17.694 0.697 0/0	2.544 0.697 4/16	2.381 0.034 0/0	CMP 3 FAN 3	2	2	0	0	0	0	0	0	0	0	0	5
NOV	SUM 0.004 PEAK 3.968 DAY/HR 2/16	31.042 0.692 0/0	0.692 0.692 2/16	4.696 0.034 0/0	CMP 0 FAN 0	1	1	0	0	0	0	0	0	0	0	0	1
DEC	SUM 0.000 PEAK 0.000 DAY/HR 31/24	37.200 0.050 0/0	0.000 0.000 0/0	7.771 0.041 0/0	CMP 0 FAN 0	0	0	0	0	0	0	0	0	0	0	0	0
YR	SUM 6.519 PEAK 14.197 MON/DAY 0/0	1225.443 2.038 0/0	1008.255 2.038 7/13	89.319 0.072 0/0	CMP 251 FAN 234	148	148	272	299	127	21	3	0	0	0	0	1121

UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	S'UP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	INDOOR FAN ENERGY (MBTU)		
JAN	0.	0.000	0.000	0.126	0.000	0.000	0.000	0.000	0.000	0.000
FEB	0.	0.000	0.000	0.114	0.000	0.000	0.000	0.000	0.000	0.000
MAR	0.	0.006	0.005	0.113	0.000	0.000	0.000	0.000	0.000	0.000
APR	4.	0.095	0.055	0.058	0.000	0.000	0.000	0.000	0.000	0.001
MAY	5.	0.131	0.073	0.030	0.000	0.000	0.000	0.000	0.000	0.002
JUN	41.	0.975	0.520	0.001	0.000	0.000	0.000	0.000	0.000	0.013
JUL	128.	3.009	1.567	0.000	0.000	0.000	0.000	0.000	0.000	0.040
AUG	78.	1.833	0.970	0.000	0.000	0.000	0.000	0.000	0.000	0.024
SEP	19.	0.455	0.240	0.016	0.000	0.000	0.000	0.000	0.000	0.006
OCT	0.	0.010	0.009	0.052	0.000	0.000	0.000	0.000	0.000	0.000
NOV	0.	0.004	0.002	0.104	0.000	0.000	0.000	0.000	0.000	0.000
DEC	0.	0.000	0.000	0.127	0.000	0.000	0.000	0.000	0.000	0.000
ANNUAL	277.	6.519	3.441	0.741	0.000	0.000	0.000	0.000	0.000	0.087

CSPF (WITH PARASITICS) = 1.53 (BTU/BTU)

CSPF (WITHOUT PARASITICS) = 1.89 (BTU/BTU)

	UNIT RUN TIME (HOURS)	TOTAL LOAD ON UNIT (MBTU)	ENERGY IN TO UNIT (MBTU)	AUXILIARY ENERGY (MBTU)	SUP UNIT LOAD (MBTU)	SUP UNIT ENERGY (MBTU)	WASTE HEAT GENERATED (MBTU)	WASTE HEAT USE (MBTU)	DEFROST LOAD (MBTU)	INDOOR FAN ENERGY (MBTU)
JAN	107.	-5.336	8.476	0.064	0.000	0.000	0.000	0.000	0.000	0.033
FEB	85.	-4.227	6.792	0.059	0.000	0.000	0.000	0.000	0.000	0.026
MAR	49.	-2.449	4.129	0.070	0.000	0.000	0.000	0.000	0.000	0.015
APR	11.	-0.558	0.985	0.071	0.000	0.000	0.000	0.000	0.000	0.003
MAY	3.	-0.143	0.258	0.074	0.000	0.000	0.000	0.000	0.000	0.001
JUN	0.	0.000	0.000	0.072	0.000	0.000	0.000	0.000	0.000	0.000
JUL	0.	0.000	0.000	0.074	0.000	0.000	0.000	0.000	0.000	0.000
AUG	0.	0.000	0.000	0.074	0.000	0.000	0.000	0.000	0.000	0.000
SEP	2.	-0.092	0.168	0.072	0.000	0.000	0.000	0.000	0.000	0.001
OCT	9.	-0.453	0.803	0.073	0.000	0.000	0.000	0.000	0.000	0.003
NOV	45.	-2.244	3.787	0.068	0.000	0.000	0.000	0.000	0.000	0.014
DEC	85.	-4.247	6.919	0.066	0.000	0.000	0.000	0.000	0.000	0.026
ANNUAL	395.	-19.748	32.316	0.837	0.000	0.000	0.000	0.000	0.000	0.121

HSPF (WITH PARASITICS) = 0.60 (BTU/BTU)

HSPF (WITHOUT PARASITICS) = 0.61 (BTU/BTU)

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993SDL RUN 1

REPORT- SS-F ZONE DEMAND SUMMARY IN SYS-1

FOR HOUSE-1

WEATHER FILE- TRY CHICAGO

- - - D E M A N D S - - - -		- - B A S E B O A R D S - - -		- - T E M P E R A T U R E S - - -		- - L O A D S N O T M E T - -		
MONTH	HEAT EXTRACTION ENERGY (MBTU)	HEAT ADDITION ENERGY (MBTU)	BASEBOARD ENERGY (MBTU)	MAXIMUM BASEBOARD LOAD (KBTU/HR)	MAXIMUM ZONE TEMP (F)	MINIMUM ZONE TEMP (F)	HOURS UNDER HEATED	HOURS UNDER COOLED
JAN	0.00000	-5.298	0.00000	0.000	74.2	55.1	0	0
FEB	0.00262	-4.192	0.00000	0.000	75.0	55.1	0	0
MAR	0.02122	-2.424	0.00000	0.000	77.4	55.1	0	0
APR	0.46508	-0.549	0.00000	0.000	78.2	55.2	0	0
MAY	0.80302	-0.143	0.00000	0.000	78.0	55.2	0	0
JUN	1.78336	-0.001	0.00000	0.000	78.0	65.8	0	0
JUL	2.99525	0.000	0.00000	0.000	78.2	72.1	0	0
AUG	2.42679	0.000	0.00000	0.000	78.2	69.8	0	0
SEP	1.08423	-0.089	0.00000	0.000	78.0	56.2	0	0
OCT	0.41764	-0.442	0.00000	0.000	78.1	55.2	0	0
NOV	0.12538	-2.222	0.00000	0.000	78.2	55.2	0	0
DEC	0.00000	-4.209	0.00000	0.000	74.0	55.2	0	0

SINGLE FAMILY RESIDENCE

===WITH ATTACHED SUNSPACE===

DOE-2.1E-001 Thu Nov 11 10:51:11 1993SDL RUN 1

REPORT- SS-O TEMPERATURE SCATTER PLOT SYS-1

FOR HOUSE-1

WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
80-85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
75-80	86	74	62	50	50	57	77	81	93	118	145	172	187	187	195	181	173	164	156	155	147	135	133	105	2983
70-75	62	64	65	66	62	59	54	110	265	247	220	193	178	178	170	184	192	201	209	210	218	213	49	63	3532
65-70	42	43	50	50	53	46	39	10	7	0	0	0	0	0	0	0	0	0	0	0	0	16	56	44	456
60-65	51	39	33	32	27	28	25	16	0	0	0	0	0	0	0	0	0	0	0	0	0	1	96	98	446
BELOW 60	124	145	155	167	173	175	170	148	0	0	0	0	0	0	0	0	0	0	0	0	0	0	31	55	1343

*** **

SYS-REP-1

= HOURLY-REPORT

PAGE 1 - 1

MMDDHH	GLOBAL	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1
	DRY BULB TEMP F	ZONE TEMP F	FLOAT TEMP F	THERMOST SETPOINT F	EXTRACTN RATE BTU/HR	CONVEC EXTRACTN BTU/HR	ZONE TEMP F	FLOAT TEMP F	EXTRACTN RATE BTU/HR	CONVEC EXTRACTN BTU/HR	SUNSPACE VENT EXT BTU/HR
	---(8)	---(6)	---(21)	---(7)	---(8)	---(61)	---(6)	---(21)	---(8)	---(61)	---(64)
125 1	30.0	57.4	57.4	55.0	0.	0.	50.5	50.5	0.	0.	0.
125 2	31.0	55.2	55.2	55.0	-12.	0.	49.4	49.4	0.	0.	0.
125 3	32.0	55.2	53.6	55.0	-1514.	0.	48.4	48.4	0.	0.	0.
125 4	33.0	55.2	52.9	55.0	-2087.	0.	47.9	47.9	0.	0.	0.
125 5	33.0	55.2	52.5	55.0	-2533.	0.	46.9	46.9	0.	0.	0.
125 6	32.0	55.2	52.5	55.0	-2525.	0.	45.7	45.7	0.	0.	0.
125 7	33.0	55.2	52.9	55.0	-2168.	0.	45.0	45.0	0.	0.	0.
125 8	32.0	55.2	54.7	55.0	-472.	0.	45.6	45.6	0.	0.	0.
125 9	33.0	70.1	56.1	70.0	-12900.	0.	57.5	57.5	0.	0.	0.
12510	36.0	70.2	62.5	70.0	-7278.	0.	72.5	72.5	0.	0.	0.
12511	39.0	70.2	69.1	70.0	-1051.	-1411.	80.8	80.8	0.	1382.	0.
12512	43.0	74.2	74.2	78.0	0.	-2303.	88.9	88.9	0.	2272.	0.
12513	45.0	74.0	74.0	78.0	0.	-551.	89.6	89.6	0.	545.	2265.
12514	46.0	74.2	74.2	78.0	0.	0.	89.8	89.8	0.	0.	3272.
12515	47.0	74.0	74.0	78.0	0.	-506.	88.7	88.7	0.	500.	2612.
12516	48.0	74.0	74.0	70.0	0.	-1786.	88.5	88.5	0.	1766.	0.
12517	48.0	72.8	72.8	70.0	0.	-1960.	77.9	77.9	0.	1926.	0.
12518	44.0	70.2	70.0	70.0	-262.	-759.	74.0	74.0	0.	732.	0.
12519	41.0	70.2	66.9	70.0	-3047.	0.	71.4	71.4	0.	0.	0.
12520	38.0	70.2	66.2	70.0	-3784.	0.	67.2	67.2	0.	0.	0.
12521	37.0	70.2	65.6	70.0	-4304.	0.	64.3	64.3	0.	0.	0.
12522	36.0	70.2	64.8	70.0	-5068.	0.	61.6	61.6	0.	0.	0.
12523	35.0	64.4	64.4	55.0	0.	0.	59.3	59.3	0.	0.	0.
12524	35.0	62.7	62.7	55.0	0.	0.	57.5	57.5	0.	0.	0.
DAILY SUMMARY (JAN 25)											
MN	30.0	55.2	52.5	55.0	-12900.	-2303.	45.0	45.0	0.	0.	0.
MX	48.0	74.2	74.2	78.0	0.	0.	89.8	89.8	0.	2272.	3272.
SM	907.0	1575.9	1523.1	1562.0	-49004.	-9275.	1569.0	1569.0	0.	9124.	8149.
AV	37.8	65.7	63.5	65.1	-2042.	-386.	65.4	65.4	0.	380.	340.
MONTHLY SUMMARY (JAN)											
MN	30.0	55.2	52.5	55.0	-12900.	-2303.	45.0	45.0	0.	0.	0.
MX	48.0	74.2	74.2	78.0	0.	0.	89.8	89.8	0.	2272.	3272.
SM	907.0	1575.9	1523.1	1562.0	-49004.	-9275.	1569.0	1569.0	0.	9124.	8149.
AV	37.8	65.7	63.5	65.1	-2042.	-386.	65.4	65.4	0.	380.	340.

	GLOBAL	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	
	DRY BULB TEMP F	ZONE TEMP F	FLOAT TEMP F	THERMOST SETPOINT F	EXTRACTN RATE BTU/HR	CONVEC EXTRACTN BTU/HR	ZONE TEMP F	FLOAT TEMP F	EXTRACTN RATE BTU/HR	CONVEC EXTRACTN BTU/HR	SUNSPACE VENT EXT BTU/HR	
	---	(8)	---	(6)	---	(21)	---	(7)	---	(8)	---	(61)
7 6 1	62.0	75.2	75.2	78.0	0.	0.	70.7	70.7	0.	0.	0.	
7 6 2	62.0	74.3	74.3	78.0	0.	0.	69.2	69.2	0.	0.	0.	
7 6 3	61.0	73.3	73.3	78.0	0.	0.	67.8	67.8	0.	0.	0.	
7 6 4	60.0	72.2	72.2	78.0	0.	0.	67.0	67.0	0.	0.	0.	
7 6 5	61.0	72.2	72.2	78.0	0.	0.	66.1	66.1	0.	0.	0.	
7 6 6	61.0	73.5	73.5	78.0	0.	0.	67.3	67.3	0.	0.	0.	
7 6 7	64.0	76.4	76.4	78.0	0.	0.	69.6	69.6	0.	0.	0.	
7 6 8	69.0	75.0	77.7	75.0	2430.	0.	74.5	74.5	0.	0.	0.	
7 6 9	73.0	75.0	78.6	75.0	3203.	0.	80.2	80.2	0.	0.	0.	
7 610	76.0	77.8	80.0	78.0	1935.	0.	80.1	80.1	0.	0.	1571.	
7 611	78.0	77.8	82.5	78.0	4140.	0.	81.1	81.1	0.	0.	1323.	
7 612	79.0	77.9	83.9	78.0	5277.	0.	82.3	82.3	0.	0.	1384.	
7 613	80.0	77.9	84.5	78.0	5951.	0.	83.2	83.2	0.	0.	1423.	
7 614	80.0	77.9	85.3	78.0	6597.	0.	83.1	83.1	0.	0.	1589.	
7 615	81.0	77.9	86.1	78.0	7324.	0.	86.2	86.2	0.	0.	2024.	
7 616	81.0	77.9	86.2	78.0	7434.	0.	84.5	84.5	0.	0.	2049.	
7 617	81.0	77.9	86.0	78.0	7217.	0.	84.1	84.1	0.	0.	1624.	
7 618	81.0	77.9	86.0	78.0	7185.	0.	84.4	84.4	0.	0.	1653.	
7 619	78.0	77.9	86.0	78.0	7210.	0.	81.0	81.0	0.	0.	1516.	
7 620	75.0	77.9	84.3	78.0	5708.	0.	79.9	79.9	0.	0.	790.	
7 621	72.0	75.0	82.8	75.0	6958.	0.	79.5	79.5	0.	0.	199.	
7 622	71.0	77.8	80.8	78.0	2603.	0.	78.7	78.7	0.	0.	0.	
7 623	71.0	77.8	80.3	78.0	2263.	0.	77.6	77.6	0.	0.	0.	
7 624	69.0	77.8	78.0	78.0	184.	0.	76.0	76.0	0.	0.	0.	
DAILY SUMMARY (JUL 6)												
MN	60.0	72.2	72.2	75.0	0.	0.	66.1	66.1	0.	0.	0.	
MX	81.0	77.9	86.2	78.0	7434.	0.	86.2	86.2	0.	0.	2049.	
SM	1726.0	1832.4	1926.1	1863.0	83617.	0.	1854.2	1854.2	0.	0.	17145.	
AV	71.9	76.3	80.3	77.6	3484.	0.	77.3	77.3	0.	0.	714.	
MONTHLY SUMMARY (JUL)												
MN	60.0	72.2	72.2	75.0	0.	0.	66.1	66.1	0.	0.	0.	
MX	81.0	77.9	86.2	78.0	7434.	0.	86.2	86.2	0.	0.	2049.	
SM	1726.0	1832.4	1926.1	1863.0	83617.	0.	1854.2	1854.2	0.	0.	17145.	
AV	71.9	76.3	80.3	77.6	3484.	0.	77.3	77.3	0.	0.	714.	
YEARLY SUMMARY												
MN	30.0	55.2	52.5	55.0	-12900.	-2303.	45.0	45.0	0.	0.	0.	
MX	81.0	77.9	86.2	78.0	7434.	0.	89.8	89.8	0.	2272.	3272.	
SM	2633.0	3408.3	3449.1	3425.0	34614.	-9275.	3423.2	3423.2	0.	9124.	25293.	
AV	54.9	71.0	71.9	71.4	721.	-193.	71.3	71.3	0.	190.	527.	

SYS-REP-1

= HOURLY-REPORT

PAGE 1 - 2

MMDDHH	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	SUNSP-1
	SENSIBLE LOAD-IN BTU/HR	HTG SET POINT F	CLG SET POINT F	CONVEC AIRFLOW CFM	COM WIN SOL GAIN BTU/HR	COM WIN SOL LOAD BTU/HR	COM WIN CONDUCTN BTU/HR	COM WALL ABSD SOL BTU/HR	COM WALL CONDUCTN BTU/HR	COM WALL CONDUCTN BTU/HR	SENSIBLE LOAD-IN BTU/HR
	---- (1)	---- (17)	---- (18)	---- (62)	---- (56)	---- (57)	---- (58)	---- (59)	---- (60)	---- (1)	
125 1	-7668.	55.0	78.0	0.0	0.	0.	0.	94.	-91.	-3056.	
125 2	-7860.	55.0	78.0	0.0	0.	0.	0.	96.	-111.	-3189.	
125 3	-7916.	55.0	78.0	0.0	0.	0.	0.	98.	-128.	-3291.	
125 4	-7716.	55.0	78.0	0.0	0.	0.	0.	96.	-142.	-3213.	
125 5	-7839.	55.0	78.0	0.0	0.	0.	0.	98.	-153.	-3376.	
125 6	-7668.	55.0	78.0	0.0	0.	0.	0.	99.	-161.	-3603.	
125 7	-7121.	55.0	78.0	0.0	0.	0.	0.	99.	-169.	-3621.	
125 8	-5139.	55.0	78.0	0.0	0.	0.	0.	94.	-177.	-3236.	
125 9	-3908.	70.0	78.0	0.0	0.	0.	0.	98.	-184.	-662.	
12510	-2435.	70.0	78.0	0.0	0.	0.	0.	102.	-183.	2303.	
12511	574.	70.0	78.0	170.0	0.	0.	0.	103.	-152.	4939.	
12512	3471.	70.0	78.0	178.6	0.	0.	0.	102.	-87.	7061.	
12513	3488.	70.0	78.0	33.3	0.	0.	0.	105.	-12.	7246.	
12514	3413.	70.0	78.0	0.0	0.	0.	0.	104.	59.	7366.	
12515	2349.	70.0	78.0	31.0	0.	0.	0.	106.	108.	6773.	
12516	747.	70.0	78.0	113.2	0.	0.	0.	105.	135.	5219.	
12517	-652.	70.0	78.0	200.0	0.	0.	0.	105.	147.	2752.	
12518	-1932.	70.0	78.0	160.0	0.	0.	0.	97.	147.	896.	
12519	-3172.	70.0	78.0	0.0	0.	0.	0.	100.	122.	-190.	
12520	-3573.	70.0	78.0	0.0	0.	0.	0.	101.	87.	-986.	
12521	-3956.	70.0	78.0	0.0	0.	0.	0.	98.	55.	-1398.	
12522	-4668.	70.0	78.0	0.0	0.	0.	0.	101.	24.	-1830.	
12523	-5024.	55.0	78.0	0.0	0.	0.	0.	99.	-5.	-2136.	
12524	-4849.	55.0	78.0	0.0	0.	0.	0.	98.	-30.	-2328.	
DAILY SUMMARY (JAN 25)											
MN	-7916.	55.0	78.0	0.0	0.	0.	0.	94.	-184.	-3621.	
MX	3488.	70.0	78.0	200.0	0.	0.	0.	106.	147.	7366.	
SM	-79055.	1530.0	1872.0	886.1	0.	0.	0.	2396.	-902.	8440.	
AV	-3294.	63.8	78.0	36.9	0.	0.	0.	100.	-38.	352.	
MONTHLY SUMMARY (JAN)											
MN	-7916.	55.0	78.0	0.0	0.	0.	0.	94.	-184.	-3621.	
MX	3488.	70.0	78.0	200.0	0.	0.	0.	106.	147.	7366.	
SM	-79055.	1530.0	1872.0	886.1	0.	0.	0.	2396.	-902.	8440.	
AV	-3294.	63.8	78.0	36.9	0.	0.	0.	100.	-38.	352.	

	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	HOUSE-1	SUNSP-1
	SENSIBLE LOAD-IN BTU/HR	HTG SET POINT F	CLG SET POINT F	CONVEC AIRFLOW CFM	COM WIN SOL GAIN BTU/HR	COM WIN SOL LOAD BTU/HR	COM WIN CONDUCTN BTU/HR	COM WALL ABSD SOL BTU/HR	COM WALL CONDUCTN BTU/HR	SENSIBLE LOAD-IN BTU/HR
	---- (1)	---- (17)	---- (18)	---- (62)	---- (56)	---- (57)	---- (58)	---- (59)	---- (60)	---- (1)
7 6 1	155.	55.0	78.0	0.0	0.	0.	0.	84.	51.	-532.
7 6 2	-289.	55.0	78.0	0.0	0.	0.	0.	84.	38.	-743.
7 6 3	-694.	55.0	78.0	0.0	0.	0.	0.	83.	25.	-902.
7 6 4	-1114.	55.0	78.0	0.0	0.	0.	0.	93.	13.	-981.
7 6 5	-597.	55.0	78.0	0.0	0.	0.	0.	84.	2.	-1037.
7 6 6	866.	55.0	78.0	0.0	0.	0.	0.	84.	-8.	-697.
7 6 7	3125.	55.0	78.0	0.0	0.	0.	0.	85.	-16.	-204.
7 6 8	3452.	70.0	78.0	0.0	0.	0.	0.	96.	-18.	801.
7 6 9	4253.	70.0	78.0	0.0	0.	0.	0.	101.	-11.	1907.
7 610	5410.	70.0	78.0	0.0	0.	0.	0.	98.	9.	3128.
7 611	6816.	70.0	78.0	0.0	0.	0.	0.	98.	37.	2978.
7 612	7600.	70.0	78.0	0.0	0.	0.	0.	98.	60.	3191.
7 613	8206.	70.0	78.0	0.0	0.	0.	0.	103.	76.	3411.
7 614	8704.	70.0	78.0	0.0	0.	0.	0.	101.	88.	3421.
7 615	9429.	70.0	78.0	0.0	0.	0.	0.	104.	97.	4550.
7 616	9494.	70.0	78.0	0.0	0.	0.	0.	103.	104.	4037.
7 617	9204.	70.0	78.0	0.0	0.	0.	0.	102.	114.	3477.
7 618	9143.	70.0	78.0	0.0	0.	0.	0.	102.	119.	3557.
7 619	9134.	70.0	78.0	0.0	0.	0.	0.	103.	119.	2644.
7 620	7556.	70.0	78.0	0.0	0.	0.	0.	100.	118.	1728.
7 621	6213.	70.0	78.0	0.0	0.	0.	0.	98.	109.	1096.
7 622	5180.	55.0	78.0	0.0	0.	0.	0.	98.	99.	760.
7 623	4483.	55.0	78.0	0.0	0.	0.	0.	101.	90.	598.
7 624	2114.	55.0	78.0	0.0	0.	0.	0.	98.	82.	272.
DAILY SUMMARY (JUL 6)										
MN	-1114.	55.0	78.0	0.0	0.	0.	0.	83.	-18.	-1037.
MX	9494.	70.0	78.0	0.0	0.	0.	0.	104.	119.	4550.
SM	117840.	1530.0	1872.0	0.0	0.	0.	0.	2297.	1398.	36458.
AV	4910.	63.8	78.0	0.0	0.	0.	0.	96.	58.	1519.
MONTHLY SUMMARY (JUL)										
MN	-1114.	55.0	78.0	0.0	0.	0.	0.	83.	-18.	-1037.
MX	9494.	70.0	78.0	0.0	0.	0.	0.	104.	119.	4550.
SM	117840.	1530.0	1872.0	0.0	0.	0.	0.	2297.	1398.	36458.
AV	4910.	63.8	78.0	0.0	0.	0.	0.	96.	58.	1519.
YEARLY SUMMARY										
MN	-7916.	55.0	78.0	0.0	0.	0.	0.	83.	-184.	-3621.
MX	9494.	70.0	78.0	200.0	0.	0.	0.	106.	147.	7366.
SM	38785.	3060.0	3744.0	886.1	0.	0.	0.	4693.	496.	44898.
AV	808.	63.8	78.0	18.5	0.	0.	0.	98.	10.	935.

SYS-REP-1

= HOURLY-REPORT

PAGE 1 - 3

MDDHH	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1
	HTG SET POINT F	CLG SET POINT F	CONVEC AIRFLOW CFM	COM WIN CONDUCTN BTU/HR	COM WALL ABSD SOL BTU/HR	COM WALL CONDUCTN BTU/HR	SUNSPACE VENT FLW CFM
	----(17)	----(18)	----(62)	----(58)	----(59)	----(60)	----(63)
125 1	-999.0	999.0	0.0	0.	94.	72.	0.0
125 2	-999.0	999.0	0.0	0.	96.	51.	0.0
125 3	-999.0	999.0	0.0	0.	98.	28.	0.0
125 4	-999.0	999.0	0.0	0.	96.	4.	0.0
125 5	-999.0	999.0	0.0	0.	98.	-9.	0.0
125 6	-999.0	999.0	0.0	0.	99.	-16.	0.0
125 7	-999.0	999.0	0.0	0.	99.	-19.	0.0
125 8	-999.0	999.0	0.0	0.	94.	-25.	0.0
125 9	-999.0	999.0	0.0	0.	98.	-24.	0.0
12510	-999.0	999.0	0.0	0.	102.	-16.	0.0
12511	-999.0	999.0	170.0	0.	103.	20.	0.0
12512	-999.0	999.0	178.6	0.	102.	56.	0.0
12513	-999.0	999.0	33.3	0.	105.	81.	47.6
12514	-999.0	999.0	0.0	0.	104.	101.	70.2
12515	-999.0	999.0	31.0	0.	106.	117.	57.4
12516	-999.0	999.0	113.2	0.	105.	125.	0.0
12517	-999.0	999.0	200.0	0.	105.	129.	0.0
12518	-999.0	999.0	160.0	0.	97.	125.	0.0
12519	-999.0	999.0	0.0	0.	100.	122.	0.0
12520	-999.0	999.0	0.0	0.	101.	115.	0.0
12521	-999.0	999.0	0.0	0.	98.	105.	0.0
12522	-999.0	999.0	0.0	0.	101.	102.	0.0
12523	-999.0	999.0	0.0	0.	99.	99.	0.0
12524	-999.0	999.0	0.0	0.	98.	95.	0.0
DAILY SUMMARY (JAN 25)							
MN	-999.0	999.0	0.0	0.	94.	-25.	0.0
MX	-999.0	999.0	200.0	0.	106.	129.	70.2
SM	-23976.0	23976.0	886.1	0.	2396.	1436.	175.3
AV	-999.0	999.0	36.9	0.	100.	60.	7.3
MONTHLY SUMMARY (JAN)							
MN	-999.0	999.0	0.0	0.	94.	-25.	0.0
MX	-999.0	999.0	200.0	0.	106.	129.	70.2
SM	-23976.0	23976.0	886.1	0.	2396.	1436.	175.3
AV	-999.0	999.0	36.9	0.	100.	60.	7.3

SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	SUNSP-1	
HTG SET POINT F	CLG SET POINT F	CONVEC AIRFLOW CFM	COM WIN CONDUCTN BTU/HR	COM WALL ABSD SOL BTU/HR	COM WALL CONDUCTN BTU/HR	SUNSPACE VENT FLW CFM	
----(17)	----(18)	----(62)	----(58)	----(59)	----(60)	----(63)	
7 6 1	-999.0	999.0	0.0	0.	84.	137.	0.0
7 6 2	-999.0	999.0	0.0	0.	84.	134.	0.0
7 6 3	-999.0	999.0	0.0	0.	83.	129.	0.0
7 6 4	-999.0	999.0	0.0	0.	93.	129.	0.0
7 6 5	-999.0	999.0	0.0	0.	84.	117.	0.0
7 6 6	-999.0	999.0	0.0	0.	84.	109.	0.0
7 6 7	-999.0	999.0	0.0	0.	85.	104.	0.0
7 6 8	-999.0	999.0	0.0	0.	96.	113.	0.0
7 6 9	-999.0	999.0	0.0	0.	101.	126.	0.0
7 6 10	-999.0	999.0	0.0	0.	98.	131.	357.0
7 6 11	-999.0	999.0	0.0	0.	98.	134.	404.6
7 6 12	-999.0	999.0	0.0	0.	98.	141.	404.6
7 6 13	-999.0	999.0	0.0	0.	103.	150.	428.4
7 6 14	-999.0	999.0	0.0	0.	101.	154.	476.0
7 6 15	-999.0	999.0	0.0	0.	104.	159.	428.4
7 6 16	-999.0	999.0	0.0	0.	103.	160.	476.0
7 6 17	-999.0	999.0	0.0	0.	102.	160.	476.0
7 6 18	-999.0	999.0	0.0	0.	102.	160.	476.0
7 6 19	-999.0	999.0	0.0	0.	103.	160.	357.0
7 6 20	-999.0	999.0	0.0	0.	100.	159.	142.8
7 6 21	-999.0	999.0	0.0	0.	98.	157.	23.8
7 6 22	-999.0	999.0	0.0	0.	98.	155.	0.0
7 6 23	-999.0	999.0	0.0	0.	101.	152.	0.0
7 6 24	-999.0	999.0	0.0	0.	98.	149.	0.0
DAILY SUMMARY (JUL 6)							
MN	-999.0	999.0	0.0	0.	83.	104.	0.0
MX	-999.0	999.0	0.0	0.	104.	160.	476.0
SM	-23976.0	23976.0	0.0	0.	2297.	3377.	4450.6
AV	-999.0	999.0	0.0	0.	96.	141.	185.4
MONTHLY SUMMARY (JUL)							
MN	-999.0	999.0	0.0	0.	83.	104.	0.0
MX	-999.0	999.0	0.0	0.	104.	160.	476.0
SM	-23976.0	23976.0	0.0	0.	2297.	3377.	4450.6
AV	-999.0	999.0	0.0	0.	96.	141.	185.4
YEARLY SUMMARY							
MN	-999.0	999.0	0.0	0.	83.	-25.	0.0
MX	-999.0	999.0	200.0	0.	106.	160.	476.0
SM	-47952.0	47952.0	886.1	0.	4693.	4813.	4625.9
AV	-999.0	999.0	18.5	0.	98.	100.	96.4

SYS-REP-2 = HOURLY-REPORT

MMDDHH	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1
	CLG COIL AIR TEMP F	ENTERING AIR TEMP F	TOT HTG COIL PWR BTU/HR	TOT CLG COIL PWR BTU/HR	TOTAL ELEC-PWR KW	TOT FAN ELECTRIC KW	SUPPLY ELECTRIC KW	HEATING GAS BTU/HR	COOLING ELECTRIC KW
	----	(2) ---- (3)	---- (5)	---- (6)	---- (32)	---- (33)	---- (49)	---- (45)	---- (47)
125 1	0.0	61.4	0.	0.	0.350	0.000	0.000	100.	0.050
125 2	0.0	57.8	0.	0.	0.350	0.000	0.000	100.	0.050
125 3	0.0	55.6	-1504.	0.	0.353	0.003	0.003	3568.	0.050
125 4	0.0	55.6	-2075.	0.	0.354	0.004	0.004	4403.	0.050
125 5	0.0	55.6	-2518.	0.	0.355	0.005	0.005	5051.	0.050
125 6	0.0	55.6	-2510.	0.	0.565	0.004	0.004	5039.	0.050
125 7	0.0	55.6	-2155.	0.	0.715	0.004	0.004	4521.	0.050
125 8	0.0	55.6	0.	0.	1.372	0.000	0.000	100.	0.050
125 9	0.0	55.6	-14511.	0.	0.857	0.026	0.026	22121.	0.050
12510	0.0	70.5	-7243.	0.	0.544	0.013	0.013	11881.	0.050
12511	0.0	70.6	-1045.	0.	0.549	0.010	0.002	2895.	0.050
12512	0.0	70.6	0.	0.	0.669	0.009	0.000	100.	0.050
12513	0.0	74.6	0.	0.	0.508	0.004	0.000	100.	0.050
12514	0.0	74.4	0.	0.	0.446	0.003	0.000	100.	0.050
12515	0.0	74.6	0.	0.	0.448	0.004	0.000	100.	0.050
12516	0.0	74.4	0.	0.	0.452	0.006	0.000	100.	0.050
12517	0.0	74.4	0.	0.	0.641	0.010	0.000	100.	0.050
12518	0.0	73.2	0.	0.	0.697	0.008	0.000	100.	0.050
12519	0.0	70.6	-3029.	0.	0.746	0.005	0.005	5797.	0.050
12520	0.0	70.6	-3763.	0.	1.168	0.007	0.007	6864.	0.050
12521	0.0	70.6	-4279.	0.	1.169	0.008	0.008	7613.	0.050
12522	0.0	70.6	-5039.	0.	1.170	0.009	0.009	8712.	0.050
12523	0.0	70.6	0.	0.	1.161	0.000	0.000	100.	0.050
12524	0.0	64.8	0.	0.	1.161	0.000	0.000	100.	0.050
DAILY SUMMARY (JAN 25)									
MN	0.0	55.6	-14511.	0.	0.350	0.000	0.000	100.	0.050
MX	0.0	74.6	0.	0.	1.372	0.026	0.026	22121.	0.050
SM	0.0	1583.7	-49671.	0.	16.801	0.140	0.089	89666.	1.200
AV	0.0	66.0	-2070.	0.	0.700	0.006	0.004	3736.	0.050
MONTHLY SUMMARY (JAN)									
MN	0.0	55.6	-14511.	0.	0.350	0.000	0.000	100.	0.050
MX	0.0	74.6	0.	0.	1.372	0.026	0.026	22121.	0.050
SM	0.0	1583.7	-49671.	0.	16.801	0.140	0.089	89666.	1.200
AV	0.0	66.0	-2070.	0.	0.700	0.006	0.004	3736.	0.050

SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	
CLG COIL ENTERING AIR TEMP AIR TEMP F F		TOT HTG COIL PWR BTU/HR	TOT CLG COIL PWR BTU/HR	TOTAL ELEC-PWR KW	TOT FAN ELECTRIC KW	SUPPLY ELECTRIC KW	HEATING GAS BTU/HR	COOLING ELECTRIC KW	
----	----	----	----	----	----	----	----	----	
(2)	(3)	(5)	(6)	(32)	(33)	(49)	(45)	(47)	
7 6 1	0.0	76.5	0.	0.	0.300	0.000	0.000	100.	0.000
7 6 2	0.0	75.6	0.	0.	0.300	0.000	0.000	100.	0.000
7 6 3	0.0	74.7	0.	0.	0.300	0.000	0.000	100.	0.000
7 6 4	0.0	73.7	0.	0.	0.300	0.000	0.000	100.	0.000
7 6 5	0.0	72.6	0.	0.	0.511	0.000	0.000	100.	0.000
7 6 6	0.0	72.6	0.	0.	0.661	0.000	0.000	100.	0.000
7 6 7	0.0	73.9	0.	0.	1.322	0.000	0.000	100.	0.000
7 6 8	0.0	76.8	0.	0.	0.781	0.000	0.000	100.	0.000
7 6 9	0.0	75.4	0.	0.	0.481	0.000	0.000	100.	0.000
7 610	52.1	75.4	0.	2170.	1.036	0.024	0.009	100.	0.517
7 611	50.1	78.2	0.	4759.	1.425	0.034	0.018	100.	0.774
7 612	50.3	78.2	0.	6095.	1.415	0.039	0.023	100.	0.910
7 613	50.5	78.3	0.	7018.	1.459	0.043	0.026	100.	1.008
7 614	50.9	78.3	0.	7468.	1.510	0.048	0.029	100.	1.052
7 615	50.2	78.3	0.	8411.	1.611	0.049	0.032	100.	1.155
7 616	50.4	78.3	0.	8524.	1.807	0.052	0.033	100.	1.166
7 617	50.4	78.3	0.	8446.	1.858	0.051	0.032	100.	1.158
7 618	50.8	78.3	0.	8226.	1.897	0.051	0.032	100.	1.136
7 619	50.5	78.3	0.	8115.	2.266	0.046	0.032	100.	1.094
7 620	50.1	78.3	0.	6562.	2.069	0.030	0.025	100.	0.921
7 621	0.0	78.3	0.	0.	1.113	0.001	0.000	100.	0.000
7 622	50.9	75.4	0.	2869.	1.686	0.013	0.012	100.	0.561
7 623	50.2	78.2	0.	2635.	1.663	0.011	0.010	100.	0.540
7 624	0.0	78.2	0.	0.	0.302	0.001	0.000	100.	0.000
DAILY SUMMARY (JUL 6)									
MN	0.0	72.6	0.	0.	0.300	0.000	0.000	100.	0.000
MX	52.1	78.3	0.	8524.	2.266	0.052	0.033	100.	1.166
SM	657.5	1840.2	0.	81298.	28.074	0.493	0.312	2400.	11.991
AV	27.4	76.7	0.	3387.	1.170	0.021	0.013	100.	0.500
MONTHLY SUMMARY (JUL)									
MN	0.0	72.6	0.	0.	0.300	0.000	0.000	100.	0.000
MX	52.1	78.3	0.	8524.	2.266	0.052	0.033	100.	1.166
SM	657.5	1840.2	0.	81298.	28.074	0.493	0.312	2400.	11.991
AV	27.4	76.7	0.	3387.	1.170	0.021	0.013	100.	0.500
YEARLY SUMMARY									
MN	0.0	55.6	-14511.	0.	0.300	0.000	0.000	100.	0.000
MX	52.1	78.3	0.	8524.	2.266	0.052	0.033	22121.	1.166
SM	657.5	3424.0	-49671.	81298.	44.876	0.633	0.401	92066.	13.191
AV	13.7	71.3	-1035.	1694.	0.935	0.013	0.008	1918.	0.275

SYS-REP-2

= HOURLY-REPORT

PAGE 1 - 2

MMDDHH	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1
	LATENT COOLING BTU/HR	PLR COOLING FRAC.OR MULT.	PLR HEATING FRAC.OR MULT.	COOL-CAP F(WB, DB) FRAC.OR MULT.	COOL-SH F(WB, DB) FRAC.OR MULT.	EIR F(WB, DB) FRAC.OR MULT.	EIR F(PLR) FRAC.OR MULT.	EIR BTU/BTU	COOLING CAPACITY BTU/HR	SENSIBLE CAPACITY BTU/HR
	---- (48)	---- (61)	---- (62)	---- (63)	---- (64)	---- (66)	---- (67)	---- (68)	---- (70)	---- (71)
125 1	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	11024.
125 2	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	10093.
125 3	0.	0.000	0.030	0.987	1.369	0.000	0.000	0.0000	23690.	10044.
125 4	0.	0.000	0.041	0.987	1.369	0.000	0.000	0.0000	23690.	10043.
125 5	0.	0.000	0.050	0.987	1.369	0.000	0.000	0.0000	23690.	10043.
125 6	0.	0.000	0.050	0.987	1.369	0.000	0.000	0.0000	23690.	10043.
125 7	0.	0.000	0.043	0.987	1.369	0.000	0.000	0.0000	23690.	10044.
125 8	0.	0.000	0.009	0.987	1.369	0.000	0.000	0.0000	23690.	10044.
125 9	0.	0.000	0.290	0.987	1.369	0.000	0.000	0.0000	23690.	10045.
12510	0.	0.000	0.145	0.987	1.369	0.000	0.000	0.0000	23690.	16427.
12511	0.	0.000	0.021	0.987	1.369	0.000	0.000	0.0000	23690.	16469.
12512	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	16505.
12513	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18788.
12514	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18699.
12515	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18790.
12516	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18720.
12517	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18683.
12518	0.	0.000	0.005	0.987	1.369	0.000	0.000	0.0000	23690.	18020.
12519	0.	0.000	0.061	0.987	1.369	0.000	0.000	0.0000	23690.	16508.
12520	0.	0.000	0.075	0.987	1.369	0.000	0.000	0.0000	23690.	16492.
12521	0.	0.000	0.086	0.987	1.369	0.000	0.000	0.0000	23690.	16488.
12522	0.	0.000	0.101	0.987	1.369	0.000	0.000	0.0000	23690.	16486.
12523	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	16481.
12524	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	13036.
DAILY SUMMARY (JAN 25)										
MN	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	10043.
MX	0.	0.000	0.290	0.987	1.369	0.000	0.000	0.0000	23690.	18790.
SM	0.	0.000	1.008	23.690	32.852	0.000	0.000	0.0000	568563.	348016.
AV	0.	0.000	0.042	0.987	1.369	0.000	0.000	0.0000	23690.	14501.
MONTHLY SUMMARY (JAN)										
MN	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	10043.
MX	0.	0.000	0.290	0.987	1.369	0.000	0.000	0.0000	23690.	18790.
SM	0.	0.000	1.008	23.690	32.852	0.000	0.000	0.0000	568563.	348016.
AV	0.	0.000	0.042	0.987	1.369	0.000	0.000	0.0000	23690.	14501.

	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1	SYS-1
	LATENT COOLING BTU/HR	PLR COOLING FRAC.OR MULT.	PLR HEATING FRAC.OR MULT.	COOL-CAP F(WB, DB) FRAC.OR MULT.	COOL-SH F(WB, DB) FRAC.OR MULT.	EIR F(WB, DB) FRAC.OR MULT.	EIR F(PLR) FRAC.OR MULT.	EIR BTU/BTU	COOLING CAPACITY BTU/HR	SENSIBLE CAPACITY BTU/HR
	----(48)	----(61)	----(62)	----(63)	----(64)	----(66)	----(67)	----(68)	----(70)	----(71)
7 6 1	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	19929.
7 6 2	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	19415.
7 6 3	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18861.
7 6 4	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18288.
7 6 5	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	17653.
7 6 6	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	17650.
7 6 7	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	18442.
7 6 8	0.	0.000	0.000	0.987	1.369	0.000	0.000	0.0000	23690.	20088.
7 6 9	0.	0.000	0.000	0.993	1.316	0.000	0.000	0.0000	23836.	18419.
7 610	313.	0.093	0.000	0.976	1.263	0.857	0.206	0.0754	23416.	17574.
7 611	557.	0.204	0.000	0.973	1.380	0.873	0.303	0.1131	23351.	21055.
7 612	734.	0.261	0.000	0.972	1.369	0.881	0.354	0.1331	23321.	20910.
7 613	968.	0.300	0.000	0.973	1.363	0.889	0.388	0.1473	23361.	20821.
7 614	757.	0.322	0.000	0.968	1.341	0.891	0.406	0.1546	23222.	20476.
7 615	961.	0.363	0.000	0.966	1.369	0.900	0.442	0.1700	23189.	20952.
7 616	959.	0.368	0.000	0.966	1.361	0.900	0.447	0.1716	23193.	20829.
7 617	1102.	0.363	0.000	0.970	1.360	0.899	0.442	0.1698	23278.	20819.
7 618	913.	0.354	0.000	0.967	1.344	0.899	0.435	0.1671	23207.	20546.
7 619	778.	0.348	0.000	0.971	1.355	0.873	0.430	0.1603	23294.	20730.
7 620	754.	0.280	0.000	0.978	1.377	0.849	0.370	0.1339	23473.	21075.
7 621	0.	0.000	0.000	0.984	1.372	0.000	0.000	0.0000	23615.	20979.
7 622	366.	0.121	0.000	0.986	1.313	0.820	0.231	0.0809	23654.	18378.
7 623	337.	0.111	0.000	0.988	1.371	0.819	0.222	0.0778	23711.	20917.
7 624	0.	0.009	0.000	0.989	1.356	0.000	0.000	0.0000	23746.	20678.
DAILY SUMMARY (JUL 6)										
MN	0.	0.000	0.000	0.966	1.263	0.000	0.000	0.0000	23189.	17574.
MX	1102.	0.368	0.000	0.993	1.380	0.900	0.447	0.1716	23836.	21075.
SM	9499.	3.497	0.000	23.516	32.560	11.349	4.677	1.7547	564387.	475483.
AV	396.	0.146	0.000	0.980	1.357	0.473	0.195	0.0731	23516.	19812.
MONTHLY SUMMARY (JUL)										
MN	0.	0.000	0.000	0.966	1.263	0.000	0.000	0.0000	23189.	17574.
MX	1102.	0.368	0.000	0.993	1.380	0.900	0.447	0.1716	23836.	21075.
SM	9499.	3.497	0.000	23.516	32.560	11.349	4.677	1.7547	564387.	475483.
AV	396.	0.146	0.000	0.980	1.357	0.473	0.195	0.0731	23516.	19812.
YEARLY SUMMARY										
MN	0.	0.000	0.000	0.966	1.263	0.000	0.000	0.0000	23189.	10043.
MX	1102.	0.368	0.290	0.993	1.380	0.900	0.447	0.1716	23836.	21075.
SM	9499.	3.497	1.008	47.206	65.412	11.349	4.677	1.7547	1132950.	823499.
AV	198.	0.073	0.021	0.983	1.363	0.236	0.097	0.0366	23603.	17156.

SYS-REP-2 = HOURLY-REPORT

PAGE 1 - 3

MMDDHH	PLANT-1	PLANT-1	PLANT-1
	COOLING LOAD BTU/HR	HEATING LOAD BTU/HR	ELECTRIC LOAD KW
	---- (1)	---- (2)	---- (3)
125 1	0.	0.	0.350
125 2	0.	0.	0.350
125 3	0.	0.	0.353
125 4	0.	0.	0.354
125 5	0.	0.	0.355
125 6	0.	0.	0.565
125 7	0.	0.	0.715
125 8	0.	0.	1.372
125 9	0.	0.	0.857
12510	0.	0.	0.544
12511	0.	0.	0.549
12512	0.	0.	0.669
12513	0.	0.	0.508
12514	0.	0.	0.446
12515	0.	0.	0.448
12516	0.	0.	0.452
12517	0.	0.	0.641
12518	0.	0.	0.697
12519	0.	0.	0.746
12520	0.	0.	1.168
12521	0.	0.	1.169
12522	0.	0.	1.170
12523	0.	0.	1.161
12524	0.	0.	1.161
DAILY SUMMARY (JAN 25)			
MN	0.	0.	0.350
MX	0.	0.	1.372
SM	0.	0.	16.801
AV	0.	0.	0.700
MONTHLY SUMMARY (JAN)			
MN	0.	0.	0.350
MX	0.	0.	1.372
SM	0.	0.	16.801
AV	0.	0.	0.700

SYS-REP-2 = HOURLY-REPORT

PAGE 2 - 3

	PLANT-1	PLANT-1	PLANT-1
	COOLING LOAD BTU/HR	HEATING LOAD BTU/HR	ELECTRIC LOAD KW
	----(1)	----(2)	----(3)
7 6 1	0.	0.	0.300
7 6 2	0.	0.	0.300
7 6 3	0.	0.	0.300
7 6 4	0.	0.	0.300
7 6 5	0.	0.	0.511
7 6 6	0.	0.	0.661
7 6 7	0.	0.	1.322
7 6 8	0.	0.	0.781
7 6 9	0.	0.	0.481
7 610	0.	0.	1.036
7 611	0.	0.	1.425
7 612	0.	0.	1.415
7 613	0.	0.	1.459
7 614	0.	0.	1.510
7 615	0.	0.	1.611
7 616	0.	0.	1.807
7 617	0.	0.	1.858
7 618	0.	0.	1.897
7 619	0.	0.	2.266
7 620	0.	0.	2.069
7 621	0.	0.	1.113
7 622	0.	0.	1.686
7 623	0.	0.	1.663
7 624	0.	0.	0.302
DAILY SUMMARY (JUL 6)			
MN	0.	0.	0.300
MX	0.	0.	2.266
SM	0.	0.	28.074
AV	0.	0.	1.170
MONTHLY SUMMARY (JUL)			
MN	0.	0.	0.300
MX	0.	0.	2.266
SM	0.	0.	28.074
AV	0.	0.	1.170
YEARLY SUMMARY			
MN	0.	0.	0.300
MX	0.	0.	2.266
SM	0.	0.	44.876
AV	0.	0.	0.935

Parameterized Building

Input before macro processing

INPUT FOR PARAMETRIZED BUILDING BEFORE MACRO PROCESSING

```

$----- file : samp7.inp ----- DOE2.1E sample run 7 -----
$----- Parametrized building using Input Macros

##write

input LOADS ..
##includesilent samp7loc.inc

run-period JAN 1 1981 THRU DEC 31 1981 ..
loads-report verification=(LV-B,LV-D,LV-F) ..

LOCATION[chicago] azimuth = 0 ..

WA-1-2 = layers material = (WD01,PW03,IN02,GP01) ..
RB-1-1 = layers material = (RG01,BR01,IN22,WD01) i-f-r = .76 ..
WALL-typl = construction layers = WA-1-2 ..
ROOF-typl = construction layers = RB-1-1 ..
IWF-typl = construction u = 0.5 ..
FLOOR-typl = construction u = 0.05 ..
GT-typl = glass-type p=1 s-c=.60 ..

$-----SPACE CONDITIONS-----$

OCC-SCH= schedule THRU DEC 31 (WD) (1,7) (0) (8,17) (1) (18,24) (0)
              (WEH) (1,24) (0) ..
CORE-LITE-SCH= schedule THRU DEC 31 (WD) (1,6) (0) (7,18) (1) (19,24) (0)
              (WEH) (1,24) (0) ..
INF-SCH= schedule THRU DEC 31 (WD) (1,7) (0) (8,17) (1) (18,24) (0)
              (WEH) (1,24) (0) ..
PERIM-LITE-SCH= schedule THRU DEC 31 (WD) (1,6) (0) (7,18) (.8) (19,24) (0)
              (WEH) (1,24) (0) ..

CORE= space-conditions t = (75)
      people-schedule = OCC-SCH people-heat-gain = 450
      area/person = 100
      lighting-schedule = CORE-LITE-SCH
      lighting-w/sqft = 2
      light-to-space = .75 light-to-return = .25
      inf-method = AIR-CHANGE inf-schedule = INF-SCH
      air-changes/hr = 0.8
      z-type = CONDITIONED ..

PERIM= space-conditions like CORE
      area/person = 90
      lighting-schedule = PERIM-LITE-SCH
      air-changes/hr = 0.6 ..

$----- set some macros for glass type and constructions.

##set1 GLASS_TYPE GT-typl,
##set1 EW_CONS WALL-typl
##set1 IW_CONS IWF-typl
##set1 ROOF_CONS ROOF-typl
##set1 UGF_CONS FLOOR-typl

##include samp7lib.inc

##$---- now generate each floor.
##$
##$ # W D H perim_D window space conditions for
##$ frac core north south east west
##$ -----

```

```
$
$----- ground floor
FLOOR( g, 100, 50, 10, 15 , .20, CORE, PERIM, PERIM, PERIM, PERIM )
$----- 1st floor
FLOOR( 1, 100, 50, 10, 15 , .30, CORE, PERIM, PERIM, PERIM, PERIM )
$----- top floor
FLOOR( t, 100, 50, 10, 15 , .30, CORE, PERIM, PERIM, PERIM, PERIM )

end ..
compute LOADS ..
stop ..
```

Parameterized Building

Include file for building location

```
INCLUDE FILE FOR BUILDING LOCATION FOR PARAMETRIZED BUILDING
=====
```

```
##$ file : samp7loc.inc
##$
##$   This file contains the LOCATION(Name) macro, that produces the
##$   'building-location' command. Here 'Name' is the name of the
##$   city.
##$   An example of usage is :
##$           LOCATION[chicago] azimuth = 0 ..
##$
##def LOCATION(Name)
##nolist
  building-location
##if   #[Name eqs boston]
      lat = 42.37 lon = 71.07 alt = 50 t-z = 5
##elseif #[Name eqs newyork]
      lat = 40.72 lon = 74.00 alt = 50 t-z = 5
##elseif #[Name eqs philadelphia]
      lat = 39.95 lon = 75.17 alt = 50 t-z = 5
##elseif #[Name eqs detroit]
      lat = 42.33 lon = 83.00 alt = 600 t-z = 5
##elseif #[Name eqs chicago]
      lat = 41.88 lon = 87.63 alt = 600 t-z = 6
##elseif #[Name eqs sanfrancisco]
      lat = 37.78 lon = 122.42 alt = 50 t-z = 8
##elseif #[Name eqs losangeles]
      lat = 34.07 lon = 118.25 alt = 50 t-z = 8
##elseif #[Name eqs sandiego]
      lat = 32.72 lon = 117.15 alt = 50 t-z = 8
##elseif #[Name eqs phoenix]
      lat = 33.45 lon = 112.07 alt = 1000 t-z = 7
##else
Abort -- building location undefined in file : samp7loc.inc
##endif

##$ defaults for all locations:
      hol = YES daylight-savings = YES
##list
##enddef
```

Include file for floor and space macros

```
INCLUDE FILE FOR FLOOR AND PERIMETER SPACE MACROS FOR PARAMETRIZED BUILDING
=====
```

```
##$ file : samp7lib.inc
##$
##$   This file contains the FLOOR[...] and PERIM-SPACE[...] macros.
##$   The FLOOR[...] macro is used for specifying one floor of the
##$   building with given dimensions. It uses the PERIM-SPACE[...]
##$   macro to create the perimeter spaces.
##$
##$-----
##$ The following macro defines one floor of the building.
##$   Its arguments are :
##$       floor_NUM : g for ground floor; 1 for first floor ;
##$                 2 for second floor; etc. ; t for top floor .
##$                 s for single floor building.
##$       floor_W   : floor width.
##$       floor_D   : floor depth.
##$       floor_H   : floor height.
##$       floor_perim_D : depth of the perimeter spaces.
##$       floor_winFrac : window to wall ratio for exterior surfaces.
##$       cond_C    : u-name of space conditions for the interior space.
```



```

interior-wall area = AREA-IW[]
              next-to = #[ SP-NAMO[] // "_N" ]
              construction = IW_CONS[] ..
interior-wall area = AREA-IW[]
              next-to = #[ SP-NAMO[] // "_S" ]
              construction = IW_CONS[] ..

##endif

#[SP-NAMO[] // "_W" ] = PERIM-SPACE(
    _W, 0, floor_D, Z-SP[], 90
    , AREA-SP[], floor_D, floor_winFrac
    , cond_W )

##if #[AREA-IW[] GT 0 ]
interior-wall area = AREA-IW[]
              next-to = #[ SP-NAMO[] // "_N" ]
              construction = IW_CONS[] ..
interior-wall area = AREA-IW[]
              next-to = #[ SP-NAMO[] // "_S" ]
              construction = IW_CONS[] ..

##endif

$----- Core space -----$
##set1 TMP1 #[ 2 * floor_perim_D ]
##set1 AREA-SP #[ #[floor_W - TMP1[]] * #[floor_D - TMP1[]] ]
##if #[ AREA-SP[] GT 0 ]
    #[SP-NAMO[] // "_C" ] = space x = floor_perim_D y = floor_perim_D
                                z = Z-SP[] azimuth = 0 area = AREA-SP[]
                                volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
                                space-conditions=cond_C ..

interior-wall area = #[ #[floor_W - TMP1[]] * floor_H ]
              next-to = #[ SP-NAMO[] // "_S" ]
              construction = IW_CONS[] ..
interior-wall area = #[ #[floor_W - TMP1[]] * floor_H ]
              next-to = #[ SP-NAMO[] // "_N" ]
              construction = IW_CONS[] ..
interior-wall area = #[ #[floor_D - TMP1[]] * floor_H ]
              next-to = #[ SP-NAMO[] // "_E" ]
              construction = IW_CONS[] ..
interior-wall area = #[ #[floor_D - TMP1[]] * floor_H ]
              next-to = #[ SP-NAMO[] // "_W" ]
              construction = IW_CONS[] ..

##if #[ floor_NUM EQS "g" ]
underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
##else
interior-wall area = AREA-SP[]
              next-to = #[ #[SP-" // FLOOR-PREV[] ] // "_C" ]
              construction = IW_CONS[] ..

##endif

##if #[ floor_NUM EQS "t" ]
roof x = floor_perim_D y = floor_perim_D
     h = #[floor_D - #[ 2 * floor_perim_D ] ]
     w = #[floor_W - #[ 2 * floor_perim_D ] ]
     construction = ROOF_CONS[] ..

##endif

##endif
##$
##$ update the z-coordinate.
##set1 Z-SP #[ Z-SP[] + FLOOR-HEIGHT[] ]
##set1 FLOOR-PREV floor_NUM
##$
##endif

##$
##$-----$

```

```

##$ The following macro defines one perimeter space.
##$ Its arguments are :
##$   sname : part of the name of space. ( N, S, E, W )
##$   xx,yy,zz : x, y, z location of the space.
##$   sazim : space azimuth.
##$   sarea : space area.
##$   swidth : space width.
##$   swinFrac : window to wall ratio of exterior surfaces.
##$   space_cond : u-name of space conditions.
##$ This macro uses the FLOOR-NUM[], FLOOR-HEIGHT[] and WINDOW_HEIGHT[]
##$ that are set by the FLOOR macro.
##$ It also uses :
##$   GLASS_TYPE macro to set the glass-type of windows.
##$   EW_CONS macro to set the exterior-wall construction.
##$   IW_CONS macro to set the interior-wall construction.
##$   ROOF_CONS macro to set the roof construction.
##$   UGF_CONS macro to set the underground-wall,floor construction.
##$-----
##$
##$
##def PERIM-SPACE[sname,xx,yy,zz,sazim,sarea,swidth,swinFrac,space_cond]

    space      x = xx y = yy z = zz azimuth = sazim area = sarea
              volume = #[ sarea * FLOOR-HEIGHT[] ]
              space-conditions = space_cond ..
    exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
              w = swidth construction = EW_CONS[] ..
##set1 TMP1 #[ #[swinFrac * #[FLOOR-HEIGHT[] * swidth]] / WINDOW_HEIGHT[] ]
##if #[ TMP1[] GT 0 ]
    window     x = #[ #[swidth - TMP1[]] / 2 ]
              y = 3.0
              w = TMP1[] h = WINDOW_HEIGHT[]
              glass-type = GLASS_TYPE[] ..
##endif

##if #[ #[FLOOR-NUM[] EQS "g"] or #[FLOOR-NUM[] EQS "s"] ]
    underground-floor area = sarea construction = UGF_CONS[] ..
##else
    interior-wall area = sarea construction = IW_CONS[]
              next-to = #[ #["SP_" // FLOOR-PREV[]] // sname ] ..
##endif

##if #[ #[FLOOR-NUM[] EQS "t"] or #[FLOOR-NUM[] EQS "s"] ]
    roof x = 0 y = 0
        h = FLOOR-PERIM-D[]
        w = #[ swidth - FLOOR-PERIM-D[] ]
        construction = ROOF_CONS[] ..
##endif
##$
##endif

```


Parameterized Building

Input showing macro evaluation steps

INPUT FOR PARAMETRIZED BUILDING SHOWING INTERMEDIATE STEPS OF MACRO EVALUATION

```
* 1 * $---- file : samp7.inp ----- DOE2.1E sample run 7 -----  
* 2 * $---- Parametrized building using Input Macros  
* 3 *  
# 4 # ##write  
* 5 *  
* 6 * input LOADS ..
```

LDL PROCESSOR INPUT DATA

Thu Nov 11 11:14:58 1993LDL RUN 1

```

# 7 # ##includesilent samp7loc.inc
file : INPUT2.TMP
# 8 #
# 9 # run-period JAN 1 1981 THRU DEC 31 1981 ..
# 10 # loads-report verification=(LV-B,LV-D,LV-F) ..
# 11 #
# 12 # LOCATION[chicago] azimuth = 0 ..
.10 36 # ##list
# 13 #
# 14 # WA-1-2 = layers material = (WD01,PW03,IN02,GP01) ..
# 15 # RB-1-1 = layers material = (RG01,BR01,IN22,WD01) i-f-r = .76 ..
# 16 # WALL-typ1 = construction layers = WA-1-2 ..
# 17 # ROOF-typ1 = construction layers = RB-1-1 ..
# 18 # IWF-typ1 = construction u = 0.5 ..
# 19 # FLOOR-typ1 = construction u = 0.05 ..
# 20 # GT-typ1 = glass-type p=1 s-c=.60 ..
# 21 #
# 22 # $-----SPACE CONDITIONS-----$
# 23 #
# 24 # OCC-SCH= schedule THRU DEC 31 (WD) (1,7)(0) (8,17)(1) (18,24)(0)
# 25 # (WEH) (1,24)(0) ..
# 26 # CORE-LITE-SCH= schedule THRU DEC 31 (WD) (1,6)(0) (7,18)(1) (19,24)(0)
# 27 # (WEH) (1,24)(0) ..
# 28 # INF-SCH= schedule THRU DEC 31 (WD) (1,7)(0) (8,17)(1) (18,24)(0)
# 29 # (WEH) (1,24)(0) ..
# 30 # PERIM-LITE-SCH= schedule THRU DEC 31 (WD) (1,6)(0) (7,18)(.8) (19,24)(0)
# 31 # (WEH) (1,24)(0) ..
# 32 #
# 33 # CORE= space-conditions t = (75)
# 34 # people-schedule = OCC-SCH people-heat-gain = 450
# 35 # area/person = 100
# 36 # lighting-schedule = CORE-LITE-SCH
# 37 # lighting-w/sqft = 2
# 38 # light-to-space = .75 light-to-return = .25
# 39 # inf-method = AIR-CHANGE inf-schedule = INF-SCH
# 40 # air-changes/hr = 0.8
# 41 # z-type = CONDITIONED ..
# 42 # PERIM= space-conditions like CORE
# 43 # area/person = 90
# 44 # lighting-schedule = PERIM-LITE-SCH
# 45 # air-changes/hr = 0.6 ..
# 46 #
# 47 # $----- set some macros for glass type and constructions.
# 48 #
# 49 # ##set1 GLASS_TYPE GT-typ1
# 50 # ##set1 EW_CONS WALL-typ1
# 51 # ##set1 IW_CONS IWF-typ1
# 52 # ##set1 ROOF_CONS ROOF-typ1
# 53 # ##set1 UGF_CONS FLOOR-typ1
# 54 #
# 55 # ##include samp7lib.inc
1 # 1 # ##$ file : samp7lib.inc
1 # 2 # ##$
1 # 3 # ##$ This file contains the FLOOR[...] and PERIM-SPACE[...] macros.
1 # 4 # ##$ The FLOOR[...] macro is used for specifying one floor of the
1 # 5 # ##$ building with given dimensions. It uses the PERIM-SPACE[...]
1 # 6 # ##$ macro to create the perimeter spaces.

```

```

1 # 7 # $$$
1 # 8 # $$$-----
1 # 9 # $$$ The following macro defines one floor of the building.
1 # 10 # $$$   Its arguments are :
1 # 11 # $$$       floor_NUM : g for ground floor; 1 for first floor ;
1 # 12 # $$$       2 for second floor; etc. ; t for top floor .
1 # 13 # $$$       s for single floor building.
1 # 14 # $$$       floor_W   : floor width.
1 # 15 # $$$       floor_D   : floor depth.
1 # 16 # $$$       floor_H   : floor height.
1 # 17 # $$$       floor_perim_D : depth of the perimeter spaces.
1 # 18 # $$$       floor_winFrac : window to wall ratio for exterior surfaces.
1 # 19 # $$$       cond_C    : u-name of space conditions for the interior space.
1 # 20 # $$$       cond_N    : u-name of space conditions for the north space.
1 # 21 # $$$ In addition, the following macros must be set to define glass type,
1 # 22 # $$$ and wall constructions:
1 # 23 # $$$       GLASS_TYPE glass type of windows.
1 # 24 # $$$       EW_CONS   exterior-wall construction.
1 # 25 # $$$       IW_CONS   interior-wall construction.
1 # 26 # $$$       ROOF_CONS  roof construction.
1 # 27 # $$$       UGF_CONS   underground-wall,floor construction.
1 # 28 # $$$       WINDOW_HEIGHT window height. ( default = 3.0 )
1 # 29 # $$$-----
1 # 30 # $$$
1 # 31 # $$$def FLOOR[floor_NUM,floor_W,floor_D,floor_H,floor_perim_D,floor_winFrac
1 # 32 # $$$   ,cond_C, cond_N, cond_S, cond_E, cond_W]
1 # 33 # $$$
1 # 34 # $$$           --->| |<--- floor_perim_D
1 # 35 # $$$
1 # 36 # $$$
1 # 37 # $$$
1 # 38 # $$$
1 # 39 # $$$
1 # 40 # $$$
1 # 41 # $$$
1 # 42 # $$$
1 # 43 # $$$
1 # 44 # $$$
1 # 45 # $$$
1 # 46 # $$$
1 # 47 # $$$
1 # 48 # $$$
1 # 49 # $$$
1 # 50 # $$$
1 # 51 # $$$
1 # 52 # $$$
1 # 53 # $$$
1 # 54 # $$$
1 # 55 # $$$
1 # 56 # $$$
1 # 57 # $$$
1 # 58 # $$$
1 # 59 # $$$
1 # 60 # $$$
1 # 61 # $$$
1 # 62 # $$$
1 # 63 # $$$
1 # 64 # $$$
1 # 65 # $$$
1 # 66 # $$$
1 # 67 # $$$
1 # 68 # $$$
1 # 69 # $$$
1 # 70 # $$$
1 # 71 # $$$

```

```

1 # 56 # $$$ifndef WINDOW_HEIGHT
1 # 57 # $$$   ##set1 WINDOW_HEIGHT 3.0
1 # 58 # $$$endif
1 # 59 # $$$
1 # 60 # $$$ifndef Z-SP
1 # 61 # $$$   ##set1 Z-SP 0
1 # 62 # $$$endif
1 # 63 # $$$
1 # 64 # $$$   ##set1 FLOOR-HEIGHT floor_H
1 # 65 # $$$   ##set1 FLOOR-NUM floor_NUM
1 # 66 # $$$   ##set1 FLOOR-PERIM-D floor_perim_D
1 # 67 # $$$
1 # 68 # $$$   ##set1 SP-NAM0 [{"SP_" // floor_NUM}
1 # 69 # $$$
1 # 70 # $$$   ##set1 AREA-SP [{" floor_perim_D * [{" floor_W - floor_perim_D } ]
1 # 71 # $$$   [{"SP-NAM0[] // "_N"} = PERIM-SPACE[ "_N, floor_W, floor_D, Z-SP[],180

```

```

1 # 72 #           , AREA-SP[], floor_W, floor_winFrac
1 # 73 #           , cond_N ]
1 # 74 #
1 # 75 #   $(SP-NAM0[] // "_S") = PERIM-SPACE[ _S, 0, 0, Z-SP[], 0
1 # 76 #           , AREA-SP[], floor_W, floor_winFrac
1 # 77 #           , cond_S ]
1 # 78 #
1 # 79 #   ##set1 AREA-SP #[floor_perim_D * #[ floor_D - floor_perim_D ] ]
1 # 80 #   $(SP-NAM0[] // "_E") = PERIM-SPACE[ _E, floor_W, 0, Z-SP[], -90
1 # 81 #           , AREA-SP[], floor_D, floor_winFrac
1 # 82 #           , cond_E ]
1 # 83 #   ##set1 AREA-IW #[ 1.4142 * #[ floor_perim_D * floor_H ] ]
1 # 84 #   ##if #[AREA-IW[] GT 0 ]
1 # 85 #       interior-wall area = AREA-IW[]
1 # 86 #                   next-to = #[ SP-NAM0[] // "_N" ]
1 # 87 #                   construction = IW_CONS[] ..
1 # 88 #       interior-wall area = AREA-IW[]
1 # 89 #                   next-to = #[ SP-NAM0[] // "_S" ]
1 # 90 #                   construction = IW_CONS[] ..
1 # 91 #   ##endif
1 # 92 #
1 # 93 #   $(SP-NAM0[] // "_W") = PERIM-SPACE[ _W, 0, floor_D, Z-SP[], 90
1 # 94 #           , AREA-SP[], floor_D, floor_winFrac
1 # 95 #           , cond_W ]
1 # 96 #   ##if #[AREA-IW[] GT 0 ]
1 # 97 #       interior-wall area = AREA-IW[]
1 # 98 #                   next-to = #[ SP-NAM0[] // "_N" ]
1 # 99 #                   construction = IW_CONS[] ..
1 # 100 #      interior-wall area = AREA-IW[]
1 # 101 #                   next-to = #[ SP-NAM0[] // "_S" ]
1 # 102 #                   construction = IW_CONS[] ..
1 # 103 #   ##endif
1 # 104 #
1 # 105 # $----- Core space -----$
1 # 106 # ##set1 TMP1 #[ 2 * floor_perim_D ]
1 # 107 # ##set1 AREA-SP #[ #[floor_W - TMP1[]] * #[floor_D - TMP1[]] ]
1 # 108 # ##if #[ AREA-SP[] GT 0 ]
1 # 109 #   $(SP-NAM0[] // "_C") = space x = floor_perim_D y = floor_perim_D
1 # 110 #                           z = Z-SP[] azimuth = 0 area = AREA-SP[]
1 # 111 #                           volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
1 # 112 #                           space-conditions=cond_C ..
1 # 113 #   interior-wall area = #[ #[floor_W - TMP1[]] * floor_H ]
1 # 114 #                   next-to = #[ SP-NAM0[] // "_S" ]
1 # 115 #                   construction = IW_CONS[] ..
1 # 116 #   interior-wall area = #[ #[floor_W - TMP1[]] * floor_H ]
1 # 117 #                   next-to = #[ SP-NAM0[] // "_N" ]
1 # 118 #                   construction = IW_CONS[] ..
1 # 119 #   interior-wall area = #[ #[floor_D - TMP1[]] * floor_H ]
1 # 120 #                   next-to = #[ SP-NAM0[] // "_E" ]
1 # 121 #                   construction = IW_CONS[] ..
1 # 122 #   interior-wall area = #[ #[floor_D - TMP1[]] * floor_H ]
1 # 123 #                   next-to = #[ SP-NAM0[] // "_W" ]
1 # 124 #                   construction = IW_CONS[] ..
1 # 125 #
1 # 126 #   ##if #[ floor_NUM EQS "g" ]
1 # 127 #       underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
1 # 128 #   ##else
1 # 129 #       interior-wall area = AREA-SP[]
1 # 130 #                   next-to = #[ ["SP_" // FLOOR-PREV[]] // "_C" ]
1 # 131 #                   construction = IW_CONS[] ..
1 # 132 #   ##endif
1 # 133 #
1 # 134 #   ##if #[ floor_NUM EQS "t" ]
1 # 135 #       roof x = floor_perim_D y = floor_perim_D
1 # 136 #           h = #[floor_D - #[ 2 * floor_perim_D ] ]

```

```


1 # 137 #           w = #[floor_W - #[ 2 * floor_perim_D ] ]
1 # 138 #           construction = ROOF_CONS[] ..
1 # 139 #           #endif
1 # 140 # #endif
1 # 141 # #!$
1 # 142 # #!$ update the z-coordinate.
1 # 143 # #!set1 Z-SP #[ Z-SP[] + FLOOR-HEIGHT[] ]
1 # 144 # #!set1 FLOOR-PREV floor_NUM
1 # 145 # #!$
1 # 146 # #endif
1 * 147 *
1 # 148 # #!$
1 # 149 # #!$-----
1 # 150 # #!$ The following macro defines one perimeter space.
1 # 151 # #!$   Its arguments are :
1 # 152 # #!$       sname :   part of the name of space. ( N, S, E, W )
1 # 153 # #!$       xx,yy,zz : X, y, z location of the space.
1 # 154 # #!$       sazim :   space azimuth.
1 # 155 # #!$       sarea :   space area.
1 # 156 # #!$       swidth :  space width.
1 # 157 # #!$       swinFrac : window to wall ratio of exterior surfaces.
1 # 158 # #!$       space_cond : u-name of space conditions.
1 # 159 # #!$ This macro uses the FLOOR-NUM[], FLOOR-HEIGHT[] and WINDOW_HEIGHT[]
1 # 160 # #!$ that are set by the FLOOR macro.
1 # 161 # #!$ It also uses :
1 # 162 # #!$   GLASS_TYPE macro to set the glass-type of windows.
1 # 163 # #!$   EW_CONS   macro to set the exterior-wall construction.
1 # 164 # #!$   IW_CONS   macro to set the interior-wall construction.
1 # 165 # #!$   ROOF_CONS macro to set the roof construction.
1 # 166 # #!$   UGF_CONS  macro to set the underground-wall,floor construction.
1 # 167 # #!$-----
1 # 168 # #!$
1 # 169 # #!def PERIM-SPACE(sname,xx,yy,zz,sazim,sarea,swidth,swinFrac,space_cond)
1 # 170 #
1 # 171 #   space           x = xx y = yy z = zz azimuth = sazim area = sarea
1 # 172 #                   volume = #[ sarea * FLOOR-HEIGHT[] ]
1 # 173 #                   space-conditions = space_cond ..
1 # 174 #   exterior-wall  x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
1 # 175 #                   w = swidth construction = EW_CONS[] ..
1 # 176 #   #!set1 TMP1 #[ #[swinFrac * #[FLOOR-HEIGHT[] * swidth]] / WINDOW_HEIGHT[] ]
1 # 177 #   #!if #[ TMP1[] GT 0 ]
1 # 178 #       window     x = #[ #[(swidth - TMP1[]) / 2 ]
1 # 179 #                   y = 3.0
1 # 180 #                   w = TMP1[] h = WINDOW_HEIGHT[]
1 # 181 #                   glass-type = GLASS_TYPE[] ..
1 # 182 #   #endif
1 # 183 #
1 # 184 #   #!if #[ #[FLOOR-NUM[] EQS "g" ] or #[FLOOR-NUM[] EQS "a" ] ]
1 # 185 #       underground-floor area = sarea construction = UGF_CONS[] ..
1 # 186 #   #!else
1 # 187 #       interior-wall area = sarea construction = IW_CONS[]
1 # 188 #                   next-to = #[ ["SP_" // FLOOR-PREV[]] // sname ] ..
1 # 189 #   #endif
1 # 190 #
1 # 191 #   #!if #[ #[FLOOR-NUM[] EQS "t" ] or #[FLOOR-NUM[] EQS "s" ] ]
1 # 192 #       roof         x = 0 y = 0
1 # 193 #                   h = FLOOR-PERIM-D[]
1 # 194 #                   w = #[ swidth - FLOOR-PERIM-D[] ]
1 # 195 #                   construction = ROOF_CONS[] ..
1 # 196 #   #endif
1 # 197 # #!$
1 # 198 # #endif
file : INPUT2.TMP
* 56 *
# 57 # #!$---- now generate each floor.

```

```

# 58 # ##$
# 59 # ##$ # W D H perim_D window space conditions for
# 60 # ##$ frac core north south east west
# 61 # ##$ -----
# 62 * $
* 63 * $----- ground floor
* 64 * FLOOR[ g, 100, 50, 10, 15 , .20, CORE, PERIM, PERIM, PERIM, PERIM ]
.1# 32 # ##$
.1# 33 # ##$ --->| |<--- 15
.1# 34 # ##$
.1# 35 # ##$
.1# 36 # ##$
.1# 37 # ##$
.1# 38 # ##$
.1# 39 # ##$
.1# 40 # ##$
.1# 41 # ##$
.1# 42 # ##$
.1# 43 # ##$
.1# 44 # ##$
.1# 45 # ##$
.1# 46 # ##$
.1# 47 # ##$
.1# 48 # ##$
.1# 49 # ##$
.1# 50 # ##$
.1# 51 # ##$
.1# 52 # ##$
.1# 53 # ##$
.1# 54 # ##$
.1# 55 # ##$
.1# 56 # ##$
.1# 57 # ##$
.1# 58 # ##$
.1# 59 # ##$
.1# 60 # ##$
.1# 61 # ##$
.1# 62 # ##$
.1# 63 # ##$
.1# 64 # ##$
.1# 65 # ##$
.1# 66 # ##$
.1# 67 # ##$
.1# 68 # ##$
.1# 69 # ##$
.1# 70 # ##$
.1# 71 # ##$
.1# 72 # ##$
.2# 170 # ##$
.2# 171 # ##$
.2# 172 # ##$
.2# 173 # ##$
.2# 174 # ##$
.2# 175 # ##$
.2# 176 # ##$
.2# 177 # ##$
.1.2# 178 # ##$
.1.2# 179 # ##$
.1.2# 180 # ##$
.1.2# 181 # ##$
.2# 182 # ##$
.2# 183 # ##$
.2# 184 # ##$
.1.2# 185 # ##$

```



```

.2# 186 # ##else
.1.2- 187 - interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2- 188 - next-to = #[ #["SP_" // FLOOR-PREV[]] // _N ] ..
.2# 189 # ##endif
.2* 190 *
.2# 191 # ##if #[ #["FLOOR-NUM[] EQS "t" ] or #["FLOOR-NUM[] EQS "s" ] ]
.1.2- 192 - roof x = 0 y = 0
.1.2- 193 - h = FLOOR-PERIM-D[]
.1.2- 194 - w = #[ 100 - FLOOR-PERIM-D[] ]
.1.2- 195 - construction = ROOF_CONS[] ..
.2# 196 # ##endif
.2# 197 # ##$
.1* 73 *
.1* 74 * #[SP-NAM0[] // "_S" ] = PERIM-SPACE[ _S, 0, 0, Z-SP[], 0
.1* 75 * , AREA-SP[], 100, .20
.1* 76 * , PERIM ]
.2* 170 *
.2* 171 * space x = 0 y = 0 z = Z-SP[] azimuth = 0 area = AREA-SP[]
.2* 172 * volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 * space-conditions = PERIM ..
.2* 174 * exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 * w = 100 construction = EW_CONS[] ..
.2# 176 # ##set1 TMP1 #[ #[.20 * #[FLOOR-HEIGHT[] * 100]] / WINDOW-HEIGHT[] ]
.2# 177 # ##if #[ TMP1[] GT 0 ]
.1.2* 178 * window x = #[ #[100 - TMP1[]] / 2 ]
.1.2* 179 * y = 3.0
.1.2* 180 * w = TMP1[] h = WINDOW-HEIGHT[]
.1.2* 181 * glass-type = GLASS_TYPE[] ..
.2# 182 # ##endif
.2* 183 *
.2# 184 # ##if #[ #["FLOOR-NUM[] EQS "g" ] or #["FLOOR-NUM[] EQS "s" ] ]
.1.2* 185 * underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 # ##else
.1.2- 187 - interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2- 188 - next-to = #[ #["SP_" // FLOOR-PREV[]] // _S ) ..
.2# 189 # ##endif
.2* 190 *
.2# 191 # ##if #[ #["FLOOR-NUM[] EQS "t" ] or #["FLOOR-NUM[] EQS "s" ] ]
.1.2- 192 - roof x = 0 y = 0
.1.2- 193 - h = FLOOR-PERIM-D[]
.1.2- 194 - w = #[ 100 - FLOOR-PERIM-D[] ]
.1.2- 195 - construction = ROOF_CONS[] ..
.2# 196 # ##endif
.2# 197 # ##$
.1* 77 *
.1# 78 # ##set1 AREA-SP #[15 * #[ 50 - 15 ] ]
.1* 79 * #[SP-NAM0[] // "_E" ] = PERIM-SPACE[ _E, 100, 0, Z-SP[], -90
.1* 80 * , AREA-SP[], 50, .20
.1* 81 * , PERIM ]
.2* 170 *
.2* 171 * space x = 100 y = 0 z = Z-SP[] azimuth = -90 area = AREA-SP
.2* 171 * [ ]
.2* 172 * volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 * space-conditions = PERIM ..
.2* 174 * exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 * w = 50 construction = EW_CONS[] ..
.2# 176 # ##set1 TMP1 #[ #[.20 * #[FLOOR-HEIGHT[] * 50]] / WINDOW-HEIGHT[] ]
.2# 177 # ##if #[ TMP1[] GT 0 ]
.1.2* 178 * window x = #[ #[50 - TMP1[]] / 2 ]
.1.2* 179 * y = 3.0
.1.2* 180 * w = TMP1[] h = WINDOW-HEIGHT[]
.1.2* 181 * glass-type = GLASS_TYPE[] ..
.2# 182 # ##endif
.2* 183 *
.2# 184 # ##if #[ #["FLOOR-NUM[] EQS "g" ] or #["FLOOR-NUM[] EQS "s" ] ]

```

```

.1.2* 185 *      underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 #      ##else
.1.2- 187 -      interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2- 188 -      next-to = #[ #["SP_" // FLOOR-PREV[]] // _E ] ..
.2# 189 #      ##endif
.2* 190 *
.2# 191 #      ##if #[ #[FLOOR-NUM[] EQS "t"] or #[FLOOR-NUM[] EQS "s" ]
.1.2- 192 -      roof x = 0 y = 0
.1.2- 193 -      h = FLOOR-PERIM-D[]
.1.2- 194 -      w = #[ 50 - FLOOR-PERIM-D[] ]
.1.2- 195 -      construction = ROOF_CONS[] ..
.2# 196 #      ##endif
.2# 197 # $$$
.1# 82 #      ##set1 AREA-IW #[ 1.4142 * #[ 15 * 10 ] ]
.1# 83 #      ##if #[AREA-IW[] GT 0 ]
.1.1* 84 *      interior-wall area = AREA-IW[]
.1.1* 85 *      next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 86 *      construction = IW_CONS[] ..
.1.1* 87 *      interior-wall area = AREA-IW[]
.1.1* 88 *      next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 89 *      construction = IW_CONS[] ..
.1# 90 #      ##endif
.1* 91 *
.1* 92 *      #[SP-NAM0[] // "_W" ] = PERIM-SPACE[ _W, 0, 50, Z-SP[], 90
.1* 93 *      , AREA-SP[], 50, .20
.1* 94 *      , PERIM ]
.2* 170 *
.2* 171 *      space x = 0 y = 50 z = Z-SP[] azimuth = 90 area = AREA-SP[]
.2* 172 *      volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 *      space-conditions = PERIM ..
.2* 174 *      exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 *      w = 50 construction = EW_CONS[] ..
.2# 176 #      ##set1 TMP1 #[ #[.20 * #[FLOOR-HEIGHT[] * 50]] / WINDOW-HEIGHT[] ]
.2# 177 #      ##if #[ TMP1[] GT 0 ]
.1.2* 178 *      window x = #[ #[50 - TMP1[]] / 2 ]
.1.2* 179 *      y = 3.0
.1.2* 180 *      w = TMP1[] h = WINDOW-HEIGHT[]
.1.2* 181 *      glass-type = GLASS_TYPE[] ..
.2# 182 #      ##endif
.2* 183 *
.2# 184 #      ##if #[ #[FLOOR-NUM[] EQS "g"] or #[FLOOR-NUM[] EQS "s" ]
.1.2* 185 *      underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 #      ##else
.1.2- 187 -      interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2- 188 -      next-to = #[ #["SP_" // FLOOR-PREV[]] // _W ] ..
.2# 189 #      ##endif
.2* 190 *
.2# 191 #      ##if #[ #[FLOOR-NUM[] EQS "t"] or #[FLOOR-NUM[] EQS "s" ]
.1.2- 192 -      roof x = 0 y = 0
.1.2- 193 -      h = FLOOR-PERIM-D[]
.1.2- 194 -      w = #[ 50 - FLOOR-PERIM-D[] ]
.1.2- 195 -      construction = ROOF_CONS[] ..
.2# 196 #      ##endif
.2# 197 # $$$
.1# 95 #      ##if #[AREA-IW[] GT 0 ]
.1.1* 96 *      interior-wall area = AREA-IW[]
.1.1* 97 *      next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 98 *      construction = IW_CONS[] ..
.1.1* 99 *      interior-wall area = AREA-IW[]
.1.1* 100 *      next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 101 *      construction = IW_CONS[] ..
.1# 102 #      ##endif
.1* 103 *
.1* 104 *      $----- Core space -----$
.1# 105 #      ##set1 TMP1 #[ 2 * 15 ]


```



```

.1# 106 # ##set1 AREA-SP #[ #[100 - TMP1[]] * #[50 - TMP1[]] ]
.1# 107 # ##if #[ AREA-SP[] GT 0 ]
.1.1# 108 *   #[SP-NAM0[] // "_C" ] = space x = 15 y = 15
.1.1# 109 *   z = Z-SP[] azimuth = 0 area = AREA-SP[]
.1.1# 110 *   volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.1.1# 111 *   space-conditions=CORE ..
.1.1# 112 *   interior-wall area = #[ #[100 - TMP1[]] * 10 ]
.1.1# 113 *   next-to = #[ SP-NAM0[] // "_S" ]
.1.1# 114 *   construction = IW_CONS[] ..
.1.1# 115 *   interior-wall area = #[ #[100 - TMP1[]] * 10 ]
.1.1# 116 *   next-to = #[ SP-NAM0[] // "_N" ]
.1.1# 117 *   construction = IW_CONS[] ..
.1.1# 118 *   interior-wall area = #[ #[50 - TMP1[]] * 10 ]
.1.1# 119 *   next-to = #[ SP-NAM0[] // "_E" ]
.1.1# 120 *   construction = IW_CONS[] ..
.1.1# 121 *   interior-wall area = #[ #[50 - TMP1[]] * 10 ]
.1.1# 122 *   next-to = #[ SP-NAM0[] // "_W" ]
.1.1# 123 *   construction = IW_CONS[] ..
.1.1# 124 *
.1.1# 125 # ##if #[ g EQS "g" ]
.2.1# 126 *   underground-floor area = ARFA-SP[] construction = UGF_CONS[] ..
.1.1# 127 # ##else
.2.1- 128 -   interior-wall area = AREA-SP[]
.2.1- 129 -   next-to = #[ ["SP_" // FLOOR-PREV[]] // "_C" ]
.2.1- 130 -   construction = IW_CONS[] ..
.1.1# 131 # ##endif
.1.1# 132 *
.1.1# 133 # ##if #[ g EQS "t" ]
.2.1- 134 -   roof x = 15 y = 15
.2.1- 135 -   h = #[50 - #[ 2 * 15 ] ]
.2.1- 136 -   w = #[100 - #[ 2 * 15 ] ]
.2.1- 137 -   construction = ROOF_CONS[] ..
.1.1# 138 # ##endif
.1# 139 # ##endif
.1# 140 # ##$
.1# 141 # ##$ update the z-coordinate.
.1# 142 # ##set1 Z-SP #[ Z-SP[] + FLOOR-HEIGHT[] ]
.1# 143 # ##set1 FLOOR-PREV g
.1# 144 # ##$
* 65 * $----- 1st floor
* 66 * FLOOR[ 1, 100, 50, 10, 15 , .30, CORE, PERIM, PERIM, PERIM, PERIM ]
.1# 32 # ##$
.1# 33 # ##$
.1# 34 # ##$
.1# 35 # ##$
.1# 36 # ##$
.1# 37 # ##$
.1# 38 # ##$
.1# 39 # ##$
.1# 40 # ##$
.1# 41 # ##$
.1# 42 # ##$
.1# 43 # ##$
.1# 44 # ##$
.1# 45 # ##$
.1# 46 # ##$
.1# 47 # ##$
.1# 48 # ##$
.1# 49 # ##$
.1# 50 # ##$
.1# 51 # ##$
.1# 52 # ##$
.1# 53 # ##$
.1# 54 # ##$
.1.1# 55 # ##ifndef WINDOW_HEIGHT

```



```

.1.1- 56 -    ##set1 WINDOW_HEIGHT 3.0
.1# 57 #    ##endif
.1# 58 # ##$
.1.1# 59 #    ##ifndef Z-SP
.1.1- 60 -    ##set1 Z-SP 0
.1# 61 #    ##endif
.1# 62 # ##$
.1# 63 #    ##set1 FLOOR-HEIGHT 10
.1# 64 #    ##set1 FLOOR-NUM 1
.1# 65 #    ##set1 FLOOR-PERIM-D 15
.1# 66 # ##$
.1# 67 #    ##set1 SP-NAMO #["SP_" // 1]
.1# 68 # ##$
.1# 69 #    ##set1 AREA-SP #[ 15 * #[ 100 - 15 ] ]
.1# 70 #    #[SP-NAMO[] // "_N" ] = PERIM-SPACE[ _N, 100, 50, Z-SP[],180
.1# 71 #    , AREA-SP[], 100, .30
.1# 72 #    , PERIM ]
.2# 170 *
.2# 171 *    space          x = 100 y = 50 z = Z-SP[] azimuth = 180 area = AREA-S
.2# 171 * P[]
.2# 172 *    volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2# 173 *    space-conditions = PERIM ..
.2# 174 *    exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2# 175 *    w = 100 construction = EW_CONS[] ..
.2# 176 #    ##set1 TMP1 #[ #[.30 * #[FLOOR-HEIGHT[] * 100]] / WINDOW_HEIGHT[] ]
.2# 177 #    ##if #[ TMP1[] GT 0 ]
.1.2# 178 *    window          x = #[ #[100 - TMP1[]] / 2 ]
.1.2# 179 *    y = 3.0
.1.2# 180 *    w = TMP1[] h = WINDOW_HEIGHT[]
.1.2# 181 *    glass-type = GLASS_TYPE[] ..
.2# 182 #    ##endif
.2# 183 *
.2# 184 #    ##if #[ #[FLOOR-NUM[] EQS "g" ] or #[FLOOR-NUM[] EQS "s" ] ]
.1.2- 185 -    underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 #    ##else
.1.2# 187 *    interior-wall   area = AREA-SP[] construction = IW_CONS[]
.1.2# 188 *    next-to = #[ #[ "SP_" // FLOOR-PREV[] ] // _N ] ..
.2# 189 #    ##endif
.2# 190 *
.2# 191 #    ##if #[ #[FLOOR-NUM[] EQS "t" ] or #[FLOOR-NUM[] EQS "s" ] ]
.1.2- 192 -    roof x = 0 y = 0
.1.2- 193 -    h = FLOOR-PERIM-D[]
.1.2- 194 -    w = #[ 100 - FLOOR-PERIM-D[] ]
.1.2- 195 -    construction = ROOF_CONS[] ..
.2# 196 #    ##endif
.2# 197 # ##$
.1# 73 *
.1# 74 *    #[SP-NAMO[] // "_S" ] = PERIM-SPACE[ _S, 0, 0, Z-SP[], 0
.1# 75 *    , AREA-SP[], 100, .30
.1# 76 *    , PERIM ]
.2# 170 *
.2# 171 *    space          x = 0 y = 0 z = Z-SP[] azimuth = 0 area = AREA-SP[]
.2# 172 *    volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2# 173 *    space-conditions = PERIM ..
.2# 174 *    exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2# 175 *    w = 100 construction = EW_CONS[] ..
.2# 176 #    ##set1 TMP1 #[ #[.30 * #[FLOOR-HEIGHT[] * 100]] / WINDOW_HEIGHT[] ]
.2# 177 #    ##if #[ TMP1[] GT 0 ]
.1.2# 178 *    window          x = #[ #[100 - TMP1[]] / 2 ]
.1.2# 179 *    y = 3.0
.1.2# 180 *    w = TMP1[] h = WINDOW_HEIGHT[]
.1.2# 181 *    glass-type = GLASS_TYPE[] ..
.2# 182 #    ##endif
.2# 183 *
.2# 184 #    ##if #[ #[FLOOR-NUM[] EQS "g" ] or #[FLOOR-NUM[] EQS "s" ] ]

```

```

.1.2- 185 -      underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 #      ##else
.1.2* 187 *      interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2* 188 *      next-to = #[ #["SP_" // FLOOR-PREV[]] // _S ] ..
.2# 189 #      ##endif
.2* 190 *
.2# 191 #      ##if #[ #[ FLOOR-NUM[] EQS "t" ] or #[ FLOOR-NUM[] EQS "s" ] ]
.1.2- 192 -      roof x = 0 y = 0
.1.2- 193 -      h = FLOOR-PERIM-D[]
.1.2- 194 -      w = #[ 100 - FLOOR-PERIM-D[] ]
.1.2- 195 -      construction = ROOF_CONS[] ..
.2# 196 #      ##endif
.2# 197 #      ##$
.1* 77 *
.1# 78 #      ##set1 AREA-SP #[ 15 * #[ 50 - 15 ] ]
.1* 79 *      #[ SP-NAM0[] // "_E" ] = PERIM-SPACE[ _E, 100, 0, Z-SP[], -90
.1* 80 *      , AREA-SP[], 50, .30
.1* 81 *      , PERIM ]
.2* 170 *
.2* 171 *      space x = 100 y = 0 z = Z-SP[] azimuth = -90 area = AREA-SP
.2* 171 *      [ ]
.2* 172 *      volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 *      space-conditions = PERIM ..
.2* 174 *      exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 *      w = 50 construction = EW_CONS[] ..
.2# 176 #      ##set1 TMP1 #[ #[ .30 * #[ FLOOR-HEIGHT[] * 50 ] ] / WINDOW-HEIGHT[] ]
.2# 177 #      ##if #[ TMP1[] GT 0 ]
.1.2* 178 *      window x = #[ #[ 50 - TMP1[] ] / 2 ]
.1.2* 179 *      y = 3.0
.1.2* 180 *      w = TMP1[] h = WINDOW-HEIGHT[]
.1.2* 181 *      glass-type = GLASS_TYPE[] ..
.2# 182 #      ##endif
.2* 183 *
.2# 184 #      ##if #[ #[ FLOOR-NUM[] EQS "g" ] or #[ FLOOR-NUM[] EQS "s" ] ]
.1.2- 185 -      underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 #      ##else
.1.2* 187 *      interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2* 188 *      next-to = #[ #["SP_" // FLOOR-PREV[]] // _E ] ..
.2# 189 #      ##endif
.2* 190 *
.2# 191 #      ##if #[ #[ FLOOR-NUM[] EQS "t" ] or #[ FLOOR-NUM[] EQS "s" ] ]
.1.2- 192 -      roof x = 0 y = 0
.1.2- 193 -      h = FLOOR-PERIM-D[]
.1.2- 194 -      w = #[ 50 - FLOOR-PERIM-D[] ]
.1.2- 195 -      construction = ROOF_CONS[] ..
.2# 196 #      ##endif
.2# 197 #      ##$
.1# 82 #      ##set1 AREA-IW #[ 1.4142 * #[ 15 * 10 ] ]
.1# 83 #      ##if #[ AREA-IW[] GT 0 ]
.1.1* 84 *      interior-wall area = AREA-IW[]
.1.1* 85 *      next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 86 *      construction = IW_CONS[] ..
.1.1* 87 *      interior-wall area = AREA-IW[]
.1.1* 88 *      next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 89 *      construction = IW_CONS[] ..
.1# 90 #      ##endif
.1* 91 *
.1* 92 *      #[ SP-NAM0[] // "_W" ] = PERIM-SPACE[ _W, 0, 50, Z-SP[], 90
.1* 93 *      , AREA-SP[], 50, .30
.1* 94 *      , PERIM ]
.2* 170 *
.2* 171 *      space x = 0 y = 50 z = Z-SP[] azimuth = 90 area = AREA-SP[]
.2* 172 *      volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 *      space-conditions = PERIM ..
.2* 174 *      exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]

```

```

.2* 175 *          w = 50 construction = EW_CONS[] ..
.2# 176 # ##set1 TMP1 #[ [.30 * #[FLOOR-HEIGHT[] * 50] / WINDOW_HEIGHT[] ]
.2# 177 # ##if #[ TMP1[] GT 0 ]
.1.2* 178 *          window      x = #[ #[50 - TMP1[]] / 2 ]
.1.2* 179 *          y = 3.0
.1.2* 180 *          w = TMP1[] h = WINDOW_HEIGHT[]
.1.2* 181 *          glass-type = GLASS_TYPE[] ..
.2# 182 # ##endif
.2* 183 *
.2# 184 # ##if #[ #[FLOOR-NUM[] EQS "g"] or #[FLOOR-NUM[] EQS "s"] ]
.1.2- 185 -          underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 # ##else
.1.2* 187 *          interior-wall   area = AREA-SP[] construction = IW_CONS[]
.1.2* 188 *          next-to = #[ #[ "SP_" // FLOOR-PREV[] ] // "_W" ] ..
.2# 189 # ##endif
.2* 190 *
.2# 191 # ##if #[ #[FLOOR-NUM[] EQS "t"] or #[FLOOR-NUM[] EQS "s"] ]
.1.2- 192 -          roof      x = 0 y = 0
.1.2- 193 -          h = FLOOR-PERIM-D[]
.1.2- 194 -          w = #[ 50 - FLOOR-PERIM-D[] ]
.1.2- 195 -          construction = ROOF_CONS[] ..
.2# 196 # ##endif
.2# 197 # ##$
.1# 95 #          ##if #[ AREA-IW[] GT 0 ]
.1.1* 96 *          interior-wall area = AREA-IW[]
.1.1* 97 *          next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 98 *          construction = IW_CONS[] ..
.1.1* 99 *          interior-wall area = AREA-IW[]
.1.1* 100 *          next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 101 *          construction = IW_CONS[] ..
.1# 102 #          ##endif
.1* 103 *
.1* 104 * $----- Core space -----$
.1# 105 # ##set1 TMP1 #[ 2 * 15 ]
.1# 106 # ##set1 AREA-SP #[ #[100 - TMP1[]] * #[50 - TMP1[]] ]
.1# 107 # ##if #[ AREA-SP[] GT 0 ]
.1.1* 108 *          #[SP-NAM0[] // "_C" ] = space x = 15 y = 15
.1.1* 109 *          z = Z-SP[] azimuth = 0 area = AREA-SP[]
.1.1* 110 *          volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.1.1* 111 *          space-conditions=CORE ..
.1.1* 112 *          interior-wall area = #[ #[100 - TMP1[]] * 10 ]
.1.1* 113 *          next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 114 *          construction = IW_CONS[] ..
.1.1* 115 *          interior-wall area = #[ #[100 - TMP1[]] * 10 ]
.1.1* 116 *          next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 117 *          construction = IW_CONS[] ..
.1.1* 118 *          interior-wall area = #[ #[50 - TMP1[]] * 10 ]
.1.1* 119 *          next-to = #[ SP-NAM0[] // "_E" ]
.1.1* 120 *          construction = IW_CONS[] ..
.1.1* 121 *          interior-wall area = #[ #[50 - TMP1[]] * 10 ]
.1.1* 122 *          next-to = #[ SP-NAM0[] // "_W" ]
.1.1* 123 *          construction = IW_CONS[] ..
.1.1* 124 *
.1.1# 125 #          ##if #[ 1 EQS "g" ]
.2.1- 126 -          underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.1.1# 127 #          ##else
.2.1* 128 *          interior-wall   area = AREA-SP[]
.2.1* 129 *          next-to = #[ #[ "SP_" // FLOOR-PREV[] ] // "_C" ]
.2.1* 130 *          construction = IW_CONS[] ..
.1.1# 131 #          ##endif
.1.1* 132 *
.1.1# 133 #          ##if #[ 1 EQS "t" ]
.2.1- 134 -          roof      x = 15 y = 15
.2.1- 135 -          h = #[50 - #[ 2 * 15 ] ]
.2.1- 136 -          w = #[100 - #[ 2 * 15 ] ]

```

```

.2.1- 137 -                construction = ROOF_CONS[] ..
.1.1# 138 #                ##endif
.1# 139 #                ##endif
.1# 140 #                ##$
.1# 141 #                ##$ update the z-coordinate.
.1# 142 #                ##set1 Z-SP #[ Z-SP[] + FLOOR-HEIGHT[] ]
.1# 143 #                ##set1 FLOOR-PREV 1
.1# 144 #                ##$
* 67 * $----- top floor
* 68 * FLOOR[ t, 100, 50, 10, 15 , .30, CORE, PERIM, PERIM, PERIM, PERIM ]
.1# 32 #                ##$
.1# 33 #                ##$
.1# 34 #                ##$
.1# 35 #                ##$
.1# 36 #                ##$
.1# 37 #                ##$
.1# 38 #                ##$
.1# 39 #                ##$
.1# 40 #                ##$
.1# 41 #                ##$
.1# 42 #                ##$
.1# 43 #                ##$
.1# 44 #                ##$
.1# 45 #                ##$
.1# 46 #                ##$
.1# 47 #                ##$
.1# 48 #                ##$
.1# 49 #                ##$
.1# 50 #                ##$
.1# 51 #                ##$
.1# 52 #                ##$
.1# 53 #                ##$
.1# 54 #                ##$
.1.1# 55 #                ##ifndef WINDOW_HEIGHT
.1.1- 56 -                ##set1 WINDOW_HEIGHT 3.0
.1# 57 #                ##endif
.1# 58 #                ##$
.1.1# 59 #                ##ifndef Z-SP
.1.1- 60 -                ##set1 Z-SP 0
.1# 61 #                ##endif
.1# 62 #                ##$
.1# 63 #                ##set1 FLOOR-HEIGHT 10
.1# 64 #                ##set1 FLOOR-NUM t
.1# 65 #                ##set1 FLOOR-PERIM-D 15
.1# 66 #                ##$
.1# 67 #                ##set1 SP-NAM0 #["SP_" // t]
.1# 68 #                ##$
.1# 69 #                ##set1 AREA-SP #[ 15 * #[ 100 - 15 ] ]
.1* 70 *                #[SP-NAM0[] // "_N" ] = PERIM-SPACE[ _N, 100, 50, Z-SP[],180
.1* 71 *                , AREA-SP[], 100, .30
.1* 72 *                , PERIM ]
.2* 170 *
.2* 171 *                space          x = 100 y = 50 z = Z-SP[] azimuth = 180 area = AREA-S
.2* 171 *                P[]
.2* 172 *                volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 *                space-conditions = PERIM ..
.2* 174 *                exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 *                w = 100 construction = EW_CONS[] ..
.2# 176 #                ##set1 TMP1 #[ #[.30 * #[FLOOR-HEIGHT[] * 100] / WINDOW_HEIGHT[] ]
.2# 177 #                ##if #[ TMP1[] GT 0 ]
.1.2* 178 *                window          x = #[ #[100 - TMP1[]] / 2 ]
.1.2* 179 *                y = 3.0
.1.2* 180 *                w = TMP1[] h = WINDOW_HEIGHT[]
.1.2* 181 *                glass-type = GLASS_TYPE[] ..
.2# 182 #                ##endif

```

```

.2* 183 *
.2# 184 # ##if #[ #[FLOOR-NUM[] EQS "g"] or #[FLOOR-NUM[] EQS "s"] ]
.1.2- 185 -     underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 # ##else
.1.2* 187 *     interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2* 188 *     next-to = #[ #[ "SP_" // FLOOR-PREV[] ] // _N ] ..
.2# 189 # ##endif
.2* 190 *
.2# 191 # ##if #[ #[FLOOR-NUM[] EQS "t"] or #[FLOOR-NUM[] EQS "s"] ]
.1.2* 192 *     roof x = 0 y = 0
.1.2* 193 *         h = FLOOR-PERIM-D[]
.1.2* 194 *         w = #[ 100 - FLOOR-PERIM-D[] ]
.1.2* 195 *         construction = ROOF_CONS[] ..
.2# 196 # ##endif
.2# 197 # ##$
.1* 73 *
.1* 74 *     #[SP-NAM0[] // "_S"] = PERIM-SPACE[ _S, 0, 0, Z-SP[], 0
.1* 75 *         , AREA-SP[], 100, .30
.1* 76 *         , PERIM ]
.2* 170 *
.2* 171 *     space x = 0 y = 0 z = Z-SP[] azimuth = 0 area = AREA-SP[]
.2* 172 *         volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 *         space-conditions = PERIM ..
.2* 174 *     exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 *         w = 100 construction = EW_CONS[] ..
.2# 176 # ##set1 TMP1 #[ #[.30 * #[FLOOR-HEIGHT[] * 100]] / WINDOW-HEIGHT[] ]
.2# 177 # ##if #[ TMP1[] GT 0 ]
.1.2* 178 *     window x = #[ #[100 - TMP1[]] / 2 ]
.1.2* 179 *         y = 3.0
.1.2* 180 *         w = TMP1[] h = WINDOW-HEIGHT[]
.1.2* 181 *         glass-type = GLASS_TYPE[] ..
.2# 182 # ##endif
.2* 183 *
.2# 184 # ##if #[ #[FLOOR-NUM[] EQS "g"] or #[FLOOR-NUM[] EQS "s"] ]
.1.2- 185 -     underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 # ##else
.1.2* 187 *     interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2* 188 *     next-to = #[ #[ "SP_" // FLOOR-PREV[] ] // _S ] ..
.2# 189 # ##endif
.2* 190 *
.2# 191 # ##if #[ #[FLOOR-NUM[] EQS "t"] or #[FLOOR-NUM[] EQS "s"] ]
.1.2* 192 *     roof x = 0 y = 0
.1.2* 193 *         h = FLOOR-PERIM-D[]
.1.2* 194 *         w = #[ 100 - FLOOR-PERIM-D[] ]
.1.2* 195 *         construction = ROOF_CONS[] ..
.2# 196 # ##endif
.2# 197 # ##$
.1* 77 *
.1# 78 # ##set1 AREA-SP #[15 * #[ 50 - 15 ] ]
.1* 79 *     #[SP-NAM0[] // "_E"] = PERIM-SPACE[ _E, 100, 0, Z-SP[], -90
.1* 80 *         , AREA-SP[], 50, .30
.1* 81 *         , PERIM ]
.2* 170 *
.2* 171 *     space x = 100 y = 0 z = Z-SP[] azimuth = -90 area = AREA-SP
.2* 171 *     [ ]
.2* 172 *         volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 *         space-conditions = PERIM ..
.2* 174 *     exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 *         w = 50 construction = EW_CONS[] ..
.2# 176 # ##set1 TMP1 #[ #[.30 * #[FLOOR-HEIGHT[] * 50]] / WINDOW-HEIGHT[] ]
.2# 177 # ##if #[ TMP1[] GT 0 ]
.1.2* 178 *     window x = #[ #[50 - TMP1[]] / 2 ]
.1.2* 179 *         y = 3.0
.1.2* 180 *         w = TMP1[] h = WINDOW-HEIGHT[]
.1.2* 181 *         glass-type = GLASS_TYPE[] ..

```

```

.2# 182 # ##endif
.2* 183 *
.2# 184 # ##if #([FLOOR-NUM[] EQS "g") or #[FLOOR-NUM[] EQS "s" ]
.1.2- 185 -     underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 # ##else
.1.2* 187 *     interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2* 188 *     next-to = #[ #["SP_" // FLOOR-PREV[]] // _E ] ..
.2# 189 # ##endif
.2* 190 *
.2# 191 # ##if #([FLOOR-NUM[] EQS "t") or #[FLOOR-NUM[] EQS "s" ]
.1.2* 192 *     roof x = 0 y = 0
.1.2* 193 *     h = FLOOR-PERIM-D[]
.1.2* 194 *     w = #[ 50 - FLOOR-PERIM-D[] ]
.1.2* 195 *     construction = ROOF_CONS[] ..
.2# 196 # ##endif
.2# 197 # $$$
.1# 82 #     ##set1 AREA-IW #[ 1.4142 * #[ 15 * 10 ] ]
.1# 83 #     ##if #[AREA-IW[] GT 0 ]
.1.1* 84 *         interior-wall area = AREA-IW[]
.1.1* 85 *         next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 86 *         construction = IW_CONS[] ..
.1.1* 87 *         interior-wall area = AREA-IW[]
.1.1* 88 *         next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 89 *         construction = IW_CONS[] ..
.1# 90 #     ##endif
.1* 91 *
.1* 92 * #[SP-NAM0[] // "_W"] = PERIM-SPACE[ _W, 0, 50, Z-SP[], 90
.1* 93 *     , AREA-SP[], 50, .30
.1* 94 *     , PERIM ]
.2* 170 *
.2* 171 * space x = 0 y = 50 z = Z-SP[] azimuth = 90 area = AREA-SP[]
.2* 172 *     volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.2* 173 *     space-conditions = PERIM ..
.2* 174 *     exterior-wall x = 0 y = 0 azimuth = 0 h = FLOOR-HEIGHT[]
.2* 175 *     w = 50 construction = EW_CONS[] ..
.2# 176 #     ##set1 TMP1 #[ #[.30 * #[FLOOR-HEIGHT[] * 50] / WINDOW_HEIGHT[]]
.2# 177 #     ##if #[ TMP1[] GT 0 ]
.1.2* 178 *         window x = #[ #[50 - TMP1[]] / 2 ]
.1.2* 179 *         y = 3.0
.1.2* 180 *         w = TMP1[] h = WINDOW_HEIGHT[]
.1.2* 181 *         glass-type = GLASS_TYPE[] ..
.2# 182 #     ##endif
.2* 183 *
.2# 184 # ##if #([FLOOR-NUM[] EQS "g") or #[FLOOR-NUM[] EQS "s" ]
.1.2- 185 -     underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.2# 186 # ##else
.1.2* 187 *     interior-wall area = AREA-SP[] construction = IW_CONS[]
.1.2* 188 *     next-to = #[ #["SP_" // FLOOR-PREV[]] // _W ] ..
.2# 189 # ##endif
.2* 190 *
.2# 191 # ##if #([FLOOR-NUM[] EQS "t") or #[FLOOR-NUM[] EQS "s" ]
.1.2* 192 *     roof x = 0 y = 0
.1.2* 193 *     h = FLOOR-PERIM-D[]
.1.2* 194 *     w = #[ 50 - FLOOR-PERIM-D[] ]
.1.2* 195 *     construction = ROOF_CONS[] ..
.2# 196 # ##endif
.2# 197 # $$$
.1# 95 #     ##if #[AREA-IW[] GT 0 ]
.1.1* 96 *         interior-wall area = AREA-IW[]
.1.1* 97 *         next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 98 *         construction = IW_CONS[] ..
.1.1* 99 *         interior-wall area = AREA-IW[]
.1.1* 100 *         next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 101 *         construction = IW_CONS[] ..
.1# 102 #     ##endif

```

```

.1* 103 *
.1* 104 * $----- Core space -----$
.1# 105 # ##set1 TMP1 #[ 2 * 15 ]
.1# 106 # ##set1 AREA-SP #[ #[100 - TMP1()] * #[50 - TMP1()] ]
.1# 107 # ##if #[ AREA-SP[] GT 0 ]
.1.1* 108 *     #[SP-NAM0[] // "_C" ] = space x = 15 y = 15
.1.1* 109 *     z = Z-SP[] azimuth = 0 area = AREA-SP[]
.1.1* 110 *     volume = #[ AREA-SP[] * FLOOR-HEIGHT[] ]
.1.1* 111 *     space-conditions=CORE ..
.1.1* 112 *     interior-wall area = #[ #[100 - TMP1()] * 10 ]
.1.1* 113 *     next-to = #[ SP-NAM0[] // "_S" ]
.1.1* 114 *     construction = IW_CONS[] ..
.1.1* 115 *     interior-wall area = #[ #[100 - TMP1()] * 10 ]
.1.1* 116 *     next-to = #[ SP-NAM0[] // "_N" ]
.1.1* 117 *     construction = IW_CONS[] ..
.1.1* 118 *     interior-wall area = #[ #[50 - TMP1()] * 10 ]
.1.1* 119 *     next-to = #[ SP-NAM0[] // "_E" ]
.1.1* 120 *     construction = IW_CONS[] ..
.1.1* 121 *     interior-wall area = #[ #[50 - TMP1()] * 10 ]
.1.1* 122 *     next-to = #[ SP-NAM0[] // "_W" ]
.1.1* 123 *     construction = IW_CONS[] ..
.1.1* 124 *
.1.1# 125 # ##if #[ t EQS "g" ]
.2.1- 126 -     underground-floor area = AREA-SP[] construction = UGF_CONS[] ..
.1.1# 127 # ##else
.2.1* 128 *     interior-wall area = AREA-SP[]
.2.1* 129 *     next-to = #[ #[SP_* // FLOOR-PREV[] ] // "_C" ]
.2.1* 130 *     construction = IW_CONS[] ..
.1.1# 131 # ##endif
.1.1* 132 *
.1.1# 133 # ##if #[ t EQS "t" ]
.2.1* 134 *     roof x = 15 y = 15
.2.1* 135 *     h = #[50 - #[ 2 * 15 ] ]
.2.1* 136 *     w = #[100 - #[ 2 * 15 ] ]
.2.1* 137 *     construction = ROOF_CONS[] ..
.1.1# 138 # ##endif
.1# 139 # ##endif
.1# 140 # ##$
.1# 141 # ##$ update the z-coordinate.
.1# 142 # ##set1 Z-SP #[ Z-SP[] + FLOOR-HEIGHT[] ]
.1# 143 # ##set1 FLOOR-PREV t
.1# 144 # ##$
* 69 *
* 70 * end ..
* 71 * compute LOADS ..
* 72 * stop ..

```


Parameterized Building

Input after macro processing

INPUT FOR PARAMETRIZED BUILDING AFTER MACRO PROCESSING

=====

```

< 5 >
< 6 > input LOADS ..
< 8 >
< 9 >   run-period JAN 1 1981 THRU DEC 31 1981 ..
< 10 >  loads-report verification=(LV-B,LV-D,LV-F) ..
< 11 >
< 12 >
< 11 >  building-location
< 21 >      lat = 41.88 lon = 87.63 alt = 600 t-z = 6
< 33 >
< 35 >      hol = YES daylight-savings = YES
< 13 >
< 14 > WA-1-2 = layers material = (WD01,PW03,IN02,GP01) ..
< 15 > RB-1-1 = layers material = (RG01,BR01,IN22,WD01) i-f-r = .76 ..
< 16 > WALL-typ1 = construction layers = WA-1-2 ..
< 17 > ROOF-typ1 = construction layers = RB-1-1 ..
< 18 > IWF-typ1 = construction u = 0.5 ..
< 19 > FLOOR-typ1 = construction u = 0.05 ..
< 20 > GT-typ1 = glass-type p=1 s-c=.60 ..
< 21 >
< 22 > $-----SPACE CONDITIONS-----$
< 23 >
< 24 > OCC-SCH= schedule THRU DEC 31 (WD) (1,7)(0) (8,17)(1) (18,24)(0)
< 25 > (WEH)(1,24)(0) ..
< 26 > CORE-LITE-SCH= schedule THRU DEC 31 (WD) (1,6)(0) (7,18)(1) (19,24)(0)
< 27 > (WEH)(1,24)(0) ..
< 28 > INF-SCH= schedule THRU DEC 31 (WD) (1,7)(0) (8,17)(1) (18,24)(0)
< 29 > (WEH)(1,24)(0) ..
< 30 > PERIM-LITE-SCH= schedule THRU DEC 31 (WD) (1,6)(0) (7,18)(.8) (19,24)(0)
< 31 > (WEH)(1,24)(0) ..
< 32 >
< 33 > CORE= space-conditions t = (75)
< 34 > people-schedule = OCC-SCH people-heat-gain = 450
< 35 > area/person = 100
< 36 > lighting-schedule = CORE-LITE-SCH
< 37 > lighting-w/sqft = 2
< 38 > light-to-space = .75 light-to-return = .25
< 39 > inf-method = AIR-CHANGE inf-schedule = INF-SCH
< 40 > air-changes/hr = 0.8
< 41 > z-type = CONDITIONED ..
< 42 > PERIM= space-conditions like CORE
< 43 > area/person = 90
< 44 > lighting-schedule = PERIM-LITE-SCH
< 45 > air-changes/hr = 0.6 ..
< 46 >
< 47 > $----- set some macros for glass type and constructions.
< 48 >
< 54 >
< 147 >
< 56 >
< 62 > $
< 63 > $----- ground floor
< 70 > "SP_9_N" =
< 170 >
< 171 > space x = 100 y = 50 z = 0 azimuth = 180 area = 1275
< 172 > volume = 12750
< 173 > space-conditions = PERIM ..
< 174 > exterior-wall x = 0 y = 0 azimuth = 0 h = 10
< 175 > w = 100 construction = WALL-typ1 ..
< 178 > window x = 16.666666031
< 179 > y = 3.0
< 180 > w = 66.666664124 h = 3.0

```

```

< 181 >             glass-type = GT-typl ..
< 183 >
< 185 >         underground-floor area = 1275 construction = FLOOR-typl ..
< 190 >
< 73 >
< 74 > *SP_g_S" =
< 170 >
< 171 >     space           x = 0 y = 0 z = 0 azimuth = 0 area = 1275
< 172 >                   volume = 12750
< 173 >                   space-conditions = PERIM ..
< 174 >     exterior-wall   x = 0 y = 0 azimuth = 0 h = 10
< 175 >                   w = 100 construction = WALL-typl ..
< 178 >     window          x = 16.666666031
< 179 >                   y = 3.0
< 180 >                   w = 66.666664124 h = 3.0
< 181 >                   glass-type = GT-typl ..
< 183 >
< 185 >         underground-floor area = 1275 construction = FLOOR-typl ..
< 190 >
< 77 >
< 79 > *SP_g_E" =
< 170 >
< 171 >     space           x = 100 y = 0 z = 0 azimuth = -90 area = 525
< 172 >                   volume = 5250
< 173 >                   space-conditions = PERIM ..
< 174 >     exterior-wall   x = 0 y = 0 azimuth = 0 h = 10
< 175 >                   w = 50 construction = WALL-typl ..
< 178 >     window          x = 8.333333969
< 179 >                   y = 3.0
< 180 >                   w = 33.333332062 h = 3.0
< 181 >                   glass-type = GT-typl ..
< 183 >
< 185 >         underground-floor area = 525 construction = FLOOR-typl ..
< 190 >
< 84 >             interior-wall area = 212.129989624
< 85 >             next-to = "SP_g_N"
< 86 >             construction = IWF-typl ..
< 87 >             interior-wall area = 212.129989624
< 88 >             next-to = "SP_g_S"
< 89 >             construction = IWF-typl ..
< 91 >
< 92 > *SP_g_W" =
< 170 >
< 171 >     space           x = 0 y = 50 z = 0 azimuth = 90 area = 525
< 172 >                   volume = 5250
< 173 >                   space-conditions = PERIM ..
< 174 >     exterior-wall   x = 0 y = 0 azimuth = 0 h = 10
< 175 >                   w = 50 construction = WALL-typl ..
< 178 >     window          x = 8.333333969
< 179 >                   y = 3.0
< 180 >                   w = 33.333332062 h = 3.0
< 181 >                   glass-type = GT-typl ..
< 183 >
< 185 >         underground-floor area = 525 construction = FLOOR-typl ..
< 190 >
< 96 >             interior-wall area = 212.129989624
< 97 >             next-to = "SP_g_N"
< 98 >             construction = IWF-typl ..
< 99 >             interior-wall area = 212.129989624
< 100 >            next-to = "SP_g_S"
< 101 >            construction = IWF-typl ..
< 103 >
< 104 > $----- Core space -----$
< 108 > *SP_g_C" = space x = 15 y = 15
< 109 >                   z = 0 azimuth = 0 area = 1400

```

```

< 110 >                                volume = 14000
< 111 >                                space-conditions=CORE ..
< 112 >    interior-wall area = 700
< 113 >                                next-to = "SP_g_S"
< 114 >                                construction = IWF-typl ..
< 115 >    interior-wall area = 700
< 116 >                                next-to = "SP_g_N"
< 117 >                                construction = IWF-typl ..
< 118 >    interior-wall area = 200
< 119 >                                next-to = "SP_g_E"
< 120 >                                construction = IWF-typl ..
< 121 >    interior-wall area = 200
< 122 >                                next-to = "SP_g_W"
< 123 >                                construction = IWF-typl ..
< 124 >
< 126 >    underground-floor area = 1400 construction = FLOOR-typl ..
< 132 >
< 65 > $----- 1st floor
< 70 > "SP_1_N" =
< 170 >
< 171 >    space                x = 100 y = 50 z = 10 azimuth = 180 area = 1275
< 172 >                                volume = 12750
< 173 >                                space-conditions = PERIM ..
< 174 >    exterior-wall        x = 0 y = 0 azimuth = 0 h = 10
< 175 >                                w = 100 construction = WALL-typl ..
< 178 >    window                x = 0
< 179 >                                y = 3.0
< 180 >                                w = 100 h = 3.0
< 181 >                                glass-type = GT-typl ..
< 183 >
< 187 >    interior-wall        area = 1275 construction = IWF-typl
< 188 >                                next-to = "SP_g_N" ..
< 190 >
< 73 >
< 74 > "SP_1_S" =
< 170 >
< 171 >    space                x = 0 y = 0 z = 10 azimuth = 0 area = 1275
< 172 >                                volume = 12750
< 173 >                                space-conditions = PERIM ..
< 174 >    exterior-wall        x = 0 y = 0 azimuth = 0 h = 10
< 175 >                                w = 100 construction = WALL-typl ..
< 178 >    window                x = 0
< 179 >                                y = 3.0
< 180 >                                w = 100 h = 3.0
< 181 >                                glass-type = GT-typl ..
< 183 >
< 187 >    interior-wall        area = 1275 construction = IWF-typl
< 188 >                                next-to = "SP_g_S" ..
< 190 >
< 77 >
< 79 > "SP_1_E" =
< 170 >
< 171 >    space                x = 100 y = 0 z = 10 azimuth = -90 area = 525
< 172 >                                volume = 5250
< 173 >                                space-conditions = PERIM ..
< 174 >    exterior-wall        x = 0 y = 0 azimuth = 0 h = 10
< 175 >                                w = 50 construction = WALL-typl ..
< 178 >    window                x = 0
< 179 >                                y = 3.0
< 180 >                                w = 50 h = 3.0
< 181 >                                glass-type = GT-typl ..
< 183 >
< 187 >    interior-wall        area = 525 construction = IWF-typl
< 188 >                                next-to = "SP_g_E" ..
< 190 >

```

```

< 84 > interior-wall area = 212.129989624
< 85 > next-to = "SP_1_N"
< 86 > construction = IWF-typl ..
< 87 > interior-wall area = 212.129989624
< 88 > next-to = "SP_1_S"
< 89 > construction = IWF-typl ..
< 91 >
< 92 > "SP_1_W" =
< 170 >
< 171 > space x = 0 y = 50 z = 10 azimuth = 90 area = 525
< 172 > volume = 5250
< 173 > space-conditions = PERIM ..
< 174 > exterior-wall x = 0 y = 0 azimuth = 0 h = 10
< 175 > w = 50 construction = WALL-typl ..
< 178 > window x = 0
< 179 > y = 3.0
< 180 > w = 50 h = 3.0
< 181 > glass-type = GT-typl ..
< 183 >
< 187 > interior-wall area = 525 construction = IWF-typl
< 188 > next-to = "SP_g_W" ..
< 190 >
< 96 > interior-wall area = 212.129989624
< 97 > next-to = "SP_1_N"
< 98 > construction = IWF-typl ..
< 99 > interior-wall area = 212.129989624
< 100 > next-to = "SP_1_S"
< 101 > construction = IWF-typl ..
< 103 >
< 104 > $----- Core space -----$
< 108 > "SP_1_C" = space x = 15 y = 15
< 109 > z = 10 azimuth = 0 area = 1400
< 110 > volume = 14000
< 111 > space-conditions=CORE ..
< 112 > interior-wall area = 700
< 113 > next-to = "SP_1_S"
< 114 > construction = IWF-typl ..
< 115 > interior-wall area = 700
< 116 > next-to = "SP_1_N"
< 117 > construction = IWF-typl ..
< 118 > interior-wall area = 200
< 119 > next-to = "SP_1_E"
< 120 > construction = IWF-typl ..
< 121 > interior-wall area = 200
< 122 > next-to = "SP_1_W"
< 123 > construction = IWF-typl ..
< 124 >
< 128 > interior-wall area = 1400
< 129 > next-to = "SP_g_C"
< 130 > construction = IWF-typl ..
< 132 >
< 67 > $----- top floor
< 70 > "SP_t_N" =
< 170 >
< 171 > space x = 100 y = 50 z = 20 azimuth = 180 area = 1275
< 172 > volume = 12750
< 173 > space-conditions = PERIM ..
< 174 > exterior-wall x = 0 y = 0 azimuth = 0 h = 10
< 175 > w = 100 construction = WALL-typl ..
< 178 > window x = 0
< 179 > y = 3.0
< 180 > w = 100 h = 3.0
< 181 > glass-type = GT-typl ..
< 183 >
< 187 > interior-wall area = 1275 construction = IWF-typl

```

```

< 188 >                 next-to = "SP_1_N" ..
< 190 >
< 192 >     roof x = 0 y = 0
< 193 >         h = 15
< 194 >         w = 85
< 195 >         construction = ROOF-typl ..
< 73 >
< 74 > *SP_t_S* =
< 170 >
< 171 >     space          x = 0 y = 0 z = 20 azimuth = 0 area = 1275
< 172 >                 volume = 12750
< 173 >                 space-conditions = PERIM ..
< 174 >     exterior-wall x = 0 y = 0 azimuth = 0 h = 10
< 175 >                 w = 100 construction = WALL-typl ..
< 178 >     window        x = 0
< 179 >                 y = 3.0
< 180 >                 w = 100 h = 3.0
< 181 >                 glass-type = GT-typl ..
< 183 >
< 187 >     interior-wall  area = 1275 construction = IWF-typl
< 188 >                 next-to = "SP_1_S" ..
< 190 >
< 192 >     roof x = 0 y = 0
< 193 >         h = 15
< 194 >         w = 85
< 195 >         construction = ROOF-typl ..
< 77 >
< 79 > *SP_t_E* =
< 170 >
< 171 >     space          x = 100 y = 0 z = 20 azimuth = -90 area = 525
< 172 >                 volume = 5250
< 173 >                 space-conditions = PERIM ..
< 174 >     exterior-wall x = 0 y = 0 azimuth = 0 h = 10
< 175 >                 w = 50 construction = WALL-typl ..
< 178 >     window        x = 0
< 179 >                 y = 3.0
< 180 >                 w = 50 h = 3.0
< 181 >                 glass-type = GT-typl ..
< 183 >
< 187 >     interior-wall  area = 525 construction = IWF-typl
< 188 >                 next-to = "SP_1_E" ..
< 190 >
< 192 >     roof x = 0 y = 0
< 193 >         h = 15
< 194 >         w = 35
< 195 >         construction = ROOF-typl ..
< 84 >                 interior-wall area = 212.129989624
< 85 >                 next-to = "SP_t_N"
< 86 >                 construction = IWF-typl ..
< 87 >                 interior-wall area = 212.129989624
< 88 >                 next-to = "SP_t_S"
< 89 >                 construction = IWF-typl ..
< 91 >
< 92 > *SP_t_W* =
< 170 >
< 171 >     space          x = 0 y = 50 z = 20 azimuth = 90 area = 525
< 172 >                 volume = 5250
< 173 >                 space-conditions = PERIM ..
< 174 >     exterior-wall x = 0 y = 0 azimuth = 0 h = 10
< 175 >                 w = 50 construction = WALL-typl ..
< 178 >     window        x = 0
< 179 >                 y = 3.0
< 180 >                 w = 50 h = 3.0
< 181 >                 glass-type = GT-typl ..
< 183 >

```

```

< 187 > interior-wall area = 525 construction = IWF-typl
< 188 > next-to = "SP_1_W" ..
< 190 >
< 192 > roof x = 0 y = 0
< 193 > h = 15
< 194 > w = 35
< 195 > construction = ROOF-typl ..
< 96 > interior-wall area = 212.129989624
< 97 > next-to = "SP_t_N"
< 98 > construction = IWF-typl ..
< 99 > interior-wall area = 212.129989624
< 100 > next-to = "SP_t_S"
< 101 > construction = IWF-typl ..
< 103 >
< 104 > $----- Core space -----$
< 108 > "SP_t_C" = space x = 15 y = 15
< 109 > z = 20 azimuth = 0 area = 1400
< 110 > volume = 14000
< 111 > space-conditions=CORE ..
< 112 > interior-wall area = 700
< 113 > next-to = "SP_t_S"
< 114 > construction = IWF-typl ..
< 115 > interior-wall area = 700
< 116 > next-to = "SP_t_N"
< 117 > construction = IWF-typl ..
< 118 > interior-wall area = 200
< 119 > next-to = "SP_t_E"
< 120 > construction = IWF-typl ..
< 121 > interior-wall area = 200
< 122 > next-to = "SP_t_W"
< 123 > construction = IWF-typl ..
< 124 >
< 128 > interior-wall area = 1400
< 129 > next-to = "SP_1_C"
< 130 > construction = IWF-typl ..
< 132 >
< 134 > roof x = 15 y = 15
< 135 > h = 20
< 136 > w = 70
< 137 > construction = ROOF-typl ..
< 69 >
< 70 > end ..
< 71 > compute LOADS ..

```

REPORT- LV-B SUMMARY OF SPACES OCCURRING IN THE PROJECT

WEATHER FILE- TRY CHICAGO

NUMBER OF SPACES 15 EXTERIOR 13 INTERIOR 2

SPACE	SPACE*FLOOR MULTIPLIER	SPACE TYPE	AZIMUTH	LIGHTING (WATT / SQFT)	PEOPLE	EQUIP (WATT / SQFT)	INFILTRATION METHOD	AIR CHANGES PER HOUR	AREA (SQFT)	VOLUME (CUFT)
SP_g_N	1.0	EXT	180.0	2.00	14.2	0.00	AIR-CHANGE	0.60	1275.00	12750.00
SP_g_S	1.0	EXT	0.0	2.00	14.2	0.00	AIR-CHANGE	0.60	1275.00	12750.00
SP_g_E	1.0	EXT	-90.0	2.00	5.8	0.00	AIR-CHANGE	0.60	525.00	5250.00
SP_g_W	1.0	EXT	90.0	2.00	5.8	0.00	AIR-CHANGE	0.60	525.00	5250.00
SP_g_C	1.0	INT	0.0	2.00	14.0	0.00	AIR-CHANGE	0.80	1400.00	14000.00
SP_1_N	1.0	EXT	180.0	2.00	14.2	0.00	AIR-CHANGE	0.60	1275.00	12750.00
SP_1_S	1.0	EXT	0.0	2.00	14.2	0.00	AIR-CHANGE	0.60	1275.00	12750.00
SP_1_E	1.0	EXT	-90.0	2.00	5.8	0.00	AIR-CHANGE	0.60	525.00	5250.00
SP_1_W	1.0	EXT	90.0	2.00	5.8	0.00	AIR-CHANGE	0.60	525.00	5250.00
SP_1_C	1.0	INT	0.0	2.00	14.0	0.00	AIR-CHANGE	0.80	1400.00	14000.00
SP_t_N	1.0	EXT	180.0	2.00	14.2	0.00	AIR-CHANGE	0.60	1275.00	12750.00
SP_t_S	1.0	EXT	0.0	2.00	14.2	0.00	AIR-CHANGE	0.60	1275.00	12750.00
SP_t_E	1.0	EXT	-90.0	2.00	5.8	0.00	AIR-CHANGE	0.60	525.00	5250.00
SP_t_W	1.0	EXT	90.0	2.00	5.8	0.00	AIR-CHANGE	0.60	525.00	5250.00
SP_t_C	1.0	EXT	0.0	2.00	14.0	0.00	AIR-CHANGE	0.80	1400.00	14000.00
BUILDING TOTALS					162.0				15000.00	150000.00

REPORT- LV-D DETAILS OF EXTERIOR SURFACES IN THE PROJECT

WEATHER FILE- TRY CHICAGO

NUMBER OF EXTERIOR SURFACES 17 RECTANGULAR 17 OTHER 0
 (U-VALUE INCLUDES OUTSIDE AIR FILM; WINDOW INCLUDES FRAME, IF DEFINED)

SURFACE	SPACE	- - - W I N D O W S - - -		- - - - W A L L - - - -		- W A L L + W I N D O W S -		AZIMUTH
		U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	U-VALUE (BTU/HR-SQFT-F)	AREA (SQFT)	
SP_g_S		0.926	200.00	0.067	800.00	0.239	1000.00	NORTH
SP_1_S		0.926	300.00	0.067	700.00	0.325	1000.00	NORTH
SP_t_S		0.926	300.00	0.067	700.00	0.325	1000.00	NORTH
SP_1_W		0.926	150.00	0.067	350.00	0.325	500.00	EAST
SP_g_W		0.926	100.00	0.067	400.00	0.239	500.00	EAST
SP_t_W		0.926	150.00	0.067	350.00	0.325	500.00	EAST
SP_t_N		0.926	300.00	0.067	700.00	0.325	1000.00	SOUTH
SP_g_N		0.926	200.00	0.067	800.00	0.239	1000.00	SOUTH
SP_1_N		0.926	300.00	0.067	700.00	0.325	1000.00	SOUTH
SP_g_E		0.926	100.00	0.067	400.00	0.239	500.00	WEST
SP_t_E		0.926	150.00	0.067	350.00	0.325	500.00	WEST
SP_1_E		0.926	150.00	0.067	350.00	0.325	500.00	WEST
SP_t_N		0.000	0.00	0.168	1275.00	0.168	1275.00	ROOF
SP_t_E		0.000	0.00	0.168	525.00	0.168	525.00	ROOF
SP_t_S		0.000	0.00	0.168	1275.00	0.168	1275.00	ROOF
SP_t_W		0.000	0.00	0.168	525.00	0.168	525.00	ROOF
SP_t_C		0.000	0.00	0.168	1400.00	0.168	1400.00	ROOF
SP_g_N		0.000	0.00	0.050	1275.00	0.050	1275.00	UNDERGRND
SP_g_S		0.000	0.00	0.050	1275.00	0.050	1275.00	UNDERGRND
SP_g_E		0.000	0.00	0.050	525.00	0.050	525.00	UNDERGRND
SP_g_W		0.000	0.00	0.050	525.00	0.050	525.00	UNDERGRND
SP_g_C		0.000	0.00	0.050	1400.00	0.050	1400.00	UNDERGRND

REPORT- LV-D DETAILS OF EXTERIOR SURFACES IN THE PROJECT

WEATHER FILE- TRY CHICAGO

(CONTINUED)

	AVERAGE U-VALUE/WINDOWS (BTU/HR-SQFT-F)	AVERAGE U-VALUE/WALLS (BTU/HR-SQFT-F)	AVERAGE U-VALUE WALLS+WINDOWS (BTU/HR-SQFT-F)	WINDOW AREA (SQFT)	WALL AREA (SQFT)	WINDOW+WALL AREA (SQFT)
NORTH	0.926	0.067	0.296	800.00	2200.00	3000.00
EAST	0.926	0.067	0.296	400.00	1100.00	1500.00
SOUTH	0.926	0.067	0.296	800.00	2200.00	3000.00
WEST	0.926	0.067	0.296	400.00	1100.00	1500.00
ROOF	0.000	0.168	0.168	0.00	5000.00	5000.00
ALL WALLS	0.926	0.067	0.296	2400.00	6600.00	9000.00
WALLS+ROOFS	0.926	0.111	0.250	2400.00	11600.00	14000.00
UNDERGRND	0.000	0.050	0.050	0.00	5000.00	5000.00
BUILDING	0.926	0.092	0.198	2400.00	16600.00	19000.00

REPORT- LV-F DETAILS OF INTERIOR SURFACES IN THE PROJECT

WEATHER FILE- TRY CHICAGO

NUMBER OF INTERIOR SURFACES 34
(U-VALUE INCLUDES BOTH AIR FILMS)

SURFACE NAME	AREA (SQFT)	CONSTRUCTION NAME	SURFACE TYPE	U-VALUE (BTU/HR-SQFT-F)	ADJACENT SPACES	
					SPACE-1	SPACE-2
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_g_E	SP_g_N
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_g_E	SP_g_S
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_g_W	SP_g_N
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_g_W	SP_g_S
	700.00	IWF-typ1	QUICK STANDARD	0.500	SP_g_C	SP_g_S
	700.00	IWF-typ1	QUICK STANDARD	0.500	SP_g_C	SP_g_N
	200.00	IWF-typ1	QUICK STANDARD	0.500	SP_g_C	SP_g_E
	200.00	IWF-typ1	QUICK STANDARD	0.500	SP_g_C	SP_g_W
	1275.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_N	SP_g_N
	1275.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_S	SP_g_S
	525.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_E	SP_g_E
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_1_E	SP_1_N
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_1_E	SP_1_S
	525.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_W	SP_g_W
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_1_W	SP_1_N
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_1_W	SP_1_S
	700.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_C	SP_1_S
	700.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_C	SP_1_N
	200.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_C	SP_1_E
	200.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_C	SP_1_W
	1400.00	IWF-typ1	QUICK STANDARD	0.500	SP_1_C	SP_g_C
	1275.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_N	SP_1_N
	1275.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_S	SP_1_S
	525.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_E	SP_1_E
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_t_E	SP_t_N
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_t_E	SP_t_S
	525.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_W	SP_1_W
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_t_W	SP_t_N
	212.13	IWF-typ1	QUICK STANDARD	0.500	SP_t_W	SP_t_S
	700.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_C	SP_t_S
	700.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_C	SP_t_N
	200.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_C	SP_t_E
	200.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_C	SP_t_W
	1400.00	IWF-typ1	QUICK STANDARD	0.500	SP_t_C	SP_1_C

REPORT- LS-D BUILDING MONTHLY LOADS SUMMARY

WEATHER FILE- TRY CHICAGO

MONTH	C O O L I N G						H E A T I N G						E L E C	
	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	2.94071	15 15	40.F	35.F	46.954	-100.090	12 8	-7.F	-7.F	-303.466	6471.	25.680		
FEB	3.03121	9 16	23.F	19.F	78.665	-88.189	6 8	22.F	22.F	-244.194	5855.	25.680		
MAR	4.78147	3 16	79.F	62.F	156.169	-67.232	24 8	6.F	5.F	-276.647	6780.	25.680		
APR	18.25086	27 16	84.F	61.F	215.393	-31.668	8 8	30.F	27.F	-207.410	6780.	25.680		
MAY	23.73145	21 13	85.F	75.F	232.219	-18.483	6 7	37.F	33.F	-117.475	6163.	25.680		
JUN	44.88414	4 15	85.F	67.F	243.338	-5.474	1 5	48.F	47.F	-70.638	6780.	25.680		
JUL	69.09688	13 15	97.F	77.F	302.914	-1.320	6 4	60.F	54.F	-37.546	6780.	25.680		
AUG	55.78048	26 16	94.F	76.F	272.907	-2.272	5 5	55.F	54.F	-49.795	6471.	25.680		
SEP	34.12464	11 15	86.F	72.F	250.087	-13.255	22 5	35.F	31.F	-111.728	6780.	25.680		
OCT	16.95434	5 15	74.F	62.F	167.687	-28.918	21 5	30.F	29.F	-137.386	6471.	25.680		
NOV	6.33158	2 14	75.F	61.F	167.828	-62.562	15 4	26.F	25.F	-178.102	5855.	25.680		
DEC	2.91600	10 15	41.F	35.F	59.871	-90.931	26 7	15.F	15.F	-212.285	6780.	25.680		
TOTAL	282.824					-510.395					77965.			
MAX					302.914					-303.466		25.680		

Metric Input/Output Example

LDL PROCESSOR INPUT DATA

Thu Nov 11 11:30:36 1993LDL RUN 1

```
* 1 * INPUT LOADS INPUT-UNITS=METRIC OUTPUT-UNITS=METRIC ..
* 2 *
* 3 * TITLE LINE-1 * METRIC INPUT/OUTPUT EXAMPLE *
* 4 *   LINE-2 * SMALL BAR/LOUNGE *
* 5 *   LINE-3 * SYSTEM 4: PKG PSZ WATER-COOLED UNIT *
* 6 *   LINE-4 * WITH WATER-SIDE ECONOMIZER * ..
* 7 *
* 8 * $ Note: a metric LOADS input will not work with the
* 9 * $ preassembled materials and constructions library, BDL LIB,
* 10 * $ which is in English units. You will have to create your
* 11 * $ own metric version of BDL LIB by doing a LIBRARY-INPUT LOADS
* 12 * $ run with INPUT-UNITS=METRIC (see Reference Manual (2.1A),
* 13 * $ pp. II.21.147,152). Alternatively, as in this example,
* 14 * $ you can remove BDL LIB from your run control file and enter
* 15 * $ metric constructions in your LOADS input using the MATERIALS,
* 16 * $ LAYERS and CONSTRUCTION commands.
* 17 *
* 18 * $ This example demonstrates how LOADS hourly report variables
* 19 * $ can be passed to SYSTEMS and printed in SYSTEMS hourly
* 20 * $ reports.
* 21 *
* 22 * ABORT ERRORS .. LIST WARNINGS ..
* 23 *
* 24 * RUN-PERIOD   JAN 1 1988 THRU DEC 31 1988 ..
* 25 *
* 26 * $ CHICAGO $
* 27 * BUILDING-LOCATION  LATITUDE=42
* 28 *                   LONGITUDE=88
* 29 *                   ALTITUDE=186 $ meters $
* 30 *                   TIME-ZONE=6
* 31 *                   AZIMUTH=0 ..
* 32 *
* 33 * LOADS-REPORT   SUMMARY=(LS-A,LS-C,LS-D)
* 34 *               VERIFICATION=(LV-C,LV-M) ..
* 35 *
* 36 * $ OCCUPANCY $
* 37 *
* 38 * OC1 = DAY-SCHEDULE (1,24) VALUES=(.2,.2,0,0,0,0,
* 39 *   .4,.4,.2,.2,.2,.3,.6,.1,.1,.1,.5,.7,.5,.5,.7,.8,.8,.6) ..
* 40 * OC2 = DAY-SCHEDULE (1,24) VALUES=(.4,.4,0,0,0,0,
* 41 *   .2,.2,.1,.1,.1,.2,.4,.2,.2,.2,.5,.7,.8,.8,.9,.9,.9,.5) ..
* 42 * OC3 = DAY-SCHEDULE (1,24) VALUES=(.4,.4,0,0,0,0,
* 43 *   0,0,0,.2,.3,.4,.5,.5,.6,.7,.7,.8,.8,.6,.5,.5,.6,.6) ..
* 44 * OCCUP = SCHEDULE THRU DEC 31 (WD) OC1 (SAT) OC2 (SUN,HOL) OC3 ..
* 45 *
* 46 * $ LIGHTING $
* 47 *
* 48 * L1 = DAY-SCHEDULE (1,2) VALUES=(.5) (3,6) (.1) (7,9) (.5)
* 49 *   (10,18) (.4) (19,24) (1) ..
* 50 * L2 = DAY-SCHEDULE (1,2) VALUES=(.5) (3,6) (.1) (7,12) (.5)
* 51 *   (13,18) (.8) (19,24) (1) ..
* 52 * L3 = DAY-SCHEDULE (1,2) VALUES=(.5) (3,9) (.1) (10,12) (.4)
* 53 *   (13,17) (.6) (18,19) (1) (20,24) (.5) ..
* 54 * LIGHTS = SCHEDULE THRU DEC 31 (WD) L1 (SAT) L2 (SUN,HOL) L3 ..
* 55 *
* 56 * $ CONSTRUCTIONS $
* 57 *
* 58 * WDSHINGLE = MATERIAL THICKNESS   = .0178 $ m $
```

```

* 59 *          CONDUCTIVITY = .1154 $ W/m-K $
* 60 *          DENSITY      = 512.6 $ kg/m3 $
* 61 *          SPECIFIC-HEAT = 1255 $ J/kg-K $ ..
* 62 *
* 63 * PLYWOOD = MATERIAL THICKNESS = .0127 $ m $
* 64 *          CONDUCTIVITY = .1154 $ W/m-K $
* 65 *          DENSITY      = 544.6 $ kg/m3 $
* 66 *          SPECIFIC-HEAT = 1213 $ J/kg-K $ ..
* 67 *
* 68 * POLYSTYR = MATERIAL THICKNESS = .0191 $ m $
* 69 *          CONDUCTIVITY = .0346 $ W/m-K $
* 70 *          DENSITY      = 28.8 $ kg/m3 $
* 71 *          SPECIFIC-HEAT = 1213 $ J/kg-K $ ..
* 72 *
* 73 * GYPBOARD = MATERIAL THICKNESS = .0191 $ m $
* 74 *          CONDUCTIVITY = .1602 $ W/m-K $
* 75 *          DENSITY      = 800.9 $ kg/m3 $
* 76 *          SPECIFIC-HEAT = 837 $ J/kg-K $ ..
* 77 *
* 78 * BUILTUPRF = MATERIAL THICKNESS = .0095 $ m $
* 79 *          CONDUCTIVITY = .1624 $ W/m-K $
* 80 *          DENSITY      = 1121.3 $ kg/m3 $
* 81 *          SPECIFIC-HEAT = 1464 $ J/kg-K $ ..
* 82 *
* 83 * ACOUSTILE = MATERIAL THICKNESS = .0127 $ m $
* 84 *          CONDUCTIVITY = .0571 $ W/m-K $
* 85 *          DENSITY      = 288.3 $ kg/m3 $
* 86 *          SPECIFIC-HEAT = 1339 $ J/kg-K $ ..
* 87 *
* 88 * AIRLAYER = MATERIAL RESISTANCE = .162 $ m2-K/W $ ..
* 89 *
* 90 *
* 91 * WA1=LAYERS MATERIAL = (WDSHINGLE, PLYWOOD, POLYSTYR, GYPBOARD) ..
* 92 * RF1=LAYERS MATERIAL = (BUILTUPRF, PLYWOOD, POLYSTYR, AIRLAYER, ACOUSTILE)
* 93 *          INSIDE-FILM-RES = .108 $ m2K/W $ ..
* 94 *
* 95 * S-WALL   = CONSTRUCTION LAYERS=WA1 ..
* 96 * ROF     = CONSTRUCTION LAYERS=RF1 ..
* 97 * FOUND   = CONSTRUCTION U-VALUE=1.48 $ W/m2-K $ ..
* 98 * DR1     = CONSTRUCTION U-VALUE=3.35 $ W/m2-K $ ..
* 99 * GLASS1  = GLASS-TYPE GLASS-TYPE-CODE=3 PANES=1 .. $ CLEAR 6.3mm PLATE
* 100 *
* 101 * SET-DEFAULT FOR EXTERIOR-WALL HEIGHT=4.88 $ m $
* 102 *          CONSTRUCTION=S-WALL ..
* 103 *
* 104 * SET-DEFAULT FOR WINDOW GLASS-TYPE=GLASS1 HEIGHT=3.66 $ m $ ..
* 105 *
* 106 * BLDG=   SPACE AREA          = 200.72 $ m2 $
* 107 *          VOLUME             = 734.0 $ m3 $
* 108 *          LIGHTING-W/AREA     = 11.4 $ W/m2 $
* 109 *          LIGHTING-SCHEDULE = LIGHTS
* 110 *          LIGHTING-TYPE      = REC-FLUOR-NV
* 111 *          LIGHT-TO-SPACE     = 1.0
* 112 *          EQUIPMENT-W/AREA   = 5.38 $ W/m2 $
* 113 *          EQUIP-SCHEDULE     = LIGHTS
* 114 *          AREA/PERSON        = 4.18 $ m2 $
* 115 *          PEOPLE-HEAT-GAIN   = 161 $ W $
* 116 *          PEOPLE-SCHEDULE    = OCCUP
* 117 *          INF-METHOD       = AIR-CHANGE
* 118 *          AIR-CHANGES/HR    = .3
* 119 *          INF-SCHEDULE      = OCCUP ..
* 120 *
* 121 *          EXTERIOR-WALL WIDTH=12.19 $ m $ AZIMUTH=0 ..
* 122 *
* 123 *          EXTERIOR-WALL WIDTH=16.46 $ m $ AZIMUTH=90 ..

```

```

* 124 *
* 125 *          DOOR          HEIGHT=2.13 $ m $
* 126 *                      WIDTH=0.91 $ m $
* 127 *                      CONSTRUCTION=DR1 ..
* 128 *
* 129 *          EXTERIOR-WALL  WIDTH=12.19 $ m $ AZIMUTH=180 ..
* 130 *
* 131 *          WIN-1 = WINDOW  WIDTH=9.14 $ m $
* 132 *                      OVERHANG-W=15.24 $ m $
* 133 *                      OVERHANG-D=3.05 $ m $
* 134 *                      OVERHANG-A=3.05 $ m $
* 135 *                      OVERHANG-B=0.61 $ m $ ..
* 136 *
* 137 *          $ WEST WALL ABUTS ADJOINING BUILDING $
* 138 *
* 139 *          UNDERGROUND-WALL AREA=15.79 $ m2 $
* 140 *                      CONSTRUCTION=FOUND ..
* 141 *
* 142 *          ROOF           HEIGHT=12.19 $ m $
* 143 *                      WIDTH=16.46 $ m $
* 144 *                      CONSTRUCTION=ROF
* 145 *                      TILT=0 ..
* 146 *
* 147 * $ Example of passing LOADS hourly report variables to
* 148 * $ SYSTEMS hourly reports
* 149 *
* 150 *          HR-SCH-1      =SCHEDULE      THRU JAN 4 (ALL) (1,24) VALUES=(0)
* 151 *                      THRU JAN 5 (ALL) (1,24) VALUES=(1)
* 152 *                      THRU DEC 31 (ALL) (1,24) VALUES=(0) ..
* 153 *
* 154 *          LRB-1        =REPORT-BLOCK   VARIABLE-TYPE=GLOBAL
* 155 *                      VARIABLE-LIST=(15) .. $ total horizontal solar $
* 156 *
* 157 *          LRB-2        =REPORT-BLOCK   VARIABLE-TYPE=WIN-1
* 158 *                      VARIABLE-LIST=(15) .. $ solar gain thru window $
* 159 *
* 160 *          LDS-REP-1    =HOURLY-REPORT  REPORT-SCHEDULE=HR-SCH-1
* 161 *                      OPTION=BINARY-FILE $ to pass Loads hourly variables
* 162 *                      $ to Systems
* 163 *                      REPORT-BLOCK=(LRB-1,LRB-2) ..
* 164 *
* 165 *          END ..
* 166 *          COMPUTE LOADS ..
* 167 *          INPUT SYSTEMS INPUT-UNITS=METRIC OUTPUT-UNITS=METRIC ..

```

SDL PROCESSOR INPUT DATA

Thu Nov 11 11:30:36 1993SDL RUN 1

```

* 168 *
* 169 * SYSTEMS-REPORT SUMMARY=(SS-A,SS-J,SS-O) ..
* 170 *
* 171 * FANSON = SCHEDULE THRU DEC 31 (MON,SAT) (1,24) VALUES=(1)
* 172 *           (SUN,HOL) (1,2) VALUES=(1) (3,9) (0) (10,24) (1) ..
* 173 * C-SETPT = SCHEDULE THRU DEC 31 (ALL) (1,24) TEMP=(24.4) .. $ deg C $
* 174 * H-SETPT = SCHEDULE THRU DEC 31 (ALL) (1,24) TEMP=(22.2) .. $ deg C $
* 175 *
* 176 * ENV = ZONE-CONTROL DESIGN-HEAT-T = 22.2 $ deg C $
* 177 *           DESIGN-COOL-T = 23.3 $ deg C $
* 178 *           HEAT-TEMP-SCH = H-SETPT
* 179 *           COOL-TEMP-SCH = C-SETPT ..
* 180 *
* 181 * BLDG = ZONE ZONE-CONTROL = ENV
* 182 *           OA-FLOW/PER = 25.5 $ m3/h $
* 183 *           FLOW/AREA = 12.8 $ m3/h-m2 $ ..
* 184 *
* 185 *
* 186 * SYS1 =SYSTEM SYSTEM-TYPE = PSZ
* 187 *           OA-CONTROL = FIXED
* 188 *           SUPPLY-FLOW = 4748 $ m3/h $
* 189 *           HEATING-CAPACITY = -35145 $ W $
* 190 *           MAX-SUPPLY-T = 37.8 $ deg C $
* 191 *           MIN-SUPPLY-T = 12.8 $ deg C $
* 192 *           SUPPLY-STATIC = 63.5 $ mm water $
* 193 *           SUPPLY-EFF = .47
* 194 *           SIZING-RATIO = 1.2
* 195 *           COOL-SIZING-RAT = .833
* 196 *           HEAT-SIZING-RAT = .75
* 197 *           F-SCH = FANSON
* 198 *           ZONE-NAMES = (BLDG)
* 199 *           WS-ECONO = YES
* 200 *           CONDENSER-TYPE = WATER-COOLED ..
* 201 *
* 202 * WS-ECON =PLANT-ASSIGNMENT
* 203 *           SYSTEM-NAMES = (SYS1)
* 204 *           CIRC-PUMP-TYPE = VARIABLE-FLOW
* 205 *           TWR-SET-POINT = 12.8 $ deg C $
* 206 *           MIN-TWR-WTR-T = 12.8 $ deg C $
* 207 *           DHW-FLOW = 2.52 $ liters/min $
* 208 *           DHW-SCH = DOMHW ..
* 209 *
* 210 * D1 = DAY-SCHEDULE (1,7) VALUES=(0)
* 211 *           (8,21) (.1,.2,.3,.4,.55,.6,.6,.45,.4,.45,.45,.4,.3,.3)
* 212 *           (22,24) (0) ..
* 213 * D2 = DAY-SCHEDULE (1,7) VALUES=(0)
* 214 *           (8,22) (.15,.2,.25,.4,.5,.55,.55,.45,.45,.45,.45,.4,.35,
* 215 *           .25,.2) (23,24) (0) ..
* 216 * D3 = DAY-SCHEDULE (1,9) VALUES=(0)
* 217 *           (10,19) (.1,.25,.3,.35,.35,.3,.3,.35,.3,.2)
* 218 *           (20,24) (0) ..
* 219 * DOMHW = SCHEDULE THRU DEC 31 (WD) D1 (SAT) D2 (SUN,HOL) D3 ..
* 220 *
* 221 * HR-SCH-2 =SCHEDULE THRU JAN 4 (ALL) (1,24) VALUES=(0)
* 222 *           THRU JAN 5 (ALL) (1,24) VALUES=(1)
* 223 *           THRU DEC 31 (ALL) (1,24) VALUES=(0) ..
* 224 *

```

```
* 225 * SRB-1      =REPORT-BLOCK  VARIABLE-TYPE=LOADS-DATA $ to get hourly $
* 226 *                                     $ variables from Loads $
* 227 *          VARIABLE-LIST=(1) ..
* 228 *
* 229 * SRB-2      =REPORT-BLOCK  VARIABLE-TYPE=GLOBAL
* 230 *          VARIABLE-LIST=(8) .. $ outside drybulb $
* 231 *
* 232 * SRB-3      =REPORT-BLOCK  VARIABLE-TYPE=BLDG
* 233 *          VARIABLE-LIST=(6,7,8) .. $ zone temp, temp setp, extract rate $
* 234 *
* 235 * SYS-REP-1  =HOURLY-REPORT  REPORT-SCHEDULE=HR-SCH-2
* 236 *          REPORT-BLOCK=(SRB-1,SRB-2,SRB-3) ..
* 237 *
* 238 * END ..
* 239 * COMPUTE SYSTEMS ..
* 240 *
* 241 * INPUT PLANT INPUT-UNITS=METRIC OUTPUT-UNITS=METRIC ..
```


P D L P R O C E S S O R I N P U T D A T A

Thu Nov 11 11:30:36 1993PDL RUN 1

```
* 242 *
* 243 * WS-ECON = PLANT-ASSIGNMENT ..
* 244 * PLANT-REPORT          SUMMARY=(BEPS,BEPU) ..
* 245 *
* 246 * DWH= PLANT-EQUIPMENT  TYPE= DHW-HEATER
* 247 *                      SIZE= .0088 ..    $ Megawatts $
* 248 *
* 249 * $ Choose cubic meters as the unit for natural gas: $
* 250 *
* 251 * ENERGY-RESOURCE      RESOURCE = NATURAL-GAS
* 252 *                      ENERGY/UNIT = 10860 $ Wh/m3, based on 1050 Btu/ft3 $
* 253 *                      UNIT-NAME   = M3
* 254 *                      DEM-UNIT-NAME = M3/HR ..
* 255 *
* 256 * END ..
* 257 * COMPUTE PLANT ..
* 258 *
* 259 * INPUT ECONOMICS INPUT-UNITS=METRIC OUTPUT-UNITS=METRIC ..
```

EDL PROCESSOR INPUT DATA

Thu Nov 11 11:30:36 1993EDL RUN 1

```

* 260 *
* 261 * ECONOMICS-REPORT SUMMARY=(ES-D,ES-E) ..
* 262 *
* 263 * $ following costs are in US dollars $
* 264 *
* 265 * ELEC-COST = UTILITY-RATE RESOURCE = ELECTRICITY
* 266 * MONTH-CHGS = (21.75)
* 267 * DEMAND-CHGS = (.81)
* 268 * BLOCK-CHARGES = (E-SM,E-WN) ..
* 269 *
* 270 * E-SM = BLOCK-CHARGE BLOCK-SCH = SEASON
* 271 * SCH-FLAG = 2
* 272 * BLOCK1-TYPE = ENERGY
* 273 * BLOCK1-DATA = (1250,.0829)
* 274 * BLOCK2-TYPE = KWH/KW
* 275 * BLOCK2-DATA = (125,.0829,0
* 276 * 1,.0514,0) ..
* 277 *
* 278 * E-WN = BLOCK-CHARGE BLOCK-SCH = SEASON
* 279 * SCH-FLAG = 1
* 280 * BLOCK1-TYPE = ENERGY
* 281 * BLOCK1-DATA = (1250,.0778)
* 282 * BLOCK2-TYPE = KWH/KW
* 283 * BLOCK2-DATA = (125,.0778,0,
* 284 * 1,.0514,0) ..
* 285 *
* 286 * SEASON = SCHEDULE THRU APR 30 (ALL) (1,24) VALUES=(1)
* 287 * THRU OCT 31 (ALL) (1,24) VALUES=(2)
* 288 * THRU DEC 31 (ALL) (1,24) VALUES=(1) ..
* 289 *
* 290 * GAS-COST = UTILITY-RATE RESOURCE = NATURAL-GAS
* 291 * MONTH-CHGS = (10.73)
* 292 * BLOCK-CHARGES = (GAS-CH) ..
* 293 *
* 294 * $ 0.22 dollars/m3 for first 1200 m3, 0.15 dollars/m3 above that: $
* 295 *
* 296 * GAS-CH = BLOCK-CHARGE BLOCK1-TYPE = ENERGY
* 297 * BLOCK1-DATA = (1200,.22,
* 298 * 1,.15) ..
* 299 *
* 300 * END ..
* 301 * COMPUTE ECONOMICS ..

```

***** END-OF-FILE READ ON INPUT FILE.

DOE-2 UNITS TABLE

	ENGLISH	MULTIPLIED BY	GIVES	METRIC	MULTIPLIED BY	GIVES	ENGLISH
1			1.000000			1.000000	
2			1.000000			1.000000	
3	BTU		0.293000	WH		3.412969	BTU
4	BTU/HR		0.293000	WATT		3.412969	BTU/HR
5	BTU/LB-F	4183.830078		J/KG-K		0.000239	BTU/LB-F
6	BTU/HR-SQFT-F	5.674460		W/M2-K		0.176228	BTU/HR-SQFT-F
7	DEGREES		1.000000	DEGREES		1.000000	DEGREES
9	SQFT		0.092903	M2	10.763915		SQFT
10	CUFT		0.028317	M3	35.314724		CUFT
11	LB/HR		0.453592	KG/HR		2.204624	LB/HR
12	LB/CUFT	16.018459		KG/M3		0.062428	LB/CUFT
13	MPH		0.447040	M/S		2.236936	MPH
14	BTU/HR-F		0.527178	W/K		1.896893	BTU/HR-F
15	FT		0.304800	M		3.280840	FT
16	BTU/HR-FT-F		1.729600	W/M-K		0.578168	BTU/HR-FT-F
17	BTU/HR- SQFT		3.152480	WATT /M2		0.317211	BTU/HR- SQFT
18	IN		2.540000	CM		0.393701	IN
19	UNITS/IN		0.393700	UNITS/CM		2.540005	UNITS/IN
20	UNITS		1.000000	UNITS		1.000000	UNITS
21	LB		0.453592	KG		2.204624	LB
22	FRAC.OR MULT.		1.000000	FRAC.OR MULT.		1.000000	FRAC.OR MULT.
23	HOURS		1.000000	HRS		1.000000	HOURS
24	PERCENT-RH		1.000000	PERCENT-RH		1.000000	PERCENT-RH
25	CFM		1.699010	M3/H		0.588578	CFM
26	IN-WATER	25.400000		MM-WATER		0.039370	IN-WATER
27	LB/SQFT	4.882400		KG/M2		0.204817	LB/SQFT
28	KW		1.000000	KW		1.000000	KW
29	W/SQFT	10.763920		W/M2		0.092903	W/SQFT
30	THERMS	25.000000		THERMIES		0.040000	THERMS
31	KNOTS	0.514440		M/SEC		1.943861	KNOTS
32	HR-SQFT-F /BTU	0.176228		M2-K /W	5.674467		HR-SQFT-F /BTU
33	\$DOLLARS	1.000000		\$DOLLARS		1.000000	\$DOLLARS
34	MBTU/HR	0.293000		MWATT		3.412969	MBTU/HR
35	YEARS	1.000000		YEARS		1.000000	YEARS
36	\$/HR	1.000000		\$/HR		1.000000	\$/HR
37	HRS/YEARS	1.000000		HRS/YEARS		1.000000	HRS/YEARS
38	PERCENT	1.000000		PERCENT		1.000000	PERCENT
39	\$/MONTH	1.000000		\$/MONTH		1.000000	\$/MONTH
40	GALLONS/MIN/TON	1.078000		LITERS/MIN/KW		0.927644	GALLONS/MIN/TON
41	BTU/LB	0.645683		WH/KG		1.548748	BTU/LB
42	LBS/SQIN-GAGE	68.947571		MBAR-GAGE		0.014504	LBS/SQIN-GAGE
43	\$/UNIT	1.000000		\$/UNIT		1.000000	\$/UNIT
44	BTU/HR/PERSON	0.293000		W/PERSON		3.412969	BTU/HR/PERSON
45	LBS/LB	1.000000		KGS/KG		1.000000	LBS/LB
46	BTU/BTU	1.000000		KWH/KWH		1.000000	BTU/BTU
47	LBS/KW	0.453590		KG/KW		2.204634	LBS/KW
48	REV/MIN	1.000000		REV/MIN		1.000000	REV/MIN
49	KW/TON	1.000000		KW/TON		1.000000	KW/TON
50	MBTU	0.293000		MWH		3.412969	MBTU
51	GAL	3.785410		LITER		0.264172	GAL
52	GAL/MIN	3.785410		LITERS/MIN		0.264172	GAL/MIN
53	BTU/F	1897.800049		J/K		0.000527	BTU/F
54	UNITS/HR	1.000000		UNITS/HR		1.000000	UNITS/HR
55	\$/UNIT-HR	1.000000		\$/UNIT-HR		1.000000	\$/UNIT-HR
56	KW/CFM	0.588500		KW/M3/HR		1.699235	KW/CFM
57	BTU/SQFT-F	20428.400391		J/M2-K		0.000049	BTU/SQFT-F
58	HR/HR	1.000000		HR/HR		1.000000	HR/HR

59	BTU/FT-F	6226.479980	J/M-K	0.000161	BTU/FT-F
60	R	0.555556	K	1.799999	R
61	INCH MER	33.863800	MBAR	0.029530	INCH MER
62	UNITS/GAL/MIN	0.264170	UNITS/LITER/MIN	3.785441	UNITS/GAL/MIN
63	(HR-SQFT-F/BTU) 2	0.031056	(M2-K /W) 2	32.199585	(HR-SQFT-F/BTU) 2
64	KBTU/HR	0.293000	KW	3.412969	KBTU/HR
65	KBTU	0.293000	KWH	3.412969	KBTU
66	CFM	0.471900	L/S	2.119093	CFM
67	CFM/SQFT	18.288000	M3/H-M2	0.054681	CFM/SQFT
68	1/R	1.799900	1/K	0.555586	1/R
69	1/KNOT	1.943860	SEC/M	0.514440	1/KNOT
70	FOOTCANDLES	10.763910	LUX	0.092903	FOOTCANDLES
71	FOOTLAMBERT	3.426259	CANDELA/M2	0.291864	FOOTLAMBERT
72	LUMEN / WATT	1.000000	LUMEN / WATT	1.000000	LUMEN / WATT
73	KBTU/SQFT-YR	3.152480	KWH/M2-YR	0.317211	KBTU/SQFT-YR

DATA FOR SPACE BLDG

LOCATION OF ORIGIN IN
 BUILDING COORDINATES

XB (M)	YB (M)	ZB (M)	SPACE AZIMUTH (DEG)	SPACE*FLOOR MULTIPLIER	HEIGHT (M)	AREA (M2)	VOLUME (M3)
0.00	0.00	0.00	0.00	1.0	3.66	200.72	734.00

TOTAL NUMBER OF SURFACES	NUMBER OF EXTERIOR SURFACES	NUMBER OF INTERIOR SURFACES	NUMBER OF UNDERGROUND SURFACES	DAYLIGHTING	SUNSPACE
5	4	0	1	NO	NO

NUMBER OF SUBSURFACES

TOTAL	EXTERIOR WINDOWS	DOORS	INTERIOR WINDOWS
2	1	1	0

FLOOR WEIGHT (KG/M2)	CALCULATION TEMPERATURE (C)
341.8	21.1

INFILTRATION

SCHEDULE	INFILTRATION CALCULATION METHOD	FLOW RATE (M3/H-M2)	AIR CHANGES PER HOUR	HEIGHT TO NEUTRAL ZONE (M)
OCCUP	AIR-CHANGE	0.00	0.30	0.0

PEOPLE

SCHEDULE	NUMBER	AREA PER PERSON (M2)	PEOPLE ACTIVITY (WATT)	PEOPLE SENSIBLE (WATT)	PEOPLE LATENT (WATT)
OCCUP	48.0	4.2	161.0	0.0	0.0

LIGHTING

SCHEDULE	LIGHTING TYPE	LOAD (WATTS/ M2)	LOAD (KW)	FRACTION OF LOAD TO SPACE
LIGHTS	REC-FLUOR-NV	11.40	0.00	1.00

ELECTRICAL EQUIPMENT

SCHEDULE	ELEC LOAD (WATTS/ M2)	ELEC LOAD (KW)	FRACTION OF LOAD TO SPACE	
			SENSIBLE	LATENT
LIGHTS	5.38	0.00	1.00	0.00

EXTERIOR SURFACES (U-VALUE EXCLUDES OUTSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (M2)	WIDTH (M)	HEIGHT (M)	CONSTRUCTION	U-VALUE		SURFACE TYPE
						(W/M2-K)		
	1.0	59.49	12.19	4.88	S-WALL	0.948		DELAYED
	1.0	80.32	16.46	4.88	S-WALL	0.948		DELAYED
	1.0	59.49	12.19	4.88	S-WALL	0.948		DELAYED
	1.0	200.65	16.46	12.19	ROF	0.824		DELAYED

SURFACE	AZIMUTH (DEG)	TILT (DEG)	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SPACE COORDINATES		
			XB (M)	YB (M)	ZB (M)	X (M)	Y (M)	Z (M)
	0.0	90.0	0.00	0.00	0.00	0.00	0.00	0.00
	90.0	90.0	0.00	0.00	0.00	0.00	0.00	0.00
	180.0	90.0	0.00	0.00	0.00	0.00	0.00	0.00
	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00

UNDERGROUND SURFACES (U-VALUE INCLUDES INSIDE AIR FILM)

SURFACE	MULTIPLIER	AREA (M2)	CONSTRUCTION	U-VALUE (W/M2-K)
	1.0	15.79	FOUND	1.48

EXTERIOR WINDOWS (U-VALUE INCLUDES OUTSIDE AIR FILM)

WINDOW	MULTIPLIER	GLASS AREA (M2)	GLASS SHADING COEFF	NUMBER OF PANES	GLASS TYPE CODE	SET-BACK (M)	GLASS WIDTH (M)	GLASS HEIGHT (M)	CENTER-OF-GLASS U-VALUE		GLASS VISIBLE TRANS
									(W/M2-K)		
WIN-1	1.0	33.45	1.00	1	3	0.00	9.14	3.66	5.796		0.900

METRIC INPUT/OUTPUT EXAMPLE
SYSTEM 4: PKG PSZ WATER-COOLED UNIT
REPORT- LV-C DETAILS OF SPACE

SMALL BAR/LOUNGE
WITH WATER-SIDE ECONOMIZER
BLDG

DOE-2.1E-001 Thu Nov 11 11:30:36 1993LDL RUN 1

WEATHER FILE- TRY CHICAGO

----- (CONTINUED) -----

WINDOW	LOCATED IN SURFACE	LOCATION OF ORIGIN IN BUILDING COORDINATES			LOCATION OF ORIGIN IN SURFACE COORDINATES	
		XB (M)	YB (M)	ZB (M)	X (M)	Y (M)
WIN-1		0.00	0.00	0.00	0.00	0.00

*** BUILDING ***

FLOOR AREA 2161 SQFT 201 SQMT
 VOLUME 25921 CUFT 734 CUMT

TIME	COOLING LOAD		HEATING LOAD	
	JUN 20	4PM	JAN 12	6AM
DRY-BULB TEMP	90F	32C	-5F	-21C
WET-BULB TEMP	77F	25C	-6F	-21C

	SENSIBLE		LATENT		SENSIBLE			
	(KBTU/H)	(KW)	(KBTU/H)	(KW)	(KBTU/H)	(KW)		
WALL CONDUCTION	8.115	2.378	0.000	0.000	-19.543	-5.726		
ROOF CONDUCTION	17.543	5.140	0.000	0.000	-22.561	-6.610		
WINDOW GLASS+FRM COND	5.604	1.642	0.000	0.000	-21.145	-6.195		
WINDOW GLASS SOLAR	10.594	3.104	0.000	0.000	1.840	0.539		
DOOR CONDUCTION	0.333	0.097	0.000	0.000	-0.713	-0.209		
INTERNAL SURFACE COND	0.000	0.000	0.000	0.000	0.000	0.000		
UNDERGROUND SURF COND	-0.532	-0.156	0.000	0.000	-1.330	-0.390		
OCCUPANTS TO SPACE	8.350	2.446	8.954	2.624	1.323	0.388		
LIGHT TO SPACE	4.125	1.209	0.000	0.000	2.187	0.641		
EQUIPMENT TO SPACE	2.032	0.595	0.000	0.000	0.819	0.240		
PROCESS TO SPACE	0.000	0.000	0.000	0.000	0.000	0.000		
INFILTRATION	1.497	0.439	2.815	0.825	0.000	0.000		
TOTAL	57.658	16.894	11.770	3.449	-59.122	-17.323		
TOTAL LOAD	69.428 KBTU/H		20.342 KW		-59.122 KBTU/H		-17.323 KW	
TOTAL LOAD / AREA	32.13BTU/H.SQFT		101.348 W /SQMT		27.365BTU/H.SQFT		86.304 W /SQMT	

 * NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR *
 * LOADS *
 * 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION *
 * IN CONSIDERATION *

MONTH	- - - - - C O O L I N G - - - - -					- - - - - H E A T I N G - - - - -					- - - E L E C - - -	
	COOLING ENERGY (MWH)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KW)	HEATING ENERGY (MWH)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KW)	ELEC TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.14665	25 13	7.C	4.C	7.095	-5.189	12 6	-21.C	-21.C	-17.323	1308.	3.368
FEB	0.19079	17 13	4.C	1.C	7.393	-4.385	4 6	-14.C	-14.C	-15.216	1180.	3.368
MAR	0.28203	3 17	26.C	16.C	7.694	-2.909	24 6	-13.C	-14.C	-15.061	1313.	3.368
APR	1.52560	27 17	29.C	17.C	11.227	-1.209	9 5	-3.C	-4.C	-9.629	1271.	3.368
MAY	2.43285	21 12	31.C	24.C	14.436	-0.547	7 5	1.C	-2.C	-7.902	1308.	3.368
JUN	4.07833	20 15	32.C	25.C	16.894	-0.127	1 5	9.C	8.C	-3.853	1271.	3.368
JUL	5.99154	13 17	37.C	25.C	16.233	-0.011	6 5	16.C	13.C	-1.592	1315.	3.368
AUG	5.10707	22 14	28.C	21.C	15.445	-0.018	5 5	13.C	12.C	-2.203	1306.	3.368
SEP	2.69067	19 15	30.C	18.C	13.267	-0.392	23 5	2.C	1.C	-7.410	1264.	3.368
OCT	1.62448	10 15	20.C	12.C	11.420	-0.983	21 5	-1.C	-2.C	-8.982	1308.	3.368
NOV	0.61120	2 13	23.C	16.C	13.387	-2.679	15 6	-2.C	-3.C	-10.955	1257.	3.368
DEC	0.06493	10 15	5.C	2.C	6.029	-4.625	26 7	-9.C	-9.C	-13.919	1299.	3.368
TOTAL	24.746					-23.072					15401.	
MAX					16.894					-17.323		3.368

METRIC INPUT/OUTPUT EXAMPLE
 SYSTEM 4: PKG PS2 WATER-COOLED UNIT
 REPORT- SV-A SYSTEM DESIGN PARAMETERS

SMALL BAR/LOUNGE
 WITH WATER-SIDE ECONOMIZER
 SYS1

DOE-2.1E-001 Thu Nov 11 11:30:36 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

SYSTEM NAME	SYSTEM TYPE	ALTITUDE MULTIPLIER	FLOOR AREA (M2)	MAX PEOPLE									
SYS1	PS2	1.020	200.7	48.									
SUPPLY FAN (M3/H)	ELEC (KW)	DELTA-T (C)	RETURN FAN (M3/H)	ELEC (KW)	DELTA-T (C)	OUTSIDE AIR RATIO	COOLING CAPACITY (KW)	SENSIBLE (SHR)	HEATING CAPACITY (KW)	COOLING EIR (KWH/KWH)	HEATING EIR (KWH/KWH)		
5812.	2.094	1.1	0.	0.000	0.0	0.215	31.544	0.824	-26.359	0.24	0.20		
ZONE NAME		SUPPLY FLOW (M3/H)	EXHAUST FLOW (M3/H)	FAN (KW)	MINIMUM FLOW RATIO	OUTSIDE AIR FLOW (M3/H)	COOLING CAPACITY (KW)	SENSIBLE (SHR)	EXTRACTION RATE (KW)	HEATING CAPACITY (KW)	ADDITION RATE (KW)	MULTIPLIER	
BLDG		5812.	0.	0.000	1.000	1249.	0.00	0.00	20.46	0.00	-19.42	1.0	

METRIC INPUT/OUTPUT EXAMPLE
 SYSTEM 4: PKG PSZ WATER-COOLED UNIT
 REPORT- SS-A SYSTEM MONTHLY LOADS SUMMARY FOR

SMALL BAR/LOUNGE
 WITH WATER-SIDE ECONOMIZER
 SYS1

DOE-2.1E-001 Thu Nov 11 11:30:36 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

----- COOLING -----						----- HEATING -----					----- ELEC -----	
MONTH	COOLING ENERGY (MWH)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KW)	HEATING ENERGY (MWH)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KW)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)
JAN	0.00000				0.000	-11.322	12 3	-17.C	-18.C	-26.947	2815.	5.512
FEB	0.00000				0.000	-9.664	11 6	-15.C	-16.C	-26.645	2547.	5.512
MAR	0.00180	3 15	24.C	18.C	1.315	-7.189	24 5	-13.C	-13.C	-26.568	2846.	5.512
APR	0.18150	28 15	26.C	20.C	13.160	-2.995	9 6	-3.C	-4.C	-18.174	2782.	8.031
MAY	0.70550	21 13	31.C	24.C	26.022	-1.306	7 6	1.C	-2.C	-14.791	2951.	9.741
JUN	2.43235	20 18	33.C	26.C	30.732	-0.210	1 6	9.C	8.C	-6.697	3296.	12.874
JUL	7.23019	13 17	36.C	26.C	29.873	-0.002	6 6	16.C	13.C	-0.905	4518.	12.263
AUG	5.06050	26 17	34.C	24.C	25.500	-0.011	5 6	13.C	12.C	-3.272	3984.	11.588
SEP	1.06278	11 17	30.C	22.C	21.712	-0.825	23 6	2.C	1.C	-13.755	2953.	9.986
OCT	0.13723	30 19	23.C	19.C	12.433	-2.359	21 6	-1.C	-2.C	-16.761	2826.	8.221
NOV	0.04100	2 13	23.C	16.C	7.322	-6.103	14 10	-2.C	-2.C	-21.879	2717.	5.512
DEC	0.00000				0.000	-9.872	9 6	-10.C	-11.C	-24.862	2806.	5.512
TOTAL	16.853					-51.858					37041.	
MAX					30.732					-26.947		12.874

HOUR	--- COOLING ---				--- HEATING ---			DAY COOLING PEAK			
	HOURLY COOLING LOAD (KWH)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP	HOURLY HEATING LOAD (KWH)	DRY- BULB TEMP	WET- BULB TEMP	HOURLY COOLING LOAD (KWH)	SENSIBLE HEAT RATIO	DRY- BULB TEMP	WET- BULB TEMP
	JUN 20				JAN 12			JUL 3			
1	0.645	0.478	20.C	18.C	-26.097	-15.C	-16.C	16.370	0.618	27.C	22.C
2	0.000	0.000	20.C	18.C	-26.627	-16.C	-17.C	12.341	0.635	27.C	22.C
3	0.000	0.000	19.C	17.C	-26.947	-17.C	-18.C	11.073	0.641	27.C	22.C
4	0.000	0.000	19.C	17.C	-26.941	-19.C	-19.C	9.871	0.646	26.C	21.C
5	0.000	0.000	18.C	17.C	-26.870	-20.C	-21.C	8.560	0.635	25.C	21.C
6	0.000	0.000	18.C	17.C	-26.789	-21.C	-21.C	6.622	0.568	26.C	21.C
7	0.000	0.000	19.C	18.C	-26.487	-21.C	-22.C	12.845	0.648	26.C	21.C
8	0.000	0.000	23.C	18.C	-26.622	-22.C	-22.C	15.546	0.658	28.C	22.C
9	4.007	0.600	24.C	19.C	-25.915	-22.C	-22.C	18.141	0.680	29.C	23.C
10	16.650	0.653	27.C	22.C	-25.567	-22.C	-22.C	20.362	0.688	31.C	23.C
11	20.851	0.679	28.C	22.C	-25.019	-20.C	-21.C	22.047	0.690	31.C	23.C
12	24.419	0.658	29.C	23.C	-21.282	-18.C	-18.C	25.813	0.687	32.C	24.C
13	24.883	0.672	29.C	23.C	-18.043	-16.C	-17.C	25.018	0.706	32.C	24.C
14	27.371	0.679	31.C	24.C	-17.257	-14.C	-16.C	25.308	0.722	33.C	24.C
15	30.433	0.652	32.C	25.C	-17.326	-16.C	-17.C	24.669	0.753	33.C	23.C
16	30.256	0.633	32.C	26.C	-18.733	-16.C	-17.C	26.128	0.728	33.C	23.C
17	30.732	0.637	33.C	26.C	-21.568	-17.C	-18.C	26.172	0.732	33.C	23.C
18	28.659	0.647	32.C	25.C	-24.240	-19.C	-19.C	26.426	0.727	33.C	23.C
19	26.365	0.613	32.C	26.C	-23.417	-20.C	-21.C	24.680	0.730	32.C	22.C
20	20.381	0.594	26.C	23.C	-25.397	-20.C	-21.C	23.338	0.714	31.C	22.C
21	13.235	0.632	21.C	19.C	-25.081	-19.C	-20.C	21.807	0.711	29.C	21.C
22	11.925	0.601	21.C	19.C	-24.355	-19.C	-20.C	21.458	0.709	29.C	21.C
23	5.685	0.538	21.C	18.C	-24.360	-19.C	-19.C	16.944	0.728	27.C	20.C
24	3.999	0.579	22.C	18.C	-24.795	-18.C	-19.C	14.055	0.678	24.C	20.C
SUM								455.592			
MAX	30.732				-26.947						

SYSTEM-TYPE	PSZ	SQFT/TON	247.2
COOLING PEAK	153.04 (WATT /M2)	HEATING PEAK	-134.20 (WATT /M2)
SUPPLY AIR PEAK FLOW	28.95 (M3/H-M2)	MIN-OA/PERSON	26.01 (M3/H)
OA FRAC AT CLG PEAK	0.215	OA FRAC AT HTG PEAK	0.215

* ASTERISKS INDICATE HOURS LOADS NOT MET

METRIC INPUT/OUTPUT EXAMPLE
 SYSTEM 4: PKG PSZ WATER-COOLED UNIT
 REPORT- SS-0 TEMPERATURE SCATTER PLOT

SMALL BAR/LOUNGE
 WITH WATER-SIDE ECONOMIZER
 SYS1 FOR BLDG

DOE-2.1E-001 Thu Nov 11 11:30:36 1993SDL RUN 1

WEATHER FILE- TRY CHICAGO

TOTAL HOURS AT TEMPERATURE LEVEL AND TIME OF DAY

HOUR	1AM	2	3	4	5	6	7	8	9	10	11	12	1PM	2	3	4	5	6	7	8	9	10	11	12	TOTAL
ABOVE 29.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
26.7-29.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
23.9-26.7	85	53	40	37	32	42	46	63	92	110	130	156	168	170	170	171	167	168	159	148	139	133	127	99	2705
21.1-23.9	277	276	258	261	266	254	252	236	241	247	231	207	197	195	195	194	198	197	206	216	225	231	237	265	5562
18.3-21.1	3	2	5	5	5	7	5	4	4	7	3	2	0	0	0	0	0	0	0	1	1	1	1	1	57
15.6-18.3	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	2
BELOW 15.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

MMDDHH	GLOBAL	WIN-1	GLOBAL	BLDG	BLDG	BLDG
	GLOBAL SOLAR WATT /M2	SOL GAIN GLAS+FRM WATT	DRY BULB TEMP C	ZONE TEMP C	THERMOST SETPOINT C	EXTRACTN RATE WATT
	----(15)	----(15)	----(8)	----(6)	----(7)	----(8)
1 5 1	0.0	0.0	-14.4	21.8	22.2	-9868.
1 5 2	0.0	0.0	-13.9	21.8	22.2	-10493.
1 5 3	0.0	0.0	-13.9	21.7	22.2	-12186.
1 5 4	0.0	0.0	-13.3	21.7	22.2	-13109.
1 5 5	0.0	0.0	-13.3	21.7	22.2	-12773.
1 5 6	0.0	0.0	-12.8	21.7	22.2	-12976.
1 5 7	0.0	0.0	-12.2	21.8	22.2	-11357.
1 5 8	2.8	17.0	-11.7	21.7	22.2	-11864.
1 5 9	45.8	458.9	-10.6	21.8	22.2	-11959.
1 510	99.6	1157.2	-10.0	21.8	22.2	-10977.
1 511	139.3	1668.4	-8.3	21.9	22.2	-10669.
1 512	159.5	1946.1	-7.8	21.9	22.2	-9838.
1 513	203.5	2786.4	-7.2	22.0	22.2	-8739.
1 514	175.1	2359.9	-7.2	22.0	22.2	-9040.
1 515	121.9	1558.3	-7.2	22.0	22.2	-9088.
1 516	51.6	557.5	-6.7	22.0	22.2	-9649.
1 517	2.6	116.8	-6.7	22.0	22.2	-9363.
1 518	0.0	0.0	-7.2	22.0	22.2	-9656.
1 519	0.0	0.0	-7.8	22.0	22.2	-9284.
1 520	0.0	0.0	-9.4	21.9	22.2	-9954.
1 521	0.0	0.0	-10.0	21.9	22.2	-9030.
1 522	0.0	0.0	-10.0	22.0	22.2	-8233.
1 523	0.0	0.0	-10.0	22.0	22.2	-8290.
1 524	0.0	0.0	-9.4	22.0	22.2	-8699.
DAILY SUMMARY (JAN 5)						
MN	0.0	0.0	-14.4	21.7	22.2	-13109.
MX	203.5	2786.4	-6.7	22.0	22.2	-8233.
SM	1001.7	12626.6	167.2	933.7	941.7	-247094.
AV	41.7	526.1	-10.1	21.9	22.2	-10296.
MONTHLY SUMMARY (JAN)						
MN	0.0	0.0	-14.4	21.7	22.2	-13109.
MX	203.5	2786.4	-6.7	22.0	22.2	-8233.
SM	1001.7	12626.6	167.2	933.7	941.7	-247094.
AV	41.7	526.1	-10.1	21.9	22.2	-10296.
YEARLY SUMMARY						
MN	0.0	0.0	-14.4	21.7	22.2	-13109.
MX	203.5	2786.4	-6.7	22.0	22.2	-8233.
SM	1001.7	12626.6	167.2	933.7	941.7	-247094.
AV	41.7	526.1	-10.1	21.9	22.2	-10296.

METRIC INPUT/OUTPUT EXAMPLE
SYSTEM 4: PKG PSZ WATER-COOLED UNIT
REPORT- PV-A EQUIPMENT SIZES

SMALL BAR/LOUNGE
WITH WATER-SIDE ECONOMIZER

DOE-2.1E-001 Thu Nov 11 11:30:36 1993PDL RUN 1

WEATHER FILE- TRY CHICAGO

EQUIPMENT	NUMBER		NUMBER		NUMBER		NUMBER		NUMBER	
	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD	SIZE	INSTD
	(MWATT)	AVAIL	(MWATT)	AVAIL	(MWATT)	AVAIL	(MWATT)	AVAIL	(MWATT)	AVAIL
DHW-HEATER	0.009	1								

ENERGY TYPE: UNITS: MWH	ELECTRICITY	NATURAL-GAS
CATEGORY OF USE -----		
AREA LIGHTS	10.5	0.0
MISC EQUIPMT	4.9	0.0
SPACE HEAT	0.0	76.9
SPACE COOL	4.0	0.0
HEAT REJECT	4.1	0.0
PUMPS & MISC	1.8	0.0
VENT FANS	17.4	0.0
DOMHOT WATER	0.0	28.3
	-----	-----
TOTAL	42.7	105.2

TOTAL SITE ENERGY	147.90	MWH	736.5	KWH/M2-YR	GROSS-AREA	736.5	KWH/M2-YR	NET-AREA
TOTAL SOURCE ENERGY	233.38	MWH	1162.2	KWH/M2-YR	GROSS-AREA	1162.2	KWH/M2-YR	NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.7
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

ENERGY TYPE: SITE UNITS:	ELECTRICITY KWH	NATURAL-GAS M3
CATEGORY OF USE -----		
AREA LIGHTS	10463.	0.
MISC EQUIPMT	4938.	0.
SPACE HEAT	0.	24162.
SPACE COOL	3991.	0.
HEAT REJECT	4137.	0.
PUMPS & MISC	1772.	0.
VENT FANS	17432.	0.
DOMHOT WATER	0.	8889.
	-----	-----
TOTAL	42733.	33051.

TOTAL ELECTRICITY	42733. KWH	1.838 KWH	/ M2 -YR GROSS-AREA	1.838 KWH	/ M2 -YR NET-AREA
TOTAL NATURAL-GAS	33051. M3	1.421 M3	/ M2 -YR GROSS-AREA	1.421 M3	/ M2 -YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.7
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

METRIC INPUT/OUTPUT EXAMPLE
 SYSTEM 4: PKG PSZ WATER-COOLED UNIT
 REPORT- ES-D ENERGY COST SUMMARY

SMALL BAR/LOUNGE
 WITH WATER-SIDE ECONOMIZER

DOE-2.1E-001 Thu Nov 11 11:30:36 1993EDL RUN 1

UTILITY-RATE	RESOURCE	METERS	METERED ENERGY UNITS/YR	TOTAL CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	RATE USED ALL YEAR?
ELEC-COST	ELECTRICITY	1 2 3 4 5	42732. KWH	3386.	0.0792	YES
GAS-COST	NATURAL-GAS	1 2 3 4 5	33051. M3	5997.	0.1815	YES

 9384.

ENERGY COST/GROSS BLDG AREA: 4.34
 ENERGY COST/NET BLDG AREA: 4.34

METRIC INPUT/OUTPUT EXAMPLE
 SYSTEM 4: PKG PSZ WATER-COOLED UNIT
 REPORT- ES-E SUMMARY OF UTILITY-RATE:

SMALL BAR/LOUNGE
 WITH WATER-SIDE ECONOMIZER
 GAS-COST

DOE-2.1E-001 Thu Nov 11 11:30:36 1993EDL RUN 1

UTILITY-RATE: GAS-COST

RESOURCE: NATURAL-GAS
 METERS: 1 2 3 4 5

DEMAND-WINDOW: HOUR
 BILLING-DAY: 31

10860. BTU/M3
 RATE-LIMITATION: 0.0000

RATE-QUALIFICATIONS

BLOCK-CHARGES

DEMAND-RATCHETS

MIN-MON-RATCHETS

MIN-ENERGY: 0.0
 MAX-ENERGY: 0.0
 MIN-DEMAND: 0.0
 MAX-DEMAND: 0.0
 QUALIFY-RATE: ALL-MONTHS
 USE-MIN-QUAL: NO

GAS-CH

MONTH	METERED ENERGY M3	BILLING ENERGY M3	METERED DEMAND M3/HR	BILLING DEMAND M3/HR	ENERGY CHARGE (\$)	DEMAND CHARGE (\$)	ENERGY CST ADJ (\$)	TAXES (\$)	SURCHRG (\$)	FIXED CHARGE (\$)	MINIMUM CHARGE (\$)	VIRTUAL RATE (\$/UNIT)	TOTAL CHARGE (\$)
JAN	5875	5875	13.3	13.3	965	0	0	0	0	11	0	0.1661	976
FEB	5110	5110	12.2	12.2	850	0	0	0	0	11	0	0.1685	861
MAR	4202	4202	11.8	11.8	714	0	0	0	0	11	0	0.1725	725
APR	2261	2261	8.3	8.3	423	0	0	0	0	11	0	0.1919	434
MAY	1453	1453	6.9	6.9	302	0	0	0	0	11	0	0.2152	313
JUN	861	861	3.5	3.5	189	0	0	0	0	11	0	0.2325	200
JUL	725	725	2.2	2.2	159	0	0	0	0	11	0	0.2348	170
AUG	716	716	2.2	2.2	157	0	0	0	0	11	0	0.2350	168
SEP	1110	1110	6.5	6.5	244	0	0	0	0	11	0	0.2297	255
OCT	1881	1881	7.8	7.8	366	0	0	0	0	11	0	0.2004	377
NOV	3577	3577	10.4	10.4	621	0	0	0	0	11	0	0.1765	631
DEC	5281	5281	11.1	11.1	876	0	0	0	0	11	0	0.1679	887
TOTAL	33051	33051	13.3		5868	0	0	0	0	129		0.1815	5997