

# Lawrence Berkeley National Laboratory

## Recent Work

### Title

MINUTES OF THE HYDROGEN SAFETY COMMITTEE ACCIDENT WITH SWAGELOCK CAP

### Permalink

<https://escholarship.org/uc/item/89f9d5n0>

### Authors

Byrns, Rod  
Barrera, Frank.

### Publication Date

1980-03-01

LBID-221<.1  
0041



# Lawrence Berkeley Laboratory

UNIVERSITY OF CALIFORNIA

## Engineering & Technical Services Division


RECEIVED  
LAWRENCE  
BERKELEY LABORATORY

JUL 21 1980

LIBRARY AND  
DOCUMENTS SECTION

**For Reference**

Not to be taken from this room



LBID-221 e.1

## **DISCLAIMER**

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

**ENGINEERING NOTE**

AA0300

M3277

1 OF 2

AUTHOR Rod Byrns,  
Frank Barrera *FB*DEPARTMENT  
Mechanical EngineeringLOCATION  
BerkeleyDATE  
March 2, 1964

PROGRAM - PROJECT - JOB

MECHANICAL ENGINEERING

MINUTES OF THE HYDROGEN SAFETY COMMITTEE

CP-105

TITLE

ACCIDENT WITH SWAGELOCK CAP

A personal injury occurred on January 30, 1964, to a Bubble Chamber Compressor Room Operator while performing a hydrostatic pressure test. The accident occurred when the operator loosened a 3/8-inch Swagelock plug to relieve the pressure on a vessel containing 4000 psi hydrostatic pressure. The plug blew out of the union nut and penetrated his right hand parallel to the palm for a distance of about 2 inches. No bones were broken. One-and-a-half hours of surgery were required to remove the plug and repair the hand.

The pressure vessel was fabricated from a 3 1/2-inch Schedule 80 stainless steel pipe, 35-inches long. Stainless steel end plates with copper gaskets were fastened to the vessel with eight (8) tie bolts of 1/2-inch diameter. Two 3/8-inch Swagelock butt weld elbows were welded to the side of the vessel. The design pressure is 1800 psi for hydrogen gas near liquid nitrogen temperature.

The hydrostatic test was a proof test and this was the third vessel tested in a series of four. The test consisted of pressurizing the vessel, isolating the vessel from the pump, and monitoring the pressure on a bourdon gage for a minimum of eight hours. This particular vessel had been under 4000 psi pressure for eight hours; the test has been completed and witnessed by Frank Barrera.

The system is shown on Figure 1.




FIGURE 1

The location is shown on Figure 2.

**ENGINEERING NOTE**

AA0300

M3277

2 OF 2

AUTHOR

Rod Byrns,  
Frank Barrera

DEPARTMENT

Mechanical Engineering


LOCATION

Berkeley

DATE

March 2, 1964

CP-106

FIGURE 2Precautions and Recommendations

1. Approach all high pressure systems with extreme care. Often the tendency is to respect gas systems and to treat hydrostatic tests as completely safe. Two facts make hard pressure hydrostatic tests hazardous:
  - a. Trapped Air. Ideally all air should be bled out of a system. However a bourdon gage is impossible to bleed unless vacuum pumped. It is recommended that whenever possible the air be removed from a system with a vacuum pump before filling with water.
  - b. Metal Spring Constant. The stress in the metal parts store energy. It is estimated that the stored available energy in the tie rods was 175 ft-lbs which is equivalent to the energy stored in a  $\frac{1}{2}$  cubic inch of air at 4000 psi.
2. Install permanent bleed valves on all pressure testing equipment. Never bleed a line or relieve pressure by loosening a fitting. All piping and fittings on test equipment must be of the same pressure rating as the maximum pump pressure.
3. Test equipment away from traffic areas. Use barricades and barriers.
4. Avoid use of Swagelock plug fittings. If necessary for test work, barricade caps and tighten sufficiently to deform tube wall.

This report was done with support from the Department of Energy. Any conclusions or opinions expressed in this report represent solely those of the author(s) and not necessarily those of The Regents of the University of California, the Lawrence Berkeley Laboratory or the Department of Energy.

Reference to a company or product name does not imply approval or recommendation of the product by the University of California or the U.S. Department of Energy to the exclusion of others that may be suitable.

TECHNICAL INFORMATION DEPARTMENT  
LAWRENCE BERKELEY LABORATORY  
UNIVERSITY OF CALIFORNIA  
BERKELEY, CALIFORNIA 94720