

# Lawrence Berkeley National Laboratory

## Recent Work

### Title

CRYOGENIC HEAT LEAK ESTIMATES

### Permalink

<https://escholarship.org/uc/item/15j99862>

### Authors

Pope, William L.  
Byrns, Roscoe A.

### Publication Date

1980-06-01



# Lawrence Berkeley Laboratory


UNIVERSITY OF CALIFORNIA, BERKELEY

## Engineering & Technical Services Division

RECEIVED  
LAWRENCE  
BERKELEY LABORATORY  
  
JUL 21 1980  
  
LIBRARY AND  
DOCUMENTS SECTION

**For Reference**

Not to be taken from this room



LB1D-224 e.1

## **DISCLAIMER**

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

LAWRENCE BERKELEY LABORATORY - UNIVERSITY OF CALIFORNIA		CODE	SERIAL	PAGE
<b>ENGINEERING NOTE</b>		ES0510	M4930	1 of 11
AUTHOR	DEPARTMENT	LOCATION	DATE	
W. Pope/R. Byrns	Mechanical Engineering	Berkeley	May 11, 1976	
PROGRAM - PROJECT - JOB				
ESCAR MECHANICAL FACILITIES				
REFRIGERATION DISTRIBUTION				
TITLE				
CRYOGENIC HEAT LEAK ESTIMATES				
<p><u>SUMMARY.</u> Static heat loads to LHe (and LN<sub>2</sub>) are tabulated herein. No real surprises from previous estimates are found. Mass flow requirements for magnet lead cooling are also redetermined. Very little refrigeration margin for pulsing will exist if lead cooling demands exceed the 3 gm/sec refer design spec.</p>				
<p>Tabulated in this note are crude but up to date estimates of the LHe and LN<sub>2</sub> static heat loads to the various ESCAR cryogenic sub systems (elements). Whenever they exist, the estimates are from the Engineer in Charge of detail design of that particular element, otherwise they are my own <u>temporary</u> crude guesses.</p>				
<p>In most cases it can be noted (see Tables 1 and 2) that little or no other documentation exists for the estimates. Also in the case of the ring straight sections, the estimates are old and based on preliminary design layouts which have not had the benefit of critical internal engineering review, because of effort redirection in the preliminary design phase.</p>				
<p>It is important that these heat leak estimates be periodically upgraded and distributed in a similar format to project personnel as design definition improves, so that total system trade-offs and make-or-buy component decisions can be made. We need your help on this.</p>				
<p>We need the heat leak estimates in order to size and select the distribution lines (1 <math>\phi</math> and 2 <math>\phi</math> flow pressure drop calculations) to minimize refrigerator and magnet ring impact and cost.</p>				
<p>I've attempted to present these heat leak estimates in a format suitable for general internal information and control purposes, but needless to say, it is possible to read too much (or too little) from them, and therefore they are not suitable for outside distribution yet. The circled numbers in Column 6 are my own crude <u>conservative</u> estimates which I use for conservative pressure drop calculations. Better numbers will go here when we get them.</p>				
<p>The current lead heat leak estimates, however, are <u>not</u> very conservative. The <u>best</u> real gas cooled leads conduct about 1.0 mw per amp lead to helium at the optimum current; the 1.33 figure assumed here simply totals out to 3 gms/sec (refer spec) if the 4 each 2000 A dipole pairs and 32 each 500 A quadrupole pairs are operated "self sufficient" with <math>(dq/dm)_p = 21.3</math> J/gm. The 2400 A leads we built and tested were on the order of 20 to 40% higher heat leak, but we can't now narrow this down better, because they weren't pushed to high voltage and were masked by other system heat leaks. A limited scope retest of these leads would be desirable.</p>				
<p>The tabulated numbers ending with .999 are also <u>very crude</u>; my guesses - for those who can't resist adding columns of numbers. These will be changed as soon as they are better defined.</p>				

**ENGINEERING NOTE**

ES0510

M4930

2 OF 11

AUTHOR

W. Pope/R. Byrns

DEPARTMENT

Mechanical Engineering

LOCATION

Berkeley

DATE

May 11, 1976

Although M. Green got recent (informal) heat leak specs on flexible vacuum and MLI insulated helium lines of 3 sizes (modified "semiflex"), most of the heat leak numbers stated herein are for "rigid" lines with a smooth wall inner tube and strain relief bellows at suitable intervals. The flexible lines are higher heat leak and higher pressure drop. In our case, most lines can be rigid, so line heat leak estimates stated are from a recent Cryenco brochure.

So far we've used some of the heat leaks information tabulated herein to make some preliminary pressure drop calculations for distribution line type selection and sizing.

We've looked at the following circuits for 2  $\phi$  flow pressure drop.

A. Helium System:

1. Straight section elements (very preliminary).

B. Nitrogen System:

1. Main ring magnet elements.

These calculations were done in similar fashion to the Martinelli-Nelson pressure drop stuff in my ESCAR note of 2/13/75 which was briefly reviewed by P. Vander Arend. When the new main ring magnet element helium flow passages and static (and dynamic) helium heat leaks are specified, we will reinvestigate the helium circuit 2  $\phi$  flow pressure drop. With the new larger dipole magnet flow passages, there shouldn't be any surprises. Line sizes and types will dictate system operating pressure; there are several trade-offs to be considered here.

To do the above calculations, program TUF22 had to be expanded to include the viscous liquid-turbulent vapor equations of Tanabe's (for nitrogen). (After these revisions, I checked the results with simpler problems against Tanabe's program, TUF2E.) In addition a number of assumptions had to be made which I'll only briefly mention here.

- A. For the straight section helium system calculations, I've assumed a circuit configuration similar to John Carrieri's schematic of 4/7/76; line physical lengths compatible with Bob Caylor's Quadrant II layout (18C9705) and element sizes consistent with Egon Hoyer's RF cavity layouts (18C3526 and 18C3536) and John Carrieri's straight section and injection line transition cryopumps (18C5596 and his sketches of 9/9/75).
- B. For the main ring magnet element nitrogen system calculations, I've assumed physical dimensions compatible with R. V. Schafer's D-4 cryostat (18C7635) and R. B. Meuser's quadrupole cryostat (design study #437) with guesses about what the new dipole charge lead pot will be like.

LAWRENCE RADIATION LABORATORY - UNIVERSITY OF CALIFORNIA		CODE	SERIAL	PAGE
<b>ENGINEERING NOTE</b>		ES0510	4930	3 OF 11
AUTHOR	DEPARTMENT	LOCATION	DATE	
W. Pope/R. Byrns	Mechanical Engineering	Berkeley	May 11, 1976	

These calculations show that there will be no pressure drop problems cooling an entire magnet quadrant with two small parallel LN<sub>2</sub> lines to the magnet shields. The flow regime is laminar liquid/turbulent vapor with a total magnet quadrant LN<sub>2</sub> heat leak of about 100 watts. These calculations will be reported in detail later.

A final word of caution. None of the heat leak numbers herein are going to be accurate to within  $\pm 10\%$ . Most will be in the  $\pm 20 - 40\%$  range and some are probably off by a factor of 2. This situation can and will improve somewhat with new information as the design progresses.

TABLE 1  
 ESCAR STATIC HEAT LEAK TO LHe

Element Description	Element Budget (w)	No. of Elements	Total Budget (w)	Element Estimate (w)	Total Estimate (w)	Documentation or Drg. No.	Date Estimator	Assumptions, Comments and Basis
6 dipoles (no ends)	41.4 <sup>(1)</sup>	4	165.6	?	①20 <sup>(2)</sup> WP 5/76	See 18C7635	R.B.M.	(1) 6x1.38 m @ 5 w/m. (2) 5.0x6x4=120 (guess).
8 quads + 2 quad CLP's (no ends)	42.8 <sup>(3)</sup>	4	171.2	?	①20 <sup>(4)</sup> WP 5/76	See RBM Drg. "Design Study #437"	R.B.M.	(3) 8:16 m @ 5 w/m+1.0. (4) 30.0x4=120 (guess).
Dipole current lead pot	②	4	8.	?	⑧ WP 4/15/76	?	R.W.	Guess.
Dip./quad junctions + warm ends	⑩	4	40.		④0 WP 5/76	See	R.B.M.	Guess.
2000A dipole lead pair	5.333 (2000A) <sup>(5)</sup> 3.733(OA) <sup>(6)</sup>	4	21.33 14.93		②1 <sup>(7)</sup> WP 5/76 ①5 <sup>(7)</sup>	See Cryogenics Apr. 1975 pg. 198	R.W.	(5) assumes $q_1 = 1.33$ m W/A lead. (6) assumes $q_0/q_1 = 0.7$ . (7) rough minimum estimate.
500A quadrupole lead pair	1.333 (500A) <sup>(5)</sup> 0.933(OA) <sup>(6)</sup>	32	42.67 29.87		④3 <sup>(7)</sup> WP 5/76 ③0 <sup>(7)</sup>	"	R.W.	(same as above).
?? A cold trim coil lead pair	?	?	?	?	?	?	W.S.G./ J.R.	?
Approx. magnet quadrant static heat Leak to LHe @ zero current (watts)					$Q_q \approx \frac{333}{4}$ $\approx 83.$	None	5/11/76 W.P.	Sum of the above. Does not include lines, bayonets, etc.

AUTHOR  
 W. Pope/R. Byrns

DEPARTMENT  
 Mechanical Engineering

LOCATION  
 Berkeley

DATE  
 May 11, 1976

CODE  
 ES0510

SERIAL  
 M1930

PAGE  
 4 of 11

RL-9220-2a (Rev. 4/64)

ADVISOR

W. Pope/R. Byrns

DEPARTMENT

Mechanical Engineering

LOCATION

Berkeley

DATE

May 11, 1976

Table 1 (continued)

Element Description	Element Budget (w)	No. of Elements	Total Budget (w)	Element Estimate (w)	Total Estimate (w)	Documentation or Drg. No.	Date Estimator	Assumptions, Comments and Basis
RF cavity and drift tube cryo-pumps	80 <sup>(9)</sup>	1	80 <sup>(9)</sup>	75 <sup>(8)</sup>	75	E.H. notes	4/16/76 E.H.	(8) rough re-estimate.
Ring cryo-pump		1		11.6	11.6	EN M4745	9/5/74 E.H.	(9) cryopump estimate in miniproject proposal (1973).
Extraction str. section cryopanel		1		4.603 <sup>(10)</sup> (J.C. 9/75)	9.2 W.P.	See 18C6786	R.W.	(10) optimistic-no warm end radiation included.
Experimental str. section cryopanel		1		4.6 <sup>(10, 11)</sup> (J.C. 9/75)	9.2 W.P.	"	R.W.	(11) lacking definition. Assumed to be same as extract. str. section.
Injection str. section cryopanel		1		6.616 <sup>(10)</sup> (12) (J.C. 9/75)	13.2 W.P.	See 18C5596	R.W.	(12) 4.603+2.013 (J.C. 9/75).
Main distribution box + broken stem valves		1		19.999	19.999	None	4/15/76 W.P.	Crude guess.
Local distribution box + B.S. valves		3		7.999	23.999	None	4/15/76 W.P.	Crude guess.
1 1/2" cold He supply		1		22.5	22.5	None	5/11/76 W.P.	Rigid w/MLI 15 m @ 1.5 w/m.
2" cold He return		1		25.5	25.5	None	5/11/76 W.P.	Rigid w/MLI 15 m @ 1.7 w/m.



AUTHOR: W. Pope/R. Byrns DEPARTMENT: Mechanical Engineering LOCATION: Berkeley DATE: May 11, 1976

Table 1 (continued)

Element Description	Element Budget (w)	No. of Elements	Total Budget (w)	Element Estimate (w)	Total Estimate (w)	Documentation or Drg. No.	Date Estimator	Assumptions, Comments and Basis
1" cold He return		1		10.5	10.5	None	5/11/76 W.P.	Rigid w/MLI 15 m @ 0.7 w/m.
1" line to cryopanel		4		13.3	53.2	None	5/11/76 W.P.	Rigid w/MLI 19 m @ 0.7 w/m
1 1/2" local lines to magnets		8		10.8	86.4	None	5/11/76 W.P.	Rigid w/MLI & 2 bayonets on short U. 6 m @ $\approx$ 1.8 w/m (Bends).
1 3/4 magnets bayonets		16		2.0	32 <sup>(13)</sup>	None	5/11/76 W.P.	(13) Crude guess @ doable. Possible to eliminate altogether.
Helium storage	?	1			?	None		
Contingency, miscellaneous, etc (w)					150	None	5/11/76 W.P.	( $\approx$ 20% of above).
Approx. total static heat leak to LHe @ zero current (w) (no storage dewar)					<u>875</u>	None	5/11/76 W.P.	

**ENGINEERING NOTE**

ES0510

4930

7 OF 11

AUTHOR

W. Pope/R. Byrns

DEPARTMENT

Mechanical Engineering

LOCATION

Berkeley

DATE

May 11, 1976

Lead Cooling Requirements

The best real gas cooled current leads have a cold end heat leak of about 1.0 mW/amp lead at the optimum current (Ref. 1). The above tabulated lead heat leak estimates assume  $q_0(I_{opt})/I_{opt} = 1.33$  mW/amp lead or a 33% margin on "doability".

If the selected ESCAR magnet current leads (8 each @ 2000 A and 64 each @ 500 A) are only this good and operated "self sufficient" @ 4.5°K, the total lead mass flow required would be:

$$\dot{m}_L = \frac{\sum NI(q_0/I)}{(dq/d\dot{m})_p} = \frac{[8(2000) + 64(500)] (1.33 \times 10^{-3})}{21.3}$$

$$= 3.0 \text{ gm/sec}$$

Thus the assumed leads (no allowance for trim coils @ 4.5°K) just meet the CTI/FNAL/LBL 1500 W refer specification for lead cooling.

ESCAR/REFER SUPPLY-DEMAND FIT


The 1500 W refer design spec calls for 1450 watts of refrigeration at 4.5°K plus 3.0 gm/sec of lead cooling and 350 l/hr (~ 11.6 gm/sec) of liquifaction (@ zero refrigeration).

The 875 watt total estimated static heat leak in Table 1 suggests we will have 1450-875 = 575 W available for pulsing. However this assumes we only extract 3.0 gm/sec for lead cooling. The above refer Liquifaction/Refrigeration is sketched in Figure 1 where a straight line interaction is assumed (which is simply a good first order guess).

It can be noted in Figure 1 that if the lead cooling demand increased 50%, to say 4.5 gm/sec, the available refrigeration @ 4.5°K would be about 1125 W leaving only 250 watts margin for pulsing.

## References

Ref. 1. Cryogenics, April, 1975, pg. 198.



AUTHOR

W. Pope/R. Byrns

DEPARTMENT

Mechanical Engineering

LOCATION

Berkeley

DATE

May 11, 1976

TABLE 2

ESCAR STATIC HEAT LEAK TO LN<sub>2</sub>

Element Description	Element Estimate (w)	No. Elements	Total Estimate (w)	Documentation or Drg. No.	Date Estimator	Assumptions, Comments and Basis
One magnet quadrant inc: 6 dipoles + CLP + 8 quads + D/Q junction + ends + quad CLP's (2)	99.3	4	397.2	TUFAZ2 07 5/7/76	5/7/76 W.P.	Detailed estimate of current configuration.
RF cavity and drift tube cryopumps	69.5 <sup>(1)</sup>	1	69.5 <sup>(1)</sup>	EN M4745	9/5/74 E.H.	<sup>(1)</sup> Includes local cavity dist. line losses. Preliminary design est.
Ring cryopump	453	1	453	EN M4745	9/5/74 E.H.	Preliminary design est.
Extraction str. section cryopanel	50.69	1	50.69	See 18C6786	9/18/75 J.C.	
Experimental str. section cryopanel	50.69	1	50.69	See 18C6786	9/18/75 J.C.	Lacking definition. Assumed to be similar to extr. str. section.

AUTHOR

W. Pope/R. Byrns

DEPARTMENT

Mechanical Engineering

LOCATION

Berkeley

DATE

May 11, 1976

TABLE 2 (continued)

Element Description	Element Estimate (w)	No. Elements	Total Estimate (w)	Documentation or Drg. No.	Date Estimator	Assumptions, Comments and Basis
Injection str. section cryopanel	77.64 <sup>(2)</sup>	1	77.64 <sup>(2)</sup>	See 18C5596	9/9/75 J.C.	(2) Sum of 50.69 + 26.95.
Dipole charge lead pot (CLP) (Ref.)	7.999 (Ref.)	4	⟨ 31.999 ⟩ (Ref.)	None	5/6/74 W.P.	Very crude guess (ask R.W.). Ref. only - included in quadrant above.
Main distribution box	14.999/39.999	1	14.999/39.999	None	5/6/76 W.P.	Crude guess/not in work.
Local distribution box	0./4.999	3	0./14.999	None	5/6/76 W.P.	Layout in work.
13,000 gal LN <sub>2</sub> storage	419.999 <sup>(3)</sup>	1	419.999 <sup>(3)</sup>	None	5/10/76 W.P.	(3) Crude guess based on 0.5% per day loss @ 30 psia. See Scott, Cryogenic Engineering, pg. 221.

AUTHOR

W. Pope/R. Byrns

DEPARTMENT

Mechanical Engineering

LOCATION

Berkeley

DATE

May 11, 1976

TABLE 2 (continued)

Element Description	Element Estimate (w)	No. Elements	Total Estimate (w)	Documentation or Drg. No.	Date Estimator	Assumptions, Comments and Basis
2" VI LN <sub>2</sub> main supply line	59.999 <sup>(4)</sup> (20.4) <sup>(5)</sup>	1	59.999 (20.4)	Cryenco Brochure	5/6/76 W.P.	(4) 12 m @ 5 w/m-rigid w/o MLI. (5) 12 m @ 1.7 w/m-rigid w/MLI (alt.)..
1" VI Ring Distribution line	83.999 <sup>(6)</sup> (28.) <sup>(7)</sup>	2	83.999 (28.)	"	5/10/76 W.P.	(6) 40 m @ 2.1 w/m-rigid w/o MLI. (7) 40 m @ 0.7 w/m-rigid w/MLI (alt.)..
3/4" VI local distribution flex hose	20.4 <sup>(8)</sup> (6.8) <sup>(9)</sup>	8	163.2 (54.4)	"	5/10/76 W.P.	(8) 3 m @ 6.8 w/m-flex w/o MLI. (9) 3 m @ 2.27 w/m-flex w/MLI (alt.)..
Non-vacuum insulated cold stem valves	TBD				W.P.	

This report was done with support from the Department of Energy. Any conclusions or opinions expressed in this report represent solely those of the author(s) and not necessarily those of The Regents of the University of California, the Lawrence Berkeley Laboratory or the Department of Energy.

Reference to a company or product name does not imply approval or recommendation of the product by the University of California or the U.S. Department of Energy to the exclusion of others that may be suitable.

TECHNICAL INFORMATION DEPARTMENT  
LAWRENCE BERKELEY LABORATORY  
UNIVERSITY OF CALIFORNIA  
BERKELEY, CALIFORNIA 94720