

Lawrence Berkeley National Laboratory

Recent Work

Title

CENTER FOR BUILDING SCIENCE FY 1988 ANNUAL REPORT

Permalink

<https://escholarship.org/uc/item/1n8492zm>

Author

Lawrence Berkeley National Laboratory

Publication Date

1989-05-01



Lawrence Berkeley Laboratory

UNIVERSITY OF CALIFORNIA

CENTER FOR BUILDING SCIENCE

RECEIVED
LAWRENCE
BERKELEY LABORATORY

JUL 23 1989


LIBRARY AND
DOCUMENTS SECTION

FY 1988 ANNUAL REPORT

MAY 1989

TWO-WEEK LOAN COPY

*This is a Library Circulating Copy
which may be borrowed for two weeks.*



APPLIED SCIENCE
DIVISION

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

ANNUAL REPORT FY 1988

CENTER FOR BUILDING SCIENCE of the APPLIED SCIENCE DIVISION

Elton J. Cairns

Head, Applied Science Division
and
Associate Director, LBL

Arthur H. Rosenfeld

Director, Center for Building Science
and
Professor of Physics
University of California at Berkeley

Applied Science Division
Lawrence Berkeley Laboratory
University of California
Berkeley, California 94720

This work was supported by the Assistant Secretary for Conservation
and Renewable Energy, Office of Buildings and Community Systems,
Buildings Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098

CENTER FOR BUILDING SCIENCE STAFF

Arthur Rosenfeld, Director

Sam Cohen
Deborah Gordon
Debbie Giallombardo
Leo Levenson
Ralph McLaughlin

Robert Mowris
Cindy Polansky
Nan Wishner
Cheryl Wodley

INDOOR ENVIRONMENT PROGRAM STAFF

David Grimsrud, Program Leader
Anthony Nero, Deputy Program Leader

Kathleen Alevantis
James Allen
Michael Apte
Stephen Brown
Edie Canfield
Edward Churka
Joan Daisey*
Nancy DeMello
Richard Diamond
Darryl Dickerhoff
Helmut Feustel
William Fisk†
Karina Garbesi

Ted Gartner
Lara Gundel
Jed Harrison
Alfred Hodgson
Nori Hudson
Anne Kovach
Anna Lee
Mark Modera
Nancy Morrison
William Nazaroff
Timothy Nuzum
Denise Odenwalder
Richard Prill

Kenneth Revzan
Alan Robb
Greg San Martin
Gail Schiller
Richard Sextro*
Max Sherman*
Brian Smith
Carol Stoker
Richard Szydlowski
Lucia Tin
Greg Traynor
Bradley Turk
Henrik Wallman

*Group Leader

†Acting Group Leader, 8/88-8/89

ENERGY ANALYSIS PROGRAM STAFF

Mark Levine, Program Leader[‡]
 Ronald Ritschard, Deputy Program Leader[‡]
 Michael Rothkopf, Deputy Program Leader[‡]

Hashem Akbari
 Barbara Atkinson*
 Barry Barnes
 Sarita Bartlett
 John Beldock
 Didier Borderon*
 Tom Borgers*
 Betty Bratton
 James Bull
 John Busch
 Stephen Byrne
 Charles Campbell
 Kathleen Carlson
 Peter Chan
 Mark Christensen
 Deborah Connell
 Paul Craig[†]
 Philip Cunliffe
 Marie DeBurge*
 Yum Donggwan*
 Susan Ellis
 Joseph Eto
 Anthony Fisher
 Sunita Gandhi
 Charles Goldman
 Mark Goralka
 Kathleen Greely
 Steven Greenberg*

William Hanneman
 Jeff Harris[‡]
 Diane Hawk
 Kristin Heinemeier*
 Norbert Hirt*
 Yu Joe Huang
 Yizhu Huang*
 Gilberto Jannuzzi*
 Edward Kahn
 Andrea Ketoff
 Margaret Knight
 Jonathan Koomey
 Florentin Krause
 Wilson Lai*
 Feng Liu*
 Christopher Marnay
 Philip Martien*
 Antonella Marucco*
 Bartlett McGuire
 Elizabeth McGuire
 James McMahon
 Alan Meier
 Stephen Meyers
 Evan Mills
 Bruce Nordman
 Richard Norgaard
 Karen Olson

Samuel Oren
 Park Chun Hun*
 Soo-Hun Park*
 Woo Park*
 Mary Ann Piette
 Giancarlo Pireddu*
 Leo Rainer
 John Randolph
 Itzhak Ravid*
 Paolo Ricci
 Itzhak Ravid*
 Henry Ruderman
 Jayant Sathaye
 Lee Schipper[‡]
 Nancy Schorn
 Renee Slonek
 Steven Stoft
 Haider Taha
 Isaac Turiel
 Dorothy Turner
 Robert Twiss
 Stephen Tyler
 Edward Vine
 Walter Westman
 Deborah Wilson
 David Wood
 Winifred Wood

*Participating guest

[†]University of California at Davis

[‡]Group leader

BUILDING ENERGY SYSTEMS

PROGRAM STAFF

Michael A. Wahlig, Program Leader

Brandt Andersson
Bruce Birdsall
Fred Buhl
William Carroll
Dominique Dumortier
Kathleen Ellington

Ahmet Erdem
Brenda Hatfield
Robert Hitchcock
Ronald Kammerud*
Jean-Michel Nataf
Cindy Polansky

Joseph Rasson[†]
Edward Sowell[‡]
Charlotte Standish
Mashuri Warren
Frederick Winkelmann*

*Group Leader

[†]Engineering Division

[‡]Participating guest

WINDOWS AND LIGHTING PROGRAM STAFF

Stephen Selkowitz, Program Leader

Dariusz Arasteh
Erica Atkin
Charles Benton
Samuel Berman*
Carolann Caffrey
Mark Cavanagh
Robert Clear
Douglas Crawford
Dennis DiBartolomeo
Marc Fountain
Ellen Gailing
Ann Hatcher
Mary Lou Hinman
Donald Hollister
John Hutchins
Richard Johnson
Harry Keller

Guy Kelley
Jong Jin Kim
Joseph Klems
Steven Lambert
Carl Lampert
Donald Levy
Fuzi Li†
Anne McClintock
Cherise Morris
Oliver Morse‡
Manfred Neiger†
Werner Osterhaus
Konstantinos Papamichael
Susan Petersen
Susan Reilly
Robert Richardson†

Michael Rubin
Francis Rubinstein
Jennifer Schuman
Stephen Selkowitz*
Masanori Shukuya†
Michael Siminovitch
Robert Sullivan
Rudy Verderber
Gregory Ward
Richard Whiteman§
Michael Wilde
Ruth Williams
John Wolfe
David Wruck
Mehrangiz Yazdanian
Edward Yin

*Group Leader

†Participating Guest

‡Plant Engineering

§Engineering Division

CONTENTS

CENTER FOR BUILDING SCIENCE

Introduction	1-1
California Institute for Energy Efficiency	1-10
Testimony	1-11
Least Cost Utility Planning	1-11
Publications List	1-13

INDOOR ENVIRONMENT PROGRAM

Introduction	2-1
--------------------	-----

INDOOR RADON

Evaluation of Several Techniques to Reduce Radon: Preliminary Results from Fourteen Houses <i>B.H. Turk, J. Harrison, R.G. Sextro, L.M. Hubbard, K.J. Gadsby, T.G. Matthews, C.S. Dudney, and D.C. Sanchez</i>	2-2
Intensive Radon Mitigation Research: Lessons Learned <i>B.H. Turk, R.J. Prill, R.G. Sextro, and J. Harrison</i>	2-2
Monitoring and Evaluation of Radon Mitigation Systems Over a Two-Year Period <i>R.J. Prill</i>	2-3
Appraisal of the U.S. Data on Indoor Radon Concentrations <i>A.V. Nero, K.L. Revzan, and R.G. Sextro</i>	2-3
Parametric Modelling of Temporal Variations in Radon Concentrations in Homes <i>K.L. Revzan, B.H. Turk, J. Harrison, A.V. Nero, and R.G. Sextro</i>	2-5
Technique for Measuring the Indoor ^{222}Rn Source Potential of Soil <i>W.W. Nazaroff and R.G. Sextro</i>	2-6
Mapping Surficial Radium Content as a Partial Indicator of Radon Concentrations in U.S. Houses <i>K.L. Revzan, A.V. Nero, and R.G. Sextro</i>	2-7

INDOOR ORGANIC CHEMISTRY

Indoor Atmospheric Chemistry: Interactions of Radon with other Gaseous Pollutants <i>J.M. Daisey, R. Sextro, A.T. Hodgson, N. Brown, and D. Lucas</i>	2-9
Initial Efficiencies of Air Cleaners for the Removal of Nitrogen Dioxide and Volatile Organic Compounds <i>J.M. Daisey and A.T. Hodgson</i>	2-9
Volatile Organic Compounds in Large Buildings <i>J.M. Daisey and A.T. Hodgson</i>	2-10
Development of a Sampling and Analysis Method for Polycyclic Aromatic Compounds in Indoor Air <i>J.M. Daisey, L.A. Gundel, A.T. Hodgson, and F.J. Offermann</i>	2-11
The Role of Heterogeneous Reactions of NO ₂ in Indoor Air <i>J.M. Daisey and L.A. Gundel</i>	2-11
Transport of Volatile Organic Compounds from Soil into a Residential Basement <i>A.T. Hodgson, K. Garbesi, R.G. Sextro, and J.M. Daisey</i>	2-12

INDOOR AIR QUALITY AND CONTROLS

The Indoor Environment of Commercial Buildings <i>D.T. Grimsrud, J.T. Brown, W.J. Fisk, and J.R. Girman</i>	2-12
Pacific Northwest Existing Home Indoor Air Quality Survey and Weatherization Sensitivity Study <i>B.H. Turk, D.T. Grimsrud, J. Harrison, R. J. Prill, and K.L. Revzan</i>	2-13
Commercial Building Ventilation Measurements Using Multiple Tracer Gases <i>W.J. Fisk, R.J. Prill, and O. Seppanen</i>	2-14

INDOOR EXPOSURE ASSESSMENT

Indoor Exposure Assessment <i>G.W. Traynor, A.V. Nero, S.R. Brown, M.A. Apte, and B.V. Smith</i>	2-15
---	------

ENERGY PERFORMANCE OF BUILDINGS

Energy Performance of Buildings <i>M.H. Sherman, R.C. Diamond, D.J. Dickerhoff, H.E. Feustel, M.K. Herrlin, A. Kovach, M.P. Modera, B.V. Smith, C. Stoker, and Y. Utsumi</i>	2-17
---	------

PUBLICATIONS LIST.....	2-23
------------------------	------

ENERGY ANALYSIS PROGRAM

Introduction	3-1
--------------------	-----

BUILDING ENERGY ANALYSIS

Utility Accounting in Public Housing <i>R. Ritschard, K. Greely</i>	3-2
Energy Management Practices in Public Housing <i>E. Vine</i>	3-2
Energy Requirements for Multifamily Buildings <i>R. Ritschard, Y.J. Huang</i>	3-3
A Comparison of Central vs. Individual HVAC and DHW Systems in Multifamily Buildings <i>S. Byrne</i>	3-3
Analysis of Energy Performance of Unbalanced Single-Pipe Steam Heating Systems in Multifamily Buildings <i>Y.J. Huang, R. Ritschard</i>	3-4

BUILDING ENERGY DATA

Estimating Nationwide Conservation Potential from Measured Data <i>K.M. Greely, A. Meier, C. Goldman, J. Harris</i>	3-5
Least-Cost Utility Planning <i>F. Krause, J.P. Harris, M. Levine, A.H. Rosenfeld</i>	3-6
Rated vs. Measured Energy Use of Refrigerators <i>A. Meier, K. Heinemeier</i>	3-7
Experience with Energy Efficiency Programs for New Buildings <i>E. Vine, J. Harris</i>	3-8
Analysis of Commercial Electric End-Use Data <i>H. Akbari, I. Turiel, J. Eto, L. Rainer</i>	3-9
Development of a Simplified Tool to Calculate Commercial Sector EUIs <i>I. Turiel, B. Lebot</i>	3-9
Comparative Assessment of the DSM Plans of Four New York Utilities <i>C. Goldman, E. Kahn</i>	3-10
Energy Use and Efficiency of Electronic Office Equipment <i>J. Harris</i>	3-11
EMCS for Utility/Customer Interface <i>H. Akbari, M. Goralka, K. Heinemeier</i>	3-12

Field Measurement of Heat Island Data	
<i>H. Akbari, L. Rainer, H. Taha</i>	3-13
Analysis of Residential End-Use Load Shapes	
<i>H. Ruderman, J.H. Eto, K.E. Heinemeier, A. Golan, D. Wood</i>	3-14

ENERGY CONSERVATION POLICY

Analysis of Federal Appliance Efficiency Standards	
<i>H. Ruderman, P. Chan, P. Cunliffe, A. Heydari,</i> <i>J. Hobart, J. Koomey, B. Lebot, M. Levine,</i> <i>J. McMahon, T. Springer, S. Stoft, I. Turiel, D. Wood</i>	3-15
Engineering Analyses of Appliance Efficiency Improvements	
<i>I. Turiel, A. Heydari, B. Lebot</i>	3-16
Assessment of Impacts of Appliance Standards on Manufacturers	
<i>S. Stoft, P. Cunliffe, J. Hobart</i>	3-17
Residential Energy Demand Forecasting	
<i>J. McMahon, P. Chan</i>	3-18
The Regional Energy and Economic Impacts of Appliance Efficiency Standards	
<i>J. Eto, J. McMahon, J.G. Koomey, P. Chan, M. Levine</i>	3-18
Research and Policy Studies to Promote Building Energy Efficiency in Southeast Asia	
<i>M. Levine, J. Deringer, J. Busch, Y.J. Huang, H. Akbari, K. Olson</i>	3-19

ENVIRONMENTAL POLICY ANALYSIS

Global Biodiversity: Habitat Change and Species Extinctions	
<i>W. Westman</i>	3-22
Effects of Climate Change on Vegetation in California and Baja California	
<i>W. Westman</i>	3-23

INTERNATIONAL ENERGY STUDIES

Contribution of LDC Energy Use to the Global Climate Problem	
<i>J. Sathaye, A. Ketoff, Lipper, S. Lele</i>	3-24
European Electric Power Generation: The Role of Oil	
<i>D. Hawk, L. Schipper</i>	3-25
Residential Energy Conservation Policy and Programs in Six OECD Countries	
<i>D. Wilson, L. Schipper, S. Tyler, S. Bartlett</i>	3-26
Home Electricity Use in the OECD Countries: Recent Changes	
<i>L. Schipper, D. Hawk, A. Ketoff, N. Hirt</i>	3-27
Electricity in the LDCs: Trends in Supply and Use Since 1970	
<i>S. Meyers, J. Sathaye</i>	3-28

Production, Consumption, and Trade of Natural Gas: Western Europe and the Developing Countries <i>J. Sathaye, A. Ketoff, G. Pireddu</i>	3-29
Energy Markets and Energy Demand: China and the U.S. <i>J. Sathaye, L. Schipper, M. Levine</i>	3-30

RESOURCE MARKET MECHANISMS

Competition in Electricity Generation <i>E. Kahn</i>	3-31
---	------

BUILDING ENERGY SYSTEMS PROGRAM

Introduction	4-1
Building Systems Analysis <i>R.C. Kammerud, B. Andersson, J. Birdsall, W.L. Carroll</i> <i>D. Dumortier, B. Hatfield, R.J. Hitchcock, J. Eto,</i> <i>F. Winkelmann, E. Vine</i>	4-2
Absorption Heat Pumps <i>M. Wahlig, J. Rasson, M. Warren</i>	4-5
Simulation Research <i>F.C. Winkelmann, B.E. Birdsall, W.F. Buhl, K.L. Ellington,</i> <i>A.E. Erdem, J.M. Nataf, E.F. Sowell</i>	4-6

WINDOWS AND LIGHTING PROGRAM

Introduction	5-1
Windows and Daylighting <i>S.E. Selkowitz, D. Arasteh, C. Benton, D.L. DiBartolomeo,</i> <i>R.L. Johnson, J.J. Kim, J.H. Klems, C.M. Lampert,</i> <i>K. Papamichael, M.D. Rubin, R. Sullivan, and G.M. Wilde</i>	5-2
Lighting Systems Research <i>S.M. Berman, R.R. Verderber, R.D. Clear, D. Crawford,</i> <i>D.D. Hollister, D.J. Levy, O.C. Morse, F.M. Rubinstein,</i> <i>M.J. Siminovitch, G.J. Ward, and R. Whiteman</i>	5-11

Center for Building Science

Annual Report

FY 1988

Introduction

The Center for Building Science consists of four programs in the Applied Science Division. It was established to provide an umbrella so that groups in different programs but with similar interests could combine to perform joint research, develop new research areas, share resources, and produce joint publications. As detailed below, potential savings for the U.S. society from energy efficient buildings are enormous. But these savings can only be realized through an expanding federal R&D program that develops expertise in this new area. The Center for Building Science develops efficient new building components, computer models, data and information systems, and trains needed building scientists.

Rationale for Building Science

Buildings are the major energy consumer in the U.S. In 1985 our buildings sector used \$170 billion worth of energy, mainly as electricity. Of the total annual U.S. electricity sales of \$150 billion, most (\$110 billion) went to the building sector of our economy for operating the equipment, lighting, and appliances (see **Table 1**). The use of fuels in buildings is also substantial: \$60 billion out of the total of \$290 billion.

Since 1973, rising energy prices remarkably reduced our energy bills. In the case of buildings, in the 13 years from 1973 to 1986, our stock of households has grown 30% but residential energy use by only 6%. Commercial floor space has grown 40%, but commercial energy use by only 23%. If we assume (incorrectly) that frozen efficiency would have kept energy use constant per household and per unit floor area of commercial buildings, then we find that our improved energy efficiency has saved 5 quads/year, worth \$32B/year. But in fact in the decade before 1973, the number of households grew 21% and residential energy use grew 55%—almost 10% greater than the 46% real growth of GNP. This rapid rise was presumably because we were installing central heating and cooling and many large appliances. If we assume (more realistically) that “business as usual” meant residential energy use proportional to GNP, then our improved building efficiency has now saved us 6 quads/year, worth \$43B/year.

Before 1973, energy prices were low and there was little interest in improving our efficiency, so it was conventional wisdom that our energy use would grow at least as fast as GNP. In **Figure 1a** (for the U.S.) the heavy solid line represents actual consumption of total primary energy. The lighter solid line is simply GNP scaled to go through the 1973 energy use of 73 quadrillion BTU (73 quads). Backcast to 1965, we see that GNP and energy use tracked nicely, corresponding to frozen efficiency, but forecast to '85 we see GNP rising 33% while actual use has leveled off at 73 quads. Thus, we have achieved an astounding 33% increase in efficiency, and a remarkable \$150 Billion in savings, but are still left with a \$440 Billion annual energy bill.

In **Figure 1**, the broken lines represent oil plus natural gas, which are partially interchangeable in our society since many boilers switch from one fuel to the other depending on price. Despite a 33% growth in GNP, oil & gas use has declined even faster than our (also declining) domestic production of fossil fuels (shown by the dotted line).

Table 1. U.S. Energy Expenses, 1985*			
Sector	Fuel (\$10 ⁹)	Electricity (\$10 ⁹)	Total (\$10 ⁹)
Buildings	60	110	170
Residential	40	60	100
Commercial	20	50	70
Industry	70	40	110
Buildings	3	7	10
Transport	160	0	160
TOTAL	290	150	440

* Excluding Federal subsidies and rounded to the nearest 10 billion

Source: *State Energy Price and Expenditure Report 1985*, DOE/EIA-0376(85) October 1987.

Notes to Table 1:

1. To update these costs to 1986 in 1986\$ would raise the electricity costs, lower the fuel costs, and probably give a few per cent total reduction. [Between 1980 and 1983, total energy bills rose 3% per year, electricity bills rose 6% per year, and the difference (fuel) dropped very slightly.]
2. In addition to the tabulated costs paid directly by customers in 1984, there were federal subsidies (11%) of \$44 billion, bringing the energy total to about \$480 billion, larger than all public and private expenditures for Health (\$400B), Defense (\$300B), Education (\$200B), or Farm Income (\$140B). For source of \$44B energy subsidies see Heede, Morgan, and Ridley, "*The Hidden Costs of Energy*," Center for Renewable Resources, Washington, D. C., 20036 (1985).
3. Industrial buildings: In addition to 50 billion square feet of commercial buildings, there are 5 to 10 billion square feet of industrial buildings, probably closer to 10B ft², resulting in the estimate of \$10B energy bill shown in the table.




FIGURE 1. U.S. and OECD Energy Use: Actual and Projected by GNP. Projected energy use is calculated on a GNP basis in constant 1985 dollars, with both forecast and "back-cast" values from 1973. Primary energy (left-hand scales) includes fuel burned at the power plant, in units of "quads" [quadrillion (10^{15} Btu)]. The oil and gas savings were converted from quads to fractions of OPEC capacity using an estimated 1986 total OPEC capacity of 29 Mbod (58 quads). For the right-hand scales, quads were converted to 1985 dollars using the 1985 U.S. cost of energy (about \$440 billion). The upper figure is for the U.S. and the lower figure shows comparable data for the entire Organization for Economic Cooperation and Development (OECD). In 1985, oil and gas savings for the U.S. were one-half of total OPEC capacity, and for the OECD oil and gas savings were 5/6 of total OPEC capacity.

XCG 861-7060 C (U.S.), XCG 861-7060 B (OECD)

Compared to 1973, we are now annually saving 1/2 of OPEC's current capacity of 29 million barrels of oil per day. It seems certain that if we had not reduced the need for this oil and gas, it would have come only from imports, since our domestic production is steadily declining.

Figure 1b tells the same story for the OECD, which includes all of North America, Western Europe, and Japan. The OECD annual energy bill is \$900 B, but (compared to 1973 efficiency) we have saved \$250 B/year. Our oil & gas savings are 5/6 of current OPEC capacity. Because of the North Sea, OECD production of oil and gas is still rising, but nowhere near enough to supply the amount we have saved. So, again, OECD imports would be nearly 5/6 of OPEC capacity higher.

Figure 2 further illustrates, over a much longer time scale from 1949 to 1987, the old "lock-step" relationship of energy use to GNP before 1973, and also shows the large contribution from improved energy efficiency since 1973. Although one-third to one-half of the savings from conservation since 1973 are due to structural changes in the economy, the net effect in 1987 is a reduction in energy use of 27.4 quads and avoided CO₂ emissions of almost 500 million tons. **Figure 2** also shows that in 1987 the total amount of energy from non-fossil sources was 35.6 quads—equal to one-third the energy we would have used if we were still operating at 1973 efficiency levels. This highlights the importance of energy efficiency as the bridge to a renewable energy future.

What would we be paying for oil and gas if OPEC were at 100% of capacity and in addition there were still a major shortage of oil? **Figure 3** hints at the answer—OPEC was able to affect dramatic price increases in those years where more than 80% of its capacity was in use. This suggests substantial price increases every year above \$25/barrel, which we paid during the period from 1979 to 1984, disastrous increases of \$100, 200 or even 300 Billion in our trade and budget deficits, and a global security problem, compared to which the present problems in the Persian Gulf pale to insignificance.

How much time do we have before OPEC production again exceeds 80% of capacity? From 1973 to 1985 world oil demand increased less than 1% per year, but in 1986 low oil prices caused demand to increase by 3%. The recovery in oil prices during 1987 improved the competitive positions of other fuels so that world oil demand rose by only 1.4% in 1987. Each percentage point increase in world oil demand is equivalent to 0.6 million barrels of oil per day (Mbod). OPEC supplies over 30% of the world's oil, and **Figure 3** shows that current OPEC production is about 65% of capacity—3 Mbod below 80% of capacity. If world oil demand continues to grow at between 1 to 3% per year, it will take about 8 years for OPEC to reach or exceed 80% of capacity where large price increases are likely to occur.

How can these drastic increases be delayed? >From a technical standpoint, the potential energy savings from both retrofitting existing buildings and constructing efficient new buildings are remarkable. One way of estimating the savings that are realistically obtainable is by a "least-cost" scenario that maximizes life-cycle costs. A recent study for the state of Michigan indicates that, by the end of a 20 year period of new construction and retrofitting, the potential technical savings are 60% and a realistic scenario could yield 35% savings.

Another continuing study by the Heat Island Program shows that one of the cheapest ways to reduce peak-power demand and save kilowatts of air conditioning power is to plant urban trees. This is discussed more thoroughly by Akbari et al in the Energy Analysis chapter, but put very simply the recipe is: pay \$15 to \$75 to plant and water 3 trees around a house, wait 10 years for the trees to grow, and then save about 1 or 2 kW of peak power and about 750 to 2000 kWh/year in air conditioning energy per house.

U.S. Primary Energy Use: Actual vs. Predicted by GNP (1949-1987)




FIGURE 2. U.S. Primary Energy Use: Actual vs. Predicted by GNP (1949-1987). The figure shows energy consumption by source for the U.S. from 1949 to 1987. The upper dashed line is GNP in 1982 dollars scaled to go through 74.3 quads in 1973, and illustrates how GNP and energy use were in a lock-step before 1973. Although one-third to one-half of the savings are due to structural changes in the economy, the net effect in 1987 is a reduction in energy use of 27.4 quads and avoided CO₂ emissions of about 500 million tons. Adding the contribution from conservation to the other non-fossil sources gives 35.6 quads—equal to one third of the energy we would have used if we were still operating at 1973 efficiency levels.

Sources: U.S. DOE/EIA, *Annual Energy Review 1986*, U.S. DOE/EIA, *Monthly Energy Review*, October 1987, January 1988, Council of Economic Advisors, *Economic Report to the President*, January 1988.

OPEC Pricing Behavior




FIGURE 3. OPEC Pricing Behavior, 1975 through March 1989. The figure suggests that OPEC was able to maintain or increase prices only during those years when 80% or more of its capacity was in use. If this still holds true we only have a 1 or 2 Mbod margin of safety before OPEC regains control of world oil prices. OPEC capacity is defined here as the "realistic" maximum sustainable capacity that can be achieved within 30 days, and sustained for a period of 90 days. Estimates of OPEC capacity have varied over the past 15 years from a high of 39.3 Mbod in 1975 to a low of 28.0 Mbod in 1983 during the Iran-Iraq war. Current capacity is estimated to be 28.2 Mbod. These estimates are available from the U.S. Energy Information Agency, Office of Energy Markets and End-Use, and are based on CIA data. All data shown are average values for the year, and recent data are averages for the month.

Table 2 compares the cost of saving a kWh of electricity and a pound of carbon (as CO₂) for urban trees and several other familiar strategies such as efficient electric appliances and efficient cars. From **Table 2** it is clear that urban trees are the most cost-effective measure—about 10 times cheaper than nuclear power.

Improving our energy efficiency will also improve our economic competitiveness. In 1985, the U.S. used 11.2% of its GDP for energy and Japan used 5%. **Figure 4** clarifies this point and puts the efficiency, as measured by energy use per GDP, of other countries in perspective. The details of the figure are explained in the caption, but the summary is that we spend about 6% more of our GDP on energy than do the economical Japanese. Japan's per-capita income has come from behind and is now passing that in the U.S. Nevertheless, we can be proud that we have the second best record of the nine countries pictured, thanks to appliance and automobile labels, automobile standards (*and* imported cars), building standards, federal and utility conservation programs, a vigorous R&D program, and of course the market.

How has Japan become as productive as the U.S. on less than half the energy? The answer lies in Japan's unflagging commitment to energy efficiency. For example, between 1973 and 1985 energy use per pound of steel produced had declined by 15%, electricity used to operate new refrigerators had dropped by 73%, and electricity used to run room air conditioners had dropped 42%. Japanese new cars are already at 29 mpg and under the influence of their gasoline prices of nearly \$3/gallon will probably continue to climb, whereas the U.S. CAFE standards are now stuck at 26 mpg.

Of course to achieve this efficiency the Japanese had to make investments, whose repayment eats into about 20% of their savings. So instead of having 6% more of their GDP available than we do, they really have gained only about 5%. However, about half of this gain is due to lifestyle differences—Japanese buildings are kept cooler in the winter and warmer in the summer, their houses and apartments are smaller, and their appliances and cars are smaller. In fact, on a volume basis our appliances and houses are either as efficient or more efficient than the Japanese, the same is true on a horsepower basis of most of our automobiles. This means that the Japanese probably have only a 3% edge over the U.S. in terms of energy efficiency. This differential of 3% of GDP means that, even if all else were equal, our products cost on average about 3% more than comparable Japanese products, thus impairing our balance of payments and the dollar/yen ratio.

Let us examine in more detail what will happen in 10 or 20 years if OPEC regains control and energy prices double. Without a continuing, vigorous conservation program, our energy bill could zoom from 10% to 20% of GNP. We predict that the Japanese will continue to invest in efficiency even during the glut, get down to 3% of GNP at today's cheap prices, and later climb back to only 6%. And they will be experienced at manufacturing and exporting energy-efficient products, which seem likely to be in demand. If this occurs the competitive outlook will be very bleak indeed.

So a large part of the prescription for our economic problems is a continuing healthy dose of improving energy efficiency in all sectors of the economy. The potential *societal* savings are of great importance to our country. They will be manifest in a better balance of trade (less purchase of foreign oil and more efficiently manufactured products), the freeing of investment capital (less expenditures on the development of oil, gas, coal, and electricity), enhancement of national security (less dependence on Middle East petroleum), an extension of the energy services available from the Strategic Petroleum Reserve, and a lessening of environmental insults.

Table 2. Cost effectiveness, energy savings, and carbon savings of urban trees/light surfaces, efficient electric appliances, and efficient cars (Akbari 1988).

Measure	CCE ¹ (¢/kWh)	Payback Time (yr)	CCC ¹ (¢/lb C)	Implemented Fraction ¹ (%)	ΔUEC^1 by 2000	ΔE (Quad/yr)	ΔC (M Tons/yr)	Cost of Program (\$B)
Urban Trees/ Light Surfaces ²	0.2-1.0	0.3-1.8	0.25-1.25	50	24%	0.55	18	0.5-2.5
Efficient Electric Appliances ³	2	3	2.5	100	17%	.6	21	10
Efficient Cars ⁴	50¢/gal	2.5	8.3	100%	38%	2.8	60	50
Coal Power ⁵	8	10	Base Case	—	—	—	—	—
Nuclear Power ⁵	11	?	4	10% of Coal	—	—	60	84

1. a) CCE is Cost of Conserved Energy, CCC is Cost of Conserved Carbon, and UEC is Unit Energy Consumption.
b) Cost of Program is the nation-wide cost for implementing the measure.
2. Urban Trees/Light Surfaces
a) We assumed 100 M trees cost \$5-25 each (including water for 2 years) for a total cost of \$B 0.5-2.5, a real interest rate of 7%, 3 seedlings planted per air conditioned house, and a growth period of 10 years to yield adequate shade.
b) In calculating CCC, we assumed that electricity is produced from coal-fired power plants at 1 kWh = 11,600 Btu = ~ 0.8 lb of carbon.
c) ΔUEC for air conditioning is direct + indirect effects of urban trees/white surfaces for both residential and commercial sectors.
3. Appliances (Source: Geller 1987, based on the 1987 NAECA)
4. Cars (Source: Ross 1987)
a) The CCE for improving the fleet efficiency of cars from 26 to 36 mpg is estimated to be 50¢/gal.
b) The CCC assumes 6 lb of carbon in a gallon of gasoline.
c) Today, at 18.6 mpg, we use 6.63 Mbod of transportation gasoline. The 26 mpg standard will reduce this 6.63 to 4.75 Mbod. Further gain from 26 to 36 mpg will reduce 4.75 to 3.42, saving 1.33 Mbod, corresponding to 2.8 Quads.
e) Program cost is based on 125 million cars and light trucks at an additional cost of \$400 each.
5. Coal Power and Nuclear Power (Source: Delene 1988)
a) This is *not* the CCE, but is the cost of coal or nuclear power delivered to the customer. The U.S. median cost for a new coal plant is 4.7 ± 0.7 ¢/kWh, and the U.S. median cost for a pressurized-water nuclear reactor is 7.7 ¢/kWh (this doesn't include decommissioning costs or the very uncertain physical, environmental, and economic risks). Add 3-4 ¢/kWh to both of the above costs for transmission and distribution.
b) The CCC assumes nuclear replaces a retiring coal plant yielding a difference of 3 ¢/kWh. At 0.8 lb/kWh of carbon from coal, the nuclear option translates to a CCC of 4 ¢/lb C.
c) Assuming nuclear replaces 10% of coal-fired plants as they are retired, translates to about 30 baseload plants (30 GW). The current U.S. median cost for nuclear plants is \$2800/kW in 1986 dollars.

Energy Consumption and GDP: 1970-1985




FIGURE 4. Primary Energy Use vs GDP (both per capita) for Nine Industrial Countries. Each country is represented by a connected sequence of points beginning in 1970 and ending in 1985. The conversion from local GDP to dollars is based on July 1, 1987 exchange rates; earlier points are plotted using individual national deflators. The lines labeled "U.S. energy use at 5%, 10%, 15% and 20% of GDP", are based on an average price of primary energy in U.S. 1987 dollars, or \$6.14/GJ. For oil, we use 1 ton-equivalent = 42.6 GJ; hydroelectric and nuclear electricity are converted to primary energy using IEA's generation efficiency of 38.5%, except for Japan which is converted at 35.1%.

Sources: Price: U.S. DOE/EIA 1984, *State Energy Price and Expenditure Report 1985*, October 1987. Income and Population: IMF International Financial Statistics, 1986. Energy Consumption: OECD/IEA *Energy Balances 1970-1985*, 1987. Soviet Data: *UN Demographic Yearbook*, 1985.

There is no question that conservation has been of tremendous benefit to our society and that these benefits will continue only if energy related research is continued. Work in the following areas will be especially valuable. Building energy research accelerates energy and cost savings available through conservation by 1) developing innovative concepts that lead to energy efficient products (e.g., advanced lighting systems, advanced windows), 2) gaining an understanding of the performance of actual buildings, 3) predicting the performance of new approaches (e.g., daylighting), and 4) developing the tools (e.g., computer programs) for the design of efficient buildings and the formulation of standards for buildings. Also, research is critical to understanding the human health and productivity in buildings, including 1) indoor air pollution, and 2) the relationship of lighting to performance. Finally, analytic studies can help predict the impact of energy policies and programs on society: for example consumers, the building industry, and the energy utilities.

The work of the Center is organized into four programs:

1. Energy Analysis,
2. Building Energy Systems,
3. Windows and Lighting, and
4. Indoor Environment.

There are approximately 170 people in these four programs which represent about 70% of the effort of the Applied Science Division. Accomplishments of these programs during FY 1986 (ending September 30, 1986) are contained in the following four chapters, reprinted from the Applied Science Division Annual Report. Activities that particularly involved Center Staff are described in the next three sections.

California Institute for Energy Efficiency

In 1986, the Center Director, with others from the Applied Science Division and the Universitywide Energy Research Group (UERG), conceptualized a research program on energy end-use and efficiency that would address the needs of California. An organizing committee was formed and the concept was named the California Institute for Energy Efficiency (CIEE). The goals of this institute were to:

- 1) carry out a mid-term research program based primarily on the expertise of LBL and the UC campuses, but involving other California research and education institutions;
- 2) receive financial support from California energy utilities (e.g. PG&E);
- 3) receive institutional backing from the California Public Utilities Commission (CPUC) and the California Energy Commission (CEC);
- 4) establish mechanisms for transferring research results to utilities; and
- 5) benefit California ratepayers through lower energy costs.

It was difficult to devise an organizational entity that was simultaneously compatible with CIEE's intended purpose and acceptable to the utilities, LBL, UERG, and the University of California Office of the President (UCOP). During FY 88 the organizing committee, working with William Frazer (Senior Vice President of Academic Affairs), solved this problem by establishing CIEE as a provisional Organized Research Unit (ORU) that is a "branch" of UERG on the LBL "campus".

At the same time the organizing committee was giving birth to CIEE, efforts were underway to obtain funding from California utilities and commissions. These efforts resulted in LBL funding amounting to \$785K by the end of FY 1988 (this does not include UERG

funding). At this point, the future of CIEE as an established research institute seems assured.

Testimony

Testifying before congressional committees and before state utility commissions is an important activity of the Center for Building Science. During 1988 the director testified before the following committees on behalf of the following organizations:

- 1) Before the Subcommittee on Energy and Power of the Committee on Energy and Commerce, U.S. House of Representatives, Washington D.C.
- 2) On behalf of the State of Connecticut Office of Policy and Management, Department of Public Utility Control, regarding application of Connecticut Light & Power Company to amend its rate schedules.
- 3) Before the Subcommittee on Fisheries, Wildlife Conservation and the Environment of the Committee on Merchant Marine and Fisheries, U.S. House of Representatives. Washington, DC.
- 4) On behalf of the Conservation Law Foundation for the Massachusetts Department of Public Utilities investigation into the pricing and ratemaking treatment to be afforded new electric generating facilities which are not qualifying facilities.
- 5) On behalf of the State of Michigan Public Service Commission regarding its hearings in the matter of the application of Midland Cogeneration Venture Ltd. partnership for approval of capacity charges contained in a power purchase.
- 6) On behalf of the Conservation Law Foundation of New England and the Natural Resources Council of Maine before the State of Maine Public Utilities Commission regarding the petition by the Central Maine Power Company for a certificate of public convenience and necessity for purchase of generating capacity and energy from Hydro Quebec.
- 7) Before the Wisconsin Public Service Commission's hearings on Advance Plan 5
- 8) At the public hearing on the California Energy Commission's 1988 Conservation Report.
- 9) On behalf of the Conservation Law Foundation and the Vermont Natural Resources Council, Vermont Public Interest Research Group, before the State of Vermont Public Service Board regarding the investigation into least-cost investments, energy efficiency, conservation, and management of energy demand

More details of these activities can be obtained by requesting publications listed at the end of this section.

Least Cost Utility Planning

During 1988 the National Association of Regulatory Utility Commissioners (NARUC) convened in San Francisco for their annual meeting. Members of the NARUC Conservation Committee were invited to Lawrence Berkeley Laboratory for a full day of presentations describing least cost utility planning (LCUP) research conducted by programs of the Center. Twenty one NARUC members (including several commissioners) accepted the invitation. Proceedings of the meeting were presented to all attendees. Sessions went well and the overall reaction of the participants was very enthusiastic. In fact Commissioner Stone, Illinois Commerce Commission, sent a thank you letter that said in part:

"The program was really well planned and consistently engrossing. I think it obvious that interest was high and enthusiasm great..."

Funding was obtained for a project to create a LCUP Information Systems Network because of efforts by the Director of the Center and others. The goal of this project is to update and merge technology data bases from such institutions as EPRI, GRI, LBL in this country and similar institutions in other countries. During FY 88 contacts were established with representatives of EPRI, GRI, and NARUC and discussions are underway to devise a procedure for combining information in the databases of these three institutions. In addition the establishment of a least cost journal is being actively pursued by the Center Director and Stephen Wiel, Commissioner, Nevada Public Service Commission.

PUBLICATIONS LIST

CENTER FOR BUILDING SCIENCE

This list of publications covers the period from January 1980 to July 1988. For earlier or more recent Center Publications, please call (415) 486-4834. A cumulative list of publications for the programs in the Center may also be obtained by calling this number.

Publications and Testimony (Popular articles follow)

1988

LBL-25228

"Promoting Efficiency Investments in New Buildings", J. Koomey and A. Rosenfeld, August 1988, To be presented at the 1988 ACEEE Summer Study on Energy Efficiency in Buildings Pacific Grove, CA., August 28-September 3, 1988 (draft).

LBL-25179

"The Impact of Summer Heat Islands on Cooling Energy Consumption and Global CO₂ Concentration", H. Akbari, J. Huang, P. Martien, L. Rainer, A. Rosenfeld, and H. Taha, September 1988, To be presented at the 1988 ACEEE Summer Study on Energy Efficiency in Buildings. Pacific Grove, CA., August 28-September 3, 1988, (draft).

LBL-24920

"Developing Demand-Side Energy Resources in the United States: Trends and Policies", E. Mills, J. Harris, and A. Rosenfeld, April 1988, Accepted for publication in *Energie Internationale*, 1988-1989, April 19, 1988 (draft).

LBL-24008

"Residential Cooling Loads and the Urban Heat Island: The Effect of Albedo", H. Taha, H. Akbari, A. Rosenfeld, and J. Huang, January 1988, Accepted for publication in *Building and Environment*.

LBL *

"Energy Efficiency, Competition, and Least-Cost Planning", A. Rosenfeld, E. Mills, R. Mowris, and J. Koomey, April 1988, Presented at the NARUC Least Cost Utility Planning Conference, Aspen, CO., April 10-13, 1988.

LBL *

"Energy Efficiency Versus Draining America", A. Rosenfeld, March 31 1988, Testimony for Oversight Hearing on Oil Development in ANWR and National Energy Policy; Subcommittee on Fisheries and Wildlife Conservation and the Environment, Committee on Merchant Marine and Fisheries, U.S. House of Representatives Washington, DC.

LBL *

"Urban Trees and Light-Colored Surfaces: Inexpensive and Effective Strategies for Reducing Summer Heat Island, Cooling Energy Consumption, and Global CO₂ Concentration", H. Akbari, J. Huang, P. Martien, L. Rainer, A. Rosenfeld, and H. Taha, May 1-3 1988, Presented at the EPA/LBL Workshop on Energy Efficiency and Structural Change: Implications for the Greenhouse Problem. Berkeley, CA.

LBL *

"Energy Efficiency: The Progress and the Promise", A. Rosenfeld, E. Mills, and R. Mowris, May 1-3 1988, Presented at the EPA/LBL Workshop on Energy Efficiency and Structural Change: Implications for the Greenhouse Problem. Berkeley, CA.

LBL *

"Testimony on behalf of the State of Michigan Public Service Commission regarding its hearings in the matter of the Application of Midland Cogeneration Venture Ltd", A. Rosenfeld, June 13 1988, Partnership for Approval of Capacity Charges Contained in a Power Purchase Agreement with Consumers Power Company, Case #U-8871 et al., Lansing, MI.

LBL *

"Testimony", A. Rosenfeld, May 2 1988, Testimony on behalf of the Conservation Law Foundation to the Massachusetts Department of Public Utilities investigation into the pricing and ratemaking treatment to be afforded new electric generating facilities which are not qualifying facilities.

LBL *

"The Importance of Research and Development in Advancing Energy Efficiency", J. Harris, E. Mills, R. Mowris, A. Rosenfeld, H. Geller, M. Ledbetter, June 1988, DRAFT.

LBL *

"Testimony on behalf of the Conservation Law Foundation of New England and the Natural Resources Council of Maine regarding the Petition for Certificate of Public Convenience and Necessity for Purchase of Generating Capacity and Energy from Hydro Quebec", A. Rosenfeld, May 16 1988, Before the State of Maine Public Utilities Commission, Central Maine Power Company, Augusta, Docket No. 88-111 ME.

LBL *

"Testimony on behalf of the Conservation Law Foundation and the Vermont Natural Resources Council, Vermont Public Interest Research Group, regarding the Investigation into Least-Cost Investments, Energy Efficiency, Conservation, and Management of Energy Dem", A. Rosenfeld, July 25 1988, before the State of Vermont Public Service Board, Docket No. 5270, Montpelier, VT..

LBL *

"Energy Efficiency and Least-Cost Planning", A. Rosenfeld, R. Mowris, and J. Koomey, July 12 1988, Comments prepared for the California Energy Commission, Conservation Programs Committee, Public Hearing on the Draft 1988 Conservation Report, Sacramento, CA.

LBL *

"Energy-Efficient Buildings", A. H. Rosenfeld and D. Hafemeister, 1988, *Scientific American*, Vol. 258, No. 4, April 1988, pp. 78-85.

LBL *

"Promoting Efficiency Investments in New Buildings: A New Policy to Improve Building Efficiency, Reduce Pollution, and Avoid Power Plant Construction", A. Rosenfeld and J. Koomey, August 4 1988, testimony on behalf of Wisconsin's Environmental Decade before the Wisconsin Public Service Commission's Hearings on Advance Plan 5, Docket No. 05-EP-5, Madison, WI.

1987

LBL-24755b

"Conservation, Competition and National Security", A. Rosenfeld, November 4 1987, [Some concluding remarks made at the 15th Annual Illinois Energy Conference, University of Illinois at Chicago, November 10-11, 1987.] Published in *Strategic Planning and Energy Management Journal* Vol. 8, No. 1, 1988, pp. 5-30.

LBL-24755a

"Conservation, Competition and National Security", A. Rosenfeld, November 4 1987, Testimony for the Hearing on Energy Security: The Role of Conservation in the National Energy Picture; Subcommittee on Energy and Power, Committee on Energy and Commerce, U.S. House of Representatives. Washington, D.C.

LBL-23025

"Analysis of Michigan's Demand-Side Electricity Resources in the Residential Sector: Volume I, Executive Summary", F. Krause, A. Rosenfeld, M. Levine, May 1987, Report prepared for the State of Michigan Department of Commerce and Public Service Commission.

LBL-22932

"Managed Versus Unmanaged 7-Year Electric Growth: Californians Needed 3 New Plants, Texans Needed 11", E. Mills and A. H. Rosenfeld, February 1987, Excerpted in *Physics and Society*, a quarterly publication of the American Physical Society, Vol. 16, Number 2, pp. 3-4, April, 1987.

LBL-21291

"The Potential of Vegetation in Reducing Summer Cooling Loads in Residential Buildings(Revision of #251.)", J. Huang, H. Akbari, H. Taha, A. Rosenfeld, March 1987, *Journal of Climate and Applied Meteorology*, Vol. 26, No. 9 (September 1987), pp. 1103-1116.

LBL *

"Testimony", A. Rosenfeld, December 1987, Testimony on Behalf of the State of Connecticut Office of Policy and Management, Department of Public Utility Control, regarding Application of Connecticut Light & Power Company to Amend Its Rate Schedules, December 9-10, 1987.

LBL *

"Conservation and Competitiveness", Arthur H. Rosenfeld, July 1987, Testimony for the Hearing on Economic Growth Opportunities in Energy Conservation Research, House Budget Committee Task Force on Community and Natural Resources. Washington, D.C. July 15, 1987.

LBL *

"Energy-Efficient Buildings: The Case for R&D", A. Rosenfeld, March 1987, Testimony for Hearing on Conservation and Renewables, Subcommittee on Energy Research and Development, Senate Committee on Energy and Natural Resources. Washington, DC, March 26, 1987.

LBL *

"Federal Research and Development on Energy Efficiency: A \$50 Billion Contribution to the U.S. Economy (Revision of #249.)", A. Rosenfeld, H. Geller, J. Harris, M. Levine, January 1987, Presented at ASHRAE Annual Meeting (January 1987) and published in *ASHRAE Transactions* 1987, V. 93, Pt. 1, pp. 1011-1024.

LBL *

"The Successes of Conservation", A. Rosenfeld, May 1987, Published in *Proceedings of the Workshop on Integrated Energy Resources Planning for Electricity on Oahu*, pp. 40-98. Honolulu, HI, May 20-21, 1987.

LBL *

"The Role of Federal Research and Development in Advancing Energy Efficiency: A \$50 Billion Contribution to the US Economy", H. Geller, J. Harris, M. Levine, A. Rosenfeld, 1987, *Annual Review of Energy* 1987, Vol. 12, pp. 357-395.

LBL *

"Testimony", A. Rosenfeld, June 1987, Direct Testimony Before the Public Service Commission of the District of Columbia on Behalf of the Office of the People's Counsel (OPC), Formal Case No. 834, Phase II, New Issue 16 Washington, D.C. June 18, 1987.

LBL *

"The Successes of Conservation", A. Rosenfeld and E. Mills, July 1987, Published in 'Demand-Side Management and Electricity End-Use Efficiency,' *Proceedings from the NATO Advanced Study Institute* (Eds. A. de Almeida and A. Rosenfeld), pp. 17-61. Povo do Varzim, Portugal, July 20-31, 1987.

LBL *

"The Potential for Electrical Efficiency in the Residential Sector Case Study Michigan, USA", F. Krause, W. Colborne, A. Rosenfeld, July 1987, Published in 'Demand-Side Management and Electricity End-Use Efficiency,' *Proceedings from the NATO Advanced Study Institute* (Eds. A. de Almeida and A. Rosenfeld), pp. 621-642. Povo do Varzim, Portugal, July 20-31, 1987.

1986

LBL-21893

"Undoing Uncomfortable Summer Heat Islands Can Save Gigawatts of Peak Power", H. Akbari, H. Taha, J. Huang, A. Rosenfeld, August 1986, Published in *Proceedings of the American Council for an Energy-Efficient Economy 1986 Summer Study on Energy Efficiency in Buildings*, Vol. 2, pp. 2.7-2.22, Santa Cruz, CA, August 17-23, 1986.

LBL-21831

"Technical Potential for Electrical Energy Conservation and Peak Demand Reduction in Texas Buildings", B. Hunn, M. Baughman, S. Silver, A. Rosenfeld, and H. Akbari, February 1986, Report to the Public Utility Commission of Texas.

LBL-20557

"Avoided Gigawatts Through Utility Capital Recovery Fees", A. H. Rosenfeld and M. E. Verdict, August 1986, Published in *Proceedings of the American Council for an Energy-Efficient Economy 1986 Summer Study on Energy Efficiency in Buildings*, Vol. 8, pp. 8.195-8.202, Santa Cruz, CA, August 17-23, 1986.

LBL-20525

"Planning For Oil Overcharge Funds: The California Experience", Edward Vine, Jayant Sathaye, and Arthur H. Rosenfeld, 1986, Published in *Energy*, Vol. 11, No. 10, pp. 977-984.

LBL-20507

"Smart Meters and Spot Pricing: Experiments and Potential", A. H. Rosenfeld, D. A. Bulleit, and R. A. Peddie, March 1986, Published in *IEEE Technology and Society Magazine*, Special Issue on Efficient Use of Energy, Vol. 5, No. 1, (Ed. R. H. Williams).

LBL-20364

"Ventilation Strategies for Different Climates", H. Feustel, M. Modera, and A. Rosenfeld, April 1986, Published in *Proceedings of the ASHRAE IAQ '86 Conference: 'Managing Indoor Air for Health and Energy Conservation,'* Atlanta, GA, pp. 342-363, April 20-23, 1986.

LBL *

"Federal R&D on Energy Efficiency: A \$50 Billion Contribution to the U.S. Economy (A White paper on the Consequences of Proposed FY 1987 Budget Cuts) [Parts A&B]", A. Rosenfeld, J. Harris, M. Levine., March 1986, Written by the American Council for an Energy-Efficient Economy and the Energy Conservation Coalition. March 4, 1986..

LBL *

"Residential Conservation Power Plant Study, Phase I -- Technical Potential", H. Geller, A. Almeida, B. Barkovich, C. Blumstein, D. Goldstein, A. Meier, P. Miller, O. de la Moriniere, A. Rosenfeld, and L. Schuck, February 1986, Report prepared for Pacific Gas and Electric Company by the American Council for an Energy-Efficient Economy.

LBL *

"Testimony", A. H. Rosenfeld, April 1986, address to the Electricity Demand & Supply Session, Legislative Assembly of Ontario, Select Committee on Energy pp. 27-49, April 9, 1986.

1985

LBL-20527

"California's Petroleum Violation Escrow Account (PVEA) Evaluation Report", Arthur Rosenfeld, Jayant Sathaye, and Edward Vine, March 1985, Consultant Report (two volumes) prepared for the California Energy Commission, March 15, 1985.

LBL-20508

"Electrical Energy Conservation and Peak Demand Reduction B. Potential for Buildings in Texas: Preliminary Results", B. D. Hunn, M. L. Baughman, S. C. Silver, A. H. Rosenfeld, and H. Akbari, September 1985, Published in the *Proceedings of the Second Annual Symposium, Improving Building Energy Efficiency in Hot and Humid Climates*, Texas A&M University. College Station, TX, pp. 271-278, September 24-26, 1985.

LBL-20506

"Residential Energy Efficiency: Progress Since 1973 and Future Potential", Arthur H. Rosenfeld, April 1985, Chapter 6 from the *Proceedings of the APS Short Course 'Energy Sources: Conservation and Renewables,' AIP Conference Proceedings No. 135*, Washington, DC, April 27-28, 1985.

LBL-20505

"Energy Conservation in Large Buildings", A. Rosenfeld and D. Hafemeister, April 1985, Chapter 8 from the *Proceedings of the APS Short Course 'Energy Sources: Conservation and Renewables,' AIP Conference Proceedings No. 135*, Washington, DC, April 27-28, 1985.

LBL-19448

"The High Cost-Effectiveness of Cool Storage in New Commercial Buildings", O. de la Moriniere and A. H. Rosenfeld, June 1985, Presented at ASHRAE Annual Meeting, Honolulu, HI, ASHRAE Transactions HI-85-15 No. 4.

LBL-19135

"Shifting Peak Power: At the Meter, Beyond the Meter, and At the Checkbook", A. H. Rosenfeld, May 1985, Presented at the PG&E Energy Expo (Session 220: Load Management with HVAC), Oakland, CA, May 22, 1985.

LBL *

"Energy-Efficient U.S. Buildings and Equipment: Progress Toward Least Lifecycle Cost", A. H. Rosenfeld, June 1985, Proceedings of the Soviet-American Symposium on Energy Conservation, Moscow Published as a special issue of *Energy*, Eds. R. Socolow and M. Ross, Vol. 12, No. 10/11, pp. 1017-1028, 1987.

LBL *

"Statement on the Least Cost Utility Planning Initiative", A. H. Rosenfeld and M. D. Levine, September 1985, Testimony before the Subcommittee on Energy Development and Applications of the Committee on Science and Technology, U.S. House of Representatives Washington, D.C. September 26, 1985.

LBL *

"Technological Frontiers and the Public Utilities: The Regulatory Challenge", A. H. Rosenfeld, March 1985, address to the 'Conservation, Load Management and Improved Metering for Electric Utility Customers' session, pp. 115-130, a CPUC-sponsored symposium at Stanford University, Stanford, CA, March 28-29, 1985.

1984

LBL-18669

"Home Energy Rating Systems: Sample Approval Methodology for Three Tools", Y. J. Huang, B. Dickinson, C. Hsui, A. H. Rosenfeld, B. S. Wagner, August 1984, published in *Doing Better: Setting An Agenda for the Second Decade, Proceedings from the 1984 ACEEE Summer Study on Energy Efficiency in Buildings*, Vol. B, pp. B135-B143 Santa Cruz, CA.

LBL-17553

"Statement on the DOE FY'85 Conservation Budget Request for Buildings & Community Systems", A. H. Rosenfeld, February 1984, Testimony for Hearings on DOE Conservation & Solar Energy Budget for FY'85 by the U.S. House of Representatives, Subcommittee on Energy Conservation & Power of the Committee on Energy & Commerce.

LBL *

"Saving Peak Power: At the Meter, Beyond the Meter, and At the Checkbook", A. H. Rosenfeld, August 1984, Plenary session talk presented at the 1984 ACEEE Summer Study on Energy-Efficient Buildings, Santa Cruz, CA.

LBL *

"Home Energy Ratings: A promising Approach to Energy Conservation", A.H. Rosenfeld and Linda Schuck, April 1984, published in the *Energy Conservation Bulletin*, a publication of the Energy Conservation Coalition, Vol. 3, No. 5.

LBL *

"Saving Peak Power: At the Meter, Beyond the Meter, and At the Checkbook", A. H. Rosenfeld, August 1984, plenary session talk presented at the 1984 ACEEE Summer Study on Energy-Efficient Buildings, Santa Cruz, CA.

1983

LBL-16121

"Summary of International Data on Monitored Low-Energy Houses: A Compilation and Economic Analysis", J. C. Ribot, A. H. Rosenfeld, F. Flouquet, and W. Luhrsén., 1983, presented at 1983 International Conference on Earth Sheltered Buildings, Sydney, Australia, August, 1983.

LBL-16064

"Technology for Energy-Efficient Buildings--Progress and Potentials--Many Suggestions and Some Opportunities for Collaboration", A. H. Rosenfeld, 1983, Presented at the France-California Colloquium sponsored by AFME, Sophia Antipolis, France, May 16, 1983.

LBL-15412R

"The Assessment of progress in Energy-Efficient Buildings", Leonard W. Wall and Arthur H. Rosenfeld, 1983, Presented at the Second International Congress on Building Energy Management, Ames, Iowa. May 30-June 3, 1983.

LBL-15374

"Progress in Energy Efficient Buildings", L. W. Wall and A. H. Rosenfeld, 1983, Presented at the Association of Energy Engineers, 5th Energy Audit Symposium and Productivity Exposition, Los Angeles, CA, February 17-18, 1983.

LBL-15183

"Energy Efficiency in Chinese Apartment Buildings, Parametric Runs with the DOE.2 Computer program", Yu J. Huang, Metin Lokmanhekim, Antonio Canha de Piedade, Arthur H. Rosenfeld, Dien Tseng, 1983, Presented at First U.S.-China Conference on Energy, Resources and Environment, Beijing, China, November 7-12, 1982 Published in Chinese in *The World Architecture*, 1983.

LBL-10738

"Supplying Energy Through Greater Efficiency: The potential for Energy Conservation in California's Residential Sector", A. Meier, J. Wright, and A. H. Rosenfeld, 1983, University of California press, 200 pages, December, 1983 (Supersedes LBL-10738).

LBL-08913

"Storage of Heat and Coolth in Hollow-Core Concrete Slabs: Swedish Experience and Application to Large, American-Style Buildings", L. O. Andersson, K. G. Bernander, E. Isfalt, A. H. Rosenfeld, June 1983, LBL.

1982

LBL-15182

"Technology for Energy-Efficient Buildings", Arthur H. Rosenfeld, 1982, Presented at the First U.S.-China Conference on Energy, Resources, and Environment, November, 1982.

LBL-14914

"Technical Issues for Building Energy Use Labels", B. S. Wagner and A. H. Rosenfeld, 1982, Published in *What Works: Documenting Energy Conservation in Buildings, the Proceedings from the Second ACEEE Summer Study on Energy Efficient Buildings*, (Editors: J. Harris, C. Blumstein), pp. 388-402. Santa Cruz, CA. August, 1982.

LBL-14838

"Validation of Building Energy Analysis Techniques: A Summary Report of Building Energy Compilation and Analysis-part V (BECA-V)", B. S. Wagner and A. H. Rosenfeld, 1982, Abstract Published in *What Works: Documenting Energy Conservation in Buildings, Proceedings from the Second ACEEE Summer Study on Energy-Efficient Buildings*, Editors: J. Harris, C. Blumstein, p. 535, Santa Cruz, CA, August, 1982.

LBL-14788

"Monitored Low-Energy Houses in North America and Europe: A Compilation and Economic Analysis", J. C. Ribot, A. H. Rosenfeld, P. Flouquet, W. Luhrsens, 1982, Published in *What Works: Documenting Energy Conservation in Buildings, Proceedings from the Second ACEEE Summer Study on Energy-Efficient Buildings* (Editors: J. Harris, C. Blumstein) pp. 242-256, Santa Cruz, CA, August, 1982.

LBL-14787

"A Summary Report of Building Energy Compilation and Analysis (BECA)--part B: Existing North American Residential Buildings", L. W. Wall, C. A. Goldman, and A. H. Rosenfeld, 1982, Published in *What Works: Documenting Energy Conservation in Buildings, the Proceedings from the Second ACEEE Summer Study on Energy Efficient Buildings* (Editors: J. Harris, C. Blumstein), pp. 81-94. Santa Cruz, CA. August, 1982.

LBL-14576

"Monitored Superinsulated and Solar Houses in North America: A Compilation and Economic Analysis", J. C. Ribot, J. G. Ingersoll, and A. H. Rosenfeld, 1982, Presented at PASSIVE '82, the National passive Solar Conference, Knoxville, TN, August 29-September 3, 1982.

LBL-14111

"Infiltration and Indoor Air Quality in a Sample of Passive Solar and Superinsulated Houses", B. S. Wagner and A. H. Rosenfeld, 1982, Presented at PASSIVE '82, the National Passive Solar Conference, Knoxville, TN, August 29-September 3, 1982.

LBL-13385

"Building Energy Compilation and Analysis (BECA) part B: Existing North American Residential Buildings", Leonard W. Wall, Charles A. Goldman, Arthur H. Rosenfeld, and Gautam S. Dutt, July 1982, Published in *Energy & Buildings*, 5 (1983), pp. 151-170.

LBL *

"(DRAFT, 3/19/82) A March 1982 Update of Our April 1981 Testimony: Accelerating the Building Sector's Sluggish Response to Rising Energy Prices (Testimony before the Interior Appropriations Committee, U.S. House of Representatives).", A. H. Rosenfeld and M. D. Levine, March 1982, LBL.

1982

"Building Energy Rating Systems: Panel Summary.", A. H. Rosenfeld and L. Schuck, 1982, Reproduced from *Proceedings of ACEEE 1982 Summer Study on Energy-Efficient Buildings*, Santa Cruz, CA, August 22-28,.

1981

LBL-13608

"Supply Curves of Conserved Energy for California's Residential Sector", Alan Meier, Arthur H. Rosenfeld, Jan Wright, December 1981, Published in *Energy*, Vol. 7, No. 4, pp. 347-358, 1982.

LBL-13385

"Building Energy Compilation and Analysis, Part B: North American Residential Retrofit", Leonard W. Wall, Charles A. Goldman, Arthur H. Rosenfeld, Gautam S. Dutt, 1981, Presented at ICEUM III, the International Conference on Energy Use Management, West Berlin, October 26, 1981.

LBL-12889

"Technical Opportunities for Energy Efficient Buildings, A Least-Cost Scenario, 1980-2000", A.H. Rosenfeld, D. Claridge, P. Cleary, J. Deringer, K. Gawell, D. Goldstein, J. Harris, H. Kelly, W. Metz, and J. Wright, September 1981, Published in *Proceedings of the 1981 International Gas Research Conference*, pages 1504-1512, sponsored by Gas Research Institute, American Gas Association, and U.S. Department of Energy, Los Angeles, CA.

LBL-12739

"Accelerating the Buildings Sector's Sluggish Response to Rising Energy Prices", A. H. Rosenfeld and M. D. Levine, April 1981, Testimony before the Interior Appropriations Committee, U.S. House of Representatives.

LBL-06840

"TWOZONE Users Manual (2nd edition, revised)", Ashok J. Gadgil, Gay Gibson, and Arthur H. Rosenfeld, October 1981, LBL.

LBL *

"Progress in Energy-Efficient Buildings - The Potential for Saving 8 Million Barrels a Day by 2000, at a Cost of \$10 Per Conserved Barrel", A. H. Rosenfeld, June 1981, abstract of talk to Atomic Industrial Forum.

LBL *

"Impact of FY'82 and FY'83 Budget Cuts on Conservation Programs at Lawrence Berkeley Laboratory", A. H. Rosenfeld, December 1981, Testimony before the Subcommittee on Conservation and Power, Committee on Energy and Commerce, U.S. House of Representatives.

LBL *

"A New Prosperity: Building A Sustainable Energy Future", A. H. Rosenfeld, 1981, *The SERI Solar/Conservation Study*, Buildings Section (pp. 11-175), Brick House Publishing.

LBL *

"Saving Oil & Money Through Energy Efficient Buildings", A. H. Rosenfeld, speaker, October 1981, Lawrence Hall of Science Symposium Celebrating the 50th Anniversary of LBL.

LBL *

"House Doctor Demonstration, Training, and Retrofit Monitoring Project, a cooperative project between LBL and PG&E", A. H. Rosenfeld, June 1981, LBL.

LBL *

"Energy Efficiency: The Impact of Conservation", Arthur H. Rosenfeld, February 1981, Academy Forum, National Academy of Sciences, Moderator: Harvey Brooks. National Academy Press, Washington, D.C.

LBL *

"Measurement and Control of Indoor Air Quality in Existing and New Homes", A. H. Rosenfeld and C. D. Hollowell, May 1981, Testimony before the Subcommittees on Energy Development and Applications and Natural Resources, Agriculture Research, and Environment of the Committee on Science and Technology, U.S. House of Representatives.

LBL

"Progress in Energy-Efficient Buildings - The Potential for Saving 8 Million Barrels a Day by 2000, at a Cost of \$10 Per Conserved Barrel", A. H. Rosenfeld, May 1981, Testimony before the Subcommittee on Energy Conservation and Power of the Committee on Energy and Commerce, U.S. House of Representatives.

1981

"Energy Demand", Arthur H. Rosenfeld and Alan K. Meier, 1981, chapter from *AIP 50th Anniversary-Physics Vade Mecum*.

* = no LBL number. Call (415) 486-4834 for information on obtaining this document.

1980

LBL-11300

"Technical Potentials and Policy Recommendations for Conservation and Renewable Resources: A Least Cost Scenario, 1980-2000", A. H. Rosenfeld, D. Goldstein, J. Harris, D. Claridoe, and K. Gawell, July 1980, LBL.

LBL-10738

"Supplying Energy Through Greater Efficiency: The Potential for Energy Conservation in California's Residential Sector", J. Wright, A. Meier, M. Maulhardt, H. Arin, A. H. Rosenfeld, March 1980, LBL.

LBL *

"Saving Half of California's Energy and Peak Power in Building and Appliances", A. H. Rosenfeld, D. B. Goldstein, A. J. Lichtenberg, and P. P. Craig, 1980, From *Energy Policy Modeling: United States and Canadian Experiences*, University of British Columbia Press.

LBL *

"Testimony on Energy Efficient Buildings before the U.S. House of Representatives Subcommittee on Energy Development and Applications Committee on Science and Technology", A. H. Rosenfeld, February 1980, LBL.

LBL *

"Shell Answer Book #22", Sheldon Lambert, assistance from A. H. Rosenfeld, 1980, Copies can be obtained from the Shell Oil Company (public distribution = 6.5 million copies).

LBL *

"Colloquium Transcripts: Caltech Series in Energy Realities", A. H. Rosenfeld, May 1980, LBL.

LBL *

"Testimony: On BEPS. Before the Subcommittee on Energy Regulation, Senate Committee on Energy and Natural Resources", A. H. Rosenfeld, June 1980, LBL.

POPULAR ARTICLES

Non-technical publications that either describe work at LBL or are authored by LBL researchers are listed below. These articles are designed to have a much wider appeal than the more usual LBL publications that report research results. Because the success of many developments in energy efficiency depend on people's attitudes and living habits, it is important that developments in this field reach a wide audience.

1. "How We Can Fight the Greenhouse Effect", H. Gilliam, *This World*, part of the Sunday Edition of the *San Francisco Chronicle* (July 31, 1988).
2. "The Greenhouse Challenge", *Oakland Tribune* (July, 14, 1988)
3. "Counting kilowatts", *Boston Globe* (July 2, 1988)
4. "Controlling Indoor Air Pollution", A. V. Nero, *Scientific American*, 258(5), 42-48 (May 1988).
5. "Power-Guzzling Homes Trouble Utilities: They are Joining the States in Battling the Builders", I. Peterson, *The New York Times*, Section 8, (Sunday, May 8, 1988).
6. "Energy Efficiency: Less means More - Fueling a Sustainable Future", J. Raloff, *Science News*, 133, 296-298 (May 7, 1988).
7. "High Tech Window Coatings "Supply" Energy Services", A. H. Rosenfeld, *Conservation Research Note #1*, 1-6, May 1988 (available from the Center for Building Science, Lawrence Berkeley Laboratory, Berkeley, CA 94720).
8. "Energy Efficient Buildings", A. H. Rosenfeld and D. Hafemeister, *Scientific American*, 258(4) 78-85 (April 1988).
9. "Building on Success: The Age of Energy Efficiency", C. Flavin and A. B. Durning, *Worldwatch Paper 82*, 1-63 (March 1988).
10. "Lighting the Way", S. Berman with L. Yarris, *LBL Research Review*, 13(1) 2-9 (Spring 1988)
11. "The Role of Federal Research and Development in Advancing Energy Efficiency: A \$50 Billion Contribution to the US Economy", H. Geller, J. P. Harris, M. D. Levine, and A. H. Rosenfeld, *Ann. Rev. Energy*, 12, 357-95 (1987).
12. "The Rise and Fall and Rise of Energy Conservation", M. Reisner, *The Amicus Journal*, 22-31 (Spring 1987).

INDOOR ENVIRONMENT PROGRAM

INTRODUCTION

The Indoor Environment Program examines the scientific issues associated with the design and operation of buildings to optimize building energy performance and occupant comfort and health. Optimizing occupant health and comfort is addressed in various ways by groups within the Program. To examine energy flow through all elements of the building shell, the Energy Performance of Buildings Group measures air infiltration rates, studies thermal characteristics of structural elements, and develops simplified models of the behavior of complete buildings. Potential savings in the infiltration area are great. The heat load associated with natural infiltration is about 2.5 quads/yr costing about \$15 billion annually. It may be economic to reduce this by 25%.

This change, however, may produce undesirable effects in the building environment. Since ventilation is the dominant removal mechanism for building pollutants, concern continues about the impact of designs or changes in operation that lead to its reduction.

This issue has been an important theme for other projects in the Program. Efforts include characterizing the emission of various pollutant classes from their respective sources, studying the effectiveness of ventilation in removing pollutants from indoor atmospheres, and examining the nature and importance of chemical and physical reactions that can affect the production of airborne pollutants. Projects have concentrated on three major pollutant classes: combustion products arising from indoor heaters and other combustion appliances; radon and its progeny, arising from materials (primarily soil) that contain radium, a naturally occurring radionuclide; and formaldehyde and other organics, arising from a variety of building materials and furnishings. In addition, the Ventilation and Indoor Air Quality Control and Energy

Performance of Buildings projects investigate techniques for controlling airborne pollutant concentrations, develop devices for monitoring pollutants in laboratories and buildings, and design or carry out field surveys of energy use and indoor air quality in residential and commercial buildings. The Indoor Exposure Assessment project also devotes time to assessing the health effects of indoor pollutant exposures. We continue to explore several important themes:

- A. **Air quality in buildings is dominated by sources.** Problems are more often related to strong indoor sources than to deficiencies in ventilation.
- B. **Air pollution is a buildings problem.** Pollutants concentrations observed in buildings are comparable to those outdoors (when major indoor sources are present, the concentrations indoor are substantially higher). Since people spend 70-90% of their time inside buildings, the major portion of their exposure to air pollutants occurs within buildings. We conclude that air pollution is a buildings problem because sources and removal processes are often associated with building structure and operation.
- C. **Ventilation is the best control strategy for indoor pollution.** Ventilation using outdoor air affects all indoor pollutants similarly and is therefore, the best single strategy for pollutant control in buildings. This assertion acknowledges that we cannot identify all pollutant sources in a building. Since such information is often lacking, ventilation remains the best general indoor pollution control strategy.

Evaluation of Several Techniques to Reduce Radon: Preliminary Results from Fourteen Houses *

B.H. Turk, J. Harrison, R.G. Sextro, L.M. Hubbard†, K.J. Gadsby‡, T.G. Matthews‡, C.S. Dudney‡, D.C. Sanchez§

Fourteen homes with basements and hollow block foundation walls in north-central New Jersey, were selected for this research project. Seven homes were studied by Lawrence Berkeley Laboratory, while the other seven were studied by Oak Ridge National Laboratory and Princeton University. One home from each group of seven did not have a radon control system installed, and served as a control.

Beginning in the fall of 1986, radon concentrations and other parameters in the homes were intensively monitored with continuous, real-time instrumentation. Monitoring continued for 7 to 13 months. We developed diagnostic procedures to guide choice of the appropriate radon reduction technique in each house. Oak Ridge National Laboratory and Princeton also used a modification of these diagnostic procedures. Radon control systems were designed to: (1) effectively and economically reduce indoor radon concentrations below 148 Bq m^{-3} (4 pCi l^{-1}), and (2) allow comparison of a variety of mitigation systems. These were installed beginning in November, 1986. System-types included: subsurface ventilation (SSV) by depressurization (SSD), and SSV by pressurization (SSP) in 11 homes, ventilation of perimeter drain tiles/drain ducts (eight homes), air-to-air heat exchangers (AAHX) in two homes, basement pressurization (three homes), block wall ventilation (three homes), and caulking and sealing openings to the soil (all homes).

Subsurface ventilation by depressurization was very often recommended and successful. SSP was less effective than SSD in all homes where it was evaluated. This contrasts with results from earlier studies in the Spokane, WA area. Drawing air from the cores of block walls and SSV via a connection to perimeter drain (perimeter of basement slab floor) were generally effective due to the efficient ventilation and depressurization of major subslab regions

from which radon normally entered the house. Pressurization of basements with air drawn from upstairs caused satisfactory reductions in indoor radon levels in only one house where the basement could be sufficiently tightened to permit adequate pressurization. The AAHX's reduced radon concentrations to an extent consistent with the theory that concentrations are proportional to the reciprocal of the total ventilation rate when ventilation is not associated with a change in indoor air pressures. This supports previous work indicating that AAHX's are generally adequate only in homes with low initial indoor radon levels and ventilation rates. Finally, caulking and sealing often resulted in a measurable reduction in baseline indoor levels, but never achieved the target concentration.

Intensive Radon Mitigation Research: Lessons Learned*

B.H. Turk, R.J. Prill, R.G. Sextro, and J. Harrison†

Two intensive field studies of radon control have provided an opportunity to conduct follow-on research, and to compare and combine data and results from regions with different soils and types of house construction. The first study near Spokane, Washington involved 14 homes often having foundation walls of poured concrete placed in soils of uniformly high permeability and low to moderate soil gas radon concentrations. The second study was conducted in north-central New Jersey on seven homes that had foundation walls constructed of hollow core blocks. The soils around the New Jersey homes were variable in both permeability and radon concentrations in soil gas.

For control homes (homes that did not receive radon control systems until conclusion of the projects) in both studies, indoor radon levels remained higher than expected in the spring and summer. During these seasons, the warmer outdoor air temperatures are expected to diminish the thermally-caused negative pressure differences that drive the bulk flow of radon-containing soil gas into the houses. It was discovered that soil temperatures substantially modify the pressure differentials (ΔP s) that drive soil gas entry into basements in both summer and

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division, by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division and Pollutant Characterization and Safety Research Division of the U.S. Department of Energy (DOE) under contract no. DE-AC03-76SF00098, and by the U.S. Environmental Protection Agency (EPA) through Interagency Agreement DW89931876-01-0 with DOE. The work by ORNL/Princeton was co-sponsored by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments and Pollutant Characterization and Safety Research Division of DOE under contract no. DE-AC03-84OR21400, by the EPA through IAG-40-1709-85 with DOE, and by the New Jersey Department of Environmental Protection.

†Princeton University

‡Oak Ridge National Laboratory

§U.S. Environmental Protection Agency

*This work was supported by the Bonneville Power Administration (BPA) under contract no. DE-A179-83BP12921, by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division, by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division and Pollutant Characterization and Safety Research Division of the U.S. Department of Energy (DOE) under contract no. DE-AC03-76SF00098, and by the U.S. Environmental Protection Agency (EPA) through Interagency Agreement DW89931876-01-1 with DOE.

†U.S. Environmental Protection Agency

winter. Calculations for a one-story house in New Jersey show that warmer soil in winter and cooler soil in summer (relative to the prevailing outdoor temperatures), reduces the magnitude of the basement pressure difference by about 1 Pa. At times during the summer, the cooler soil gas temperatures can cause the ΔP s to be negative, drawing radon into the building.

Another finding is that the forced-air distribution of many residential heating and cooling systems can increase the natural depressurization of the substructure by up to 10 Pa (but generally less) and also transfer large amounts of radon from the substructure to the upper floors. These effects are more pronounced if leaky return air ducts or plenums are located in the substructure.

For the majority of homes in these two studies, sub-surface ventilation (SSV) was the most appropriate and effective radon control technique. The data and measurement results indicate that 40% to 90% of the air in SSV exhaust airstreams originates in basements. This suggests that the leakiness of the below-grade substructure surfaces greatly influences the flow resistance to an SSV system.

Air-to-air heat exchangers (AAHX) were generally practical for radon control only in those houses or zones of houses that have low to moderate initial radon levels and ventilation rates. Finally, the success of another mitigation system based on pressurizing the basement depends on achieving a pressure in the basement that is at least 2 to 3 Pa greater than the average wintertime natural depressurization of the basement. Only basements that can easily be maintained air tight therefore are suitable for this system.

Monitoring and Evaluation of Radon Mitigation Systems Over a Two-Year Period*

R.J. Prill

In previous research studies, elevated concentrations of radon were found in a significant percentage of the houses located in Eastern Washington and Northern Idaho. A subsequent study, completed in 1986, developed and evaluated radon mitigation techniques and systems in fourteen houses in the area of the Spokane River Valley. This research reports on the performance of these radon mitigation systems for a period of two years.

*This work was supported by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division and Pollutant Characterization and Safety Research Division, and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division of the U.S. Department of Energy (DOE) under Contract No. DE-AC03-76SF00098.

Seasonal and annual radon concentrations in all zones and on each level of these houses were measured using mailed alpha-track detectors during the two-year follow-up period. Each house was inspected and the radon mitigation system evaluated during the second heating season of the follow-up study. Some of the systems were modified to eliminate problems which had developed over time.

The alpha-track measurements generally showed an increase in radon levels in a majority of the houses compared to the levels measured immediately after the installation mitigation systems. The greatest increases in radon concentrations occurred in 3 of the 4 houses equipped with basement pressurization systems. In most of the houses equipped with sub surface ventilation systems the radon concentrations also increased over the course of the follow-up period. Radon concentrations in the two houses equipped with air-to-air heat exchangers appeared to depend upon the duration of operation and fan speed settings of the heat exchangers. Factors causing decreased performance of the mitigation system included: (1) a build up of dust and lint on the soil, beneath the slab, at the pipe outlet of subsurface ventilation systems operated in the pressurization mode; (2) noisy and vibrating fans which were turned off by occupants; (3) air-to-air heat exchanger, basement pressurization, and subsurface ventilation system fans which were sometimes turned off or fan speeds reduced by occupants even when there was not a noise problem; and (4) crawl space vents which were closed or sealed.

Appraisal of the U.S. Data on Indoor Radon Concentrations*

A. V. Nero, K. L. Revzan, and R. G. Sextro

Recent surveys of indoor radon concentrations have suggested that the risk to the U.S. population is much greater than was indicated by earlier surveys. We examine the bases of the discrepancy and show that the interpretations of the recent surveys are in error.

PRE-1984 STUDIES

Results from a number of small surveys were used in 1984 as the basis for developing a U.S. concentration distribution. This analysis discriminated between those surveys undertaken because high indoor concentrations were known or suspected and those that were designed on a

*This work was supported by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division and Pollutant Characterization and Safety Division, and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building Energy Research and Development, Building Systems Division, of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

random basis. Furthermore, data taken in the winter were normalized to an approximate annual-average concentration, and the different data sets were weighted by number of houses, region, and population in order to examine the sensitivity of the resulting distribution to these factors. The resulting aggregate distribution, found to be insensitive to weighting, has an average or arithmetic mean (AM) of 55 Bq m^{-3} . Approximately 2% of homes were found to exceed annual-average concentrations of 300 Bq m^{-3} . The distribution was represented well by a lognormal function with a geometric mean (GM) of 33 Bq m^{-3} and a geometric standard deviation (GSD) of 2.8. The annual-average concentration was, on the average, 72% of that measured in the winter. The inclusion of data from areas where concentrations were expected to be higher on the basis of prior information raised the average concentration substantially, as had been expected. A second important survey entailed year-long radon monitoring in 1984-1985 in the homes of 453 physics faculty at 101 universities throughout the United States. The results correspond well to a lognormal distribution with a GM of 38 Bq m^{-3} and a GSD of 2.36. Both surveys utilized data accumulated in living spaces rather than basements, which is a major distinction from the more recent data sets. The fraction of houses with concentrations above 150 Bq m^{-3} are estimated from the earlier survey at 7%, and from the latter survey at 6%. Because of the difference in GSDs, perhaps due to reliance on a particular subpopulation in the latter survey, the functions diverge at higher concentrations; still, the fractions above 300 Bq m^{-3} are only a factor of two apart.

RECENT STUDIES

In one study, Alter and Oswald find that approximately 60,000 U.S. etched-track measurements are found to average 266 Bq m^{-3} . However, 50,000 of the data are from only 6 states, including some known to have high concentrations. Removing the data from these states yields an average, for the 10,251 remaining data, of 158 Bq m^{-3} . Two alternative methods of obtaining a more representative selection yield averages of 152 and 153 Bq m^{-3} . The authors find this convergence striking, assert that the results provide a rough "exposure" estimate, and conclude that the national "exposure" exceeds the 55 Bq m^{-3} cited previously. In fact, even the three restricted sets of data are likely to overrepresent homes with high concentrations. Further, the parameter of interest for indoor exposures is the annual-average concentration in the living space.

A major difficulty is that a large portion of the measurements are performed in basements. Concentrations in basements average approximately twice those on first floors during the winter, with an even larger ratio during the summer. In fact, for a subset of measurements for which location was recorded, the 44% taken in basements have an average concentration 2.0 times the average from the non-basement readings. If we attempt to correct an apparent average of 155 Bq m^{-3} to a living-space average assuming that 44% have results that are a factor of 2 high,

we find a corrected average of 108 Bq m^{-3} . It is even more difficult to quantify the effect of oversampling in areas or houses where high concentrations are known or suspected. We note that a 25% reduction of the AM yields 81 Bq m^{-3} ; there are indications from the etched-track data themselves and from comparison with the EPA data discussed below that the effect of oversampling is at least this large. Finally, a preponderance of measurements are performed during winter only. As indicated above, annual-average concentrations have been found to average approximately 72% of winter values. Given probable mixes of seasons in which the etched-track measurements were taken, the annual-average concentration may therefore be 80 or 90% of the value above, i.e., approximately 69 Bq m^{-3} . These considerations are enough to indicate that an average less than 75 Bq m^{-3} , reasonably consistent with the earlier surveys, is probable.

Alter and Oswald also find that 23% of the 10,251 data exceed the EPA remedial level of 148 Bq m^{-3} . However, a lognormal function with a GM of 61 Bq m^{-3} and a GSD of 3.2 is found to fit the data below 148 Bq m^{-3} very well, with a considerable excess of data above this point, particularly of very high values. The considerations discussed in the previous paragraph account for this excess.

A second data set has arisen from recent efforts of the EPA in conjunction with 10 states. During the winter of 1986-1987, charcoal detectors were deployed in statistically chosen samples of homes in nine states, plus another state in which volunteers were relied on. Examining the EPA press material, one finds the following information: the number of homes monitored in the main sample varied from 190 to 1787 for the ten states, totaling approximately 10,000. The AM for the main sample was 110 Bq m^{-3} ; 20% of measurements exceeded 148 Bq m^{-3} and approximately 1.1% exceeded 740 Bq m^{-3} . Measurements were performed following the EPA screening protocol so that, as indicated in some of the EPA backup material, these results - taken in winter and, often, in basements - do not represent annual-average concentrations to which people are exposed. Nonetheless, the press reports, following the EPA press release, compared these results directly with the EPA action guideline and indicated that 21% of the homes exceeded the guideline, an inappropriate use of the data.

If the correction from basement concentrations described above is made to the AM of 110 Bq m^{-3} , and the resulting 76 Bq m^{-3} is corrected to an annual-average using the factor of 0.72, an AM of 55 Bq m^{-3} is found. The precise agreement with previous results is fortuitous, but indicates that - if proper adjustments could be made - agreement would be quite satisfactory. Furthermore, these adjustments would drastically reduce the fractions above 148 and 740 Bq m^{-3} , apparently to the vicinity of the early results, which were that 6 or 7% of homes exceed 148 Bq m^{-3} and perhaps 0.1% exceed 740 Bq m^{-3} .

Any two probabilities may be used to define a lognormal distribution. The particular distribution which passes through the given probabilities for 148 and 740 Bq m^{-3} has a GM of 58 Bq m^{-3} and a GSD of 3.0, which implies an

AM of 106 Bq m^{-3} , which is close enough to the actual AM to suggest that the lognormal may be a useful representation of the data. If so, then lognormality is maintained at least to the region of 740 Bq m^{-3} , which contrasts with the data of the Alter-Oswald study. Both the GM and the GSD of the distribution are higher than those of the early surveys, of course, but we have shown that they have been overestimated. Extrapolation of the lognormal indicates that 0.01% of the homes, i.e., 1 home, should exceed 3700 Bq m^{-3} . The actual number is 3, so that we expect that fewer than 3 in 10,000 homes exceed this level, which is a much smaller fraction than has been suggested.

CONCLUSIONS

Monitoring efforts undertaken before 1985 indicate that the radon concentration in U.S. houses averages approximately 55 Bq m^{-3} and that, in approximately 6%, annual-average levels exceed 150 Bq m^{-3} , with perhaps 1-2% having 300 Bq m^{-3} or more. However, several recent large-scale data sets yield average concentrations of $100\text{--}150 \text{ Bq m}^{-3}$, with perhaps 20% of results exceeding 150 Bq m^{-3} , leading to an exaggerated estimate of risk. In fact, these recent data sets overrepresent high-concentration houses or include sampling performed in basements or in the winter only. Adequate information is not available to adjust these results precisely to annual-average indoor concentrations experienced by the population, but plausible corrections yield results that are consistent with the distributions previously found.

Parametric Modelling of Temporal Variations in Radon Concentrations in Homes*

K.L. Revzan, B.H. Turk, J. Harrison, A.V. Nero, R.G. Sextro

The radon concentrations in the living area, the basement, and underlying soil of a New Jersey home have been measured at half-hour intervals over the course of a year, as have indoor and outdoor temperatures, wind speed and direction, and indoor-outdoor and basement-subslab pressures; in addition, periods of furnace operation have been logged. We generalize and extend an existing

radon entry model in order to demonstrate the dependence of the radon concentrations on the environmental variables and the extent of furnace use. The model contains parameters which are dependent on geological and structural factors which have not been measured or otherwise determined; statistical methods are used to find the best values of the parameters. The non-linear regression of the model predictions (over time) on the measured living area radon concentrations yields an R^2 of 0.88.

Theory

We assume that a house is divided into two zones, the basement and living area, of which only the former is in contact with the soil; the house is assumed to be depressurized as a result of temperature differences between inside and outside and the flow of wind around the structure. On the basis of a highly simplified model, we represent the soil gas radon concentration, C_s , as

$$C_s = p_1 (1 - \exp[-p_2/\Delta p_s]), \quad (1)$$

where the p_n are parameters which depend on the properties of the soil and on the nature of the openings between basement and soil and Δp_s is the pressure across the soil.

From the mass-balance, assuming the outdoor radon concentration to be negligible, the steady-state radon concentration in the basement is

$$C_b = (f_{sb}C_s + f_{lb}C_l) / (f_{bo} + f_{bl}), \quad (2)$$

where C_b , C_l , and C_s are the radon concentrations in the basement, living area, and soil, respectively, and f_{sb} , f_{lb} , f_{bo} , and f_{bl} are the flows from soil to basement, living area to basement, basement to outside, and basement to living area, respectively, and where the outside concentration and diffusive entry have been neglected. Similarly, the steady-state living area concentration is

$$C_l = f_{bl} C_b / (f_{lo} + f_{lb}), \quad (3)$$

where f_{lo} is the living area to outside flow.

We now assume that the flow from living area to basement, f_{lb} , is entirely due to furnace operation, that the flow from basement to living area is the sum of f_{lb} and a term directly proportional to the flow from the living area to the outside, and that the basement to outside flow is a constant multiple of the living area to outside flow, so that

$$C_b = \frac{f_{sb} C_s (1 + p_3 A_f)}{(p_4 + p_5 A_f) f_{lo}}, \quad (4)$$

and

$$C_l = (p_6 + p_7 A_f) C_b / (1 + p_7 A_f) \quad (5)$$

where A_f is the fraction of the time the furnace is in operation. When the furnace is not in operation, C_b is the quotient of a source term and the outside to basement flow; when the furnace is in operation, assuming the fur-

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division and by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division and Pollutant Characterization and Safety Research Division of the U.S. Department of Energy (DOE) under Contract No. DE-AC03-76SF00098. It was also supported by the Office of Environmental Engineering Technology Demonstration, Office of Research and Development of the U.S. Environmental Protection Administration (EPA) through interagency agreement DW89931876-01-0 with DOE.

nance flow to dominate other flows between the two interior zones, the denominator becomes the total flow into the house. With the furnace off, the house can be represented by the two-zone model; with the furnace on, the air of the two zones is mixed and the house is effectively a single zone.

If we now represent the flows appearing in equations 4 and 5 by

$$f_{sb} = p_8 \Delta T + p_9 u^2; f_{lo} = (p_{10} \Delta T + p_{11} u^2)^{0.5}, \quad (6)$$

where ΔT is an appropriate temperature difference and u is the wind speed, and if we further assume that Δp_s is proportional to f_{sb} , then we have a model in which the only independent variables are the temperature difference, the wind speed, and the fractional furnace operation. There are 3 parameters in the equations determining C_s (1 and 6), 6 in those determining C_b (1, 4, and 6, with terms collected), and 2 in that determining C_i (5).

Results

We shall apply the model to a two-story dwelling with a basement located in north central New Jersey, which was selected as the control for a year-long study of the effectiveness of remedial action in six other houses in the same general area. The basement is almost entirely below grade; it contains a forced-air furnace whose ductwork has been observed to be leaky. Radon concentrations were measured in the soil below the basement slab, in the basement itself, and on the first floor using continuous radon monitors. Environmental measurements included indoor, outdoor, and soil temperatures, wind speed and direction, barometric pressure, and precipitation. Differential pressures were measured between the top and bottom of the basement slab, between the first floor and the basement, and across the four walls separating the basement from the outside air. Furnace operation was measured on a binary (on/off) basis. Data was collected for 10 months, beginning on 18 September 1986; all data was logged automatically at half-hour intervals. The comparison between theory and experiment is, however, based on three-day averages of the data.

A linear regression shows that Δp_s is directly dependent on ΔT , u , and possibly on A_f , but it is impossible to determine statistically which of the variables must be included in the equation. The best results occur when we use the basement temperature, the soil temperature at 70 cm depth, and the furnace activity; the R^2 is 0.82. If the same variables are used to predict C_s , we find an R^2 of 0.62. The model accounts for the general tendency of the data, but is insufficient to account for the day-to-day fluctuations. There may be inhomogeneities in the soil gas concentration in the vicinity of a house, in which case a spot measurement could be unrepresentative of the average and the model would not be expected to predict well.

The basement concentration data can be divided into three distinct periods: two periods of warm weather during which relatively large fluctuations in concentration

occurred and the winter period, running from December 4 through March 12, during which the fluctuations were relatively small. The difference in character between the warm and cold weather periods may be due to freezing of the soil. When we model the basement concentration using equations 4, 6, and 7 with C_s equal to its measured value, the fit is quite poor, suggesting that the soil gas measurement is not representative. When we use equation 1 to represent the soil gas, the fit to the data for the full year is poor, but some success is found in fitting distinct equations to the data for the warm and cold weather periods taken separately. The best fit to the warm weather data is obtained when the basement-outside temperature difference and the wind speed are used in both the source and removal terms; the R^2 is 0.63. The best fit to the cold weather data is obtained when the basement-soil temperature difference and the furnace activity are used in the source term; the R^2 is 0.70. The comparison of theory and data for the basement reveals the inadequacy of the theory; one major flaw may be the inability of the theory to represent the flow across the building shell (the air exchange) correctly.

When the measured values of C_b are used in equation 5, we find p_1 and p_2 to be 0.24 and 5.1, respectively, with an R^2 of 0.93; we regard this result as confirming the theory leading to that equation. When the calculated values of C_b are used, we find an R^2 of 0.88, which is satisfactory, but we note that the prediction of the basement concentrations is not good, and the result may be fortuitous.

Technique for Measuring the Indoor ^{222}Rn Source Potential of Soil *

W.W. Nazaroff and R.G. Sextro

Elevated indoor radon concentrations are often caused by high rates of entry of radon generated in soil within a few meters of a building's substructure. The potential of soil for generating high indoor radon concentrations depends on two factors: (1) the rate of release of radon from soil grains into the pore space of the soil, and (2) the volume of soil that can contribute its emanated radon to indoor air. The aim of this work is to develop techniques for measuring these factors and a method for combining

*This work was supported by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division and Pollutant Characterization and Safety Research Division, and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division of the U.S. Department of Energy (DOE) under Contract No. DE-AC03-76SF00098. It was also supported by the Office of Radiation Programs, of the U.S. Environmental Protection Agency (EPA) through Interagency Agreement DW89932609-01-0 with DOE.

the results into a single indicator of the indoor radon source potential of soil.

The experimental method entails installing a sampling probe into the soil. A pump is used to extract air from the soil through the probe, and a sample of this air is analyzed to determine its radon content. From this measurement, the rate of release of radon into the soil pores can be determined. The difference in air pressure established by the pump is measured between the tip of the probe and the atmosphere, and the rate of air flow through the probe is also measured. From these parameters, and the dimensions of the probe, the permeability of the soil is computed. This characteristic indicates how much soil may contribute radon to the interior of a building.

A theoretical analysis of radon transport in soil is developed as a basis for interpreting the experimental data and for combining the results into a single indicator of radon source potential. In the analysis, it is first argued that, for homogeneous soil, molecular diffusion may be neglected compared with bulk flow as a radon transport mechanism in cases in which the source potential is high. Then, equations for the pressure field and the radon flux are formulated and solved numerically for two idealized soil cavities with reduced air pressure (1) an isolated sphere, and (2) a long cylinder with a horizontal axis. The first case represents the soil sampling probe, and the latter case is a model for a house in which there is a leakage path from the soil around the basement perimeter, such as a floor-wall gap or crack.

In a preliminary field test, the measured indoor radon source potential in soils adjacent to four New Jersey houses was found to correlate well with the measured average indoor radon concentrations.

Successful preliminary tests suggest that this may be a useful basis for setting priorities in efforts to identify individual houses with high concentrations. The method could also be used to determine whether construction practices in an area need to be modified to prevent elevated radon concentrations in future housing. Further survey work must be conducted comparing measured indoor radon concentrations with the indoor radon source potential of nearby soil. Ultimately, the demonstration of a strong empirical correlation between the higher observed indoor concentrations and the source potential is both sufficient and necessary to justify the use of this method for appraising the risk of high indoor radon concentrations from soil.

Mapping Surficial Radium Content as a Partial Indicator of Radon Concentrations in U.S. Houses

K.L. Revzan, A.V. Nero, R.G. Sextro

In connection with the problem of indoor radon, we discuss the use of data from the National Aerial Radiometric Reconnaissance to develop maps of radium in soil, at various resolutions, for the contiguous 48 states. We examine the relationship between the results of measurements of radon in houses and the indications of the U.S. map, noting that some, but by no means all, of the areas known to have elevated radon concentrations appear as areas of higher radium concentration than their surroundings and that there are other areas, in which measurements of high radon levels have not been made, which are suggested as deserving of interest. We discuss mapping techniques for smaller areas and possible methods of dealing with apparent discrepancies between adjacent areas.

Results of Mapping

An important factor determining radon concentrations in houses is the radon concentration in the pore spaces of the underlying soil. For that reason, a useful first step in the identification of areas of elevated radon is the development of a map of soil gas concentration or, what is equivalent, a map of radium concentration in soil, for the U.S. Though such a map cannot *exclude* any area of the country from the possibility of having houses with high radon levels (since, for example, high permeability soil may allow transport of sufficient soil gas of low radon concentration to produce a high indoor concentration), it can suggest certain areas which are likely to have large numbers of those houses.

The necessary data for a radium map was obtained by the National Aerial Radiometric Reconnaissance (NARR), which measured the gamma radiation from the top 0.5 m of soil or rock in order to discover uranium deposits. From the data of this survey, obtained and processed by a number of subcontractors, a database of manageable size was developed, in which we have stored the average radium concentration for each 1.6 km along the survey flightlines. A map of the contiguous 48 states was then

*This work was supported by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division and Pollutant Characterization and Safety Division, and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division of the U.S. Department of Energy (DOE) under Contract No. DE-AC03-76SF00098. It was also supported by the Office of Radiation Programs of the U.S. Environmental Protection Agency (EPA) through Interagency Agreement DW89932609-01-0 with DOE. This report has not been subjected to EPA review. Its contents do not necessarily reflect the views of EPA, nor does mention of firms, trade names, or commercial products constitute endorsement or recommendation for use.

created, on which a dot has been placed in each 20×20 km area, the size of the dot representing the average radium concentration in that area.

The map reveals that certain areas appear sufficiently different in character from their surroundings to lead to suspicion that there might be problems involved in attempting to compare data obtained by different subcontractors despite their use of the same calibration procedures. The problem is perhaps most clearly exhibited in the Rawlins and Greeley quadrangles of Wyoming and Colorado. The means of Ra for the two quadrangles are 6.3 and 8.1 Bq kg⁻¹, while the mean Ra of the six surrounding quadrangles is 33.3 Bq kg⁻¹. Other possible calibration anomalies appear in southwestern South Dakota, eastern Washington and western Idaho, and San Jose, California. The average radium concentration of the territories surveyed by individual subcontractors ranges from 20 to 32 Bq kg⁻¹, but the variation may be explained, at least in part, by the different areas of the country flown by each; the question of the importance of subcontractor performance remains open.

The following areas, which the map reveals as having high radium concentrations compared to their surroundings, have also been found to have high radon concentrations in homes: eastern Pennsylvania-northern New Jersey (Reading Prong), eastern Tennessee-western North Carolina, western Washington-eastern Idaho (Spokane-Cour d'Alene), and western Florida (phosphate-bearing land). Apart from Florida, where the situation is well understood, and Tennessee, the mean levels of radium in these areas, while higher than their surroundings, are not high in absolute terms, and the nature of the relationship between the means of radium in soil and radon in houses remains to be established.

One region is known to have high radon concentrations but does not appear to have high radium levels: the Red River valley of North Dakota. While the map shows the valley to be somewhat higher in radium than the territory to the east and west, the level is the same as that of the territory to the south, so that it is difficult to infer that this might be a region of interest. There are a number of areas which, conversely, have high radium concentrations but in which high radon levels have not been found: central California, southern Arizona-New Mexico, a number of regions in the Rocky Mountain states, central New Hampshire-southern Maine, and, most conspicuously, southwestern South Dakota. Some of these are known to be areas in which uranium deposits occur; some, as we have suggested, may stand out because of calibration problems; some may be worthy of investigation.

The Statistics of Radium in Soil

On the basis of the 22,172 average radium concentrations used for the U.S. map, the geometric mean (GM) is 25 Bq kg⁻¹, the geometric standard deviation (GSD) is 1.6,

the arithmetic mean (AM) is 27 Bq kg⁻¹, and the arithmetic standard deviation (ASD) is 12 Bq kg⁻¹. These parameters are useful for making comparisons among regions, but they are misleading in that each datum is treated as if it were itself an observation rather than as an average of original observations. Since we have retained the number of observations, the AM, and the ASD for each 1.6 km flightline datum, it is a simple matter to calculate an ASD for each 20×20 km region and then, to calculate an ASD for the contiguous U.S. On the basis of the original 24,591,855 measurements, this ASD is 21 Bq kg⁻¹. Calculation of the GM and GSD on the same basis involves approximations, since we have not retained the GM and GSD of the observations in our database. If we assume the data to be lognormally distributed, however, we may use the AM and ASD to calculate a GM and GSD: 21 Bq kg⁻¹ and 2.0, respectively.

If we now consider that each original observation itself represents an integration of several hundred square feet and that large areas of the country remain unobserved due to the relatively large distances between flightlines, it is apparent that the actual GM of observations of radium in soil made at ground level, each representing an area the size of a house, is likely to be somewhat greater than 2.0. The GM of measurements of radon concentration in houses in the U.S. is approximately 2.8. Suppose that the indoor radon concentration is the product of the soil gas radon concentration, represented by the radium concentration, and some other lognormally distributed factor or combination of factors. Given the fact that the logarithms of GSDs add in quadrature, two factors contributing equally to the variation in radon would each have a GSD of 2.1, which is very close to the calculated GSD for radium. On this basis, the observed variation in radium in soil accounts for roughly half the observed variation in indoor radon.

It is clear, however, that we must look to factors other than radium in soil to explain the radon concentration data. In part of Eastern Pennsylvania, for example, we find a GM indoor radon concentration of 120 Bq m⁻³ (with a GSD of 3.4), which is a factor of 3.6 higher than the national GM. The GM radium for this area is generally 20-40 Bq kg⁻¹, with a high of 56 Bq kg⁻¹; the GSD is generally 1.5-2.5. If the relationship between radium and the other factors affecting radon in houses were to be the same in Eastern Pennsylvania as in the contiguous 48 states as a whole, the GM radium should be on the order of 75 Bq kg⁻¹ and the GSD should be 2.4.

Conclusions

We have shown that, on a national basis, as much as half the variation in radon from region to region may be accounted for by the level of radium in the soil, but that there are regions for which the radium concentration does not account for the relatively high observed radon.

Indoor Atmospheric Chemistry: Interactions of Radon with other Gaseous Pollutants *

J.M. Daisey, R. Sextro, A.T. Hodgson, N. Brown, and D. Lucas

Research was initiated on the radiolytic interactions of radon and radon progeny with other gaseous indoor pollutants. The objectives are to chemically characterize the gaseous and particulate products generated by the radioactive decay of radon and its progeny, to determine formation rates and size distributions of the aerosols and resultant equilibrium factors and to elucidate reaction mechanisms.

Three environmental chamber experiments were conducted for the purpose of determining appropriate experimental parameters. These experiments were conducted in collaboration with P.K. Hopke and M. Ramamurthi, University of Illinois.

The chamber was spiked with a mixture of volatile organic compounds (VOC) and radon. VOC and radon decay rates, over and above chamber background (determined in a separate chamber experiment), were monitored for 42 hours. The activity size distribution of the ultrafine aerosol was measured with a multi-screen sampler. Four VOC were used: n-hexane, toluene, 2,3-dimethyl-2-butene, and limonene. The 2,3-dimethyl-2-butene had a net decay rate of 0.007 h^{-1} . The limonene decayed at a net rate of 0.004 h^{-1} . The decay rates for the other two compounds were not significantly different from those measured in the absence of radon. In this experiment, there was no evidence of formation of ultrafine aerosol; however, it was determined that n-butanol from the condensation nucleus counter had back diffused into the chamber. This compound is a free radical inhibitor and contamination of the chamber with the n-butanol probably accounts for the lack of particle formation in contrast to the first experiment.

A molecular beam mass spectrometer is being modified and evaluated to allow for the detection and quantification of ions produced by the radioactive decay of radon and its progeny in indoor air. The apparatus had previously been used to measure neutral species in transient combustion events, using electron-impact ionization and analog signal detection and averaging methods. Many significant changes are needed in the beam system to permit the detection of the low concentrations of ions that are expected in these experiments.

Initial Efficiencies of Air Cleaners for the Removal of Nitrogen Dioxide and Volatile Organic Compounds *

J.M. Daisey and A.T. Hodgson

The objective of this research was to investigate the effective cleaning rates (ECRs) of selected portable air cleaners for removing NO_2 and volatile organic compounds from air when first exposed to concentrations typical of those found indoors. The ECR represents the air volume per unit time from which a contaminant has been removed and is useful in evaluating the cleaning effect in rooms of different sizes. We used NO_2 and VOC because they have documented adverse health effects and are commonly found at elevated concentrations in residences:

Four portable air cleaners were selected for study. All incorporated some activated carbon. Two devices designated PF1 and PF2 had multiple stage filter cartridges employing glass fiber mats for particle removal. The PF1 air cleaner had a layer of finely divided carbon impregnated in a fibrous mat and had the least amount of carbon. The PF2 unit had a layer containing activated carbon pellets (115 g) and a catalyst (99 g). The ES unit had a HEPA filter for particle removal, and contained the largest amount of activated carbon ($\sim 130 \text{ g}$) which was combined with potassium permanganate ($\sim 90 \text{ g}$). The fourth device, EP, removed particles by electrostatic precipitation rather than filtration and had 55 g of activated carbon.

Experiments were conducted in a 20-m^3 environmental chamber operated without mechanical ventilation. The chamber was ventilated and then the NO_2 and VOC were added to the chamber and mixed. The air cleaner was turned on and the rate of decay of the compounds was determined. Removal efficiencies for NO_2 were determined at an initial chamber concentration of $\sim 500 \mu\text{g m}^{-3}$. Six VOC, representative of five major classes of VOC typically found in indoor environments were used: n-heptane, an aliphatic hydrocarbon; toluene, an aromatic hydrocarbon; dichloromethane (methylene chloride) and tetrachloroethylene chlorinated hydrocarbons; hexanal an aldehyde; and 2-butanone (methyl ethyl ketone) a ketone. The average initial chamber concentrations for these compounds ranged from 130 to $680 \mu\text{g m}^{-3}$.

None of the air cleaners removed dichloromethane. The initial ECRs for NO_2 and the remaining five VOC (averaged for the VOC) for the four air cleaners are shown (figure). The ES and PF2 devices were reasonably effective.

*This research is supported by the Director, Office of Energy Research, Office of Health and Environmental Research, under Contract No. DE-AC03-76SF00098.

*This work was supported by the U.S. Consumer Product Safety Commission under Contract No. CPSC-IAG-86-1259 and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Buildings Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

Volatile Organic Compounds in Large Buildings *

J.M. Daisey and A.T. Hodgson




Figure Initial effective cleaning rates of four air cleaners for NO₂ and five VOC (average). Effective cleaning rate for the PF2 air cleaner after 150 hours of operation in a house is also shown.

tive initially in removing NO₂ and the five VOC. Removal rates were equal to one air change per hour or more for a room of about 40 m³. The PF2 device, which had a catalyst as well as carbon, had the highest ECR for NO₂ and was almost twice as effective in removing NO₂ as was the ES unit. These two devices had relatively high air flow rates and the most carbon. The PF1 and the EP devices, had much lower ECRs for the removal of NO₂ and VOC and would not effectively remove these pollutants from even a small room.

The PF2 air cleaner was subsequently operated, with the same filter, for 2.5 months (150 hours) in an older residence of non-smokers who used a gas range for cooking. The air cleaner was then tested a third time in the chamber. The figure compares the ECRs in the first and third experiments. For NO₂, the ECR was reduced to about one-third of the initial value. For the five VOC removed by the air cleaner, the ECRs after field operation were about half the initially measured values. The product literature for this device states the estimated filter life is about 1000 hours.

Further investigation is needed to determine ECRs and efficiencies over periods of extended use for air cleaners which have relatively high ECRs. Investigation of possible chemical reactions occurring with extended use is also warranted.

There have been increasing numbers of complaints about discomfort and illness in new and newly renovated office buildings. This increase in complaints has been correlated with reduction in ventilation for energy efficiency and increased uses of synthetic building materials and furnishings. Exposures to volatile organic compounds (VOC), originating from materials and furnishings and various products used in large buildings are suspected to play a role. However, there has been relatively little research to characterize VOC in large buildings, to identify their sources, to evaluate temporal and spatial variations in VOC concentrations or the effects of building ventilation on concentrations.

The purposes of the ongoing study of VOC in large buildings are: 1) to develop a data base of concurrent measurements of VOC concentrations and ventilation; 2) to investigate both short- and long-term temporal variations in source strengths of VOC; and 3) to develop methods to identify major sources and estimate their contributions to indoor VOC concentrations.

To date, simultaneous measurements of VOC and of ventilation have been made in four large office buildings, a museum-teaching facility and a school. Concentrations of total organic carbon in these buildings have ranged from less than 1 to 11 mg·m⁻³.

Temporal variations in indoor concentrations of VOC and the effects of ventilation on VOC have been under detailed investigation in a large seven-story office building in Portland, OR in collaboration with R. Grot, National Institute of Standards and Technology. The first measurements were made in August, 1987, before the building was completely finished but after it was partially occupied. Subsequent VOC samples have been collected on three occasions over a period of a year. In addition, samples of major materials used to finish the interior have been collected and screened for VOC emissions.

The concentrations of VOC and total organic carbon in the Portland building have varied considerably over the study, with the highest concentrations observed when the ventilation rate was lowest. The concentration and ventilation rate data were used in a single-equation mass balance model to estimate specific source strengths and to determine if these had declined as expected over time. The results showed that the source strengths of the individual VOC and of total organic carbon remained relatively

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Buildings Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098 and by the National Bureau of Standards under Interagency Agreement No. BG-130(01).

constant over the course of the study. The dominant source of the VOC in this particular building appears to be, not the interior finish materials, but a solvent-using activity in the building. Efforts to estimate the contribution of this activity to indoor concentrations are in progress. The emission of total organic carbon in this building was estimated to be over 2.5 kg per 8-hour day.

Development of a Sampling and Analysis Method for Polycyclic Aromatic Compounds in Indoor Air *

J.M. Daisey, L.A. Gundel, A.T. Hodgson, and F.J. Offermann†

Research was initiated to develop a method for sampling and analyzing vapor- and particulate-phase polycyclic aromatic hydrocarbons (PAH) and nitro-PAH in indoor air. Many of the PAH and nitro-PAH are carcinogens in animals but there have been few indoor measurements of these compounds. Efforts to measure these compounds in indoor air have been hampered by the lack of sensitive, validated sampling and analytical methods. For indoor air, the sampling rate must be much less than the air exchange rate so that the act of sampling has a minimal impact on the concentrations of indoor pollutants which are removed by the sampling.

The approach being taken in this research is to develop and validate a sampler consisting of a filter followed by an XAD-4 resin bed to collect, respectively, particulate and vapor phase PAH and nitro-PAH. Approximately 25 m³ of air will be sampled in 12 hours. After solvent extraction, the vapor phase compounds will be analyzed by gas chromatography-mass spectrometry and the particulate phase compounds will be analyzed by high pressure liquid chromatography with fluorescence detection. The methods will be field tested in selected houses.

The Role of Heterogeneous Reactions of NO₂ in Indoor Air *

J.M. Daisey and L.A. Gundel

Concentrations of NO₂ in indoor air can be one to two orders of magnitude greater than those in outdoor air if combustion sources such as gas stoves are present. Indoor surfaces have been shown to remove NO₂, and in a few instances, to convert it to NO. The purpose of this study was to determine if heterogeneous reactions of NO₂ on surfaces of materials in indoor environments could produce other secondary pollutants which might be hazardous or which might initiate further indoor atmospheric chemistry.

Experiments were conducted in a specially designed and constructed annular reaction vessel containing selected indoor materials: wool or nylon carpet, polyurethane foam or wallboard paper. NO₂, at concentrations of 1 ppm or less, was passed through the vessel in dry or humid (50% relative humidity) air. Concentrations of NO₂, NO, HONO, and HNO₃ were measured downstream of the reactor. An annular denuder was used to collect the acidic gases, HONO, HNO₃.

Each material removed a large fraction of the incident NO₂. The polyurethane foam removed all of the NO₂ in the air stream during the initial exposure period, but after about 5 hours was saturated. Nylon and wool carpet removed about 35% and 50%, respectively, of the incoming NO₂. NO was produced in varying amounts on all of the four materials investigated.

Significant quantities of gas phase nitrous acid (HONO) were produced from the interaction of NO₂ with both the foam and the wool carpet. Much smaller quantities of nitric acid (HNO₃) were produced. The excess of HONO over HNO₃ indicates that a direct reaction with these materials, rather than a disproportionation in sorbed surface water, has occurred. On foam, in humid air, at least 7% of the initial NO₂ (560 ppb) was converted to HONO, at a rate of about 0.5% per hour. For wool carpet, the conversion rate was only about 0.1% per hour.

The results of the experiments on heterogeneous reactions on surfaces of indoor materials have demonstrated that nitrous acid can be generated in indoor environments at substantial rates. The presence of this secondary pollutant may lead to subsequent indoor atmospheric chemistry and/or may pose some health hazard in itself.

*This work was supported by a contract from Indoor Environmental Engineering and the California Air Resources Board.

†Indoor Environmental Engineering, 3400 Sacramento Street, San Francisco, CA 94118

*This research is supported by Exploratory Research and Development Funds from the Lawrence Berkeley Laboratory.

Transport of Volatile Organic Compounds from Soil into a Residential Basement*

A.T. Hodgson, K. Garbesi, R.G. Sextro, and J.M. Daisey

For residents of nearby houses, landfills are potentially important sources of exposure to toxic volatile organic compounds (VOC). Even municipal landfills accepting only nonhazardous material have been found to contain air concentrations of VOC high enough to cause concern. If not properly contained, VOC can migrate through the soil by aqueous or gas-phase transport. Gaseous compounds in the soil around houses are available for transport into these houses.¹

Our investigation sought to identify the mechanisms involved in transport of VOC from soil gas into the basement of a house situated in an area of contaminated soil. The study site was a single-family house adjacent to a covered municipal landfill in California. We had found previous evidence of migration of gas and VOC to the site from a landfill 70 m from the house at its closest point. The house was built over a basement which was almost entirely below grade. The foundation and basement consisted of a cement-block wall built on a cement slab. Experiments were conducted at the site over a four month period during the dry season.

Thirty soil probes were installed around the house at distances ranging between 0.5 to 12 m from the basement wall. The majority of these probes terminated at a depth of 1.5 m. The in situ permeability of the soil measured at the soil probes averaged $2 \times 10^{-10} \text{ m}^2$.

Samples of soil gas, outdoor air, and indoor air for qualitative and quantitative analyses of VOC were collected on multisorbent samplers and analyzed by gas chromatography-mass spectrometry. The VOC identified in soil gas were predominantly halogenated and oxygenated compounds, a number of which have been detected in landfills. The dominant compounds in soil gas were Freon-11, Freon-12, tetrachlorethylene, dichloromethane, and acetone. Many of the compounds in soil gas were also measured in indoor air but at much lower concentrations. Since the house was unfurnished and unoccupied and had no other obvious sources, soil gas was assumed to be the primary source of most of these compounds.

The entry rate of soil gas into the basement was estimated as a function of basement depressurization. Pure SF_6 was injected into the soil around the house to provide a source of labeled soil gas. One month later, after the SF_6 had diffused over most of the site, the soil-gas concentrations of SF_6 and Freon-12, a soil-gas contam-

inant, were measured at the soil probes nearest the basement. Then, with the basement closed, the exhaust fan was operated to produce pressures in the basement of -20, -30, -40, and -50 Pa relative to ambient pressure. Concentrations of SF_6 and Freon-12 in basement air were continuously monitored throughout the experiment. The entry rate of soil gas at each depressurization stage was estimated from the concentration data using a simple mass-balance model, assuming steady-state conditions. The slopes of the regression lines of entry rate versus basement depressurization diverged for SF_6 and Freon-12 undoubtedly due to differences in their distributions around the house and the consequent uncertainties in the average soil gas concentrations of the two compounds. However, the regressions suggest that for this house the entry rate of soil gas due to pressure-driven flow would be less than $1 \text{ m}^3/\text{h}$ at a typical basement depressurization of a few Pascals resulting from wind and an indoor-outdoor temperature differential. For comparison, the infiltration rate of outdoor air for the house at typical winter conditions would be about $500 \text{ m}^3/\text{h}$.

Since the basement of this house was well coupled with the soil and the soil was moderately permeable, the pressure-driven entry of soil gas was probably limited by the low below-grade leakage area of the basement. However, for houses with greater below-grade leakage areas, soils of equal or greater permeability, and low infiltration rates, the relative contribution of pressure-driven inflow to the total inflow of air can be much higher. Therefore, it is concluded that advective transport can result in elevated indoor concentrations of soil-gas VOC in those houses which have high relative inflow rates of contaminated soil gas.

REFERENCE

1. Nazaroff WW, Lewis SR, Doyle SM, Moed BA, Nero AV Nero. Experiments on pollutant transport from soil into residential basements by pressure-driven airflow. *Environ Sci Technol* 1987; 21: 459-466.

The Indoor Environment of Commercial Buildings*

D.T. Grimsrud, J.T. Brown, W.J. Fisk, J.R. Girman

The primary focus of research in indoor air quality has been on residential buildings. This report, by contrast, concentrates on commercial (office and institutional) buildings and is intended for a broad audience ranging from

*This work was supported by the Occidental Chemical Corporation under agreement BG8602A and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

* This work was supported by the Electric Power Research Institute, Inc. (EPRI) and the Assistant Secretary for Conservation and Renewable Energy, Office of Buildings and Community Systems, Building Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

those who have no previous background in indoor air quality to those with considerable indoor air quality experience.

A recurring theme throughout the report is the sick building syndrome. This troublesome phenomenon, an attribution of the source of general feelings of irritation and malaise to the occupant's building, can cause significant economic damage to the building owners and tenants if the productivity of the workforce declines. Considerable uncertainty exists regarding the cause or causes of sick building syndrome. Current research on indoor air quality issues in commercial buildings concentrates on sick buildings; however, one must be careful not to overemphasize this topic. The health outcomes associated with the sick building syndrome tend to be short-term irritation effects. Longer-term, chronic effects associated with exposure to pollutants in commercial buildings may be equally or more important. These are not addressed typically in any study focused on the sick building syndrome. Where long-term effects are understood, they are discussed in this report.

The report is divided into seven chapters. The introductory chapter is followed by a discussion of the effects of initial design decisions that affect air quality. Many of these design decisions pertain to the ventilation systems. The mechanical ventilation systems, rare in residences but common in commercial buildings, have been identified by some as major causes of problems in the indoor environment. Their influence on indoor air quality is treated in chapter three.

Pollutants present in commercial buildings are discussed in chapter four. The discussion is organized by pollutant classes arranged in order of the expected pervasiveness of the pollutant problem. The long pollutant chapter is followed by the three final shorter chapters examining human factors, investigative procedures, and general corrective procedures to be considered when problems are discovered.

Pacific Northwest Existing Home Indoor Air Quality Survey and Weatherization Sensitivity Study *

B.H. Turk, D.T. Grimsrud, J.Harrison, R.J. Prill, and K.L. Revzan

The study reported in this paper had the following objectives:

- 1) survey indoor pollutant concentrations in unweatherized Pacific Northwest housing,

*This work was supported by the Bonneville Power Administration (BPA) under contract no. DE-A179-83BP12921, by the Assistant Secretary for Conservation and Renewable Energy, Office of Buildings and Community Systems, Building Systems Division of the U.S. Department of Energy under contract No. DE-AC03-76SF00098.

- 2) study the effect of weatherization on indoor pollutant levels.

SCREENING SURVEY

A screening survey of indoor air quality in 111 unweatherized houses was followed by staged weatherization in 40 of these 111 structures. Study sites were located in two of the three major climate areas of the Bonneville Power Administration (BPA) region. Houses in Portland and Vancouver, WA are found in the mild, coastal region while houses in Spokane and Coeur d'Alene, Idaho are located in the high plateau desert region east of the Cascade Mountains. Passive samplers to measure concentrations nitrogen dioxide, water vapor, formaldehyde, and radon were mailed to homeowners who put them in place using the shipping box as the sampler holder. Extensive telephoning was required to assure that instructions were followed. The screening survey results indicate that indoor concentrations of nitrogen dioxide (geometric mean of 5 ppb), formaldehyde (geometric mean of 37 ppb), and water vapor (arithmetic mean of 6.7 g/Kg) were significantly below levels of concern. However, the survey led to the discovery of elevated indoor radon levels in houses in the Spokane River Valley/Rathdrum Prairie of Washington and northern Idaho. The geometric mean concentration for 43 houses in that area was 4.4 pCi/L, compared with other regional and national studies that range from geometric means of 0.8 to 1.0 pCi/L. The high indoor radon levels found in the Valley/Prairie are due to the convective flow of radon-bearing soil gas from a highly permeable soil into the houses.

WEATHERIZATION STUDY

Forty-eight houses from the screening survey were chosen for the weatherization sensitivity phase of the study. Eight of the houses remained unweatherized during the study and acted as control structures; monthly measurements of pollutant concentrations were made in these houses to track the impact of non-weatherization factors on pollutant concentrations. The remaining houses underwent a variety of staged weatherization retrofits: all 40 houses received the standard BPA weatherization package, 14 houses also received wall insulation, while five of the forty houses also received house doctoring. Building and pollutant measurements were obtained using passive samplers where possible, and real-time instrumentation where necessary. Spokane/Coeur d'Alene houses were more tightly sealed against air leakage, both before (geometric mean specific leakage area of 4.9 cm²/m²) and after weatherization (geometric mean of 4.1 cm²/m²) than the Vancouver area houses (geometric mean of 5.3 and 4.9 cm²/m², respectively). BPA's standard weatherization program reduced the specific leakage area of the 40 weatherized structures approximately 12.5%. The reduction due to wall insulation (6%) was not statistically significant. House doctoring resulted in an additional reduction in leakage area of 26%.

Ventilation rates measured using passive sampling techniques and perfluorocarbon tracers (PFT) had a geometric mean of 0.37 h^{-1} before weatherization, 0.39 h^{-1} after weatherization, and 0.30 h^{-1} after house doctoring; however, these ventilation rates have not been corrected to account for different environmental conditions during the various measurement periods. The PFT-measured ventilation rates averaged approximately 20% lower than ventilation rates calculated using the measured leakage areas, weather data and a predictive model developed at LBL. The PFT technique yields results for a specific set of environmental conditions. The leakage area measurement combined with predictions accounts for environmental conditions but has significant uncertainties due to the reliance of an imperfect model. Because, ventilation rates scale with leakage area, we use the change in the leakage area of the house as the best measure of the change in the ventilation produced by weatherization.

Changes in pollutant concentrations were not well correlated with changes in ventilation rates. Factors other than ventilation, including pollutant source strengths, occupant effects, and environmental conditions are more important in influencing indoor pollutant levels.

While not correlated with changes in ventilation, pollutant concentrations did change. Measured data from this study showed increases of 11% in water vapor concentrations, 1% in formaldehyde concentrations, and reductions of 6% in NO_2 and 43% in radon concentrations when the means of the pre- and post-weatherization samples are compared. However, these results represent measurements made during different environmental conditions. Therefore, the results must be corrected to standard conditions if meaningful comparisons are to be made. Simplified models were developed to evaluate the impact of environmental conditions on indoor air pollutants. The models were used to recalculate radon, water vapor, and formaldehyde concentrations from before and after weatherization to corrected standard conditions. The concentrations adjusted to standard conditions show an increase of 8% in post-weatherization water vapor concentration relative to pre-weatherization conditions; a decrease of 3% in formaldehyde concentrations, and a decrease of 33% in radon concentrations. Only the changes in the radon concentrations are statistically significant. Where the radon data are separated by substructure type we find that only in crawlspace houses, where ventilation is added to crawlspaces during weatherization, were the indoor radon levels significantly reduced. Radon levels in houses with other substructure types may have decreased also, but the changes are not statistically significant.

The impact of weatherization on indoor air quality is rather modest with the exception of its impact on radon concentrations. In a house with a crawl space, the standard BPA weatherization package improves indoor air quality by reducing radon concentrations.

The findings from this study showed that indoor pollutant concentrations were low except for radon concentrations in existing houses in the Spokane area. The standard weatherization measures reduced the specific leakage

area and therefore the ventilation in these houses by 12%. A poor correlation was seen between ventilation changes and changes in pollutant concentrations. Finally, weatherization had a modest effect on pollutant concentrations other than radon. Weatherization caused radon concentrations to decrease significantly in crawl space houses.

Commercial Building Ventilation Measurements Using Multiple Tracer Gases*

William J. Fisk, Richard J. Prill, and Olli Seppanen

Indoor air quality and the efficiency of ventilation depend, in part, on the rate of supply of outside air and also on the spatial variability of ventilation and the indoor flow patterns. For example, some rooms may be over-ventilated and others under-ventilated. Another concern is the possibility that fresh air supplied at ceiling-level short circuits to ceiling-level return grills such that the occupied region is poorly ventilated. Such a flow pattern would be inefficient. Conversely, a displacement or piston-like flow pattern in the floor-to-ceiling direction would generally be efficient since the air exiting the building would typically have an above-average concentration of pollutants.

Three new parameters are used to describe the ventilation process in detail. The first parameter is the age of air which equals the amount of time the air has been in the building. The second parameter is the air exchange efficiency which equals the age of the air that exits the building divided by twice the spatial-average age of indoor air. The air exchange efficiency equals 0.5 when the indoor air is perfectly mixed--values below and above 0.5 indicate short circuiting and displacement flow patterns, respectively. The third parameter is the source of air fraction which equals the fraction of air at some location that entered the building through a particular air handler or by infiltration.

To measure these new parameters, we simultaneously label each incoming stream of outside air with a different tracer gas. Outside air may be labeled directly by injecting a tracer gas at a constant rate directly into the stream of outside air, or labeled indirectly by injecting the tracer into the mixture of outside air and recirculated indoor air. Tracer injection is continued until concentrations in the air exiting the building are stable. Using cart-mounted gas chromatographic systems, tracer gas concentrations are monitored versus time in the major ducts of the air han-

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Buildings and Community Systems, Building Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

ding units. During the period of injection, small local samplers in occupied spaces pump air/tracer samplers at a constant rate into one-liter sample bags yielding samples with time-average tracer concentrations. When tracer concentrations have stabilized, a syringe sample is collected at the location of each local sampler and operation of the local sampler is terminated.

Previously-established data analysis procedures based on age distribution theory have been modified to account for the use of multiple tracer gases. Source of air fractions are determined from ratios of steady-state tracer gas concentrations to measured (or predicted, if the outside air is labeled indirectly) concentrations of the same tracer gases in the streams of incoming outside air. Ages of air are determined from the source of air fractions and numerical integrations of the real-time tracer gas concentrations or by equivalent computations using the data collected at local samplers. Finally, the spatial average age of the indoor air is estimated by averaging the ages measured at numerous indoor locations.

The results of investigations in a complex of three interconnected office buildings and in an isolated office building are summarized. Within regions of these buildings that are served by a single air handler that supplies a mixture of outdoor and recirculated indoor air, the measured ages and source of air fractions varied by 30% or less from the region-average values. Monitoring at different heights above floor level provided no evidence of either short circuiting or displacement flow patterns within a room. Age of air varied more substantially between physically-isolated regions of a building (e.g., different floors with no mechanical recirculation between the floors) and between regions served by different air handlers. In the complex of buildings, air exchange efficiency values were close to 0.5, suggesting relatively uniform mixing of the indoor air in regions served by a single air handler. In the isolated building, air was supplied and removed from physically-isolated regions, and the air exchange efficiency was 0.7. Monitoring in additional buildings is required before general conclusions can be drawn regarding these aspects of ventilation in commercial buildings.

Indoor Exposure Assessment*

G.W. Traynor, A.V. Nero, S.R. Brown, M.A. Apte, and B.V. Smith

The Indoor Exposure Assessment Project has three major research themes: 1) to continue the development of a macromodel to characterize the frequency distribution of indoor pollutant concentrations; 2) to compile a data base of field measurements of indoor pollutants; and 3) to conduct assessments of the health risks associated with exposures to indoor air pollutants. Conceptually, the first two projects supply the data needed for the third project of assessing health risks from indoor air pollutants.

In FY 1988, modeling efforts assessing the distribution of indoor exposures to combustion pollutants were continued; the concentration of indoor pollutants (CIP) data base was expanded; and the overall assessment of carcinogenic risk from indoor exposures was advanced.

MACROMODEL TO ASSESS INDOOR CONCENTRATION DISTRIBUTIONS

A major effort of the Indoor Exposure Assessment Project has been to utilize available information on the behavior and occurrence of indoor pollutants as a basis for assessing, in a systematic way, the distribution of public exposures to important classes of indoor pollutants. Initial efforts of the project focussed on the problem of estimating exposures to combustion emissions. This effort has resulted in the development of a macromodel that can predict indoor pollutant distribution across houses for carbon monoxide (CO), nitrogen dioxide (NO₂) and respirable suspended particles (RSP).¹

The model development was completed in FY 88. The model is based on, and is an expansion of, mass balance principles commonly used in IAQ studies. Keys to the model include the characterization of building stock parameters relevant to IAQ (e.g., house volume, air

*This work was supported by the Director, Office of Energy Research, Office of Health and Environmental Research, Human Health and Assessments Division, by the Assistant Secretary for environment, Safety and Health, Office of Environmental Analysis, and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building System Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098; by the Directorate of Health Sciences of the U.S. Consumer Product Safety Commission through Interagency Agreement CPSC-IAQ-86 with DOE; by the Gas Research Institute, Chicago, IL with DOE; and by the Electric Power Research Institute, Palo Alto, California through contract RP2034-14 with DOE.

exchange rate), the investigation of the market penetration of combustion appliances and other indoor combustion sources, and the development of source usage models. The model utilizes deterministic and Monte Carlo simulation techniques to combine all of the inputs yielding indoor pollutant concentration distributions.

Although the initial modeling efforts concentrate on three combustion pollutants, the model is being developed with explicit attention to future expansion of the model to describe other indoor air pollutants concentrations from a wide variety of sources.

The planned activities for FY 89 are: 1) finalize the formal report on the development of the model; 2) conduct sensitivity analyses and micro/macro comparisons of the model to rank information/modeling gaps; and 3) explore the potential for generalizing the model and expanding it to include combustion pollutants other than CO, NO₂, and RSP (e.g., polycyclic aromatic hydrocarbons, dinitropyrenes or other organic mutagens), radon, and non-combustion organic contaminants such as those arising from building materials, furniture, and consumer products.

CONCENTRATIONS OF INDOOR POLLUTANTS (CIP) DATA BASE

During the last ten years public and governmental concern regarding indoor air quality in this country and elsewhere has greatly increased. This concern has resulted in hundreds of field experiments being carried out to monitor pollutant concentrations and other relevant parameters in a wide variety of building types and geographic locations.

The goal of this project is to create a computerized data base of the results of field studies devoted to monitoring indoor air quality in occupied buildings in the United States and Canada.

A major update to the Data Base was prepared during FY 88. New bibliographic references, summary data sets were added. Several minor enhancements to the software were made.

Software was written to support user entry and editing of summary search data. When distributed, this would make it possible for the user to enter not only their own bibliographic data, but also summary data and text.

The first draft of a technical reference manual was prepared. This manual is designed to provide a journeyman programmer with enough information to modify and extend the data base system. It includes file specifications, heavily commented source code, a subroutine tree, and other useful information.

The CIP Data Base (Version 3.1) has been implemented in a microcomputer environment running MS-DOS, using dBase III, and a commercial dBase III compiler, Clipper.

Additional updates to the data base will be distributed during the fiscal year. The updates will include all available published work and final reports. In addition, the user community will continue to be supported. There are over 200 current users of the CIP Data Base.

RISK ASSESSMENT

The purpose of this work is to utilize exposure information as a basis for estimating the health risks due to various classes of indoor pollutants.

Earlier work in this area has made sufficient progress in examining risks of major pollutant classes that, together with other information, it is now possible to assemble tentative pictures of risk for certain health endpoints, at least for diseases like lung cancer, that are usually fatal.

The LBL effort has previously examined data on indoor radon concentrations as a basis for estimating the distribution of indoor concentrations, and hence exposures, in U.S. homes.² This indicates that the average indoor concentration is approximately 1.5 pCi/l (55 Bq/m³) in single-family homes and that approximately 7% (or 4 million houses) have annual-average concentrations exceeding 4 pCi/l (150 Bq/m³). Together with various epidemiological data, this leads to an estimate of the average lifetime risk of lung cancer due to radon exposures of about 0.4%,³ with long-term occupants of houses with 150 Bq/m³ incurring a risk exceeding 1% and those living at higher concentrations having proportionately higher risks.

This defines a spectrum of risk from radon that is much higher than the risks associated with typical environmental pollutants, i.e., those in outdoor air and in water supplies, and that compares with occupational risks or with risks associated with personal choices - e.g., accidents in homes or cars or, in the extreme, cigarette smoking. Similarly, analysis of organic chemicals indoors leads to an estimated average risk of cancer of 0.03-1% due to indoor exposures (depending on the form of dose-response model used).^{4,5} This again is a large risk compared with other environmental situations.

This picture of risk of premature death due to indoor exposures can be filled out by noting the estimated effects of two other pollutants about which there has been much concern: environmental tobacco smoke (ETS) and asbestos.⁶ Although controversial, midrange estimates of the risk of lung cancer to the average nonsmoker, due to breathing ETS, are comparable to the middle of the estimated range for organic chemicals just noted. Estimates of the risk from asbestos exposure, arising primarily indoors, are somewhat lower. Nonetheless, estimated risks from all of these indoor pollutants just named exceed 10⁻⁴, which is larger than most environmental risks. This more complete, albeit tentative, picture of the risks of indoor pollutants provides a direct basis for considering the importance of indoor pollutants and influences the design of strategies to control indoor air pollution levels by contributing to fuller development of our general perspective on risks due to pollutant exposures.

We will continue to 1) reexamine radon risk estimates in the light of new data on U.S. radon concentrations and reanalysis of the full body of epidemiological data, 2) undertake a general evaluation of our current state of knowledge on organic chemicals and their importance, and 3) include results from combustion exposure modeling in assessment of indoor risks.

REFERENCES

1. Traynor GW et al. Macromodel for assessing indoor concentrations of combustion generated pollutants: part I, model development and preliminary predictions for CO, NO₂ and respirable suspended particles. LBL-25211; 1988 (draft).
2. Nero AV, Schwehr MB, Nazaroff WW, and Revzan KL. Distribution of radon-222 concentrations in U.S. homes. 1986, *Science* 234:992.
3. Nero AV. Estimated risk of lung cancer from exposure to radon decay products in U.S. homes: a brief review. 1988, *Atmos. Environ.* 22:2205-2211.
4. McCann J, Horn L, Girman J, and Nero AV. Potential risks from exposure to organic compounds in indoor air. 1986, LBL-22473.
5. McCann J, Horn L, Girman J, and Nero AV. Potential risks from exposure to organic carcinogens in indoor air. in Sanbhu SS, de Marini DM, Mass MJ, Moore MM and Mumford JS (Eds.). *Proceedings of EPA Symposium on Short-Term Bioassays in the Analysis of Complex Environmental Mixtures*, Durham, NC, October 20-23, 1986.
6. Nero AV. Elements of strategies for control of indoor air quality. *Indoor Air '87: Proceedings of the 4th International Conference on Indoor Air Quality and Climate: Volume 3*, Institute for Water, Soil and Air Hygiene, Berlin (West), pp. 573-578.

Energy Performance of Buildings*

M.H. Sherman, R.C. Diamond, D.J. Dickerhoff, H.E. Feustel, M.K. Herrlin, A. Kovach, M.P. Modera, B.V. Smith, C. Stoker, and Y. Utsumi

The Energy Performance of Buildings Group (EPB) carries out fundamental research into the ways energy is expended to maintain desirable conditions inside buildings. Our results form the basis of design and construction guidelines for new buildings and retrofit strategies for existing buildings. In this article, the work carried out over the last year is split into four overlapping sections: 1) Existing Buildings Efficiency Research, 2) Air Infiltration, 3) Air Leakage, and 4) Wood Burning. The emphasis in our work is on whole building performance. We collect, model, and analyze detailed data on the energy performance of buildings, including the micro-climate, the building's thermal characteristics, the mechanical systems, and the behavior of the occupants. Because of the multidisciplinary approach we work closely with other groups, both at the Laboratory and elsewhere.

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy and Office of Building and Community Systems, Building Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098, Idaho Department of Water Resources and the Bonneville Power Administration.

EXISTING BUILDINGS EFFICIENCY RESEARCH

As new buildings—both residential and commercial—are responding to higher energy prices and stricter energy codes by becoming more energy efficient, the existing stock represents a large untapped area for energy conservation activity. Of the three buildings sectors, single-family, multifamily, and commercial, multifamily has had the least level of activity, and presents some of the greatest challenges. Over one quarter of the U.S. housing stock is in multifamily buildings. The Office of Technology Assessment estimates that while current levels of retrofit activity in multifamily buildings are likely to save 0.3 quads of energy (320 petajoules) by the year 2000, the potential savings are more than three times as much.

The Existing Building Efficiency Research Program was initiated to address these problems in all three building sectors, single-family, multifamily, and commercial. The U.S. Department of Energy has designated LBL as the primary lab for carrying out research in the multifamily sector, and while the emphasis in the past years has been in coordinating research in this sector, we continue to work in single-family and commercial buildings. A review of the work in all three sectors is available.¹

Protocol Development

The need for a standardized set of procedures for monitoring buildings has led to our developing a monitoring protocol for residential buildings. An earlier draft of the protocol was used to specify the monitoring procedures during field tests in multifamily buildings in Chicago and Minneapolis/St. Paul. The experience gained at these monitoring sites has been incorporated into subsequent drafts of the protocol. The objective of the protocol is to provide a comprehensive standard for data collection and evaluation of retrofit performance. A primary goal for the protocol work is the development of an ASTM and ASHRAE standard for building monitoring.

Development of Audits and New Diagnostic Techniques

While the protocol provides a guideline for long-term monitoring, practitioners and researchers also have a need for short-term diagnostic tests to understand the characteristics of the building shell and mechanical systems. In addition to having a tool box of basic diagnostic techniques, the practitioner needs a strategy for how to use them.

The *Multifamily Audit* currently under contract to Princeton University gives the necessary information for determining appropriate retrofits for an individual building.² Based on material developed by Princeton and LBL, the audit outlines the steps to evaluate, select, and analyze the performance of the retrofits in a multifamily building. A draft of the audit was prepared in conjunction with the joint Princeton/LBL diagnostic demonstration (March, 1988) and a final copy will be available by 1989.

Diagnostics for energy use in multifamily buildings that have been developed or are currently under development include tests of boiler efficiencies, distribution losses, shell and inter-apartment leakage, and household appliance efficiencies.

Following the development of air leakage diagnostics, we tested a ten-unit apartment building to determine air flows between units and to the outside. Results from these tests showed that the individual apartments were quite leaky to the outside, but had very little leakage between units, in contrast to the older buildings we had been studying previously.

Analysis of Retrofit Performance in Multifamily Buildings

We developed two models in the past year based on data collected from earlier monitoring projects in Chicago and Minneapolis. The first models the air flow through combustion appliances (i.e., heating and hot water systems) that exhaust through a common chimney, a situation that is typical in multifamily buildings. The model can be used to predict the performance of retrofits such as vent dampers or flow restrictors based upon the physical configuration and operating characteristics of the system.³

The second model characterizes the seasonal efficiency of multifamily boilers, taking into consideration the venting issues described above, as well as jacket and ground heat losses. Jacket losses from the older brick-set boilers were as high as 12 percent. Newer, steel-case and sheet-metal boilers had jacket losses of 2-4 percent. More than 80% of the losses were found to occur in off-cycle. This model is capable of providing the data necessary to make recommendations for boiler retrofit or replacement.⁴

Institutional Barriers

The widespread adoption of many retrofits is hindered by institutional barriers, including split financial incentives between owners and tenants, lack of information on the part of building managers, and a wide range of behavioral issues. We evaluated three projects this year that looked at institutional barriers, the first on the role of apartment managers in determining the energy use in multifamily buildings, a second study on how to improve information about energy use and savings to homeowners and renters based on their utility bills, and a third project that looked at how decisions are made that affect the energy use in new office buildings.

The study of apartment managers surveyed several groups and building organizations that have addressed the problems of improving energy efficiency in multifamily buildings through better operations and maintenance. Motivation and feedback were found to be the two key elements in ensuring adequate attention by the building managers. We undertook case studies to examine the basic problems confronting apartment managers, and innovative solutions to these problems were documented.⁵

One of the difficulties in retrofit research is finding simple ways to evaluate the performance of the retrofits.

Often the only feedback available to homeowners who have undertaken retrofits is to compare utility bills from before and after the retrofit. While energy researchers can weather-normalize the pre- and post-retrofit energy consumption, homeowners will typically compare only their costs, receiving potentially misleading information.

In work carried out by the Center for Environmental Studies, Princeton University, we collaborated on a project to provide a sample of households in New Jersey with a home energy report which showed their monthly household energy consumption, weather-normalized, for a two-year period. The households were then surveyed to determine whether they found this information useful, whether it helped them determine if their previous retrofits were successful, and whether the information would encourage them to take further steps in conserving energy. The results of this feedback study showed that while most households appreciated having the information, and found it quite interesting, many were unable to grasp the concept of weather normalization. Several of the households, however, thought that the information would help them keep track of how much energy they were using.⁶ In 1988 we started a similar study to focus on providing information to tenants in multifamily buildings.

We completed the evaluation of two innovative office buildings designed to showcase new energy technologies. The work was carried out in collaboration with Princeton University, and focused on the design process and how decisions affecting energy performance were made. As part of the study we evaluated the tenants' satisfaction with the buildings.⁷ An off-shoot of this work will be our involvement in FY '89 in evaluating a sample of new energy-efficient buildings in the Pacific Northwest.

AIR INFILTRATION AND VENTILATION

With improved insulation of the building shell, heat loss from ventilation—whether controlled or by infiltration—has become an even more important fraction of a building's overall heat loss. Our air infiltration and ventilation work is split into three areas, multizone modeling, ventilation and moisture analysis, and support for the International Energy Agency's ventilation annexes.

Multizone Modeling

A number of computer programs have been developed to calculate air flow patterns in buildings. Awareness of the airflow pattern in a building is particularly important when (1) determining indoor air quality for the different zones in a building, (2) evaluating smoke distribution during a fire, and (3) calculating space conditioning loads. Sizing space conditioning equipment is also dependent upon accurate air flow information.

To treat the true complexity of the air flows in a multizone building, extensive information is needed regarding flow characteristics and pressure distributions both inside and outside the building.⁸ To reduce the input data required by detailed infiltration models, simplified models have been developed. Most of these, including the one

developed at LBL, simulate infiltration associated with single-zone structures.

A high percentage of existing buildings, however, have floor plans that characterize them more accurately as multizone structures. Although multizone models exist, the vast majority are not readily available to the end user.⁹ These models need inordinate amounts of input data. Therefore, a simplified multizone model capable of providing the same accuracy as the established single-cell models is being developed at LBL.¹⁰

The first validation of the simplified model for predicting multizone air flows was completed this year.¹¹ We plan to validate the model in the coming year through multigas tracer measurements both in the laboratory and in the field, as well as through an extensive collaborative international effort with the *Laboratoire d'Energie Solaire (LESO)* at the Ecole Polytechnique Federale de Lausanne in Switzerland.

The bulk of the multizone infiltration modeling work was done in cooperation with the Joint Research Centre of the European Communities in Ispra, Italy. Work included the preparation for the COMIS workshop in FY89. COMIS (Conjunction of Multizone Infiltration Specialists) is a year-long international workshop scheduled to take place at LBL during FY89. Experts from approximately 10 different countries will work together to complete the problem of predictive modeling of air flow in multizone buildings. The intended outcome is a general purpose computer code for use by designers, policy makers, researchers, etc.

Ventilation and Moisture

The MultiTracer Measurement System (MTMS) is a multigas tracer system that allows the simultaneous determination of the air flows between all of the zones within a building, as well as to the outside. The system is built around a quadrupole mass spectrometer which allows fast measurement of the concentration of all the tracer gasses in all zones. Injection of the tracer gas is controlled to keep a nearly constant concentration of the tracer in the zone it is injected. This is done to optimize the measurements and is not required for the analysis, as is the case in a single-gas system. MTMS has been used to measure up to five zones within a building and has the capability to measure eight.

This year MTMS was used in a comparison between multi-zone measurement systems developed by LBL, Princeton University and Brookhaven National Lab.¹² Of the three systems, MTMS gave both the greatest information about air flows and had the most flexibility.

Figure 1 shows a three day segment of one of the trace gases (gas 3) in five zones of the apartment complex. Zone 1 is an upstairs apartment and has no connection to the other zones. Zone 4 is a district heat exchanger room and has a large exhaust fan. At time 75.6 the door between zone 3 and 4 is closed and we see the concentration of gas 3 increase in zone 3 and decrease in zone 4. To obtain the desired target concentration of 10 ppm (of




Figure 1. Tracer gas concentrations in a four-zone configuration. Controlled concentration is in the zone 3.

gas 3 in zone 3) the injection rate is reduced. A similar response is seen at 70.8 when the exhaust fan is turned off, and its opposite at 71.4 when the fan is turned back on.

MTMS was also used in Princeton to measure air flows in conjunction with measurements on radon levels in a residence which used either electric resistance or central forced air heating systems.¹³ The information MTMS provided about inside air flows and flows in combustion devices helped to determine radon entry behavior and flow paths. MTMS was also used in two residences in the Pacific Northwest as part of a study to compare blower-door and passive ventilation measurement techniques.

Our effective ventilation efforts have provided techniques for estimating how much passive ventilation measurement techniques will underestimate the average ventilation rate. For typical housing the underestimates are at the 20% level. Results of the air flow calculations for the data set shown in Figure 1 are given in Figure 2. Note the large drop in flows when the door is closed and when the exhaust fan is turned off. We can also see that the flow direction between zone 3 and 2 changes when the exhaust fan is turned off. Estimated errors for these flows are typically about 10% for flows to/from outside and 20% between zones.

In FY 88, we also initiated a field monitoring project in College Station, Texas to examine the performance of a ventilation strategy for hot, humid climates. The strategy being examined consists of using pressurization ventilation in conjunction with a heat-pump water heater in the cooling season, and exhaust ventilation with the same heat pump during the heating season. This strategy should provide cost-effective ventilation and moisture management, as well as hot water, during the summer, while providing the conventional benefits of exhaust ventilation with heat recovery in the winter. Long-term data acquisition sys-




Figure 2. Air flows calculated from data in Figure 1 showing influence of fan operation and door openings.

tems were installed in both houses this summer, and the ventilation systems installed in both houses in the fall. The systems will be monitored continuously for the next year, including flip-flop tests between the systems and conventional electric resistance heating.

International Energy Agency (IEA) Support

In response to the 1973-74 oil crisis, the OECD countries formed the International Energy Agency. As part of the implementation agreement, technical annexes were created to enable countries to work together on problems of mutual interest. To date, twenty technical annexes have been formed. As the U.S. representative to Annex V, the Air Infiltration and Ventilation Centre, we provide interested parties with information material, e.g., the quarterly published Air Infiltration Review, which is sent to over 640 U.S. researchers and professionals. We also distribute the AIVC Technical Notes to interested parties. During FY 88 the Air Infiltration and Ventilation Centre responded to over 100 inquiries from the U.S. and delivered over 600 copies of technical papers held in their library of some 2,200 ventilation-related papers.

AIR LEAKAGE

The process of air flowing through unintentional apertures is called air leakage. In buildings, air leakage occurs through apertures in the building envelope, in mechanical systems, and in between building zones. Air leakage flowrates depend both on the air tightness of the building component as well as on the pressures driving the flow. For building envelopes, the technique used for measuring and characterizing their air tightness, the fan pressurization technique has evolved over the past ten years. The air tightness of residential-building mechanical systems (e.g., central furnace ducts) and the air tightness of inter-

nal partitions between zones (e.g., in multifamily buildings) have only recently begun to be examined.

Our air leakage research can be divided into three areas: leakage characterization, measurement techniques, and consensus standards. Our leakage characterization effort involves collecting and analyzing measured leakage data, as well as understanding the fluid dynamics of air leakage. As part of our measurement technique research we have developed alternative techniques for measuring building envelope airtightness, including AC Pressurization and Pulse Pressurization, and are presently developing techniques for measuring the air leakage in residential duct systems and multi-zone buildings. Finally, we are putting our experience to use by assisting the professional societies in the formation of consensus standards.

Air leakage research efforts in FY 88 focused on measurement technique development and analysis, specifically on the development of the Pulse Pressurization technique for measuring single-zone leakage, an analysis of the effects of wind on fan pressurization measurements, and on the development and analysis of multi-zone leakage measurement techniques.

The Pulse Pressurization technique determines the leakage characteristics of the envelope of an enclosure (e.g., building) from the decay of the building pressure from an elevated value down to its steady-state value.¹⁴ During FY88, the theoretical work needed to extract the leakage characteristics of the envelope from the pressure decay was performed, as was an experimental examination of the technique in a small test structure.^{15,16} The robustness of the technique was tested using the experimental data obtained, this analysis indicating that although loss mechanisms other than leakage can affect the decay of the oscillating components of the pressure, the technique provides repeatable measurements of envelope air leakage. These results imply that future implementations of the pressure-impulse mechanism will be designed so as not to excite the normal modes of the structure or its contents, which is accomplished by simply increasing the rise-time of the pressure impulse.

As fan pressurization involves the measurement of the fan flows required to maintain measured indoor-outdoor pressure differences, wind-induced pressure variations add uncertainty to the measurement. During FY88 we performed a theoretical analysis of the effects of wind on fan pressurization measurements, as well as an analysis of experimental data taken in at the University of Alberta to explore these effects. The results of these analyses indicate that wind-induced measurement uncertainties can be significantly attenuated using a four-wall pressure averaging probe and time-block averaging of pressure and flow data. The analyses also demonstrated a wind-induced bias in leakage area measurements for both single-pressure and four-wall-average pressure techniques.

As part of our work with professional committees and organizations, we were involved with two standards-writing organizations: the American Society for Testing and Materials (ASTM) and the American Society of Heating Refrigeration and Air-conditioning Engineers

(ASHRAE). We participated in several activities in ASTM during FY 88, including the modification of Standard Test Method E-779, "Determining Air Leakage Rate by Fan Pressurization" and related standards. We are also involved with ASHRAE standard project 119P, which is intended to promote energy conservation by setting maximum values for air leakage in detached single-family residential buildings. After a five year effort this standard was approved by ASHRAE.

Air leakage research efforts in FY 89 will focus on further development of the Pulse Pressurization technique, further testing of AC-pressurization and fan-pressurization techniques for measuring inter-zonal leakage, and analysis of existing data on residential duct leakage. The multi-zone techniques will be tested under controlled conditions in a multi-zone building. The duct leakage analysis will be based on data in our air-leakage database, data taken over the past several years by our staff, and on data taken as part of a field study performed by a monitoring contractor in Oregon.

The other focus of air leakage research in FY 89 will be in leakage characterization. The objective of this work is to develop a workable physical model for air flow through large apertures submitted to dynamic pressure conditions. This more basic work has application both to our two dynamic leakage measurement techniques, AC pressurization and pulse pressurization, as well as to the dynamic flows associated with natural ventilation.¹⁷

WOOD BURNING

Approximately 14% of residential space heating in the U.S. is supplied by wood burning, which when added to industrial burning, adds up to more than 3% of our primary energy needs. More importantly, approximately one third of the primary energy needs of developing countries is provided by combustion of biomass. These factors, along with the fact that wood and other biomass combustion typically occurs at very low efficiencies with high emissions of noxious gasses, particulates and greenhouse gases, have been the impetus behind the wood-burning research in our group. Our work has included the development of techniques to measure the thermal efficiency of wood burning in the laboratory and in the field, as well as studies of emissions from wood burning.

Based upon a single-channel woodstove heat-output monitor we developed several years ago, a study of wood heat delivery to single family residences was conducted in the Pacific Northwest. In FY 88, in collaboration with Pacific Power and Light, we continued our comparison between measured wood stove heat outputs and reported wood use based upon occupant surveys and site visits.¹⁸ The principal finding of this study was that the apparent field efficiencies of wood burning averaged between 20% and 30%, far below the quoted laboratory efficiencies of 40% to 60% for the types of stoves monitored. Based upon these findings, and on the apparent changes in efficiency over the course of the two-year study, it seems clear that the conventional technique for estimating wood energy delivery is both imprecise and biased. This can be

explained either by concluding that field efficiencies are far below laboratory ratings and thus the laboratory procedure should be reexamined, or by concluding that occupant reported wood use, even in conjunction with site visits by trained technicians is both a biased and uncertain estimator of actual wood consumption.

The other accomplishment in wood-burning research in FY 88 was the completion of a study of the effects of wood load and wood surface area on emissions from wood burning.¹⁹ This study provided a simple theoretical explanation for trends in emissions found in experiments performed at the Royal Institute of Technology in Sweden. Based upon the oxygen-controlled nature of enclosed wood burning, it was shown that emissions of CO, CH₄, and soot scaled almost linearly with the amount of wood surface area above some critical value (dependent upon the rate of air supply). The results of this study have implications for wood-burning policy, stove design, and appropriate test methods. In FY 89, we hope to expand our capabilities to include the development of appropriate test methods for the efficiency and emissions from cookstoves in developing countries.

REFERENCES

1. MacDonald JM, Karnitz MA, Diamond RC, Ritschard RL, Mixon WR, Sherman MH. Research update: existing building efficiency research, 1987-1988. ORNL/CON-268, Oak Ridge National Laboratory, 1988.
2. Dutt GS, Harrje DT. Multifamily building energy audit procedure, interim version. Princeton University, 1988.
3. Dumortier D, Modera MP. A model for predicting air flow through venting systems for multiple combustion applications. Lawrence Berkeley Laboratory Report LBL-23151, 1988.
4. Modera MP. Jacket and stack losses from multifamily boilers. *Proceedings of the 1988 American Council for an Energy Efficient Economy Summer Study*, Asilomar, California, 1988.
5. Diamond RC. Building managers: hidden actors in multifamily energy conservation. *Home Energy*, Vol. 5, No. 2, 1988.
6. Layne LL, Kempton W, Behrens A, Diamond RC, Fels M, Reynolds C. Design criteria for a consumer energy report: a pilot field study. PU/CEES Report No. 220, Princeton University, 1988.
7. Diamond RC. Enerplex revisited: a post-occupancy evaluation. PU/CEES Report No. 222, 1988.
8. Kula HG, Feustel HE. Review of wind pressure distribution as input data for infiltration models. Lawrence Berkeley Laboratory Report LBL-23886, 1988.
9. Feustel HE, Kendon VM. Infiltration models for multicellular structures: a literature review. Lawrence Berkeley Laboratory Report LBL-17588, 1985.
10. Feustel HE, Scartezini JL. (draft) Development and validation of a simplified multizone infiltration

- model. Lawrence Berkeley Laboratory Report LBL-23036, 1989.
11. Haugen T, Feustel HE. Applications of a simplified model for predicting air flows in multizone structures. Presented at the 8th AIVC Conference on Ventilation Technology-Research and Application, Uberlingen, Federal Republic of Germany. Lawrence Berkeley Laboratory Report LBL-23035, 1988.
 12. Harje DT, Dietz RN, Sherman MH, Bohac DL, D'Ottavio TW, Dickerhoff DJ. Tracer gas measurement systems compared in multifamily and commercial buildings. Princeton University, Center for Energy and Environmental Studies, 1988.
 13. Hubbard LM, Bolker B, Socolow R, Dickerhoff DJ. Radon dynamics in a house alternately by forced air and by electric resistance. Princeton University, Center for Energy and Environmental Studies, 1988.
 14. Yuill GK. Method and apparatus for testing the air tightness of a building using transient pressurization. United States Patent No. 4,510,791, 1985.
 15. Sherman MH, Modera MP. Signal attenuation due to cavity leakage. *Journal of the Acoustical Society of America* 84, December 1988, Lawrence Berkeley Laboratory Report LBL-24289, 1988.
 16. Bonnefous Y. Pulse pressurization - a technique for measuring building air leakage. Ecole Nationale des Travaux Publics de l'Etat, Lyon, France, 1988.
 17. Modera MP, Sherman MH, and Vacheron PF. Pulse pressurization: a technique for measuring building air leakage. September 1987, LBID-1321.
 18. Yoder R, Modera MP, Spolek G. In-situ wood heat monitoring: evaluation of Measured heat output and field efficiency. *ASHRAE Trans.* 94(I): 1988.
 19. Modera MP, Peterson F. Reducing emissions from wood stoves by reducing wood surface area. Lawrence Berkeley Laboratory Report LBL-22910, 1988.

PUBLICATIONS LIST

Indoor Radon

- LBL-24179
 "Parametric Modeling of Temporal Variations in Radon Concentrations in Homes" K.L. Revzan, B.H. Turk, J. Harrison, A.V. Nero, R.G. Sextro. *IEEE Transactions on Nuclear Science*, vol. 35, no. 1, pp.550-555 (1988).
- LBL-24344
 "Mapping Surficial Radium Content as a Partial Indicator of Radon Concentrations in U.S. Houses," K.L. Revzan, A.V. Nero, R.G. Sextro (1988).
- LBL-24345
 "Appraisal of the U.S. Data on Indoor Radon Concentrations," A.V. Nero, K.L. Revzan, R.G. Sextro (1988).
- LBL-25127
 "Evaluation of Radon Reduction Techniques in Fourteen Basement Houses: Preliminary Results," B.H. Turk, et al. *Proceedings of the 81st Annual Meeting of the Air Pollution Control Association*, Dallas, TX, June 19-24, 1988, Paper No. 88-107.2, APCA, Pittsburgh, PA, May 1988.
- LBL-25292
 "Radon Entry and Control in Seven Homes with Basements," R.G. Sextro, B.H. Turk, J. Harrison, K.L. Revzan, A.V. Nero, (1988).
- LBL-25762
 "Predicting the Rate of Radon-222 Entry from Soil into the Basement of a Dwelling due to Pressure-Driven Air Flow," W.W. Nazaroff (1988).
- LBL-25910
 "Intensive Radon Mitigation Research: Lessons Learned," B.H. Turk, R.J. Prill, R.G. Sextro, J. Harrison (1988).

Indoor Organic Chemistry

- LBL-25465
 "Evaluation of Soil-Gas Transport of Organic Chemicals into Residential Buildings: Final Report," A.T. Hodgson, K. Garbesi, R.G. Sextro, J.M. Daisey, (1988).
- LBL-24964
 "Efficiencies of Portable Air Cleaners for Removal of Nitrogen Dioxide and Volatile Organic Compounds," J.M. Daisey,

A.T. Hodgson, *Proceedings of the 81st Annual Meeting of the Air Pollution Control Association*, Paper No. 88-111.4, Dallas, TX (1988).

- LBL-25519
 "Experiments and Modeling of the Soil-Gas transport of Volatile Organic Compounds into a Residential Basement," K. Garbesi, (1988).

Indoor Air Quality and Controls

- LBL-22315
 "Indoor Air Quality and Ventilation Measurements in 38 Pacific Northwest Commercial Buildings Volume 1: Measurement Results and Interpretation, and Volume 2" B.H. Turk, et al. (1988).
- LBL-23135
 "Commercial Building Ventilation Rates and Particle Concentration," B.H. Turk, et al. (1988).
- LBL-23451
 "Exhaust-Air Heat Pump Study: Experimental Results and Update of Regional Assessment for the Pacific Northwest," P.H. Wallman, W.J. Fisk, D.T. Grimsrud, (1988).
- LBL-23979
 "Pacific Northwest Existing Home Indoor Air Quality Survey and Weatherization Sensitivity Study," B.H. Turk, et al. (1988).
- LBL-25614
 "Commercial Building Ventilation measurements Using Multiple Tracer Gases," W.J. Fisk, R.J. Prill, O. Seppanen, (1988).
- LBL-25718
 "The Impact of Gas Furnace Operation in Radon Concentrations in Residences: A Literature Survey," D.T. Grimsrud, D.M. Odenwalder, (1988).

Indoor Exposure Assessment

- LBL-22473
 "Potential Risks from Exposure to Organic Compounds in Indoor Air," J. McCann, L. Horn, J. Girman, A.V. Nero, (1988).

ENERGY ANALYSIS PROGRAM*

INTRODUCTION

The Energy Analysis Program continues to be involved in wide range of topics relating to the energy system of the United States and numerous other countries. Our interest in energy use and conservation in buildings has remained high, with increasing attention being devoted to studies of commercial buildings. The appliance standards continues to be the leading energy policy analysis activity of the Program. A long-term commitment to characterizing and understanding measured data of energy use in buildings continues. Interest in electric utility issues, with particular emphasis on demand-side activities and programs, continues high. New interest in competition among electricity generation options for utilities complements the demand-side analyses.

The involvement in international energy studies has increased from previously high levels, with no waning in the commitment to the detailed analysis of factors affecting energy use by end-use. Building energy policy studies in the countries of the Association of South East Asian Nations continue to combine the Program skills in international studies, building energy analysis, and policy studies. An increased involvement in China has been of particular note during the past year.

The environmental initiatives of the previous year saw some important results, as analyses of effects of climate change on vegetation in California and habitat change and species extinction were completed. These efforts indicate success in the effort to significantly broaden the interests of the Program.

A new and potentially critical theme emerged and took hold in the energy and environmental communities during the past year: the potential for global warming. The Program has become involved in a variety of

initiatives and analyses relating to this important topic. Data on energy demand growth in developing countries were analyzed in greater depth than previously in order to support the efforts of the Environmental Protection Agency (EPA) to understand measures to stabilize the atmosphere. Data on electricity use in developing countries were assembled to support longer-term efforts by the U.S. Department of Energy to assess the impact of electricity use in developing countries on global climate change. Studies of effects of increased temperature levels on selected vegetation types were initiated for the EPA. Numerous additional projects were designed to deal with key issues relating to global climate change, including a number of efforts with the Peoples Republic of China. Some or many of these are likely to be carried out over the next several years.

The year saw few major new problems in the energy economies of nations, with energy prices remaining relatively low and supplies in ample quantities. As a result, energy continued to play a small role in the national political scene. Nonetheless, the energy policy community continued to take note of the fact that low oil prices will not last forever, and possibly not even for another decade. There has been growing concern about an energy efficiency "plateau," resulting from low energy prices and reduced incentives to continue to improve the energy performance of economies. The advent of much more broad-based concerns about global warming has raised the recognition of the importance of long-term energy issues, even while the current situation appears manageable. It is in this broader context that new areas for energy analysis are likely to develop in the Program over the coming years.

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems, Building Services, and Building Equipment Divisions, the Office of the Assistant Secretary for Environment, Safety, and Health, the Office of Policy, Planning and Analysis, of the U.S. Department of Energy; the U.S. Department of Housing and Urban Development under an Interagency Agreement (IAA-H-87-59); the Agency for International Development; the National Science Foundation under Interagency Agreement No. BSR-8717168; the NASA Earth Sciences Division (UPN-677-80-06-05); the Environmental Protection Agency under Interagency Agreement No. DW89933219-01-0; the Residential/Commercial Technology Analysis Division of the Gas Research Institute under GRI Contract No. 5085-800-1318; the Electric Power Research Institute; through the U.S. Department of Energy, under Contract No. DE-AC03-76SF00098.

Utility Accounting in Public Housing

R. L. Ritschard and K. M. Greely

Public housing currently provides shelter and energy for over 3.4 million low-income tenants. Annual energy costs to the federal government for the public housing sector now exceed \$1 billion. Preliminary studies indicate savings as high as 50% could be realized by improving the energy efficiency of the public housing building stock. These savings have not been realized, partly because local public housing agencies lack relevant energy-related information.

We have developed a utility accounting microcomputer program (based on Lotus 1-2-3® spreadsheets) that allows local housing agencies to track use electricity, gas, oil, other fuels, water, and sewer easily and accurately within individual housing projects. After a user enters monthly utility usage and costs into the program, it will adjust utility usage and costs to calendar months and convert consumption to common units (e.g., therms or cubic feet of gas and kWh of electricity to Btus of energy); weather-correct energy usage to that which would have occurred in a year having typical weather; compare each year's consumption and costs to previous years; and compare the consumption per unit-month to that in typical public housing apartments or privately-owned apartments having similar climate and building characteristics. The software helps produce executive summaries and other tables and graphs (see Figure) for tracking utility usage and costs across different years. The program also combines for analysis utility data for all projects within a public housing agency, calculates the allowable utility expense levels, and prepares two important annual reporting forms required by the U.S. Department of Housing and Urban Development (HUD). The output of the program can be used to verify proper rate payment, identify excessive

energy use at given projects or buildings, and determine whether savings from previous energy retrofits have persisted over time. The software can also be used by local public housing agencies and by HUD to explore opportunities for reducing utility bills and to locate buildings and equipment requiring maintenance. We expect the program and documentation to be available by the end of 1988. These will be widely disseminated to local public housing agencies through the HUD User Network, which reaches more than 2600 U.S. housing agencies.

Energy Management Practices in Public Housing

E. Vine

To balance their budgets, U.S. public housing authorities (PHAs) must spend less energy. We have evaluated successful energy management practices conducted by U.S. public housing authorities. The study was undertaken to help other housing authorities learn how to manage their energy use. Housing authorities were selected primarily through interviews with U.S. Department of Housing and Urban Development (HUD) headquarters and regional offices; PHAs actively trying to manage their energy use were potential candidates for a mail survey.

An energy management survey was sent to 49 PHAs, yielding an 84% response rate. Topics addressed included energy actions, energy information, key energy actors, energy audits, program participation, financing and information sources, site description, energy management, maintenance, tenant involvement, type of metering, appliance purchasing criteria, energy use in 1980 and 1987, energy conservation measures installed, problems in managing energy, and problems in installing energy conservation measures.

We present below selected preliminary results from this study: all PHAs reported that they had saved energy since 1980; all PHAs had conducted energy audits; most PHAs (80%) had prepared an energy management accounting report; about 50% of the PHAs used in-house computers for tracking energy and cost data; about 40% of the PHAs had prepared a written energy plan for controlling energy costs, and 80% of these were currently using the plan; almost all PHAs had a preventative maintenance program; estimated average energy savings from retrofits was reported to be 21%; and the most effective energy conservation measures were insulation, window replacement, boiler replacement, and lighting conversions.

In FY 1989, we will continue analyzing these data, using multivariate statistical analysis to group these factors that determine successful energy management. We will also test several hypotheses concerning organizational change as it affects energy management.




Figure. Sample energy computation produced by utility accounting program: annual utility costs per available unit. (XBL-891-159)

Energy Requirements for Multifamily Buildings

R. L. Ritschard and Y. J. Huang

Over the past few years, multifamily buildings have been the most rapidly growing residential sector. As a result, multifamily housing has become an important sector of the energy economy.

LBL has contracted with the Gas Research Institute (GRI) to use the DOE-2.1C computer program to develop a comprehensive data base of hourly heating and cooling loads for prototypical multifamily buildings. This data base, covering 16 building types in 15 U.S. cities, reflects regional variations in climate, building construction and insulation practices, and represents the general population of multifamily buildings. Our major research goal is to provide GRI and its contractors with a reference set of building loads for use in planning and analyzing R&D programs in gas technology. The results also provide a general reference set of multifamily energy requirements for use by energy analysts. The full data base, which includes hourly heating and cooling loads (sensible and latent), domestic hot water loads, and electric consumption for each apartment unit and for the total building, will be available as part of this project.¹

The Figure shows several important features representative of multifamily buildings. First, smaller buildings with 2-4 units usually have higher energy requirements per square foot than do multistoried buildings of five or

more units. Second, energy use in older buildings is generally greater than that of newer ones. Third, in a southern climate like Atlanta, energy use for cooling may be equal to or greater than that for space heating. Finally, heating loads were more affected by improvements in thermal integrity (representative of newer buildings) than were cooling loads.

Due to the size of this data base, an interactive micro-computer program is being developed that will allow users to derive monthly loads, hourly profiles, or loads binned in different formats (e.g., by temperature and humidity ratio or by temperature and hour of day). In the next year, we will begin to use some of these data to assess different multifamily technologies. (See next article for a preliminary comparison of central vs. individual heating, ventilation, and air-conditioning (HVAC) and domestic hot water (DHW) systems in multifamily buildings.)

REFERENCE

1. Ritschard RL, Huang YJ. *Multifamily heating and cooling requirements: assumptions, methods, and summary results*, LBL-25727 draft report, 1988.

A Comparison of Central vs. Individual HVAC and DHW Systems in Multifamily Buildings

S.J. Byrne

Separate energy billing for apartments motivates energy-conscious occupants to control their energy use; such billing is facilitated by individual all-electric heating, ventilating, and air-conditioning (HVAC) systems and domestic hot water (DHW) systems. On the other hand, large, central systems are more efficient, require less maintenance, last longer, and allow more flexibility in choice of energy type. This project provides information on tradeoffs between individual and central HVAC and DHW systems in terms of energy performance and life-cycle costs in two climates, for different types of new multifamily buildings, and under varying operating conditions.

Using the DOE-2.1C computer program to model energy consumption in two typical apartment buildings—one in Chicago, the other in Atlanta—we analyzed two HVAC/DHW configurations per building; a central system consisting of a central chiller and gas-fired boiler which supply four-pipe fan coils (FPFC) and a gas-fired DHW system; and an individual system consisting of packaged terminal air-conditioners (PTAC) and electric water heaters in each apartment. To approximate energy-conserving operation, the individual PTAC system was modeled with and without a setback thermostat. We used each city's average prices for energy and equipment.




Figure. Estimated heating and cooling loads (per square foot) in typical multifamily buildings, Atlanta, GA. (XBL-8810-3732)

For both cities in our analysis, projected annual energy costs were lowest for the central HVAC/DHW system. This was especially true for Chicago because of its higher heating demand and higher price differential between electricity and natural gas. A life-cycle cost comparison of system types showed that in Chicago, multifamily buildings with more than seven apartments (in Atlanta, more than thirteen) should be designed with central HVAC and DHW systems.

Shown below is an example plot of life-cycle cost vs. number of apartments. The intersecting lines at "A" illustrate the point at which the system type should be changed to achieve the lower life-cycle cost of the two alternatives. The line segment shown between points "A" and "B" represents a building with a central chiller sized at the minimum capacity that is commercially available. The life-cycle cost between "A" and "B" is not as low as it would be if it were possible to extend the FPFC line to the left of "B" (by using a smaller chiller), represented by the dashed line. However, the oversized chiller alternative still results in a lower life-cycle cost—within the range "A" to "B"—than the PTAC system.

We plan to continue this work by analyzing the effectiveness of other system configurations, operating strategies, and newly developed metering devices. We will also evaluate other building designs and other cities.




Figure. Life-cycle cost, in Chicago, of central FPFC and individual PTAC with night setback. (XCG-8810-6793)

Analysis of Energy Performance of Unbalanced Single-Pipe Steam Heating Systems in Multifamily Buildings

Y. J. Huang and R. L. Ritschard

For the past two years, LBL has contracted with the Gas Research Institute to analyze the space conditioning loads of prototype multifamily buildings in different U.S. locations (see previous two articles). Roughly 9 million or 40% of all multifamily units are heated by centralized steam or hot water systems, of which nearly half were built before 1940. The great majority of these older units are located in Northeast and Midwest cities, and heated by single-pipe steam systems.

Because this antiquated heating system is prevalent among multifamily buildings, we developed and implemented a simplified simulation model for a single-pipe steam heating system as a modification of the DOE-2.1C program. This model was then used to analyze the energy consumption of older multifamily apartment buildings.

In this simplified model, three new variables were defined: *fill-fraction*, *mass-heat*, and *anticipator-fraction*. A single thermostat located somewhere in the building controls the steam boiler. The amount of heat delivered to each apartment zone varies according to interactions between boiler capacity, radiator size, and the new variables.

Fill-fraction (see Figure) defines the delay between the time the boiler turns on and when the apartment begins receiving heat. This delay is due to the time needed by the boiler to generate enough steam to displace the cold air in the piping and to heat absorption by the piping mass. *Anticipator-fraction* defines the reduction in maximum heat available to a zone as allowed by the anticipator. By shutting off the boiler, an anticipator reduces the heat output from the radiators even though the thermostat may still be asking for heat. *Mass-heat* defines the residual heat stored or released to the zone hourly by the radiator and piping mass depending on changes in the boiler operating time. The graph shows effects of differing fill-fractions on heat supplied to different apartments.

Simulations were done using this model to analyze energy consumption and indoor temperatures of prototypical pre-1940 buildings heated by single-pipe steam systems under various operational strategies. Sensitivity studies showed that mass-heat would cause typical steam systems without anticipators to overheat from 3° to 6°F and would use 15% to 30% more energy than standard forced-air systems. The effects of three different fill-fractions (none, fast, and slow), anticipator-fractions (0, 10, or 20 minutes), and two thermostat locations were also analyzed. Because of differences in their fill-fractions, top- and ground-floor apartments generally have unbalanced




Figure. If a zone's fill-fraction is the same as that for the control zone, the zone receives the same amount of heat (line B in the Figure). If its fill-fraction is greater, the zone will receive heat sooner than the control zone, but the differential disappears as the system part-load-ratio or boiler on-time reaches full load conditions (line A). Conversely, if its fill-fraction is less, the zone receives heat later than the control zone, but the differential again disappears at full-load conditions (line C). The dashed line indicates net heat output into a zone with a slower fill time than the control zone during an hour when ΔPLR is positive and PLR is less than the anticipator-fraction limit. (XBL-8811-3854)

heating and substantially different temperatures. If the thermostat is on the ground floor, the building load is greatly reduced, whereas the top units are underheated.

REFERENCE

1. Huang YJ, Bull JC, Fay JM, and Ritschard RL. *Computer analysis of the energy performance of unbalanced single-pipe steam heating systems in multifamily buildings*, ACEEE 1988 Summer Study on Energy Efficiency in Buildings, Asilomar, CA, 1988.

Estimating Nationwide Conservation Potential From Measured Data

K. Greely, A. Meier, C. Goldman, and J. Harris

Most estimates of regional or nationwide conservation potential have been based on simulated savings derived from engineering models. In contrast, we have developed an approach for estimating conservation potential from measured energy use and have applied this new methodology to two sectors of the U.S. housing stock.¹ Such refined estimates of conservation potential are necessary to accurately assess the extent to which energy conservation has occurred and the amount of savings remaining to be tapped.

Because measured savings have been shown to occur, their use adds certainty to estimates of conservation potential. However, the savings are specific to particular types of retrofits in certain subsectors of the stock. The challenge is to correctly adjust measured savings to compensate for differences between measured projects and the regionwide stock.

The Building Energy Use Compilation and Analysis (BECA) project documents the measured energy performance of new buildings and equipment and the measured energy savings from retrofits. To demonstrate our methodology, we chose two well-documented BECA compilations representing retrofitted multifamily buildings and new, electrically heated, single-family homes.

We first examined the conservation potential of new, electrically heated, single-family homes. We derived savings from construction of efficient new homes by comparing consumption of energy-efficient, electrically heated homes with that of similar "current practice" houses. These savings were combined with estimated construction rates for the next decade to yield a potential energy savings of 0.22 quads per year by 1997 (1 quad = 10^{15} Btu), about 45% of the projected space heating consumption by the new homes. Adjustments were then made to account for differences between new homes in the BECA compilation and the projected stock of new construction, i.e., heating system type, floor area, climate, and energy consumption (see Figure). These adjustments increase the potential energy savings to 0.32 quads per year.

To estimate the conservation potential of existing multifamily buildings in the U.S., we first classified the BECA

BECA-A Extrapolation




Figure. BECA extrapolation of stockwide savings for new, electrically heated houses. Each bar represents the change in the savings estimate caused by each additional adjustment. "REM" refers to the baseline energy use estimates for new, all-electric homes, from LBL's Residential Energy Model. Adjustments for shell characteristics and inside temperature can be performed as better data become available. (XBL-8811-3855)

multifamily buildings into those with "typical" and "intensive" retrofit packages, segmented by key building and heating system types. Savings for each segment were then extrapolated to the entire multifamily stock, using statistically representative information on consumption and building characteristics of the stock. After adjusting for differences in climate and pre-retrofit usage between BECA buildings and the U.S. multifamily stock, we found that if typical retrofits were installed in all U.S. multifamily buildings, it would save about 0.2 quads per year, while intensive retrofits could save about 0.5 quads per year. These results suggest that current energy consumption in the multifamily sector could be reduced by 9-22%.

We conclude that our method more accurately estimates the conservation potential of a sector than do traditional engineering methods because it is based on measured savings from existing buildings. We plan to improve our methodology through additional adjustments and apply our approach to other sectors of the U.S. building stock.

REFERENCE

1. Meier A, Goldman C, Greely K, Harris J. *Estimating conservation potential using BECA data*, LBL-25126, 1988.

Least-Cost Utility Planning

F. Krause, J. P. Harris, M. D. Levine, and A. H. Rosenfeld

In recent years, a growing number of utilities and state regulatory agencies have adopted a new approach to "integrated" resource planning, aimed at providing customers with *least-cost* energy services through the balanced development of both supply-side and demand-side resources. Technology advances and regulatory reforms have opened up new supply-side options, including renovation of older plants, cogeneration, and power purchases from independent producers. On the customer side of the meter, there are equally exciting new approaches. Utilities, often at the urging of regulatory agencies, are testing new ways to meet customer needs for comfort, heat, light, and power with more efficient end-use technologies. Utility and customer costs can also be reduced by shifting some loads off peak. "Least-cost" utility planning (LCUP) also poses new analytic challenges: to reliably quantify demand-side resources in ways that can be compared with conventional supply-side resources; and to develop integrated utility resource plans that balance economic objectives along with environmental and other policy goals.

In response to a Congressional mandate, the U.S. Department of Energy supports a broad R&D program on least-cost utility planning. LBL's role is to help develop and apply new data and analytical tools to assist utilities and state regulatory commissions in pursuing a balanced, least-cost energy strategy. Most of this effort addresses demand-side opportunities for end-use efficiency and load-shaping, e.g.,

- assess demand-side technologies (performance, cost, reliability, etc.)
- review and evaluate demand-side program experience, including effects of these programs on market penetration of new technologies
- develop and refine analytic tools and models for demand-side analysis and integrated resource planning
- apply new data and analysis techniques to utility-specific studies (see Figure)
- other technology-transfer efforts to encourage use of state-of-the-art planning methods.

Future work will continue evaluation of demand-side programs and technology assessments, collaborative studies with states and utilities, and a special focus on innovative strategies such as utility "resource auctions" for demand-side and supply-side resources.




Figure. Graph of Michigan residential electricity use using a conservative "supply curve" to establish technical potential and program scenario. (XCG 881-6508)

Rated vs. Measured Energy Use of Refrigerators

A. K. Meier and K. E. Heinemeier

The energy use of refrigerators is important to both consumers and utilities because they are the largest end use of electricity in most American homes and, together, consume the equivalent electrical output of 25 large power plants. The U.S. Department of Energy (DOE) developed an energy rating procedure for refrigerators. The rated energy consumption was determined through a laboratory test which is the basis for the Energy Guide labels. These labels assist the consumer in selecting the refrigerator with the lowest life-cycle costs, while planning agencies use the energy ratings to forecast electricity demand.

The laboratory test of refrigerator energy use does not attempt to duplicate the actual conditions of a typical refrigerator because they are difficult to determine. Instead, the laboratory test involves measuring the energy use of a refrigerator in a 32°C room, with the door closed, and with no food loads inserted or removed. In spite of these unrealistic assumptions, the energy consumption from the laboratory test has never been carefully compared to field use. In this project, we compared the rated energy use of refrigerators to measured field use.¹

We collected measured refrigerator use from numerous utility studies and other monitoring programs.

The correlation between rated and measured energy use for the 192 units was, on average, excellent (see Figure). However, there was considerable variation among individual refrigerators. This variation was probably due to different operating conditions (especially ambient temperature) and the presence of icemakers, plus random variation in the mechanical performance of individual units.

Monthly energy data were also available for most of the refrigerators. We compared the energy use in the peak and valley months. There was considerable fluctuation in monthly energy use; the maximum and minimum months often differed by more than 30%. These data suggest refrigerators are a greater contributor to the summer electrical peak than previously thought. The results are surprising because most forecasts assume that refrigerators have a nearly constant electrical demand. While the label was quite good at predicting annual energy use, it underpredicted the refrigerator's contribution to the summer peak.

However, for newer (and more efficient) models, the test is less accurate; the rating overpredicted energy use by more than 20% in our sample. This suggests that this type of verification may become even more important in the future.

REFERENCE

1. Meier A, Heinemeier KE. Energy use of residential refrigerators: a comparison of laboratory and field use. *ASHRAE Trans*, 1988; OT-88-14-3.




Figure. A scatterplot of DOE laboratory test ("label") consumption versus the measured annual field consumption. A line of perfect agreement is drawn for reference; units to the right of the line represent those with the label consumption greater than the field consumption. On average, the field consumption was very close to the rating, although individual models show some scatter around the line of agreement. The "columns" of points represent groups of identical refrigerators. (XBL-8810-3619)

Experience with Energy Efficiency Programs for New Buildings

E. Vine and J. Harris

This report evaluates the experience with implementing programs promoting energy efficiency in new residential and commercial construction. This report is one of a series of program experience reports that seek to synthesize current information from both published and unpublished sources to help utilities, state regulatory commissions, and others to identify, design, and manage demand-side programs.

We focused our investigation on nonregulatory programs that are designed to complement—or in some cases substitute for—mandatory energy efficiency requirements in local and state building codes. We evaluated the following types of nonmandatory programs: technology demonstrations and demonstration programs, financial incentive programs (including rebates, conservation rates, reduced hookup fees, reduced rates on loans and loan

qualifications, guaranteed savings, and tax credits), consumer information and marketing programs (including energy rating systems and energy awards), technical information programs (including professional guidelines, design tools, design assistance, and standards-related training, compliance, and quality control), and site and community planning.

In addition to presenting findings for each program category, we summarize general program conclusions, applicable to most of the energy conservation programs reviewed in this report: (1) many different types of nonmandatory programs appeared to be successful in overcoming barriers to promoting energy efficiency in new buildings; (2) no program strategy was clearly dominant; (3) few program evaluation studies exist, resulting in a paucity of quantitative data on program effectiveness, especially beyond the pilot or demonstration stages; (4) only a few programs were designed as part of a long-term strategy to promote energy-efficient construction; (5) successful programs were often characterized by intervention early in the design and planning process in order to minimize delays in the project design, approval, financing, and construction process; (6) education, training, and design assistance activities were especially important; (7) most programs focused on the early design stages of a program without addressing issues normally arising later in the program (e.g., details of construction, quality control, building commissioning, and operations and maintenance); (8) utility rate designs were typically not used as conscious reinforcement for promoting energy-efficient construction; (9) many programs were considered successful for both energy and nonenergy reasons (e.g., improved thermal comfort, creation of new markets, and improved customer relations); (10) nonmandatory programs can reinforce and pave the way for codes; and (11) most of these programs can be easily implemented in other areas around the country and in other countries.

For the design and implementation of energy conservation programs for new buildings, the evidence suggests that a comprehensive and long-term perspective is needed to design and choose programs. Long-term goals and objectives of programs need to be made explicit in order to provide program guidance. A well-integrated package of programs should contain the following program strategies: design assistance, financial incentives, quality control, training and education of design professionals and the building community, simple and easy-to-use design tools, rating and labeling of buildings, effective marketing and promotion, energy awards for buildings and for design and building professionals, building commissioning, operations and maintenance activities, process and impact evaluation, monitoring, and feedback activities.

Implementation of energy efficiency programs is not an easy task, and there have been many failures at various stages in the implementation process. The challenge is to design and implement a program that meets the needs of the target audiences as well as promote energy-efficient construction.

Analysis of Commercial Electric End-Use Data

H. Akbari, I. Turiel, J. Eto, and L. Rainer

Direct metering is the most expensive method for gathering reliable load shape data on electrical end uses. The goal of this project, which was jointly sponsored by the Southern California Edison Company (SCE) and the California Energy Commission, is to investigate a less expensive alternative to metering using 15-minute interval whole-building electric loads. Successful development of such an alternative could reduce the cost of obtaining high quality load shape data by several orders of magnitude. Given the stakes involved in electric utility resource planning, the returns promise to be large.

Our approach is to conduct detailed analyses of SCE data on commercial building characteristics, energy use, and whole-building load shapes, and in conjunction with other data, to develop, test, and apply an integrated method to estimate end-use load shapes (LSs) and energy utilization indices (EUIs). The primary data for the project are on-site surveys, load research data (LRD), and available sub-metered energy use data. Secondary data include other EUI and LS studies, commercial sector mail survey data, and typical and historic southern California weather data.

The project consists of two major parts: the first concerns the development of prototypical buildings and the

performance of energy use simulations that lead to preliminary estimates of LSs and EUIs. This part relies primarily on survey data, which are complemented by results from previous EUI and LS studies. The second part entails selective modification of the initial estimates using whole building load research and historical weather data. The methodology is illustrated schematically in the Figure.

Development of a Simplified Tool to Calculate Commercial Sector EUIs

I. Turiel and B. Lebot

This project, supported by the Electric Power Research Institute (EPRI), developed a simplified tool to calculate commercial sector energy utilization indices (EUIs). In EPRI's Commercial Sector End-Use Planning System (COMMEND) model, EUI values are one of the three key market facts. Together with floor stock and market share data, EUI values allow the construction of market profiles that depict energy use patterns at the end-use level. These profiles are important for analysis of the current energy market and they provide a starting point for end-use forecasting. The computer software developed in this project allows utilities to calculate EUIs specific to their




Figure. Integrated LS and EUI Estimation Methodology: The methodology has four major steps: 1) development of initial prototypical LSs and EUIs, using the on-site survey and mail data. Two utility programs, Non-HVAC EUI/LS and DOE-2 Input Generator (NELDIG) (estimates LSs and annual EUIs for non-HVAC end uses and prepares prototypical building input data for DOE-2 simulations) and initial profile generator, *InitProfile* (combines DOE-2 and NELDIG outputs to prepare initial estimates of hourly end-use loads), are used for this purpose; 2) construction of average hourly loads for prototype buildings using the monthly billing data and load research data. Three programs are developed for this second process: *BillAvg* (computes the average utility bills by building type from the on-site survey billing data), *LoadAvg* (computes the average hourly whole-building loads by building type from LRD), and *LoadAdj* (computes the average hourly whole-building load as normalized by average utility bills); 3) reconciliation of the initial end-use data from the first step with the average hourly loads from the second step using the End-use Disaggregation Algorithm (EDA); and 4) summarizing the reconciled hourly end-use data in the form of representative monthly load shapes, using a program called *LoadShaper*. (XBL-8811-3881)

service area without undertaking extensive studies such as a conditional demand analysis or end-use metering.

Two approaches were used to develop the EUI specifications for each end-use and business type combination studied. First, previously published EUI studies for the commercial sector were analyzed. An averaging procedure of selected studies yielded the non-weather-sensitive EUIs. Second, the 1979 Nonresidential Building Energy Consumption Survey data set was used to estimate weather-sensitive EUIs. A conditional demand analysis performed with this data set obtained heating and cooling EUIs as a function of building characteristics, operating conditions, and climate parameters.

The end products of this project are a spreadsheet program, a users guide, and an EPRI report.¹ The spreadsheet program, developed with the Lotus 123® software, calculates a matrix of EUIs for eight electrical end-uses for eleven building types. The Figure shows the flow diagram describing how the spreadsheet works. Any utility using this tool can either provide input data specific to the commercial buildings in their service territory or, in the absence of such information, use the default data provided in the software for their census region. The program also allows the user to plot bar graphs of EUIs by building types. The report provides comparisons between the EUI predictions of the program with those EUIs estimated in several electric utilities' conditional demand studies.

The spreadsheet will be used nationwide by utilities already using the COMMEND model. Several improvements have been proposed to the existing program, such as adding sensitivities of the EUIs to new parameters and adding algorithms to calculate EUIs for natural gas use.

REFERENCE

1. Turiel I, Lebot B. *Development of a simplified tool to calculate commercial sector EUIs*, draft report to EPRI, 1988.

Comparative Assessment of the DSM Plans of Four New York Utilities

C. Goldman and E. Kahn

In April 1988, New York's seven investor-owned utilities filed their first long-term Demand Side Management (DSM) Plans in response to a Public Service Commission (PSC) order. The PSC invited LBL researchers in DOE's Least Cost Utility Planning project to assist Commission staff in reviewing the utility's long-term demand-side resource plans. The principal research objective was to identify the most important least cost utility issues facing public utility commissions based on actual experience gained from working with commission staff.

Comparing the DSM plans of four utilities—Consolidated Edison, Niagara Mohawk, New York State Electric and Gas, and Rochester Gas and Electric—we assessed the potential impact of DSM programs among utilities by the year 2000 (Table). The initial DSM plans of all four utilities are modest in terms of the contribution of DSM options to reducing total system peak load in the year 2000 (3-7%). Expected savings from DSM programs range between 0-50% of the peak load growth projected for that period. However, we believe that the key indicator is "utility commitment," which reflects the utilities' stated willingness or actual commitment of dollars to implement new large-scale DSM programs in the near-term. Several utilities believe that the uncertainties associated with DSM programs are too high to justify major investments.

All four utilities identify commercial lighting as an end-use with cost-effective DSM options. Of the four utilities, only Con Edison identifies other DSM options applicable to commercial buildings (e.g., motors, thermal cool storage, efficient air conditioning replacement, curtailable electric service). In the residential sector, the summer




Figure. Flow diagram describing how the spreadsheet works. (XBL-8810-3741)

Table. Potential impact of demand-side management programs

	1987 Peak Load (MW)	Projected Load Growth to 2000 without DSM	DSM Impact Indicators			Utility Commitment ^a
			Peak Load Reduction due to DSM (MW)	% of Peak Load Growth	% of Peak Load	
Con Ed	9400	2092	742	36%	6.9%	A
RG&E	1205	255	0-105	0-41%	0-7.5%	P
NYSEG	2477	769	116	15%	3.6%	A
NiMo	5800	500	0-250	0-50%	0-4.0%	P

Con Ed and RG&E are summer peaking; NYSEG and NiMo are winter peaking utilities.

^a P = planned; A = action on some programs

peaking utilities (Con Ed and RG&E) found that replacing existing room air conditioners with high-efficiency equipment and peak clipping measures (e.g., direct control of room air conditioners and pool motors) were cost-effective DSM options. Winter-peaking utilities (NYSEG and NiMo) favored load-shifting DSM options (e.g., direct control of water heating and residential thermal storage).

We also identified the most important data and analysis needs for regulators trying to evaluate DSM plans: improved stock characterization, explicit treatment of Qualifying Facilities (QFs) in resource mix, comprehensive assessment of the achievable potential for DSM options for all end uses and sectors, research on customer response and other information relevant to DSM options (load shape impacts, incentives required to achieve certain penetration rates), and projections of avoided costs. More reliable data are available on DSM options for the residential sector than for the commercial and industrial sectors.

Our analysis also suggests that the PSC and utilities must resolve several thorny analytical and methodological problems that hinder DSM program implementation. For example, the utilities used varying economic tests for initial screening and final selection of DSM options. The PSC may need to develop a more explicit treatment of the role of various economic tests in DSM program evaluation. In addition, the utilities were particularly concerned that DSM programs would lead to substantial near-term revenue losses. Thus, the timing of DSM programs is a particularly critical issue: programs and incentives should be selected that meet the twin goals of minimizing short-run negative rate impacts while preparing for long-run expansion of DSM programs. Finally, because New York utilities are members of a centrally-dispatched power pool, DSM options should be evaluated from the perspective of optimizing benefits for the New York Power Pool. Several utilities are assessing the costs and benefits of DSM options from their individual perspectives only; for winter-peaking utilities, this approach understates the

benefits of DSM measures that could reduce the Power Pool's summer peak load.

REFERENCE

1. Goldman C, Kahn E. *Review of the Demand-Side Management Plans of Four New York Utilities*, LBL-26374, 1988.

Energy Use and Efficiency of Electronic Office Equipment

J. P. Harris

Electronic office equipment, including personal computers (PCs), minicomputers, printers, copiers, fax machines, etc., represents a fast-growing but poorly understood component of the "other" end-use in commercial buildings. This study attempts to establish office electronics as a distinct end-use, by characterizing electricity usage, trends, and efficiency opportunities. We can think of this equipment as the office equivalent to industrial process equipment; in office buildings the main "process" is the production, use, storage, and transmission of information. Except for space conditioning and lighting, information processing is the major user of energy in office buildings (up to 20% of total daytime electricity use).

Typical daytime loads from office equipment (10-20 W/m²) are about equal to lighting loads in a well-designed new office. We measured actual power use for selected office equipment, and found that it was only 20-40% of nameplate ratings. Thus, estimates of energy use

or cooling loads based on nameplate ratings are overstated. Power use varies widely for office equipment with similar functions. In particular, desktop PCs use about ten times the power of equivalent laptop models. It is often the input/output (I/O) devices (terminals, printers, scanners, fax), rather than computers themselves, that are the major power users. Future load growth depends on many market and technical factors. U.S. office equipment electricity use in 1995 could range from 130 TWh ("market saturation," current technology, expanded use of computerized printing), to about 25 TWh if today's most efficient hardware and operating systems become the norm (see Figure).

There is significant potential for improved energy efficiency in both hardware and software. Several policy options could accelerate market and technical trends (e.g., miniaturization, portability). Examples include energy efficiency labeling of hardware and software, and creative use

of government purchasing power. In the longer term, better-integrated information management systems may finally introduce the "paperless office," with major impacts on both energy use and office productivity.

REFERENCE

1. Norford L, Rabl A, Harris J, Roturier J. *Electronic office equipment: The impact of market trends and technology on end-use demand for electricity*. LBL-25558, 1988. (Forthcoming 1989, Proceedings of the Vattenfall Electricity Congress, Gothenberg, Sweden.)

EMCS for Utility/Customer Interface

H. Akbari, M. Goralka, and K. Heinemeier




Figure. Alternative load growth scenarios for office electronic equipment in the U.S. The 1988 estimate is based on 25 million "screens" serving 60 million white-collar workers, averaging 200 W/user (equivalent to a PC workstation or shared mini- or mainframe, plus screen and peripherals) and 5000 hours/year operation. The 1995(a) scenario assumes today's hardware efficiencies and usage, with full "market saturation" (65 million screens). The 1995(b) scenario shows the impact of new information services, e.g., increased I/O using computer-generated or -scanned hard-copy. Power requirements for I/O increase from 50 to 200 W/user, nearly doubling total energy use. The 1995(c) scenario ("technology potential") assumes universal adoption of today's most efficient hardware and operating systems. This reduces power from 150 to 15 W/user for computers, and from 200 to 100 W/user for I/O. Better control of idle-time would reduce average operating time to 3000 hours/year, bringing total U.S. electricity use for office electronics back to today's 25 TWh. (XBL-8810-3602)

Energy Management and Control Systems (EMCS) are being installed at an accelerating rate in new and retrofitted commercial buildings. We have explored the capabilities of EMCS for use as an interface between electric utilities and their customers for both real-time pricing and end-use data monitoring of commercial buildings. Our research, sponsored by the Pacific Gas and Electric Company, indicates that currently-sold EMCSs are intelligent enough to perform these applications, but lack the necessary software communication features and installed metering capacity for any large-scale effort with real-time pricing or data monitoring.

We have demonstrated the feasibility of the above goals by 1) performing a detailed review of previous LBL studies that demonstrate the concept of remotely collecting data from EMCSs, and 2) conducting a real-time pricing simulation.¹ From these demonstration projects, we developed specifications recommending the necessary EMCS system hardware and software features which could be incorporated into current EMCS.

Typical EMCSs sold today are fundamentally different from machines sold just four to five years ago. A typical large EMCS (see Figure) has three components: a local control module (LCM) which is directly wired to the sensors and relays, a field processing unit (FPU) which makes control decisions, and a personal computer interface. An important feature of the typical system is its modularity. The most powerful EMCS installations have all three components, but often only a FPU or a LCM is necessary for more limited applications such as controlling a single air conditioning unit. Thus, each of these components is capable of stand-alone operation without the other, higher level, components.

The utility's main interest in commercial monitoring is to obtain end-use data for forecasting commercial energy consumption and estimating how this consumption can be predictively modified to decrease the utility's net cost of




Figure. Architecture of a typical large EMCS. A typical large EMCS has three components: a local control module (LCM), a field processing unit (FPU), and a personal computer interface. (XBL-8810-8581)

services or enhance revenues. Performing this analysis requires end-use intensities and load-shape data for use in utility planning. Utilities use these data in their long- and short-term energy and peak demand forecasts, conservation and load management assessments, marketing assessments of the best end-uses to sell, capacity planning for transmission and distribution, cost-of-service/rate design for profitable end-uses, and modeling the effects of fuel substitution.

EMCSs could easily provide the information required for these analyses. Some modifications of the current systems would be required, however. If these modifications can be accomplished, a wealth of information would be available to a utility. A significant fraction of all commercial buildings already have EMCSs installed to control their HVAC equipment. The data collection process would involve a communications link, where either the EMCS automatically downloads data to a utility over a phone modem, or a utility calls up the EMCS for interrogation of the data.

The use of EMCSs in commercial buildings under real-time pricing would enable customers to adjust their demand automatically in response to fluctuating prices. The process would involve establishing a communications link between the utility and the customer's EMCS. Once a day, the utility would send an hourly price schedule to the building's EMCS. The EMCS would then use the price data to automatically instigate control strategies intended to minimize energy consumption during hours

with high prices. In this way, the customer can minimize energy bills with a minimum effort and the utility will see a reduced demand during peak periods and other times when power is most expensive to produce.

REFERENCE

1. Heinemeier KE, Akbari H. Capabilities of in-place energy management systems for remote monitoring of building energy performance: case studies. *ASHRAE Trans.*, 1987; NT-87-28-1, 93(2):2321-2336.

Field Measurement of Heat Island Data

H. Akbari, L. Rainer, and H. Taha

Although the existence of urban heat islands has been known for many years, actual measured microclimate data to quantify this effect has been limited. There has been little simultaneous multiple-site measurement of microclimatic data over long time periods. These long-term data are required to validate and improve the numerical models for predicting the impact of heat islands on cooling energy use.

Two major field studies, one in Davis, CA and one in Sacramento, CA, were carried out by the "Heat Island Project" at LBL. Both studies have yielded valuable heat island data.

In the Davis project, a well-defined tree canopy (i.e., an orchard) surrounded by open space was transected with eleven weather stations that measured dry-bulb and dew-point temperatures, wind speed, and wind direction at 1.5m above the ground. Data were collected at fifteen-minute intervals for two weeks starting on October 12, 1986. The main objective was to quantify the effects of vegetative canopies on micro-climates and in particular their creation of an oasis effect during daytime. Data were studied to analyze the variation of air temperature and wind speed within the canopy. Figure 1 shows a typical daytime air temperature traverse across the orchard. On average, the canopy was about 2°C cooler than the open fields.

Whereas the Davis project dealt with microclimatic changes within a single orchard with a grid spacing of ~100 m, the Sacramento project attempted to extend this measurement to a whole city with a grid spacing of ~1 km. In this study, the weather stations were distributed throughout Sacramento in 15 residential locations with a

*This work was supported in part by a grant from University-wide Energy Research Group, University of California, Berkeley.




Figure 1. The average effect of trees on the drybulb temperature at 3 PM during October 1986 in Davis, CA. (XBL-8811-3895)

variety of tree cover. Half-hourly data were recorded for each of these sites from July 16 through September 19, 1987. Additional weather data, including cloud cover, were collected using a computer weather monitoring network located at four local airports.

The Sacramento data have been analyzed in two ways. First, they were analyzed to quantify the effect of local characteristics such as tree cover and skyview factor on the local climate. Regression equations were then developed relating inter-site temperature differences to these local characteristics and daily weather factors such as temperature, wind speed, and wind direction. Secondly, the data were analyzed to extract an overall picture of the summer heat island and its changes throughout the day. As an example, Figure 2 shows the temperature contour on a hot August day. The temperature varies from 35°C downtown to 30°C in some of the outlying neighborhoods. Further analysis of the data shows that heavy tree cover can reduce the effect of urban heat islands by as much as 3°C.




Figure 2. Heat island temperature contours at 4 PM on August 5, 1987 in Sacramento, CA. (XBL-8812-4076)

Analysis of Residential End-Use Load Shapes

H. Ruderman, J. H. Eto, K. E. Heinemeier, A. Golan, and D. Wood

Over the past ten years, the California Energy Commission (CEC) has developed models to forecast electricity demand and peak loads in the state.¹ The models use individual end-use daily load shapes to calculate hourly loads on peak days for both weather-sensitive and non-weather-sensitive end uses. Our project, sponsored by the CEC, analyzes available metered data on end-use load shapes to refine the current estimates used in the CEC peak demand models. Initial emphasis has been placed on residential loads because of data availability; future work will concentrate on non-residential end uses. The project will also assist the Commission in laying the groundwork for transforming their peak demand models into models that forecast hourly loads throughout the year, relying on LBL's experience in constructing and validating its Residential Hourly and Peak Load Model.²

Since the project began in the summer of 1987, we have collected metered residential end-use data from the three largest electric utilities in California. End uses were

classified as conditioning (space heating and cooling) or non-conditioning (water heating, cooking, refrigeration, etc.); each group was analyzed by different techniques. For non-conditioning end uses, we aggregated the metered data into monthly and seasonal energy consumption profiles and then constructed daily load profiles for weekdays and weekend days for each season (see Figure). For conditioning end uses, we constructed matrices showing average load as a function of time of day and of outdoor temperature (or temperature-humidity index). We devised a new fitting procedure to describe the average load as a function of time and temperature suitable for use in residential load models. To our knowledge, ours is the first analytic expression developed to describe the behavior of space conditioning equipment. A final report to the CEC describing data sources, analytic methodology, and results will be written in FY 1990. Revised load shapes will be incorporated in the LBL Residential Hourly and Peak Load Model.

REFERENCES

1. California Energy Commission. *California energy demand: 1985-2005, Volume II: Electricity demand forecasting methods*, CEC Publication No. P300-87-004, Sacramento, CA, 1987.
2. Verzhbinsky G, Ruderman H, Levine, MD. *The residential hourly and peak load model: description and validation*, LBL-18698, 1986.




Figure. Average daily and monthly load shapes for water heaters. (XBL-8810-3589)

Analysis of Federal Appliance Efficiency Standards

H. Ruderman, P. Chan, P. Cunliffe, A. Heydari, J. Hobart, J. Koomey, B. Lebot, M. D. Levine, J. E. McMahon, T. Springer, S. Stoft, I. Turiel, and D. Wood

In March 1987, Congress passed and the President signed the National Appliance Energy Conservation Act (NAECA)¹ establishing efficiency standards for household appliances. The legislation provides for periodic update of the standards by the Department of Energy. LBL is responsible for an integrated analysis of the impacts of these appliance efficiency standards. The research involves a detailed assessment of the impacts on consumers, manufacturers, electric utilities, and on the nation as a whole. Work during FY 1988 focused on providing analytic support for DOE's rulemaking on two groups of products: (1) refrigerators, freezers, small gas furnaces, and television sets; and (2) dishwashers, clothes washers, and clothes dryers.

Our analysis has four major components: (1) an Engineering Analysis to quantify the efficiency improvements of various design options and their costs; (2) a Consumer Analysis to project the energy use, shipments, purchase price, and operating costs of more efficient products; (3) a Manufacturer Analysis to determine impacts on the appliance manufacturing industry; and (4) an Impact Analysis to examine the impacts of standards on various groups. The latter analysis includes changes in consumer life-cycle costs, competition within the manufacturing industry, fuel savings and reduced need for new generating capacity by electric utilities, an assessment of environmental impacts, energy savings by fuel type, and the net present benefit of standards to the nation. The Figure shows how the parts of the analysis are interrelated and how they fulfill legislative requirements for evaluating the impacts of standards. The following three articles provide more detailed information on how the Engineering, Consumer, and Manufacturer Analyses are performed.

The analysis of standards on refrigerators, freezers, small gas furnaces, and television sets was completed in the first quarter of FY 1988. We documented the methodology and results of the analysis in the Technical Support Document² published by DOE with their Notice of Proposed Rulemaking. Major improvements were made in the utility and environmental parts of the Impact Analysis for refrigerators and freezers. The utility analysis evaluated avoided utility costs, lost revenues, and generating capacity deferrals that would result from imposition of standards. In addition to estimating the reduction of power plant emissions, the environmental assessment examined changes in chlorofluorocarbon use in these appliances. We also focused on the competition between electricity and gas in the small furnace market.

To analyze the impacts of possible amended standards for clothes washers, clothes dryers, and dishwashers, we collected data on the cost and efficiency of design options




Figure. Satisfaction of legislative requirements through the analysis process. (XBL 856-8918)

for improved efficiency of these products. We modified the LBL Residential Energy Model to take into account changes in water heater energy consumption when the efficiency of clothes washers and dishwashers is increased. Analysis of these three products will continue in the first quarter of FY 1989, emphasizing the estimated reduction in water use and the cost of water and waste treatment that would occur if certain design options were employed.

REFERENCES

1. *National Appliance Energy Conservation Act*, Public Law 100-12, March 17, 1987.
2. U.S. Department of Energy, Assistant Secretary for Conservation and Renewable Energy, Building Equipment Division, *Technical support document: energy conservation standards for consumer products: refrigerators, furnaces, and television sets*, DOE/CE-0239, report prepared by Lawrence Berkeley Laboratory, November 1988.

Engineering Analyses of Appliance Efficiency Improvements

I. Turiel, A. Heydari, and B. Lebot

The economic impacts of appliance efficiency standards depend largely on the relation between cost and energy consumption of a consumer product. Our engineering analysis seeks primarily to identify this cost-consumption relation for selected appliances. In FY 1988, we analyzed refrigerators, freezers, televisions, small gas furnaces, dishwashers, clothes washers, and clothes dryers,

addressing two legislative requirements: to estimate the maximum technologically feasible efficiency levels that are possible and to ensure that new designs do not lessen consumer utility.

Our analysis selects appliance classes, baseline units, and design options, determines maximum technologically feasible designs and the efficiency improvement provided by each option, develops cost estimates, and generates price-efficiency relationships. We have studied 10 classes of refrigerators and freezers, as well as two classes each of televisions, small gas furnaces, dishwashers, clothes washers, and dryers. Many design options were studied for each product class¹. For refrigerators and freezers, a computer simulation model was used to estimate energy use under different design options. We also evaluated the energy consumption impact caused by using only those design options that did not increase the baseline amounts of chlorofluorocarbons (CFCs).

We developed energy consumption data for other products by using test data from various sources, manufacturer-provided data, and engineering calculations. Manufacturer costs were obtained from data submitted by manufacturers and from component suppliers. These costs were disaggregated into labor, materials, purchased parts, tooling and capital costs, and shipping and packaging.

The results of the simulation analyses for a top-mount automatic-defrost refrigerator-freezer are shown in the Figure. Simulations were performed under two scenarios. The cross-hatched bars in the Figure show energy use for design options which allow the amount of CFC-11 to increase above that in the baseline case unit. The white bars exclude options 2, 6, 9, and 10, which require increases in CFC-11.

In FY 1989, we plan to complete the engineering analysis for dishwashers, clothes washers, and clothes dryers. We will also evaluate other design options such as higher spin rpm for clothes washers, simultaneously considering washers and dryers in order to compute benefits. We will also respond to public comments on Notices of Proposed Rulemaking.




Figure. Energy use of a top-mounted auto defrost refrigerator-freezer for various design options (adjusted volume = 20.8 cu.ft). (XBL-8810-3614)

REFERENCE

1. Turiel I. *Design options for energy efficiency improvement of residential appliances*, LBL-22372, 1986.

Assessment of Impacts of Appliance Standards on Manufacturers

S. Stoft, P. Cunliffe, and J. Hobart

The Manufacturer Analysis determines the impact of appliance standards on the the profitability and competitiveness of the various appliance manufacturing industries. It also provides estimates of retail prices that are used by the Residential Energy Model (LBL-REM) and the life-cycle cost analysis. The Manufacturer Impact Model (LBL-MIM) uses engineering cost and efficiency estimates as well as economic and financial data that we collect to generate the necessary predictions for this analysis. Besides price and rate of profit, these include shipments, revenues, and net incomes, as well as standard errors on of all these.

In the first half of FY 1988, we completed the new version of the LBL-MIM and automated its running. It now does all of the Monte Carlo calculations, scenario

evaluation, and production of tables for the Technical Support Document (TSD) automatically. After completion, it was used to analyze impacts of possible standards on the manufacturers of refrigerators, freezers, televisions, and small gas furnaces, and to produce the appropriate tables for the TSD. In general, LBL-MIM showed that approximately all increases in manufacturing cost would be passed on by manufacturers to consumers. For some standards levels, markups were observed to increase slightly, causing an increase in profits, while for other levels a decrease in profits was observed.

During the second half of FY 1988, one major improvement was made which affects the Manufacturer Analysis and, once it has been fully extended to LBL-REM, will allow greater compatibility between LBL-MIM and LBL-REM. This involved changing the demand specification from one that implies constant price elasticity to one that implies constant life-cycle-cost elasticity. Consequently, the price elasticity now changes slightly as both the price and operating cost of an appliance change. Since price elasticity determines the manufacturer's markup, these elasticity effects, though small, can have a significant effect on a manufacturer's profits.

We also collected data on the dishwasher and laundry products industries. This included a survey of the industries, developed by us and administered by AHAM, a meeting with consultants from the dishwasher industry, and a visit to a major manufacturer. Finally, we completed our initial analysis and the initial draft of the TSD for these products.

Residential Energy Demand Forecasting

J. E. McMahon and P. Chan

The LBL Residential Energy Model (LBL-REM) provides estimates of the impacts on consumers of federal policies affecting energy consumption by home appliances, including furnaces and air conditioners. LBL-REM combines engineering estimates of possible appliance designs with a simulation of market behavior for the purchase of appliances, including fuel choice, efficiency choice, and usage behavior (see Figure).

The LBL-REM has been improved this year by: incorporating the effects of the National Appliance Energy Conservation Act (NAECA) of 1987 into the base case; modeling the interactions between internal loads (e.g., waste heat from refrigerators) and space conditioning energy use (heating and cooling); directly using discrete design options from engineering analyses, without any smoothing or curve fitting (new data became available for refrigerators, refrigerator-freezers, freezers, and some new sub-markets listed below); and explicitly modeling the individual sub-markets for small gas furnaces, dishwashers, clothes washers, and televisions (none of which were previously analyzed).

The model was used to perform several analyses of impacts of federal policies on consumers and on national energy consumption, including: regional impacts of the

NAECA; possible new conservation standards for small gas furnaces, televisions, and dishwashers; and possible updates to conservation standards for refrigerators, refrigerator-freezers, freezers, clothes washers, and clothes dryers.

In addition, LBL-REM results were used to analyze impacts on manufacturers, electric utilities, and the environment.

We plan to continue to model impacts of any proposed federal conservation standards, including incorporating into LBL-REM any new data from public comments on the proposed rules for dishwashers, televisions, and small gas furnaces, and on updated standards for refrigerators, refrigerator-freezers, freezers, clothes washers, and clothes dryers. A new water heater algorithm will be formulated to take into account hot water use by clothes washers and dishwashers. A new feature will be estimates of impacts of federal energy conservation standards on residential water consumption and on water and sewage costs. The future analysis of room air conditioners, water heaters, direct heating equipment, and pool heaters will be performed on a regional basis. We will continue improving the consumer analysis and forecasting capabilities of LBL-REM.

The Regional Energy and Economic Impacts of Appliance Efficiency Standards

J. H. Eto, J. E. McMahon, J. G. Koomey, P. T. Chan, and M. D. Levine

While nationwide analyses performed by LBL overwhelmingly support the cost-effectiveness of appliance efficiency standards, the regional impacts of the standards have never been examined. These impacts will vary greatly due to regional differences in climate, appliance stocks/saturations, energy costs, and demographic trends. In the present work, we use an end-use energy demand forecasting model to assess the energy, peak demand, and economic impacts of the standards for the ten DOE planning regions of the continental U.S.

We find that the standards will save the nation nearly \$25 billion (in 1987 dollars) in cumulative net present benefits to 2015. The savings consist of reductions in electricity generation of 800 TWh and in direct fuel use of almost 2 Quads.

We find that the largest absolute and percentage electricity savings will occur in the South Atlantic and Southwest DOE regions due to both the high saturation of air conditioning and the relatively greater cooling loads found in these climates. Conversely, we observe the lowest percentage electricity savings in New England due




Figure. Logic diagram showing major components of LBL Residential Energy Model. (XCG 8412-13510)

to lower air conditioning saturations and smaller cooling requirements.

Percentage savings for all other fuels are relatively modest and uniform across all regions with the exception of the Northwest region where we predict fuel use will increase slightly. In the Northwest, NAECA has the effect of reducing the attractiveness of electricity as a heating fuel because heat pumps (25% of electric heating appliances) become too expensive relative to expected annual heating requirements. In this situation, fossil fuel furnace sales increase, leading to increasing consumption of other fuels.

The analysis is of special significance to electric utility planners because the end-use model we employ shows how the structure of demand will be affected by the standards. For example, we find that, while overall air conditioning equipment sales will change only slightly, sales will shift away from central air and heat pumps in favor of room air conditioners. For water heating appliances, we find that electric water heating sales will increase at the expense of other types of water heating equipment. These effects are small nationwide, but can be significant in some regions.

The end-use detail of our forecasts also allows us to provide guidance to utilities considering rebate programs to stimulate the purchase of even more efficient appliances. We find that only modest rebates (\$50-\$100/unit) will be needed to stimulate the purchase of more efficient central air conditioners, but that utilities must distinguish between models that do and do not save electricity peak demands. In order to encourage purchases of more efficient refrigerators, we find that a rebate must offset almost the entire incremental cost of the efficiency improvement.

Research and Policy Studies to Promote Building Energy Efficiency in Southeast Asia

M. D. Levine, H. Akbari, J. F. Busch, J. J. Deringer, Y. J. Huang, and K. H. Olson

The purpose of this project is to assist five ASEAN countries[†] to identify appropriate government policy options for buildings energy conservation, to enhance their policy analysis capabilities, and to implement policy initiatives.

Several on-going assistance programs have continued through this past year. First, workshops in building energy audit procedures have been given in ASEAN for several years by LBL consultants. Second, assistance has been provided to several countries in developing energy conservation standards for new commercial buildings. Malaysia is in the process of adopting a new building standard for implementation. Thailand is also evaluating a similar standard that will be voluntary.

A policy options paper has been prepared to define a wide range of policy approaches that could be pursued in addition to building energy standards to reduce energy use in buildings.

The most important new activity of the project has been the development and implementation of research activities on building energy conservation in each of the ASEAN countries. These research efforts are summarized in the accompanying Table. These research activities, as they progress in each of the countries, will yield a deeper understanding of energy use in ASEAN buildings. This in turn will provide a sound technical basis for effective policies to reduce energy use in buildings.

[†]The countries are Indonesia, Malaysia, the Philippines, Singapore, and Thailand.

Table. ASEAN in-country research projects

<i>Country</i>	<i>Project Title</i>	<i>Description</i>
Indonesia	Policy	Review existing building regulations; conduct building audits; develop energy conservation policy for buildings.
Indonesia	Survey of Energy Use In Hotels and Simulation Studies	Audits of hotels and other commercial buildings; energy analysis using computer simulation tools (DOE-2 and ASEAM.2) to determine cost savings.
Indonesia	Weather/Solar Radiation Data	Collect hourly solar and weather data in Bandung and Jakarta; analyze weather data; develop typical weather year and prepare in DOE-2 format.
Indonesia	Control and Monitoring of Commercial Buildings	Review existing buildings with energy management and control systems (EMCS) in place; review economies and energy savings of retrofit measures; upgrade existing EMCS with new controls and monitoring equipment and monitor building energy use.
Malaysia	Utility Policy	Measure building hourly load profiles using UPLAN simulation code; analyze short- and long-term marginal costs for utility; analyze commercial conservation/load management effects on load shapes; conduct financial analysis of costs, tariffs, and marketing strategies; analyze overall implications for future utility policy.
Malaysia	Chiller Optimization and Control	On-site study of buildings with building automation systems (EMCS) in place; simulate performance of these buildings; compare simulation results with actual.
Malaysia	Energy Audit Studies and Development of Energy Conservation Requirements for Malaysian Buildings	Analyze results of audit survey of 10-12 buildings using ASEAM.2; analyze and revise OTTV equation using solar radiation data; perform DOE-2 studies; assess economics of implementation of standards on existing buildings.
Malaysia	External Shading of Windows	Survey and tabulate use of external shading devices on existing buildings; build physical model to analyze effectiveness of shading devices; correlate results to those of DOE-2 simulations for selected devices; develop shading schedules for DOE-2.
Malaysia	Administration and Policy Studies	Survey 25+ existing government buildings and analyze results; identify possible targets for energy conservation measures; study effect of implementation of policy on existing government buildings.
Philippines	Lighting and Daylighting	Survey and compile results of actual lighting and daylighting conditions in 20+ buildings, including survey of behavioral response to daylight and artificial light; study daylight geometrics, such as glare and brightness imbalance; develop DOE-2 daylight simulations; set up controlled physical models for monitoring.

<i>Country</i>	<i>Project Title</i>	<i>Description</i>
Philippines	Forced and Natural Ventilation	Survey and compile results of actual air conditions and thermal comfort in 12 buildings; correlate ESPAIR computer simulations with findings of survey; prepare design guidebook for natural ventilation.
Philippines	Air Conditioning Equipment	Survey component cooling equipment in 50+ commercial buildings; study effects of air conditioning efficiency improvements using ASEAM.2, and for selected buildings, DOE-2.
Philippines	Performance of Typical Building Insulating and Reflective Materials	Perform correlation studies to determine heat transfer values of materials in non-air conditioned buildings and potentials for comfort conditioning and energy efficient design; establish U-values for typical building cross-sections of materials and components commonly used in the Philippines but not covered by ASHRAE; build test cell to test materials.
Philippines	Analysis, Assessment, and Policy	Survey building characteristics and energy use and also building managers' attitudes toward energy conservation investment; perform detailed energy audits of 50 buildings; study performance of cogeneration systems and investigate utility pricing policy affecting cogeneration use; perform DOE-2 and ASEAM.2 simulations in support of policy development including development of building energy conservation standards; analyze policy issues.
Singapore	Lighting and Daylighting	Extend existing lighting survey of 200 buildings to include industrial buildings and obtain more detailed data from existing 200.
Singapore	Energy Analysis Using DOE-2	Prepare new weather data for Singapore for use in DOE-2; evaluate OTTV equation and develop simplified expression for estimating energy use; assess and validate simplified energy estimation methodologies using survey data; develop algorithms for revised energy standards.
Singapore	Energy Management	Conduct energy measurements in existing buildings; compare results with simulation studies; evaluate energy conservation options; produce manual on energy management.
Singapore	Assessment, Analysis, and Policy	Verify solar correction factors based on a full year of solar data; study conductance heat gains through glass; verify ETDQ values for classification of construction—light, medium, and heavy. revise OTTV handbook; develop approach to the revised standards.
Thailand	Natural Ventilation	Collect and analyze weather data including solar data for Chiang Mai; Using ESPAIR simulation code, conduct natural ventilation studies; produce design guidebook on natural ventilation; organize dissemination workshop.

Country	Project Title	Description
Thailand	Lighting and Daylighting	Perform daylighting studies with DOE-2; evaluate daylighting availability in Bangkok; investigate various design methodologies; conduct experiment to compare effectiveness of installed daylighting controls in an office environment; organize in-country workshop.
Thailand	Air Conditioning Research	Perform parametric study of air conditioning system performance via simulation; evaluate actual performance of air conditioning equipment.
Thailand	Assessment, Analysis, and Policy	Perform audits and analyze data; formulate policies, develop standards and implementation package.

Global Biodiversity: Habitat Change and Species Extinctions*

W. E. Westman

Current concern about the global loss of species arises in part from the rapid rate of clearing of species-rich tropical forests. We are using satellite remote sensing to quantify rates and patterns of tropical deforestation, and are linking this information to predictions of species endangerment by use of field data and predictive models. Current efforts in a pilot study are focused on two tropical rainforest regions: southern Uganda, and northern Queensland, Australia.

In our work in Uganda,¹ using LANDSAT multispectral scanner (MSS) data, we found a net removal of 29% of the forest area in Mabira Forest Reserve during the period 1972-1988 (see Figure). During the same period, the edge-to-area ratio of the forest increased by 29%, and a maximum of 7% of the forest regrew in cut areas. We could also differentiate heavily-logged from lightly- or moderately-logged areas of forest using the MSS data. By

linking this information to field-based studies, we could identify which two of seven primate species in the area were expected to thrive differentially under current patterns of forest disturbance.

In Queensland,² we conducted field work on the Atherton Tableland to examine how vascular plant species, and an indicator arthropod species (a giant centipede), respond to forest fragmentation over time. The research included an investigation of differences in attributes of plants growing on newer forest edges vs. forest interiors.

In future work, we plan to examine the impacts of forest clearing in Uganda on a larger regional scale using Advanced Very High Resolution Radiometer satellite data (1 km resolution), and to use predictive models from biological theory to predict regional impacts on the biota.

REFERENCES

1. Westman WE, Strong LL, Wilcox BA. *Tropical deforestation and species endangerment: the role of remote sensing*. Landscape Ecology: in review.
2. Westman WE. *Structural and floristic attributes of recolonizing species in large rainforest gaps, North Queensland*. Vegetatio: in review.

*Collaborators were Laurence Strong, Christine Hlavka (NASA Ames Research Center); Bruce Wilcox (Institute for Sustainable Development); Hank Shugart, John Weishampel (University of Virginia); C.J. Tucker (NASA Goddard Space Flight Center). This work was sponsored by the National Science Foundation and the NASA Earth Sciences Division.




Figure. Mabira Forest reserve in southeastern Uganda, showing disturbance observed during a field survey in 1987-1988. (XBL-8810-3674)

Effects of Climate Change on Vegetation in California and Baja California*

W. E. Westman

General circulation models of global climate predict that California's climate will become warmer and wetter with continued buildup of carbon dioxide over the next century. By observing predicted climate changes for California in relation to existing climatic tolerances of vegetation, we made predictions of vegetation change using direct gradient analysis. We predicted that chaparral elements would expand at the expense of southern oak woodland and blue-oak digger pine woodland; that yellow-pine/mixed conifer and red fir forest elements would expand at the expense of subalpine forests in the Sierra Nevada, and that inland prairie and sage elements would expand into areas now supporting coastal sage and succulent scrub vegetation.

Higher summer temperatures imply an aggravation of ozone formation in coastal southern California. The effects

of increased precipitation, increased temperature, and increased ozone levels on the coastal association (Venturan) of coastal sage scrub were examined under varying fire frequency regimes using a simulation model (FINICS).¹ Simulations of the combined effect of these changes (see Figure) indicate that long fire-return intervals (30-40 years) would be needed to maintain mixed-species shrub dominance. This could intensify conflicts between biodiversity goals and current fire hazard reduction practices involving prescribed burning at shorter return intervals.

Some early warning signs of changes in Venturan coastal sage scrub under increased evapotranspirative stress and elevated ozone may be inferred by comparing ecophysiological and morphological changes along a gradient in these parameters in the Santa Monica Mountains. As sites of elevated temperature and ozone are approached, early season leaves of the dominant black sage (*Salvia mellifera*) become larger and less dense, nitrogen and lignin concentrations increase, and the chlorophyll (*a/b*) ratio decreases. At both coastal and inland sites, reduced shrub cover increases the opportunity for growth of annuals, including exotic grasses.

We plan to expand our simulation modeling to include the behavior of the evergreen shrublands (chaparral) of California, and examine the relative abilities of the evergreen and drought-deciduous shrublands to thrive under future climatic alteration.

*George P. Malanson, Dept. of Geography, Univ. of Iowa, collaborated in this work, which was sponsored by the Environmental Protection Agency.




Figure. Changes in percent cover (y-axis) of five species of coastal sage scrub over time (x-axis) under FINICS model simulation, assuming plant growth under the altered climate of doubled carbon dioxide levels, increased ambient ozone, and higher fire intensities. a-d show responses to fire return intervals of 10, 20, 30, and 40 years respectively. (XBL-889-10424)

REFERENCE

1. Westman WE, Malanson GP. "Effects of climate change on mediterranean-type ecosystems in California and Baja California," in: RL Peters, ed. *Consequences of the greenhouse effect for biodiversity*. Yale Univ. Press, New Haven, CT: in press.

Contribution of LDC Energy Use to the Global Climate Problem

J. Sathaye, A. Ketoff, L. Schipper, and S. Lele

Over the last century, the global atmospheric concentration of carbon dioxide and other "greenhouse gases" has increased substantially. This may have serious conse-

quences for human well-being over the next century. Emissions from energy consumption are the single largest contributor to this effect. An examination of possible trends in energy consumption and the potential for its reduction is therefore crucial to any attempt to prevent or delay global warming.

We have explored the contribution of developing countries (LDCs) to the demand side of the problem.¹ We use information about energy and economic activity in the developing and developed countries to construct two basic scenarios for the year 2025 in five regions: Asia, China, Africa, Latin America and the Middle East. These are based on assumptions about economic growth rates, energy price trends, and population growth. We also construct two policy cases to examine the effect policies could have in reducing energy intensity and activity levels in the two basic scenarios. In analyzing energy demand, we examine five sectors in each region: industry, transportation, residential, commercial and agriculture. We establish measures of energy intensity (energy consumption per unit of activity) for each sector, and seek to understand the

changes in structure of that sector that influence its energy intensity. We also examine the changes in the mix of fossil fuels (taken as a group), biomass, and electricity in each sector.

The Table gives the overall results by region for the rapid economic growth scenario. The results for non-LDC regions are derived from basic assumptions consistent with those used for the LDC scenarios. The results show the large shift in share of energy consumption from the industrialized to the developing countries. About half of world energy use takes place in the LDCs in 2025. Modern fuel use increases at 3.4% annually in the LDCs between 1985 and 2025. Almost 80% of the increase in fossil fuel combustion in this scenario occurs in the LDCs. Their contribution to carbon dioxide also increases in similar proportion.

It is estimated that such an increase in energy consumption will lead to a realized temperature increase of 2.5°C by 2050. To place this in perspective, the anticipated temperature rise of 1.5-4.5°C over the next 100 years is equivalent to the temperature increase that has taken place over the last 18,000 years.

We also construct scenarios where strong policies are adopted to control growth in energy use. These would lead to a temperature increase of about 1.5°C by 2050.

REFERENCE

1. Sathaye J, Ketoff A, Schipper L, Lele S. *An end-use approach to development of long-term energy demand scenarios for developing countries*, LBL-25611, Sept. 1988.

European Electric Power Generation: The Role of Oil

D. Hawk and L. Schipper

Annual primary oil demand in European member countries of the Organization for Economic Cooperation and Development (OECD) declined by approximately 25% between 1973 to 1986. Nearly one-third of this decline is the result of the phasing-out of oil for use in electricity generation. In 1973 in France, Germany, Italy, England & Wales, and Sweden, oil was the first- or second-most important energy source for electricity generation—

Table. Energy demand in 1985 and 2025, all regions

Region	1985 EJ*	2025					
		Rapid Scenario		R/Policy Scenario		GDP/Cap.	Pop.
	EJ*	EJ	% AAGR**	EJ	% AAGR	% AAGR	% AAGR
C-Planned Asia	29	96	2.9	77	2.4	3.8	1.0
Middle East	9	42	3.7	36	3.3	2.0	2.3
Africa	8	43	3.4	32	2.7	1.7	2.4
Latin America	19	72	3.3	56	2.7	2.8	1.5
S and E Asia	22	85	3.3	66	2.7	3.6	1.5
LDC Total	90	337	3.3	266	2.7	4.5	1.5
World Total	354	642	1.5	514	0.9	2.1	1.3

* 1 EJ is 10^{18} Joules, or about 23.9 MTOE, 0.5 MBDOE, or 0.95 quadrillion BTU.

** % AAGR = % average annual growth rate.

Note: Energy demand includes that for modern and traditional fuels.

generating between 14% to 59% of electricity produced. By 1986, oil use for electricity generation had declined to between 1.5% and 5.6% in all countries except Italy (39.4%), where oil is still being used for base-load generation. However, the oil generation facilities existing in 1973 are still in place and are operable (in various stages of reserve) and some oil-fired generation is used, primarily to meet peak load. Thus, the infrastructure that enables oil-based electricity generation remains in place, but the *intensity* with which oil is used has changed. This sector could trigger a large and quick rise in the demand for oil: a potential 25% increase in the total oil demand for these five countries. The Figure shows the huge increases in oil use by the power sector that would result if the oil-using capacity in each of these countries was used at its highest feasible level (capacity factors between 60% and 79%). The case 1 potential is calculated using only oil capacity. The case 2 potential is calculated using all of the oil-using capacity, which includes capacity with multi-fuel capability.

In England & Wales and Sweden, oil-based generation may soon increase above 1986 levels. In Sweden, oil-based generation will be used to bridge a supply gap that will result from the de-commissioning of nuclear power plants in the absence of new generation capacity to replace it. In England & Wales, a competitive environment introduced through privatization, the relative youth of the oil capacity, and the current low oil prices may cause oil-based electricity generation to have a competitive advantage, even replacing some coal-fired generation. Continued delays in the nuclear program would encourage the use of oil to bridge supply gaps until the nuclear capacity comes on-line or a different generation source is selected. In Italy and Germany, oil-fired electricity generation will likely remain relatively constant. Unless German law changes, no additional oil-based generation will occur. Only in France will oil-based generation decline.




Figure. Oil use by the power sector, past, present, and potential. (XCG 8810-6780)

Although oil-fired electricity generation may increase above 1986 levels in the near future in some countries, the maximum potential levels of oil-based generation calculated in this report will not be attained in any of the countries *unless* a major electricity generation resource or technology suffers a severe, unforeseen disruption. In the absence of such a disruption, institutional barriers against dependence on oil will preclude the realization of the existing potential. Nonetheless, the "hidden" potential for oil use in the power sector, represented by the existing oil-fired capacity, must be borne in mind. As institutions and political agendas evolve, so too might attitudes regarding oil use.

REFERENCE

1. Hawk DV, Schipper L. *The role of oil in electricity generation in five european countries: past, present, and potential*, LBL-25674, draft report.

Residential Energy Conservation Policy and Programs in Six OECD Countries

D. Wilson, L. J. Schipper, S. Tyler, and S. Bartlett

In response to the impacts of high international oil prices in the 1970s and early 1980s, the governments of many countries implemented policies and programs for the purpose of reducing household energy consumption. Through these policies and programs, governments sought to improve the residential energy market (by removing perceived market barriers), change that market (by offering subsidies, charging taxes, etc.), and alter the make-up of items on the market (appliances, heating equipment, etc.). The tools they used to meet these goals were information, subsidies, regulations, and price manipulation.

The current low price of oil has offered governments a reprieve: time to pause and look back. That process is currently taking place within several governments as they anticipate the necessity of moving forward with new programs motivated by changes in energy prices and/or other concerns such as the negative environmental impacts of energy supply and consumption processes. In this study, we describe and compare policies and programs that were implemented in Denmark, France, Japan, Sweden, West Germany, and the U.S. We present them along with contextual factors which determine both policy and program goals and the range of feasible measures/methods for achieving them. Contextual factors include: energy supply and demand structure; political and social environment; economic environment; institutional structures of relevant government agencies; and physical environment (climate, age and thermal quality of the housing stock, etc). Each

of the above-mentioned topics is then discussed individually, using the specific experiences of the study countries to highlight and illustrate our observations with regard to their use.

These analyses have resulted in several fundamental conclusions regarding residential energy conservation program design. The first of these is that the most far-reaching programs take an integrated approach, using more than one tool to achieve a well-defined policy goal. An important example of this took place in Denmark where a program package of subsidies, home audits, and a home labeling program were used to attempt to improve the thermal quality of the existing housing stock. The specific tool or set of tools to be used in a program should be chosen based on both program objectives and context. The implementation of program tools commonly requires combined efforts of a variety of government institutions. The relationships and interactions between these institutions should be directly addressed as part of every program design, and where possible should be enhanced. In addition, relationships between government and non-government institutions (such as industry and academia) should be nurtured. These relationships can provide important channels to consumers and an infrastructure for supporting program implementation. Wherever possible, existing infrastructures should be used to implement programs. Both the Swedish retrofit subsidy plan that was melded into the existing national home loan program and the program in Germany that supported the publication of energy efficiency information through a well-known and widely-read magazine provide examples of this. A multitude of examples of problematic programs that attempted to create and rely exclusively on new institutions and infrastructures also exist. Finally, program evaluation should be part of every program design. Evaluations should be used both as part of the implementation process (i.e., learning and adapting as you go along) and after programs are completed (i.e., enhancing the learning curve effect). Although program evaluations have become more common in the U.S., they are still relatively sparse in other countries (except Sweden). Removing the many barriers to program evaluations should be a high priority goal of policy- and decision-makers responsible for initiating and/or planning residential energy conservation programs.

Home Electricity Use in OECD Countries: Recent Changes

L. Schipper, D. Hawk, A. Ketoff, and N. Hirt

The Home Electricity Use Study* has been recently updated to study changes through 1987.¹ These changes

*This work was additionally supported by the International Energy Agency, Paris, France and Oslo City Light, Oslo, Norway.

suggest that the wave of increased efficiency seen in our earlier study has peaked. Except for the heating market, inter-country differences are shrinking. The inter-country comparison suggests that many factors besides price and income influence the levels and patterns of residential electricity use in homes of the Organization for Economic Cooperation and Development (OECD) countries.

The Figure shows per-capita use in 1986 divided into end uses. The most important difference among countries is the use of electric space heating, a dominant component of sales growth in France, Sweden, and Norway. Secondary use of electricity for heating, i.e., in combination with other main heating systems, has grown in Denmark and is now a leading component of growth in electricity in Japan, where heat pumps reach the 50% saturation level.

The historical evolution of the countries shown in the Figure reveals that once homes reach a level of consumption corresponding to about 1000kWh/cap. for lighting, appliances, and cooking, then household electricity use only grows significantly if electricity makes significant inroads against fossil fuels in the space and water heating markets. In Sweden and Norway, such gains drove strong increases in household electricity use in the late 1970s and 1980s. In these countries, electricity heats 35% and 65% of all homes, respectively. In the Netherlands, by contrast, electricity heats almost no homes: instead cheap gas provides space heat, hot water, and cooking for over 90% of homes.

Differences in structural features, such as housing and appliance characteristics, incomes, and habits and lifestyles are not insignificant but many of these differences have diminished over time. This is particularly true for electric appliances. As the number of major international appliance manufacturers has declined, appliances have become more homogeneous.

If the differences in use patterns shown in the Figure are analyzed further, significant differences in intensity, or use per household, are found. For example, homes with electric water heating in Germany use considerably less




Figure. Electricity use per capita in 1986, climate corrected. D = West Germany, GB = Great Britain, I = Italy, J = Japan, S = Sweden, F = France, DK = Denmark, N = Norway, and NL = Netherlands (XBL-8811-3856)

electricity per home for that purpose than those in the U.S., Sweden, or Japan. German homes use instant water heaters with almost no tank losses, while Japanese, American, and Swedish homes use large tanks.

The efficiency of electric appliances has increased markedly in most of the study countries. These improvements limited the growth in appliance electricity use caused by increased saturation levels; in a few countries (Denmark, Sweden, United States), growth in use per household was very slow or even negative after 1978. Appliances sold in 1988, while far more efficient than similar ones sold in the early 1970s, may not be significantly more efficient than those sold in 1985. If this "efficiency plateau" proves lasting, then electricity use for appliances could begin to grow again as larger and more fancy models appear in households. Our comparisons also suggest that there are slight differences in the sizes and efficiencies of appliances within European countries; in countries with high electricity prices, such as Denmark and Germany, efficiency is slightly higher than in countries with lower prices. Appliances in North America are larger and less efficient than their European counterparts.

The price of electricity is an important determinant of the level of demand in the long run. If cheap compared to fossil fuels, electric heating gains a high market share (as in Norway), and water heating becomes attractive as well. Prices also influence comfort and lighting levels, and have some impact on appliance size and use. Income is an important determinant of the level of demand while stocks of major appliances are growing, but becomes less important thereafter, particularly in countries where the most expensive appliances are often the most electricity-efficient ones. Technology—the choice of heating system and insulation and the actual design of appliances—is certainly influenced by electricity prices, but other factors, such as climate, the presence of central space- and water-heating, and the traditions of the housing industry also influence the design and use of appliances.

Work in FY 1989 will focus on four areas. First, we shall continue our dialogue with the major appliance manufacturers to better quantify the savings in electricity use since 1973 that have arisen from greater efficiency. We will also explore the factors driving the future appliance market, and how new appliance features will influence electricity consumption. We will extend the comparison of household electricity use to 1987, with special emphasis on a Scandinavian comparison. Thirdly, we will explore the impact of certain kinds of lifestyle changes on future electricity use. Finally, we will extend our analyses to cover important end uses in developing countries, based on direct experience with surveys in Venezuela and Indonesia as well as information generated from our urban energy-use network.

REFERENCE

1. Schipper L, Ketoff A, Meyers S, Hawk D. Residential electricity consumption in industrialized countries: changes since 1973. *Energy* 1987; 12:12:1197-1208.

Electricity in the LDCs: Trends in Supply and Use Since 1970

S. Meyers and J. Sathaye

The share of world electricity production accounted for by the less developed countries (LDCs) grew from 11% in 1970 to 20% in 1986. The average annual growth rate for LDC electricity production in this period—8.4%—was over twice the rate of 3.8% in the "developed" countries. Growth in the 1980s—6.7%/year through 1986—has been less than the rate of 9.4%/year in the 1970s, mainly due to slower economic growth in Latin America and Africa.

Electricity production has grown fastest in Asia (9.5%/year between 1970 and 1986), followed by China (8.8%/year), Latin America (7.7%/year), and Africa (6.4%/year). Among the 13 countries in our study, growth ranged from 5.2%/year in Argentina to 13.2%/year in South Korea. Indonesia, Malaysia, and Thailand averaged growth in excess of 10%/year, and Pakistan, Taiwan, and Brazil were close to this.

Electricity generation is much higher in China (450 TWh in 1986) than in any other LDC. Brazil (212 TWh) and India (202 TWh) are also major producers of electricity. The next largest—Mexico, South Korea, and Taiwan—are well below India.

The share of total LDC electricity production derived from fossil fuels has remained at about 65% since 1970. The share of fossil fuels in 1986 was 77% in China and Africa (56% if South Africa is excluded), and 70% in Asia. In Latin America, the hydropower share increased from 51% to 61% between 1970 and 1986. Hydro's role has increased in China since 1970, but has declined in Asia and Africa.

The LDCs have experienced a shift away from oil to coal, natural gas, and nuclear power (mainly in Asia). Coal dominates power generation in China and India, and is also prominent in South Korea and Taiwan. Natural gas plays an important role in Pakistan, Thailand, and Venezuela. For 12 major LDCs, the combined share of oil in total public generation declined from 27% in 1970 to 17% in 1986. The share of hydro fell from 48% to 44%, coal grew from 15% to 22%, while nuclear went from 2% to 9%.

The extent to which electricity consumption grows faster than the economy depends in part on the stage of economic development in which a country finds itself. The ratios between average growth in electricity consumption and growth in real GDP in the 1970-86 period in the 13 study LDCs were mostly between 1.6 and 1.9. The ratio was lower in Taiwan and Malaysia, reflecting their more mature level of economic development.

The industrial sector dominates electricity consumption in nearly all LDCs, but its share of total consumption has generally declined in the face of faster growth in the residential and commercial sectors (see Figure). Residential electricity use per capita has grown at more than 10%/year in most of the countries due to increase in the




Figure. Electricity consumption by sector for 12 LDCs. (XBL-8810-3591)

number of homes that have electricity and rising ownership of appliances.

As electricity demand grows, many LDCs face increasing difficulty as they seek to expand supply and maintain existing systems. Power shortages are critical in many countries and environmental issues are becoming more important. Measures that are receiving closer attention include reform of tariffs to better reflect costs, reducing demand through end-use efficiency improvement, encouraging private power generation, and improving technical and managerial aspects of electric utilities.

REFERENCE

1. Meyers S, Sathaye J. *Electricity in the LDCs: trends in supply and use since 1970*, LBL-26166, 1988.

Production, Consumption, and Trade of Natural Gas: Western Europe and the Developing Countries

J. Sathaye, A. Ketoff, and G. Pireddu

World-wide, natural gas is assuming growing importance. It is being discovered in increasing quantities in the developing countries and it is also the fuel of choice to substitute for oil in oil-importing countries. It is environmentally more benign than other fuels and emits less "greenhouse gases" relative to those associated with the use of oil and coal. For these reasons, its use will be highly valued in the future.

This work is intended to describe the current and potential use of natural gas in several regions of the


world—Western Europe, Asia, Latin America, and the Middle East. Within each region, we focus on a few countries that are in a position to export, or are already exporting, natural gas to other countries.

In Western Europe, natural gas demand is not expected to increase by more than 10-20% by the end of the century. The major uncertainty is whether the Scandinavian countries will use more of the abundant gas available in that region for power generation and space heating. The long-term demand for gas could increase considerably if environmental policies forced additional displacement of other fuels.

The Asian region (not including the Soviet Union) accounts for about 6% of the world's natural gas reserves. Indonesia, Malaysia, Brunei, and Afghanistan have deposits large enough with respect to domestic demand to export natural gas. Taiwan and Japan have smaller and dwindling deposits of natural gas. The region is far from fully explored and new discoveries have been reported in Papua New Guinea and India. Asian reserves are expected to increase over the next two decades. Natural gas utilization will depend on the location of the natural gas deposits within a country and the level of reserves relative to the country's needs. Countries that discovered natural gas recently have used it in industry and power generation. Residential use occurred in countries that had heating needs and those that discovered gas some decades ago. Exports of gas, either as LNG or methanol, from Malaysia and Indonesia will remain a long term option; those from other Asian countries are unlikely given their current reserves and indigenous demand for natural gas.

Natural gas in Latin America has changed from being a by-product of the petroleum industry in the 1960s and the early 1970s to become an important energy source for the indigenous market. The prospect for export of natural gas from this region is limited. Demand is growing in the three major producing countries—Argentina (Figure), Mexico, and Venezuela—and is likely to expand in the others, particularly in Brazil. Increasing demand can be expected in the residential sector as a result of both an increase in the number of users (in Venezuela and Mexico) and an increase in comfort levels (in Argentina). Use in transport will remain minimal, although it might grow considerably in certain markets if strong government programs are launched. Industrial demand will remain dominant, particularly as the use of gas is seen as beneficial either to the environment (e.g., in Mexico), or to the international competitiveness of local industry (e.g., in Venezuela). With both Venezuela and Mexico pushing the use of gas as raw material for petrochemicals, demand in this sector is bound to increase considerably. Both countries would rather export higher-valued petrochemicals than LNG. Given present trends in demand patterns in Latin America, reserves of natural gas appear insufficient to allow export in the long run. Furthermore, since most of the gas is associated with oil, gas for export would be available only when demand for oil, and therefore production of oil, is high.

The cost of natural gas in the Middle East is minimal, since its production is associated with oil. Final users are



Source: IES/LBL.
Own use/Losses includes gas reinjected.

Figure. Natural gas in Argentina. (XBL-8812-4249)

charged low prices to favor its use over other, more exportable, petroleum products. Gas demand (in producing countries) will continue to expand as petrochemicals, power generation, and large industries switch off oil products. The uncertainty of the international oil market will push governments (in particular, Saudi Arabia and Kuwait) to seek non-associated resources to be tapped in case of shortages of associated gas. Capital availability might be a constraint, but the priority is high as countries prefer to keep oil underground in a period of low oil prices. In Iran, additional marketable production requires considerable amounts of capital, as major fields are scattered in the southern regions of the country. The end of the Iran-Iraq war is likely to boost industrial demand as well as residential use in newly reconstructed cities, which might justify increased efforts on the production side. As local use of gas becomes a key element of economic development, exports are not likely to be sought by any of the countries examined, with the exception of Qatar and Abu Dhabi. In the other countries, we can expect natural gas to be used in petrochemicals, fertilizers, and other energy-intensive products which will be marketed locally and/or exported.

With increasing discoveries of natural gas world-wide, the likelihood of additional gas becoming available for export in the form of LNG or, after transformation, in the form of methanol is strong.

Energy Markets and Energy Demand: China and the U.S.

J. Sathaye, L. Schipper, and M. D. Levine

Knowledge abroad about China's energy demand patterns and its likely future growth of demand is limited. Likewise, Chinese planners are eager to seek additional information and knowledge about energy use and government policy in the U.S. In order to exchange information and viewpoints, a symposium was sponsored jointly by the State Planning Commission of China and the Office of Policy, Planning and Analysis of the U.S. Department of Energy. The Chinese-American Symposium on Energy Markets and the Future of Energy Demand was organized by the Energy Research Institute of the State Economic Commission of China, and Lawrence Berkeley Laboratory and Johns Hopkins University from the United States. It was held in Nanjing, China in late June 1988. It was attended by about 15 Chinese and an equal number of U.S. experts on various topics related to energy demand and supply.

The Chinese papers provide an excellent overview of the emerging energy demand and supply situation in China and the obstacles the Chinese planners face in managing the expected large increase in demand for energy. Topics discussed by speakers included energy demand modelling, energy pricing reform, air pollution and energy use, and patterns of energy use and conservation in buildings, transportation, industry, and power generation.

The huge rate of economic growth in China has brought with it a dramatic increase in energy use. Energy conservation, however, has not yet surfaced as a common concern or practice among the populace, and lack of price incentive for conserving energy has allowed a huge incremental increase in energy use to accompany China's approximately 10% annual rise in GNP. Of great concern to China's leaders is that country's energy pricing structure, which encourages inefficiency and discourages conservation. "Planned" (i.e., subsidized) prices are replaced in practice by locally derived prices, which in turn often yield to black-market prices. Representatives of the Chinese government expressed their eagerness to reform pricing and to develop and implement conservation techniques and policies.

Conference participants also discussed China's efforts to control indoor and outdoor pollution, especially in urban areas. In China, almost all cooking is done using low-quality coal that is not cleaned (cleaning reduces substantially the sulphur content of the coal). In addition, scrubbers are not yet used by coal-fired power plants. Acid rain has resulted from these practices, and damage caused by acidic pollution is glaringly evident: a slide presentation at the conference depicted two sides of a monument, its windward side pitted and its leeward side, smooth.

Future work with the Chinese is likely to involve collaborations on such topics as energy pricing reform, energy demand and global warming, and building energy conservation. A follow-on conference in which the Chinese researchers travel to LBL is envisioned in FY 1991.

Competition in Electricity Generation

E. Kahn

Competition in the generation of electricity began with the Public Utilities Regulatory Policy Act (PURPA) of 1978. PURPA required regulated utilities to purchase the output of certain private, unregulated suppliers at prices based on the cost of equivalent power. Producers who met the technology specifications embodied in PURPA, essentially cogenerators and users of renewable energy, were called Qualifying Facilities (QFs). The response to PURPA was very substantial in regions which offered favorable terms. In some cases, the response overwhelmed utilities and their regulators, creating a need to ration or limit QF supplies. This unanticipated development spurred interest in reforming the PURPA process to make it more efficient. The principal reform which has emerged from these concerns is the creation of auction or bidding systems in which PURPA suppliers compete for the right to sell under long-term contracts. PURPA auctions raise many design and implementation questions. These have been studied in detail previously.

The Federal Energy Regulatory Commission (FERC) has taken the initiative to broaden the PURPA auction process initiated in individual states. In a series of Proposed Rules, the FERC has suggested expanding the scope of competitive bidding to include all sources of supply instead of only the QFs. The principal effect of the proposed FERC rules would be to create a new class of unregulated suppliers, called Independent Power Producers (IPPs) who would compete with the QFs and regulated producers for the right to provide new generating capacity. The far-ranging nature of the FERC proposals raises a number of policy and technical questions.

We examined the welfare impacts of the FERC proposals in light of prospects for regulatory policy. PURPA and the FERC initiatives have arisen in part out of dissatisfaction with the performance of regulation, particularly with regard to inducing efficient investment in generation facilities. Three scenarios for future regulatory policy were delineated and used as a background against which to evaluate the FERC proposals. These scenarios are: 1) capital minimization, in which utilities avoid investment due to hostile regulation, 2) joint responsibility, in which regulators share planning authority explicitly with utilities, and 3) optimal risk aversion, in which utilities avoid risky

investment, but there is no sharing of responsibility with regulators. The balance of costs and benefits varies in each scenario. Depending on the degree of competition between the IPPs and regulated suppliers, there will be no differences in bargaining power and flexibility. Efficiency gains will be obtained, but at the price of higher transaction costs. On balance, the FERC proposals appear beneficial. Details are available.¹

The FERC proposals imply major changes in the structural organization of the electric utility industry. The underlying assumption that the wholesale generation market is workably competitive implies that the traditionally vertically-integrated and regulated firm will be altered significantly. The key element in these long-run changes is the evolution of the transmission system. The FERC proposals do not explicitly take up the questions raised about transmission under wholesale competition. Any system which evolves must provide for system security, efficient pricing of transmission services in the short-run, and capacity expansion in the long run. Achieving all three objectives will require some kind of cooperative arrangement between the buyers, who will probably end up operating the system, and the sellers, who may have to bear the financial burden of expanding capacity to reach new markets.

The planning and operating environment will also change substantially under wholesale competition. Contractual arrangements will play a larger role in unit commitment and economic dispatch. The utility's obligation to serve will be tested as its "supplier of last resort" function gets defined more precisely. It is plausible that the overall level of wholesale generation reliability may degrade somewhat. Storage technologies, which provide an inventory function, will play a larger role in smoothing out these problems.

There can be expected to be major re-allocations of assets among firms. Some of this will involve divestitures that move particular resources to higher valued uses. More important will be consolidations that will help to make the market operations more efficient. On the buyers' side, small distribution companies can achieve important efficiencies through merger. One problem is that many of these companies are publically owned, and lack the financial incentives to consolidate. Mergers among suppliers will not be harmful as long as monopoly power does not accumulate. The prospects are good that these abuses can be prevented. Detailed results are available.²

Future work on these issues will focus on implementation problems of designing all source competitions for bulk power and the resource planning problems these must address.

REFERENCES

1. Kahn E. *Welfare and efficiency benefits of all sources bidding*, LBL-26212, 1988.
2. Kahn E. *Structural evolution of the electric utility industry*, LBL-26165, 1988.

BUILDING ENERGY SYSTEMS PROGRAM

INTRODUCTION

The main theme of the Program is the comprehensive simulation, analysis, monitoring, and evaluation of the energy performance of whole buildings, emphasizing nonresidential buildings. Many of the projects develop and apply comprehensive computer models that enable integrated performance analyses of heating, cooling, and daylighting systems. A further activity involved research on absorption heat pumps for solar cooling and gas-driven applications.

The Simulation Research Group maintains and continues development of DOE-2, a public-domain computer program for detailed, hour-by-hour simulation of energy use in buildings. DOE-2 is in wide use in the U.S. and thirty other countries to design energy-efficient buildings and to research innovative building technologies. During FY 1988, new capabilities were added to DOE-2, enhancing its usefulness.

The Simulation Research Group is also developing the next generation of simulation software, for use in the 1990's and beyond. A plan has been formulated in collaboration with groups in the United States and United Kingdom to create an "Energy Kernel System" consisting of an extensive library of software modules and an executive program that will allow users to produce a wide variety of customized simulation programs. In FY 1988, LBL continued development of the Simulation Problem Analysis Kernel (SPANK) as the first prototype of the Energy Kernel System.

The Building Systems Analysis Group continued investigating the performance impacts of energy technologies in nonresidential buildings. As part of a bilateral research agreement, a simplified technique for evaluating long-term energy performance of daylit buildings (based on short-term monitored data) was applied to buildings in the United Kingdom. The technique has proven to be useful, and its continued application and refinement—focusing on energy performance of atria spaces—are being undertaken as part of U.S. contributions to an International Energy Agency (IEA) collaboration.

In collaboration with the IEA Task XI work on passive commercial buildings, we have begun to investigate the daylighting, heating, cooling, and functional effects of atria in large buildings, including the resulting comfort conditions. We have developed new simulation tools to evaluate atrium effects.

A project was initiated to develop a methodology for sizing thermal energy storage (TES), used in cooling

systems of nonresidential buildings. Simulations were carried out for two prototypical buildings in three diverse climates in order to identify the climate, design, and operating variables that are significant in determining cool-storage-capacity requirements (and that therefore must be accounted for in the sizing methodology). Existing calculation techniques were found to be acceptable for use in TES sizing from a mathematical perspective, but accepted applications practice must be modified in order to avoid undersizing the system (with resultant loss of cooling).

Development of a computerized tool for evaluation of the energy consumption impacts of retrofit measures in institutional buildings was initiated. This project was motivated by an evaluation of the DOE Institutional Conservation Program completed during the previous year. The evaluation indicated that estimates of energy savings due to retrofits based on monitored data are often at least partially masked by changes in energy use caused by retrofit-independent alterations in the functional or operational environment of the building. The tool being developed allows estimates of energy savings to be corrected for these additional changes, thereby improving the quality of retrofit evaluations.

Several small projects—new-building and retrofit studies—have been carried out for the U.S. Army Corps of Engineers, Construction Engineering Research Laboratory, examining the energy performance of Department of Defense (DOD) facilities. Most notably, simulations compared the energy performance effectiveness of existing DOD building design standards with new federal standards developed by the Department of Energy. For most of the building and climate combinations examined, the existing standards proved to be at least as stringent as those now being promulgated.

The Absorption Heat Pump Project continued research on regenerative absorption heat pumps for high-efficiency solar-driven and gas-driven systems for cooling and heating. As part of a joint U.S./Israel effort, computer models are being developed to enable the detailed analysis and design of these and other new types of advanced absorption heat pumps. These models were used during FY 1988 to simulate the performance of three specific types of high-efficiency absorption cycles, for a wide range of configurations and operating conditions. In addition, an initial cost estimate was made for one of the heat pumps.

Building Systems Analysis*

R.C. Kammerud, B. Andersson, B. Birdsall, W.L. Carroll, D. Dumortier, B. Hatfield, R.J. Hitchcock, J. Eto, F. Winkelmann, and E. Vine

ATRIUM RESEARCH RELATED TO INTERNATIONAL AGREEMENTS

In FY 1987, LBL developed a strong collaborative arrangement as part of the US/UK Bilateral Agreement to use a monitored British building to test a daylighting evaluation method. Because the United States is doing far less monitoring of commercial buildings than are several European countries, this relationship with LBL atrium research is being continued and extended to the broader-based International Energy Agency Task XI on Solar Commercial Buildings.

The United States committed LBL to a limited role in IEA Task XI, as Leader of Subtask B (Simulation) and active member of the Task's Atrium Working Group. LBL is also continuing to work with the UK, both within the Bilateral Agreement and as part of the IEA Atrium Group.

The atrium work completed in FY 1988 focused on developing tools that can be used to better evaluate the critical issues in atria, namely the interplay of daylighting and thermal-energy conservation techniques, as well as the resultant comfort levels in the atrium. Several buildings were evaluated for possible inclusion in the LBL atrium simulation plans.

As Subtask Leader, LBL provided considerable assistance to the IEA Task by coordinating simulations and by providing weather data, software, and expertise to members of the Atrium Working Group and other participants in the Task. LBL has also acted as a conduit for significant information exchange between U.S. and European researchers.

Two key buildings were selected for detailed atrium simulations, one in Norway and the other in the UK. Data on the construction and monitoring of these buildings will be provided to LBL as a basis for the simulation studies. Three additional buildings were identified for further testing of the daylighting evaluation method, two in the UK and one in Sweden.

Initial building simulation models will be established for each of the atrium buildings. The results from these simulations will be compared to data provided from the building monitoring, and modifications will be made to the input descriptions until the model provides an accurate representation of the actual building results. Site visits



Figure 1. Gateway 2 Office Block, Oxford: UK/US Atrium Case Study. (XBB 8812-11756)

will be made to both buildings in March in order to clear up any remaining discrepancies.

Simulations will test the sensitivity of atrium energy use to glazing modifications, ventilation, daylighting effects, HVAC integration options, and controls and building operation. Resulting comfort conditions in the atria will be evaluated to determine the potential functionality of atria under different energy scenarios.

LBL will act as consultant and provide support as needed to the British and Swedish researchers applying the daylighting evaluation method (DPEM) to their buildings.

THERMAL ENERGY STORAGE SYSTEM SIZING

The use of cool storage to provide air conditioning in commercial buildings is becoming a widely accepted load management technique. Electric utilities are providing favorable off-peak rates to encourage shifting the air conditioning load away from peak periods. Utilities benefit by deferring addition of new generation capacity and by making better use of efficient base load plants; the customers benefit by having lower electricity bills.

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of State and Local Assistance Programs, Institutional Conservation Program Division, the Office of Solar Heat Technologies, Solar Buildings Technology Division, and the Office of Buildings and Community Systems, Building Systems Division of the U.S. Department of Energy; and by the Electric Power Research Institute and the United States Army Construction Engineering Research Laboratory through the Department of Energy, under Contract No. DE-AC03-76SF00098.

Although some storage systems have been undersized, most are believed to have been oversized, detracting from their economic effectiveness. This is difficult to confirm or refute because the existing literature on sizing procedures and performance does not allow the effectiveness of installed systems to be assessed as it relates to sizing. Our project was undertaken to 1) identify the major problems with sizing cool storage systems, 2) develop a preliminary sizing methodology, and 3) identify long-term research issues relating to thermal energy storage in buildings, and 4) develop a plan for addressing these issues.

Sizing methods used for conventional cooling systems are not directly applicable to thermal energy storage systems which operate on a diurnal (or possibly longer) cycle. For conventional cooling systems, equipment size is determined by the peak rate of extraction of thermal energy from the air stream at the cooling coil, accounting for coincident supply air requirements for all zones in the building. In contrast, sizing of cooling systems using thermal energy storage must be based on estimates of peak extraction requirements for all zones integrated over the operating cycle; design sizing must be based on the hour-by-hour coil load profile.

In our study, these coil load profiles were calculated for prototypical buildings using DOE-2. Simulations examined hourly and daily cooling capacity requirements during the cooling season for a 20,000-square-foot, single-story office building and for a 160,000-square-foot, two-story building serving only retail sales functions. The buildings were simulated for Miami (Florida), Dallas/Fort Worth (Texas), and Chicago (Illinois) climates using TMY weather data. These building types and climates were selected because they represent relative extremes, effectively bounding the range of storage sizing issues of importance. Analyses did not include simulation of any specific storage system; instead, buildings were simulated with a conventional cooling system; daily coil energy requirements were interpreted as the total capacity that must be available from the cooling system. This energy may be supplied by a combination of storage and chiller (partial storage or demand-limiting strategy) or by the storage system alone (full-storage strategy). Peak daily coil-energy requirements define the necessary storage capacity.

Based on these simulations, we concluded that the peak integrated load occurs during multi-day periods of severe weather. These periods typically do not include the most severe day or hour in a particular climate; for this reason, traditionally accepted descriptions of peak climate characteristics are inadequate.

We found that much of the integrated coil load at peak consists of energy accumulated during periods when the building is not cooled and is allowed to reach space temperatures above the design temperature. Under these conditions, energy is stored in building materials and furnishings that must be removed by the cooling system in order to satisfy comfort requirements during the subsequent occupied period. The magnitude of the stored energy at peak depends on the length of the uncooled

period and of the severe climate period, and on a host of building design parameters relating to thermal capacity and climatic interactions. The magnitude of the peak is also substantially influenced by internal gains and climate interactions considered in sizing calculations for conventional systems.

The only sizing calculations believed to account adequately for the full range of variables that affect peak integrated loads are hourly simulations; this is the sizing procedure recommended here. Guidelines have been documented in order to ensure that the simulation provides a technically sound estimate of peak integrated loads on which to base the storage capacity calculation. Of particular importance, these guidelines ensure that the simulation effectively approximates the heat removal characteristics of a storage system. It is believed that this is a major source of error in sizing TES systems.

We have also considered the appropriateness of other sizing calculation techniques, most notably the simplified method currently recommended by ASHRAE and widely used in design of conventional systems. This method, based on cooling-load factors (CLFs) and on cooling-load temperature differences (CLTDs), can provide reliable estimates of peak integrated coil loads if three refinements are made: first, the CLFs and CLTDs must be refined to provide an improved estimate of the underlying coil load under steady periodic climate and operating conditions; second, a method must be developed for superposing that portion of the coil load that is due to deviations in building operating schedule from the steady periodic assumptions. A preliminary suggestion in this regard has been investigated as part of this project; third, a representation of peak climate conditions that reflects multi-day climate severity must be developed. Preliminary suggestions in these regards have been made.

ICP RETROFIT ENERGY SAVINGS ESTIMATION MODEL (RESEM)

To improve the quality of aggregate estimates, Lawrence Berkeley Laboratory is developing a building-specific Retrofit Energy Savings Estimation Model (RESEM) for the DOE Institutional Conservation Program (ICP). RESEM is a user-friendly tool that will allow state and regional ICP staff to use readily available information for reliably determining the energy and cost savings directly caused by ICP-supported retrofits for a single building. [For maximum accuracy and validity, pre- and post-retrofit energy use (and thus savings) must be directly based on utility billing data.] In FY 1988, we developed design and performance criteria for RESEM, developing methodologies that could not be acquired elsewhere, and began software implementation of the tool.

Technical Capabilities and Methods

RESEM is sophisticated enough in its energy modeling to reflect explicitly the influence of a wide range of design, operation, and weather parameters, as well as the full range of actual building designs and specifications actually

encountered in ICP. The model also interacts with the full range of Energy Conservation Measures (ECMs) allowed under the ICP program.

The engineering model used in RESEM is based on existing public domain methods and algorithms in order to minimize validation efforts and to provide a credible finished model. Building energy consumption is broken down into components of fuel type and end use. This breakdown is key to both the billing-data reconciliation process and the allocation of savings to specific ECMs.

The basic premise of the energy model calibration is that a building's actual utility billing history is the most reliable starting point for determining "real" savings resulting from ECM installation. RESEM uses a specially developed method to accomplish this reconciliation, yielding a "calibrated" modification of the building input description (thereby reproducing actual billed consumption). Reconciliation is done for pre- and post-retrofit building configurations.

RESEM uses a specially developed allocation method for estimating the effects of each ECM in producing the total observed energy savings. To the degree allowed by the energy simulation model, this method takes into account the interactive effects that occur when multiple ECM are installed simultaneously.

Other Features

RESEM is designed to run on currently available, "upper-end" PCs and workstations, decentralizing ECM savings analyses to state and regional levels. RESEM runs fast enough that the session time for an interactive analysis consists mostly of the time the user needs to collect, organize, and input data.

RESEM is a self-contained and complete software package that needs no additional software routines for operation. The model contains all supporting information necessary for a building analysis except specific user-provided information about the building being analyzed; general supporting information such as weather, fuel costs, and defaults are available directly to the user from a comprehensive data base built into RESEM. RESEM has an easy-to-use interface, providing real-time diagnostic messages to help users recover from input errors, command syntax errors or ambiguities; real-time status messages to keep users informed at all times about the progress of the analysis; and an online help feature that provides context-dependent information based on menu and analysis status when the help request is made. This feature makes written documentation largely unnecessary.

Although only a minimum of information specific to a given building need be input, RESEM can provide a detailed description of any or all aspects of the building when detail is necessary for the most accurate estimates of ECM savings. At any level of input detail the interface shows users explicitly what input parameters are defaulted, what the default values are, and allows users to selectively alter these defaults for the analysis.

RESEM knows all 74 ECM types recognized in the ICP program, and codified in the Grant Tracking System

(GTS). Input screens for each ECM type allow a detailed description of the ECM, accurately reflecting design changes to a retrofitted building.

Users can automatically generate verification summaries of all inputs; analysis status during the analysis process; and analysis results including pre-and post-retrofit energy use broken out by end-use and fuel type, retrofit savings for each ECM, and economic measures of ECM performance. Future RESEM development will provide a "Performance Profile" of the building energy consumption and savings (comparing these to average data for an entire class of similar buildings) and an aggregation capability that will allow for total savings realized over a given period in various geographical regions and subregions, building types, and retrofit types.

CORPS OF ENGINEERS' EFFICIENT BUILDINGS

The U.S. military has significantly reduced energy consumption in the past ten years through increasingly stringent energy use standards. DOD standards are a straightforward performance standard, whereas the new DOE energy standards applying to all federal (including military) buildings are both prescriptive and performance standards. The Army Corps of Engineers would prefer to retain DOD standards because they are familiar, easier to apply, and the Corps believes the DOD standards are more stringent than the new DOE standards. The Corps asked LBL to establish whether the DOD standards exceed those of DOE. If so, compliance with the DOD standards would simultaneously meet DOE standards.

Six standard buildings were compared (barracks, battalion HQ, chapel, child care center, warehouse, and maintenance facility), developing a reference building for each according to the DOE procedure. This required application of prescriptive DOE standards to a building of the

BLAST PROTOTYPE FOR THE BARRACKS BUILDING




Figure 2. Detailed Zoning for Simulation of Standard Barracks. (XBL 8812-4339)

same type, size, and height as the building under investigation. A BLAST simulation was then run to calculate an energy budget which DOE would allow for that building. This budget was then compared to the DOD energy budget. This was done for six climate regions.

For three of the buildings, the DOD standards always implied compliance with the analogous DOE standards. For two other buildings, the DOE standards were slightly better in only two climates. For the remaining building—the child care center—DOE standards required considerably lower energy use in several climates.

We plan to examine more closely the two buildings that have marginal differences in the standards to determine whether these differences are within the range of uncertainty of DOE procedures and therefore effectively equivalent. The child care (school) building type will be investigated to determine whether the DOD standards must be improved or whether the DOE standards for schools are unrealistic.

Other work will include a life-cycle cost analysis of two building types to determine optimum insulation levels. A set of BLAST input "templates" will be prepared for typical DOE building types to make application of the DOE standards easier for those using BLAST for federal buildings or for other buildings to which DOE standards might apply.

Absorption Heat Pumps*

M. Wahlig, J. Rasson, and M. Warren

Research has continued on development of high-efficiency thermally driven chillers and heat pumps that use *regenerative* absorption cycles. Constant-temperature (instead of constant-pressure) input and output conditions allow regenerative cycles to achieve higher efficiencies than do most (or all) other classes of absorption cooling cycles.

In previous years, simplified calculational methods predicted that a double-effect regenerative (2R) absorption-cycle chiller would operate at about 55%—and a single-effect regenerative (1R) absorption chiller at about 70%—of the ideal Carnot coefficient of performance (COP). Because these cycles are well suited to variable input temperatures between 180 and 280°F, they were explored with solar cooling applications in mind. A 2R chiller was built and tested, and it attained the predicted performance.

Previous work had also identified a gas-driven regenerative cycle configuration, called an absorber-coupled double-effect regenerative (ADR) cycle, that could attain a higher efficiency than the 1R cycle by taking advantage of the high, constant temperature of a gas source.

During FY 1988, we continued development of simulation models that would enable calculation of the performance of high-efficiency absorption-cycle chillers and heat pumps that use ammonia-water as the working fluid pair (work supported by the DOE/Solar Buildings Program as part of a joint U.S./Israel project). We also calculated the detailed performance of a 1R-cycle heat pump over a full range of operating conditions (work supported by the DOE/Buildings Conservation Program, through the Oak Ridge National Laboratory). In addition, we calculated the performance and made an initial estimate of the manufacturing cost of an ADR heat pump (work supported by the Pacific Gas and Electric Company (PG&E) and the Gas Research Institute through PG&E).

The public-domain chemical process flowsheet simulator ASPEN (Advanced System for Process Engineering), selected as the basic tool for modeling the absorption cycles, had been successfully adapted to simulate the 2R cycle. In FY 1988, ASPEN was further modified to simulate the more complex 1R cycle. Convergence problems (in initial attempts to model certain 1R components) were overcome, and the full 1R cycle was simulated successfully.

An in-house, LBL-developed simulation technique (HPSIM) had been developed during FY 1987 to simulate absorption cycles. Although not as comprehensive as ASPEN in its computational ability, HPSIM uses far less computer storage capacity and run time. HPSIM uses a combined simultaneous equation-iterative solution method, using the solver HYBRID. In FY 1988, after the modification of ASPEN for modeling the 1R cycle was completed, the 1R performance predictions of the ASPEN and HPSIM models were found to agree within $\pm 2\%$.

The HPSIM model was then used to calculate the performance of the 1R cycle for different configurations and operating conditions. In particular, the number of pressure steps in the 1R cycle could be reduced from seven to four with a decrease of only about 4% in the cooling COP. Further reduction to three pressure steps reduced the COP another 10%. These results showed that a substantial reduction in cycle complexity (and therefore in manufacturing cost and operating reliability) is possible with only a small decrease in cycle efficiency. The four-pressure-step 1R cycle was calculated to operate at about 65% of the Carnot COP over the full operating range.

The design of the ADR-cycle heat pump was modified to simplify considerably its manufacture and reduce its cost, only modestly reducing its efficiency. Because the ADR cycle uses a higher input temperature than does the 1R cycle, the efficiency of the ADR cycle is expected to be less sensitive to the number of pressure steps. This was confirmed in simulations of ADR cycle performance using the HPSIM model. Reduction from seven to three pressure steps resulted in a negligible decrease in the cooling COP over the full range of operating conditions. A

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Solar Heat Technologies, Solar Buildings Technology Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098; the Department of Engineering Research, Pacific Gas and Electric Company under Contract No. Z19-5-269-87; and the Oak Ridge National Laboratory under Contract No. 10X-SB315V.

further reduction to two pressure steps produced a COP reduction of 10–15%.

We then calculated the expected performance of a three-pressure-step ADR heat pump for a full range of cooling-mode and heating-mode operating conditions. At standard ARI rating conditions, the cooling-cycle COP is about 1.69 using water-cooled operation and about 1.35 using air-cooled operation. The heating-cycle COP is about 2.13 at 47°F outdoor temperature, and about 1.66 at 17°F outdoor temperature. These are cycle COP values and do not include combustion efficiency or parasitic electric power for the pumps or fans.

A "first-cut" manufacturing cost study was conducted by Pioneer Engineering and Manufacturing Company for a four-pressure-step ADR heat pump. Detailed cost estimates were made for the new heat exchangers unique to the ADR heat pump design, and existing cost estimates were used for components common to other heat pumps operating at the same pressures and using ammonia as the refrigerant. A rough estimate for the solution pump cost was based on available information, resulting in an estimated total manufacturing cost of about \$1550 for a 3-ton ADR heat pump. A similar cost study for a three-pressure-step design would be expected to result in a slightly lower cost. Iteration in design detail could also have a substantial effect on reducing manufacturing cost.

A primary objective of the joint U.S./Israel project being conducted by the Technion and LBL is to develop a simulation model suitable for all types of absorption chiller and heat pump cycles. Initial attention is being focused on the generator-absorber heat exchange (GAX) cycle because it is likely to be the first advanced absorption cycle to be available commercially and is therefore a candidate for being driven by evacuated-tube solar collectors that can operate efficiently up to 400°F.

Accordingly, the Technion and LBL are using separate calculations of GAX cycle performance as a measure of agreement between the various computer models for absorption cycles. The intention is to combine the best solution methods into a single computer model, which will most likely be an improved version of the user-friendly model originated by the Technion group. The GAX cycle was successfully simulated at LBL using HPSIM, and intercomparisons of LBL and Technion results of GAX cycle simulations—as well as resolution of any differences that may occur using different models—are expected to take place during FY 1989.

Simulation Research*

F.C. Winkelmann, B.E. Birdsall, W.F. Buhl, K.L. Ellington, A.E. Erdem, J.M. Nataf, and E.F. Sowell[†]

The Simulation Research Group (SRG) has the long-term objective of providing the architectural, engineering, and research communities with software tools to assist in the design of energy-efficient, cost-effective buildings. The ongoing research of the SRG has two main focuses: 1) to develop and maintain the current-generation benchmark program (DOE-2), and 2) to develop the next generation of building performance calculation tools (the Energy Kernel System).

DOE-2 is a public-domain computer program which, given a description of a building's climate, architecture, materials, operating schedules, and HVAC equipment, performs an hour-by-hour simulation of the building's expected energy use and energy cost. DOE-2 is widely used in the United States and 35 other countries to design energy-efficient buildings, analyze the impact of new technologies, and to develop energy conservation standards. Details of the development and structure of the DOE-2 program are available.¹⁻¹¹

The Energy Kernel System will provide basic tools and information to allow SRG and other groups to develop future simulation programs. It will also provide a mechanism for exchanging research results and technology advances, and a basis for integrating performance simulation into computer aided design (CAD) and expert system software.

DOE-2

SRG maintains a research effort to develop enhanced versions of DOE-2. This ongoing research is divided into three parts: 1) introduction of algorithm description techniques into the code; 2) modeling of building envelope components and systems; and 3) simulation of HVAC equipment and associated control systems. The next version of the program, DOE-2.1D, is scheduled for public release in FY 1989. Several major new features follow:

User-Defined Functions. A new FUNCTION command added to the DOE-2 SYSTEMS program permits modification, enhancement, or replacement of DOE-2 calculations without recompiling the program. Users write

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division of the U.S. Dept. of Energy under Contract No. DE-AC03-76SF00098.

[†]Visiting scientist. Permanent address: Department of Computer Science, California State University at Fullerton, Fullerton, California.

their own algorithms in a FORTRAN-like language and place this information in their input, along with information indicating how and where the new algorithms are to be used. This feature allows researchers to add new HVAC simulation features, such as innovative control schemes, that could not be modeled by the regular DOE-2 calculations.

Generalized Library. A new library feature allows DOE-2 users to create custom libraries containing descriptions of any building component or system of components. Libraries may be defined to contain such data as room geometry, standard operating schedules, or frequently used HVAC system descriptions. This feature will greatly simplify input preparation.

Improved Fenestration Calculation. Because heat gain and loss through windows greatly affects the energy performance of most buildings, DOE-2 window thermal calculations are being improved to calculate automatically the shading of diffuse solar radiation by neighboring buildings and by architectural elements such as overhangs (previously only the shading of direct solar radiation was calculated); to more accurately calculate skyward infrared radiation loss from the building envelope, taking into account atmospheric conditions and architectural obstructions; and to more accurately calculate the amount of sky diffuse radiation falling on windows and walls.

Desiccant Cooling. In most climates, occupant comfort during warmer months requires that room air be dehumidified. Several companies are developing desiccant cooling systems in which a hygroscopic material such as lithium bromide removes moisture from the supply air stream. The desiccant is "regenerated" for further use by drying it with hot air from a gas-fired heater. Gas-fired desiccant systems of this type can replace or supplement conventional electric-driven cooling systems; however, almost nothing is known about the economics of desiccant systems for different climates, building types, and utility rate structures. For this reason, SRG (with funding from the Gas Research Institute via the GARD Division of the Chamberlain Manufacturing Corporation) is creating DOE-2 models to simulate the performance of a variety of desiccant systems currently under development. GRI will use these DOE-2 models to identify the most cost-effective desiccant cooling schemes.

Advanced Simulation

In recent years, the search for more efficient building designs has led to components, systems, and whole building structures which are extremely complex and therefore difficult to analyze. Because existing programs like DOE-2 were initially conceived in an era when design questions were much simpler than they are today, the analytic capabilities of these programs are fundamentally limited. Generalized, computationally efficient, easily extendible techniques are needed to accurately simulate the interactions between building-envelope components and HVAC equipment. Analysis of complex designs and advanced technologies requires substantially improved building perfor-

mance simulation programs. To continue to meet DOE's long-term objective of providing up-to-date and reliable analysis tools, basic research has begun into new simulation techniques. This work will lead to replacement of DOE-2 with a tool designed to meet the needs of architects and engineers in the 1990's.

An international collaborative effort between SRG and research groups in the U.K. has been initiated to produce the new software. This effort will provide not only a significant advance in building performance simulation but also a mechanism for communicating and exchanging results among diverse communities of designers and researchers.

Within the general goals and structure of the advanced simulation software,¹²⁻¹⁵ the primary goal is to provide a software environment (the **Energy Kernel System** or **EKS**) for developing new simulation programs. This environment would allow a high level of model construction flexibility and facilitate state-of-the-art integration of new techniques with old. Other goals are to permit different modeling approaches, to encourage collaboration among model developers, and to take advantage of emerging software engineering in the area of multiprocessing.

The EKS (Figure) will consist of 1) a library of software modules or *objects* representing different building components, physical processes, and mathematical solution techniques, and 2) an executive program or *harness* which allows users to link software objects to form customized energy models. The EKS user will first construct a *template* which defines a model as a collection of objects and a set of messages controlling the order of execution of the objects and the flow of information among them. The template is used by the harness to construct the final program in the form of source (or executable) code.

The EKS is designed for use by model *developers*, not by model users. It is intended to be an efficient way of creating simulation models that can be used in a stand-alone fashion or for integration into multipurpose environments such as computer-aided design (CAD) systems, expert systems, or energy management systems.

SPANK: A Prototype Energy Kernel System. In FY 1986 the SRG began developing new software called the Simulation Problem ANALysis Kernel (SPANK) as a first prototype of the EKS.^{16,17} SPANK views a simulation problem as a network — the nodes represent nonlinear equations, and the lines linking the nodes (called links or arcs) represent variables in the equations. The network representation of a simulation problem is completely equivalent to describing the problem as a set of simultaneous, nonlinear algebraic and differential equations. The network representation allows use of graph theory techniques to reduce the size of the problem to be solved.

A simulation problem in SPANK consists of a set of coupled equations. Each equation or relation among variables is known as a *primitive object*. Primitive objects may be combined into *macro objects*, and primitive and macro objects can be combined into more complex macro objects. Thus modules (sets of equations) which represent complicated physical processes or entities can be built up




Figure 1: Proposed Energy Kernel System for creating building energy simulation models. (XBL 8712-5767)

from simple components. After the necessary objects (simple or complex) are defined, the problem description is completed by “linking” the objects together, i.e., by specifying the variables common to given equations.

Users need only define the simulation problem and do not need to choose a computation sequence (e.g., write a procedural algorithm in FORTRAN or other language) to solve the set of equations.

SPANK creates the solution sequence in two steps. First, a particular relationship (equation) is selected for each variable and inverted to give a formula for that variable. After the matching is accomplished, the second step is to find a set of break variables—a *cut set*, that become the iteration variables in the solution sequence. (Initial values are guessed and then used to solve for all the variables using the set of relationships. This procedure yields new values for the cut set variables. A scheme such as Newton-Raphson iteration is then used for choosing the next guess for the cut set.)

When faced with solving a system of nonlinear equations, most simulation programs simply iterate on all the variable, i.e., the cut set includes all variables in the problem. One of SPANK’s major contributions is to use graph theory methods to reduce the cut size greatly and thus effectively reduce the problem size.

In FY 1988, object-oriented techniques were developed to allow SPANK to simulate time-dependent

processes by integrating first-order differential equations.¹⁸

In FY 1988, we will continue to maintain and support the DOE-2 program and to publish the quarterly *DOE-2 User News*. An improved version of the program, DOE-2.1D, will be completed and released to the public.

The SPANK program will be released for outside review after in-house testing of new SPANK features, including a graphics-based input processor, dynamic simulation, and symbolic manipulation of objects. Detailed specifications for the EKS will be developed.

REFERENCES

1. LBL Simulation Research Group, *DOE-2 Supplement, Version 2.1C*, LBL-8706 Rev. 4., 1984, Suppl.
2. LBL Simulation Research Group, *DOE-2 BDL Summary, Version 2.1C*, LBL-8688 Rev. 4, 1984.
3. LBL Simulation Research Group, *DOE-2 Users Guide, Version 2.1A*, LBL-8689 Rev. 3, 1981.
4. LBL Simulation Research Group, *DOE-2 Sample Run Book, Version 2.1C*, LBL-8678 Rev. 2.
5. LBL Simulation Research Group [LBL] and Group Q-11 [LANL]. *DOE-2 Reference Manual, Version 2.1C*, LBL-8706 Rev. 4, 1984.
6. Diamond SC, Hunn BD. *DOE-2 Verification Project: Phase 1, Interim Report*, LANL Publication LA-8295-MS, 1981; Diamond SC, Capiello CC, Hunn BD.

- DOE-2 Verification Project: Phase 1, Final Report, LANL Publication LA-10649-MS, 1986.
7. Hirsch JJ. *Simulation of HVAC Equipment in the DOE-2 Program*, LBL-14026, 1982.
 8. Simulation Research Group. *Overview of the DOE-2 Building Energy Analysis Computer Program*, LBL-19735, 1985.
 9. Simulation Research Group [LBL] and Group Q-11 [LANL]. *DOE-2 Engineers Manual, Version 2.1A*, LBL-11353 and Los Alamos National Laboratory Publication LA-8520-M, 1982.
 10. Winkelmann FC, Selkowitz S. Daylighting Simulation in the DOE-2 Building Energy Analysis Program, *Energy and Buildings*, 1986; 8:271.
 11. Buhl WF, Erdem AE, Eto JH, et al. *New Features of the DOE-2.1C Energy Analysis Program*, LBL-19870, 1985.
 12. Buhl WF, Erdem AE, Hirsch JJ, et al. *A Proposal to Develop a Kernel System for the Next Generation of Building Energy Simulation Software*, Lawrence Berkeley Laboratory, 1985.
 13. Hirsch JJ. *Plan for the Development of the Next Generation Building Energy Analysis Computer Software*, LBL-19830, 1985.
 14. Clarke JA, Hirsch JJ, Buhl WF, et al. Planned Developments in Building Energy Simulation. In: *Proceedings of the 5th CIB Symposium on Energy Conservation in the Built Environment*, Bath, England, 1986.
 15. Winkelmann FC. Advances in Building Energy Simulation in North America, *Energy and Buildings* 1987; 11:161.
 16. Anderson JL. *Network Definition and Solution of Simulation Problem*, LBL-21522, 1986.
 17. Sowell EF, et al. Prototype Object-Based System for HVAC Simulation. In: *Proceedings of the Second Systems Simulation Conference*, Liege, Belgium. LBL-22106, 1986.
 18. Sowell EF, Buhl WF. *Dynamic Extension of the Simulation Problem Analysis Kernel*. LBL-26262, 1988.

WINDOWS AND LIGHTING PROGRAM

INTRODUCTION

Over 30% of all energy used in buildings is attributable to two elements: windows and lighting. Together they account for annual consumer expenditures of over \$50 billion. Each affects not only energy use by other major building systems but also comfort and productivity, factors that have a far greater influence on building economics than direct energy consumption alone. Windows play a unique role in the building envelope, physically separating the conditioned space from the world outside without sacrificing vital visual contact. Lighting systems facilitate a variety of tasks with a wide range of visual difficulty throughout the indoor environment while defining the luminous qualities of the indoor environment. These two building elements are thus essential components of any comprehensive building science program.

Despite important achievements in reducing building energy consumption over the past decade, significant additional savings are still possible. These will come from two complementary strategies: 1) better building designs that effectively apply existing technology and extend market penetration, and 2) new advanced technologies to increase the savings potential of each application. Both the Windows and Daylighting Group and the Lighting Systems Research Group have made substantial contributions in each of these areas. The ongoing research described in the annual summary aims to further advance achievement of these goals.

The **Windows and Daylighting Group** focuses on developing the technical basis for understanding and improving the energy-related performance of windows. If the flow of heat and light through windows and skylights can be properly filtered and controlled, these building elements can outperform any insulated wall or roof component and provide net energy benefits to the building. The group's investigations are designed to develop the capability to accurately predict net fenestration performance in residential and commercial buildings. Simulation studies, field measurements in a mobile field test facility, and building monitoring studies help us to understand the complex tradeoffs in fenestration performance. The research program is conducted with the participation and support of industry, utilities, universities, design professionals, and government. The Group's three major project areas are optical materials, fenestration performance, and building applications and design tools.

In our studies of optical materials and advanced concepts, we develop and characterize thin-film coatings and other new optical materials that control radiant and thermal flows through glazings. Innovative concepts for

large-area envelope enclosures are studied. The program helped accelerate the development and market introduction of windows incorporating high-transmittance, low-emittance (low-E) coatings for R3-R5 windows. If sales follow current trends, by the year 2000 these coatings will save consumers over \$3 billion annually in heating bills alone.

Our research on window performance aims to develop new analytical models and experimental procedures to predict the thermal and solar-optical properties of the complex assemblies of glazing materials and shading devices that compose complete fenestration systems. Thermal performance models are being validated with the Mobile Window Thermal Test (MoWiTT) Facility, now collecting data at a field test site in Reno, Nevada. This unique facility combines the accuracy and control of lab testing with the realism and complexity of dynamic climatic effects. LBL daylighting studies employ a unique 24-foot-diameter sky simulator (for testing scale models under carefully controlled conditions), and new experimental facilities for measuring the photometric and radiometric properties of complex fenestration systems.

Building applications studies and design tools help us to understand the complex tradeoffs in fenestration performance as a function of building type and climate. In nonresidential buildings, major reductions in electric energy use and peak electric demand can be achieved if the tradeoffs between daylight savings and solar-induced cooling loads are understood. We are developing concepts for an Advanced Envelope Design Tool using new imaging techniques and expert systems.

The research of the **Lighting Systems Group** is divided into three major areas: advanced light sources, building applications, and impacts on productivity and health.

Our research on advanced light sources is concerned primarily with developing new technical concepts for efficiently converting electrical energy into visible light. Areas of interest include mechanisms for reducing ultraviolet self-absorption in gas-discharge lamps and excitation of the lamp plasma by radio frequency (RF) electromagnetic fields. Both areas promise more efficient conversion of electrical energy into visible light, and possibly much longer lamp life.

Our building applications research concentrates on design of lighting systems, effective use of lighting controls, and how these factors interact with a building's HVAC system.

Research in visibility concentrates primarily on gaining basic information needed to define lighting conditions that enhance productivity in a cost-effective

manner. We also seek to determine any possible undesirable visual effects such as visual fatigue, related to glare and lighting, especially as these events affect the automated workplace.

Our studies of health impacts extend electric lighting research to a wider class of human activities. In a specially designed experimental room, lighting conditions are controlled and human responses are measured objectively by sensitive instrumentation.

The Lighting Group's successes include advancing the development of high-frequency solid-state ballasts for fluorescent lamps and the invention of a new high-frequency surface wave lamp with 30% better efficiency than the common fluorescent lamp. A 2-year test of solid-state ballasts in a large office building showed an electricity savings of 40%. Scaled to the entire country, this represents an annual savings of \$5 billion. The energy-efficient surface wave lamp promises major reductions in energy use with considerably longer lamp life.

Windows and Daylighting*

S.E. Selkowitz, D. Arasteh, C. Benton, D.L. DiBartolomeo, R.L. Johnson, J.J. Kim, J.H. Klems, C.M. Lampert, K. Papamichael, M.D. Rubin, R. Sullivan, and G.M. Wilde

Approximately 20% of annual energy consumption in the United States is for space conditioning of residential and commercial buildings. About 25% of this amount is required to offset heat loss and gain through windows. In other words, 5% of U.S. energy consumption—the equivalent of 1.7 million barrels of oil per day—is tied to the performance of windows. Fenestration performance also directly affects peak electrical demand in buildings, sizing of the heating, ventilating, and air-conditioning (HVAC) system, and the thermal and visual comfort of building occupants, as well as their health and productivity.

With more intelligent use of existing technology and with development of new high-performance window materials, windows can be converted from energy liabilities to energy benefits. The aim of the Windows and Daylighting Group is to develop the tools and technologies to accomplish this goal. Research is required to develop the new technologies and capabilities to predict and improve the thermal, energy, and daylighting performance of windows and skylights. The group's work helps generate guidelines for design and retrofit strategies in residential and commercial buildings and contributes to development of advanced computer-based tools for building design.

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Buildings and Community Systems, Building Systems Division, and Office of Solar Heat Technologies, Solar Buildings Division, of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

Our program's strength lies in its breadth and depth: we examine energy-related aspects of windows at the atomic and molecular level in our materials science studies, and at the other extreme we perform field tests and in situ experiments in large buildings. We have developed, validated, and now use a unique, powerful set of computational tools and experimental facilities. Our scientists, engineers, and architects work in collaboration with researchers in industry and academia.

To be useful, the technical data developed by our program must be communicated to design professionals, industry, and others in the public and private realms. We publish our results and participate in industrial, professional, and scientific meetings and societies, national and international, to ensure that our research results are widely disseminated and utilized.

Our research is organized into three major areas:

- Optical Materials and Advanced Concepts
- Fenestration Performance
 - Thermal analysis
 - Daylighting analysis
 - Field measurement of performance
- Building Applications and Design Tools
 - Nonresidential buildings
 - Residential buildings
 - Design tools

OPTICAL MATERIALS

Significant reductions in energy consumption of buildings will come not only from better building design, but also from the development and introduction of new glazing materials. Since the inception of our program in 1976, we have worked to identify, characterize and develop promising new optical materials to assist industry with developing the next generation of advanced fenestration systems. We also provide scientific coordination for DOE-funded research projects at universities, private-sector firms, and other national laboratories, and work to transfer our research results to the private sector.

In 1976, we made the development of low-emittance (low-E) coatings a major program objective, and our DOE-supported research subsequently accelerated market introduction of high-performance low-E window systems. Several small firms began offering commercial products in 1982, and by 1985 most of the largest glass and window manufacturers offered low-E products. Incorporating low-E coatings into conventional double-glazed windows produces a lighter, more compact unit with better thermal performance than triple-glazed windows. Ultimately windows using this coating technology could have heat transfer values as low as those of insulating walls, and save more energy annually than the best-insulated wall.

DURABLE LOW-EMITTANCE COATINGS

The objective of this project is to develop a second-generation low-E coating with high transmission and clarity that will last for the lifetime of a window. Among low-E coatings made today, those based on sputtered

silver have the best optical properties and lowest emissivity. Silver, however, is a soft metal and is subject to agglomeration and loss of optical quality. We began by studying titanium nitride, a material that combines optical properties similar to those of a noble metal with the mechanical and chemical durability of a ceramic. Using advanced deposition techniques and multilayer design, we were able to produce coatings with properties exceeding those of the best commercial coatings. This year we began investigating diamond-like films for use as protective and antireflection layers for metallic low-E coatings. The first task was to deposit diamond-like films using standard industrial sputtering technology. These films tend to have low transmittance in the visible spectrum; we were able to increase transmittance by varying the deposition parameters. Figure 1 shows the beneficial effect of reducing sputtering power on the transmittance of diamond-like films. Next year we will continue to optimize the optical properties of diamond-like coatings on silver and test their durability in collaboration with industrial partners.

LOW-CONDUCTANCE GLAZINGS

With the commercial success of R3-R4 windows incorporating coatings and gas-filled insulated glass (IG) units, the next major challenge lies in increasing the R-value of windows' center-of-glass, edge-of-glass, and frame areas. In FY 88 we continued to develop our concept for a high-R window that can be manufactured using existing industrial production facilities. This high-R window is based on an innovative modification of conventional triple glazing. Two low-E coatings are placed on surfaces facing each of two krypton- or krypton/argon-filled gaps. Such a design can achieve center-of-glass R-values between 6 and 10. However, the use of conventional metal spacers to separate the glazing layers creates a large two-dimensional thermal bridge at the outer edge of the IG unit. Furthermore, even the best wood frame will degrade the thermal performance of such a window.




Figure 1. Total solar and visible transmittance versus fraction of H_2 flow in the Ar/H_2 mixture at 200 W. (XBL 892-643)

This year we collaborated with four major window manufacturers to design prototype high-R windows for demonstration home projects set up by electric utility companies in Montana and Wisconsin. Frame and edge designs were modified to reduce heat transfer in these areas. Field monitoring and MoWiTT testing of these windows is planned for FY 89. This work was supported by the Bonneville Power Administration and the Wisconsin Power and Light Company, as well as the U.S. DOE.

OPTICAL SWITCHING MATERIALS

Optical switching materials can be used to dynamically regulate the transmission of windows in buildings and automobiles. Initial studies of energy simulation of office buildings indicate that an automatically controlled switchable coating can provide substantial energy savings in lighting and cooling as well as economic benefits in reduced HVAC system size. The transmittance of a window can be controlled either by electrochromic, thermochromic, photochromic, or liquid crystal materials. Electrochromic devices appear to have the best combination of properties for window applications, including a wide-dynamic visible transmittance range (possibly 8:1 transmittance change), moderately fast switching times, and low power consumption.

During FY88 we developed component layers for the fabrication of devices. The component layers consist of the following materials: 1) electrochromic, 2) ionic electrolyte/conductor, and 3) ion storage. All of our devices are based on electrochromic nickel hydroxide. The best nickel hydroxide layers are deposited by anodic electrochemical deposition using sulfate/nitrate solutions developed by our group. In addition we have made films of nickel hydroxide and vanadium oxide by reactive d.c. sputtering. The optical and electrochemical properties of the films have been investigated using optical spectroscopy and cyclic voltammetry. We have synthesized a quarternary ammonium hydroxide polymer for use as an electrolyte in the device. This polymer has ionic conductivity of $8 \times 10^{-2} S/cm$. Devices using this polymer exhibited an integrated photopic response of 70-21% between bleached and colored states (Figure 2).

Our research in FY 89 is directed at improving the durability of the polymer electrolyte, altering the oxidation potential of nickel hydroxide by doping, and developing ion storing electrodes with compatibility to nickel hydroxide. Materials we will study for ion storage include manganese and niobium oxide. To simplify analysis, we will develop computer controlled instrumentation to perform in situ optical and electrochemical experiments.

CORE DAYLIGHTING SYSTEM DESIGN

Outdoor illuminance levels under clear skies are typically 100 times greater than required indoor illuminance levels. If just a fraction of the sunlight falling on a building could be distributed to core building zones, daylight could offset a building's entire electric lighting load during sunny periods, with automatically dimming electric




Figure 2. Electrochromic nickel oxide device shown in its colored and transparent states. (CBB 887 6776A)

luminaires providing light at other times. Several core daylighting systems have been developed, and one Japanese system is in commercial production, but these systems are not cost-effective on the basis of their energy savings. We have developed a new design, however, that could supply daylight to core building zones with a cost-effective optical technology.

Our previous work showed that direct sunlight can be channeled to core building zones through light guides small enough for retrofit as well as new-building applications. To attain this level of optical concentration, the system would use tracking solar collectors maintaining stringent tracking and optical imaging tolerances. A practical and economical collector design to achieve these tolerances was developed in FY 87. During FY 88 we developed an algorithm for optimizing the collector's mechanical design; analyzed the radiative heat gain in the system's plastic optical fiber elements and concluded that with proper design thermal gains would not exceed the fibers' thermal tolerance limit; refined the optical theory underlying the collector's Fresnel lens design and filed an initial patent application for a mechanism that substan-

tially eliminates chromatic dispersion in the lens; and developed software for completing the optical design for the overall core daylighting system.

We will continue developing the collector's optical and mechanical design and will refine our estimates of the system's performance characteristics, cost parameters, and projected energy savings. Since subjective response to the interior environment is an important element in overall system design and cost effectiveness, we will consider using the Radiance program to evaluate the system's illumination quality and its interaction with dimmable electric lighting. This software would be used as a design guide not only in the development of core daylighting systems, but also for analyzing new optical component designs for window and skylight applications.

ADVANCED GLAZINGS FOR AUTOMOBILES

Solar heat gain accounts for a large proportion of the cooling loads requiring automobiles to be built with large, high-capacity air conditioners, which in turn release significant amounts of chlorofluorocarbons (CFCs) into the atmosphere. As part of its program to reduce CFC emissions from auto air conditioners, the Environmental Protection Agency supported a study to determine the potential for reducing air conditioner size by using advanced glazing with selective transmittance properties for controlling solar heat gain. Our objective was to define the relative performance of a range of real and hypothetical absorptive and reflective glazings under static-soak and cool-down conditions.

We completed an extensive analysis of the effects of glazing and ventilation options in standard and sports-model sedans by running parametric simulations of a wide range of absorptive and reflective glazing components using a finite-difference computer program. Figure 3 shows the peak interior air temperature under static-soak




Figure 3. Peak interior air temperatures for standard and sports sedans as a function of solar transmittance. Values occur at 3 p.m. and are shown for reflective and absorptive glazings. (XBL 892-646)

conditions in Phoenix, Arizona, for glazings of varying solar transmittance. The absorptive and reflective curves represent limiting values of these properties. Our final report includes an annotated bibliography of work on solar-load control for automobiles in the form of a hyper-text computer program. This gives users quick and easy access to a large volume of data that would otherwise be too cumbersome for convenient use.

Our future work will relate auto air conditioner performance and glazing characteristics to actual fuel use. Although we know that gasoline consumption increases with air conditioner use, the potential for improving fuel efficiency has not been thoroughly studied. We plan to perform analytical and experimental investigations under a variety of driving conditions in several climates. We also expect to begin development of new coating technology to meet the performance requirements we have identified.

FENESTRATION PERFORMANCE

Research activities in this area are intended to characterize the performance of fenestration components and complete systems over the entire range of operating conditions in any climate or building type. The research develops and refines experimental techniques and analytical models for accurately determining heat-transfer and solar-optical properties of fenestration components and systems and validates these models in field-test facilities and occupied buildings. Many of the new algorithms and data sets are designed to be incorporated into hour-by-hour building energy simulation programs such as DOE-2.1. These data not only improve the accuracy of our predictions but also allow us to predict the performance of new fenestration systems and novel architectural designs. Our plan for developing and implementing these new analysis capabilities in energy simulation models is shown schematically in Figure 4.

THERMAL ANALYSIS

With the wide acceptance of low-E coatings and the introduction of low-conductance gases by the window industry, the number of possible window configurations has multiplied rapidly, creating a need for an accurate, convenient, and standard calculational procedure to determine window heat-transfer indices. The Windows and Daylighting Group developed a computer program to fill that need. WINDOW 2.0 was released in 1986 and distributed by LBL and a major window sealant manufacturer as a professional courtesy to over 800 window and IG-unit manufacturers. The program has since become the de facto standard in the industry, and our efforts to develop WINDOW and make it available to the private sector were recognized by the Federal Laboratory Consortium's 1988 Special Award for Excellence in Technology Transfer.

In FY 88 we added many new technical and user-friendly features to an updated version of the program. Users of WINDOW 3.1 have easy access to libraries of component information and can easily build or change a window and see the resultant thermal properties on the

same screen. Version 3.1 includes help screens, and its operation is consistent with standard MS-DOS software. WINDOW 3.1 is being distributed by window and sealant manufacturers, and other industry organizations have also expressed interest in distributing this program to their members.

Our early work emphasized center-of-glass U-values, but glass-edge and frame effects are known to be significant, particularly in high-performance windows. We have begun a thermal analysis program to study these two-dimensional heat transfer effects (Fig. 5). Results from these finite-element models will be incorporated into libraries in WINDOW 3.1 in order to give the user heat-transfer properties indicative of complete windows and not just center-of-glass performance. These finite-element models have been used to study pressure and temperature induced stresses in high-performance glazings.

In FY 89 we expect to use thermographic techniques in conjunction with more extensive finite-element modeling to develop and validate the library of sash and frame heat-transfer effects. These tools will also allow us to explore the problems associated with condensation on glass edges and frames.

DAYLIGHT AND SOLAR HEAT GAIN STUDIES

Providing daylight to building interiors is one of fenestration's most important functions, both from an energy perspective and from an occupant's point of view. However, the solar heat gain associated with daylight can be a benefit or cost, depending on circumstances. Analyzing the trade-offs to arrive at an optimum solution for simple glazings is difficult; for complex fenestration with sophisticated sun control systems it is virtually impossible with currently available tools. Our objective is to develop the experimental facilities and analysis models to accurately characterize the daylight and solar heat gain from fenestration systems of arbitrary complexity. We conduct a wide range of activities to establish the facilities, tools, and data to address these problems.

Solar-Optical Properties of Complex Fenestration Systems

A quantitative understanding of the solar-optical properties of fenestration systems is essential to accurately predict their luminous and thermal performance for any sun, sky or ground conditions. "Luminous performance" refers to daylight illuminance and luminance levels that determine electric lighting requirements and visual comfort. "Thermal performance" refers to solar heat gain levels that determine heating or cooling requirements and thermal comfort.

We are developing a method of calculating the solar and daylight transmission through complex fenestration systems from laboratory measurements of the solar-optical properties of window components. The method treats fenestration systems as radiation sources of varying-intensity distribution. For diffusing, diffusely reflecting, or geometrically complex components such as blinds or




Figure 4. Schematic diagram of overall fenestration modeling capabilities under development includes new measurement facilities, computer models, and intermediate calculated and measured results. Direct measurement of some intermediate calculated results provides a validation check. (XBL 885-1479)




Figure 5. a) Cross section of window edge and frame. Glazing layers are separated by a desiccant-filled metal spacer sealed inside a wood sash that rests on a wood frame. b) Vector plot of two-dimensional heat transfer through the window section shown in (a). Warm interior is at left, cold exterior at right. Size of vector denotes magnitude of heat transfer; arrow denotes direction. All glass two-dimensional heat transfer occurs within the bottom 2.5 inches of glass panes modeled. Small vectors appear as dots. (XBB 892-642)

drapes, bidirectional solar-optical property measurements are necessary. We have developed a large-scale, automated scanning radiometer/photometer to make these measurements (Fig. 6). Computer software will compute the luminous or radiant distribution transmitted by a complete fenestration system for a given set of exterior conditions by combining the properties of component layers while correctly accounting for multiple reflections. During FY88 we initiated a cooperative project with support from DOE and ASHRAE to make this method the basis for a new treatment of solar heat gain through fenestrations. Scanning radiometer measurements will be made on a representative sample of fenestration components, the completed software will be used to calculate the solar heat gain, and the method will be validated by comparison with measurements made with the Mobile Window Thermal Test Facility (MoWiTT).

DAYLIGHTING ANALYSIS

The prediction of lighting quantity and quality in the luminous environment is essential for energy-efficient lighting design. Over the years, we have developed a range of daylighting design tools to expand our modeling capabilities and improve calculational accuracy. Our most advanced daylighting simulation model, SUPERLITE 1.0, was converted to run on an IBM-compatible personal computer in FY88. We continued our efforts to expand




Figure 6. Scanning radiometer for measuring the bidirectional transmittance and reflectance of fenestration components and systems. (BBC 887-6823)

SUPERLITE capabilities to model more sophisticated daylighting systems such as complex sun control and shading systems. This work includes developing and upgrading modeling algorithms and initial efforts to create a photometric data base containing the complex optical properties of shading systems required by SUPERLITE. (Related work on the measurement of these properties is discussed in the earlier section titled "Daylight and Solar Heat Gain Studies.")

We also plan to develop tools to assist designers in qualitative assessment of daylighted environments by using the numerical output of the SUPERLITE program to produce luminance maps of light distributions in architectural spaces.

In FY89 we will provide an initial library of shading system optical properties for SUPERLITE using data from our luminance scanner. Further collaborative work with other university-based groups will be directed toward improving the ease of use of the microcomputer version of the program and enhancing its input/output capabilities.

The Sky Simulator and Daylight Photometric Laboratory

Scale-model photometry is a powerful tool for daylighting design and analysis. Our 24-ft-diameter hemispherical sky simulator (Fig. 7), located on the University of California's Berkeley campus, simulates the effects of uniform, overcast, and clear skies. Sky luminance distributions are reproduced on the underside of the hemisphere; light levels are then measured in a scale-model




Figure 7. Interior of sky simulator shows reconfigurable scale model of a five-story atrium (with one side of model removed). (CBB 848-5926)

building at the center of the simulator. From these measurements, we can accurately and reproducibly predict daylighting illuminance patterns in real buildings and thereby facilitate the design of energy-efficient buildings. The facility is used for research, for educational purposes, and on a limited basis by architects working on innovative daylighting designs.

FIELD MEASUREMENT OF FENESTRATION THERMAL PERFORMANCE

We have known for some time that winter solar heat gain through south-facing windows in conventional buildings is a significant source of "free" energy. Subsequent calculations have indicated that it is technically possible, for any orientation in any U.S. climate, to optimize windows to the point that they become positive contributors to a building's energy needs.

This claim is not likely to be widely accepted without firm experimental verification. However, to measure the performance of highly optimized window systems in a realistic way is a formidable measurement task, requiring specialized non-steady-state calorimetry on a scale never previously attempted.

To perform these measurements, the Mobile Window Thermal Test Facility (MoWiTT) was designed, built and calibrated. In developing this facility (Fig. 8), it was necessary to solve the problem of doing calorimetry on a



Figure 8. The MoWiTT facility at its field test site in Reno, Nevada. Two sealed insulating glass units are mounted in the two calorimeters. Portable building at left contains computer that controls the facility and records data, including data from on-site weather tower. (CBB 892-812)

room-sized enclosure (which would normally require careful maintenance of constant equilibrium conditions) in the presence of the solar fluxes and changing outdoor temperatures which control the behavior of a fenestration system. We solved this problem with a large-area heat flux sensor (developed as part of the project) and a very sophisticated measurement of the heat extracted from the calorimeter by its cooling system. The MoWiTT began operation in 1986 at a field-test site in Reno, Nevada.

During FY88 we completed a study of windows with frames (a cooperative study with support from the Bonneville Power Administration), which demonstrated that calculated U-values agree well with field measurements, provided that there is adequate knowledge of the local weather conditions. In most cases, results were also consistent with laboratory measurements of U-value; however, laboratory measurements appeared to be questionable for highly conductive frames. This study provides the first convincing evidence that U-value calculations can accurately predict field performance, a question which has been the subject of controversy for more than a decade. The study also demonstrated that the diffuse solar heat gain admitted by north-facing or shaded windows has a significant effect on the daily winter energy balance. This heat gain is frequently neglected in estimates of winter heat loss.

We have also begun measurements of solar heat gain and the inward flowing fraction of absorbed solar energy for windows with shading systems. These measurements form part of the cooperative study of solar heat gain undertaken with partial support from ASHRAE and described above (see Daylight and Solar Heat Gain Studies).

In 1989 we will extend our studies to include higher-performance windows and superwindows, continue the solar heat gain study, and explore the effect of common

shading systems on winter energy performance. We will utilize our data in support of a joint US/Canadian project to standardize the calculation of window U-values.

These measurements with the MoWiTT have the potential for removing uncertainties about window performance that have slowed progress in energy conservation for the past decade.

BUILDING APPLICATIONS AND DESIGN TOOLS

The development of new glazing materials and experimental characterization of fenestration system performance must be complemented by translating the benefits of such information to the building design community. The objective of our building applications activities is to apply the knowledge gained from our basic science research to real-world buildings and develop the tools to disseminate this information.

SIMULATION STUDIES: NONRESIDENTIAL BUILDINGS

Our goal is to develop a microcomputer-based fenestration performance design tool. The first phase of the project, supported by a contract from the Lighting Research Institute and DOE, has been to define a methodology for evaluating overall fenestration performance and construct a data base for conventional fenestration systems and complex operable shading systems. The second phase entails the development of the actual design tool.

A large part of our effort was directed toward reporting the results of Phase 1. In addition to completing the final report, "Commercial Building Fenestration Performance Indices Project, Phase 1: Development of Methodology," we presented a second paper, "An Approach for Evaluating the Thermal Comfort Effects of Nonresidential Building Fenestration Systems," at a comfort symposium and explained the methodology used to define comfort indices. A third paper, "An Indices Approach for Evaluating the Performance of Fenestration Systems in Non-residential Buildings," describes the overall methodology and was presented at an ASHRAE technical conference.

We began development of the microcomputer-based design tool with special emphasis being placed on the design of the user interface. Of particular importance was our study of the combination of text and graphics that are necessary to give potential users an intuitive sense of the tool's purpose and use. We also implemented several of the algorithms derived during the analytical phase of the project. Figure 9 shows an output screen from this prototype tool. Menu items are shown along the left hand side and the bar diagrams represent calculated values for four fenestration systems.

In FY89 we will to continue our Phase 2 efforts to develop a microcomputer-based tool with co-support from LRI and DOE. The tool will allow a user to access and process the glazing and shading-systems data base to determine the key performance indices as indicated in Figure 9. Simultaneous treatment of the thermal and visual comfort effects in parallel with the energy-related performance data is a major advance over past energy models.




Figure 9. Screen from fenestration design tool shows calculated values of fuel use for heating, electricity use for cooling, and peak electricity demand for four different fenestration systems. (XBL 892-645)

The tool will allow the user to weight each index to find the fenestration system that optimizes energy, cost, and comfort issues based on the user's weighting factors. The tool can also be used directly in an "optimization mode". Since the performance data are stored in simple analytical form, the user can directly determine properties of a real or hypothetical fenestration system representing an optimal solution, i.e., minimum or maximum value for each performance parameter. Combining these analytical capabilities with a hypermedia user interface will produce a powerful and effective design tool. Final design of the overall tool will be based on extensive consultation and testing by project sponsors and feedback from professional user groups.

SIMULATION STUDIES: RESIDENTIAL BUILDINGS

Our objective is to provide home builders and others involved in residential design and construction with easy access to relevant results of our window performance studies. The proliferation of new window technology offers new options to builders, but at the same time the multiplicity of options creates confusion regarding optimal selections to meet all performance requirements. We prepared a draft set of "Window Notes" that define and summarize performance factors for existing and new window technologies that affect residential energy use and comfort. This information was reviewed by the National Association of Home Builders.

Simultaneously with the development of the paper version, we created an interactive computerized version of the notes that included a variety of animation features. Figure 10 shows the main menu of this tool. The highlighted items are those aspects that were completed.

In FY 89 we will begin to expand "Window Notes" into a more comprehensive residential fenestration design manual/tool. This will ultimately include the development of a microcomputer-based simplified analysis tool.




Figure 10. Main menu screen of computerized version of "Window Notes," which summarizes performance factors of window technologies. "Window Notes" will be expanded into a comprehensive residential fenestration design tool. (XBL 892-644)

DESIGN TOOLS AND TECHNOLOGY TRANSFER

To influence energy consumption trends in the United States, it is critical to communicate our results to other researchers and building industry professionals. We use a variety of conventional media to reach a widely varied audience: other research and development groups, educational institutions, design professionals and industrial firms. We continue to develop improved fenestration analysis and design tools and handbooks, carry out design assistance studies, and sponsor workshops and meetings with manufacturing and design firms and public utilities.

Of special significance over the past several years are our efforts to explore new forms of advanced electronic media to better communicate appropriate information to varied audiences. For example, the growing public and private use of CD-ROM (compact disc read-only memory) for storing thousands of pages of text, images and audio reinforces our view of the value to the building community of the technology transfer tools based on new electronic and optical media.

We continued our interactions with the Daylighting Network of North America (DNNA), a group of 35 universities with research and instructional interests in daylighting. The network continued to publish the DNNA News and distribute software packages to faculty and practitioners. The latest advances in the development of "Hypermedia and Future Design Tools" were explored by architectural faculty representing 15 member schools of the network during a Daylighting Summer Retreat in Berkeley. A prototype workstation linking a CD-ROM drive and video disc player with high-resolution color monitor was used to demonstrate the hypermedia-based Daylighting Design Guide prototype we are developing. We expect to involve DNNA members in future development of this tool.

Our research and communication efforts are enhanced by the participation of visiting researchers from the U.S. and including foreign faculty representing Switzerland,

Germany, Japan, and Israel. The international perspective provided by our visitors is useful at a time when energy, economic, and environmental issues are increasingly viewed as global concerns.

ADVANCED DESIGN TOOLS

Our long standing interest in developing the next generation of sophisticated hardware and software design tools received significant funding from DOE, allowing us to pursue several exciting avenues. The Advanced Design and Operation Technologies (ADOT) Planning Project is intended to address the development of the technological basis for a family of design tools to be used by designers to achieve greater energy and cost savings in the next generation of U.S. buildings. Private-sector design tools utilizing ADOT technology would contain knowledge bases of energy-efficient technologies and methodologies, computer-aided-design capabilities, energy-analysis modules, and capabilities for visualizing interior and exterior building environments. Visualization capabilities include the ability to realistically simulate both quantitative and qualitative aspects of the building. The interface between the designer and the ADOT tools would rely heavily on visual representations of information and data.

In collaboration with the ADOT Planning Project, we studied imaging and visualization technologies to identify and evaluate the hardware and software requirements for the generation, manipulation and display of visual data for these advanced tools. To demonstrate the potential for the use of dynamic visual information for design decision making and education, we developed a prototype Daylighting Design Guide using new computer-based hypermedia approaches. The prototype is composed of Apple's Macintosh hardware and Hypercard software linked to a CD-ROM drive and video disc player with high-resolution color monitor. The primary thrust of this research is to explore the value and limitations of a hypermedia presentation of traditional daylighting design materials.

We expect to develop a prototype hypermedia information kiosk for demonstration and evaluation purposes with the support of DOE, LBL, and utilities.

PUBLICATIONS

1. Arasteh D, Johnson R, Selkowitz S. Definition and use of a daylight coolness index. Presented at the 1986 International Daylighting Conference, 5-7 November 1986, Long Beach, CA and to be published in the *1986 International Daylighting Conference Proceedings II*, 1989.
2. Benton C, Papamichael K, Arasteh D, Selkowitz S, Spear J. Optical analysis of tracking skylight: so-luminaire. LBL-26280, 1987.
3. Johnson K, Selkowitz S. Light guide design principles. Presented at the 1986 International Daylighting Conference, 5-7 November 1986, Long Beach, CA, and to be published in the *1986 International Daylighting Conference Proceedings II*, 1989.

4. Klems J H. U-values, solar heat gain, and thermal performance: recent studies using the MoWiTT. To be presented at the ASHRAE Winter Meeting, Fenestration U-Value Symposium, Jan 29-Feb. 1, 1989, Chicago, IL, and published in *ASHRAE Transactions*. 1988; 95 (Pt. 1), LBL-25487.
5. Klems J H, Keller H. In-situ measurements of u-values and overall thermal performance of windows, LBL-24763, 1988.
6. Kim J, Papamichael K, Selkowitz S, Spitzglas M, Modest M. Determining daylight illuminance in rooms having complex fenestration systems. Presented at the 1986 International Daylighting Conference, 5-7 November 1986, Long Beach, CA, and to be published in the 1986 *International Daylighting Conference Proceedings II*, 1989.
7. Kim J, Papamichael K, Selkowitz S. Development of regression equations for a daylighting coefficient-of-utilization model. Presented at the 1986 International Daylighting Conference, 5-7 November 1986, Long Beach, CA, and to be published in the 1986 *International Daylighting Conference Proceedings II*, 1989.
8. Papamichael K, Klems J, Selkowitz S. Determination and application of bidirectional solar-optical properties of fenestration systems. Proceedings of the 13th National Passive Solar Conference, June 19-24, 1988, Massachusetts Institute of Technology.
9. Papamichael K, Selkowitz S. Simulating the luminous and thermal performance of fenestration systems. *Lighting Design & Application*, pp. 37-45, 1987.
10. Pennisi A, Lampert C. Optical properties of electrochromic nickel oxide devices utilizing a polymeric electrolyte. Presented at the International Congress on Optical Science and Engineering, Sept 19-23, 1988, Hamburg, FDR. *Proceedings of the Conference on Optical Materials Technology for Energy Efficiency and Solar Energy Conversion VII*, Vol. 1016.
11. Reilly S, Arasteh D. A computer tool for analyzing window thermal performance. Proceedings of the 13th National Passive Solar Conference, June 19-24, 1988, Massachusetts Institute of Technology.
12. Selkowitz S, Papamichael K, Wilde M. A concept for an advanced computer-based building envelope design tool. 1986 *International Daylighting Conference Proceedings I*, pp. 496-502, 1987.
13. Sullivan R, et al. An indices approach for evaluating the performance of fenestration systems in non-residential buildings. *ASHRAE Trans.*, 1987; 94, Pt 2. LBL-23581.
14. Sullivan, R., Arasteh D, Papamichael K, Selkowitz S. An approach for evaluating the thermal comfort effects of nonresidential buildings fenestration systems. Presented at the International Symposium on Advanced Comfort Systems for the Work Environment, Troy, NY, May-1-3, 1988 and to be published in the proceedings.
15. Warren M, Selkowitz S, Morse O, Benton C, Jewell J E. Lighting system performance in an innovative daylighted structure: an instrumented study. 1986 *International Daylighting Conference Proceedings I*, pp. 215-221, 1987.
16. Wruck D, Rubin M, Sputtered Electrochromic V_2O_5 Films. *Thin Films*, (in press, 1989).

Lighting Systems Research*

S.M. Berman, R.R. Verderber, R.D. Clear, D. Crawford, D.D. Hollister, D.J. Levy, O.C. Morse, F.M. Rubinstein, M.J. Siminovitch, G.J. Ward, and R. Whiteman

New, efficient technologies and strategies have the potential to save our nation 50% of the electrical energy consumed by lighting, or about 12% of total electrical energy sales. This would amount to a yearly savings of some 220 billion kilowatt-hours of electricity, valued today at more than 16 billion dollars. The significance of this savings can be appreciated by considering projections of economic growth that predict a doubling of present commercial floor space by the year 2020. The 220 billion kilowatt-hours of saved energy would allow the new space to have its desired lighting conditions without the need for new electrical generating capacity, thereby providing an additional capital savings of more than \$100 billion.

To help achieve this more energy efficient economy, the Office of Buildings and Community Systems of the U.S. Department of Energy has established a program combining research activities and technology transfer to the lighting community (manufacturers, designers, and users). This program represents a unique partnership between a national laboratory-university complex and industry, facilitating technical advances, strengthening industrial capability, and providing designers and the public with needed information.

Past successes from this effort include development of the high-frequency solid-state ballast for improving the efficiency of fluorescent lamps; the Controlite computer program that enables designers to determine the energy and economic benefits of lighting controls in the workplace; assistance in developing the compact fluorescent lamp; important information on how lighting can effect productivity and visual functions; and determination that both photopic and scotopic spectrum affect the vision process at typical interior light levels.

The program is now actively pursuing development of more efficient light sources through technical concepts such as using isotopically enriched mercury for fluorescent

*This work was supported by the Assistant Secretary for Conservation and Renewable Energy, Office of Buildings and Community Systems, Building Equipment Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF000098.

lamps. A variety of ingenious methods for operating lamps at high frequency without electrodes are being pursued, with the goal of improved efficiency and longevity. In addition, the program is developing comprehensive strategies to optimize the benefits obtained by introducing efficient fixtures combined with lighting controls. This effort is assisted by the use of computers that can display realistic, visual simulation of the lighted workplace. In its study of the relation between lighting variables and visual function, the program is identifying human responses to lighting conditions, leading to new innovative products that improve both energy efficiency and productivity.

The program has identified new long-range technical concepts which, although high in risk, have great potential payoff. These include development of more efficient fluorescent lamp phosphors, lamps filled with novel gases, super fixture systems that overcome the inefficiencies associated with overheating, as well as the use of the spectral quality of lighting to optimize performance and comfort.

This interdisciplinary program encourages innovation in the industry, accelerates the societal benefits obtainable from a more cost-effective and efficient lighting economy. Because of its comprehensiveness, it is unique in the United States.

Since its inception in 1976, the LBL Lighting Program has produced more than 124 reports and publications. These reports, available to the public, document research on subjects such as solid-state ballasts, operation of gas-discharge lamps at high-frequency, isotopically enriched fluorescent lamps, energy-efficient fixtures, lighting control systems, and visibility and human productivity. In addition to its research activities, the internationally recognized interdisciplinary staff is involved in a variety of professional, technical, and governmental activities.

The Lighting Program combines the facilities and staff of LBL with those of the University of California College of Environmental Design and School of Optometry, both on the Berkeley campus, and the School of Medicine in San Francisco (UCSF).

Described below are highlights of the accomplishments realized in FY 1988 by each of our three major efforts: advanced light sources, building applications, and health impacts. Discussion of activities planned for FY 1989 are included in the highlight descriptions. Publications and conference presentations from the past year may be found at the end of this chapter.

ADVANCED LIGHT SOURCES

The advanced light sources effort promotes new lamp technology and light source development. To see what can be accomplished in this area, consider that the most efficacious four-foot fluorescent lamp, operated at high frequency (20 kHz), has a luminous efficacy of approximately 100 lumens of light output per watt of electrical power input. Although this is more than five times as efficient as an incandescent lamp, still greater efficacies are possible. White light can, theoretically, be produced at almost 350 lumens per watt. The advanced lamp technology program is developing the engineering science that will help

us achieve a target efficacy of 200 lumens per watt within the next few years.

In the area of fluorescent lamps, three loss mechanisms are candidates for efficiency improvements. These are self-absorption of ultraviolet (UV) radiation, electrode losses, and energy loss in lamp phosphors. In the first case, we would like to reduce self-absorption of UV radiation, a process that occurs within the lamp plasma before the radiation strikes the phosphor-covered inner wall (the phosphor converts UV radiation into visible light). If UV self-absorption is decreased, thereby reducing the chance of quenching electron collisions, the amount of UV radiation available to be converted into light at the lamp wall is increased.

In the second case, energy losses associated with electrodes can be eliminated by exciting the lamp plasma at radio frequencies (RF). The problem is to find an efficient method for coupling the RF energy into the lamp without causing new losses.

In the third case, we would like to develop a more efficient phosphor matrix that will convert one energetic UV photon into two visible photons. These concepts could lead to significant improvements in lamp efficacy.

LBL is studying several ways of reducing UV self-absorption. The first method is altering the isotopic composition of mercury. In its natural state, mercury has seven stable isotopes, each with slightly different resonance UV emission spectra. Altering the naturally occurring isotopic composition can provide more escape channels for the resonance radiation, thereby reducing the probability of quenching collisions and increasing the amount of UV radiation reaching the phosphor. The most promising possibility is isotope alteration-enrichment with ^{196}Hg , which is being pursued in a joint effort by LBL and GTE Lighting. Should isotopic alterations prove economical, modified lamps would enter the market quickly. Lamps would simply be loaded with isotopically enriched rather than natural mercury, with other lamp manufacturing processes remaining the same.

Another method of reducing UV self-absorption was recently discovered at LBL based on the application of a d.c. magnetic field having a direction parallel to the main current. Axial magnetic field strengths of about 600 gauss can increase light emission by about six percent. LBL and major firms in the lamp industry are studying practical ways to apply this technique.

A highly promising mechanism developed at LBL uses a plasma coupling principle that eliminates the need for electrodes; it allows lamp plasma excitation to occur primarily near the inner lamp wall, thereby reducing both the electrode loss and the likelihood of entrapment loss. This surface wave mode of operation occurs at high frequencies in the RF range between 100 and 500 MHz, permitting efficient lamp excitation without electrodes. The surface wave fluorescent lamp shows approximately 40 percent increased energy efficacy over normal fluorescent lamps, operates without starting circuits, and should be very long-lasting because of the absence of electrodes.

Reducing the effects of energy loss in the phosphors requires alteration of a lamp's phosphor material. The

materials used today convert each UV photon into, at most, one visible photon. Improving this conversion rate would increase the efficacy of low-pressure discharge lamps. Although a UV photon has sufficient energy to permit conversion of the UV photon into two visible photons, this process must occur quickly to prevent heat-producing collisions. LBL and GTE lighting are examining the possibilities of a program in phosphor chemistry designed to discover whether the two-photon phosphor is feasible. The lamp industry, long aware of the complexity of this problem and the extensive research required to provide solutions, is extremely interested in this cooperative effort.

If these research projects at LBL come to technological and commercial fruition, future fluorescent lamps would operate at high frequency without electrodes and would be isotopically enriched, magnetically loaded, and coated with a two-photon phosphor. Such lamps would have an efficacy of more than 200 lumens per watt, doubling the efficiency of today's best fluorescent lamps.

Other lamp technology research concentrates on high-intensity discharge (HID) lamps, which could be made both more efficient and dimmable if operated without electrodes. High-frequency operation is required to excite the lamp plasma in an electrodeless mode; it may also permit lamps to function with just one or two metal halides and no mercury or sodium. Electrodeless operation would also enable us to use compounds that have desirable light output and color, but that are excluded today because they would harm electrodes. Finally, an electrodeless lamp that could be dimmed without observable spectral changes and that could provide instant restrike could be used in many new ways. It would improve energy efficiency and would be aesthetically attractive enough for widespread use by lighting designers.

Mercury Isotope Separation and Enrichment of Fluorescent Lamps

Continued progress has been made in assessing the feasibility of photochemical separation of natural mercury to produce mercury enriched in the isotope mass ^{196}Hg . Most of the FY 1988 effort has been involved in designing and building a scaled-up reactor that can produce several grams per day of enriched mercury. This has required the development of a high flux light source now in place. Several new scientific and technical personnel have been added to the project, and a number of new developments are expected in FY 1989. These include in situ measurement of reactor performance, allowing continuous monitoring, production of enough enriched mercury to permit a high speed dispensing procedure (suitable for filling a large number of lamps with the enriched product), and economic analyses of the complete photochemical process that will permit conclusions on the feasibility of enriched mercury lamps as a market product.

Surface Wave Lamp (SWL)

Two important new findings were made during FY 1988. First, the surface wave mode of coupling was extended into a much higher power range, achieving about 10 watts per inch of discharge (as compared to the previous loading of about 1 watt per inch, typical of today's fluorescent lamps). This new level is still an order of magnitude below the 100 watts per inch typical of commercial high intensity (HID) lamps. The intermediate level achieved, which we refer to as the MID lamp, still maintains the zero reflected power condition essential for achieving high efficacy. A noteworthy aspect of the MID surface wave lamp is its instant restrike capability compared to the typical 10-minute period needed for commercial HID lamps. The question of effective coupling and restrike capabilities at an HID condition will be considered during the next year.

Our second major achievement is the development of a launcher and the finding of a frequency that allows a two-foot lamp to be energized by the surface wave mode. Efficacy improvements of about 30% for the longer-length lamp have been achieved.

Our first written examination of possible SWL power supplies indicates that a Class E amplifier with a solid state switching transistor is the most likely candidate. Further work in FY 1989 in this area will be undertaken with an outside contractor familiar with Class E amplifiers.

Electrodeless High-Intensity Discharge (HID) Lamp

The complete system for back-filling lamps 1 in. and .75 in. in diameter has been completed. These lamps are spherical in shape and are to be filled with various candidate materials for efficient HID light production. Successful glow-to-arc transition has been obtained with a pure mercury fill at slightly over 100 watts of lamp power.

Knowledge of the actual pressures in the lamp at operating conditions will be absolutely essential. For this purpose, several techniques have been initiated. The potentially best method involves insertion of a small amount of scandium (about 1% by mass) into the lamp. Scandium has some optically thin emission spectra in the visible region, and these line widths can be measured quite accurately. These scandium lines have been observed, and the success of this method will depend on an accurate calibration procedure which will be developed during FY 1989.

Lamp Fabrication Facility

Much effort in FY 1988 has been expended on developing our own lamp fabrication facility, which will enable us to build lamps from the basic glass tubing, fill with the desired gases and salts, include glass electrode seal if needed, and use all the extensive combined vacuum and oven systems needed for fill control and maintenance

of high purity. The facility required a new laboratory room that was constructed by conversion of a large, partially open storage area. Our personnel designed the facility and monitored its rehabilitation. The various fabrication components were tested and incorporated into the integrated facility. Numerous difficulties were encountered because of scheduling delays brought about by overall LBL plant complications; nevertheless, the lamp facility achieved 90% completion by the end of FY88, with the 100% level expected in early FY 1989 (Figures 1 and 2).

Isotope Modeling

This project, a joint effort with New York University, has the primary objective of developing a theoretical model to account for the effects of variations in isotopic mercury composition upon emittance of a low-pressure discharge. The secondary objective is to include the effects of partial redistribution, surface effects, and line-shape factors that affect the emittance, and hence the efficacy, of UV radiation.

The practical goal is to specify the isotope composition that maximizes emittance.




Figure 2. Lamp fabrication components including glass lathe (right) and high-speed glass saw (left). (CBB 891-341)



Figure 1. Evacuated glove box where hydroscopic salts are prepared as additives for lighting producing fills in electrodeless HID lamps (CBB 876-10627)

We have formulated a variational theoretical model of the radiant emittance of the mercury-argon discharge used in fluorescent lighting. The model includes the effects of the fine structure and isotope shifts in the resonance radiation line as well as those of atomic diffusion, resonant exchange of excitation, and radiation transport. The result is a variational principle which, when evaluated using suitable trial functions, yields a variational estimate of the radiant emittance of the discharge. This principle is used to study the effects of isotopic mercury enrichment on emittance. The special case of a single pure isotope, as well as mixtures of all seven naturally occurring isotopes, are presented. Recent experiments with enhanced ^{196}Hg and ^{201}Hg concentrations are discussed within the context of this theory. The relative merits of three isotopic mixtures recently proposed for commercial development by Alchemie, Inc. are assessed, and one of the mixtures (case 2) can be expected to lead to a greater improvement of the emittance of the discharge than the other two, with about a four percent increase over that of natural Hg. Further refinements, including additional physical effects as well as improved numerical codes, are planned for the final stage of the model.

BUILDING APPLICATIONS

Real energy savings depend on the transfer of energy-efficient technologies and strategies to the lighting

community. The building applications activities aim to assess and develop energy-efficient lighting technologies and to combine their technical performance characteristics to model energy-efficient and cost-effective lighting geometries and controls. Our analysis uses knowledge of the relationship between visual performance and physical aspects of lighting, such as illumination level, distribution, contrast, and glare. As part of this effort, a computer program has been developed that provides accurate simulations of illuminated spaces with their contents. The simulated scenes are visibly indistinguishable from real photographs; using them, we can model effects of changes in the illumination systems. Validation of luminance values produced by these simulations requires physical measurements of luminances in complex environments. Therefore, the project uses a number of novel techniques for real luminance mapping of interior environments with complex objects to obtain actual luminance values. The technology development component of this program examines engineering approaches to reducing light losses associated with thermal factors of conventional lighting fixtures. The conclusion of these efforts will be a combination of lighting systems technologies and analysis. Visual simulation of the proposed application represents the most compelling tool for promoting the implementation of energy efficient lighting.

Advanced Lighting Design

The primary objective of this effort is the development of simplified guidelines for assessing lighting contrasts, and hence, performance available in a given space as a result of illumination, fixture geometry, lamp type, and interior reflectance. The procedures involve examination and analysis of available computer programs.

During FY 1988, parametric runs on Lumen-Micro were studied to examine the question of the effect of luminaire spacing and the light distribution from particular luminaires on predicted visual performance in an open-office environment. Optimal spacing geometries have been determined. A cost-benefit analyses will be undertaken during FY 1989, taking into account the tradeoffs between higher light levels and tighter spacing with potentially diminishing returns on productivity.

Energy-Efficient Luminaires and Thermal Control Devices

Ceiling-mounted four-lamp luminaires, lens and parabolic types, were evaluated during FY 1988. The minimum lamp wall temperature of the in-place lamps were measured with various ventilation schemes and distances from the ceiling. Simple convective cooling reduced the excessive lamp wall temperature 10° to 15°C and was a function of distance from the ceiling. The thermal performance of the luminaires was measured for standard ballasts with 40-watt and 34-watt lamps, and for electronic high-frequency ballasts. The convective cooling strategy was able to recover most of the thermal loss due to lamp overheating.

During FY 1989, the thermal performance of enclosed and parabolic four- and two-lamp troffers will be measured. We will also develop optimum venting to convectively cool the fluorescent lamps controlling the ambient and plenum temperature. Measurements using a standard two-lamp F40 lamp-ballast system will be conducted for reference and compared with measurements for energy-saving magnetic ballasts and electronic ballasts.

In the area of specific devices to control lamp wall temperature, our major effort has been on concepts that use the Peltier effect coupled with a heat pipe acting as the heat sinking component.

The power to the Peltier device was obtained from the secondary filament windings of a standard ballast. This was accomplished by a filtered full wave rectifying circuit. The capacitor required is relatively large; operating the Peltier device from an unfiltered source would have a practical advantage.

An experimental variable conducting heat pipe was designed and constructed. This elegant concept requires no external power source to control lamp wall temperature.

An experimental test station constructed to evaluate the performance of these devices was used to measure the lamp-ballast combination (Figure 3).

A number of important questions regarding the efficiency of heat transfer will be examined during FY 1989. In addition, a study of the limitations of using rectified AC power (instead of DC power) for Peltier devices will be carried out. If the devices can be operated by half-wave or full-wave rectified power, the DC conversion costs could be greatly reduced.

Quality Illumination and Performance

During FY 1988, we completed an analysis of our 17-subject study of the speed of reading unrelated words. The time to read these words was measured with an




Figure 3. Luminaire laboratory with heat pipe being installed on fluorescent lamp. (CBB 89-345)

eyetracker that could determine fixation time as well as the time for a saccade. The contrast, luminance, and size of the words was controlled and varied over ranges typical of office work. The analysis showed the remarkable result that the reading speed data could be solely a function of the ratio of letter size to threshold size; the dependence on contrast and luminance occurs only through their effect on threshold size. The results indicate that a useful and simple field test can be made available to determine if a given individual has adequate illumination (or contrast) for any given reading task.

The work is currently being prepared for journal publication and for the 1989 annual meeting of the Illuminating Engineering Society.

Additional efforts on improved cost-benefit techniques have been pursued. A new model of basic visual performance shows promise of overcoming the criticisms leveled at the models by Rea and by Blackwell.

Computer Imaging

The RADIANCE modeling system was ported to the SUN workstation in FY 1988. "Alpha" test versions of the RADIANCE program were released to selected faculty and students at UCB Schools of Architecture and Optometry and to the University of Michigan Architecture Department to solicit comments and feedback from users. In 1988, RADIANCE was validated against Superlite and against daylight scale models composed of diffusely reflecting surfaces. Further validation needs to be carried out with physical measurements of specular and semi-specular materials under artificial light. A three-dimensional editor has been developed on the Macintosh and was ported to the X-windowing system on the SUN workstation. Additional utilities to improve program usability were also added.

Effort in 1989 will be devoted to completing the verification of RADIANCE accuracy by comparing calculations with empirical measurements from both scale and full-size models.

In addition, a lighting design firm will be selected to work with LBL, using RADIANCE software to design a complete energy-efficient lighting system.

IMPACTS OF NEW LIGHTING TECHNIQUES ON PRODUCTIVITY AND HEALTH

The idea that lighting might negatively affect health has appeared often in the lay press during the past few years. Scientific data are lacking, especially to ascertain whether new energy-efficient technologies adversely affect human health and productivity.

Performance and productivity may be influenced by lamp electronics and associated controls, fixtures, or the geometry and location of the lighting system. We classify these lighting factors as color variations; glare; intensity fluctuations; spectrum variations, including the ultraviolet region; electromagnetic fields generated by the lamp, ballast, or controls; and flicker. All of these could evoke a

variety of human responses (behavioral, psychophysical, physiological, or biochemical).

Our research seeks to assure that new energy-efficient lighting technologies do not adversely affect human health and productivity. We are investigating whether any aspect of new technologies can produce responses in humans. If we identify responses, we will characterize the effects and identify the necessary changes in lighting technologies. Although subjective responses of workers provide some information, such responses are generally confounded by a mix of sociological factors and individual motivations. The investigations carried out by LBL use objective responses to establish cause and effect, and ensure repeatability.

The impacts program is divided into two areas: 1) direct effects of lighting on the human autonomic system (carried out at University of California, San Francisco and LBL); and 2) interactions of lighting that affect visual performance and productivity or comfort (carried out at the UC School of Optometry and LBL), which are termed here "lighting ergonomics."

In the first area of this program, lamps to be evaluated include incandescent, cool-white fluorescent, high-pressure sodium, and metal halide. Human responses to various lighting conditions will be assessed by monitoring autonomic responses including heart rate, galvanic skin response, muscle strength, exercise tolerance, facial expression, and pupillary response. Behavior measures to be used include memory (Wechsler Memory Scale and Sternberg's Memory Scanning Time), cognitive function (mental arithmetic), time estimation, and simple reaction time. Other behavioral tasks will probably be included.

Data gathering and subject control are supervised by trained medical personnel. A national technical advisory committee oversees and reviews the project. First results of this effort concern the effects of visible spectrum and low-frequency radiation on human muscle strength and, as described previously, they indicate that psychological factors are the likely cause of reported effects. A second set of experiments using infrared pupillometry has, however, demonstrated that the spectral response of the pupil at typical interior light levels is the scotopic spectrum and thus that red photoreceptors are active at these light levels.

The second area of this program primarily studies issues of glare and flicker resulting from lighting systems.

Present knowledge and prescriptions by the lighting community for dealing with glare are based on subjective responses without support by objective criteria. It is reasonable to implicate pupillary responses as relevant to glare discomfort because pain receptors are present in the iris, and the nervous pathway necessary to signal pain is present in the fifth trigeminal cranial nerve. Some studies by vision scientists have suggested pupillary response as a possible objective correlate to the sensation of discomfort, but this conclusion is not generally accepted in the vision community. We have undertaken a series of studies to

clarify the possibility that pupillary dynamics can be used as an indicator of glare response.

Visual system responses to the oscillating light levels pervasive in our interior environments has also been implicated in many anecdotal reports. The program has undertaken a series of direct physiologic measurements to investigate whether such responses can be established.

Direct Effects of Lighting on the Human Autonomic System

The first phase of work on brightness perception has been completed, clearly demonstrating a significant contribution of scotopic spectrum to brightness as perceived by subjects in a room. This result, coupled with our previous finding showing the scotopic spectral response for pupil size, implies that under typical interior light levels, vision function is mesopic, i.e., both rods and cones of the retina are active. Our present experiments are consistent with a brightness function expressed by the equation $B = \log P + 0.9 \log S$, where B is the perceived brightness while P and S are the values of the viewed photopic and scotopic luminance. The significance for energy efficiency demonstrated by this equation can be seen by comparing warm white and daylight fluorescent lamps of equal wattages, in which case the daylight illuminant will appear twice as bright. The value of 0.9 in the above equation has some uncertainty, and the second phase of this effort (to be accomplished in 1989) will determine more precisely the quantitative mix of photopic and scotopic spectrum that correlates with perceived brightness.

The most compelling demonstration of rod contribution to brightness perception will be shown by the pupil stimulator. This device, under development at LBL, will allow brightness comparisons to be made with periodic time, varying luminances where the oscillation rate can be adjusted to occur below and above the rod fusion frequency. Currently, the instrumentation is undergoing revisions and the system optics are being altered in order to incorporate the new, more intense light sources. These new light sources will allow a much better focusing capability into the fiber optic system that was not very efficient with the previous choice of light source, i.e., the tungsten halogen lamps. The construction is expected to be completed during FY 1989.

The effects of pupil size on visual performance are being studied by observing the contrast sensitivity of subjects. The experimental protocols have been established and the software developed to allow the equal-luminance double grating to appear simultaneously on the TV screen. Subjects will then choose which of the two presentations is the grating, i.e., only one side of the rectangular page projected will actually be a vertical grating (the other will simply be a uniform equal-mean-luminance rectangular patch). Figure 4 shows the chamber at the UCSF laboratory where the pupil measurements are performed.




Figure 4. Subject seated in lighting test chamber is being prepared for pupil measurements by remote infrared pupillometry. (CBB 870-10637)

Lighting Ergonomics

Discomfort Glare Studies

We have completed experimentation on the frequency spectrum of pupillary unrest (hippus) under conditions of the absence of discomfort glare and in the presence of discomfort glare where the light levels were set to provide equal mean pupil area. This condition is achieved by producing the pupil size with a bright but large area source while the discomfort glare condition is achieved with a small, intense glare source in a relatively low-level uniform surrounding. The frequency spectrum is then determined by Fourier transform of the time, varying pupillary unrest and the two lighting conditions compared. The results show no observable differences in spectrum shape

or intensity. Our conclusion is therefore contrary to previous results and claims that argue for a difference on the hipus spectrum.

Experiments planned for FY 1989 will test the hypothesis that pupillary response is associated with the sensation of discomfort glare. A pilot study on the influence of color on discomfort glare showed that for small geometric sizes of the glare source, the sensation of discomfort had a definite spectral response, with the more blue or red portions of the spectrum being more efficacious in eliciting the discomfort. This preliminary result is consistent with brightness perception for small sources. This is the first known controlled effort on the spectral response of discomfort glare, and this effort should give lighting designers and users useful information about this form of glare. The effort is anticipated to be completed during FY 1989.

Electroretinogram Studies of Flicker

Microelectrode studies in the cat visual system as well as visual evoked potential and electroretinogram (ERG) studies in humans have demonstrated synchronous responses to periodic time-varying stimuli at frequencies higher than human perceptual fusion. We have determined the time-averaged ERG responses of two human subjects who viewed text on a visual display unit (VDU) at typical values of luminance and contrast. The refresh rate of the VDU was varied in 5 Hz increments between 46 and 81 Hz. In addition, we measured the ERG response in one subject with intense flickering light, provided by a projector and rotating sector disc, to examine whether synchronous ERGs could be obtained at frequencies as high as those found to produce responses in the cat electrophysiologic studies (100-120 Hz). For the VDU stimulus, we found clearly identifiable synchronous ERG responses at refresh rates as high as 71 Hz. Synchronous responses to the more intense source were clearly evident at frequencies as high as 162 Hz. Figure 5 shows subject with the electroretinogram lens in place.

A further study was initiated to examine whether this subject would show an ERG response when directly viewing a two-lamp fluorescent light fixture. Fluorescent lamps conventionally operate on line frequencies of 50 Hz in Europe and 60 Hz in the United States and provide light output that is modulated and oscillating at twice this line frequency. At these "high" frequencies, any consequences of "flickering" light level have been presumed to be absent because the oscillation rate is above that perceivable by humans. However, the subject showed a direct physiologic response to fluorescent lamp modulation in terms of synchronous retinal responses in electroretinogram measurements at frequencies even higher than the 120 Hz oscillation rate. Thus, there is some evidence of responses to light oscillation even though they are not directly perceived. Whether such responses could be related to the reported symptoms of headaches and eyestrain remains to be established. The studies are now being prepared for submission for publication in the vision science and lighting literature.




Figure 5. Close-up view of subject with electroretinogram lens inserted into left eye. Lens consists of a circular wire on a contact plastic on the cornea and a silver speculum resting against the sclera. (CBB 876-4387)

PUBLICATIONS

1. Verderber R. Energy efficient lighting on board naval ships – phase II – the T-8 lamp system. 1987 (LBL-23153).
2. Rubinstein F, Verderber R, Ward G. Photo-electric control of daylight following lighting systems (daylight sensing photocell placement). *Electric Power Research Institute*, 1987 (LBL-24872).
3. Berman S, Greenhouse D, Bailey I, Raasch T. Human electroretinogram responses to visual display flicker. *The Association for Research in Vision and Ophthalmology (ARVO) Annual Meeting Abstract Issue*, Vol. 29, May 1-6, 1988, Sarasota, FL (LBL-24666).
4. Rubinstein F, Ward G, Verderber R. Improving the performance of photo-electrically controlled lighting systems. *Proceedings of the IES Annual Conference*, August 7-11, 1988, Minneapolis, MN (LBL-24871).
5. Ward G, Rubinstein F. A new technique for computer simulation of illuminated spaces. *Journal of the IES* 1989; 18(1): 80-91 (LBL-23042).
6. Clear R, Berman S. Estimation of linear interpolation error. *Journal of the IES*, in press, 1988 (LBL-24811).
7. Verderber R, Morse O, Rubinstein F. Performance of electronic ballast and controls with 34- and 40-watt fluorescent lamps. *Proceedings of the IEEE-IAS Annual Conference*, October 1-3, 1988, Minneapolis, MN (LBL-25429).
8. Verderber R, Rubinstein R, Siminovitch M. Control of lamp wall temperature. *Proceedings of the IEEE-IAS Annual Conference*, October 1-3, 1988, Minneapolis, MN (LBL-25430).

LAWRENCE BERKELEY LABORATORY
TECHNICAL INFORMATION DEPARTMENT
UNIVERSITY OF CALIFORNIA
BERKELEY, CALIFORNIA 94720