

Lawrence Berkeley National Laboratory

Lawrence Berkeley National Laboratory

Title

DRAFT INTERIM REPORT: NATIONAL PROGRAM PLAN FOR PASSIVE AND HYBRID SOLAR HEATING AND COOLING

Permalink

<https://escholarship.org/uc/item/36x277b3>

Author

Authors, Various

Publication Date

1979

Draft Interim Report: National Program Plan for Passive and Hybrid Solar Heating and Cooling

Prepared by

Energy and Environment Division
Lawrence Berkeley Laboratory
University of California

Solar Energy Research Institute

Heating and Cooling Research and Development Branch
Office of Conservation and Solar Applications
of the U.S. Department of Energy

RECEIVED
LAWRENCE
BERKELEY LABORATORY

FEB 26 1979

LIBRARY AND
DOCUMENTS SECTION

January 1979

TWO-WEEK LOAN COPY

*This is a Library Circulating Copy
which may be borrowed for two weeks.*

*For a personal retention copy, call
Tech. Info. Division, Ext. 6782*

under Contract No. 7405-ENG-48

LBL-8606 e.2

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

Draft Interim Report: National Program Plan for Passive and Hybrid Solar Heating and Cooling

Energy and Environment Division
Lawrence Berkeley Laboratory
University of California

Solar Energy Research Institute

Heating and Cooling Research and Development Branch
Office of Conservation and Solar Applications
of the U.S. Department of Energy

This work was supported by the Office of Conservation & Solar Applications
of the U.S. Department of Energy

FOREWORD

This interim report on the National Program Plan for Passive Solar Heating and Cooling was prepared by the U.S. Department of Energy (DOE), Office of Conservation and Solar Applications (Passive Solar Program). The Plan is based on a thorough assessment of the present status of passive and hybrid solar heating and cooling. It is written for those familiar with the basics of solar heating and cooling, but not necessarily a detailed understanding of passive solar systems. The Plan describes the Federal program for passive solar systems for buildings and agricultural and industrial process heat applications,[†] including those activities to be funded in whole or in part by the Federal government.

The Plan is an integral part of the Department of Energy's objective to stimulate the development of an industrial, commercial, and professional capability for designing, producing, and distributing solar energy systems, thus contributing toward meeting our national energy requirements through the effective use of solar energy. The development and utilization of passive solar heating and cooling are essential elements for accomplishing this objective.

This report complements several previous national programs for solar heating and cooling of buildings, agricultural and industrial process heat, and solar heating and cooling research and development. It is a comprehensive plan addressing not only research and development needs but also activities necessary to support and stimulate the utilization of passive solar systems. To

[†]The present interim report of the National Program Plan for Passive Solar Heating and Cooling does not include activities related to agricultural or industrial process heat applications. However, this section will be prepared and included in the Final Plan.

assure the completeness and appropriateness of the Plan, this interim report will be widely circulated for review and comment by all those concerned with the development and utilization of passive solar systems.

Additionally, it is expected that several organizations, such as the American Institute of Architects; the American Society of Heating, Refrigeration, and Air-Conditioning Engineers; the National Association of Home Builders; and the Solar Energy Industry Association, will conduct formal reviews of this Plan and provide DOE with comments and recommendations.

A final report on the National Program Plan for Passive Solar Heating and Cooling will be issued late in 1979. Comments should be received no later than May 30, 1979. Comments should be sent to:

Dr. Frederick H. Morse
Conservation and Solar Applications
U.S. Department of Energy
Washington, D.C. 20545

It is anticipated that this Program Plan will be revised, amended, and updated on a regular basis as results of and experience with implementation become available.

TABLE OF CONTENTS

	Page
Foreword	1
List of Tables	5
List of Figures	5
INTRODUCTION	6
PART I: PLANNING CONTEXT	15
Section A: Definition of Passive Solar Systems	16
General Definitions	16
Space Heating	16
Space Cooling	18
Hot Water	19
Section B: Background of Federal Involvement in Passive Solar Heating and Cooling	21
Section C: Program Goal and Objectives	24
Section D: Implementation	27
PART II: TECHNOLOGY DEVELOPMENT	30
Section E: Background	31
Status of Technology Development	33
Strategy for Technology Development	37
Emphasis for Technology Development	40
Section F: Systems Descriptions	41
Space Heating	41
Space Cooling	50
Section G: Task Classifications	56
Basic Physical Studies Tasks	56
Product Development Tasks	60
Systems Development Tasks	63

	Page
PART III: TECHNOLOGY UTILIZATION	66
Section H: Background	67
Status of Technology Utilization	68
Strategy for Technology Utilization	70
Emphasis of Technology Utilization	73
Section J: Process Description	75
Commercialization Readiness Assessment	76
Technology Transfer	76
Stimulation of Technology Delivery Capability	77
Stimulation of Market Demand	77
Section K: Task Classifications	79
PART IV: APPENDICES	80
Appendix A: Technology Development Tasks	81
Appendix B: Systems Development Schedules	109
Appendix C: Technology Utilization Tasks	111
Appendix D: Technology Utilization Schedules	121
Appendix E: Projected Passive Solar Space-Heating Energy Impact	122

LIST OF TABLES

		Page
TABLE II-1	Heating Systems for Development	49
TABLE II-2	Cooling Systems for Development	55
TABLE II-3	Technology Development Task Classification	57
TABLE III-1	Technology Utilization Task Classification	79

LIST OF FIGURES

FIGURE II-1	Examples of Passive Heating Systems	45
FIGURE II-2	Examples of Single-Story, Multi-zone, Passive Solar Systems	46
FIGURE II-3	An Example of a Multi-Story, Multi-Zone Passive Solar System	47
FIGURE II-4	An Example of a Multi-Story, Multi-Zone Passive Solar System	48
FIGURE II-5	Examples of Passive Cooling Systems	54
FIGURE II-6	System Development Process	58

INTRODUCTION

This report represents the Department of Energy's National Program Plan for Passive Solar Heating and Cooling of Buildings, Domestic Hot Water, and for Agricultural and Industrial Process Applications. It is part of the federal program of research, development, demonstration, and commercialization to establish solar energy as a viable energy resource for the nation. Authority for the establishment of a vigorous federal solar energy program comes from the Solar Energy Research, Development, and Demonstration Act (P.L. 93-473), signed into law on October 26, 1974.

Program planning of solar energy research, development, demonstration, and commercialization is being carried out under guidelines established by P.L. 93-473 and by four other legislative acts passed by the 93rd and 94th Congresses: the Solar Heating and Cooling Demonstration Act of 1974 (P.L. 93-409), the Energy Reorganization Act of 1974 (P.L. 93-438), the Federal Non-Nuclear Energy Research and Development Act of 1974 (P.L. 93-577), and the Energy Conservation and Production Act of 1976 (P.L. 94-385). Together with the Department of Energy Organization Act of 1977 (P.L. 95-75), which consolidated the energy functions of ERDA, FEA, and several other federal agencies into the Department of Energy, these five laws give authority to DOE to undertake a wide range of activities as part of a research, development, demonstration, and commercialization program aimed at effective energy utilization. This program is spelled out in part in the "Definition Report: National Solar Energy Research, Development, and Demonstration Program" (ERDA-49).

The primary goal of the program is to work with industry in the development and early introduction of economically competitive and environmentally acceptable solar energy systems to help meet national energy requirements. One element of the program, Direct Thermal

Application, has as its purpose the accelerated, widespread application of solar heating and cooling and solar process heating systems that are economically viable as well as socially and environmentally acceptable. This program element has two interrelated subprograms: Solar Heating and Cooling of Buildings, and Agricultural and Industrial Process Heat Applications. DOE has prepared program plans for each of these applications--National Program for Solar Heating and Cooling of Buildings (ERDA 76-6) and Program Description: Solar Energy for Agricultural and Industrial Process Heat (ERDA 76-88)--as well as a detailed Solar Heating and Cooling Research and Development Plan (DOE/CS-0008). The present Program Plan is a comprehensive set of activities related to the development and use of passive solar heating and cooling that is only generally outlined in the other three documents.

In this Plan, it is recognized that the application of passive solar heating and cooling involves, to a significant degree, existing materials, components, and assemblies such as glazings, concrete and masonry products, and insulation, that are commonly used in the construction industry. It is the application and design of these materials, components, and assemblies into an architectural form that controls natural energy flows through the structure (from and between collection, storage, and the space) that constitutes most passive solar heating and cooling systems. Furthermore, since many of the key components for passive solar systems exist or are under development, the Plan builds upon this existing technology. By supporting work on a wide range of problems, the Plan seeks to assist the industry (including manufacturers, designers, suppliers, installers, consumers, regulators, lenders, researchers, and legislators) in developing cost-effective components and systems, and the capability to effectively and appropriately use passive solar heating and cooling. The Plan seeks to balance the emphasis on problems surrounding the development of passive solar systems with those problems surrounding the utilization of passive solar systems. Only with a conscious concern for and

a directed program in both areas will the accelerated, widespread use of passive solar heating and cooling for buildings and for agricultural and industrial processes occur.

Government's Role

As in all Federal program plans, an important issue is the nature and extent of the government's role in the processes of developing a technology and facilitating its use. The stated Federal goal of energy related research, development, demonstration, and commercialization is to perform a supplementary role: to support what is not or cannot be supported by the private sector. This focus implies that Federal involvement in technology development and utilization should build on an existing industry capability; that the government should engage in areas of research, development, demonstration, and commercialization in which industry cannot; or that the urgency of the problem/need and the degree of the risk is such that Federal participation is required to accelerate the development and utilization of a technology.

This intent is clearly stated in legislation establishing the National Solar Energy Research, Development, Demonstration, and Commercialization Program. The Solar Energy Research, Development, and Demonstration Act of 1974 states that it is the policy of the Federal government to:

- pursue a vigorous program of research assessment of solar energy as a major source of energy for our national needs; and
- provide for the development and demonstration of practical means to employ solar energy at a commercial scale.

Just as importantly, this Act, as well as the Federal Non-Nuclear Energy Research and Development Act of 1974 and the Solar Heating and Cooling Demonstration Act of 1974 outlines the decision criteria that should be used by federal agencies in the technology development and

utilization process. These include:

- A determination of the extent of the problem and whether the objectives of the program are national or widespread in their significance;
- The urgency of the public need for the potential results of the program, the immediate and potential applications of the solar energy that would be collected and converted to useful forms by the program, and the effect of the energy produced in conserving other non-renewable forms of energy and yet facilitating the availability of adequate supplies of energy to all regions of the United States;
- The technological feasibility of the program, including improvements that it might provide in the efficiency of energy production and use, the reduction of waste materials or waste energy, and the potential of the program for production of net energy;
- The potential economic viability of the process that would be developed by the program, as determined by an economic assessment of how competitive its energy products would be with those of processes using either alternative sources of energy or alternative technologies;
- The environmental and social impacts and consequences of the systems produced as a result of the program and, in particular, the impacts of the use of water required at the commercial application stage;
- The potential for the transfer of the technology developed from the Federal government to the private sector and to other applications;
- The nature and extent of Federal participation, if any, required in the program and, in particular, consideration of the following questions:

- (1) Are there potential opportunities for non-Federal interests to recapture the Federal investment in the undertaking through normal commercial utilization of proprietary knowledge gained during the project, and are opportunities sufficient to encourage timely results?
- (2) Are there potential opportunities to induce non-federal support of the undertaking through regulatory actions, end-use controls, tax and price incentives, public education, or other alternatives to direct Federal financial assistance?
- (3) Is the degree of risk involved in developing and implementing the program too high to encourage non-Federal entities to undertake such actions?
- (4) Does the magnitude of the investment required to undertake the program appear to exceed the financial capabilities of non-Federal entities that might otherwise be encouraged to undertake such actions?

These criteria have been considered during the preparation of this program plan. However, it is recognized that our present knowledge of performance and costs of passive solar heating and cooling is limited. Consequently, many of the recommended tasks are directed toward developing the information necessary to more fully determine appropriate government action.

Technology Status

As part of the preparation of this National Program Plan, a meeting[†] was held with representatives from industry, universities,

[†]The meeting was held in Reston, Virginia, October 31 - November 2, 1977, and was attended by 70 individuals with expertise in passive solar heating and cooling.

and federal and state government agencies. The objectives of this meeting were to:

- Assess the present state of the art of passive solar heating and cooling, both in terms of the development and utilization of the technology;
- Identify major problems limiting improved performance, reduced costs, and/or widespread utilization; and
- Recommend short- and long-term tasks to solve these problems.

Subsequently, numerous other meetings were held in support of DOE's Commercialization Readiness Assessment to identify energy technologies that can have a significant near-term impact on energy consumption. These meetings, held throughout the summer and fall of 1978, involved hundreds of individuals from the design professions, commercial and residential construction industry, utilities, lending institutions, state and local governments, national laboratories, regional solar energy centers, manufacturers and suppliers, and consumers. The purposes of these meetings were to assess the commercial readiness of passive solar systems, including a determination of market penetration and energy displacement, and to propose a commercialization strategy for accelerating the widespread application of passive techniques.

From these meetings, a review of the literature, and other discussions, the status of passive solar heating and cooling was defined. The following points became clear:

- Passive solar systems can provide a major part of a building's thermal energy requirements.
- Passive solar systems are, in general, more cost-effective than active systems.
- For passive heating, potential overall system efficiencies are high because of the low temperatures of collection.

- The state of the art varies greatly for different passive solar systems. Passive solar cooling is generally less developed than passive solar heating.
- Passive solar design concepts and climactic regions are so varied that careful analysis is required to determine the most cost-effective systems for different applications.
- Emphasis to date has been directed primarily to new residential buildings. Significant opportunities exist for the use of passive solar systems in new commercial buildings and in existing residential and commercial buildings.
- The two major problems to be addressed are user-oriented design methods and increasing the awareness, knowledge, and understanding of passive solar systems by the building industry and the general public.
- A large body of knowledge and information exists that directly or indirectly relates to passive solar systems. However, this information is generally not widely known or applied to passive solar design. A major effort should be undertaken to identify, collect, evaluate, repackage (if necessary), and disseminate this information.
- The potential for early commercialization and significant energy impact is high because many simple passive solar approaches are cost-effective in almost every part of the country today.
- Passive systems are based upon the effective use of common building materials and construction techniques resulting in minimum likelihood of malfunction. Their high reliability results from using few moving parts, moderate operating temperature ranges of components, and use of time-proven materials.
- Operating costs are negligible and maintenance is very small compared to capitalization expense.

- Although development of some specialized products would be helpful, most materials, manufactured products, and construction methods needed for commercialization are now commonly employed in building construction.
- Few institutional barriers exist to the widespread application of passive systems and those that do exist can be overcome through an effective commercialization program.
- Widespread use of passive solar systems poses no significant on-site or off-site environmental hazards.

Structure of the Program

The National Passive Program is organized around two interrelated program areas: Technology Development and Technology Utilization. Together, these two areas are seen as processes for achieving the accelerated widespread use of passive solar heating and cooling.

Technology development is simply that process through which an idea is developed to a point of potential widespread application. Its focus is towards research, development, testing, and assessment of a technology. The outcome of the technology development process is generally either a product (hardware) or documentation of results (software) leading to the development of user-oriented design methods, or both.

Technology utilization is the process of identifying cost-effective, environmentally and socially acceptable technologies and developing a conducive application environment (market) for those technologies. Its activities include determining the readiness of a technology in terms of performance and cost for entering the marketplace, assessing potential markets, identifying and mitigating restrictions to use, performing technology transfer and market development activities, and monitoring and feeding back information within and between the utilization process and the development process.

Structure of the Plan

The National Program Plan for Passive Solar Heating and Cooling consists of four major parts. The first part (Sections A through D) describes the planning context. A definition of a passive solar system is given, as well as a background of Federal involvement in passive solar heating and cooling, program goals and objectives, and an overall implementation approach. The second part (Sections E through G) addresses the technology development program area. Background information on the status of and the strategy and emphasis for technology development is provided, followed by descriptions of passive heating and passive cooling systems and an overview of task classifications for technology development. The third part (Sections H through K) describes the technology utilization program area. Again, background information is given on the status of and the strategy and emphasis for technology utilization. This is followed by a narrative description of the technology utilization process and an overview of task classifications for technology utilization.

The fourth part (Appendices) provides detailed information on the tasks and schedules. Appendix A contains brief descriptions of the technology development tasks. Appendix B presents system development schedules for promising passive solar heating and cooling systems selected for intensive development activity. Appendix C contains brief descriptions of the technology utilization tasks. Appendix D presents schedules for utilization tasks selected for near-term implementation. As previously noted, the tasks necessary to develop and introduce agricultural and industrial process systems are not described in this plan. Appendix E presents the projected energy impact of passive solar space-heating of residences and light commercial buildings. These projections were generated for the Department of Energy document, "Commercialization Strategy Report for Passive Heating."

PART I: PLANNING CONTEXT

SECTION A: DEFINITION OF PASSIVE SOLAR SYSTEMS

SECTION B: BACKGROUND OF FEDERAL INVOLVEMENT IN
PASSIVE SOLAR HEATING AND COOLING

SECTION C: PROGRAM GOAL AND OBJECTIVES

SECTION D: IMPLEMENTATION

SECTION A:
DEFINITION OF PASSIVE SOLAR SYSTEMS

A passive solar building is designed to maximize utilization of the environmental resource while minimizing consumption of the conventional fuels used for heating, cooling, and energy distribution/management. This is generally accomplished by the architectural elements and features of the building through the purposeful collection (dissipation), storage, and distribution of energies available at the site. The passive solar components are not easily distinguishable from the remainder of the structure since they serve multiple functions. This section defines passive systems as used in this Plan and differentiates active, passive, and hybrid systems for heating, cooling, and domestic hot water applications.

General Definitions

The most widely accepted definition of a passive system is one in which the thermal energy flow is by natural means (involving conduction, convection, radiation, and evaporation).

An active system is one in which all the thermal energy flow is by forced means (involving fans or pumps).

A hybrid system is one incorporating a major passive aspect, where at least one of the significant thermal energy flows is by natural means and at least one is by forced means.

The rationale for these definitions for heating, cooling, and hot water systems is presented below.

Space Heating

A solar space heating system contains the following elements:


- a space (or, more specifically, contents) to be heated;

- a collector where solar radiation is admitted into the system and converted to heat by an absorber (this may be nothing more than a surface of the normal building envelope);
- thermal storage (this may be nothing more than the normal thermal capacity of the building mass).

Possible energy flows exist between:

- collector and storage;
- collector and space;
- storage and space.

In a given system, some of these connections may not exist (or they may be insignificant).



The energy flows will fall into one of two broad categories:

- forced (using fans or pumps); or
- natural (involving conduction, convection, radiation, etc.).

The distinction being made is based on the driving influence causing the energy flow, and not on the degree of regulation. The term "natural energy flow" is not synonymous with "unregulated energy flow." Natural energy flow can, in fact, be highly regulated by mechanically-actuated controls, such as dampers or moving insulation. The important point is that the flow motivation derives from non-mechanical sources.

If all of the significant exchanges linking the three elements involve forced flow, the system shall be classified as active.

If all of the significant exchanges linking the three elements involve purely natural flow, the system shall be classified as passive.


If at least one of the exchanges involves forced flow and at least one involves purely natural flow, then the system shall be classified as hybrid.

This Plan encompasses passive and hybrid space heating systems.

Space Cooling

A space cooling system contains the following elements:

- a space (or, more specifically, contents) to be cooled;
- an environmental sink to which heat is discharged (sky, atmosphere, or ground);
- thermal storage (this may be nothing more than the normal thermal capacity of the building mass).



If all of the significant exchanges linking the three elements involve purely natural flow, the system shall be classified as passive.

If all of the significant exchanges linking the three elements involve forced flow, the system shall be classified as active.


If at least one of the exchanges involves forced flow and at least one involves purely natural flow, then the system shall be classified as hybrid.

This Plan encompasses passive and hybrid space cooling systems.

Hot Water

A hot water system consists of four elements:

- source (utility, well, etc);
- storage tank(s);
- collector(s);
- use point(s).



The system is passive if:

- The maximum height to which water must be elevated to operate the heating system does not exceed the static head from the utility or the head required for normal operation of the well system.
- The heat flow from collector to storage occurs by purely natural means (conduction, convection, etc.).

- Transport of heated water from storage to use point is accomplished strictly through the use of pressure from the utility or the well pump.

In short, a passive hot water system requires no pumps other than those required for the normal water supply (utility or well).

In addition to passive hot water systems, the Plan will consider hybrid systems using pumps to circulate hot water in delivery loops or to assist in moving heat from collector to storage. The crucial issue is that the static head and friction losses should be small enough to hold promise of a high coefficient of performance. This will normally mean delivery loops of modest length and close proximity of collector and storage.

SECTION B:
BACKGROUND OF FEDERAL INVOLVEMENT IN PASSIVE
SOLAR HEATING AND COOLING

The Federal government has been involved in funding solar energy research and development for a number of years. Previous to the establishment of the Energy Research and Development Administration in January 1975, which together with the Federal Energy Administration and other federal agencies became the Department of Energy in 1977, solar energy research was funded primarily by the National Science Foundation (NSF) with some support from other federal agencies, such as the Department of Housing and Urban Development (HUD) and the National Aeronautics and Space Administration (NASA). Funding from these agencies of passive solar heating and cooling projects was a small percentage of the small amount available for solar energy research.

Solar energy research and development support increased significantly under the NSF/RANN Solar Heating and Cooling of Buildings Program. Begun in 1973, three contractors undertook a study of the technical, economic, societal, legal, and environmental factors influencing the widespread use of solar energy for the heating and cooling of buildings. Passive solar systems, for all practical purposes, were not addressed in any of these studies. Results from these studies led to a number of proof-of-concept experiments funded by NSF and then by ERDA, none of which were passive. However, HUD had during this same time funded an analysis of a passively solar heated and cooled residence privately constructed in southern California.

Passage of the Solar Heating and Cooling Demonstration Act of 1974 provided government funds to demonstrate solar heating by 1977 and combined solar heating and cooling by 1979. Although passive solar systems have not been excluded from funding, very few passive solar projects have been demonstrated in either residential or

commercial buildings (3 out of 227 commercial projects and 25 out of 4,000 residential units). This lack of passive demonstration projects is due in part to the limited number of applications received, the lack of awareness and understanding of passive solar systems within the building industry, and the operational characteristics of the demonstration program. To address this problem, HUD sponsored a passive residential design competition during the summer of 1978. Over 550 applications were submitted, resulting in 162 awards: 145 for new homes and 17 for existing homes.

The initial stages of a passive solar research and development program were under way at Los Alamos Scientific Laboratories with the support of ERDA. LASL was developing the capability to predict passive solar system performance through the use of computer simulation and to validate the results through controlled test room experiments. At about the same time, a passive solar research and development plan was being formalized during the preparation of the interim National Program Plan for Research and Development in Solar Heating and Cooling (DOE/CS-0008). In this plan, five paths for passive solar systems were identified: two for building heating and control, and three for agricultural and industrial process heat. A more detailed discussion of these paths is presented in the background section of the technology development program area (see page). For each path, a number of research and development tasks were identified for funding in whole or in part by the Federal government.

On the basis of the interim R&D plan, two solicitations for passive solar research and development were issued: Request for Proposal No. 1443, "Controls and Passive Systems for Solar Heating and Cooling"; and Program Research and Development Announcement No. 0005, "Passive and Hybrid Systems for Solar Heating and Cooling Applications." As a result of these two solicitations, 19 building experiments were funded along with two control, one heat pipe, and one cooling study. In addition to these projects, LASL has continued its work in passive solar heating analysis, monitoring, and testing.

The Solar Energy Research Institute has established a Passive Technology Branch emphasizing design tool development, user evaluation, and passive design development. Lawrence Berkeley Laboratories has initiated projects to study radiative and passive cooling as well as potential applications of passive systems in large-scale commercial buildings. Also, the National Bureau of Standards is developing thermal data and instrumentation requirements for monitoring the performance of passive solar systems. Together, these efforts form the basis of the coordinated National Passive Solar Research and Development Program.

Besides the research and development elements of the present program, some work has been supported to look at legislation, tax credits, information availability, and building codes that influence the use of passive solar systems. Also, three national conferences and workshops on passive solar heating and cooling have been sponsored by DOE. On the whole, however, very little has been done in the technology utilization program area.

Passive solar systems have recently received significant support and attention from two major policy and planning studies: the Presidentially authorized Domestic Policy Review on Solar Energy, and the DOE-initiated Commercialization Readiness Assessment. The Domestic Policy Review concluded that passive solar systems can play a vital role in reducing United States energy requirements in space conditioning of buildings. The Commercialization Readiness Assessment built upon this conclusion with a comprehensive analysis of factors influencing the realization of this potential and a Commercialization Plan for the accelerated development and application of passive systems. The conclusions and recommendations from these two policy and planning efforts have been made part of this National Program Plan for Passive Solar Heating and Cooling.

SECTION C:
PROGRAM GOAL AND OBJECTIVES

The goal of the National Passive Program is the displacement of a substantial quantity of non-renewable energy through the rapid development and widespread use of passive solar heating and cooling systems. Appendix E indicates energy market penetration for passive solar heating systems with and without tax credit (as contained in the National Energy Act of 1978). Both cases assume a comprehensive federal passive program. Energy market penetration for passive cooling, large commercial buildings, and agricultural and industrial processes have not been analyzed to date.

Achievement of the program goal would be characterized by an awareness and application of passive systems by designers and builders; an availability of materials, components, and assemblies appropriate for passive solar design; a conducive application environment including necessary codes and standards, informed lenders, insurers, and regulators, and informational and educational programs; an awareness and understanding of and demand for passive solar heating and cooling by the general public; a significant ongoing research and development capability within the private sector; and, most importantly, a large number of passive solar applications in the residential, commercial, industrial, and agricultural markets.

The National Passive Solar Program is designed to achieve this goal by supporting research, development, and testing aimed at developing cost-effective passive solar energy materials, components, assemblies, and systems and by undertaking focused commercialization activities aimed at assuring the utilization of passive solar heating and cooling systems. With this in mind, the following program objectives have been formulated:

- Conduct a research and development program directed at identifying the technical performance and costs of various passive solar heating and cooling systems and developing the necessary documentation for product development, user-oriented design tools, and commercialization activities.
- Develop and widely disseminate design tools and methods for use by designers, builders, developers, and consumers.
- Develop analytical methods for rigorous technical and economic assessment of passive solar systems.
- Develop a full range of marketable passive products easily integrated with conventional construction materials and practices.
- Assist in the development of marketable passive designs for new and retrofit application in residential and commercial buildings.
- Market field test the feasibility of passive solar heating and cooling in new and existing residential and commercial buildings, with special emphasis on the development of low-cost systems for retrofit installations.
- Support passive solar heating and cooling applications in government buildings to promote the utilization of solar energy by all government agencies.
- Operate an information system for collecting, storing, evaluating, reporting, and disseminating technical, environmental, social, and economic data generated by passive solar research, development, market field testing, and commercialization activities.
- Conduct market research studies to determine user acceptance requirements and to identify areas of opportunity for focusing commercialization activities.

- Identify and promulgate the necessary legislation, codes, and incentives to mitigate or eliminate existing legal or institutional restrictions that may discourage the development and use of passive solar systems.
- Continuously re-evaluate when and where federal action should be taken to promote passive solar systems and determine what actions are most appropriate to promote those systems.
- Continuously monitor and assess activities performed under this plan to ensure that necessary feedback and communication is maintained within and between program areas.

SECTION D: IMPLEMENTATION

As previously mentioned, DOE has an ongoing, directed National Solar Research, Development and Demonstration Program. The DOE Commercialization Readiness Assessment for Passive Solar Heating has been completed, and the Congressionally mandated National Plan for Accelerating Commercialization of Solar Energy is still in progress. This National Program Plan for Passive Solar Heating and Cooling builds upon the existing R&D program, incorporates recommendations from the completed Commercialization Plan, and provides input to ongoing commercialization planning activity. It recognizes and incorporates the broad range of activities being managed by numerous federal agencies and national laboratories related to passive solar heating and cooling and integrates these activities into a coordinated Program Plan. Implementation of passive program tasks will utilize to the greatest extent possible the existing elements of the National Solar Energy Program. This will include the following:

- Demonstration Program: The residential and commercial solar demonstration program is likely to be extended until 1982. The passive residential design competition may continue, perhaps at a regional level. Commercial demonstrations of passive systems should be expanded, but done through a directed design development activity.
- Research and Development Program: A directed passive solar research and development program has been initiated and a first round of building experiments and studies has been funded. Passive solar research and development will be expanded to support materials and component studies, assembly development and testing, and systems development and analysis; to determine the cost and performance of a variety of passive solar heating and cooling concepts; and to develop user-oriented design methods for these concepts.

- Information and Education Program: Many efforts are under way to disseminate information on solar heating and cooling to a wide range of audiences. At the same time, educational programs and materials are being developed and implemented. Passive technology utilization activities will build upon these ongoing efforts.
- International Cooperation: There are established lines of communication between solar energy research and development in the United States and other countries, including several bilateral agreements for scientific and technical activities in solar energy. Also, there is great interest and ongoing research in passive solar systems in a number of these countries. The Plan will strengthen and build upon these relationships by sharing results and undertaking cooperative research and development in passive solar heating and cooling.
- Federal Buildings Program: This program provides a unique opportunity for the use of passive solar heating and cooling in Federally owned buildings. Activities will be directed towards identifying promising candidates within existing and proposed new federal buildings for the integration of developed passive solar heating and cooling systems.

The success of this National Passive Program depends not only on conducting successful research, development, and demonstration projects, but on the integration of passive solar systems into the national economy on a widespread and continuing basis. This requires the intimate involvement of many private organizations and institutions, especially small businesses, in the execution of the Plan and hence its development. If the technological and institutional developments produced by the program are to satisfy the needs of these organizations and institutions, it is essential that they be encouraged to participate in the development of guidelines, criteria, and specifications upon which the program is based. One of DOE's primary

considerations in designing approaches and in selecting participants in specific projects will be to ensure the early and continuing participation of these segments of the economy whose acceptance of passive solar heating and cooling is essential to its general adoption.

As with the majority of activities undertaken in support of the National Solar Research, Development, and Demonstration Program, performance of specific program tasks will be based primarily on public solicitations, such as Requests for Proposals (RFP's), Program Research and Development Announcements (PRDA's), Program Opportunity Notices (PON's), and Requests for Grant Applications (RFGA's). This process will maintain the involvement of industry, universities, and small businesses in performing identified program tasks. Also, project support is expected to continue from the national laboratories, the Solar Energy Research Institute (SERI), and the regional solar energy centers.

This National Passive Program Plan identifies various major systems for passive solar heating and cooling and then identifies tasks that must be completed to develop and introduce cost-effective passive systems. Since the Passive Program Plan is part of DOE's overall energy program, it has numerous points of contact with other DOE divisions and with other federal agencies. The implementation of this Plan will be coordinated with all appropriate groups by an interagency committee with interest and involvement in passive solar heating and cooling. Also, it is anticipated that a Passive Program Office will be established within DOE to assist this interagency committee in the coordination of implementation activities.

PART II: TECHNOLOGY DEVELOPMENT

SECTION E: BACKGROUND

SECTION F: SYSTEMS DESCRIPTION

SECTION G: TASK CLASSIFICATIONS

SECTION E: BACKGROUND

Technology development is that process through which an idea is developed to a point of potential widespread application. It generally involves research, development, testing, and documentation. Its domain is broad, encompassing basic physical studies as well as materials, assembly, and system development for a variety of applications (residential, commercial, agricultural, and industrial) and system functions (heating, cooling, lighting, and hot water). The result of the technology development process is either a product, documentation of results leading to user-oriented design methods, or building/system designs based upon products and/or design methods. The process must be sensitive to user needs and market requirements. The designer/researcher must be aware of the issues involved in the process of a technology gaining acceptance within the industry and the market (e.g., standard building practices, codes, and standards; education and training; financing; user attitudes; and market aggregation).

Technology development for passive solar heating and cooling has characteristics that significantly distinguish it from other energy technologies. Passive solar systems are design-oriented rather than product-oriented. The process usually involves the architectural translation of a concept or idea for using solar radiation or other environmental energies incident on a building to reduce the energy requirement of the building. Passive systems normally use common materials, components, and assemblies, but in ways different from traditional design practice. Consequently, the technology development program for passive solar heating and cooling is systems-oriented.

A systems focus does not imply that new materials and assemblies would serve no purpose. On the contrary, new materials and products

which are envisioned, and some of which are presently under development, have the potential to profoundly increase the impact of passive solar. The point is that highly effective passive solar systems can be realized now using common materials and building processes. The final success or failure of a passive solar design is based on the ability to organize the elements of the structure in such a manner as to provide for a significant fraction of the energy requirement in a predictable manner.

The specific objectives of the technology development program are to:

- Identify and collect environmental data relevant to the performance of passive systems. Availability of solar radiation and sky properties are of special importance, but work is also needed on atmospheric effects and ground conditions.
- Analyze existing materials and assemblies and develop new materials and assemblies appropriate for passive applications.
- Identify promising passive systems concepts.
- Develop thermal and economic models and computer simulation codes for all presently developed and characterized passive solar heating and cooling systems.
- Validate system models on the basis of data obtained from passive solar buildings and test rooms.
- Use validated computer simulation codes to perform systems studies related to parametric sensitivities, climactic applicability, economic trade-offs, etc.
- Use results of thermal and economic system studies to generate user-oriented design tools.
- Develop marketable products and designs.

Status of Technology Development

Prior to the establishment of a directed national solar heating and cooling research and development program, passive solar research and development was almost entirely carried out by a small group of dedicated researchers and practitioners. These individuals generated a variety of passive concepts, tested them, and eventually incorporated them into their buildings. Most of the time, these individuals' homes were the proving grounds for ideas on passive solar designs. Their decisions were often based as much on intuition and feel as they were on hard technical data and design methods. Although their procedures may not have been analytical in all cases, their results, most often, were impressive. It is in large measure because of these pioneers that passive solar heating and cooling is receiving the high level of attention that it is today.

The advantages of and opportunities for passive solar heating and cooling were well recognized and represented in the National Program Plan for Research and Development in Solar Heating and Cooling (DOE/CS-0008). The R&D plan identified eleven paths[†] for the solar heating and cooling of buildings--of which two were for passive solar systems--and eleven paths for agricultural and industrial applications--of which three were for passive systems. For each path, a number of research and development tasks were identified for government support. A brief description of the five paths to passive solar heating and cooling is presented in this section of the Plan. A complete listing of all technology development projects funded by the passive program is presented in the book, Solar Heating and Cooling Research and Development Project Summaries (DOE/CS-0010, currently being updated).

[†]A path is simply the linking of a method of energy collection or rejection with a particular application.

Heating and Cooling of Buildings

Passive Heating of Space or Structure (Path H-2): This path encompasses a variety of passive solar heating systems. Its focus is broad, with R&D activities in the area of materials characterization and development, assembly evaluation and development, and systems modeling and testing. The schedule of tasks called for the initiation of system studies of existing buildings, basic material and climate studies, and hybrid and control studies during 1978. The status of major activities is as follows:

- Computer simulation model for thermal storage walls completed and in use. Mass storage wall (with and without vents) and water storage wall computer modeling approaches validated by comparison with test room results. Models for direct gain, sun space and roof storage systems being developed.
- Three thermal storage wall heating systems analyzed for hourly solar/weather data from 29 cities.
- Parametric studies completed for thermal storage wall effect of storage mass, glass area, allowable room temperature, effect of wall thickness and thermal conductivity, ground reflectance, number of glazings, and inlet condition.
- Twenty-five passive solar heated buildings instrumented with two to four months of winter data accumulated for each building.
- Fifteen 5' x 8' x 10' test rooms constructed. One year of data accumulated for various thermal storage wall system configurations in two test rooms. Remainder of test rooms will include experiments on thermic diode panel, direct gain, roof aperture systems, and material and assembly studies. These experiments will be operational during the winter of 1979.
- Twelve building experiments funded to demonstrate passive and hybrid solar heating and cooling systems. Experiments involve a range of systems including direct gain (south aperture and

shaded roof aperture), storage walls, storage roof, sun space (greenhouse and solariums), and ponds.

- Three test room experiments funded to study (1) details of convective flows associated with storage walls with vents; (2) polyethylene greenhouse retrofits with a variety of storage materials; and (3) a number of system types interacting with an existing building.
- Seven assembly component studies funded to develop, monitor, and assess various passive system elements, including heat pipes, control techniques, collector assemblies, reflectors, lightweight storage, and thermic diodes.
- Manufactured buildings program initiated to investigate the application of passive techniques to factory-built residential, commercial, and agricultural buildings.
- Design tool program initiated to develop simplified techniques.
- Investigations of macro- and micro-economics of residential applications of passive techniques are ongoing, including the development of a passive system costing technique and economic system optimization procedure.
- Program initiated to identify and evaluate possible roles for passive solar energy within more general energy management schemes for large-scale commercial and industrial buildings.
- Systems studies under way to investigate various passive solar domestic hot water options.
- Detailed thermocirculation model completed for laminar and turbulent flow between parallel plates.
- Passive solar simulation capability being integrated into public domain building energy analysis computer programs.
- User evaluation of speculatively built residential passive solar designs is under way.

- Two user-oriented handbooks for residential design to be completed in FY 1979.
- Performance factors for passive solar heating systems have been defined.

Passive and Hybrid Cooling (Path C-4): This path is concerned with the cooling of buildings through selective interaction with cooler parts of the environment, which can be accomplished in a variety of ways, even during those times of the year when the average dry-bulb temperature is high. Among the common methods of passive cooling are ventilation of the structure (or storage mass) with night air, which works well in climates with large diurnal temperature swings; evaporative cooling, which works well in dry climates; radiative sky cooling, which works well in climates with clear skies; and conduction to the ground, which works well in locations where the average ground temperature is low enough to be consistent with human comfort. The R&D emphasis is directed towards expanding the knowledge of the processes involved, generating and validating thermal simulation computer models, and determining the heat rejection, storage, and absorption characteristics of various designs in different geographic areas.

The schedule of tasks called for continuing system studies of current passive approaches, developing variants of current passive approaches, and performing basic materials and climate studies during 1978 and 1979. The status of these activities is as follows:

- A computer simulation program to model the infrared spectral emission characteristics of the atmosphere under a variety of weather conditions has been funded.
- One test cell funded to test and analyze a combined passive and hybrid night-sky radiation and convective cooling system.
- Data collection and evaluation is under way for a roof pond passive heated and cooled house in Las Cruces, New Mexico.

- A detailed spectral radiometer has been developed and four instruments have been deployed in various parts of the U.S. By the fall of 1979, a full summer of data will be available for all four sites.
- A contract has been awarded to refine movable-insulation schemes for thermal storage roof systems.
- A five-year joint U.S.-Saudi Arabia program in passive cooling was begun in FY 1979.

Agricultural and Industrial Process Heat

The following paths and their status are not described in the present interim National Program Plan. However, they will be completed for the final Plan:

Passive Solar Heating for Shelters and Greenhouses (Path HP);
 Direct Drying of Agricultural and Industrial Products (Path DD);
 Passive Cooling for Agricultural and Industrial Process Applications (Path CP).

Strategy for Technology Development

The strategy for technology development is composed of three elements: basic physical studies, product development, and systems development.

Basic Physical Studies

Because our knowledge of environmental effects is very limited and our present models of these effects inaccurate, studies will be initiated to examine atmospheric and terrain effects and physical properties of sky and ground. The objective of these studies would be to develop accurate models of environmental effects to be used in more detailed computer simulation programs for passive solar heating and cooling system performance calculations.

Two additional basic physical studies will also be initiated: (1) an analysis of existing solar radiation data and recommendations for the type and quality of data needed for passive solar design (vertical surface solar radiation data, for example); and (2) a detailed examination of heat exchange mechanisms based upon basic principles of heat transfer.

Product Development

Although many of the elements of passive solar systems are conventional building materials, new materials need to be developed and existing materials analyzed for use in passive solar designs. Development and analysis projects will be initiated in the following areas: glazings (analysis of the thermal and optical properties of glazing materials alone and in combinations, and development of high-transmissivity, high-insulation glazings, optical shutters, and optical coatings); absorbers and emitters (studies of existing absorption and emission characteristics of materials); reflectors; insulation; storage (especially development and analysis of lightweight materials for heat storage at slightly above room temperature); fluids; and sealants.

At the present time, an insufficient number of package assemblies are available for integration into passive solar designs. Projects will be funded to develop and analyze assemblies in the following areas: glazing, reflector, and movable insulation assemblies, alone and in combination; storage assemblies, particularly container designs for mass production and ease of installation; and sensors, actuators, and controls, focusing on light and heat flow control devices.

Projects or studies may also be initiated for fans, pumps, and valves used in hybrid systems; heat exchangers, particularly air-earth heat transfer; and heat pipes and thermal diodes.

Systems Development

This is the most crucial element of the technology development program area. It brings together all of the previous materials, assemblies, and basic physical projects and studies for the concept generation, thermal analysis, testing and documentation of passive solar heating and cooling systems. The strategy for systems development is as follows:

- Continued development of computer simulation codes for presently developed passive solar heating and cooling systems; continued testing, monitoring and analysis of existing buildings and test rooms; and validation of system models with test results. The purpose of this strategy element is to generate the needed documentation leading to the preparation of user-oriented design tools such as handbooks, programs for programmable calculators, and detailed computer design methods.
- Concept generation, assessment, and analysis of promising new passive solar heating and cooling systems, including, where appropriate, computer simulation model development, test room construction, model validation, and documentation.
- Initiation of a side-by-side, controlled, adaptable, full-scale test building experiment involving a range of passive solar systems to be located at several sites representing distinct climactic conditions. The objectives of the experiment would be to determine energy yields that can be expected from various passive solar systems in different climactic regions, validate computer simulation analysis models of those systems in full building experiments, establish levels of cost-effectiveness for different types of passive systems in different geographic/climactic regions, and demonstrate the viability of passive solar systems in different parts of the country. (Beyond these development activities, there is the

opportunity to increase the awareness and understanding of passive solar heating and cooling within the building industry, the architectural and engineering colleges and universities, and among the general public.

Emphasis for Technology Development

Because the technical basis for understanding and designing passive solar systems is just emerging, most research and development has focused on small-scale, single-zone structures, primarily residences and test rooms. Several larger passive solar buildings have been built, but characteristically they have resembled the small, single-zone structures. While it is important to continue a technology development emphasis in this area to further understanding and to develop an analysis and design capability, it is clear that the focus must be enlarged. The opportunity for passive solar systems in large, new structures such as schools, office buildings, commercial facilities, and warehouses is large. Additionally, existing residential and commercial structures represent both a challenge and an opportunity for the development and application of passive systems. Beyond the opportunity is the necessity to redesign our existing buildings to better utilize our dwindling fossil fuel resources.

For these reasons, a substantial new effort will be invested in technology development activities addressing large-scale, multi-zone structures and retrofitting existing residential and commercial buildings. Systems concept generation, assessment, computer simulation modeling, full-scale testing, and architectural integration will be stressed. These activities will be tied to the demonstration and the federal buildings programs for possible early application of developed concepts.

SECTION F:
SYSTEMS DESCRIPTIONS

Beyond the general definitions of passive solar heating and cooling are a number of significant factors that influence the performance of passive solar systems and begin to characterize generic types of systems. This section identifies those significant factors for space heating and cooling and presents a scheme for system classification.

Space Heating (Path H2)

We may characterize passive solar heating systems by consideration of the following important combinations of factors:

- I. Where the sunlight is accepted into the system and the portion of the sky from which sunlight is predominantly received. There exists a limited number of energy-advantageous combinations of these two factors:
 - A south aperture in the building accepts sunlight from the south sky (winter sun).
 - A shaded roof aperture admits sunlight predominantly from the south sky (winter sun).
 - A roof aperture in the building accepts sunlight from the upward part of the sky (summer sun).
 - A remote aperture, i.e., one which is not part of the building envelope proper, can be set at any angle to accept light from any part of the sky.

- II. The manner in which energy is delivered to the space, which in turn is correlated to the degree of uniformity which can be imposed on the thermal environment of the space. There exist three broad categories of passive solar heating systems based on the energy delivery to the space:

- For direct heating, sunlight is admitted directly to the space, where it is converted to heat by absorption on the interior surfaces and contents of the space (people, furnishings, plants, etc.). The contents or surfaces of the space must be exposed to sunlight in order for the system to collect energy. The air temperature in the space "floats" with the absorbing surfaces and/or the storage.
- For indirect heating, sunlight is converted to heat by absorption on a surface external to the space. Contents of the space are not exposed to direct sunlight. The air temperature in the space "floats" with the absorber and/or the storage.
- For isolated heating, sunlight is converted to heat by absorption on a surface external to the space. Contents of the space are not exposed to direct sunlight. The air temperature in the space can be regulated independently of the absorber and storage.

The following matrix indicates the level of control of the thermal environment for each type of system (direct, indirect, or isolated) in terms of sunlight exposure and thermal coupling of the space to absorbing surfaces or storage mass:

	Direct	Indirect	Isolated
Sunlight enters space	Yes	No	No
Air temperature floats with absorber and/or storage	Yes	Yes	No

Isolated heating systems can be completely passive, but in terms of control over the thermal environment, they resemble active systems; that is, the system interaction with the space can be fully regulated and turned "on" and "off."

Given these basic definitions, we can classify the common passive heating systems in terms of the following matrix:

DIRECT	INDIRECT	ISOLATED	
●	●	●	SOUTH APERTURE
●	●	●	SHADED ROOF APERTURE
●	●	●	ROOF APERTURE
	●	●	REMOTE

Various combinations of aperture location and mechanisms for transferring energy to storage and to the occupied space are shown schematically in Figure II-1.

The configurations shown include the currently most common passive heating systems and provide a representative sampling of less common systems which may have equal potential. These combinations by no means exhaust the list of possibilities. Additionally, this figure introduces a general nomenclature for passive system description.

Combinations of the three systems are of considerable importance. For example, direct gain openings can be placed in a storage wall or an isolated storage wall. The openings can be sized to account for daytime winter heating requirements and for year-round illumination. Another example of combined direct and indirect heating is the use of clear or translucent water storage containers placed in the aperture. Some light is absorbed and stored in the water and some light is transmitted into the space to heat and illuminate.

There exists an assortment of multi-zone, single-story schemes with solar heating applied to each zone. Some of the more interesting examples are illustrated in Figure II-2. These systems have the attractive quality that each zone can be individually designed to meet the particular thermal and illumination requirements dictated by the intended function of the space.

Asymmetric solar excitations, such as occur in south aperture systems, naturally drive a north-south zone separation. Multi-story

commercial structures will clearly be north-south zoned in most cases and the functional utilization of the space must be planned in accordance. However, in order to fully implement passive design concepts and maintain flexibility in space utilization, methods of enhancing or suppressing the natural zone structure of the space must be developed. In some cases this can be accomplished by purely passive means; in other cases hybrid schemes involving mechanically-assisted heat transfer will be more appropriate. Figures II-3 and II-4 show examples of concepts for using passive solar energy in multi-story buildings.

Table II-1 is a list of space-heating systems selected for intensive development activity. It is not assumed that this list exhausts the promising possibilities, nor is it assumed that government supported development activity will be limited to this list. Unsolicited proposals for the development of promising innovative systems outside the scope of this list are welcomed by the Department of Energy. It is understood that the option of a sun-space add-on should be considered for each of the south-wall systems. Work on unshaded direct-gain roof elements will emphasize limited collection areas for daylighting applications (i.e., skylights). For multi-zone, single-story buildings, the emphasis will be on the natural coupling between zones and simple, effective means of moving energy in order to control zonal differentiation. Consideration should be given to systems in which energy is delivered to each zone and systems in which energy is delivered to some zone(s) and transported by natural or forced means to other zone(s).

The problem of energy transport becomes very critical in large-scale buildings, particularly for high-occupancy commercial applications or situations where industrial processes require high ventilation rates. The most appropriate roles for passive solar within more general energy management schemes are not presently identified, and identification of those roles will require a substantial level of effort in innovative concept generation as well as rigorous technical evaluation.






FIGURE II-1: EXAMPLES OF PASSIVE SOLAR HEATING SYSTEMS

FIGURE 11-2: EXAMPLES OF SINGLE-STORY, MULTI-ZONE, PASSIVE SOLAR SYSTEMS





47




FIGURE II-3: AN EXAMPLE OF A MULTI-STORY, MULTIZONE PASSIVE SOLAR SYSTEM




FIGURE II-4: AN EXAMPLE OF A MULTI-STORY, MULTI-ZONE PASSIVE SOLAR SYSTEM

TABLE II-1
Heating Systems for Development

SINGLE ZONE:

South Aperture:

1. Direct-Gain Wall
2. Storage Wall (with and without vents)
3. Isolated Storage Wall (with vents and/or moving insulation)
4. Collection Wall (with storage floor, wall, or ceiling)
5. Collection Sun-Space (with storage floor, wall, or ceiling)
6. Combinations of 1 through 5

Shaded Roof Aperture:

7. Shaded Direct-Gain Roof
8. Shaded Storage Roof

Roof Aperture:

9. Direct-Gain Roof
10. Storage Roof
11. Collection Roof (with storage floor, wall, or ceiling)
12. Combinations of 7 through 11

Remote Aperture:

13. Remote Collection with storage floor
14. Remote Collection with isolated storage (e.g., solar ponds)
15. Ground Preheat

MULTIZONE:

Single Story

Multi-Story

Community and Urban Projects

Space Cooling (Path C4)

Passive cooling involves the discharge of energy by selective coupling of the system to the cooler parts of the environment. If the environmental conditions are correct, this energy flow will occur by natural means. Possible environmental sinks for heat from the system are the sky, atmosphere, and ground.

In sky cooling, radiation from the system passes through the atmosphere and dissipates into outer space. Environmentally, it is the "purest" mode of cooling, since none of the energy discharged from the system appears in the local microclimate. Radiative sky cooling works well in environments with clear skies, and has the potential to cool the system below the ambient air temperature. The primary limit to this cooling mechanism is convective and radiative heat gain from the surrounding atmosphere.

Energy from the system can also be discharged directly to the atmosphere during those times when the ambient air conditions are favorable to such an exchange. Heat can be dissipated by raising the sensible heat energy of the surrounding air (e.g., night air cooling) or by raising its latent heat energy (e.g., evaporative cooling). In either case, the energy transfer can be greatly enhanced by increased air movement. The driving force for this movement can come from wind, fans, or special convective drive mechanisms. In dry environments, evaporative cooling has the potential, like radiative sky cooling, to reduce the system temperature below the ambient air temperature. Evaporative cooling has the disadvantage of expending water, a commodity which may be in short supply in the climates where evaporative cooling is most effective.

Because of the great thermal mass of the earth, ground temperatures during the summer will normally be several degrees below the average ambient air temperature. Unlike evaporative or radiative sky cooling, which require special climactic conditions such as dry air or clear skies, ground cooling can be used to displace a substantial fraction of the normal cooling load, even in humid, overcast

environments. However, dehumidification by mechanical means may still be required.

The following table summarizes the environmental sinks, along with the primary mechanisms involved in the energy transfer.

Sink	Primary Energy Transfer Mechanism
Sky	Radiation
Atmosphere	Convection [†]
Ground	Conduction

[†]Includes evaporation.

In analogy to heating systems, there are direct, indirect, and isolated cooling processes:

- Direct cooling occurs when the interior surfaces and contents of the space are exposed directly to the environmental energy sink(s).
- Indirect cooling occurs when the space is cooled by uncontrolled radiation to storage (or some exchange surface) which is in turn cooled by exposure to the environmental energy sink(s).
- Isolated cooling occurs when the space is cooled by controlled fluid or radiative transfer to storage (or some exchange surface) which is in turn cooled by exposure to the environmental energy sink(s).

As in the case of heating, we can classify passive cooling systems in terms of a matrix:

DIRECT	INDIRECT	ISOLATED	
●	●	●	SKY
●	●	●	ATMOSPHERE
●		●	GROUND

A representative sample of combinations of the environmental thermal energy sinks and mechanism for transferring energy to the occupied space are shown in Figure II-5. Here, also, these schematics include the currently most common cooling systems and other possible configurations. Again, the figure does not exhaust the list of potential cooling systems.

Table II-2 is a list of promising space-cooling systems selected for intensive development activity. Emphasis has been placed on systems whose elements can serve both a heating and a cooling function, and whenever possible the heating system nomenclature is retained. For example, a Storage Roof cooling system uses all the same elements as a Storage Roof heating system, except that the air space, which may be necessary to reduce winter losses, must be eliminated for summer cooling. Also listed in the table are several promising cooling schemes whose elements do not serve a heating function.

In general, passive heating is considerably more advanced than passive cooling. As a consequence, the list of cooling schemes identified for concentrated attention is not as well-defined nor as detailed as the list of heating systems. For many advanced heating systems there does not exist a well-defined cooling system employing some or all of the same elements. For example, there are several well-understood Storage Wall heating systems, but no well-defined schemes for using that mass with comparable effectiveness in the cooling mode. Despite the lack of well-defined concepts, the idea of using storage walls in the cooling mode appears to merit further

consideration. Similarly, the list contains other cooling systems derived from heating systems, such as shaded storage roof, and cooling roof with storage floor.

As in the case of passive space heating, roles for passive cooling in more general energy management schemes for large-scale commercial and industrial buildings remain to be identified and evaluated.

It is not assumed that this list of space-cooling systems exhausts the promising possibilities, and proposals for development of innovative systems are welcomed.






FIGURE II-5: EXAMPLES OF PASSIVE SOLAR COOLING SYSTEMS

TABLE II-2
Cooling Systems for Development

SINGLE ZONE:

Sky and/or Atmospheric Sink:

1. Storage Roof[†]
2. Cooling Roof with storage floor, wall, or ceiling[†]
3. Evaporative Cooling Ponds (remote)[†]
4. Shaded Storage Roof[†]
5. North-Facing Shaded Storage Roof

Atmospheric Sink:

6. Storage Wall[†]
7. Night Air-Charged Storage Floor, Wall, or Ceiling[†]
8. North Storage Wall[§]
9. Flat Shaded Storage Roof
10. Regenerative Air-Charged Storage
11. Ventilation

Ground Sink:

12. Isolated Ground[†]
13. Direct Ground

MULTIZONE:

Single Story

Multi-Story

Community and Urban Projects

[†]Storage has dual function in analogous heating system.

[§]For direct-gain heating systems, storage has heating function.

SECTION G:
TASK CLASSIFICATIONS

This section describes the areas by which the tasks are classified. The technology development tasks themselves are contained in Appendix A with systems development schedules presented in Appendix B. Tasks are classified in three general categories: Basic Physical Studies, Product Development, and System Development. The sub-categories within these classifications are identified in Table II-3.

This classification scheme recognizes that the system development process plays a central role in motivating tasks in the basic physical studies and product development areas, in addition to the tasks which are directly related to the development of passive systems. The systems development process steps and their relationship to the two supporting task areas and to the technology utilization tasks is shown schematically in Figure II-6. For clarity, the major activities performed during the process are shown to the left of the schematic flow diagram.

Following is a brief description of the type of activities to be undertaken in each task area.

Basic Physical Studies Tasks

Basic physical studies are concerned with environmental and physical phenomena that can influence the performance of passive solar heating and cooling systems. The following activities have been identified for study:

<u>Name of Study</u>	<u>Description of Study</u>
Solar Radiation	Analysis of existing solar radiation data and recommendations for the type, quality, and disposition of data required for the design of passive solar heating and cooling systems.

TABLE II-3
Technology Development Task Classifications

<p>I. BASIC PHYSICAL STUDIES</p>	<p>A. Solar Radiation B. Sky Properties C. Atmospheric Effects D. Ground Properties E. Terrain F. Heat Exchange Mechanisms</p>
<p>II. PRODUCT DEVELOPMENT TASKS (MATERIALS AND ASSEMBLIES)</p>	<p>A. Glazing Mat'ls & Assemblies B. Absorber & Emitter Mat'ls & Assemblies C. Reflector Mat'ls & Assemblies D. Insulation Mat'ls & Assemblies E. Storage Mat'ls & Assemblies F. Combination Assemblies G. Fluids & Sealants H. Sensors, Actuators, & Controls I. Fans, Pumps, Valves, etc. J. Heat Exchangers K. Heat Pipes & Thermal Diodes</p>
<p>III. SYSTEM DEVELOPMENT TASKS</p>	<p>A. Concept Generation & Assessment B. System Specification (Architectural & Engineering Definition) C. System Analysis (Thermal Modeling, Economic Analysis, etc.) D. Data & Instrumentation Requirements E. Performance Data Acquisition (Test Rooms & Instrumented Buildings) F. System Studies (Parametric Sensitivity, Climactic Applicability, etc.) G. Design Tools (Handbooks, Computer Codes, etc.) H. Performance Criteria I. Market Field Tests</p>

- Architectural/Engineering Definition
- Design Development
 - Thermal Modeling
 - Economic Analysis
 - Human Comfort
 - Environmental Analysis
 - Architectural/Engineering Evaluation
- Validation of Analysis Technique
- Test Rooms/Small Scale Testing
- Instrumented Buildings/Full Scale Tests
- Parametric Sensitivity
- Climactic Applicability
- Control Strategies
- Rules-of-Thumb
- Handbooks
- Computer Programs
- Competitions
- Marketable Design Development




FIGURE II-6. System Development Process

<u>Name of Study</u>	<u>Description of Study</u>
Sky Properties	Collect data on sky radiation properties in different geographic locations. Analyze and assess applicability of radiative cooling in various parts of the country. Develop programs for computer simulation of atmosphere.
Atmospheric Effects	Assemble existing design-related information on wind velocity, relative humidity, ambient dry-bulb temperature, dewpoint, etc., and extend measurements of these quantities as appropriate. Develop computer simulations of the effects of these factors on the operation and efficiency of the various passive heating and cooling systems.
Ground Properties	Expand as required the data base for ground temperature and conductivity for various soil types and conditions. Develop computer simulation programs for ground-thermal effects. Validate computer code against test results.
Terrain	Assess impact of natural terrain and the built environment on passive solar heating and cooling systems and identify range of suitable sites. In particular, the effects of the environment on solar availability and wind patterns will be addressed.
Heat Exchange Mechanisms	Examine heat exchange and heat transfer processes which are appropriate to passive solar heating and cooling applications. Consideration will be given to heat flow within fluids, between different fluids, and between fluids and solids.

Product Development Tasks

Tasks in the product development category include design, development, testing, and evaluation of both materials and assemblies of materials which will either enhance passive system performance or simplify the implementation of a passive design. Materials tasks are concerned with evaluating existing materials for their applicability to passive solar design concepts and the development of new materials and components to solve specific problems encountered in passive solar design. Activity in this area includes gathering and publishing data on existing materials which are of special interest to passive solar system designers.

An assembly is an organization of materials and/or components into a functional portion of a passive solar system. This generally involves traditional building materials and products that are "assembled" to form collection elements (i.e., glass and framing into window assemblies), storage elements (i.e., concrete or masonry units for thermal storage wall), and other functional elements of passive solar systems (i.e., absorbers, reflectors, insulation, and controls). The tasks in this area are directed toward the evaluation of these materials and products in complete assemblies and the development of entirely new assemblies for passive solar heating and cooling applications. Activity in this area includes gathering and publishing data oriented toward passive solar building designers.

<u>Project Area</u>	<u>Description of Activity</u>
Glazings	Analyze the thermal and solar optical properties of glazing materials alone and in combination, and develop high transmissivity glazings, optical shutters, heat mirrors, and coatings with other advantageous properties such as I.R. transparency or directional sensitivity of optical properties. Characterize the performance of glazing assemblies

Project Areas

Description of Activity

	<p>in terms of in-use optical and thermal transmission and reflection and in terms of infiltration. Develop movable glazing assemblies.</p>
Absorbers and Emitters	<p>Examine existing absorption and emission characteristics of materials with emphasis on those used in radiative cooling systems. Develop selective absorbers and emitters for heating and cooling applications. Develop absorber/storage and emitter/storage combinations. Develop schemes for cooling radiators.</p>
Reflectors	<p>Examine properties of existing reflective materials. Test as required. Organize and publish data. Develop heat mirrors and other innovative reflective materials; develop ground plane reflectors and reflector/movable-insulation combinations.</p>
Insulation	<p>Review available insulation material properties and determine applicability to passive design approaches. Organize and publish data. Develop movable insulation systems alone and in combination with glazing, reflector, and storage assemblies.</p>
Storage	<p>Characterize existing materials, searching for improved combinations, and develop lightweight and/or high heat capacity storage materials. Develop high thermal mass masonry and concrete structural systems, water containers, and containerization for phase change materials.</p>
Combinations	<p>Develop designs for factory or site-built combinations of glazing, absorbers/emitters, reflectors, insulation or storage that will simplify the</p>

Project Areas

Description of Activity

construction of passive systems. Both economic advantages and fabrication simplifications will motivate these tasks.

Fluids and Sealants

Examine existing fluids from the point of view of corrosion, specific heat transfer, and latent heat transfer. Consider possibilities of reverse thermosyphoning. Develop improved sealants around dampers and movable insulation and improve integration of glazing systems into the building envelope.

Sensors, Actuators, and Controls

Evaluate existing sensors, actuators, and controls for performance, cost, durability, and reliability. Identify need for and develop new devices.

Fans, Pumps, and Valves

Assess state of the art for applicability and appropriateness to passive solar systems. Identify need for and develop new devices.

Heat Exchangers

Assess state of the art for applicability and appropriateness to passive solar design. Generate new concepts, including prototype for air-earth heat transfer. Assess concepts and test most promising for cost and performance.

Heat Pipes and Thermal Diodes

Develop thermal diodes and generate concepts for heat pipe and thermal diode applications to passive solar systems.

Systems Development Tasks

The full development of a passive solar system encompasses the following activities:

<u>Name of Activity</u>	<u>Description</u>
Concept Generation and Assessment	Develop basic physical descriptions of systems including their thermal processes and proposed modes of operation. This activity is followed by a preliminary evaluation of the systems in terms of technical and economic potential. It is assumed that this activity would occur at several critical points during the development of a system, but special attention will be given to the preliminary assessment which occurs immediately after concept generation.
System Specification	This activity results in the engineering realization of a concept. It includes the detailed physical description of the system and the manner in which it is integrated with the conventional building structure and systems. Materials and fabrication procedure identification, controls and operating strategies definition, etc., are part of the specification procedure.
Systems Analysis (Thermal Modeling, Economic Analysis, Human Comfort, Environmental Analysis, etc.)	This theoretical proof-of-concept activity consists of a complete analysis of the specified passive solar heating and/or cooling system. This evaluation will include thermal and economic considerations, environmental impact if appropriate, technical feasibility,

<u>Name of Activity</u>	<u>Description</u>
Data and Instrumentation Requirements	and human comfort and human interaction factors as necessary. This analysis will establish preliminary performance criteria and will be used in the definition of thermal performance factors and development of specifications for instrumentation appropriate to monitoring of performance factors in subsequent testing activities.
Performance Data Acquisition (Test Rooms and Instrumented Buildings)	Definition of thermal performance factors and development of specifications for instrumentation appropriate to monitoring the performance factors of full-scale buildings. Controlled experiments involving parts of systems or miniature systems. This is the first step in the engineering proof-of-concept. The final engineering proof-of-concept includes controlled experiments involving full-scale buildings. These case studies are utilized to provide final validation for the systems analysis activities described above.
System Studies	Studies dealing with thermal and economic performance sensitivity, climactic applicability, control strategies, economic trade-offs, and other system optimization considerations.
Performance Criteria	Results of experiments and studies will be used to establish performance expectations.

<u>Name of Activity</u>	<u>Description</u>
Design Tools	Results of the systems studies tasks and data collected from the product development tasks, performance data acquisition tasks, and system analysis tasks will be documented and published in forms appropriate to all levels of the building community. Handbooks, rules-of-thumb, guidelines, hand-held calculator programs, and other aids will be made publically available.
Market Field Tests	The final step in the technology development process is the testing of the marketability of the end-products: the design concepts, the design tools, the associated materials and hardware. The market field testing program will assess the compatibility of the technology with the marketplace and with the users of the technology who produce the marketable designs and products.

PART III:

TECHNOLOGY UTILIZATION

SECTION H: BACKGROUND

SECTION J: PROCESS DESCRIPTION

SECTION K: TASK CLASSIFICATIONS

SECTION H: BACKGROUND

Technology utilization is the process of identifying cost-effective and environmentally and socially acceptable technologies and developing a conducive application environment (market) for those technologies. It is concerned with moving a technology from research, development, and market field testing to widespread acceptance and application in the marketplace. This purposeful movement of a technology is often called the commercialization process.

The commercialization of passive solar systems is distinctly different from commercialization of hardware-oriented technologies. In the latter case the components and systems are typically visible entities, the contribution of which to the welfare of the consumer is easily determined and/or readily apparent. Passive solar systems, on the other hand, are generally integral parts of the building design. The passive solar components are not easily distinguishable from the remainder of the structure; they often consist of materials which are already common in the building industry (e.g., glass, masonry, insulation, etc.).

Passive solar energy utilization is primarily a design procedure. Successful commercialization relies, first, on casting the procedure in a form that is amenable to application by the design profession; second, on stimulating the profession to apply the procedure; and third, on sensitizing both the consuming market and consumer-supporting financial, utility, and real estate segments of the economy to the benefits of passive design through existing communication channels.

The specific objectives of the technology utilization program are to:

- Determine the technical, market/economic, environmental, and institutional readiness of passive cooling and domestic hot water systems for commercialization. This objective has been

accomplished for passive solar heating. If appropriate, prepare a detailed commercialization plan.

- Conduct detailed market research studies to determine user acceptance requirements and to identify areas of opportunity for focusing commercialization activities.
- Operate a technology transfer program for collecting, storing, evaluating, reporting, and disseminating technical, market/economic, environmental, and social data generated by passive solar research, development, market field testing, and commercialization activities.
- Widely disseminate passive solar design tools to designers, builders, and consumers.
- Establish an effective education and training program for architects, engineers, builders, developers, construction tradespeople, lending officials, and code officials.
- Stimulate the passive design delivery capability of the construction industry by assuring solar access, establishing effective performance criteria, reducing codes and standards hurdles, and introducing economic incentives.
- Stimulate and accelerate the demand for passive solar designs through a coordinated program of consumer education; utility involvement; federal, state, and local facilities programs; tax credits; and design competitions.

Status of Technology Utilization

Only limited passive commercialization activities are occurring throughout the country, most of which are non-federally funded. A few of these activities are described below.

- HUD has sponsored in conjunction with DOE and SERI a passive residential design competition resulting in 162 awards.
- The states of Minnesota and Illinois have sponsored residential design competitions.
- TVA, Wisconsin Power and Light, Pacific Gas & Electric, and many other utilities are investigating the peak load sharing potential of passive systems and consumer loan programs to finance solar system costs.
- New Mexico, California, Oregon, and Colorado have income tax credits for passive systems.
- Virginia has a property tax exemption provision for passive systems.
- California, New Mexico, and several other states have initiated passive solar education courses for builders and designers.
- Four regional solar energy centers have been established by DOE to assist in the accelerated commercialization of solar energy technology.
- Certain localities (e.g., Davis, California) have modified building codes and zoning regulations to accommodate passive systems.
- SERI has completed a technology readiness assessment of passive solar heating and cooling focusing primarily on economic performance projections.
- Several publications and pamphlets on passive systems have been completed for designers and builders including a passive solar bibliography and a survey of passive solar buildings.

Even though passive systems exist which have proven potential for energy savings, the rate of new passive buildings construction indicates a lack of and need for commercialization activities.

Passive solar designs have not reached the general marketplace. This is partially due to the lack of adequate economic and thermal performance data for various passive designs. To have a major impact in the marketplace, a definite need exists for an organized and concentrated program to promote the awareness of, supply of, and demand for passive solar systems.

Strategy for Technology Utilization

The commercialization strategy for passive solar heating and cooling systems is based on the following considerations:

- Regional and local conditions play an important role in the commercialization of passive solar systems. The building design and construction industries and the consumer market are more regionally and locally oriented than are most consumer-hardware industries.
- The commercialization of passive solar systems must emphasize education of an existing industry rather than the development of a new one. The building industry exists with established constituencies and practices; it must be sensitized to the passive solar concepts and benefits.
- Passive solar design is more an attitude and a design process than a technology. Commercialization activities must recognize the motivational and knowledge-intensive characteristics of passive design and respond accordingly.

The strategy for technology utilization is composed of four elements: commercialization readiness assessment, technology transfer, stimulation of technology delivery capability, and stimulation of market demand.

Commercialization Readiness Assessment

Prior to the commercialization of any technology, it is necessary to know the technical, market/economic, environmental, and institutional readiness of the technology to enter the marketplace. This includes identifying the benefits to be achieved by commercializing the technology, as well as the barriers that must be mitigated. The readiness assessment and benefits analysis result in a commercialization plan describing a coordinated set of development and utilization activities to move the technology into the marketplace. This would include market research to characterize the market for various passive systems by consumer group, by user type, by application, by geographic location, and by alternative fuel costs.

A commercialization readiness assessment has been performed for passive solar heating. The results and recommendations of this assessment have been included in this Plan. Assessments need to be performed for passive cooling, domestic hot water, and agricultural and industrial processes.

Technology Transfer

Just as important as having a demand for passive solar designs and products is having an established building community capability to meet those demands. Technology transfer is the means to develop within the building community a capability to design, build, finance, and market passive solar systems. The commercialization strategy for passive systems includes the establishment of a technology transfer system composed of three activities: data management, education and training, and information dissemination.

The purpose of data management will be the development and maintenance of a data and information base on passive systems. It will consolidate present data and information on passive systems (e.g., performance, market potential, economic viability, design tools, etc.) and be updated as information and data from tasks called for

in this Plan become available. It is essentially a resource for supporting other commercialization activities.

A primary use of this resource will be the preparation of training materials and programs for regionally and state implemented workshops and seminars. Initially, education and training activities will be directed toward architects, engineers, and builders as key elements in the passive technology delivery system. Subsequent education activities will focus on planners, lenders, government officials, and realtors.

The purpose of the third activity of the technology transfer system will be the dissemination of information to various user groups influential in commercializing passive solar systems. This activity will include determining user requirements, evaluating information appropriateness, converting the information to a useful form, disseminating the material through established user communication channels, and monitoring and evaluating the effectiveness of the program.

Stimulation of Technology Delivery Capability

The decision to use a passive system is based upon many factors, such as client desires, designer awareness and understanding, regulatory acceptance, and lender approval. Removing some of the uncertainties during this decision-making process may greatly stimulate the application of passive techniques. Several areas where this may be appropriate are solar access, building codes and standards, and performance criteria. Additionally, incentives may be proposed to encourage a positive decision regarding the application of a passive system.

Stimulation of Market Demand

A market demand is essential to the commercialization of a technology. The demand can be real or perceived, and is depressed by a

lack of awareness, knowledge, and decision-making data, as well as by risks (real or imagined) related to new design concepts, systems, or practices. Therefore, stimulation of market demand is generally necessary to overcome initial prejudices or traditional attitudes. Strategies for stimulating market demand include consumer education, utility programs, government building programs, design competitions, and financial incentives.

Emphasis of Technology Utilization

The lack of design tools and marketable passive building designs has been identified as an important obstacle. However, the completion of these two development activities is not an essential prerequisite to starting the commercialization efforts. The first generation of passive solar heating design tools has almost been completed and initial steps have been taken in the process of generating marketable designs. The first phase of commercialization can be initiated immediately and carried out in parallel with marketable design development. Emphasis will be on detailed market research to carefully identify areas of opportunity and to focus commercialization activities.

The cornerstone of phase two, and indeed of the entire commercialization effort, is education and information dissemination. A key element in the commercialization of passive systems is the ability of the building community to effectively integrate passive solar approaches into their normal design and construction processes.

The goals of commercialization will be met when passive solar design is accepted as "standard practice" by both design professionals and building trades; in other words, when common materials and passive solar products are used in such a way as to maximize the benefits of the environmental resource with minimal dependence on mechanical equipment and conventional fuels. Education of the key

participants in the building industry (designers, builders, developers, planners, lenders, regulatory officials, etc.) and expansion of existing professional design and trade organization education and information programs will greatly stimulate near-term use of passive concepts.

An important parallel activity is consumer education. Involvement of the consumer at all stages of the commercialization process is important to the testing and refinement of ideas. The role of the consumer in molding the ultimate outcome of the process is just as critical in the early stages as it is later on, and failure to achieve an appropriate level of early involvement can lead to critical mistakes. Furthermore, a demand in the marketplace is a crucial stimulant to rapid development in the delivery sector. Since the building industry has little difficulty selling its present product, it appears that little or no commitment will be made until a consumer demand is perceived.

A secondary, but still very significant, emphasis will be on the use of incentives to stimulate both the supply and demand sectors-- e.g., tax credits and small business loans for builders and accelerated depreciation and income tax credits for commercial and private consumers. Also of significance in stimulating both the delivery and demand sectors will be various government-sponsored building programs involving public buildings and design-build competitions.

SECTION J: PROCESS DESCRIPTION

The process of achieving widespread utilization (commercialization) can be divided into the following elements:

- commercialization readiness assessment;
- technology transfer;
- stimulation of technology delivery capability;
- stimulation of market demand.

These elements represent a continuum and often overlap one another. Each is also connected in various ways to the technology development process. For example, one portion of the commercialization readiness assessment is a thorough technical evaluation, considering operational status, capital and operating expenses, technical barriers, etc., to determine the readiness of the technology to enter the marketplace. Many times, results from this evaluation identify further development activity that must occur before accelerated commercialization takes place.

A primary function of the commercialization process is the identification of industry and consumer needs so that technology development and utilization activities can be selected, modified, or re-directed to meet those needs. In this respect, all commercialization activities are designed to address or involve the various groups that represent or influence the technology delivery system. These groups include legislators, regulatory officials, lenders, lawyers, architects, engineers, builders/developers, manufacturers, suppliers, installers, craftsmen, and consumers. Each group has specific informational, educational, and motivational requirements that must be considered if one hopes to stimulate the commercialization process. Therefore, to best determine what these requirements are for each group, it is crucial that they be involved in the commercialization planning process. As tasks are initiated, evaluation by these same groups is needed to determine the effect of the activities toward

achieving the commercialization objective.

A more detailed description of the utilization elements is presented below.

Commercialization Readiness Assessment

As a first step in the utilization process, it is necessary to assess the readiness of a technology to enter the marketplace and to be successfully applied. This would include an assessment of a technology in terms of (1) technical readiness (operational status, capital and operating expenses, current developments underway, and technical barriers); (2) market/economic readiness (market description, economic analysis, market penetration, and market barriers); (3) environmental readiness (environmental compliance and environmental barriers); and (4) institutional readiness (institutional barriers and manufacturer status). This is generally followed by a benefits analysis which assesses (in the case of energy technologies) energy impacts, recipients of benefits, and cost impacts.

The commercialization readiness assessment provides a comprehensive look at a technology and serves as a basis for deciding whether further commercialization planning is warranted. Those technologies deemed "ready" for commercialization--i.e., those with no major technical, cost, or institutional barriers--proceed to primarily market research studies and commercialization strategy development. Both of these planning tasks are designed to focus commercialization efforts and give priority to certain systems, applications, geographic locations, and user groups.

Technology Transfer

A second step in the utilization process involves intervening in the marketplace with those groups who, directly or indirectly, influence the use of a technology. The primary intent is to familiarize them with the technology--its development status, its technical

and economic potential, its marketability, and its application requirements. Technology transfer generally involves data management, education and training, and information dissemination. It is concerned with communication, the purposeful transfer of information to change an individual's behavior. This requires the appropriate selection of communication channels, as well as information content and format.

Technology transfer activities must have well-defined methods and channels of feedback. The influence or effect of an activity must be quickly determined so that corrective actions can be taken when necessary. Technology transfer activities can also play a significant role in identifying new needs or requirements that may be addressed by new or modified tasks either in the development or utilization areas.

Stimulation of Technology Delivery Capability

A knowledgeable delivery sector may not by itself accelerate the commercialization of a technology. It may be necessary to modify certain industry ground rules or to provide additional protection or assurances to motivate the user community to adopt a technology. This element of the utilization process is responsible for characterizing the technology delivery system and identifying key points in this system where stimulation may be effective in accelerating the use of a technology. The types of activities that may be appropriate to stimulate application of passive systems include: assuring solar access through zoning or deed modifications; modifying building codes to allow innovative passive design approaches; developing standards for passive solar materials and components; and legislating incentives to support small business development.

Stimulation of Market Demand

Perhaps the most important element of the commercialization process is the creation or enhancement of market demand for the

technology. The success of the commercialization process is measured by market demand for the technology and the ability of the industry to meet this demand. Market demand can be stimulated in many ways. For passive systems this includes consumer education; utility programs; solar energy in public buildings programs; national, regional, and state design/build competitions, and financial incentives. The difficult task is the selection of those actions which will most effectively stimulate a rapid and enduring market response.

The technology development and utilization processes must be regularly assessed in terms of effectiveness in achieving program goals. To do this, acceptable evaluation criteria and measurement techniques are needed. Just as important, comments and recommendations from the user community and the public are necessary to evaluate the program and to initiate new tasks or modifications to existing tasks.

As with any government sponsored program, determining when government involvement is and is not appropriate requires careful consideration. Government action can stifle the development and utilization of a technology or it can provide effective support and direction. Timing can be the most critical element of government involvement. As part of the program analysis activity, the role of the government will be carefully assessed.

SECTION K:
TASK CLASSIFICATIONS

This section describes the areas by which the tasks are organized. The technology utilization tasks themselves are contained in Appendix C with schedules for some of these tasks presented in Appendix D.

Table III-2 provides an overall picture of the task classification scheme. Because the general nature of the activities that occur in each of these areas has been given in the preceding section, no further description of these activities is provided here.

TABLE III-1
Technology Utilization Task Classifications

I. COMMERCIALIZATION READINESS ASSESSMENT	<ul style="list-style-type: none"> A. Technical readiness B. Market/economic readiness C. Environmental readiness D. Institutional readiness E. Benefits analysis F. Commercialization planning
II. TECHNOLOGY TRANSFER	<ul style="list-style-type: none"> A. Data management B. Education and training C. Information dissemination
III. STIMULATION OF TECHNOLOGY DELIVERY CAPABILITY	<ul style="list-style-type: none"> A. Solar access B. Building codes and standards C. Performance criteria D. Incentives
IV. STIMULATION OF MARKET DEMAND	<ul style="list-style-type: none"> A. Consumer education B. Utility programs C. Solar energy in federal facilities D. Solar energy in state/local bldgs. E. National, regional, and state design/build competitions F. Policy studies G. Incentives

PART IV:

APPENDICES

- APPENDIX A: TECHNOLOGY DEVELOPMENT TASKS
- APPENDIX B: SYSTEMS DEVELOPMENT SCHEDULES
- APPENDIX C: TECHNOLOGY UTILIZATION TASKS
- APPENDIX D: TECHNOLOGY UTILIZATION SCHEDULES

APPENDIX A:
TECHNOLOGY DEVELOPMENT TASKS

The following classification scheme is used to organize the technology development tasks:

<p>I. BASIC PHYSICAL STUDIES</p>	<p>A. Solar Radiation B. Sky Properties C. Atmospheric Effects D. Ground Properties E. Terrain F. Heat Exchange Mechanisms</p>
<p>II. PRODUCT DEVELOPMENT TASKS (MATERIALS AND ASSEMBLIES)</p>	<p>A. Glazing Mat'ls & Assemblies B. Absorber & Emitter Mat'ls & Assemblies C. Reflector Mat'ls & Assemblies D. Insulation Mat'ls & Assemblies E. Storage Mat'ls & Assemblies F. Combination Assemblies G. Fluids & Sealants H. Sensors, Actuators, & Controls I. Fans, Pumps, Valves, etc. J. Heat Exchangers K. Heat Pipes & Thermal Diodes</p>
<p>III. SYSTEM DEVELOPMENT TASKS</p>	<p>A. Concept Generation & Assessment B. System Specification (Architectural & Engineering Definition) C. System Analysis (Thermal Modeling, Economic Analysis, etc.) D. Data & Instrumentation Requirements E. Performance Data Acquisition (Test Rooms & Instrumented Buildings) F. System Studies (Parametric Sensitivity, Climactic Applicability, etc.) G. Design Tools (Handbooks, Computer Codes, etc.) H. Performance Criteria I. Market Field Tests</p>

Listed below are specific tasks which have been identified to be significant to the development of passive solar technology. The tasks have been further classified as applying to passive solar heating (H), passive solar cooling (C), or both (H,C). Where

possible, the tasks are specific; in many areas where passive technology is not well developed, general tasks have been defined.

Many of the tasks are important to two or more of the passive systems which have been recommended for development; for this reason, individual tasks are not cross-referenced to systems and definitive time schedules have not been provided. The general time frame for system development provided in Appendix B indicates only those tasks from the list which are of crucial significance to the systems with which they are associated.

I. BASIC PHYSICAL STUDIES TASKS

A. Solar Radiation

I.A.1 (H)

Increase the number of sites where solar radiation on a south-facing vertical surface is recorded. Use this data to refine existing methods of estimating vertical surface solar radiation from measured horizontal solar data.

I.A.2 (H)

Devise a technique for separating sky radiation from ground-plane reflected radiation. Develop a system for describing and characterizing the local terrain at these sites. Make this information available through the existing data network and other appropriate mechanisms.

I.A.3 (H,C)

Define solar design years appropriate to passive heating and cooling systems. Of special significance is the beam to diffuse radiation ratio, its hourly variation, and the parameterization in terms of local observables. The effect of local solar persistence should be included.

I.A.4 (C)

Investigate methods of parametric expression of daylighting effectiveness in terms of beam and diffuse radiation.

I.A.5 (H,C)

Assess the impact of sky-light polarization on daylighting effectiveness.

I.A.6 (H,C)

Assess the adequacy of existing sky-light polarization data in terms of daylighting. Extend measurements as necessary.

B. Sky Properties

I.B.1 (C)

Develop, test, and deploy infrared sky radiometers for measuring the spectral atmospheric emission parameters in various parts of the country. These measurements will be utilized to assess the potential effectiveness of emitting surfaces for radiative cooling systems.

I.B.2 (C)

Parameterize the infrared emission characteristics of the sky in terms of common observables and interpret the parameterizations in terms of effective sky temperature.

I.B.3 (C)

Define a radiative cooling design day which separates the visible and infrared portions of the spectrum for both daytime and nighttime periods.

C. Atmospheric Effects

I.C.1 (H)

Study energy-loss effects of wind-stripping of still air layer at the surfaces of buildings. The study should consider a variety of materials, surface textures, and building configurations, with special emphasis on glazings.

I.C.2 (H,C)

Investigate methods of parametric reduction of weather data for use in passive heating and cooling system analysis and design.

I.C.3 (H,C)

Study effects of wind and temperature on infiltration in standard building constructions.

I.C.4 (C)

Develop algorithms for wind-augmented evaporation cooling.

I.C.5 (C)

Assess microclimate effects of evaporative cooling in high population density applications.

I.C.6 (C)

Define and develop a design night relevant to ventilation cooling systems. The design conditions should include windspeed, dry bulb temperature, and dewpoint.

D. Ground Properties

I.D.1 (C)

Perform a state-of-the-art investigation of ground temperatures and ground conductivities. Private and government sources (including military) should be surveyed.

I.D.2 (C)

Extend the Department of Agriculture ground temperature measurements to greater depths and a greater climactic range.

I.D.3 (C)

Carry out studies of ground conductivity and temperature for various soil types and conditions as affected by ground water. Develop a method of characterizing the thermal conductivity and heat capacity in terms of local measurements.

I.D.4 (C)

Define a design year for soil thermal properties for a variety of climactic regions.

E. Terrain

I.E.1 (H,C)

Initiate studies to assess the potential of passive heating and cooling systems in terms of available sites. Attention should be given to shadowing, local wind patterns, and reflectivity of the terrain. Both natural terrain and the built environment should be considered in new and retrofit applications.

I.E.2 (C)

Assess and characterize the effect of local terrain features on wind-driven ventilation cooling.

F. Heat Exchange Mechanisms

I.F.1 (H)

Perform in-depth theoretical and experimental studies of air flow in storage walls with vents. Consider spacing between glazing and storage, collection surface texture, storage configuration, and inlet and outlet configuration. Generate heat transfer coefficients from fundamental principles.

I.F.2 (H,C)

Investigate the infiltration aspects of simple doors and doors with airlocks.

I.F.3 (H,C)

Investigate temperature-driven and pressure-driven convective heat transfer in bulk fluids within a space and through openings in walls. The purpose will be to develop algorithms for integration into existing computer codes to describe thermal operation of passive systems. Validate with experimental data.

I.F.4 (H,C)

Generate convective heat transfer coefficients appropriate to various passive configurations starting with fundamental principles. Validate utilizing experimental data.

I.F.5 (H,C)

Investigate heat transfer coefficients at the interface between air and a solid surface. Parameterize the coefficients as functions of the measurable boundary conditions.

I.F.6 (H,C)

Investigate the effects of flow passage size and system layout on the performance of low velocity, natural convection solar heating and cooling systems which utilize rock bed thermal storage. Analyze the stability of the flow through the rock bed and the effects of turns, duct sizes, and obstructions on the air flow characteristics of the system.

I.F.7 (H,C)

Investigate horizontal and vertical heat transfer (both convective and conductive) in water as functions of container configuration and the location of the aperture through which energy is delivered to the water.

I.F.8 (C)

Generate and investigate windscreen configurations which enhance wind-augmented evaporation cooling.

I.F.9 (C)

Investigate air flow patterns in actual building situations. Correlate observed patterns with natural ventilation through openings in the building envelope.

II. PRODUCT DEVELOPMENT TASKS

A. Glazing Materials and Assemblies

II.A.1 (H)

Develop infrared reflection coatings. Emphasize increasing the solar spectrum transmittance of the coating while retaining the reflection characteristics. Study the effect of IR reflection and solar transmission on collection performance for both flat black absorber and selective absorber surfaces.

II.A.2 (H)

Determine the effect of glass surface conditions on collector performance. Include an evaluation of traditional glass surface figuring and etching.

II.A.3 (H)

Continue development of surface etching processes for reducing reflectivity on both glass and plastics. Determine the types of glass or plastic most appropriate for this treatment, their potential for mechanical surface failure, the effect on them of dirt and repeated washing, and their cost-effectiveness.

II.A.4 (H,C)

Investigate/develop "optical shutter" glazings in the following categories:

- Electric-field actuated, variable-plasma-edge semiconductor films.
- Electric-field actuated, variable-color-center-density films.
- Thermally actuated reflective films.

II.A.5 (H,C)

Develop durable coatings for plastic glazings. Compare the cost of applying a coating of polymeric plastic on PVC film to the cost of building the stabilizer into the polymeric material.

II.A.6 (H,C)

Collect and publish existing designer-oriented information on glazing materials, components, and assemblies appropriate to passive heating and cooling systems. Extend information base as necessary to cover the full spectrum of relevant topics related to in-use transmission, heat loss, infiltration, etc.

II.A.7 (H,C)

Test, as required, available glazings individually and in combination. Investigate the reflectivity, absorptivity, transmissivity, and diffusion effects as a function of angle of incidence and material age. Document hourly and daily transmitted solar radiation through various combinations of glazings as a function of:

- angle of glazing;
- sun angle and intensity.

Experimental data are desirable because of the poorly understood effects that diffusion in the first layer can have on the transmission of subsequent layers. Non-optical data should also be acquired; flammability, outgassing, and aging effects are of special importance.

II.A.8 (H,C)

Investigate means for applying both IR reflective and anti-reflective coatings uniformly in large volume production. Consider coatings for glass and plastics, and study the cost implications of the production process.

II.A.9 (H,C)

Generate and evaluate concepts for movable glazing for south-aperture and roof aperture systems.

II.A.10 (C)

Survey existing IR-transparent materials to identify promising candidates for use with sky-cooling radiators.

II.A.11 (C)

Develop IR-transparent materials for use with sky-cooling radiators.

II.A.12 (C)

Generate and test concepts for glazing assemblies which incorporate mechanical reflective shutters for daylighting control.

B. Absorber and Emitter Materials and Assemblies

II.B.1 (H)

Institute a survey of existing selectively absorbing coatings and assess potential for application to masonry storage units, containers for water and PCM storage, and other building materials. Durability and safety issues will be addressed.

II.B.2 (H)

Investigate additives for water which can be used to "fine tune" the absorptivity of water in clear storage tubes. Emphasis should be placed on high absorptivity in the UV and IR.

II.B.3 (H)

Devise variable absorbers for use in clear, water storage containers.

II.B.4 (H,C)

Collect and publish existing designer-oriented information on absorber coatings and emitter coatings appropriate to passive solar applications. Durability and safety considerations will be included in this documentation.

II.B.5 (H,C)

Collect and publish existing designer-oriented information on collectors and radiators which might be appropriate to passive solar applications. Information on installation and applying experience, durability, safety, performance, etc. will be included.

II.B.6 (C)

Institute a survey of existing selective emitters and assess feasibility for applications to passive solar cooling.

II.B.7 (C)

Identify desired properties of selective emitters for use in radiative sky-cooling applications.

II.B.8 (C)

Develop selective emitters with properties appropriate for use in radiative sky-cooling applications.

II.B.9 (C)

Undertake a comprehensive program to measure the infrared optical properties of candidate materials for radiative cooling systems. Materials with appropriate absorptance/emittance characteristics will be used in fabrication of radiative cooling panel/windscreen systems. These prototype configurations will be tested and evaluated in test bed measurements.

II.B.10 (C)

Perform a state-of-the-art investigation of surface coatings and finishes which control solar loading on the building envelope and/or have selective spectral properties. Military and aerospace technologies will be included as prospective sources for data, materials properties, measurement facilities, and other pertinent information.

II.B.11 (C)

Generate and investigate windscreen schemes for minimizing atmospheric heating of sky-cooling radiators.

C. Reflector Materials and Assemblies

II.C.1 (H)

Collect and publish existing designer-oriented information on reflector materials and assemblies which might be appropriate to passive solar applications. Durability and performance will be emphasized.

II.C.2 (H)

Generate and test schemes for ground reflectors for south-aperture systems.

II.C.3 (H)

Generate and test schemes for combination reflector and movable insulation assemblies for a broad range of passive systems.

D. Insulation Materials and Assemblies

II.D.1 (H,C)

Collect and publish existing designer-oriented information on shades, shutters, and moving insulation which have been successfully applied to, or show promise for, passive heating and/or cooling systems.

II.D.2 (H,C)

Generate and test schemes for moving insulation for south, roof, and shaded-roof apertures. Emphasize potential for integration with glazing, reflector, and storage assemblies.

II.D.3 (H,C)

Develop low-cost insulative sheathings for application to the outside of masonry and other high-mass structures. Emphasis should be placed on ease of application, resistance to weather and fire, and minimizing material and application costs.

E. Storage Materials and Assemblies

II.E.1 (H)

Develop and test a variety of clear containers suitable for placing in direct sunlight. Schemes should be generated both for south-aperture and roof-aperture applications.

II.E.2 (H)

Generate and test concepts for innovative high-heat capacity, high-absorptivity furnishings suitable to direct heating systems (e.g., water furniture). Select promising examples for testing and use in direct heating systems. Special attention will be paid to durability of the storage assemblies.

II.E.3 (H)

Generate and test concepts for water storage floors suitable for direct heating systems.

II.E.4 (H)

Investigate methods for combating aqueous corrosion of the various materials used for water tanks and heat exchangers. Include chemical additives and electrolytic processes. Consideration will be given to toxicity and to relevant potability requirements.

II.E.5 (H)

Identify and test non-corrodible liners for water storage tanks. These liners might be made of plastic, fiberglass, or other materials.

II.E.6 (H)

Investigate the use of unconventional materials such as concrete composites for water-storage tanks.

II.E.7 (H,C)

Compile data, in user-oriented form, pertaining to existing storage assemblies suitable for passive solar applications. Information should include conductivity, specific heat, latent heat, cost (on regional basis), durability, reliability, modular dimensions, etc.

II.E.8 (H,C)

Generate and test concepts for masonry and concrete structural elements with additives to yield high heat capacity and conductivity.

II.E.9 (H,C)

Develop inexpensive techniques of encapsulating phase-change materials. Emphasis should be placed on energy exchange and durability.

II.E.10 (H,C)

Develop phase-change material storage assemblies appropriate to passive heating and cooling applications.

II.E.11 (H,C)

Investigate thermal losses from underground storage assemblies. Include effects of conductive heat transfer in soils and mass transfer due to groundwater movement.

F. Combination Assemblies

II.F.1 (H,C)

Develop schemes for combining glazing, absorbers or emitters, storage, reflectors, and insulation into assemblies which are economically advantageous and/or provide performance benefits over the non-integrated alternatives. Also consider the addition of necessary heat exchangers, hybrid components such as fans and pumps, and central systems.

G. Fluids and Sealants

II.G.1 (H,C)

Investigate heat transfer fluids that expand on cooling to provide the possibility of a reverse thermosyphon.

II.G.2 (H,C)

Collect and publish existing designer-oriented information on sealants, appropriate to passive solar applications.

II.G.3 (H,C)

Develop sealants for use around dampers, movable insulation, and movable glazing.

II.G.4 (H,C)

Survey and characterize existing sealants for use in reducing infiltration through glazing assemblies. Investigate silicones, ethylene terpolymerhydroxide (rubber) adhesive, polyvinyl butyral, EPDM, organic tars, etc. Study outgassing temperature stability, UV degradation, strength characteristics, cost of materials and installation, durability, toxicity, etc.

H. Sensors, Actuators, and Controls

II.H.1 (H,C)

Develop and test sensors and controls which respond to the mean radiant temperature of the conditioned space.

II.H.2 (H,C)

Develop and test controls and actuators for movable insulation schemes.

I. Fans, Pumps, Valves, etc.

II.I.1 (H,C)

Develop and test fans and pumps specifically sized and designed for application to passive and/or hybrid systems.

II.I.2 (H,C)

Design and test damper and control assemblies suitable for use with thermocirculation systems in Trombe walls and other natural convection systems.

J. Heat Exchange

II.J.1 (H,C)

Survey existing heat exchangers and assess applicability to passive systems (e.g., for solar ponds, ground cooling, etc.).

II.J.2 (H,C)

Generate concepts for heat exchangers designed to use the ground as a source or sink for heat. Select promising schemes for development and testing.

II.J.3 (H,C)

Investigate heat exchange processes in salt-gradient-stabled ponds. Develop heat exchanger designs appropriate to that application.

K. Heat Pipes and Thermal Diodes

II.K.1 (H,C)

Assess the state of the art of the heat pipe and thermal diode technologies. Consider the appropriateness of the operational characteristics and performance of currently available components and systems.

II.K.2 (H,C)

Study applications of inexpensive heat pipes to passive buildings.

II.K.3 (H,C)

Investigate use of heat pipes for transporting energy between collection and storage and between storage and space.

II.K.4 (H,C)

Generate and test concepts for heat pipe connections of environment to storage and storage to space.

II.K.5 (H)

Generate and test concepts for using heat pipes in passive solar hot water systems.

III. SYSTEMS DEVELOPMENT TASKS

A. Concept Generation and Assessment

III.A.1 (H)

Investigate the possibilities for passive wall heating by thermosyphon from flat plate liquid collectors.

III.A.2 (H)

Generate and assess concepts for using east wall (with moving insulation) for early-morning direct-gain heating.

III.A.3 (H)

Generate and assess concepts for space heating using remote collection with storage floor.

III.A.4 (H)

Develop structural schemes for shaded-roof aperture systems, integrating insulation, reflectors, storage, structure, etc. The goal is to provide a standard roofing system which can be purchased and easily erected as a substitute for standard, flat, built-up roofs. Emphasis should be on:

- details of manufacture and deployment;
- ease of maintenance and operation;
- safety and durability.

A full range of systems will be investigated, including:

- direct heating;
- indirect heating with roof storage;
- isolated heating with roof storage;
- combinations including clear water storage (direct and indirect).

Both factory and site-built systems will be designed; design parameters will include thermal performance and daylighting.

III.A.5 (H)

Generate and assess passive solar mobile home concepts. Emphasis should be placed on direct gain systems with water floor storage, using south-aperture for single widths and shaded roof aperture for the north section in double-wide mobile homes. The generation of other innovative mobile home schemes should be encouraged.

III.A.6 (H,C)

Generate and assess schemes for mobile home passive solar retrofit. Emphasis should be placed on add-ons for south walls, including habitable spaces with south or south-sloping apertures. The generation of other innovative schemes should be encouraged.

III.A.7 (H,C)

Generate and assess concepts for urban-scale solar applications.

III.A.8 (H,C)

Generate concepts for integrating photovoltaics with passive solar heating and cooling systems.

III.A.9 (H,C)

Investigate the relative merits of plants, ozone generators, and heat exchangers (between outgoing and incoming air) as sources of oxygen for occupied buildings. Compare on the basis of performance (oxygen level, ion level, impurity content) and cost (back-up energy required).

III.A.10 (H,C)

Generate and assess schemes for transferring heat between zones in single and multiple depth N-S zone configurations.

III.A.11 (H,C)

Generate schemes for passive preheating and pre-cooling of ventilation air.

III.A.12 (H)

Assess the energy implications of retrofit use of convection driven, window-mounted air heaters.

III.A.13 (C)

Generate and assess schemes for using fans to augment evaporative cooling in shaded storage roof systems.

III.A.14 (C)

Generate and test conceptual and engineering designs for radiative cooling systems if feasibility is established in test bed applications.

III.A.15 (C)

Generate schemes for roof storage systems which are modularly expandable in two directions and which are suitable for commercial applications (e.g., warehouses, workrooms, etc.). Low-powered hybrid configurations may be appropriate.

III.A.16 (C)

Generate and assess configurations for utilizing stack effect for cooling purposes in high-rise buildings and assess thermal potential. Functional space utilization impacts of the systems will be considered as a function of building type and geometry.

III.A.17 (C)

Generate and assess schemes for using nocturnal outside air for cooling the building envelope or a storage mass. The cooled components would be used for cooling the space during daylight hours.

III.A.18 (C)

Investigate the potential in hot climates for using conduction to the ground for direct cooling.

III.A.19 (C)

Assess the environmental implications of widespread use of evaporative cooling and compare to the effects resulting from utilization of competing technologies.

III.A.20 (C)

Assess the energy implications of shaded and unshaded skylights (with and without both moving insulation and reflectors) which are used both for heating and illumination.

B. System Specification

III.B.1 (H)

Develop specifications for passive and hybrid convective pre-heaters for ventilation air. System specifications should include integration of the passive/hybrid components with the conventional HVAC equipment.

III.B.2 (H)

Engineer movable insulation systems for glazing assemblies and storage systems exposed to the occupied space.

III.B.3 (H,C)

Select several promising functional applications for passive or hybrid solar heating and cooling office buildings, motels, etc. Select and specify configurations which are appropriate to these applications and which respect basic passive solar heating and/or cooling design principles (e.g., double-loaded corridor office spaces with corridor running east-west). Energy management issues will be included as appropriate in the specifications.

III.B.4 (H,C)

Develop specifications for combining stack effect/natural convective systems with outside air ventilation and with isolated thermal storage systems. Integration with the conventional HVAC equipment will also be considered.

III.B.5 (C)

Develop specifications for improved evaporative cooling systems of special significance and ease of maintenance, operational efficiency, and low cost.

III.B.6 (C)

Define the engineering specifications for a variety of roof storage cooling systems and associated movable insulation schemes.

III.B.7 (C)

Perform engineering specification of radiative cooling systems.

C. System Analysis

III.C.1 (H)

Develop algorithms which characterize solar absorption in clear water containers with and without absorbing additives.

III.C.2 (H)

Investigate two-dimensional heat flow characteristics in vented storage walls, direct-gain storage systems, and in slab-on-grade construction. If necessary, develop descriptive algorithms for those heat transfer situations.

III.C.3 (H,C)

Continue development of network analysis computer codes to account for the following range of passive solar heating system characteristics:

- direct, indirect, isolated, and combinations;
- south, roof, and shaded roof apertures;
- water (clear and opaque), masonry, and PCM storage;

III.C.4 (H,C)

Modify existing public domain building energy analysis programs to provide simulation capabilities which include passive heating and cooling systems and which focus on commercial building types. In addition to developing models which describe the passive collection and storage elements and the associated inter- and intra-zone energy distribution systems, extension and/or improvements will be made to existing heat transfer algorithms which limit the programs to conventional building types. The resulting code will be validated, documented, and made available to the design and engineering communities.

III.C.5 (H,C)

Investigate applicability of passive heating and cooling techniques to high occupancy situations.

III.C.6 (H,C)

Identify the uncommon features of passive systems which affect occupant comfort; quantify and assess the need for control systems which respond to these comfort-influencing parameters.

III.C.7 (H,C)

Carry out studies, using detailed hour-by-hour computer codes, to compare the practicality of various active and passive systems as a function of degree of control over the thermal environment in the functional space.

III.C.8 (H,C)

Perform a state-of-the-art investigation of closed-cycle environments (e.g., submarines, spaceships, etc.) to identify techniques for generating oxygen and purifying air. Human comfort studies and performance criteria related to these systems should also be identified.

III.C.9 (H,C)

Determine the characteristics, requirements, and costs of conventional cooling systems when they are coupled to passive heating and cooling systems to provide heating and cooling in various climates.

III.C.10 (H,C)

Use appropriate thermal balance and/or response-factor energy analysis programs to predict temperatures in the vicinities of the north and south walls and the ceiling and floor in multizone configurations as a function of:

- number of N-S divisions;
- number of E-W divisions;
- number of floors;
- north-south extent of space;
- east-west extent of space;
- ceiling height;
- nature of wall(s) which separate N-S spaces;
- nature of south-aperture collection (direct, indirect, insulated);
- COP for energy distribution (infinity for totally passive distribution, finite if fans used);
- climate.

Validate with test data wherever possible.

III.C.11 (H,C)

Perform a systematic examination of the health, safety, and comfort issues which arise in buildings characterized by low infiltration and ventilation rates. The influence of the building materials, auxiliary HVAC system, and functional utilization of both residential and commercial structures should be identified.

III.C.12 (H,C)

Integrate phase-change material storage into hourly computer analysis programs. Utilize the code to optimize the phase-change temperature and heat transfer criteria for phase-change storage systems.

III.C.13 (H,C)

Develop computer codes to simulate ground effects on system performance. Consider the following range of buildings:

- mounted on stilts;
- with crawlspace;
- with basement;
- slab on grade;
- slab on grade with N Berm;
- slab on grade with N, E, and W Berms;
- slab on grade with N, E, W Berms and roof direct;
- buried to roof-line;
- buried completely.

Use computer codes to assess relative merits of the various configurations in both heating and cooling situations.

III.C.14 (H,C)

Assess the suitability of the techniques used in existing public domain building energy analysis computer programs for passive systems simulation. Both residential-oriented thermal balance programs and multi-zone codes which emphasize commercial building types will be examined. Particular attention will be paid to identifying the limitations of current techniques for analysis of (1) thermally massive building elements and (2) radiative and convective heat transfers within the functional space.

III.C.15 (H,C)

Perform a systematic study of the solar add-on costs associated with the various passive system configurations. Surveys will be made of the incremental costs incurred in existing passive buildings and detailed estimates of costs expected for other configurations will be obtained. These data should reflect differences in regional construction costs as well as alternative construction methods.

III.C.16 (H,C)

Identify special control logic and control actuator requirements suitable for passive solar energy systems.

III.C.17 (H,C)

Investigate the potential of "smart controller" (e.g., micro-processors) for the operation of passive solar systems. Identify sensors and data inputs (e.g., weather predictions) which would be meaningful in establishing control strategies.

III.C.18 (H,C)

Perform systems studies to establish the energy implications of building proportions--i.e., relative magnitude of north-south, east-west and vertical extent.

III.C.19 (H,C)

Investigate and tabulate the add-on cost characteristics of the various passive solar energy systems by reviewing existing passive solar energy system installations and costs, using standard cost-estimating procedures for buildings.

III.C.20 (H,C)

Identify parameters which characterize the thermal performance of large mass (e.g., masonry) constructions and passive system configurations. These parameters should be part of simplified methods for predicting the thermal performance of buildings which utilize passive system configurations.

III.C.21 (C)

Investigate the potentials of dehumidifiers, heat pumps, and solar desiccant dryers for extending the climactic range and occupancy level of passive cooling by handling part of the latent load.

III.C.22 (C)

Determine the characteristics, requirements, and costs of conventional cooling systems when they are coupled to passive heating and cooling systems to provide heating and cooling in various climates.

III.C.23 (C)

Incorporate measured atmospheric infrared emission parameters into a load-calculating computer program.

III.C.24 (C)

Investigate evaporative and/or nocturnal outside air cooling in conjunction with rock bed or other storage system.

D. Data and Instrumentation Requirements

III.D.1 (H,C)

Based on the systems analysis tasks, identify a broad range of factors and/or parameters which characterize the thermal performance of the full scope of passive solar heating and cooling systems. The parameters should allow comparative evaluation between different systems and absolute evaluation of a particular system.

III.D.2 (H,C)

An identification should be made of the most crucial performance factors which would be appropriate to a very broad-based program to gather statistically significant data from many passive solar heating and cooling demonstration projects.

III.D.3 (H,C)

Define the thermal parameters which must be measured to evaluate system performance and which will provide for engineering proof-of-concept; measurement frequency and accuracy must also be determined.

III.D.4 (H,C)

Define a standardized method for reporting passive solar heating and cooling system performance. In addition to including meaningful and measurable system performance parameters and variables, data on mechanical design, livability, operating characteristics, and maintenance requirements must be documented.

III.D.5 (H,C)

Select an instrumentation package appropriate to basic performance measurement and in-depth experimental studies of passive solar systems.

III.D.6 (H,C)

Set standards for sub-metering on solar energy projects to ensure adequate measurement of the use of auxiliary units.

III.D.7 (H,C)

A multi-level instrumentation package (i.e., a basic package with options) should be identified and developed for use in a broad-based, extensive passive solar systems monitoring program. The basic package should provide for a minimum set of measurements to include:

- comfort achieved;
- weather conditions;
- auxiliary energy used.

The options should allow expansion of the system to approximately 40 or more channels to allow for detailed performance evaluations and for computer code validations.

III.D.8 (H,C)

Investigate methods of compressing systems data by pre-processing. This will reduce the quantity of data which must be stored and provide a condensed output that will be more easily understood.

E. Performance Data Acquisition

III.E.1 (H,C)

Continue and expand as appropriate existing small-scale passive heating and cooling system testing efforts.

III.E.2 (H,C)

Expand present test cell program as necessary to validate analytic models.

III.E.3 (H,C)

Design a systems testing program employing side-by-side, controlled, full-scale test cell experiments involving a range of passive solar systems to be located at several sites representing distinct climactic conditions. Emphasis should be on rigorous system-to-system and climate-to-climate comparisons, while keeping costs down and allowing for a broad range of experiments by devising test cells with highly interchangeable parts. Over the full range of sites the potential should exist for experiments involving:

- direct, indirect, isolated, and combination heating through south apertures (with or without sunspace add-on), roof apertures, and shaded roof apertures;
- direct, indirect, and isolated cooling to sky, atmosphere, and ground;
- water, masonry, and PCM storage;
- conventional construction.

Consideration should be given to appropriate control strategies, simulation of occupancy, and the use of the data to validate all significant passive solar computer codes. A scheme for assessing the results in terms of comfort and back-up energy should be devised.

III.E.4 (H,C)

Assess the merits of side-by-side systems testing program. If judgement of side-by-side systems testing program is favorable, select institutions for test sites. Emphasis should be on universities with strong technical programs and design-profession education programs.

III.E.5 (H,C)

Undertake expansion and/or continuation of preliminary full-scale testing of passive systems as appropriate.

F. System Studies

III.F.1 (H)

Investigate the impact of body heat and other internal heat sources on heating requirements in well-insulated, low-infiltration buildings.

III.F.2 (H)

Investigate the effect of distribution of thermal mass in direct-gain systems. Identify the importance of location, color, coverings, etc. on the effectiveness of thermal storage in direct-gain systems.

III.F.3 (H,C)

Sensitivity studies will be undertaken to quantify the effects in building performance of (1) passive system design parameters; (2) building design, use, and operation parameters; and (3) auxiliary heating/cooling system controls and control strategies. These studies will be utilized in assessing the applicability of passive design concepts to various combinations of building design and end uses.

III.F.4 (H,C)

Assess the trade-offs between illumination and summer load for various direct-gain apertures.

III.F.5 (H,C)

Institute study of north-windows trade-off between summer ventilation and winter heat losses. Establish design guidelines for percent windows on north wall. Carry out similar studies for east and west windows.

III.F.6 (H,C)

Use building energy analysis computer programs with passive systems simulation capabilities to study the thermal performance of residential and commercial buildings. The studies should emphasize (1) the impact of varying climactic conditions on system design; (2) desing optimization; (3) definition of control strategies; (4) interaction of auxiliary HVAC systems with the passive system; and (5) definition of energy distribution systems which improve thermal performance and comfort conditions in multizone structures.

III.F.7 (H,C)

Perform sensitivity studies on an assortment of generic active, hybrid, and passive solar systems with respect to ambient temperature, wind speed and direction, humidity, and solar radiation at a variety of locations. Characterize variations in system response from year to year. Compare variation from one system type to the next.

III.F.8 (C)

Study the regional applicability of cooling systems based on both selective and non-selective emitting systems.

G. Design Tools

III.G.1 (H,C)

Integrate thermal balance and/or network analysis routines into user-oriented computer programs appropriate for the building design community.

III.G.2 (H,C)

Develop and validate simplified techniques for analyzing and predicting the performance of passive solar buildings. Handbook tables and graphs, hand calculation methods, hand-held calculator programs, and simplified computer programs are included. Supporting documentation is required for all design tools developed under this task.

III.G.3 (H,C)

Use output from analytical tools developed in the program to periodically expand and update residential-scale passive solar design handbooks.

III.G.4 (H,C)

Use output from multizone computer simulation studies to develop and periodically expand and update a commercial-scale passive solar concept manual.

H. Performance Criteria

III.H.1 (H,C)

Based on validated analysis techniques developed for each passive heating and cooling system, identify and document an initial set of functional criteria relating to the thermal performance of the system. The criteria will appropriately account for climactic effects and for the full range of system design parameters which affect performance.

III.H.2 (H,C)

Based on the initial criteria and a broad-based experimental program, develop definitive performance criteria which are technically valid in actual building situations. The criteria should include a methodology for assessing compliance based on design information and a procedure for measuring post-construction compliance.

I. Market Field Tests

III.I.1 (H,C)

Perform an assessment of the technical readiness of individual passive solar heating and cooling systems in order to determine their potential marketability. The assessment will include examination of (1) the availability of appropriate design tools, (2) suitability of existing designer and user experience, and (3) adequacy of the existing economic data base.

III.I.2 (H,C)

Initiate a program to test the marketability of specific passive systems in both new and retrofit applications to different building types. The testing will serve as the final step in the proof-of-concept process; it will examine the climactic adaptability of the developed designs, it will test the design tools both with respect to usability and technical viability, and it will provide a broad-based test of the validity of initial performance criteria. These building programs will be initiated for residential and commercial buildings and/or specific passive system type. Relevant information will be thoroughly documented for each building constructed in the program; this will include:

- pre-construction parameters: design; performance estimate
- construction costs
- post-occupancy evaluation: performance; comfort.

III.I.3 (H,C)

The results of the market field testing programs will be used to perform a technological and economic feasibility analysis to determine cost-effectiveness based upon system type, application, climactic region, and geographic location. The analysis will provide a basis for commercialization activities and will be used to encourage designers, developers, and builders to employ the developed passive solar approaches for heating and

cooling. Secondary uses include: (1) broadening awareness and understanding of passive solar within the residential and commercial design and construction community and the general public; (2) development of passive solar designs appropriate to the marketplace; (3) identification of barriers to commercialization; and (4) acquisition of cost, performance, market, and attitudinal data.

HEATING SYSTEMS	DEVELOPMENT TASKS									Important Associated Tasks
	Concept Generation and Assessment	System Specification	System Analysis Thermal, Economic, etc. Human Comfort	Data and Instrumentation Requirements	Performance Data Acquisition	System Studies Parametric Sensitivity	Design Tools	Performance Criteria	Market Field Tests	
<u>Single Zone</u>										
● South Aperture										
1. Direct-Gain Wall	●	○	○	○	○	○	○	80	79-81	I.A.1-2
2. Storage Wall (With and Without Vents)	●	●	●	○	●	●	●	80	79-81	I.A.1-2
3. Isolated storage Wall (With Vents and/or Movable Insulation)	○	○	○	○	○	○	80	80	80-82	I.A.1-2, I.F.5-6
4. Collection Wall w/Storage Floor, etc.	80	80	80	○	○	80-81	80-81	81	80-83	I.A.1-2, I.F.5-6
5. Collection Sunspace w/Storage Floor, etc.	80	80	80	○	○	80-81	80-81	81	80-83	I.A.1-2, I.F.5-6
6. Combinations of 1 through 5	80-83	80-83	80-83	81	80-83	80-83	82-83	83	81-84	I.A.1-2, I.F.5-6
● Shaded Roof Aperture										
7. Shaded Direct-Gain Roof	○	○	○	○	○	80-82	81-82	82	80-83	I.A.1-2
8. Shaded Storage Roof	○	○	○	○	○	80-82	81-82	82	80-85	I.A.1-2
● Roof Aperture										
9. Direct-Gain Roof [†]	○	○	○	○	○	○	80-81	81	†	I.A.5-6
10. Storage Roof	○	○	○	○	○	80-81	80-82	81	80-85	
11. Collection Roof w/Storage Floor, Ceiling, or Wall*	80-82	80-82	81-82	81	81-83	81-82	81-82	82	81-83	I.F.5-6
12. Combinations of 7 through 11	81-84	81-84	81-84	82	81-84	81-84	83-84	84	82-85	I.F.5-6
● Remote Aperture										
13. Remote Collection w/Storage Floor	○	○	○	○	○	80	80-81	81	80-83	I.F.5-6
14. Remote Collection w/Isolated Storage (e.g., Solar Pond)	80	80	80-81	81	81-83	81	81-82	82	81-83	I.F.5-6
15. Ground Preheat	○	○	○	80-81	80-84	81-84	82-84	84	81-85	I.F.5, II.J.1-2
<u>Multi-Zone</u>										
● Single-Story	80-81	80-81	80-82	80-81	80-83	81-82	82-83	83	81-84	I.F.3, I.F.5
● Multi-Story	○	○	○	81	81-85	80-84	82-85	84	83-86	I.F.3, I.F.5
● Community & Urban Systems	○	80-85	81-85	81-82	82-86	82-86	83-86	85	84-87	I.E.1

[†]Emphasis will be on limited collection area for day lighting applications.

*Includes active collection and passive discharge to functional space.

● - Completed

● - Completed for selected versions

○ - Under way

79 - To be initiated

COOLING SYSTEMS	DEVELOPMENT TASKS									Important Associated Tasks
	Concept Generation and Assessment	System Specification	System Analysis: • Thermal, Economic • Human Comfort	Data & Instrumentation Requirements	Performance Data Acquisition	System Studies Parametric Sensitivity	Design Tools	Performance Criteria	Market Field Tests	
<u>Single Zone</u>										
• Sky and/or Atmospheric Sink										
1. Storage Roof	○	○	○	○	○	80-81	80-82	83	80-85	I.B.1-3, I.C.3, I.F.5, II.A.10, II.A.10, II.A.11, II.B.6-10
2. Cooling Roof w/Storage Floor, Wall, or Ceiling	80-82	80-82	81-82	81	81-83	81-83	82-83	83	82-83	I.B.1-3, I.C.3, I.F.5, II.A.10, II.A.11, II.B.6-10
3. Evaporative Cooling Ponds (Remote)	80-82	80-82	81-82	81	81-83	81-83	82-83	83	82-83	I.B.1-3, I.C.3, I.F.5, II.A.10, II.A.11, II.B.6-10, II.J.1, II.J.3
4. Shaded Storage Roof	○	80-81	81-82	80	80-83	81-83	82-83	82	81-85	I.C.3, I.F.5
5. North-Facing Shaded Storage Roof	○	○	81-82	81	○	81-83	82-83	82	81-83	I.C.3, I.F.5
• Atmospheric Sink										
6. Storage Wall	80-82	80-82	81-82	81	81-83	81-83	82-83	82	81-84	I.C.3, I.F.5
7. North Storage Wall	80-82	80-82	81-82	81	81-83	81-83	82-83	83	81-84	I.C.3, I.F.5
8. Flat Shaded Storage Roof	80-82	80-82	81-82	81	81-83	81-83	82-83	82	81-84	I.C.3, I.F.5
9. Night Air-Charged Storage Floor, Wall, or Ceiling	80-81	80-82	80-82	80	80-82	81-83	81-83	82	81-84	I.C.3, I.C.5, I.F.5, I.F.6
10. Regenerative Air-Charged Storage	80-81	80-82	80-82	80	80-82	81-83	81-83	82	81-84	I.C.3, I.F.5, I.F.6
11. Ventilation	80-81		81-82	81	81-83	81-83	82-83	82	81-84	I.C.3, I.C.5, I.F.5, I.F.9
• Ground Sink										
12. Isolated Ground	○	○	80-82	81	81-84	81-84	82-84	83	82-85	I.D.1, I.D.3, I.D.4, I.F.5, II.J.1, II.J.2
13. Direct Ground	80-81	80-81	80-82	80	81-83	81-83	82-83	82	81-85	I.D.1, I.D.3, I.D.4
<u>Multi-Zone</u>										
• Single Story	80-82	80-82	80-83	81	80-83	81-84	82-84	83	81-85	I.C.3, I.F.5, II.I.1
• Multi-Story	○	80-84	80-84	81	81-85	81-84	82-85	84	83-86	I.C.3, I.F.5, I.F.6, II.I.1
• Community & Urban Systems	80-84	81-85	81-85	81-82	82-86	82-86	83-86	84	83-87	Unidentified

APPENDIX C:
TECHNOLOGY UTILIZATION TASKS

Presented in this Appendix are utilization tasks. They have been generated from a review of current passive solar issues and problems within the utilization process. The task emphasis is on near-term activities. Special consideration was given to the results of the Reston meeting and subsequent commercialization meetings in defining and giving priority to the tasks. Many of these critical near-term utilization tasks will provide information and data for defining more specific long-term tasks and will help establish a detailed comprehensive utilization plan.

TABLE III-1

Technology Utilization Task Classifications

<p>I. COMMERCIALIZATION READINESS ASSESSMENT</p>	<p>A. Technical readiness B. Market/economic readiness C. Environmental readiness D. Institutional readiness E. Benefits analysis F. Commercialization planning</p>
<p>II. TECHNOLOGY TRANSFER</p>	<p>A. Data management B. Education and training C. Information dissemination</p>
<p>III. STIMULATION OF TECHNOLOGY DELIVERY CAPABILITY</p>	<p>A. Solar access B. Building codes and standards C. Performance criteria D. Incentives</p>
<p>IV. STIMULATION OF MARKET DEMAND</p>	<p>A. Consumer education B. Utility programs C. Solar energy in federal facilities D. Solar energy in state/local bldgs. E. National, regional, and state design/build competitions F. Policy studies G. Incentives</p>

I. COMMERCIALIZATION READINESS ASSESSMENT

A. Technical Readiness

I.A.1

Maintain a continuously updated technical readiness assessment for all passive systems, to be used in identifying systems for intensified commercialization activities. The near-term emphasis will be on initiating a detailed assessment of passive space-cooling systems, to complement the existing space heating assessment.

B. Market/Economic Readiness

I.B.1

For systems judged technically ready or close to technically ready, identify prime markets in terms of

- building construction rate;
- compatibility of climate and passive system;
- competing technologies;
- receptivity of community to innovative building designs;
- characteristics of local construction business and attitudes of building community.

I.B.2

Evaluate community attitudes toward passive solar installations, impact on land values, and influences on future development of neighborhoods.

I.B.3

Evaluate consumer attitudes to passive solar energy systems including devices that require intervention by the resident (moving insulating panels at night, etc.). Compare consumer attitudes in this area with consumer reaction to other energy conservation measures.

I.B.4

Interview occupants of passive solar buildings to assess the life-style and comfort factors of different passive approaches. Both technical (quantifiable) and non-technical (qualitative) issues should be addressed

C. Environmental Readiness

I.C.1

Assess the environmental readiness of all passive systems deemed technically ready and marketable.

I.C.2

Use microclimate studies to assess environmental acceptability of evaporative cooling in densely-built, large-scale developments.

I.C.3

Assess the water resource impact of evaporative cooling in arid climates.

D. Institutional Readiness

I.D.1

Synthesize information on the building industry experience. Identify factors that have slowed or prevented building technology innovations as well as factors that have accelerated the adoption of such innovations. Draw parallels and distinctions between past building technology innovations and passive solar and identify likely problem areas.

I.D.2

Assess lender attitudes which could impact funding of passive solar projects.

E. Benefits Analysis

I.E.1

Perform benefits analysis for all passive systems deemed technically ready and marketable. Disaggregate according to economic and climactic conditions prevalent in those parts of the U.S. where building construction rates are high. Base benefits analysis on passive systems sized to maximize net present worth. System emphasis will be as follows:

Short-term: Storage wall, direct-gain wall, and combinations of the two.

Mid-term: Roof and shaded roof aperture heating systems.

Long-term: Passive hot-water and cooling.

F. Commercialization Planning

I.F.1

Refine and update commercialization planning on the basis of technical, market/economic, environmental, and institutional readiness assessments and benefits analyses. The near-term planning will emphasize space heating; in the future, the emphasis will shift to space cooling and passive hot water.

II. TECHNOLOGY TRANSFER

A. Data Management

II.A.1

Expand data base for passive program: nationally through the information center and regionally through the RSEC's.

B. Education and Training

II.B.1

Organize lectures and seminars for the financial community stressing:

- performance and reliability of passive solar;
- benefits of considering projected energy expenditures in determining allowable mortgage.

II.B.2

Organize lectures, seminars, university curricula, and conferences for building designers (architects and engineers) emphasizing:

- basic principles;
- design decision-making;
- detailed thermal analysis.

Among other things, these activities should provide support to and be coordinated with other parts of the program, such as the design/build competition.

II.B.3

Organize lectures, seminars, and conferences for builders, developers, and related professional organizations. Among other things, these activities should provide support to and be coordinated with other parts of the program, such as the marketable design development.

II.B.4

Organize lectures, seminars, and conferences for planners and government officials, emphasizing the integration of solar considerations into more general land management and planning methods.

II.B.5

Develop and fund trade-school courses for installers and craftspeople.

II.B.6

Organize lectures and seminars for realtors. Emphasize the importance of a variety of energy issues, such as solar exposure, orientation, window placement, overhangs, vegetation, insulation, etc.

II.B.7

Fund the preparation of articles for architectural, engineering, and planning professional journals.

C. Information Dissemination

II.C.1

Expand information dissemination program nationally through the information center and regionally through the RSEC's. Prepare literature, films, slide presentations, and other information packages suitable for use by universities, trade schools, and professional groups and organizations. Materials should be made available for designers, builders, developers, planners, government officials, craftspeople, installers, realtors, and lenders.

II.C.2

Provide technical and design specification documentation to the building community.

IV. STIMULATION OF TECHNOLOGY DELIVERY CAPABILITY

A. Solar Access

III.A.1

Based on the results of the land use surveys and the land use planning tools developed in the technical areas, develop planning guidelines and provide planning assistance to municipal officials, and developers.

III.A.2

Initiate development of model solar access regulations which recognize regional, local, and site-specific characteristics.

III.A.3

Initiate development of model urban planning legislation.

III.A.4

Provision of assistance to state and local governments in tailoring model code to the locale and in defining and implementing necessary legislation.

B. Building Codes and Standards

III.B.1

Provide information and guidelines to state and local officials for implementation of conservation codes which are not detrimental to the solar alternative.

III.B.2

Develop guidelines for recommended modifications to state codes which inhibit passive solar implementation.

III.B.3

Assistant to code officials:

- Prepare and distribute information describing passive systems and their elements to code officials.
- Provide guidelines for evaluating the effectiveness of passive solar elements and distribute to code officials.
- Provide assistance to state and local code officials in evaluation of passive system compatibility with existing codes.

C. Performance Criteria

III.C.1

Expand on the results of Technology Development task III.H.1 to establish detailed thermal and lighting criteria for a range of fully-developed passive solar systems, in a range of climates.

D. Incentives

III.D.1

Based on studies of building construction industry (task I.D.1), identify those parts of the industry where substantial national benefits could be derived from financial incentives such as tax credits and government loans and grants.

III.D.2

Use prime-market studies (task I.B.1) to identify target communities for concentrated second-generation market field tests.

III.D.3

Encourage FHA and local building authorities to make passive solar add-ons eligible as part of basic home mortgages.

III.D.4

Encourage FHA and local building authorities to use passive solar in low-cost public housing.

IV. STIMULATION OF MARKET DEMAND

A. Consumer Education

IV.A.1

Organize lectures, with slide-shows and films, for presentation at consumer and civic group meetings. Emphasis should be on simple principles and the elements of good design: solar exposure, orientation, window placement, overhangs, vegetation placement, etc.; but some more detailed lectures emphasizing philosophical and technical issues should also be available.

IV.A.2

Supply public and institutional libraries with literature and films on passive solar.

IV.A.3

Develop lectures, textbooks, films, slide-shows, and mobile and science class demonstrations for public school education. Fund field trips to passive solar facilities.

IV.A.4

Generate posters and television commercials on passive solar.

IV.A.5

Assist in preparation of articles for various popular periodicals.

IV.A.6

Encourage dissemination of information through product manufacturer advertising.

B. Utility Programs

IV.B.1

Use results of system studies (see Technology Development Tasks) to encourage utilities to promote passive solar where beneficial to their load profile.

C. Solar Energy in Federal Facilities

IV.C.1

Select high-visibility federal building projects to demonstrate a range of functional applications and building system types.

D. Solar Energy in State/Local Buildings

IV.D.1

Encourage and support building and community demonstrations with high visibility. Share the design and solar add-on cost of several state and local buildings, a substantial portion of which will be schools. Use projects as focus for educational programs:

- Provide accommodations for field trips to passive solar facilities.
- Provide literature on passive solar facilities.

E. National, Regional, and State Design/Build Competitions

IV.E.1

Use prime-market studies (Task I.B.1) to identify regions, states, and cities for design/build competitions.

IV.E.2

Hold passive solar design competitions, the primary purposes of which will be to:

- reward designers (who might not otherwise find an appropriate forum) for innovative ideas;
- increase public and building community awareness;
- build the most promising designs.

F. Policy Studies

IV.F.1

Study and evaluate the impact of conventional fuel subsidies on the life cycle cost comparisons of passive and conventional heating systems.

IV.F.2

In conjunction with other federal and state agencies and with representatives of the conventional fuel industry, develop scenarios for phased reduction of subsidies.

G. Incentives

IV.G.1

Establish a definitional and procedural framework for federal income tax credits which is easily administered and which simultaneously promotes design integrity in response to local climate conditions.

IV.G.2

Establish a definitional and procedural framework for low-interest loans which is easily administered and which simultaneously promotes design integrity in response to local climate conditions.

IV.G.3

Define criteria for accelerated depreciation eligibility.

IV.G.4

Establish a definitional and procedural framework for loan guarantees which is easily administered and which simultaneously promotes design integrity in response to local climate conditions.

IV.G.5

Integrate passive solar financing options into local solar loan programs.

IV.G.6

Encourage state adoption of alternative mortgage instrument programs for solar financing.

IV.G.7

Encourage state income tax credits which promote design integrity in response to local climate conditions.

IV.G.8

Encourage adoption of property tax exemptions for passive solar add-on cost.

TECHNOLOGY UTILIZATION TASK SCHEDULES

APPENDIX D:

ACTIVITY	FISCAL YEAR							
	1978	1979		1980	1981	1982	1983	1984
TECHNOLOGY DEVELOPMENT ACTIVITIES								
MARKETABLE PRODUCT DEVELOPMENT			ISSUE RFP	AWARDS	RFP AWARDS	AWARDS	AWARDS	AWARDS
PRODUCT AND ASSEMBLY DEVELOPMENT	4		ISSUE RFP	AWARDS		AWARDS		
DESIGNS FOR SITE-BUILT ASSEMBLIES			ISSUE RFP	AWARDS		AWARDS		
REGIONAL PRODUCT STUDIES			4	4				
MARKETABLE DESIGN DEVELOPMENT								
MANUFACTURED BUILDINGS			1 2	1 2	1 2	1 2		
SINGLE-FAMILY TRACT HOMES AND MULTIFAMILY			1 2	1 2	1 2	1 2		
LIGHT COMMERCIAL COMMUNITY AND URBAN APPLICATIONS			1 2	1 2	1 2	1 2	1 2	1 2
DESIGN TOOL DEVELOPMENT								
DATA REPORTS (DR)	5		5	HANDBOOKS & TOOLS	5	5	5	5
PERFORMANCE DATA ACQUISITION								
LOW COST DATA PKG DEVELOPED			DR		DR	DR	DR	DR
TECHNOLOGY UTILIZATION ACTIVITIES								
UTILIZATION READINESS ASSESSMENT				4	4	CONF.	CONF.	CONF.
TECHNOLOGY TRANSFER			3	3	3	3	3	3
STIMULATION OF TECHNOLOGY DELIVERY CAPABILITY								
REGULATORY AND LEGAL								
SOLAR ACCESS								
BUILDING CODES AND STANDARDS			4	4	PT 4	PT 4	4	4
CONSUMER PROTECTION AND WARRANTIES			4	4	4	4	4	4
INSTITUTIONAL								
FHA AND LOCAL BUILDING AUTHORITY			4	4	4	4	4	4
DELIVERY INCENTIVES								
STIMULATION OF MARKET DEMAND			4	4	4	4	4	4
CONSUMER EDUCATION			3	3	3	3	3	3
REGIONAL AND STATE DESIGN COMPETITIONS			3	3	3	3	3	3
PASSIVE SOLAR IN FEDERAL FACILITIES			4	4	4	4	4	4
DEMAND INCENTIVES			4	4	4	4	4	4

DEPARTMENT CONTROLLED
 PROGRAM CONTROLLED
 SIGNIFICANT MILESTONE
 INTERMEDIATE EVENT

NOTES: 1. DESIGN PHASE COMPLETED 4. REPORT
 2. BUILD PHASE INITIATED 5. HANDBOOKS AND DESIGN TOOLS
 3. INFORMATION PACKAGES

APPENDIX E:

PROJECTED PASSIVE SOLAR SPACE-HEATING ENERGY IMPACT

Residential and Light Commercial
Passive Solar Costs and Energy Impacts
Without Tax Credits

EXPECTED MARKET PENETRATION	1985	1990	2000
<u>New Construction</u>			
New Energy Market (quads)	.134	.134	.134
Energy Penetration (quads in that year)	.0034	.012	.028
Percent of New Energy Market Penetrated	2.5%	8.9%	20.8%
Percent Penetration of New Units	6.0%	19.0%	41.0%
<u>Retrofit Construction</u>			
Total Retrofit Energy Market (quads)	9.52	9.94	10.5
Energy Penetration Retrofit (quads)	.0042	.0120	.0196
Percent of Retrofit Energy Market Penetrated	.04%	.12%	.18%
Percent Penetration of Retrofit Units of Total	.17%	.47%	.73%
Total Annual Energy Displaced (quads), [†] New and Retrofit	.0202	.107	.5

[†]Total annual energy displaced, in quads, by passive heating systems installed between 1978 and the year designated.

APPENDIX E (cont'd)

Residential and Light Commercial
Passive Solar Costs and Energy Impacts
With Tax Credits

EXPECTED MARKET PENETRATION	1985	1990	2000
<u>New Construction</u>			
New Energy Market (quads)	.134	.134	.134
Energy Penetration (quads in that year)	.0084	.020	.032
Percent of New Energy Market Penetrated	6.2%	14.9%	23.7%
Percent Penetration of New Units	12.0%	30%	48%
<u>Retrofit Construction</u>			
Total Retrofit Energy Market (quads)	9.52	9.94	10.5
Energy Penetration Retrofit (quads)	.0101	.022	.017
Percent of Retrofit Energy Market Penetrated	.11%	.23%	.16%
Percent Penetration of Retrofit Units of Total Stock	.41%	.88%	.62%
Total Annual Energy Displaced (quads), [†] New and Retrofit	.0502	.222	.64

[†]Total annual energy displaced, in quads, by passive heating systems installed between 1978 and the year designated.

This report was done with support from the Department of Energy. Any conclusions or opinions expressed in this report represent solely those of the author(s) and not necessarily those of The Regents of the University of California, the Lawrence Berkeley Laboratory or the Department of Energy.

Reference to a company or product name does not imply approval or recommendation of the product by the University of California or the U.S. Department of Energy to the exclusion of others that may be suitable.

TECHNICAL INFORMATION DEPARTMENT
LAWRENCE BERKELEY LABORATORY
UNIVERSITY OF CALIFORNIA
BERKELEY, CALIFORNIA 94720