Lawrence Berkeley National Laboratory

Recent Work

Title

U.S. Industrial and Commercial Motor System Market Assessment Report Volume 1:
Characteristics of the Installed Base

Permalink

<https://escholarship.org/uc/item/42f631k3>

Authors

Rao, Prakash
Sheaffer, Paul
Chen, Yuting
et al.

Publication Date

2022-12-23

Peer reviewed

Energy Technologies Area Lawrence Berkeley National Laboratory

LBNL-2001382

U.S. Industrial and Commercial Motor System Market Assessment Report

Volume 1: Characteristics of the Installed Base

Prakash Rao, Ph.D.¹, Paul Sheaffer¹, Yuting Chen, Ph.D.¹,
Miriam Goldberg, Ph.D.², Benjamin Jones², Jeff Cropp³,
and Jordan Hester³

¹Lawrence Berkeley National Laboratory

²DNV GL

³Cadmus

January 2021

Revised September 2021

Disclaimer

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Ernest Orlando Lawrence Berkeley National Laboratory is an equal opportunity employer.

Copyright

This manuscript has been authored by an author at Lawrence Berkeley National Laboratory under Contract No. DE-AC02-05CH11231 with the U.S. Department of Energy. The U.S. Government retains, and the publisher, by accepting the article for publication, acknowledges, that the U.S. Government retains a non-exclusive, paid-up, irrevocable, world-wide license to publish or reproduce the published form of this manuscript, or allow others to do so, for U.S. Government purposes.

Prepared for the
Advanced Manufacturing Office
Office of Energy Efficiency and Renewable Energy
U.S. Department of Energy

Prakash Rao
Paul Sheaffer
Yuting Chen

Ernest Orlando Lawrence Berkeley National Laboratory
1 Cyclotron Road
Berkeley, CA 94720

With contributions from

Miriam Goldberg and Benjamin Jones, DNV GL
Jeff Cropp and Jordan Hester, Cadmus

January 2021
Revised September 2021

The work described in this study was funded by the Advanced Manufacturing Office of the U.S. Department of Energy's Office of Energy Efficiency and Renewable Energy under Lawrence Berkeley National Laboratory Contract No. DE-AC02-05CH11231

Preface

In the late 1990s, the U.S. Department of Energy (DOE) conducted two seminal studies to better understand the installed stock and energy savings opportunities of industrial and commercial motor systems: *The United States Industrial Electric Motor Systems Market Opportunities Assessment* (industrial sector) and *Opportunities for Energy Savings in the Residential and Commercial Sectors with High Efficiency Electric Motors* (commercial sector). In the more than 20 years since the publication of these reports, the U.S. industrial and commercial sectors have undergone changes, including facility and/or motor system stock turnover, offshoring and onshoring of manufacturing, passage of motor efficiency standards, cost reductions in motor driven systems, and more. To gain a more current understanding of motor systems in the U.S. industrial and commercial sectors, DOE initiated an update to these two studies. Launched in 2016 and led by Lawrence Berkeley National Laboratory (LBNL), the Motor System Market Assessment (MSMA) provides an updated, more comprehensive assessment of the installed stock of motor systems in both the industrial and commercial sectors, a review of the supply chains supporting motor and drives in the U.S., and the performance improvement opportunity available from using best available technologies and maintenance and operation practices. The outcomes of the MSMA are documented in three *U.S. Industrial and Commercial Motor System Market Assessment* reports, with this report being the first listed:

1. *Volume 1: Characteristics of the Installed Base* (this report) documents the findings on the installed base of motor systems in the U.S. industrial and commercial sectors. Quantification of energy savings potential is not documented in this report but in Volume 3. A searchable website with the underlying information contained in this report is available at <https://motors.lbl.gov/inventory>. This website has been established to serve as a complement to this Volume 1 report and allows readers to create their own crosscuts and conduct their own analysis using the results from the Motor System Market Assessment.
2. *Volume 2: Advanced Motors and Drives Supply Chain Review* reviews the state of supply chains for motors and drives installed in U.S. industrial and commercial facilities, focusing on advanced motor and drive technologies and their constituent materials.
3. *Volume 3: Energy Savings Opportunity* analyzes the energy performance improvement opportunity for the installed base of U.S. industrial and commercial motor systems.

This Volume 1 report was originally released in January 2021. A revised version was released in September 2021. The revisions include updates to Tables 12 and 14, Figures 53, 54, 56, and 57, and accompanying text to correct minor omissions and incorrect categorizations. Additionally, references and links to the website for this report was added to the text.

Acknowledgements

This work was supported by the Assistant Secretary for Energy Efficiency and Renewable Energy, Advanced Manufacturing Office of the U.S. Department of Energy under Contract No. DE-AC02-05CH11231.

The authors would like to thank the following individuals for their guidance and leadership:

Allen Hefner, U.S. Department of Energy Advanced Manufacturing Office
Paul Scheihing, U.S. Department of Energy Advanced Manufacturing Office (retired)
Aimee McKane, Lawrence Berkeley National Laboratory (retired)

The authors are grateful to the following individuals and their organizations for their reviews and valuable insights:

Kirk Anderson, National Electrical Manufacturers Association
Tom Bishop, Electrical Apparatus Service Association
Rob Boteler, National Electrical Manufacturers Association
Rolf Butters, U.S. Department of Energy Advanced Manufacturing Office
R. Neal Elliot, Ph.D., P.E., American Council for an Energy-Efficient Economy
Peter Gaydon, Hydraulic Institute
Michael Ivanovich, Air Movement and Control Association
Edward G. Rightor, Ph.D., American Council for an Energy-Efficient Economy
Ethan Rogers, U.S. Department of Energy Advanced Manufacturing Office

The authors would like to thank the many people across several organizations that helped execute the Motor System Market Assessment: Christie Amero and Aaron Huston of Cadmus, Zach Podell-Eberhardt of Cascade Energy, Mike Witt and Christina Robichaud of DNV GL, John Smegal of the U.S. Department of Energy Advanced Manufacturing Office, the late Dr. Shihab Asfour and center staff at the University of Miami Industrial Assessment Center (IAC), Dr. Bryan Rasmussen and center staff at the Texas A&M IAC, Dr. Sanjeev Khanna and center staff at the University of Missouri IAC, Dr. Robert Williams and center staff at the University of Nebraska – Lincoln IAC, and Anna D'Alessio, Steve Greenberg, Phil Price, and Darren Sholes of Lawrence Berkeley National Laboratory.

The authors are also grateful for the support provided by the following individuals and organizations for their efforts towards recruiting sites for assessments: Eli Levine, Robert Bruce Lung, and the Technical Account Managers of the U.S. Department of Energy's Better Plants Program; Kitt Butler and staff at Advanced Energy; and staff at Duke Energy.

This study and report were made possible by the 369 industrial and commercial facilities assessed and their staff facilitating the assessments. We are very grateful to these facilities and their staff for their generosity and support.

List of Acronyms and Abbreviations

AC	Alternating current
ASD	Adjustable speed drive
Beverage/Tobacco	Beverage and tobacco products
CBECS	Energy Information Agency's Commercial Building Energy Consumption Survey
CBP	County business patterns
CFM	Cubic feet per minute
Chemical	Chemicals
CI	Confidence interval
CIP	Cleaning in place
Computer/Electronic	Computer and electronic products
COP	Coefficient of performance
DC	Direct current
DOE	United States Department of Energy
EDU	Education
EIA	Energy Information Administration
Electrical Equipment	Electrical equipment and appliances
EMW	Electric master weight
Fabricated Metal	Fabricated metal products
Food	Food products
FSA	Food sales
FSE – Food service	Food service
Furniture	Furniture and related products
GPM	Gallons per minute
GWh	Gigawatt-hour
HCI	Health care: Inpatient
HCO	Health care: Outpatient
HP	Horsepower
HVAC	Heating, ventilation and air-conditioning
IN-Hg	Inches mercury
In-Wg	Inches water gauge
IQ	Interquartile range
ISO	International Organization for Standardization
kWh	Kilowatt-hour
LBNL	Lawrence Berkeley National Laboratory
LCL	Lower confidence limit
Leather	Leather and allied products
LEED	Leadership in Energy and Environmental Design
LOD	Lodging (includes Nursing)
MECS	Energy Information Agency's Manufacturing Energy Consumption Survey
MEM	Mercantile: Enclosed and Strip Malls
MER	Mercantile: retail ()
MPU	Mean-per-unit

MSMA	Motor System Market Assessment
N/A	Not applicable
NAICS	North American Industry Classification System
NEMA	National Electrical Manufacturers Association
OFF	Office
OTH	Other and vacant
Paper	Paper and allied products
PAS	Public assembly
Petroleum Refining	Petroleum and coal products
Plastic/Rubber	Plastic and rubber products
POS	Public order and safety
Primary Metal: Iron/Steel	Primary metal: Iron and steel mills and ferroalloy manufacturing
Primary Metal: Other	Primary metals: other
Printing	Printing and related support
PSIG	Pounds per square in gauge
PSU	Primary sampling units
REW	Religious worship
RPM	Rotations per minute
RSE	Relative standard error
RWSN	Ratio weight site to national
SER	Service
SIC	Standard industrial classification
Textile Mill	Textile mills
Textile Product	Textile product mills
Transportation	Transportation equipment
TWh	Terawatt-hour
UCL	Upper confidence limit
UTC	Unable to collect
VFD	Variable frequency drives
WAS	Warehouse and storage
Wastewater	Municipal wastewater treatment
Wood	Wood products
WCMS	Combined motor to site weight
WFMN	Final motor to national weight
WFMS	Final motor to site weight
WMS	Preliminary motor to site weight
WSN	Site to national weight

Executive Summary

Motor-driven systems are ubiquitous, operating in virtually every industrial site and commercial building. These motors consume close to one-third of all the electricity in the United States and are vital to the U.S. economy. Lawrence Berkeley National Laboratory, under the direction of the U.S. Department of Energy's Advanced Manufacturing Office, conducted a multiyear research project to study motor systems in the industrial and commercial building sectors. This report is Volume 1 of the results, showing an inventory of the installed base of electric motor systems in the industrial and commercial building sectors and their operating characteristics.

Background and Motivation

A lack of sufficient data is a major barrier to effective decision making that will help to capture the energy savings potential in motor systems. Prior to the release of this report, there was no information on the current state of motor driven systems in U.S. industrial and commercial facilities. This limited the ability to conduct analysis on energy savings potential, develop technologies to address energy and productivity gaps, and develop programs to promote energy efficiency.

Findings

Key findings on the installed base of motors and their operating characteristics are summarized below.

Installed Base. The installed base key findings show total electricity consumption and motor system counts by subsector, driven equipment, and system size range.

Motor system electricity consumption

- Industrial and commercial three-phase motor systems greater than or equal to 1 horsepower (hp) consume ~1,079 terawatt-hours (TWh)/year, about 29 percent of the total electric grid load.
 - Industrial: 546,963 gigawatt-hours (GWh), about 69 percent of all electricity consumption and 13 percent of overall energy consumption in the sector.
 - Commercial: 532,024 GWh, about 43 percent of all electricity consumption and 26 percent of overall energy consumption in the sector.
- Sixty-two percent of the industrial sector's estimated annual motor system electricity consumption resides in the top six subsectors, with the Chemicals subsector (106,000 GWh) being the largest.
- Twenty-nine percent of all industrial sector motor system electricity consumption is for materials processing, followed by 21 percent for pumps and fans/blowers each.
- Seventy-five percent of industrial motor system electricity consumption is attributed to 1-500 hp motor systems.
- Seventy percent of the commercial sector's estimated annual motor system electricity consumption resides in the top seven subsectors, with the Office subsector (93,334 GWh) being the largest.

- Forty-eight percent of all commercial sector motor system electricity consumption is for refrigeration compressors (e.g., chillers, air conditioners). Refrigeration compressors, fans/blowers, and pumps account for 94 percent of the sector's motor system electricity consumption.
- Eighty percent of commercial sector motor system electricity consumption is attributed to the 1-50 hp size range.

Motor system counts and size

- There are 52.5 million motor systems greater than or equal to 1 hp in the industrial and commercial sectors, with 10.8 million in industrial and 41.7 million in commercial facilities.
- The average connected motor system horsepower at a facility is 1,595 hp for the industrial sector and 89 hp for the commercial sector.
- Average motor size is 27 hp for industrial and 8 hp for commercial.
- Sixty-two percent of the industrial sector's estimated motor system units reside in the top six subsectors, with Machinery (2 million) accounting for the most.
- Seventy-four percent of the commercial sector's estimated motor system units reside in the top seven subsectors, with the Mercantile: Enclosed and Strip Malls subsector (6.3 million) accounting for the most units.
- Ninety-nine percent of the motor system units in the industrial sector are in the 1-500 hp range, with 49 percent in the 1-5 hp range.
- Ninety-nine percent of the motor system units in the commercial sector are in the 1-50 hp size range.

Operating Characteristics. This section summarizes findings related to operating characteristics of industrial and commercial motor systems; specifically, findings related to load factor, load control, and transmission type. Additionally, findings related to energy management and maintenance practices are also summarized.

Load factor (percent of full speed load)

- Thirty-four percent of industrial sector motor system electricity consumption operates at variable load, with load factors between 40 percent and 75 percent.
- Forty-three percent of industrial sector motor system units operate at constant loads greater than 75 percent of full load.
- Forty percent of commercial sector motor system electricity consumption operates at variable load, with load factors between 40 percent and 75 percent.
- Thirty-six percent of commercial sector motor system units operate at variable loads, with load factors between 40 percent and 75 percent.
- Very little of industrial or commercial motor system electricity consumption operates at load factors under 40 percent load. Only 6 percent of industrial sector motor system electricity consumption, and 9 percent of the industrial motor systems operate under 40 percent load factor.
- Only 3 percent of the commercial sector motor system electricity consumption operates under 40 percent of load factor.

Load control

- On average, 16 percent of motor system capacity at an industrial facility uses variable frequency drives (VFDs), and 74 percent has no load control technology/equipment.
- The rate of installation of VFDs and other load control technologies in the industrial and commercial sectors increases with motor system size.
- On average, 4 percent of motor system capacity at a commercial facility uses VFDs, and 91 percent has no load control technology/equipment.
- The share of motor system capacity with a VFD increases with increasing facility size for both the industrial and commercial sectors. In the industrial sector, 17 percent of motor system capacity in large facilities is on a VFD compared to 8 percent in small facilities. Similarly, 10 percent of the motor system capacity in large commercial facilities is on a VFD, compared to 2 percent in small commercial facilities.
- The uptake of VFDs by driven equipment type in the industrial sector is nearly uniform, at about 23 percent of electricity consumption for each equipment type, with most operating using temperature or pressure setpoints as the control mechanism.
- The uptake of VFDs by driven equipment type in the commercial sector varies, but is highest for fan/blower systems with the most common metric for VFD control being pressure setpoint.

Transmission type

- Thirty-four percent of industrial sector motor systems and 44 percent of commercial sector motor systems use direct drive transmission to convey motor shaft power to the end-use equipment. Direct drive is the most common transmission type observed across both sectors.

Motor system energy management

- Forty-nine percent of industrial facilities consider energy efficiency in the procurement of motor system components, and 58 percent consider energy efficiency in the design of new motor systems.
- Large industrial facilities are more likely to consider energy efficiency in the procurement and design of motor systems and related components compared to small facilities.
- Fifty-nine percent of commercial facilities consider energy efficiency in the procurement of motor system components, and 67 percent consider energy efficiency in the design of new motor systems.
- Large commercial facilities are less likely to consider energy efficiency in the procurement and/or design of motor systems and related components compared to small facilities
- Across all industrial facilities, external energy assessments were the most common method for identifying energy efficiency measures, with 59 percent utilizing external assessors.
- Thirteen percent of industrial facilities and 18 percent of commercial facilities had an inventory of all their motors, spare and connected.

Motor system maintenance

- It is estimated that commercial and industrial facilities experience more than 8 million and 6 million hours annually of unplanned motor system downtime, respectively, due to failure.
- On average, a commercial facility experiences three hours of unplanned motor system downtime due to failure per year, and an industrial facility experiences 47 hours per year.
- In the industrial sector, 54 percent of all facilities have a repair/replace policy, with the leading criteria guiding the policy being lowest first cost, which is used by 36 percent of facilities.
- Four percent of industrial motors were rewound over the past two years.
- In the commercial sector, 16 percent of all facilities have a repair/replace policy. Most facilities were unaware of the criteria underpinning the policy. The most commonly cited criteria guiding the policy are lowest first cost (11 percent) and quickest option (10 percent).
- Less than 1 percent of commercial motors were rewound over the past two years.

Table of Contents

<i>Preface</i>	<i>iv</i>
<i>Acknowledgements</i>	<i>v</i>
<i>List of Acronyms and Abbreviations</i>	<i>vi</i>
<i>Executive Summary</i>	<i>viii</i>
<i>List of Figures</i>	<i>xiv</i>
<i>List of Tables</i>	<i>xviii</i>
<i>Background and Motivation</i>	<i>1</i>
<i>Methodology</i>	<i>4</i>
Objectives	4
Scope	4
Sampling approach	5
Planned sample allocation.....	6
Final sample allocations.....	8
Sample weighting and scaling	11
Assessment details	14
Uncertainty assessment	15
<i>Findings</i>	<i>16</i>
Installed base characteristics	18
Overall industrial and commercial.....	18
Industrial sector breakdown by facility type	20
Commercial sector breakdown by facility type	27
Driven equipment breakdown.....	36
Motor system size breakdown	55
DC motor system demographics	61
Motor age.....	67
Comparison to previous report.....	68
Highlights	71
Operating characteristics	73
Motor load factor	73
Load control.....	83
Transmission type	99
Energy management practices	103
Maintenance practices.....	108
Comparison to previous report.....	116
Highlights	117
<i>References</i>	<i>120</i>
<i>Glossary</i>	<i>122</i>
<i>Appendix A: Sampling Allocation</i>	<i>A-1</i>
Units of analysis	A-1

Data sources for the population characteristics and sampling frame	A-1
Sample stratification	A-1
Metrics used for sample allocation	A-3
Sample sizes by commercial and industrial subsector	A-3
Allocation to size bins within a subsector.....	A-4
Sample selection within a sampling cell	A-7
Sample by census region	A-7
Sample improvements compared to the prior study.....	A-10
Limitations of separating recruitment lists from the sample allocation population.....	A-11
Data sources	A-11
<i>Appendix B: Weighting Description.....</i>	<i>B-1</i>
Construction of weights	B-1
Basic weights	B-1
Ratio estimation expansion.....	B-5
Basic ratio estimator	B-5
Applying the weights: Direct expansion.....	B-8
Direct expansion for non-count variables	B-8
National totals directly from the motor-record data.....	B-9
Uncertainty	B-10
Components of uncertainty	B-10
Imputation approach	B-12
Calculating motor consumption and motor counts results	B-19
MSMA confidence limits.....	B-19
MSMA and MECS/CBECS combined confidence limits.....	B-29
<i>Appendix C: Field Assessment Questions.....</i>	<i>C-1</i>
Basic motor inventory questions.....	C-2
Pump checklist.....	C-16
Fan/blower checklist	C-20
Compressed air checklist.....	C-24
Refrigeration checklist.....	C-35
Facility general motor practices questions.....	C-43

List of Figures

Figure 1: Final sample allocation for industrial assessments. The numbers on the figures indicate the number of samples conducted within each facility size category per subsector. Size categories with no number had one sample completed.....	9
Figure 2: Final sample allocation for commercial assessments. Consult the List of Acronyms and Abbreviations for the full name of each subsector. The numbers on the figures indicate the number of samples conducted within each facility size category per subsector. Size categories with no number had one sample completed.	9
Figure 3: Motor weights calculation flowchart.....	12
Figure 4: Legibility of nameplates on motors assessed: commercial (L) and industrial (R).....	16
Figure 5: Guide to reading box plots	17
Figure 6: Estimates of total industrial and commercial motor system annual electricity consumption with 90 percent confidence intervals. Note that the upper and lower bounds of the confidence intervals for the commercial and industrial sectors will not sum to the national level due to the method used for their calculation. The averages do sum.	18
Figure 7: Estimate of total industrial and commercial motor units with 90 percent confidence intervals. Note that the upper and lower bounds of the confidence intervals for the commercial and industrial sectors will not sum to the national level due to the method used for their calculation. The averages do sum.	19
Figure 8: Distribution of facility total connected hp for the industrial and commercial sectors. Please refer to Figure 5 for guidance on interpreting the box plots.	20
Figure 9: Total industrial motor system annual electricity consumption by subsector with 90 percent confidence intervals.....	21
Figure 10: Motor counts by industrial subsector with 90 percent confidence intervals	23
Figure 11: Share of industrial motor system counts and electricity consumption by industrial subsector. The Balance of Subsectors category includes: Electrical Equipment, Furniture, Leather, Miscellaneous, and Textile Product.....	25
Figure 12: Distribution of facility total connected hp by industrial subsector. Please refer to Figure 5 for guidance on interpreting the box plots.....	26
Figure 13: Total industrial annual motor system electricity consumption by facility size	28
Figure 14: Total industrial motor system count by facility size	28
Figure 15: Total commercial motor system annual electricity consumption by subsector with 90 percent confidence intervals.....	29
Figure 16: Motor counts by commercial subsector with 90 percent confidence intervals	31
Figure 17: Distribution of facility total connected hp by commercial subsector. The inset graph rescales the data by removing the Health Care: Inpatient subsector, allowing for the values of other subsectors to be more readily read. Please refer to Figure 5 for guidance on interpreting the box plots.	33
Figure 18: Share of motor system electricity consumption and counts by commercial subsector.....	34
Figure 19: Commercial sector motor system annual electricity consumption by facility size	35
Figure 20: Commercial sector motor system counts by facility size	36
Figure 21: Industrial motor system annual electricity consumption by driven equipment. UTC indicates that the equipment driven by the motor could not be identified.	37
Figure 22: Share of motor system electricity consumption by driven equipment and technology type for the industrial sector.....	38

Figure 23: Breakdown of industrial motor counts by driven equipment	40
Figure 24: Share of motor system units by driven equipment and technology type for the industrial sector	41
Figure 25: Distribution of driven equipment size within the industrial sector. Please refer to Figure 5 for guidance on interpreting box plots.....	42
Figure 26: Distribution of annual run hours by driven equipment for the industrial sector, Please refer to Figure 5 for guidance on interpreting box plots.	42
Figure 27: Industrial motor system annual electricity consumption by process type.....	44
Figure 28: Industrial motor system counts by process type.....	45
Figure 29: Commercial motor system annual electricity consumption by driven equipment	46
Figure 30: Share of motor system electricity consumption by driven equipment and technology type for the commercial sector	47
Figure 31: Breakdown of commercial motor counts by driven equipment	49
Figure 32: Share of motor system units by driven equipment and technology type for the commercial sector	50
Figure 33: Distribution of driven equipment size within the commercial sector	51
Figure 34: Distribution of annual run hours by driven equipment for the commercial sector	52
Figure 35: Commercial sector motor system annual electricity consumption by process type....	54
Figure 36: Commercial motor system counts by process type	55
Figure 37: Industrial motor system annual electricity consumption by size category.....	56
Figure 38: Industrial motor system count by size category	57
Figure 39: Distribution of annual run hours for industrial motor systems by size category. See Figure 5 for guidance on interpreting the box plots.....	58
Figure 40: Commercial motor system annual electricity consumption by size category	59
Figure 41: Commercial motor system counts by size category	59
Figure 42: Distribution of annual run hours for commercial motor systems by size category. See Figure 5 for guidance on interpreting the box plots.....	60
Figure 43: DC motor system annual electricity consumption in the industrial sector.....	61
Figure 44: DC motor system counts in the industrial sector.....	62
Figure 45: DC motor system electricity consumption by end use application for the industrial sector	62
Figure 46: DC motor system counts by end use application for the industrial sector	63
Figure 47: DC motor system annual electricity consumption by subsector in the commercial sector. Subsectors with no estimated DC motor system electricity consumption have been omitted. These are: EDU, FSA, FSE, LOD, MEM, MER, POS, REW, SER, and WAS.....	64
Figure 48: DC motor system counts in the commercial sector by subsector. Subsectors with no observed DC motor systems have been omitted. These are: EDU, FSA, FSE, LOD, MEM, MER, POS, REW, SER, and WAS.....	65
Figure 49: DC motor system electricity consumption by end use application for the commercial sector	66
Figure 50: DC motor system counts by end use application for the commercial sector	66
Figure 51: Age of industrial motor systems broken down by size. Compared to Figure 4, UTC in this figure includes UTC, illegible nameplates, and some nameplates that were legible but the age still could not be determined.	67
Figure 52: Age of commercial motor systems broken down by size.....	68

Figure 53: Industrial motor load factors in terms of industrial sector motor system annual electricity consumption	74
Figure 54: Motor load factor for industrial sector motor systems (number of units)	76
Figure 55: Average motor load factor for industrial sector motor systems by size	78
Figure 56: Motor load factors for commercial sector motor system annual electricity consumption	79
Figure 57: Motor load factor for commercial sector motor systems (number of units)	81
Figure 58: Average motor load factor for commercial sector motor systems by size	83
Figure 59: Penetration rates of VFDs and other load control technologies by industrial subsector. See Figure 12 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%..	85
Figure 60: Penetration rates of VFDs and other load control technologies by industrial facility size	86
Figure 61: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of industrial motor system annual electricity consumption. See Figure 12 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%.....	87
Figure 62: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of industrial motor system counts. See Figure 12 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%.	88
Figure 63: Penetration rates of VFDs and other control technologies by equipment type in terms of industrial motor system electricity consumption	89
Figure 64: Penetration rates of VFDs and other control technologies by equipment type in terms of industrial motor system counts	90
Figure 65: VFD control feedback for industrial air compressors, fans, pumps, and refrigeration compressors as a percentage of system counts	91
Figure 66: Penetration rates of VFDs and other load control technologies by commercial subsector. See Figure 17 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%.	92
Figure 67: Penetration rates of VFDs and other load control technologies by commercial facility size. Annotations show the corresponding percent for each segment for shares greater than 5%.	93
Figure 68: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of commercial sector motor system electricity consumption. Annotations show the corresponding percent for each segment for shares greater than 5%.....	94
Figure 69: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of commercial motor system count. Annotations show the corresponding percent for each segment for shares greater than 5%.	94
Figure 70: Penetration rates of VFDs and other control technologies by equipment type in terms of commercial sector motor system electricity consumption. Annotations show the corresponding percent for each segment for shares greater than 5%.....	96
Figure 71: Penetration rates of VFDs and other control technologies by equipment type in terms of commercial motor system counts. Annotations show the corresponding percent for each segment for shares greater than 5%.	97

Figure 72: VFD control feedback for commercial air compressors, fans, pumps, and refrigeration compressor	98
Figure 73: Transmission type for industrial motor systems by electricity consumption (l) and counts (r)	99
Figure 74: Breakdown of transmission type by driven equipment in the industrial sector. Breakdowns are provided for % of counts and % of electricity consumption. From top left clockwise: refrigeration compressors, materials processing, air compressors, fans/blowers, materials handling, and pumps.....	100
Figure 75: Transmission type for commercial motor systems by electricity consumption (l) and counts (r)	101
Figure 76: Breakdown of transmission type by driven equipment in the commercial sector. Breakdowns are provided for % of counts and % of electricity consumption. From top left clockwise: refrigeration compressors, materials processing, air compressors, fans/blowers, materials handling, and pumps.....	102
Figure 77: Consideration of energy efficiency in procurement of industrial motor and related system components. Annotations show the corresponding percent for each segment for shares greater than 5%.	103
Figure 78: Consideration of energy efficiency in design of industrial motor and related system components new capital projects. Annotations show the corresponding percent for each segment for shares greater than 5%.	104
Figure 79: Consideration of energy efficiency in procurement of commercial motor and related system components. Annotations show the corresponding percent for each segment for shares greater than 5%.	104
Figure 80: Consideration of energy efficiency in the design of new commercial motor and related system component capital projects. Annotations show the corresponding percent for each segment for shares greater than 5%.	105
Figure 81: Title of person responsible for managing motor system energy	106
Figure 82: Distribution of annual unplanned system downtime due to motor system failure. See Figure 5 for guidance on interpreting box plots.....	110
Figure 83: Criteria used for motor repair/replace policy in industrial facilities, percent of facilities	111
Figure 84: Criteria for selecting size of replacement motor in industrial facilities, percent of facilities	111
Figure 85: Criteria used for motor repair/replace policy in commercial facilities	113
Figure 86: Criteria for selecting size of replacement motor in commercial facilities	114

List of Tables

Table 1: Stakeholders of this report and how they may use its contents	3
Table 2: Industrial subsector categorization used in MSMA.....	5
Table 3: Commercial building subsector categorization used in MSMA (based on CBECS)	5
Table 4: Planned industrial sector sample allocation.....	7
Table 5: Planned commercial sector sample allocation.....	8
Table 6: Industrial sample achieved by census region.....	10
Table 7: Commercial sample achieved by census region	11
Table 8: Example of motor to site weight calculation	12
Table 9: Example of site to national weight calculation.....	13
Table 10: Example of final combined weight calculation	13
Table 11: Annual motor system electricity consumption for the industrial subsectors and comparison to overall energy and electricity consumption.....	22
Table 12: Motor count and average motor sizes by industrial subsector.....	24
Table 13: Motor system annual electricity consumption for the commercial subsectors and comparison to overall energy and electricity consumption.....	30
Table 14: Total motor count and average motor sizes by commercial subsector	32
Table 15: Industrial motor system annual electricity consumption (GWh) by driven equipment and subsector.....	39
Table 16: Motor system counts (units) by driven equipment type for each industrial subsector .	43
Table 17: Commercial motor system annual electricity consumption (GWh) by driven equipment and subsector.....	48
Table 18: Motor system counts (units) by driven equipment type for each commercial subsector	53
Table 19: Industrial motor system annual electricity consumption and counts by size category.	58
Table 20: Commercial motor system annual electricity consumption and counts by category....	60
Table 21: Rank (high to low) of industrial subsectors by motor system annual electricity consumption as estimated in 2002 and 2020 MSMA	69
Table 22: Share of industrial motor driven equipment annual electricity consumption.....	70
Table 23: Comparison of shares of industrial motor system electricity consumption and counts between 2002 and 2020 MSMA.....	70
Table 24: Load factors for industrial sector motor system annual electricity consumption (GWh) by size range and driven equipment type.....	75
Table 25: Load factor for industrial sector motor systems units by size range and driven equipment type	77
Table 26: Load factors for commercial sector motor system electricity consumption by size range and driven equipment type	80
Table 27: Load factors for commercial sector motor systems units by size range and driven equipment type	82
Table 28: Load control technology types surveyed and the categorization used in this report	84
Table 29: Location where motor system decisions are made (percentage of facilities)	105
Table 30: Methods for identifying energy efficiency measures, percent of facilities	107
Table 31: Existence of motor system inventories, percent of facilities	108
Table 32: Annual unplanned system downtime due to motor system failure.....	109
Table 33: Most common motor maintenance procedures in industrial facilities.....	112

Table 34: Industrial motor maintenance procedures over the last two years by size range.....	112
Table 35: Maintenance history of industrial motor systems by driven equipment.....	113
Table 36: Most common motor maintenance procedures in commercial facilities.....	114
Table 37: Commercial motor maintenance procedures over the last two years by size range ...	115
Table 38: Maintenance history of commercial motor systems by driven equipment.	115
Table 39: Size cut points by subsector.....	2
Table 40: Targeted and achieved sample allocations by subsector and size bin, for the industrial subsector.....	5
Table 41: Targeted and achieved sample allocations by subsector and size bin, for the commercial subsector.....	6
Table 42: Industrial sample achieved by census region.....	8
Table 43: Commercial sample achieved by census region	9
Table 44: Data sources used	12
Table 45: Example preliminary motor to site weight	2
Table 46: Example site to national weight calculation (commercial office subsector)	3
Table 47: Example combined motor to site weight calculation.....	4
Table 48: Example combined motor to national weight calculations.....	5
Table 49: Imputation for unobserved industrial site consumption	14
Table 50: Imputation for unobserved commercial site consumption.....	15
Table 51: Imputation for unobserved industrial motors	17
Table 52: Imputation for unobserved commercial motors.....	18
Table 53: Number of motors relative to site level energy consumption in MWh ratio results and 90% confidence interval (CI) by subsector.....	20
Table 54: Magnitude number of motors results and 90% confidence interval (CI) by subsector	20
Table 55: Industrial cumulative motor MWh consumption relative to site level energy consumption in MWh ratio results and 90% confidence interval (CI) by subsector	20
Table 56: Industrial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector.....	20
Table 57: Industrial number of motors relative to site level energy consumption in MWh ratio results and 90% confidence interval (CI) by subsector.....	21
Table 58: Industrial magnitude number of motors results and 90% confidence interval (CI) by subsector.....	22
Table 59: Industrial cumulative motor MWh consumption relative to site level energy consumption in MWh ratio results and 90% confidence interval (CI) by subsector	23
Table 60: Industrial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector.....	24
Table 61: Commercial number of motors relative to site level energy consumption in MWh ratio results and 90% confidence interval (CI) by subsector.....	25
Table 62: Commercial number of motors magnitude results and 90% confidence interval (CI) by subsector.....	26
Table 63: Commercial cumulative motor MWh consumption relative to site level energy consumption in MWh ratio results and 90% confidence interval (CI) by subsector	27
Table 64: Commercial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector	28
Table 65: Industrial magnitude number of motors results and 90% confidence interval (CI) by subsector.....	29

Table 66: Industrial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector.....	30
Table 67: Commercial number of motors magnitude results and 90% confidence interval (CI) by subsector.....	31
Table 68: Commercial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector	32
Table 69: Basic motor inventory.....	2
Table 70: Pump checklist.....	16
Table 71: Fan/blower checklist.....	20
Table 72: Compressed air checklist.....	24
Table 73: Refrigeration checklist.....	35
Table 74: Facility general motor practices questions	43

Background and Motivation

Motor systems are an integral part of our industrial and commercial facilities. They provide the motive force behind the fans, pumps, compressors, chillers, and conveyors in these facilities. Given their centrality to any facility's operations, they are a critical energy end use to understand, particularly when developing technologies and policies to meet sustainability goals, improve productivity, and enhance resilience.

In the late 1990s, the U.S. Department of Energy (DOE) conducted two seminal studies to better understand the installed stock and energy savings opportunities of industrial and commercial motor systems. In the industrial sector, *The United States Industrial Electric Motor Systems Market Opportunities Assessment* used primary data collected through onsite assessments and led to a greater understanding of the installed base of motor systems, their characteristics, and the opportunities for energy savings (U.S. Department of Energy, 2002). Notable findings included the following:

- Industrial motor systems consumed 679 billion kilowatt-hours (kWh) in 1994, representing 23 percent of U.S. electricity consumption.
- Cost-effective energy efficiency measures could result in 62-104 billion kWh of energy savings annually.
- Sixty-two percent of the energy savings potential was from fan, pump, and compressor end use equipment.
- Nearly half of motor system electricity consumption was attributable to approximately 3,500 facilities, or 1.5 percent of U.S. manufacturing facilities.

Opportunities for Energy Savings in the Residential and Commercial Sectors with High Efficiency Electric Motors provided an evaluation of the installed stock of motor driven equipment in U.S. commercial and residential buildings and opportunities for utilization of high efficiency motors and variable speed technologies (Arthur D. Little, 1999). Notable findings included the following:

- Commercial motor systems consumed 343 billion kWh in 1995, with refrigeration and space conditioning constituting 93 percent of the total.
- Cost-effective energy efficiency measures could result in 51 billion kWh of energy savings annually.

Due in no small part to these seminal studies, motor system technologies and usage characteristics have changed drastically since the late 1990s. Greater awareness of cost-effective strategies for reducing motor system electricity consumption have been developed and deployed. This includes several software tools, literature, and utility and government programs promoting energy efficiency improvements in motor driven systems. Additionally, several rounds of energy efficiency standards have been enacted, resulting in improved installed motor efficiency. The cost of variable speed drives has dropped substantially, and combined with utility rebate programs, has led to their greater adoption.

Further, since these results were published, the U.S. manufacturing sector has undergone a massive transformation. Due to global competition, some sectors have relocated operations overseas. Others have brought operations onshore to avail low cost and abundant natural gas. Additionally, automation and robotics have pervaded the entire sector.

Consequently, these two reports likely do not represent the current state of motor driven systems in U.S. industrial and commercial facilities. As cited in recent studies, the lack of current information on motor system electricity consumption and use characteristics limits the ability to conduct analysis on energy savings potential, develop technologies to address energy and productivity gaps, and develop programs to promote energy efficiency practices and technologies for motor systems (International Energy Agency, 2007; UNIDO, 2010; McKane and Hasanbeigi, 2011; Waide and Brunner, 2011). Specifically, the lack of information affects a range of stakeholders:

- Governments must rely on outdated information when setting research agendas, developing policies, and designing energy efficiency programs and offerings.
- Utilities and energy efficiency programs cannot identify the current market needs or potential impact when designing rebate and energy efficiency programs.
- Electric grid planners cannot identify motor system usage characteristics when developing plans to support the resilience of the electric grid.
- Manufacturers of motors, motor driven equipment, and drives are hampered when developing technologies to meet the needs of their market.
- Motor system end users are limited in their ability to identify energy saving opportunities within their own facilities because they do not have reliable benchmark information.

In response to the lack of current information and analysis on industrial and commercial motor systems, the DOE initiated an update to these two studies. Launched in 2016 and led by Lawrence Berkeley National Laboratory (LBNL), the Motor System Market Assessment (MSMA) provides an updated, more comprehensive assessment of the installed stock of motor systems in both the industrial and commercial sectors, a review of the supply chains supporting motor and drives in the U.S., and the performance improvement opportunity available from using best available technologies and maintenance and operation practices. The outcomes of the MSMA are documented in three *U.S. Industrial and Commercial Motor System Market Assessment* reports, with this report being the first listed:

1. *Volume 1: Characteristics of the Installed Base* (this report) documents the findings on the installed base of motor systems in the U.S. industrial and commercial sectors. Quantification of energy savings potential is not documented in this report but in Volume 3. A searchable website with the underlying information contained in this report is available at <https://motors.lbl.gov/inventory>. This website has been established to serve as a complement to this Volume 1 report and allows readers to create their own crosscuts and conduct their own analysis using the results from the Motor System Market Assessment.
2. *Volume 2: Advanced Motors and Drives Supply Chain Review* reviews the state of supply chains for motors and drives installed in U.S. industrial and commercial facilities, focusing on advanced motor and drive technologies and their constituent materials.

3. *Volume 3: Energy Savings Opportunity* analyzes the energy performance improvement opportunity for the installed base of U.S. industrial and commercial motor systems.

This report has been prepared as a reference for motor system stakeholders. It provides factual information as could be best determined by the assessment results and avoids speculating on any findings.

Table 1 summarizes the identified stakeholders of this report and how they may use it. This list of stakeholders is not intended to be comprehensive, and others likely exist.

Table 1: Stakeholders of this report and how they may use its contents

Stakeholder	Use of this Report
End users and sector trade associations	<ul style="list-style-type: none"> • Understand operational practices of their installed motor systems in the context of similar facilities
Motor and drive manufacturers, motor distributors, motor repair practitioners, and their trade organizations	<ul style="list-style-type: none"> • Understand the characteristics and needs of the existing installed motor base to direct development and marketing of motor offerings • Gain insight into existing motor repair/replace policies of facilities • Decision making processes around improving performance of their motor systems
Motor driven equipment manufacturers and their trade associations, distributors	<ul style="list-style-type: none"> • Understand the impact of motor and system efficiency on the performance and operation of their products • Identify underserved markets for existing products • Identify opportunities to develop new products to meet underserved and/or emerging customer needs
Electric utilities and their member organizations	<ul style="list-style-type: none"> • Understand the magnitude, operational patterns, and system characteristics of motor system electricity consumption
Energy efficiency program administrators and their member organizations	<ul style="list-style-type: none"> • Identify where to direct their programs to have greatest impact on motor system electricity consumption
Energy efficiency service providers, energy efficiency consultants, and purchasing agents for the end user	<ul style="list-style-type: none"> • Gain insight into characteristics of motors, drives, and motor driven systems in energy intensive industries and the commercial sector to assist them in targeting their interactions with customers
Regional, state, and national government	<ul style="list-style-type: none"> • Develop targeted information on which sectors, motor systems, and improvement measures offer the best opportunity for performance improvement with respect to energy savings, reliability, process optimization, productivity enhancement, and others
U.S. Department of Energy	<ul style="list-style-type: none"> • Inform the establishment of a program(s) targeted at motor end users to increase awareness of motors and motor driven systems with respect to: energy efficiency and cost savings opportunities; procurement and management procedures; and new, replacement, or repair decision making processes • Identify technologies and research needs to drive greater increases in U.S. motor and motor system efficiency • Support investments in research and initiatives to increase U.S. motor and motor system manufacturing competitiveness

Methodology

The methodology for the MSMA was detailed in Rao et al. (2016) and Rao, Sheaffer and Scheihing (2017). Complete details can be found in Appendices A through C. The methodology is summarized here.

Objectives

The MSMA was divided into two major tasks:

Task 1: Motor System Field Assessments: An assessment of the installed motor system base in the U.S. industrial and commercial sectors, including the electricity consumption, operational and maintenance practices, and their potential for greater energy efficiency

Task 2: Supply Chain Assessment: A study of the global supply chain for advanced motor and drive technologies

Task 1 was further broken into three components:

1. Develop a detailed profile of the stock of the motors and motor systems in U.S. commercial and industrial facilities.
2. Develop a profile of U.S. commercial and industrial motor and motor system purchase and maintenance practices.
3. Analyze the opportunities (by market segment) for improved energy efficiency and cost savings available through implementation of efficient motors, control technologies, system optimization, and new and future advanced motor and motor system designs.

This report details the findings from Task 1, components 1 and 2. Task 1 component 3 is detailed in Volume 3 and specifically addresses energy saving opportunities from motor systems in U.S. industrial and commercial facilities. Results from Task 2 are documented in Volume 2.

Scope

The MSMA covered all three-phase AC and DC motors greater than and including 1 horsepower (hp). Advanced motor technologies, such as synchronous reluctance and permanent magnet, were also included (as AC motors). Fractional horsepower motors (motors < 1 hp) were excluded because they are often embedded within components, and it would be difficult to assess their installed base comprehensively. Further, excluding these motors aligns with the scope of the previous assessment. The assessments encompassed the drive, motor, transmission, end use equipment, and distribution system (e.g., compressed air lines, water pipes). The types of end use equipment evaluated included: pumps, fans/blowers, air compressors, refrigeration compressors, materials handling, and materials conveying. Motor systems that utilize non-electric energy sources (e.g., fossil fuels) were not part of the assessment scope.

The industrial and commercial subsectors included in the assessment are summarized in Table 2 and Table 3, respectively. For subsector definitions, please refer to the Glossary section of this report. The industrial sector assessment followed the North American Industrial Classification System (NAICS). This allowed for simpler comparison to other data sources, such as the Energy

Information Administration’s (EIA) Manufacturing Energy Consumption Survey (MECS) (U.S. Energy Information Administration 2014). The commercial building assessment used the EIA’s Commercial Building Energy Consumption Survey (CBECS) building type categories (U.S. Energy Information Administration 2012). This was primarily done because many commercial buildings can include occupants from many different sectors (e.g., an office building could have tenants from a variety of vastly different NAICS codes). Based on the results of the previous Motor System Market Assessment and to ensure proper representation, the Primary Metals subsector was subdivided into Iron, Steel, and Ferroalloy products and all other activities when allocating samples. This is due to the large motor system electricity consumption for Iron and Steel manufacturing compared to the balance of the subsector based on the findings from the previous MSMA. Also, for the purposes of the MSMA, the Municipal Wastewater Treatment subsector only includes the treatment facility and does not include the supporting infrastructure that brings wastewater to the facility and safely discharges the treated effluent.

Table 2: Industrial subsector categorization used in the MSMA

Apparel	Leather and Allied Products	Primary Metals
Beverage and Tobacco Products	Machinery	Printing and Related Support
Chemicals	Miscellaneous	Textile Mills
Computer and Electronic Products	Municipal Wastewater Treatment	Textile Product Mills
Electrical Equipment and Appliances	Nonmetallic Mineral Products	Transportation Equipment
Fabricated Metal Products	Paper and Allied Products	Wood Products
Food Products	Petroleum and Coal Products	
Furniture and Related Products	Plastic and Rubber Products	

Table 3: Commercial building subsector categorization used in the MSMA (based on CBECS)

Education	Lodging (includes Nursing)	Public Order and Safety
Food Sales	Mercantile: Retail (other than mall)	Religious Worship
Food Services	Mercantile: Enclosed and Strip Malls	Service
Health Care: Inpatient	Office	Warehouse and Storage
Health Care: Outpatient	Public Assembly	Other and Vacant

To improve the readability of figures and data tables presented in this report, abbreviations and shortened names for the subsectors are used throughout. Please refer to the List of Acronyms and Abbreviations for these abbreviations.

The scope was limited to industrial establishments with six or more employees and commercial buildings with 1,000 square feet or more. These restrictions are consistent with the sites covered by the MECS and CBECS, respectively.

Sampling approach

Details on the sample allocation, roll-up of assessment results to the national level, and determination of confidence intervals can be found in Appendix A: Sampling Allocation and Appendix B: Weighting Description.

Planned sample allocation

Subsector (defined in Table 2 and Table 3) and facility size were used to develop a statistically representative sample of industrial and commercial facilities in the United States. This sample was used to guide the recruitment of facilities for the MSMA. The final allotment deviated from the planned sample, as described in the next section.

Specific definitions of small, medium, and large were developed for each subsector. For the industrial assessments, facilities were categorized into small, medium, and large size bins based on number of employees. The 2013 U.S. Census County Business Patterns (CBP) data provides number of establishments by employee size ranges. These were summed such that for each subsector the intention was to allot 25 percent, 50 percent, and 25 percent of the subsector's total employment respectively to the small, medium, and large size bins. Using a 25/50/25 split instead of 33/33/33 makes a more targeted definition of high with potentially somewhat lower variability and reduces the number of very small sites that will be included. Similar allocation criteria were adopted for commercial assessments using the floorspace data obtained from the 2012 CBECS.

The number of samples was allocated to the subsector-size bins based on their magnitude of the estimated motor system electricity consumption¹ and its variability across facilities within the subsector. The following aspects were considered in the final allocation:

- Optimal allocation to best characterize the subsector motor system electricity consumption with best possible precision
- Allocation proportional to estimated motor electricity consumption and the number of facilities in each subsector
- A minimum of seven assessments per subsector

The objective was to select facilities with probability proportional to its size and motor system electricity consumption. Larger facilities have a higher chance to be assessed, so that those facilities that account for the most motor system electricity consumption are intended to be better characterized, while those sites with the least motor system electricity consumption are assessed with lesser precision.

The standard deviation of motor system electricity consumption was estimated for each subsector based on the reported standard errors and sample sizes from the 2014 MECS and 2012 CBECS. Table 4 and Table 5 provide the targeted sample allocations by subsector and size bin for the industrial and commercial sectors, respectively.

¹ Estimated by multiplying the segment employment total by the estimated motor electricity consumption per employee from EIA 2010 MECS. See more details in Appendix A.

Table 4: Planned industrial sector sample allocation

Industrial Subsector	Sample Size			
	Subsector Total	Size 1 Small	Size 2 Medium	Size 3 Large
Food Products	20	4	9	7
Beverage and Tobacco Products	7	1	3	3
Textile Mills	7	1	2	4
Textile Product Mills	7	1	2	4
Apparel	7	1	4	2
Leather and Allied Products	7	2	4	1
Wood Products	7	1	3	3
Paper and Allied Products	20	2	8	10
Printing and Related Support	10	1	6	3
Petroleum and Coal Products	20	5	8	7
Chemicals	25	4	7	14
Plastic and Rubber Products	15	2	9	4
Nonmetallic Mineral Products	15	1	9	5
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	2	3	2
Primary Metals: Other	17	2	5	10
Fabricated Metal Products	20	4	7	9
Machinery	12	2	6	4
Computer and Electronic Products	18	3	8	7
Electrical Equipment and Appliances	7	1	2	4
Transportation Equipment	16	3	4	9
Furniture and Related Products	7	2	3	2
Miscellaneous	11	3	5	3
Municipal Water Facilities	9	3	3	3
Municipal Wastewater Facilities	9	3	3	3
Total	300	54	123	123

Table 5: Planned commercial sector sample allocation

Commercial Subsector	Sample Size			
	Subsector Total	Size 1 Small	Size 2 Medium	Size 3 Large
Education	13	1	4	8
Food Sales	7	1	3	3
Food Services	7	1	2	4
Health Care: Inpatient	7	1	2	4
Health Care: Outpatient	7	1	3	3
Lodging (includes Nursing)	7	1	3	3
Mercantile: Retail (other than mall)	11	1	6	4
Mercantile: Enclosed and Strip Malls	7	1	3	3
Office	20	6	9	5
Public Assembly	10	2	7	1
Public Order and Safety	7	1	3	3
Religious Worship	7	1	2	4
Service	7	1	3	3
Warehouse and Storage	17	2	7	8
Other (includes CBECS = Other, Laboratory) and Vacant	16	3	6	7
Total	150	24	63	63

Final sample allocations

Ultimately, 246 assessments were conducted in industrial facilities and 123 in commercial facilities. Due to challenges with recruiting facilities (more than 80 percent of facilities approached turned down the offer for an assessment), it was not possible to achieve the full desired sample. Further, a comprehensive directory and data on the geographic and size distribution of water facilities could not be obtained. As a result, this subsector was dropped from the scope of the MSMA. The calculation of the confidence intervals reflected the sample collected.

The final counts of assessments conducted for the industrial and commercial sectors are shown in Figure 1 and Figure 2, respectively.

Figure 1: Final sample allocation for industrial assessments. The numbers on the figures indicate the number of samples conducted within each facility size category per subsector. Size categories with no number had one sample completed.

Figure 2: Final sample allocation for commercial assessments. Consult the List of Acronyms and Abbreviations for the full name of each subsector. The numbers on the figures indicate the number of samples conducted within each facility size category per subsector. Size categories with no number had one sample completed.

As can be seen in Figure 1 and Figure 2, small facilities in some subsectors were not sampled at the rate specified in Table 4 and Table 5. For example, the assessment team was unable to gain access to any small facilities in the Electrical Equipment, Furniture, Miscellaneous, Printing,

Food Sales, and Religious Worship subsectors. This may lead to sample bias in these sectors, as relatively smaller motor systems may not have been comprehensively surveyed.

Geography was not used as an explicit sample allocation. Including geography along with subsector and size would have created sample allocations that were very small and difficult to fulfill. However, an overall target by census region was considered in the sample allocation of each subsector as an implicit stratum. Table 6 and Table 7 show the achieved sample distribution by subsector and census region, for the industrial and commercial sectors. The percent of samples allocated to each census region is also provided. For context, the 2013 County Business Patterns (which was used to allocate industrial sector samples) shows the distribution of manufacturing facilities (excluding wastewater) as: Midwest 29 percent, Northeast 18 percent, South 30 percent, and West 22 percent. Similarly, the 2012 CBECS (which was used for allocating commercial sector samples) shows the distribution of commercial facilities as: Northeast 14 percent, Midwest 22 percent, South 40 percent, and West 23 percent.

Table 6: Industrial sample achieved by census region

Subsector	Midwest	Northeast	South	West	Total
Apparel	0	1	1	5	7
Beverage/Tobacco	2	0	1	4	7
Chemical	3	0	13	2	18
Computer/Electronic	2	2	0	3	7
Electrical Equipment	1	0	4	1	6
Fabricated Metal	10	1	6	3	20
Food	6	0	6	5	17
Furniture	3	1	3	0	7
Leather	0	3	0	1	4
Machinery	4	1	2	1	8
Miscellaneous	1	3	7	1	12
Nonmetallic Mineral	2	0	0	6	8
Paper	3	2	6	2	13
Petroleum Refining	1	2	4	6	13
Plastic/Rubber	8	4	5	2	19
Primary Metal	14	1	4	2	21
Printing	4	2	0	1	7
Textile Mill	0	0	7	0	7
Textile Product	2	1	2	2	7
Transportation	8	1	4	1	14
Wastewater	4	0	4	2	10
Wood	1	1	2	4	8
Total	79	26	81	54	240*
% of Total	33%	11%	34%	23%	100%

*Six assessments were conducted in Puerto Rico, which is not part of a census region.

Table 7: Commercial sample achieved by census region

Subsector	Midwest	Northeast	South	West	Total
Education	2	5	2	2	11
Food Sales	2	4	1	0	7
Food Service	1	1	0	5	7
Health Care: Inpatient	1	1	3	2	7
Health Care: Outpatient	0	2	1	4	7
Lodging	1	2	2	2	7
Mercantile: Enclosed and Strip Malls	0	1	0	4	5
Mercantile: Retail (other than mall)	1	0	1	6	8
Office	2	2	9	3	16
Other	1	5	0	1	7
Public Assembly	3	3	0	3	9
Public Order and Safety	2	0	2	3	7
Religious Worship	1	1	1	4	7
Service	0	1	0	6	7
Warehouse and Storage	3	1	2	5	11
Total	20	29	24	50	123
% of Total	16%	24%	20%	41%	100%

Sample weighting and scaling

The assessment data were expanded to the national level to characterize the installed industrial and commercial motor system base. This was done by developing weights to estimate the population totals from the observed motor systems with the purpose of minimizing sampling biases. Specifically, three weights and one adjustment factor were developed to expand the survey assessment data at the motor system level to the national level. The framework for using the weight is shown in Figure 3.

Figure 3: Motor weights calculation flowchart

The three weights are quantity, motor group to site weight, and site to national weight:

- Quantity:** The quantity is associated with the number of motor systems within a site that are identical to an observed motor system with the same usage pattern. The quantity weight will scale a motor up from a single motor to a group of motors with the same usage pattern.
- Motor group to site weight:** This is the number of motor systems at the site represented by each assessed motor system. This weight helps to bring the motor system-specific estimates to the site-specific estimates. An example of this calculation can be found in Table 8. All motor systems in the 1-6 hp size bin were assessed, while only 25 motors of the 26 motors in the 6-21 hp size bin were assessed. The resulting weight for the 1-6 hp size bin is 1 and for the 6-21 hp size bin is 1.04 This can be interpreted to mean each of the 6-21 hp size bin motor systems represents 1.04 motor systems at this site.

Table 8: Example of motor to site weight calculation

Motor hp Size Bin	Estimated Total Motors	Total Observed Motors	Motor to Site Weight
1-6	29	29	1.00
6-21	26	25	1.04

- Site to national weight:** This is the number of sites in the full national population represented by each observed site. This weight can scale the site-specific estimates to the national level to obtain the preliminary subsector estimates. An example calculation is

shown in Table 9. The site to national weight can be calculated as the national estimated population of similar sites divided by the number of sampled sites in the same size and subsector category. For the sampled large sites indicated in Table 9, the site to national weight is 1,395.3.

Table 9: Example of site to national weight calculation

Size Category	Estimated Population of Sites	Number of Sampled Sites	Site to National Weight
Large	6,976	5	1,395.3
Medium	143,560	7	20,508.6
Small	861,836	4	215,459.1

In addition to the three weights, an adjustment factor was used to align the estimates to MECS and CBECS.

- **Adjustment factor:** To assure that the final subsector-specific national electricity consumption is consistent with the 2014 MECS and 2012 CBECS estimates, an adjustment factor was introduced for each subsector to scale the motor system electricity consumption estimates. It is calculated as the MECS/CBECS subsector electricity consumption divided by the sum of the weighted sample sites' total electricity consumption (using the site to national weights).

For each assessed motor, as illustrated by Table 10, the final combined weight can be obtained as follows:

Final Combined Motor to national weight = Quantity x Motor to site weight x Site to national weight x Adjustment factor

For the second motor record, the final combined weight is $2 \times 1.04 \times 1,395.3 \times 0.97 = 28,15.2$.

Table 10: Example of final combined weight calculation

Motor	Motor Size Bin	Quantity	Motor to Site Weight	Site to National Weight	Adjustment Factor	Final Motor to National Weight
1	6-21	1	1.04	1,395.3	0.97	1,407.6
2	6-21	2	1.04	1,395.3	0.97	2,815.2

No adjustments were made to the collected information to account for operating conditions (e.g., climate, production). It is expected that conditions like climate and production will affect a system's electricity consumption relative to a similar system operating under different conditions. For example, a motor drive system supporting space cooling in a Southern climate will consume more electricity over a year than a similar system in a Northern climate. However, since the goal of the assessment was to understand total electricity consumption of all motor systems rather than relative electricity consumption between systems, understanding these distinctions was not a primary priority. Further, information needed to make these types of adjustments would likely not be available for every facility assessed.

Assessment details

A description of the assessments can be found in Rao, Sheaffer and Scheihing (2017). A brief summary follows here.

A tablet-based software tool was designed and used to prompt survey questions and store responses. The responses to these questions formed the analytical basis for the MSMA. These questions and answer choices can be found in Appendix C: Field Assessment .

Field assessments were conducted from September 2016 through March 2019. Most of the 369 assessments were conducted over one day, with approximately 60 large industrial facilities requiring a two-day assessment. The field assessment team could directly observe approximately 100 unique motor systems in a day. If a facility had more than 100 motors, the assessment team assessed a statistically representative sample of motors. The assessment team determined the number, size, location, rough estimate of run hours, and driven equipment of motors using a combination of existing inventories and questions of facility staff. Motor systems embedded in other equipment (i.e., a cooling fan embedded in process heating equipment) were part of the scope of motors assessed. However, identifying the existence of these motor systems at a facility relied upon facility staff recalling their existence or their inclusion in an existing motor inventory. The information was populated in the tablet-based software which selected motors based on estimated electricity consumption by size and location. For example, if 20 percent of the estimated motor system electricity consumption fell into a bin of 50-100 hp within one location, then 20 percent of the motor systems selected for observation would be from this size range and location.

For duplicate motor systems, one motor system was sampled and used to represent the duplicate systems. For example, a building may have three identical heating, ventilation and air-conditioning (HVAC) systems that all have the same size, age, and maintenance history. In this case, one of the three motor systems would be selected for direct observation, and its information would be recorded as being applicable to all three. This allowed for the assessment team to potentially collect information on more than 100 motor systems during a single day assessment.

The assessment questions were broken into three categories:

1. General facility-level questions²
2. General motor system questions³
3. Motor system efficiency checklists for systems greater than 20 hp and 2,000 annual operating hours⁴

The general facility-level questions were used to determine characteristics of the facility related to operating motor systems. Questions included but were not limited to: annual energy and electricity consumption; policies related to designing, procuring, and maintaining motor systems; and policies related to identifying and implementing energy efficiency measures.

² See Appendix C: Field Assessment Questions, Table 74.

³ See Appendix C: Field Assessment Questions, Table 69.

⁴ See Appendix C: Field Assessment Questions, Table 70, Table 71, Table 72, and Table 73.

The general motor system questions were intended to gather basic technical specifications, operating characteristics, and purpose of the motor systems selected for observation. Nameplate information for all motor systems selected was gathered. Equipment specification, such as manufacturer, model, horsepower size, no load speed, number of poles, and more can be found on a motor's nameplate.⁵ Operational information such as operating hours, load factor, and load control method was also gathered. Contextual information was gathered as well, including the type of transmission and connected load, and the motor's purpose.

For a sampling of pump, fan/blower, compressed air, and refrigeration systems greater than 20 hp and operating more than 2,000 hours annually, an in-depth survey was conducted to gather more information on their installation and energy efficiency. Separate checklists were created for each type of driven equipment. The pump and fan/blower checklists were similar and gathered information on pump/fan/blower nameplate information, other pumps/fans/blowers operating in conjunction, methods of load control, and more. The compressed air and refrigeration system checklists were similar in that they considered the entire air/refrigerant system with the compressor(s) being part of the system. These checklists queried details regarding system settings, control parameters, equipment nameplate information (similar to motor nameplates, equipment nameplates provide equipment specifications such as maximum operational settings, manufacturer, model, etc.), and more.

Uncertainty assessment

The MSMA estimates were obtained based on a statistical sample of industrial and commercial facilities. As with any other statistical based analyses, these estimates have uncertainty due to the random sampling of sites and of motors within sites. The sampling errors are usually considered as random errors.⁶ The estimates are also subject to non-sampling error. The accumulation of sampling and non-sampling errors is equal to the difference between the estimate based on the sample and the real value of these estimates. Efforts were made to minimize the chance that non-sampling errors would occur that would systematically overestimate or underestimate the variable of interest.⁷ Only sampling errors can be estimated.

To quantify the uncertainty associated with the MSMA estimates, basic 90 percent confidence intervals were used to capture the random error due to the sampling process. The confidence interval is a window that brackets the point estimate and has a 90 percent chance of including the true value. More discussion about both the sampling and non-sampling errors can be found in Appendix B: Weighting Description.

⁵ For a description and guide to motor nameplate information, please see Chapter 3 of the DOE Advanced Manufacturing Office publication [Continuous Energy Improvement in Motor Driven Systems](#).

⁶ This means that these errors are equally likely to overstate or understate values of interest.

⁷ Errors that lead to systematic overestimates or underestimates contribute to bias, which cannot be identified nor quantified easily.

Findings

This section provides results from the MSMA pertaining to motor system electricity consumption and counts by overall, facility type (subsector and size), driven equipment, and motor size. It also details findings on DC motors. Findings are presented in two broad categories: Installed Base Characteristics and Operating Characteristics. Where relevant, comparisons to the previous assessment are made. Where a motor system characteristic was undeterminable, the abbreviation UTC (unable to collect) was used.

The primary and preferred method for determining many characteristics of the motor was to read its nameplate. In many cases, however, this was not possible because the nameplate was illegible. Figure 4 breaks down the legibility of the nameplates of the motors assessed. Legibility is defined as being able to read nameplate information. Illegible nameplates include those that are missing, scratched or weathered extensively, inaccessible, painted over, or otherwise unreadable. Over two-thirds of the commercial nameplates and nearly a half of the industrial nameplates were illegible.

Figure 4: Legibility of nameplates on motors assessed: commercial (L) and industrial (R)

In lieu of a legible nameplate, assessors used a secondary source of information, including querying the facility staff or estimating based on visual observation.

Many of the figures that show a characteristic on a “per facility” basis use box plots. Figure 5 explains how to read these figures. The solid horizontal line represents the median value, which is the value where half of all values in the set are higher and half are lower. The dashed line represents the average. The lower bound of the box shows the first quartile. Seventy-five percent of the values in the set are above this line. The upper bound of the box shows the third quartile. Twenty-five percent of the values in the set are above this line. The lower fence is the smallest observation within a 1.5 interquartile range (IQ) of the first quartile. The upper fence is the largest observation within a 1.5 IQ of the third quartile. Observations outside the fences are shown individually.

The box plot provides a quick indication of:

- How widely spread the bulk of the observations are (i.e., the height of the box)
- Whether the observations are distributed fairly symmetrically around the average (is the average close to the median?)
- Whether there are large numbers of extreme values far from the bulk of the data (observations outside the fences)

Figure 5: Guide to reading box plots

For total and average quantities, 90 percent confidence intervals are given in the text following the estimate as “(+/- X).” This notation indicates that the 90 percent confidence interval has a lower bound equal to the estimate minus X and an upper bound equal to the estimate plus X. Figures displaying total or average quantities show bars at the lower and upper limits of the confidence interval and a dot at the point estimate.

Installed base characteristics

This section summarizes findings characterizing the installed base of industrial and commercial motor systems greater than 1 hp. Specifically, it summarizes findings related to total electricity consumption and motor system counts by subsector, driven equipment, and system size range. Additionally, findings on run hours, DC motor penetration, and motor age are summarized. A summary of highlights for each of these topics is presented at the end of this section.

Overall industrial and commercial

The estimated annual electricity consumption for industrial and commercial three-phase and DC motor systems greater than or equal to 1 hp is 1,079 TWh/yr (+/- 36 TWh). This represents approximately 29 percent of the total electricity supply in the United States in 2018. The split between industrial and commercial motor systems is fairly even, particularly when considering the confidence intervals. Industrial motor systems consume 546,963 GWh annually (+/- 19,831 GWh), while commercial motor systems consume 532,024 GWh (+/- 29,719 GWh). The estimates of annual motor system electricity consumption can be found in Figure 6.

Figure 6: Estimates of total industrial and commercial motor system annual electricity consumption with 90 percent confidence intervals. Note that the upper and lower bounds of the confidence intervals for the commercial and industrial sectors will not sum to the national level due to the method used for their calculation. The averages do sum.

The total number of installed three-phase and DC motors greater than or equal to 1 hp in the industrial and commercial sectors is shown in Figure 7, and is estimated to be 52.5 million (+/-4.5 million). The breakdown between industrial and commercial is approximately 80 percent commercial and 20 percent industrial. It is estimated that there are 10.8 million (+/- 1.1 million) motors in the industrial sector and 41.7 million (+/-4.4 million) motors in the commercial sector.

Figure 7: Estimate of total industrial and commercial motor units with 90 percent confidence intervals. Note that the upper and lower bounds of the confidence intervals for the commercial and industrial sectors will not sum to the national level due to the method used for their calculation. The averages do sum.

As expected, based on the estimates of the annual motor system electricity consumption and counts, the average connected horsepower per facility for the industrial sector is much higher than it is for the commercial sector. The average connected horsepower per facility for the industrial sector is estimated to be 1,595. The median connected horsepower at an industrial facility is 366 hp. This implies that the chance of randomly selecting an industrial facility with more than 366 connected horsepower is equal to the chance of selecting one smaller. However, there is a large spread in the connected horsepower per facility, and larger facilities cause the average connected horsepower to be much higher than the median. For the commercial sector, the average connected horsepower per facility is estimated to be 89 hp/facility, with a median of

20 hp. The relationship between the median and average is similar to that of the industrial sector, however the difference is less pronounced. Figure 8 shows the average and distribution of connected horsepower per facility.

Figure 8: Distribution of facility total connected hp for the industrial and commercial sectors.
Please refer to Figure 5 for guidance on interpreting the box plots.

Industrial sector breakdown by facility type

Within the industrial sector, annual motor system electricity consumption varies among the different subsectors (Figure 9 and Table 11). The Chemical subsector had the highest estimated annual motor system electricity consumption (106,000 GWh/yr)—64 percent higher than the estimated annual motor system electricity consumption of the next highest subsector, Primary Metals. Table 11 provides the total motor system electricity consumption for each industrial subsector.

Figure 9: Total industrial motor system annual electricity consumption by subsector with 90 percent confidence intervals

The subsector motor system electricity consumption is compared to the overall energy and electricity consumption for the subsector in Table 11. While the Chemical subsector has the largest motor system electricity consumption, it is 10 percent of the subsector's overall energy consumption. Conversely, in subsectors like Textile Mills or Printing, where motor system electricity consumption is low in comparison to the other subsectors, it is more than one-third of the subsector's overall energy consumption. Framing the motor system electricity consumption in this manner provides insight into the relative importance of motor systems to a subsector.

Table 11: Annual motor system electricity consumption for the industrial subsectors and comparison to overall energy and electricity consumption

Subsector	Subsector annual total energy consumption* (GWh)	Subsector annual electricity consumption (GWh)	Motor system annual electricity consumption (GWh)	Electricity for motor systems (%)	Total energy for motor systems (%)
Apparel	1,465	803	419	52	29
Beverage/Tobacco	27,842	9,808	7,108	72	26
Chemical	1,033,658	134,327	105,699	79	10
Computer/Electronic	47,477	32,820	12,438	38	26
Electrical Equipment	20,808	11,764	7,800	66	38
Fabricated Metal	100,816	41,869	25,639	61	25
Food	326,480	72,331	47,585	66	15
Furniture	10,844	5,072	3,105	61	29
Leather	879	316	226	72	26
Machinery	48,063	23,424	16,040	68	33
Miscellaneous	16,705	8,466	5,643	67	34
Nonmetallic Mineral	242,369	37,498	26,322	70	11
Paper	612,516	56,017	45,026	80	7
Petroleum Refining	1,029,555	48,904	39,269	80	4
Plastic/Rubber	86,163	55,631	39,898	72	46
Primary Metals	493,530	127,040	63,917	50	13
Primary Metals: Iron & Steel	343,478	59,867	24,137	40	7
Primary Metals: All Others	150,052	67,173	39,780	59	27
Printing	26,083	14,219	9,669	68	37
Textile Mill	28,428	12,586	10,000	79	35
Textile Product	7,913	2,748	1,819	66	23
Transportation	93,196	45,185	31,847	70	34
Wastewater	N/A	30,200	27,897	92	N/A
Wood	112,539	21,308	19,592	92	17
Total	4,367,622	792,336	546,963	69	13

* denotes energy consumption excluding feedstocks

The estimated motor system count by subsector is shown in Figure 10. The Machinery subsector has the largest number of motor systems with nearly 2 million units, followed by the Chemical (1.3 million), Plastics and Rubber (1.1 million), Primary Metals (1.0 million), and Food (0.7 million) subsectors.

Figure 10: Motor counts by industrial subsector with 90 percent confidence intervals

This implies that the average motor size within the Chemicals (40 hp), Food (30 hp), and Paper (67 hp) subsectors is larger than the average size of motors in the Machinery (13 hp) and Plastic/Rubber (20 hp) subsectors. Motor counts and average motor size by industrial subsector is shown in Table 12.

Table 12: Motor count and average motor sizes by industrial subsector

Subsector	Motor Counts	Total hp	Avg hp
Apparel	28,242	315,935	11
Beverage/Tobacco	381,723	4,237,749	11
Chemical	1,287,307	51,146,960	40
Computer/Electronic	489,368	6,533,042	13
Electrical Equipment	103,339	2,487,782	24
Fabricated Metal	713,947	12,123,660	17
Food	743,691	22,282,070	30
Furniture	81,503	1,661,846	20
Leather	59,139	560,018	9
Machinery	1,971,632	25,232,570	13
Miscellaneous	194,775	4,205,412	22
Nonmetallic Mineral	357,484	18,515,220	52
Paper	308,165	20,638,730	67
Petroleum Refining	299,199	17,970,290	60
Plastic/Rubber	1,142,320	22,299,790	20
Primary Metal	1,031,109	36,787,780	36
Printing	497,586	4,958,638	10
Textile Mill	297,785	4,124,187	14
Textile Product	84,182	1,139,698	14
Transportation	468,066	19,915,280	43
Wastewater	100,599	8,159,426	81
Wood	191,363	7,612,345	40
Total	10,832,524	292,908,428	27

Figure 11 shows the share of motor system electricity consumption and counts for each industrial subsector with respect to the entire sector. Seventy-four percent of the motor system electricity consumption for the industrial sector is in the top eight subsectors (in order: Chemicals, Primary Metals, Food, Paper, Plastic/Rubber, Petroleum Refining, Transportation, and Wastewater). Sixty-four percent of the industrial motor system units are in the top six subsectors (in order: Machinery, Chemicals, Primary Metals, Plastics/Rubber, Food, and Fabricated Metals).

Figure 11: Share of industrial motor system counts (upper) and electricity consumption (lower) by industrial subsector. The Balance of Subsectors category includes: Apparel, Electrical Equipment, Furniture, Leather, Miscellaneous, and Textile Product.

The distribution of facility total connected horsepower is shown for each industrial subsector in Figure 12. This shows the magnitude of motor power capacity within each subsector. The information can be used to inform demand management activities. For many subsectors, it is not uncommon to have more than 1,000 hp of connected motor systems in a facility. However, due to the inability to access small facilities in some subsectors, the total connected horsepower per facility may be overestimated for some subsectors in Figure 12. Specifically, the total connected horsepower per facility for the Electrical Equipment, Furniture, Miscellaneous, and Printing subsectors may be smaller than observed and shown in the figure, since small facilities in these subsectors were not represented in the final sample allocation due to an inability to access these facilities.

Figure 12: Distribution of facility total connected hp by industrial subsector. Please refer to Figure 5 for guidance on interpreting the box plots.

Figure 13 provides the breakdown of total annual industrial motor system electricity consumption by facility size. Medium-size facilities accounted for half of the estimated industrial motor system electricity consumption, while small facilities accounted for 17 percent. Since the definition of medium was set so that 50 percent of all facilities fell into this category, the share of motor system electricity consumption in this size category can be expected. The findings show that small facilities consume a smaller share of motor system electricity consumption than their representation of facilities in the population, and large facilities consume more than their representation of facilities in the population.

Figure 14 shows the total industrial motor system counts by facility size. While small facilities only accounted for 17 percent of total annual industrial motor system electricity consumption, they accounted for 38 percent of the industrial motor system counts. Nevertheless, medium-size facilities accounted for the largest number of motor system units, with 48 percent of the sector's units. Small facilities house a larger share of the motor systems in the industrial sector than their representation of facilities in the population, whereas large facilities house less.

Commercial sector breakdown by facility type

The breakdown of motor system electricity consumption by commercial subsector is shown in Figure 15 (please refer to List of Acronyms and Abbreviations for acronym definitions). The Office subsector has the highest estimated annual motor system electricity consumption (93,334 GWh), followed by Education (76,338 GWh) and Lodging (59,189 GWh). Table 13 provides the total motor system electricity consumption for each commercial subsector.

Figure 13: Total industrial annual motor system electricity consumption by facility size

Figure 14: Total industrial motor system count by facility size

Figure 15: Total commercial motor system annual electricity consumption by subsector with 90 percent confidence intervals

Across the commercial sector, it is estimated that motor systems account for 34 percent of the sector's electricity consumption and 26 percent of its energy consumption (Table 13). This is quite different from the industrial sector, where motor consumption is estimated to be only 13 percent of the industrial sector's total energy consumption but 69 percent of its electricity consumption. Differences in the use of electricity between the two sectors help to explain this. Commercial buildings have many electrical end uses beyond motor systems (e.g., lighting, plug loads), and these loads are of similar magnitude to the motor system loads. The industrial sector has those same non-motor electric loads, but the electricity consumption for motor systems far outweighs those other loads.

Table 13: Motor system annual electricity consumption for the commercial subsectors and comparison to overall energy and electricity consumption

Subsector	Subsector total annual energy consumption (GWh)	Subsector total annual electricity consumption (GWh)	Annual motor system consumption (GWh)	Electricity for motor systems (%)	Total electricity for motor systems (%)
Education	246,766	134,000	76,339	57	31
Food Sales	76,785	61,000	23,643	39	31
Food Service	150,639	82,000	34,776	42	23
Health Care: Inpatient	160,896	74,000	34,759	47	22
Health Care: Outpatient	49,529	33,000	20,085	61	41
Lodging	165,292	89,000	59,189	67	36
Mercantile: Enclosed and Strip Malls	188,738	124,000	30,650	25	16
Mercantile: Retail (other than mall)	106,678	82,000	33,772	41	32
Office	363,701	253,000	93,334	37	26
Public Assembly	140,674	80,000	27,552	34	20
Public Order and Safety	38,978	21,000	11,817	56	30
Religious Worship	50,701	24,000	10,487	44	21
Service	79,715	37,000	6,893	19	9
Warehouse and Storage	125,727	83,000	40,054	48	32
Other and Vacant	95,834	64,000	28,673	45	30
Total	2,040,654	1,241,000	532,024	43	26

The Mercantile: Enclosed and Strip Malls subsector is estimated to have the largest number of motors of any commercial subsector, with 6.3 million units (Figure 16). In fact, the Mercantile: Enclosed and Strip Malls commercial subsector has more units than any of the industrial and commercial subsectors assessed. After the Mercantile: Enclosed and Strip Malls subsector, the Lodging (5.3 million) and Office (4.8 million) subsectors have the next highest estimated number of motor systems. The top eight commercial subsectors are all estimated to have more motors than the industrial subsector with the most estimated motors (Machinery, 2 million units).

Figure 16: Motor counts by commercial subsector with 90 percent confidence intervals

As shown in Table 14, the Health Care: Inpatient and the Public Assembly subsectors had the largest motors on average, at 29 hp. Compared to the industrial sector, the relatively small motor size (three subsectors have average motor sizes of 4 hp) is indicative of the typical use of motors. As will be shown in following section on Driven Equipment breakdown, HVAC systems are the largest application of motors in the commercial subsector. Additional implications of small motors are that: (1) the energy losses across the motor are larger than those for large motors, and (2) they are less likely to be repaired and more likely to be replaced upon failure.

Table 14: Total motor count and horsepower, and average motor horsepower by commercial subsector

Subsector	Motor Counts	Total hp	Avg hp
Education	3,303,261	35,969,080	11
Food sales	1,686,742	10,209,800	6
Food service	4,082,172	15,558,440	4
Health Care: Inpatient	612,586	17,590,590	29
Health Care: Outpatient	914,332	9,328,888	10
Lodging	5,340,744	22,246,690	4
Mercantile: Enclosed and Strip Malls	6,307,752	37,745,110	6
Mercantile: Retail (other than mall)	3,401,350	20,800,810	6
Office	4,762,177	58,371,190	12
Public assembly	542,034	17,580,970	32
Public order and safety	2,525,907	20,635,050	8
Religious worship	759,636	5,108,278	7
Service	1,941,057	18,530,660	10
Warehouse and storage	1,892,272	8,090,327	4
Other and Vacant	3,611,794	24,160,830	7
Total	41,683,816	321,926,713	8

The distribution of facility total connected horsepower is shown for each commercial subsector in Figure 17. This shows the magnitude of motor power capacity within each subsector. The information can be used to inform demand management activities. The Health Care: Inpatient subsector has the largest estimated connected horsepower. However, due to the inability to access small facilities in some subsectors, the total connected horsepower per facility may be overestimated for some subsectors in Figure 17. Specifically, the total connected horsepower per facility for the Food Sales and Religious Worship subsectors may be smaller than shown in the figure since small facilities in these subsectors were not represented in the final sample allocation due to an inability to access these facilities.

Figure 17: Distribution of facility total connected hp by commercial subsector. The inset graph rescales the data by removing the Health Care: Inpatient subsector, allowing for the values of other subsectors to be more readily read. Please refer to Figure 5 for guidance on interpreting the box plots.

Figure 18 shows the share of motor system electricity consumption and counts for each commercial subsector with respect to the entire sector. Seventy-one percent of the commercial sector's motor system electricity consumption resides in the top seven subsectors (in rank: Office, Education, Lodging, Warehouse and Storage, Food Service, Health Care: Inpatient, and Mercantile: Enclosed and Strip Malls). Seventy-four percent of the sector's motor systems can be found in the top seven subsectors (in rank, Mercantile: Enclosed and Strip Malls, Lodging, Office, Food Service, Warehouse and Storage, Education, and Mercantile: Retail).

Figure 18: Share of motor system counts (upper) and electricity consumption (lower) by commercial subsector

Commercial sector motor system electricity consumption is broken down by facility size in Figure 19. Medium-size facilities account for 52 percent of the sector's motor system electricity consumption, representing the largest share. This may be an artifact of the definition used in this report for medium, where 50 percent of facilities were classified as medium. Small facilities, which were defined to account for 25 percent of the facilities, account for 13 percent of the sector's motor system electricity consumption, whereas large facilities accounted for 35 percent. This indicates that small facilities account for less of the sector's motor system electricity

consumption than their share of facilities, and large facilities account for more motor system electricity consumption than their share of facilities.

Figure 19: Commercial sector motor system annual electricity consumption by facility size

Medium facilities account for 56 percent of the motor system units in the commercial sector, as shown in Figure 20. Small facilities account for 27 percent of the sector's motor system units.

Figure 20: Commercial sector motor system counts by facility size

Driven equipment breakdown

Motor system electricity consumption and counts were estimated by driven equipment type. The driven equipment types considered were air compressors, fans (includes blowers and vacuum pumps), materials handling, materials processing, pumps, refrigeration compressors, and other. Materials processing includes motor systems that use mechanical means to process materials. Examples include grinders, hydraulics, and extruder motors. Materials handling includes motor systems that transport materials, such as conveyor motors. Materials processing and handling are not commonly considered typical commercial applications. Examples of materials processing motors in the commercial sector include trash compactors, shredders, and other equipment that changes the form of a material. Examples of materials handling motors in the commercial sector include elevator, escalator, and conveyor belt motors. Findings by driven equipment are presented below, separated between the industrial and commercial sectors.

Industrial sector

Figure 21 provides the breakdown of motor system electricity consumption by driven equipment for the industrial sector. Materials processing consumes the largest share of motor system electricity, followed by pumps and fans/blowers. Air compressors and refrigeration compressors round out the top five.

Figure 21: Industrial motor system annual electricity consumption by driven equipment. UTC indicates that the equipment driven by the motor could not be identified.

Figure 22 provides the share of industrial motor system electricity consumption by driven equipment. Twenty-nine percent of the motor system load in the industrial sector is for materials processing. This is followed by fans/blowers and pumps, both at 21 percent. Figure 22 also provides further insight into the technology type for each driven equipment category. This type of information can provide insights into electrical characteristics, such as start-up loads. It can also provide insight into load control options. For example, 81 percent of all pumping loads are rotodynamic pumps, and the remaining 19 percent are positive displacement.

Figure 22: Share of motor system electricity consumption by driven equipment and technology type for the industrial sector

Table 15 provides the breakdown of industrial motor system electricity consumption by driven equipment and subsector. For 10 of the 22 subsectors, materials processing owns the largest share of the subsector's motor system electricity consumption. Fan/blower systems are the leading form of motor system electricity consumption for six of the subsectors. Pump system electricity consumption leads for three subsectors and refrigeration compression for two. The driven equipment with the largest share of a subsector's motor system electricity consumption follows the type of processes occurring in that subsector. For example, refrigeration compressors own the largest share of motor system electricity consumption in the Food subsector, where cold-storing raw and finished food product and cooling products are major processes. Similarly, pumping electricity consumption leads in the Municipal Wastewater subsector, where pumping wastewater through the various treatment processes is a major operation.

Table 15: Industrial motor system annual electricity consumption (GWh) by driven equipment and subsector. Total may differ slightly from sum of rows due to independence of calculation methods

	Air Compressors	Fan/ Blower	Material Handling	Material Processing	Pump	Refrigeration Compressors	Other and UTC	Total
Apparel	116	149	-	29	38	84	3	419
Beverage/Tobacco	1,193	1,689	524	168	1,499	1,779	256	7,108
Chemical	9,669	17,431	2,507	30,157	27,021	17,908	1,008	105,699
Computer/Electronic	1,621	3,004	60	960	3,297	3,067	428	12,438
Electrical Equipment	572	2,383	18	374	2,125	2,180	147	7,800
Fabricated Metal	4,543	4,820	777	7,032	1,108	5,247	2,112	25,639
Food	6,788	6,296	1,051	4,137	9,164	19,506	644	47,585
Furniture	399	1,084	369	516	529	205	3	3,105
Leather	40	54	3	113	15	2	-	226
Machinery	4,391	1,996	238	6,273	737	1,514	891	16,040
Miscellaneous	976	1,234	62	1,490	457	1,170	254	5,643
Nonmetallic Mineral	8,254	8,267	2,165	3,220	3,399	990	28	26,322
Paper	1,231	7,831	4,600	19,253	11,702	375	34	45,026
Petroleum Refining	3,002	4,437	2,596	9,030	16,470	410	3,325	39,269
Plastic/Rubber	3,220	9,212	1,281	20,238	2,410	3,293	244	39,898
Primary Metals	6,135	16,106	1,409	28,076	6,985	5,051	155	63,917
Primary Metals: Iron and Steel	2,541	7,108	720	8,747	4,764	258	-	24,137
Primary Metals: Other	3,595	8,998	689	19,329	2,221	4,793	155	39,780
Printing	987	3,195	716	1,991	321	2,460	-	9,669
Textile Mills	1,117	3,716	113	1,722	2,193	624	516	10,000
Textile Product	387	347	117	813	12	144	-	1,819
Transportation	5,563	8,107	133	8,355	7,647	1,970	71	31,847
Wastewater	2,320	4,868	74	3,022	17,357	7	251	27,898
Wood	1,092	6,715	1,185	8,818	1,382	23	379	19,592
Total	63,613	112,942	19,998	155,783	115,868	68,007	10,752	546,963

Figure 23 shows a breakdown of industrial motor units by driven equipment. As with the breakdown of motor system electricity consumption, materials processing has the most motor units. It is followed by fans/blowers and pumps. Comparing Figure 21 and Figure 23, air compressors have a larger share of sector electricity consumption than motor counts, indicating that air compressors tend to be larger in size than the other driven equipment.

Figure 23: Breakdown of industrial motor counts by driven equipment

Figure 24 shows the percent of units for each type of driven equipment, further breaking down the driven equipment by technology type. Materials processing and fans/blowers hold the largest share of motor system units in the industrial sector. Combined, these two equipment types constitute 61 percent of the motor systems in the industrial sector. Nearly half (47 percent) of all industrial motor systems are for materials processing or handling.

Figure 24: Share of motor system units by driven equipment and technology type for the industrial sector

Both Figure 22 and Figure 24 show that the share of materials handling motor systems (12 percent) is outsized compared to their share of motor system electricity consumption (4 percent). This implies that the materials handling motor systems are small, operate at fewer hours, and/or are lightly loaded relative to the other types of driven equipment. Figure 25 and Figure 26 confirms that materials handling motor systems are both smaller and operate for fewer hours. Figure 25 shows the distribution of size for each driven equipment type, and Figure 26 shows the distribution of annual operating hours for each driven equipment type. As will be seen later, the majority of materials handling motor systems operate at load factors greater than 75 percent and therefore are not more lightly loaded than motor systems used in other driven equipment. On the other end of the spectrum, fan/blower systems generally have smaller motors and higher run hours. The long run hours, combined with the relatively high number of units, lead to relatively high fan/blower motor system electricity consumption compared to other types of driven equipment.

Figure 25: Distribution of driven equipment size within the industrial sector. Please refer to Figure 5 for guidance on interpreting box plots.

Figure 26: Distribution of annual run hours by driven equipment for the industrial sector, Please refer to Figure 5 for guidance on interpreting box plots.

Table 16 provides the breakdown of units by driven equipment type and subsector. For 11 of the 22 subsectors, materials processing owns the largest share of motor system units. For nine subsectors, fans and blowers are the largest share.

Table 16: Motor system counts (units) by driven equipment type for each industrial subsector. Total may differ slightly from sum of rows due to independence of calculation methods

	Air Compressors	Fan/ Blower	Material Handling	Material Processing	Pump	Refrigeration Compressors	Other and UTC	Total
Apparel	1,156	12,848	-	3,877	2,646	6,496	1,219	28,242
Beverage/Tobacco	7,793	43,186	204,211	6,764	56,224	12,383	51,162	381,723
Chemical	34,528	440,304	123,305	214,953	343,489	25,287	105,441	1,287,307
Computer/Electronic	12,170	234,708	22,294	101,187	75,833	24,659	18,517	489,368
Electrical Equipment	1,745	36,803	3,215	7,486	37,451	15,237	1,401	103,339
Fabricated Metal	21,232	156,971	153,592	212,242	25,402	89,299	55,208	713,947
Food	37,394	198,810	120,243	96,569	144,975	90,971	54,729	743,691
Furniture	2,191	25,710	15,632	23,690	9,097	3,778	1,404	81,503
Leather	4,224	14,785	4,224	29,992	4,224	1,690	-	59,139
Machinery	64,418	169,796	57,995	1,460,250	86,373	111,925	20,875	1,971,632
Miscellaneous	4,476	67,223	8,504	70,926	22,480	17,655	3,511	194,775
Nonmetallic Mineral	31,727	157,061	38,636	70,626	57,084	2,277	73	357,484
Paper	3,032	60,601	60,350	92,932	87,324	2,610	1,316	308,165
Petroleum refining	5,164	35,328	52,209	41,380	105,587	522	59,010	299,199
Plastic/Rubber	26,164	375,448	106,145	393,780	100,153	62,683	77,947	1,142,320
Primary Metals	25,458	256,968	121,397	451,165	97,891	75,694	2,536	1,031,109
Primary Metals: Iron and Steel	5,920	64,269	50,898	81,157	36,188	14,977	-	253,409
Primary Metals: Other	19,538	192,699	70,499	370,008	61,702	60,717	2,536	777,699
Printing	13,243	200,422	53,311	107,850	18,440	104,113	206	497,586
Textile Mills	3,598	92,183	4,396	87,946	56,602	6,991	46,069	297,785
Textile Product	4,499	29,338	17,432	20,956	904	11,053	-	84,182
Transportation	11,525	153,905	17,433	117,409	140,555	27,065	174	468,066
Wastewater	2,028	12,133	7,876	23,095	52,771	270	2,427	100,599
Wood	8,670	26,245	60,925	60,428	24,118	448	10,529	191,363
Total	326,435	2,800,778	1,253,326	3,695,502	1,549,623	693,105	513,754	10,832,523

To examine motor system electricity consumption by application even further, Figure 27 provides the breakdown of motor system electricity consumption by process type. The intention is to provide insights into why industrial facilities use a motor system. The largest identified loads are for air handling. This indicates that the need to ventilate (for both space conditioning and emissions removal) is a significant use of motor systems, accounting for about 20 percent of industrial motor system electricity consumption. The next largest process types are refrigeration/chiller plant (process cooling) and compressed air plant (compressed air for providing force).

Figure 27: Industrial motor system annual electricity consumption by process type

Figure 28 shows the breakdown of industrial motor system units by process type. Here, the use of motor systems for ventilation and conditioning is pronounced. Air handling is the dominant process type in terms of motor system units, accounting for about 27 percent of all industrial motor units.

Figure 28: Industrial motor system counts by process type

Commercial sector

Figure 29 provides the breakdown of motor system electricity consumption by driven equipment for the commercial sector. Refrigeration compressors and fans/blowers are the dominant types of driven equipment in terms of electricity consumption. They are followed by pumps. The electricity consumption for the remaining driven equipment types are one (one-tenth) to two (one one-hundredth) orders of magnitude less than the electricity consumption for fans/blowers or refrigeration compressors.

Figure 29: Commercial motor system annual electricity consumption by driven equipment

Figure 30 provides the share of commercial motor system electricity consumption by driven equipment. Forty-eight percent of the motor system load in the commercial sector is for refrigeration compressors. This is followed by fans and blowers at 36 percent of the sector’s motor system electricity consumption. Pumps are third, and when combined with these two driven equipment types, account for 94 percent of commercial sector motor system electricity consumption. Figure 30 provides further insight into the technology type for each driven equipment category. This type of information can provide insights into electrical characteristics, such as start-up loads. It also can provide insight into load control options. Nearly 100 percent of all commercial sector motor system electricity consumption utilizes technologies that can benefit from variable frequency drives, if not already using one.

Figure 30: Share of motor system electricity consumption by driven equipment and technology type for the commercial sector

Table 17 provides the numeric estimates of the breakdown of commercial motor system electricity consumption by driven equipment and subsector. For nine of the fifteen subsectors, refrigeration systems account for the largest share of the commercial sector’s motor system electricity consumption. Fan and blower systems are the leading form of motor system electricity consumption for five of the subsectors. This result provides insight into the major uses of motor systems in the commercial sector: space cooling and ventilation.

Table 17: Commercial motor system annual electricity consumption (GWh) by driven equipment and subsector. Total may differ slightly from sum of rows due to independence of calculation methods

	Air Compressors	Fan/ Blower	Materials Handling	Materials Processing	Pump	Refrigeration Compressors	Other and UTC	Total
EDU	1,076	45,620	4	2	6,625	23,012	-	76,339
FSA	-	5,224	-	-	729	17,689	-	23,643
FSE	-	9,334	-	-	2,001	23,442	-	34,776
HCI	1,643	9,323	113	183	8,291	11,775	3,431	34,759
HCO	42	13,312	-	-	1,434	4,469	829	20,085
LOD	47	9,911	-	1,123	6,642	41,345	122	59,189
MEM	13	17,847	-	-	5,262	10,650	-	33,772
MER	71	5,232	183	-	-	25,164	-	30,650
OFF	317	34,072	237	-	7,024	44,032	7,653	93,335
OTH	3,385	7,804	-	154	10,059	7,270	-	28,673
PAS	853	14,985	-	-	2,395	9,320	-	27,552
POS	638	7,351	35	-	882	2,830	80	11,817
REW	-	3,621	-	-	603	6,263	-	10,487
SER	3,077	92	-	87	263	3,373	-	6,893
WAS	1,403	8,357	8,711	-	695	20,888	-	40,054
Total	12,564	192,085	9,282	1,549	52,907	251,522	12,115	532,024

Figure 31 shows the breakdown of commercial motor units by driven equipment. As with the breakdown of electricity consumption, refrigeration compressors and fans/blowers account for the most motor units.

Figure 31: Breakdown of commercial motor counts by driven equipment

Figure 32 shows the percent of units for each type of driven equipment. Figure 32 further breaks down the type of driven equipment by technology type. Similar to the breakdown of electricity consumption, refrigeration compressors and fans and blowers hold the largest share of motor system units in the commercial sector. Combined, these two equipment types account for 86 percent of the motor systems in the commercial sector.

Figure 32: Share of motor system units by driven equipment and technology type for the commercial sector

Figure 33 shows the distribution of size of driven equipment, and Figure 34 shows the distribution of annual operating hours for each driven equipment type in the commercial sector. It is important to view these figures along with the count of motor systems. Although the average horsepower for the “other” category is the largest, and the third quartile for materials handling is nearly the largest, these equipment types have very few motor counts. The average size of fan/blower and air compressor units is small, at 5 hp and 7 hp, respectively.

Table 18 provides the numeric values of the breakdown of units by driven equipment type and subsector. Refrigeration compressors and fans/blowers each account for the largest share of driven equipment for seven subsectors. Most subsectors do not have any materials handling. While materials processing is only 3 percent of the commercial sector motor system units, it accounts for 41 percent of the motor system units in the Service subsector. This subsector includes building types like gas stations, car washes, and repair shops. These types of activities require lift, hydraulic, and other process applications. Although looking at the breakdown of consumption and counts by driven equipment across a whole sector provides a high-level snapshot, one must be careful when applying sector-wide trends to a specific subsector, as is evident when considering the Service subsector.

Figure 33: Distribution of driven equipment size within the commercial sector. See Figure 5 for guidance on interpreting the box plots.

Figure 34: Distribution of annual run hours by driven equipment for the commercial sector. See Figure 5 for guidance on interpreting the box plots.

Table 18: Motor system counts (units) by driven equipment type for each commercial subsector. Total may differ slightly from sum of rows due to independence of calculation methods

	Air Compressors	Fan/ Blower	Materials Handling	Materials Processing	Pump	Refrigeration Compressors	Other and UTC	Total
EDU	96,844	1,847,491	719	719	407,643	949,846	-	3,303,261
FSA	-	559,426	-	-	35,265	1,092,050	-	1,686,742
FSE	-	1,336,548	-	-	79,799	2,665,825	-	4,082,172
HCI	61,410	233,120	8,270	9,062	155,922	30,508	114,295	612,586
HCO	10,871	529,662	-	-	104,203	257,706	11,889	914,332
LOD	1,463	870,411	-	248,596	173,750	4,013,692	32,833	5,340,744
MEM	6,347	4,841,689	-	-	95,205	1,364,512	-	6,307,752
MER	125,294	1,094,885	13,107	-	-	2,168,064	-	3,401,350
OFF	71,700	1,850,095	48,024	-	580,288	1,999,281	212,790	4,762,177
OTH	12,028	267,009	-	2,297	108,608	152,092	-	542,034
PAS	18,146	1,085,577	-	-	206,388	1,215,796	-	2,525,907
POS	47,592	408,724	17,539	-	61,766	101,244	122,771	759,636
REW	-	785,638	-	-	178,844	976,576	-	1,941,057
SER	529,625	155,152	-	774,325	32,599	400,571	-	1,892,272
WAS	448,721	1,270,074	610,804	1,868	30,026	1,250,302	-	3,611,794
Total	1,430,041	17,135,499	698,462	1,036,867	2,250,304	18,638,065	494,577	41,683,816

To examine motor system electricity consumption by use even further, Figure 35 shows the breakdown of commercial sector motor system electricity consumption by process type. The intention is to provide insights into why commercial facilities need to use a motor system. Eighty-six percent of all commercial motor system electricity consumption is for air handling, space cooling, and refrigeration/chiller plants.

Figure 35: Commercial sector motor system annual electricity consumption by process type

Figure 36 breaks down commercial sector motor system units by process type. Similar to the breakdown of electricity consumption, the large majority of commercial sector motor systems, about 91 percent, are for HVAC systems (air handling, refrigeration/chiller plant, and space cooling).

Figure 36: Commercial motor system counts by process type

Motor system size breakdown

Motor system electricity consumption and count were broken down by motor size category. Size categories are (in hp): 1-5, 6-20, 21-50, 51-100, 101-200, 201-500, 501-1,000, 1,001-2,000, 2,001-5,000, and 5,001+.

Industrial sector

Figure 37 shows industrial motor system annual electricity consumption by motor size category. Eighty-two percent of the electricity consumption is in the 6-1,000 hp size range, with 71 percent in the 6-500 hp size range. Combined with the 1-5 hp range (comprising 5 percent of industrial electricity consumption) this is a notable size range because it has been used in the past as a demarcation for motor energy efficiency regulations. Very large motors (>1,000 hp) account for 13 percent of the industrial motor system electricity consumption.

Figure 37: Industrial motor system annual electricity consumption by size category

The distribution of industrial motor system counts (Figure 38) is very different than the distribution of industrial motor system electricity consumption. Nearly half (49 percent) of the motor systems are 1-5 hp, but these only account for 5 percent of the electricity consumption. Ninety-nine percent of all motor system units are under 500 hp, and less than 0.2 percent are greater than 1,000 hp.

Figure 38: Industrial motor system count by size category

The estimates underlying Figure 37 and Figure 38 are shown in Table 19.

Table 19: Industrial motor system annual electricity consumption and counts by size category

Horsepower	Consumption (GWh)	Counts (thousands)
1-5	26,751	5,331
6-20	68,033	3,052
21-50	87,604	1,421
51-100	71,917	621
101-200	64,486	203
201-500	94,842	144
501-1,000	63,466	45
1,001-2,000	34,943	10
2,001-5,000	17,555	3
5,001+	17,290	1
Total	546,887	10,832

The Chemicals subsector owns the largest share of industrial motor system annual electricity consumption and counts for motors greater than 1,000 hp, with 28 percent and 25 percent, respectively. The Paper subsector owns the second largest share, with 21 percent and 20 percent, respectively.

Figure 39 shows the estimated annual run hours for industrial motor systems by size category. The run hours do not vary significantly across size categories. The exception is the 1,001-2,000 hp category, where the 25 percent quartile is nearly as high as the 75 percent quartile for the other size categories. The relatively small number of motor systems in this size category could be skewing the data.

Figure 39: Distribution of annual run hours for industrial motor systems by size category.
See Figure 5 for guidance on interpreting the box plots.

Commercial sector

Commercial motor system electricity consumption by motor size category is shown in Figure 40. The majority of the electricity consumption is in the 1-50 hp size range (80 percent). Specifically, 36 percent of the motor system electricity consumption is in the 6-20 hp size range. Small motors (1-5 hp) account for 22 percent of the sector's motor system electricity consumption. Very large motors (>1,000 hp) are not a major source of motor system electricity consumption, only accounting for 2 percent.

Figure 40: Commercial motor system annual electricity consumption by size category

The distribution of commercial motor system units by size category (shown in Figure 41) is similar to the distribution of the sector's motor system electricity consumption by size category. Both are skewed toward smaller motors. A major difference is that the peak size category is 6-20 hp for electricity consumption but 1-5 hp for counts. Sixty-six percent of commercial motor system units fall in the 1-5 hp category, followed by 28 percent in the 6-20 hp category. Ninety-nine percent of commercial motor systems greater than 1 hp are under 50 hp.

Figure 41: Commercial motor system counts by size category

The estimates underlying Figure 40 and Figure 41 are shown in Table 20.

Table 20: Commercial motor system annual electricity consumption and counts by category

Horsepower	Consumption (GWh)	Counts (thousands)
1-5	117,820	27,629
6-20	193,511	11,591
21-50	113,809	2,040
51-100	26,885	222
101-200	21,666	116
201-500	24,721	56
501-1,000	24,505	26
1,001-2,000	6,654	3
2,001-5,000	2,417	1
5,001+	-	-
Total	531,988	41,684

The annual run hours for commercial motor systems by size category is shown in Figure 42. Across horsepower size categories, the average is generally between 2,100 hr and 3,700 hr, and the median is between 2,100 hr and 3,500 hr.

Figure 42: Distribution of annual run hours for commercial motor systems by size category.
See Figure 5 for guidance on interpreting the box plots.

DC motor system demographics

It is estimated that there are 806,000 DC motor systems greater than or equal to 1 hp consuming 31,000 GWh annually in the industrial and commercial sectors. This represents 2 percent of all motors and 3 percent of total annual motor system electricity consumption in the industrial and commercial sectors. The breakdown of DC motors by industrial and commercial subsectors are provided below.

Industrial sector

DC motor systems in the industrial sector are estimated to consume about 24,000 GWh annually. The breakdown by industrial subsector is shown in Figure 43. The Plastics/Rubber, Paper, and Primary Metal subsectors are estimated to have the highest DC motor system electricity consumption, accounting for approximately 73 percent of the sector's overall DC motor system electricity consumption.

Figure 43: DC motor system annual electricity consumption in the industrial sector

There are an estimated 584,000 DC motor system units in the industrial sector. Figure 44 shows the breakdown by industrial subsector. The Machinery subsector has the most DC motor system units and accounts for 56 percent of systems in the industrial sector.

Figure 44: DC motor system counts in the industrial sector

Due to the low number of DC motor systems observed during the assessments, conducting deeper analysis and examining trends risks overextending the statistical validity of the findings. For this reason, further breakdown of electricity consumption, run hours, or other characteristics are not examined further. However, to better understand the applications of DC motor systems, the electricity consumption and counts by end use is presented as a percent of total sector DC motor system electricity consumption and counts (rather than an absolute electricity consumption value or number of units).

Figure 45 shows the breakdown of applications of industrial DC motor systems as a percent of industrial DC motor system electricity consumption. Extrusion and material shaping applications comprise 50 percent of all industrial DC motor system electricity consumption.

Figure 45: DC motor system electricity consumption by end use application for the industrial sector

The breakdown of applications of industrial DC motor systems as a percent of industrial DC motor counts is shown in Figure 46. The breakdown is quite different than the breakdown by electricity consumption in Figure 45. Seventy percent of all industrial DC motors are used in air handling applications. Extrusion and materials shaping, which accounted for 27 percent and 23 percent of industrial DC motor system electricity consumption, respectively, only accounts for 3 percent and 5 percent of DC motor units respectively, implying that the extrusion and materials shaping motors are either much larger and/or have much longer run hours than their air handling counterparts.

Figure 46: DC motor system counts by end use application for the industrial sector

Commercial sector

DC motor systems in the commercial sector are estimated to consume about 6,600 GWh annually. The breakdown by commercial subsector is shown in Figure 47. Subsectors with no estimated DC motor system electricity consumption have been omitted from Figure 44. The Office subsector accounts for approximately 88 percent of the commercial sector's overall DC motor system electricity consumption.

Figure 47: DC motor system annual electricity consumption by subsector in the commercial sector. Subsectors with no estimated DC motor system electricity consumption have been omitted. These are: EDU, FSA, FSE, LOD, MEM, MER, POS, REW, SER, and WAS.

There are an estimated 222,000 DC motor system units in the commercial sector. Figure 48 shows the breakdown by commercial subsector. Subsectors without any observed DC motor systems have been omitted from the figure. As with electricity consumption, the Office subsector has the most DC motor system units, accounting for 70 percent of the systems in the sector.

Figure 48: DC motor system counts in the commercial sector by subsector. Subsectors with no observed DC motor systems have been omitted. These are: EDU, FSA, FSE, LOD, MEM, MER, POS, REW, SER, and WAS.

Similar to the industrial sector, a low number of DC motors were observed in the commercial sector. In order to not overextend the findings, no further breakdown on absolute electricity consumption or counts for DC motor systems in the commercial sector is presented. However, to better understand the applications of DC motor systems in the commercial sector, percent breakouts by electricity consumption and counts by end use are detailed below.

The breakdown of applications of commercial DC motor systems as a percent of commercial DC motor system electricity consumption is shown in Figure 49. The overwhelming majority of DC motor system electricity consumption is for unclassified or miscellaneous applications.

Figure 49: DC motor system electricity consumption by end use application for the commercial sector

The breakdown of applications of commercial DC motor systems as a percent of commercial DC motor counts is shown in Figure 50. Similar to Figure 49, the majority of commercial DC motor system units are for unclassified or miscellaneous applications. However, nearly 30 percent of commercial DC motor systems are used in air handling applications.

Figure 50: DC motor system counts by end use application for the commercial sector

Motor age

This section will present results on the age of the installed stock of industrial and commercial three-phase motor systems greater than or equal to 1 hp. The age of the motor is an indication of its energy efficiency level, possible maintenance history, and ability to adopt new technologies (e.g., smart sensors and controls).

Industrial sector

Due in large part to illegible nameplates, the age of 63 percent of the industrial motors assessed could not be determined (see Figure 51). In cases where the nameplate was legible, the age may not have been discernible. Of the remaining 37 percent of motors, the largest share (16 percent) were fewer than 10 years old. For older motors with illegible nameplates, the likelihood that the facility staff will know the installation date of a motor preceding their employment at the facility reasons to be low. Therefore, it can be inferred that a large percentage of the motors listed as UTC are older motors (i.e., greater than 10 years old).

The distribution of size within each age range is fairly uniform and approximately follows the overall distribution of motor sizes in the industrial sector. For example, nearly half the motors within any size range, including those that were undetermined, were 1-5 hp. This is approximately the same percent of motors that are 1-5 hp across the entire industrial sector (49 percent).

Figure 51: Age of industrial motor systems broken down by size. Compared to Figure 4, UTC in this figure includes UTC, illegible nameplates, and some nameplates that were legible but the age still could not be determined.

Commercial sector

Due in large part to illegible nameplates, the age of 50 percent of the commercial motors assessed was undeterminable, as shown in Figure 52. Considering the percent of motors with illegible nameplates (69 percent, as shown in Figure 4), secondary sources of information successfully identified the age of 19 percent of the commercial motors assessed.

Of the remaining 50 percent of commercial motor systems assessed, 22 percent were under 10 years old, and 21 percent were between 10 and 20 years old. Similar to the industrial sector, the size breakdown within any size range follows the size breakdown across the commercial sector. Nearly all the motors in any age range are under 50 hp, with most between 1 and 5 hp.

Figure 52: Age of commercial motor systems broken down by size

Comparison to previous report

To better understand the changes in motor system demographics over time, the results from this MSMA were compared to the previous MSMA (2002 report) for the industrial sector.

Comparisons to the previous commercial motor system study were not made since it utilized a different methodology and did not rely on primary data collection. Overall, the manufacturing sector's motor system annual electricity consumption is far less in 2020 than it was in 2002.

Correcting for inclusion of HVAC systems in the current estimate and exclusion in the 2002 assessment, the sector's non-HVAC motor system electricity consumption is about 435,000 GWh (determined by subtracting air handling and space cooling loads from the industrial total). This represents a 25 percent reduction in motor system electricity consumption. While some of this reduction is likely due to structural changes in the manufacturing sector (e.g., offshoring, mergers, contraction), some is also due to improvements in energy efficiency.

The 2002 assessment utilized the Standard Industrial Classification (SIC) system, and this assessment utilizes the North American Industry Classification System (NAICS). However, at the level of classification utilized in both reports (two-digit SIC and three-digit NAICS), the crosswalk between the two classification systems results in minimal loss of fidelity.

Table 21 compares the top 10 motor system electricity consuming sectors in 2002 and 2020. For the most part, the subsectors in the top 10 are consistent. Two exceptions are the Textile Mill and the Electronic and Other Electric Equipment subsectors, which ranked ninth and tenth, respectively, in 2002. Neither rank in the top 10 in the current assessment. The Fabricated Metals subsector and the Nonmetallic Minerals subsector were ranked in the top 10 in the current assessment but were not in the top 10 in the previous study. It should be noted that the previous study estimated that the motor system annual electricity consumption for the SIC subsector that best aligns with Nonmetallic Minerals (Stone, Clay, and Glass products) was 10 percent of the estimated motor system electricity consumption from MECS. If the MECS estimate were used, it would rank in the top 10 in the 2002 survey. The Municipal Wastewater subsector was not surveyed in 2002. In this survey, it is estimated that its motor system electricity consumption would rank between the Nonmetallic Mineral and Fabricated Metal subsectors.

Table 21: Rank (high to low) of industrial subsectors by motor system annual electricity consumption as estimated in the 2002 and 2020 MSMA

Rank	2002	2020
1	Chemical and Allied	Chemicals
2	Paper and Allied	Primary Metals (all)
3	Primary Metals	Food
4	Petroleum and Coal	Paper and Pulp
5	Food and Kindred	Plastics and Rubber
6	Rubber and Misc. Plastics	Petroleum and Coal
7	Transportation Equipment	Transportation
8	Lumber and Wood	Nonmetallic Mineral
9	Textile Mill	Fabricated Metals
10	Electronic and Other Electric Equipment	Wood
Total (GWh)	575,430	546,963

Table 22 shows the breakdown of industrial motor system electricity consumption by driven equipment for the current and previous assessment. Some of the differences between the two may be attributed to the inclusion of HVAC in the current assessment. Specifically, this could be causing the 85 percent increase in observed refrigeration compressors. The current assessment included split air conditioning systems that utilize a central cooling plant. The differences in materials handling and materials processing between the two assessments could be attributed to how the assessment teams classified these systems. The sum of the two are nearly the same between the two assessments (35 percent in 2002 and 33 percent in 2020).

Table 22: Share of industrial motor driven equipment annual electricity consumption

Driven Equipment	2002* (%)	2020* (%)	% Change in Share
Air Compressors	16	12	-4
Fans/blowers	14	21	+7
Pumps	25	21	-4
Refrigeration Compressors	7	12	+5
Materials Handling	12	4	-4
Materials Processing	23	29	+6
Other	4	1	-3
Total	100	100	

Note: HVAC equipment was included in the 2020 assessment but not in the 2002 assessment

Table 23 shows the breakdown of industrial motor system electricity consumption and counts for the 2002 and current MSMA. The overall trends are similar: the majority of the electricity consumption is for motor systems greater than 5 hp, and the majority of the units are 1-20 hp, with the largest percentage in the 1-5 hp size range.

Table 23: Comparison of shares of industrial motor system electricity consumption and counts between the 2002 and 2020 MSMAs

Size Range (hp)	Electricity Consumption			Counts		
	2002 MSMA (%)	2020 MSMA (%)	Change (%)	2002 MSMA (%)	2020 MSMA (%)	Change (%)
1-5	4.8	4.9	1.9	58.8	49.2	-16.3
6-20	10.4	12.4	19.6	28.4	28.2	-0.8
21-50	12.7	16.0	26.1	9.1	13.1	44.2
51-100	12.7	13.2	3.5	2.9	5.7	97.8
101-200	14.4	11.8	-18.1	1.8	1.9	4.1
201-500	15.8	17.3	9.8	0.7	1.3	90.4
501-1,000	13.4	11.6	-13.4	0.2	0.4	109.9
1,001+ hp	15.7	12.8	-18.7	0.1	0.1	26.3
Total	100	100	-	102	100	-

Highlights

Motor system electricity consumption

- Industrial and commercial three-phase motor systems greater than or equal to 1 hp consume ~1,079 TWh/year, about 29 percent of total electric grid load see Figure 6).
 - Industrial: 546,963 GWh/year, about 69 percent of all electricity consumption and 13 percent of overall energy consumption in the sector (see Table 11)
 - Commercial: 532,024 GWh/year, about 43 percent of all electricity consumption and 26 percent of overall energy consumption in the sector (see Table 13)
- Motor system electricity consumption in the industrial sector has reduced by 25 percent since the previous (2002) assessment.
- Sixty-two percent of the industrial subsector's estimated annual motor system electricity consumption resides in the top six subsectors, with the Chemicals subsector (105,699 GWh) being the largest (see Table 11).
- Twenty-nine percent of all industrial sector motor system electricity consumption is for materials processing, followed by 21 percent for pumps and fans/blowers each (see Table 15).
- Seventy-five percent of industrial motor system electricity consumption is attributed to 1-500 hp motor systems (see Table 19).
- Seventy percent of the commercial subsector's estimated annual motor system electricity consumption resides in the top seven subsectors, with the Office subsector (93,334 GWh) being the largest (see Table 13).
- Forty-eight percent of all commercial sector motor system electricity consumption is for refrigeration compressors. Refrigeration compressors, fans/blowers, and pumps account for 94 percent of the sector's electricity consumption (see Table 17).
- Eighty percent of commercial sector motor system electricity consumption is attributed to the 1-50 hp size range (see Table 20).

Motor system counts and size

- There are 52.5 million motor systems greater than or equal to 1 hp in the industrial and commercial sectors, with 10.8 million in industrial and 41.7 million in commercial facilities (see Figure 7).
- The average connected motor system horsepower at a facility is 1,595 for the industrial sector and 89 for the commercial sector (see Figure 8).
- Average motor size is 27 hp for industrial and 8 hp for commercial (see Table 12 and Table 14).
- Sixty-four percent of the industrial sector's estimated motor system units reside in the top six subsectors, with Machinery (2 million) accounting for the most (see Table 12).
- Seventy-four percent of the commercial sector's estimated motor system units reside in the top seven subsectors, with the Mercantile: Enclosed mall and strip mall subsector (6.3 million) accounting for the most units (see Table 14).
- Ninety-nine percent of the motor system units in the industrial sector are in the 1-500 hp range, with 49 percent in the 1-5 hp range (see Table 19).
- Ninety-nine percent of the motor system units in the commercial sector are in the 1-50 hp size range (see Table 20).

DC motor systems:

- DC motors accounted for 4 percent of industrial and 1 percent of commercial motor system electricity consumption and 5 percent of industrial and 0.5 percent of commercial motor system counts.

Operating characteristics

This section summarizes findings related to operating characteristics of industrial and commercial motor systems greater than or equal to 1 hp. Specifically, findings related to load factor, load control, and transmission type are summarized. Additionally, findings related to energy management and maintenance practices are summarized. A summary of highlights for each of these topics is presented at the end of this section. Where tables are presented showing horsepower ranges, parenthesis (e.g., “(“ are used to indicate the range excludes the bound whereas square brackets (e.g., “[“ are used to indicate the range includes the bound. For example, “[6.0 – 21.0)” means that the range includes 6.0 but excludes 21.0.

Motor load factor

For the MSMA, the motor load factor was defined as the ratio of average motor output power to the motor’s rated power. For example, a motor rated at 100 hp but only operating at 40 hp would have a load factor of 0.4. Within the limitations of a one- or two-day assessment, the load factors of the motor observed were estimated. The MSMA team went through iterations to identify the best method using available resources to get an understanding of typical load factors for each motor observed. Rather than utilizing spot measurements, which may not be representative of the typical load factor and are time consuming to gather, facility staff were queried to estimate the motor load factor and if the load was constant or variable. Staff were provided detailed guidance on how to estimate load factor. For the MSMA, “variable” load is defined as a load that modulates during operation. “Constant” load is defined as a load that remains constant during operation. Variable and constant load are not related to duty/cycling factor. Duty/cycling factor describe the percent of time that the motor is energized (i.e., operational at any load). This has been included in the summary of the installed base when determining run hours. Where no determination of motor load factor could be made, a default value of 0.75 was used based on the assumption that the motor was appropriately sized.

The findings on motor load factor are provided below, split between the industrial and commercial sector. Within each sector, the load factor estimates are broken down by motor system electricity consumption and counts, and further by motor size range and driven equipment. The load factors presented here are not for the overall system, but of the motor itself. Attempts to understand the motor system load factor (i.e., output work performed by the system relative to the rated output work) yielded unreliable data with high nonresponse rates.

Industrial sector

Figure 53 shows the breakdown of motor load factor by industrial motor system annual electricity consumption. The largest share of motor system annual electricity consumption falls under systems that use motors that are variably loaded with a load factor between 0.4-0.75, accounting for 27 percent of industrial motor system electricity consumption. Conversely, very little industrial motor system electricity consumption falls under systems that use motors operating at constant loads, with a load factor less than 0.4 (1 percent). The second smallest category is variably loaded systems with a motor load factor under 0.4 (5 percent). This indicates that a relatively small fraction of industrial motor system annual electricity consumption is attributable to oversized motors. Overall, 38 percent of industrial motor system annual electricity

consumption is attributable to variably loaded motors, and 45 percent is attributable to constantly loaded motors.

Figure 53: Industrial motor load factors in terms of industrial sector motor system annual electricity consumption

Table 24 provides estimates of industrial motor system annual electricity consumption by motor load factor for various motor size ranges and driven equipment types. Thirty-nine percent of industrial motor system annual electricity consumption for motor systems under 50 hp is attributable to systems that operate at a constant motor load greater than 0.75. This changes for motors above 50 hp. Thirty-eight percent of industrial motor system annual electricity consumption for motor systems greater than 50 hp is attributable to systems that operate at variable motor loads between 0.4 and 0.75.

The breakdown by driven equipment in Table 24 provides insight into how driven equipment is operated. Seventy-two percent of industrial air compressor electricity consumption is from motors that operate at variable loads greater than 0.4. Thirty-five percent of industrial pumping is from motors operating at constant loads greater than 0.75; the same holds true for fan/blower systems (thirty-three percent). Forty percent of material processing electricity consumption and 44 percent of refrigeration electricity consumption is from motors operating at variable loads between 0.4 and 0.75, respectively.

Table 24: Motor load factors for industrial sector motor system annual electricity consumption (GWh) by size range and driven equipment type

	Constant Load (Load Factor $\leq$ 0.4), GWh	Constant Load (0.4 < Load Factor < 0.75), GWh	Constant Load (Load Factor $\geq$ 0.75), GWh	Variable Load (Load Factor $\leq$ 0.4), GWh	Variable Load (0.4 < Load Factor < 0.75), GWh	Variable Load (Load Factor $\geq$ 0.75), GWh	Unknown if Variable
By Size (hp)							
[1.0, 6.0)	233	2,580	11,585	1,439	4,829	3,351	2,055
[6.0, 21.0)	151	4,714	29,247	2,391	15,825	7,704	7,572
[21.0, 51.0)	167	4,142	29,549	3,332	26,212	9,716	13,839
[51.0, 101.0)	414	5,281	18,508	2,554	25,182	11,326	8,603
[101.0, 201.0)	358	3,418	13,024	4,324	24,054	8,088	11,152
[201.0, 501.0)	349	4,134	15,559	3,444	27,355	20,247	23,266
[501.0, 1001.0)	51	2,894	5,194	2,723	28,591	6,960	16,570
[1001.0, 2001.0)	-	3,195	2,601	2,624	18,180	2,690	5,659
[2001.0, 5001.0)	1,276	795	3,326	5,028	4,848	1,869	416
[5001.0, inf)	-	5,784	769	1,591	8,923	-	226
By Driven Equipment							
Air Compressor	-	829	4,406	4,418	23,864	22,130	7,966
Pump	795	8,413	40,106	5,435	27,786	8,430	24,903
Fan and Blower	739	9,303	37,349	3,946	34,699	11,486	15,421
Material Handling	24	3,879	4,634	1,815	3,453	993	5,200
Material Processing	1,363	12,707	34,113	11,904	62,587	7,856	25,254
Refrigeration Compressor	78	895	6,583	1,891	29,589	20,333	8,638
Other	-	912	2,171	41	2,021	722	1,977
Total	2,999	36,938	129,361	29,451	183,998	71,950	89,359
% of industrial total	1%	7%	24%	5%	34%	13%	16%

Figure 54 provides a breakdown of motor load factor by number of motor system units. Constant load systems operating at motor load factors greater than 0.75 dominate the installed base, representing 43 percent of all industrial motor systems. Overall, there are nearly twice as many constant motor load systems as variable load systems. Significantly underloaded motors (variable or constant under 0.4 load factor) only comprise 9 percent of the industrial motor system units.

Figure 54: Motor load factor for industrial sector motor systems (number of units)

Table 25 provides the breakdown of industrial motor system units by motor load factor for various horsepower size ranges and driven equipment types. Forty-four percent of all industrial motor systems under 100 hp use constant load motors greater than 0.75. Thirty percent of industrial motor systems between 101-5,000 hp use motors operating under variable loads between 0.4 and 0.75, representing the largest fraction of motor load types for this horsepower size range. For the largest motor systems observed ($>5,000$ hp), twenty-five percent use constant load motors operating between 0.4 and 0.75, representing the largest fraction of motor load types for this horsepower size range.

Across all driven equipment types, the most common operating condition is estimated to be constant motor load systems operating at load factors greater than 0.75. The majority of air compression (59 percent) and refrigeration compression (65 percent) systems are variably loaded. The majority of pump (57 percent), fan/blower (51 percent), materials handling (50 percent), and materials processing (58 percent) systems operate under constant load.

Table 25: Motor load factor for industrial sector motor systems units by size range and driven equipment type

	Constant Load (Load Factor $\leq$ 0.4), # units	Constant Load (0.4 < Load Factor < 0.75), # units	Constant Load (Load Factor $\geq$ 0.75), # units	Variable Load (Load Factor $\leq$ 0.4), # units	Variable Load (0.4 < Load Factor < 0.75), # units	Variable Load (Load Factor $\geq$ 0.75), # units	Unknown if Variable, # units
By Size (hp)							
[1.0, 6.0)	38,484	475,453	2,479,421	454,838	991,981	411,855	283,015
[6.0, 21.0)	12,383	188,268	1,320,204	165,863	717,662	270,672	351,101
[21.0, 51.0)	3,965	69,710	500,826	92,719	362,468	128,874	256,682
[51.0, 101.0)	4,429	35,324	200,038	39,391	184,633	64,251	93,040
[101.0, 201.0)	2,255	11,647	32,341	29,097	58,813	19,999	48,594
[201.0, 501.0)	1,306	6,434	18,848	11,753	34,560	24,848	45,590
[501.0, 1001.0)	277	1,800	2,464	2,815	28,586	4,173	5,037
[1001.0, 2001.0)	-	972	583	1,400	4,616	1,046	1,179
[2001.0, 5001.0)	239	89	281	1,052	458	107	459
[5001.0, inf)	-	303	34	191	398	-	292
By Driven Equipment							
Air Compressor	-	3,315	75,007	41,235	83,022	69,422	54,434
Pump	15,912	176,629	689,093	99,128	276,005	120,173	172,683
Fan and Blower	29,255	218,639	1,173,935	139,609	654,146	276,284	308,911
Material Handling	717	192,857	433,370	248,375	239,496	39,080	99,431
Material Processing	17,060	159,811	1,965,388	241,366	717,855	244,354	349,669
Refrigeration Compressor	395	15,588	183,427	28,787	271,907	147,585	45,416
Other	-	23,159	34,820	619	141,745	28,925	54,444
Total	63,339	789,999	4,555,039	799,119	2,384,175	925,824	1,084,988
% of Total Industrial	1%	7%	43%	8%	22%	9%	10%

Figure 55 shows the average motor load factor by size for industrial motor systems. The average motor load factor is slightly lower for motor systems greater than 500 hp than it is for motor systems less than 500 hp.

Figure 55: Average motor load factor for industrial sector motor systems by size

Commercial sector

Figure 56 shows the motor load factor by commercial sector motor system annual electricity consumption. The largest share of commercial sector motor system annual electricity consumption is for systems that use variably loaded motors with a load factor between 0.4-0.75, accounting for 40 percent of the sector's motor system electricity consumption. Conversely, very little (0.1 percent) of commercial sector motor system electricity consumption is for systems that use motors operating at constant loads with a load factor less than 0.4. The second smallest category (3 percent) is variably loaded systems operating with a motor load factor under 0.4. Similar to the findings from the industrial sector, this indicates that a relatively small fraction of commercial motor system electricity consumption is attributable to oversized motors. Overall, 64 percent of commercial motor system electricity consumption surveyed is attributable to variably loaded motors, and 31 percent is attributable to constantly loaded motors (with 5 percent unknown).

Figure 56: Motor load factors for commercial sector motor system annual electricity consumption

Table 26 provides estimates of commercial sector motor system annual electricity consumption by motor load factor for various motor size ranges and driven equipment types. Similar to the industrial sector, there is a size cutoff below which the majority of motor systems use constantly loaded motors and above which they are variably loaded. Forty-five percent of commercial motor system electricity consumption for motor systems under 5 hp use motors operating at a constant load greater than 0.75. This changes for motors above 5 hp. Forty-four percent of commercial motor system electricity consumption for motor systems above 5 hp use motors operating at variable loads between 0.4 and 0.75.

Table 26 also shows the motor load breakdown by driven equipment and provides insight into how driven equipment is operated. Forty-two percent (by electricity consumption) of commercial air compression, fan/blower, materials processing, and refrigeration compression systems use motors operating at variable loads between 0.4-0.75. Forty-two percent (by electricity consumption) of commercial sector pumping systems use motors operating at constant loads greater than 0.75. Fifty-eight percent (by electricity consumption) of materials handling systems use motors operating at variable loads less than 0.4.

Table 26: Load factors for commercial sector motor system electricity consumption by size range and driven equipment type

	Constant Load (Load Factor ≤ 0.4)	Constant Load (0.4 < Load Factor < 0.75)	Constant Load (Load Factor ≥ 0.75)	Variable Load (Load Factor ≤ 0.4)	Variable Load (0.4 < Load Factor < 0.75)	Variable Load (Load Factor ≥ 0.75)	Unknown if Variable
By Size (hp)							
[1.0, 6.0)	1	10,830	53,145	1,682	29,404	15,291	6,728
[6.0, 21.0)	16	17,208	35,161	2,511	74,358	47,802	16,462
[21.0, 51.0)	554	7,040	23,926	5,597	49,610	24,115	2,973
[51.0, 101.0)	15	650	2,697	4,310	17,649	1,400	169
[101.0, 201.0)	16	589	2,384	2,495	8,435	7,410	308
[201.0, 501.0)	-	629	1,266	-	10,933	11,201	695
[501.0, 1001.0)	-	-	5,446	752	15,655	2,656	-
[1001.0, 2000.0)	-	-	-	-	3,607	433	-
[2001.0, 5001.0)	-	-	-	-	1,225	1,194	-
By Driven Equipment							
Air Compressor	-	54	4,504	240	6,726	913	127
Pump	32	2,841	22,314	4,928	14,052	5,936	2,805
Fan and Blower	91	17,805	62,095	3,557	83,505	19,382	5,650
Material Handling	-	329	35	5,384	1,626	1,909	-
Material Processing	-	87	219	-	596	-	647
Refrigeration Compressor	479	15,829	34,641	3,237	101,763	77,587	17,985
Other	-	-	216	-	2,609	5,776	122
Total	602	36,946	124,024	17,346	210,876	111,502	27,336
% of commercial total	0%	7%	23%	3%	40%	21%	5%

Figure 57 provides the breakdown of motor load factor by number of motor system units. Systems using variable load motors operating at load factors between 0.4 and 0.75 represent 36 percent of all commercial sector motor systems, followed by constant load systems operating at motor load factors greater than 0.75, at 27 percent. Overall, there is a relatively balanced breakdown between constant load (43 percent) and variable load (52 percent) systems (with 5 percent unknown). Significantly underloaded systems (variable or constant under 0.4 load factor) only comprise 3 percent of the commercial motor system units.

Figure 57: Motor load factor for commercial sector motor systems (number of units)

Table 27 provides the breakdown of commercial sector motor system units by motor load factor for various horsepower size ranges and driven equipment types. Thirty-five percent of all commercial motor systems under 5 hp operate at constant loads greater than 0.75, representing the largest fraction of load types for this size range. Forty-eight percent of commercial motor systems above 5 hp operate at variable loads between 0.4 to 0.75, representing the largest fraction of load types for this size range.

For commercial air compressor, fan/blower, and pump system units, the most common operating condition is estimated to be constant load systems operating at 0.75 motor load factor. For materials handling and refrigeration compression systems, the most common operating condition is estimated to be variable motor load between 0.4 and 0.75. The most common operating condition for materials processing systems is constant load with a motor load factor between 0.4 and 0.75. The majority of air compression (76 percent), pump (70 percent), fan/blower (68 percent), and materials processing (76 percent) system units operate under constant load conditions.

Table 27: Motor load factors for commercial sector motor systems units by size range and driven equipment type

	Constant Load (Load Factor ≤ 0.4), # units	Constant Load (0.4 < Load Factor < 0.75), # units	Constant Load (Load Factor ≥ 0.75), # units	Variable Load (Load Factor ≤ 0.4), # units	Variable Load (0.4 < Load Factor < 0.75), # units	Variable Load (Load Factor ≥ 0.75), # units	Unknown if Variable
By Size (hp)							
[1.0, 6.0)	2,505	5,243,107	9,622,071	540,124	8,281,276	2,801,964	1,025,596
[6.0, 21.0)	2,432	1,167,442	1,217,975	387,741	5,880,791	1,852,831	1,081,771
[21.0, 51.0)	18,857	185,846	358,214	166,533	689,936	536,698	83,576
[51.0, 101.0)	263	14,321	12,216	59,286	124,829	10,061	828
[101.0, 201.0)	2,086	3,074	6,901	15,089	50,952	37,385	680
[201.0, 501.0)	-	837	1,301	1,868	38,206	10,568	3,245
[501.0, 1001.0)	-	-	2,390	468	20,102	2,975	-
[1001.0, 2001.0)	-	-	-	-	2,111	281	-
[2000.0, 5001.0)	-	-	-	-	400	187	-
By Driven Equipment							
Air Compressor	-	8,769	1,073,020	1,977	263,563	77,966	4,746
Pump	2,178	268,623	1,307,507	85,579	379,851	83,102	123,464
Fan and Blower	6,246	4,165,336	7,491,310	225,865	2,724,513	1,921,421	600,809
Material Handling	-	40,286	17,539	218,544	237,224	184,869	-
Material Processing	-	774,325	16,834	-	21,601	-	224,106
Refrigeration Compressor	17,720	1,357,287	1,185,550	639,144	11,401,265	2,829,539	1,207,560
Other	-	-	129,306	-	60,587	156,053	35,011
Total	26,144	6,614,627	11,221,067	1,171,109	15,088,604	5,252,950	2,195,696
% of Total Commercial	0%	16%	27%	3%	36%	13%	5%

Figure 58 shows the average motor load factor by size for commercial motor systems. The average motor load factor for motor systems less than 50 hp is greater than it is for motor systems greater than 50 hp.

Figure 58: Average motor load factor for commercial sector motor systems by size

Load control

The load control technology for all motor systems surveyed was documented. Table 28 specifies the terms for the load control technology categories and options used in this report. For this section, the load control technologies were grouped into “VFD,” “all others,” and “none.” To focus on load control *technologies*, load control *strategies* were categorized as “none,” since these are not technology-based strategies. Further, VFD was categorized separately from other load control technologies due to its dominance in terms of uptake of load control technologies.

Table 28: Load control technology types surveyed and the categorization used in this report

Category	Options
VFD	<ul style="list-style-type: none"> • Variable frequency drive • Multiple methods that include VFD
All others	<ul style="list-style-type: none"> • Inlet vane/damper • Variable displacement • Hydraulic drive • Multiple methods without VFD • Mechanical drive • Slide valve • Adjustable speed gearbox • Eddy current drive • None of the above
None	<ul style="list-style-type: none"> • Constant load (without any control) • On/off cycling • Multispeed motor • Outlet damper • Bypass or open flow • Throttle valve • Load/unload • Periodic material loading
UTC	Unable to collect. The control technology was undeterminable.

Industrial sector

Per Figure 59, 16 percent of industrial motor system capacity uses VFDs. Seventy-four percent have no load control technology/equipment. Across the subsectors, VFD penetration rates vary. The Beverage and Tobacco (37 percent), Chemicals (35 percent), Printing (32 percent), Plastics/Rubber (31 percent), and Wastewater (27 percent) subsectors have the highest penetration rates of VFDs among the industrial subsectors. Some of the subsectors with low penetration rates of VFDs are among the highest in overall industrial motor system electricity consumption: Paper (7 percent), Primary Metals (7 percent), and Nonmetallic Minerals (8 percent).

Figure 59: Penetration rates of VFDs and other load control technologies by industrial subsector. See Figure 12 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%.

The penetration rates of VFDs and other load control technologies by large and medium-size facilities largely follow the sector-wide penetration rates. However, the penetration rate among small facilities (8 percent) is half of the sector-wide penetration rate (Figure 60).

Figure 60: Penetration rates of VFDs and other load control technologies by industrial facility size. Unlabeled segments are < 5%.

Figure 61 shows the breakdown of load control technologies for industrial motor system electricity consumption by size range. In general, the uptake of VFDs and other control technologies increases with the size of the industrial motor system. Seventy-three percent of the electricity consumption for 1-5 hp motors is without any load control technology, whereas only 41 percent of the electricity consumption for 501-1,000 hp is without any load control technology. As motor system size increases, not only does the uptake of VFDs increase, but the uptake of all other control technologies also increases. Only 6 percent of industrial motor system electricity consumption in the 1-5 hp range uses a non-VFD control technology, whereas 27 percent of industrial motor system electricity consumption in the 501-1,000 hp size range uses a non-VFD control technology. VFD uptake for the largest motor systems (i.e., greater than 1,000 hp) is the lowest of any motor system size range. This may be due to the unavailability of commercially available VFDs for large medium-voltage motor systems.

Figure 62 shows the breakdown of load control technologies for industrial motor systems by size range. The trends are the same as the trends for industrial motor system electricity consumption (Figure 61).

Figure 61: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of industrial motor system electricity consumption. See Figure 12 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 62: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of industrial motor system counts. See Figure 12 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 63 shows the penetration rates of VFDs and other control technologies broken down by equipment type in terms of industrial motor system electricity consumption. Aside from the “other” category, the penetration rates of VFDs are fairly similar across equipment types; about 23 percent of industrial motor system electricity consumption. However, there is large variation in the uptake of other control technologies, ranging from 31 percent for refrigeration compressor systems to 1 percent for pump systems.

Figure 63: Penetration rates of VFDs and other control technologies by equipment type in terms of industrial motor system electricity consumption. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 64 shows penetration rates of VFDs and other control technologies by equipment type in terms of the percent of system counts. The penetration rate of VFDs in terms of system counts is less than the penetration rates in terms of electricity consumption for most equipment types (aside from Air Compressor and Other, for which they are nearly the same). This implies that larger motor systems are more likely to be fitted with VFDs than smaller systems. This is consistent with the findings shown in Figure 62.

Figure 64: Penetration rates of VFDs and other control technologies by equipment type in terms of industrial motor system counts. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 65 shows the metric used to control VFDs on industrial air compressor, fan/blower, pump, and refrigeration compressor systems. Across all systems, pressure or temperature setpoints are the most commonly used control metric.

Commercial sector

Overall, 4 percent of commercial motor systems use VFDs and 91 percent have no load control technology/equipment. Across the subsectors, the penetration rates of VFDs are generally low. Aside from the Health Care: Inpatient (19 percent) and the Education (15 percent) subsectors, the VFD penetration rate is less than 8 percent. Many subsectors — Food Sales, Food Service, Mercantile: Enclosed and Strip Malls, and Other/Vacant — had negligible (i.e., ~0 percent) VFD penetration rates. See Figure 66 for details.

Figure 65: VFD control feedback for industrial air compressors, fans/blowers, pumps, and refrigeration compressors as a percentage of system counts

Figure 66: Penetration rates of VFDs and other load control technologies by commercial subsector. See Figure 17 for the distribution of connect hp per facility for the industrial subsectors. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 67 shows the penetration rates of VFDs and other load control technologies by commercial facility size. The penetration rates decline with facility size, falling from 10 percent for large facilities to 2 percent for small facilities.

Figure 67: Penetration rates of VFDs and other load control technologies by commercial facility size. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 68 shows the breakdown of load control technologies for commercial sector motor system electricity consumption by size range. Similar to the industrial sector, the uptake of VFDs and other control technologies generally increases with the size of the commercial motor system. Less than 4 percent of the electricity consumption for 1-5 hp motors has any load control technology, whereas 44 percent of the electricity consumption for 101-200 hp motors has a load control technology. As motor system size increases, not only does the uptake of VFDs increase, so does the uptake of all other control technologies, peaking at 31 percent for the 501-1,000 hp size range. This may be due to the unavailability of commercially available VFDs for large medium-voltage motor systems. Also, as was shown in Figure 41, very little commercial motor system electricity consumption resides in motor systems greater than 500 hp.

Figure 69 shows the breakdown of load control technologies for commercial motor systems by size range. The trends are the same as the trends for the electricity consumption breakdown (Figure 68).

Figure 68: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of commercial sector motor system electricity consumption. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 69: Penetration rates of VFDs and other control technologies by motor size in terms of percentage of commercial motor system count. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 70 shows the penetration rates of VFDs and other control technologies broken down by equipment type in terms of commercial sector motor system electricity consumption. The penetration rates vary across equipment types. The VFD penetration rate is relatively high for fan/blower (37 percent) and pump (39 percent) systems, but negligible for all other systems except refrigeration compressor systems (8 percent). As was shown in Figure 29, fan/blower, pump, and refrigeration compressor systems account for the majority of commercial sector motor system electricity consumption. Considering this, the low penetration rates for other equipment types could be due to low representation from those equipment types.

Figure 71 shows penetration rates of VFDs and other control technologies by equipment type in terms of the percent of systems with these technologies in the commercial sector. The penetration rate of VFDs in terms of system counts is less than the penetration rates in terms of electricity consumption for most equipment types. This implies that larger motor systems and/or systems with longer run hours are more likely to be fitted with VFDs than smaller systems are. This is consistent with the findings shown in Figure 62.

Figure 72 shows the metric used to control VFDs on commercial sector air compressor, fan/blower, pump, and refrigeration compressor systems. For air compressor, fan/blower, and pump systems, pressure setpoint is the most common control metric. HVAC factors, such as ambient temperature, are the most common control metric for commercial sector refrigeration systems.

Figure 70: Penetration rates of VFDs and other control technologies by equipment type in terms of commercial sector motor system electricity consumption. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 71: Penetration rates of VFDs and other control technologies by equipment type in terms of commercial motor system counts. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 72: VFD control feedback for commercial air compressors, fans/blowers, pumps, and refrigeration compressor.

Transmission type

To completely characterize the motor systems assessed, the transmission used to convey the shaft power was recorded. Results for industrial motor systems are summarized in Figure 73 in terms of industrial sector motor system electricity consumption and units. Direct drive was the most common transmission type observed. The next most common are some type of belt drive (V belt, cog, or unknown). When the belt type was determinable, V belts were four times more common than cog belts (4 percent versus 1 percent of either industrial motor system units or electricity consumption). Gearboxes are used by 8 percent of all industrial motor systems (7 percent of all industrial motor system electricity consumption).

Figure 73: Transmission type for industrial motor systems by counts (top) and electricity consumption (bottom).

Figure 74 provides the breakdown of transmission types by driven equipment in the industrial sector. When the transmission type was known, direct shaft was the most common connection, except for materials handling motor systems. For these systems, gearboxes outpaced all other transmission types.

Figure 74: Breakdown of transmission type by driven equipment in the industrial sector. Breakdowns are provided for % of counts and % of electricity consumption. From top left clockwise: refrigeration compressors, materials processing, air compressors, fans/blowers, pumps, and materials handling.

Figure 75 summarizes the transmission types for commercial sector motor systems. Similar to the industrial sector's motor systems, the most common transmission type is direct drive (44 percent of units and 46 percent of electricity consumption). Twenty-seven percent of commercial motor systems use belts (27 percent of the sector's motor system electricity consumption). When determinable, V belts were observed far more frequently than cog belts (12 percent versus 4 percent of motor system units).

Figure 75: Transmission type for commercial motor systems by counts (top) and electricity consumption (bottom).

Figure 76 provides a breakdown of transmission types by motor driven system in the commercial sector. Unlike the industrial sector, transmission types by driven equipment are more varied in the commercial sector. While direct shaft is common across all equipment types, and gearboxes are the most common for materials handling, other transmission types constitute a majority share for other equipment types (e.g., belts for fans/blowers). Further, the most common transmission type by electricity consumption may not be the most common by motor count for a given equipment type (e.g., air compressors).

Figure 76: Breakdown of transmission type by driven equipment in the commercial sector. Breakdowns are provided for % of counts and % of electricity consumption. From top left clockwise: refrigeration compressors, materials processing, air compressors, fans/blowers, pumps, and materials handling.

Energy management practices

A survey of energy management practices was conducted as part of the facility assessments. The intent was to understand the organizational environment under which motor systems operate. This can provide insights into the adoption and maintenance of energy efficiency measures. Summarized here are responses to the consideration of energy efficiency in design and procurement, where motor system decisions are made, type of staff overseeing motor system energy management, methods for determining motor system energy efficiency measures, and existence of motor system inventories.

Procurement and Design

Figure 77 details whether or not energy efficiency is considered in the procurement of motor systems in industrial facilities. Overall, 49 percent of industrial facilities consider energy efficiency in motor system procurement. The survey responses show that large and medium facilities are more likely to consider energy efficiency than small facilities are.

Figure 77: Consideration of energy efficiency in procurement of industrial motor and related system components. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 78 summarizes the consideration of energy efficiency in the design of new capital projects for motor systems in industrial facilities. Fifty-eight percent of all industrial facilities consider energy when designing new motor system capital projects. Nearly all large (90 percent) and medium (85 percent) facilities consider it, whereas less than half (46 percent) of small facilities consider it.

Figure 78: Consideration of energy efficiency in design of industrial motor and related system components new capital projects. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 79 summarizes the consideration of energy efficiency when procuring motor system components for commercial facilities. Fifty-nine percent of commercial facilities consider energy efficiency.

Figure 79: Consideration of energy efficiency in procurement of commercial motor and related system components. Annotations show the corresponding percent for each segment for shares greater than 5%.

Figure 80 summarizes responses to whether energy efficiency is considered in the design of new motor system-related capital projects for the commercial sector. Across all commercial facilities, 67 percent consider energy efficiency. There is slight variation when examining the responses by facility size with large facilities less likely to consider it, compared to small facilities (61 percent versus 71 percent).

Figure 80: Consideration of energy efficiency in the design of new commercial motor and related system component capital projects. Annotations show the corresponding percent for each segment for shares greater than 5%.

Location of motor system decisions

Table 29 summarizes where motor system decisions are made. Across all facilities for both the industrial and commercial sector, motor decisions are usually made at the facility, not in a corporate office.

Table 29: Location where motor system decisions are made (percentage of facilities)

Size	At facility	By corporate	Mix	UTC	Total
Commercial					
LARGE	68	25	6	0	100
MEDIUM	66	29	3	2	100
SMALL	72	26	0	2	100
Industrial					
LARGE	78	3	18	1	100
MEDIUM	88	1	7	4	100
SMALL	78	8	9	5	100

Staff overseeing motor system energy management

The titles of the person responsible for managing motor systems was recorded to provide insight into the job category for the person making motor system decisions. Figure 81 summarizes those responses. The responsibility of managing motor system energy fell to the plant, facility, or maintenance manager for 71 percent of the industrial facilities. In the commercial sector, this responsibility belonged to a wider array of job titles, with the most common (36 percent) being plant engineer. The president or general manager carried this responsibility for 14 percent of commercial facilities.

Figure 81: Title of person responsible for managing motor system energy at commercial (top) and industrial (bottom) facilities.

Identification of energy efficiency measures

The facilities surveyed were asked to select from a list the methods used to identify energy efficiency measures. Responses are summarized in Table 30. Facilities could select more than one method. Fifty-nine percent of industrial facilities use an external energy assessor, far outpacing any other method queried. Peer-to-peer knowledge sharing is used by 27 percent of all industrial facilities, but for large facilities, it is the most common method (66 percent). Similarly, utility resources are used by 33 percent of all industrial facilities, but far more often by large facilities (55 percent) than small facilities (26 percent).

Across all commercial facilities, peer-to-peer knowledge sharing is the most common method for identifying energy efficiency measures (13 percent). However, for large commercial facilities, external energy assessments are the most common method (36 percent).

Table 30: Methods for identifying energy efficiency measures, percent of facilities

To identify EE improvements, what does the facility use?	Industrial (%)				Commercial (%)			
	Small	Medium	Large	Total	Small	Medium	Large	Total
External energy assessors	64	48	64	59	3	17	36	10
Kaizen events	4	11	21	7	0	0	4	0
Equipment manufacturer resources	14	48	36	24	5	10	16	8
Utility resources	26	47	55	33	6	14	29	10
State government resources	4	8	23	5	0	7	1	3
Federal government resources	4	4	17	4	0	2	12	1
Peer-to-peer knowledge sharing	18	46	66	27	12	14	27	13
Energy efficiency service provider	5	30	31	12	0	6	5	3

Use of inventories

Facilities were asked for an inventory of their motor systems. The existence of these inventories at the facility is summarized in Table 31.

In general, neither industrial nor commercial facilities had an inventory of their motor systems. Only 13 percent of industrial facilities and 18 percent of commercial facilities had an inventory of all their motors (spare and connected). For industrial facilities, larger facilities are more likely to have a motor system inventory than small facilities. Aside from inventories of all motors at small facilities (which appears to be an outlier at 29 percent), less than 10 percent of commercial facilities had any motor system inventory.

Table 31: Existence of motor system inventories, percent of facilities

Which does the facility have a list of?	Industrial (%)				Commercial (%)			
	Small	Medium	Large	Total	Small	Medium	Large	Total
All motors	13	15	19	13	29	3	4	18
Connected motors only	4	9	22	6	0	4	6	2
Pumps	13	13	30	13	0	4	8	2
Air compressors	18	43	50	25	0	4	5	2
Fans	13	18	37	15	0	5	8	2
Spare motors only	56	42	62	52	0	9	7	4

Maintenance practices

During the assessments, information on common maintenance practices and history was surveyed. Proper maintenance procedures can extend the life of the motor system, improve system reliability, and ensure that implemented energy efficiency measures deliver the expected benefits. The impact of insufficient maintenance procedures can be seen in Table 32, which shows the estimated system downtime due to motor system failures. It is estimated that commercial and industrial facilities experience more than 8 million and 6 million hours annually of unplanned motor system downtime, respectively, due to failure.

Table 32: Annual unplanned motor system downtime due to failure

Commercial Subsector Name	Total Downtime (hours)	Industrial Subsector Name	Total Downtime (hours)
EDU	377,565	Apparel	10,377
FSA	940,412	Beverage/Tobacco	13,849
FSE	1,178,406	Chemical	110,564
HCI	120,625	Computer/Electronic	144,712
HCO	58,910	Electrical Equipment	532
LOD	1,094,427	Fabricated Metal	574,221
MEM	634,697	Food	151,917
MER	-	Furniture	13,676
OFF	491,133	Leather	-
OTH	10,916	Machinery	4,184,614
PAS	-	Miscellaneous	77,136
POS	14,982	Nonmetallic Mineral	9,369
REW	1,009,541	Paper	35,085
SER	1,978,191	Petroleum Refining	297,782
WAS	468,476	Plastic/Rubber	195,814
Total	8,378,282	Primary Metal	316,372
		Printing	75,987
		Textile Mill	73,279
		Textile Product	28,174
		Transportation	36,038
		Wastewater	32,364
		Wood	8,772
		Total	6,390,635

Figure 82 estimates the distribution of annual unplanned system downtime due to motor system failure at a facility. On average, a commercial facility experiences 3 hours per year and an industrial facility experiences 47 hours per year. Note that these failures do not mean that the facility shut down but that the application being driven by the motor system was down.

Figure 82: Distribution of annual unplanned system downtime due to motor system failure.
See Figure 5 for guidance on interpreting box plots.

These estimates provide context for the importance of proper maintenance protocols. To this end, findings on several characteristics of motor system maintenance practices are summarized here, including the repair/replace policy, criteria for selection of replacement motor, and repair history. When querying about motor system maintenance history, facilities were asked to respond with respect to procedures conducted over the previous two years. Since answers to these questions relied on facility staff recalling maintenance performed, the assessment team sought to strike a balance between collecting information over a significant period of time and getting high response rates. For this reason, a two-year time frame was selected.

Industrial sector

In the industrial sector, 54 percent of all facilities have a repair/replace policy, 36 percent do not, and 9 percent were unable to respond to the question. The criteria underpinning the policy in industrial facilities are summarized in Figure 83. When known by the staff queried, cost was the leading criteria. Thirty-six percent of facilities use lowest first cost and 8 percent use lowest lifetime running costs. Cost outweighed speed of replacement, which is used by 7 percent of industrial facilities.

Figure 83: Criteria used for motor repair/replace policy in industrial facilities, percent of facilities.

Figure 84 shows the criteria for selecting the new motor size when replacing the motor. Seventy-four percent of industrial facilities replace the failed motor with one of the same size. Only 3 percent reevaluate system needs and select the motor based on the evaluation results.

Figure 84: Criteria for selecting size of replacement motor in industrial facilities, percent of facilities.

When doing repairs, 12 percent of industrial facilities always use an EASA Accredited or Green Motor Practices Group Motor Service Center, 3 percent mostly do, 4 percent sometimes do, 10 percent never do, and 60 percent did not know. Note that an EASA Accredited service center is more specific than a service center that is a member of EASA. A service center may be a member of EASA but not EASA Accredited.

The most common maintenance procedures are summarized in Table 33. This was determined by asking what percent of motors were maintained for the reasons listed in Table 33 over the past two years. The results show that belt tightening (28 percent) was the most common maintenance procedure. Only 4 percent of motors were rewound over the past two years.

Table 33: Most common motor maintenance procedures in industrial facilities

Motor Maintenance Over the Previous Two Years	Percentage of Motors Maintained (%)
Rewind	4
Bearing replacement	7
Shaft alignment	4
Belt tightening	28
Other	6

Note: Sums will not equal 100% because each maintenance procedure is independent of another.

Motor maintenance for industrial facilities is broken down by size range in Table 34. Aside from belt tightening, which shows no discernible trend with size range, most maintenance procedures occur more frequently as motor size increases.

Table 34: Industrial motor maintenance procedures over the last two years by size range

Size (hp)	Rewind (%)	Bearing Replacement (%)	Shaft Alignment (%)	Belt Tightening (%)	Other (%)
1-5	4	7	4	31	6
6-20	4	8	4	27	6
21-50	5	7	5	26	5
51-100	4	6	5	21	5
101-200	5	8	7	23	7
201-500	5	6	6	30	6
501-1,000	4	5	5	15	6
1,001-2,000	6	8	10	18	12
2,001-5,000	7	7	10	26	21
> 5,001	7	19	10	22	4

Generally, knowledge of motor maintenance scales with motor size. Facilities are more likely to be aware of maintenance to large motors compared to small motors. For example, facilities were unable to provide rewind information on 46 percent of the 1-6 hp motors. This fell to 11 percent for motors between 101-201 hp.

Table 35 shows the maintenance history for industrial pump, fan/blower, and air compressor systems. Air compressor systems are maintained more frequently than fan/blower systems, which are more frequently repaired than pump systems. This may be due to the individual system needs — air compressor systems require more maintenance than pump systems.

Table 35: Maintenance history of industrial motor systems by driven equipment

Equipment	Motor Driven Equipment Maintenance Over the Previous Two Years	% of Industrial Systems
Pumps	Bearing lubrication/replacement	14
	Seal replacement	12
	Ring adjustment or replacement	7
	Impeller replacement	5
	Other	11
Fans/blowers	Bearing lubrication/replacement	31
	Cleaning	50
Air Compressors	Lubrication and filter	71
	Trap inspection	66
	Inlet air filter replacement	73

Note: Sums will not equal 100% because each maintenance procedure is independent of another.

Commercial sector

Sixteen percent of all commercial facilities have a repair/replace policy, 76 percent did not, and 6 percent were unable to respond to the question. The criteria guiding the repair/replace policies are summarized in Figure 85. Most facilities were unable to identify the criteria for their repair/replace policy. When identifiable, lowest first cost (11 percent) and quickest option (10 percent) were the leading criteria.

Figure 85: Criteria used for motor repair/replace policy in commercial facilities, percent of facilities

When replacing a motor, the criteria for selecting the size of the replacement motor are shown in Figure 86. Overwhelmingly, motors were sized to match that of the previous motor.

Figure 86: Criteria for selecting size of replacement motor in commercial facilities, percent of facilities

When doing repairs, 54 percent of commercial facilities did not know if they use an EASA Accredited or Green Motor Practices Group Member Motor Service center, 34 percent never did, and 11 percent did not respond. Note that an EASA Accredited service center is distinct from a service center that is a member of EASA. A service center may be a member of EASA but not EASA Accredited.

Table 36 summarizes motor maintenance history for motors in the commercial sector over the past two years. This was determined by asking what percent of motors were maintained for the reasons listed in Table 36 over the past two years. The results show that belt tightening (18 percent) was the most common maintenance procedure. Less than 1 percent of commercial motors were rewound over the past two years.

Table 36: Most common motor maintenance procedures in commercial facilities

Motor Maintenance Over the Previous Two Years	Percentage of Motors Maintained (%)
Rewind	<1
Bearing replacement	1
Shaft alignment	1
Belt tightening	18
Other	2

Table 37 shows motor maintenance procedures for commercial motors by size range. Rewind, bearing replacement, and shaft alignment are rarely performed across all size ranges, particularly when compared to the frequency of belt tightening.

Table 37: Commercial motor maintenance procedures over the last two years by size range

Size (hp)	Rewind (%)	Bearing Replacement (%)	Shaft Alignment (%)	Belt Tightening (%)	Other (%)
1-5	0	1	1	16	2
6-20	0	1	1	19	1
21-50	1	4	4	33	2
51-100	2	6	8	45	1
101-200	1	4	3	24	3
201-500	1	2	1	28	2
501-1000	1	4	4	47	4
1001-2000	4	6	5	27	3
2001-5000	3	8	4	21	3

Table 38 shows the maintenance history for commercial pump, fan/blower, and air compressor systems. Similar to the industrial sector, air compressor systems are maintained more frequently than fan/blower systems and pump systems. This may be due to the individual system needs — air compressor systems require more maintenance than pump systems. Given the breakout of commercial motor systems (Figure 29 and Figure 31), fan/blower systems are much more common than pump and air compressor systems. From this perspective, proper fan/blower system maintenance would have a greater impact on commercial motor system electricity consumption than pump or air compressor system maintenance.

Table 38: Maintenance history of commercial motor systems by driven equipment

	Motor Driven Equipment Maintenance Over the Previous Two Years	% of Commercial Systems
Pumps	Bearing lubrication/replacement	13
	Seal replacement	11
	Ring adjustment or replacement	2
	Impeller replacement	1
	Other	4
Fans/blower	Bearing lubrication/replacement	10
	Cleaning	26
Air Compressors	Lubrication and filter	36
	Trap inspection	34
	Inlet air filter replacement	35

Note: Sums will not equal 100% because each maintenance procedure is independent of another

Comparison to previous report

To better understand the changes in motor system operating characteristics over time, the results from this MSMA were compared to the previous MSMA (2002 report) for the industrial sector. Some of the findings where direct comparisons could be made are detailed below. Comparisons to the previous commercial sector motor system study were not made, since it utilized a different methodology and did not rely on primary data collection.

The results show significant improvements in load factor. The 2002 report found that 44 percent of all industrial motor systems operated below 40 percent motor load. The current study finds that this has improved drastically, and only 8 percent of all industrial motor systems now operate below 40 percent motor load. Part of the difference between 2002 and now could be attributed to greater awareness of the impact of load factor on lifetime operating costs. It could also be attributable to the methodologies employed by the different studies to determine the load factor. The 2002 report relied on spot measurements, whereas this report relied on facility staff interviews.

In terms of load control, the previous MSMA study found that 9 percent of industrial motor systems and 4 percent of industrial motor system electricity consumption utilized an adjustable speed drive (ASD). The report describes ASDs as being synonymous with VFDs. In this report, 19 percent of industrial motor systems had some sort of control technology (6 percent have a VFD and 13 percent had another load control technology). Twenty-three percent of industrial motor system electricity consumption was under a load control technology (6 percent utilized a VFD and 17 percent utilized another technology type).

In terms of energy management practices, the location of motor system-related decisions remains mostly at the facility. In 2002, 91 percent of motor system-related decisions were made at the facility, whereas this report finds that 81 percent of these decisions are now made at the facility. While there is a slight decline, the overwhelming majority of facilities still make motor system-related decisions at the facility.

The title of the person making motor system-related decisions has changed drastically. In 2002, the president/general manager made these decisions at 40 percent of facilities, and the plant manager did so at 13 percent of facilities. This is nearly reversed in the current report. Motor system-related decisions are made by the plant/facility manager at 48 percent of facilities and by the general manager/president at 9 percent of facilities.

Motor maintenance practices have also changed in a few key areas. In 2002, 20-91 percent of motors were rewound depending on the horsepower size. The current report finds that only 4-7 percent of motors are rewound depending on the size. The 2002 report considered rewinds over the lifetime of the motor, whereas the current study only asked about rewinds over the last two years. This could explain some of the difference. Greater awareness of the benefits of instituting a repair/replace policy also could explain these differences. When replacing a motor, fewer facilities look at first cost now, compared to 2002. In 2002, 62 percent of facilities looked at capital cost, whereas this report found that 36 percent look at lowest first cost now. Finally, when replacing a motor, 55 percent in 2002 always replaced a motor with one that matched the

previous size. The current study finds that 74 percent replace the motor with one of the same horsepower size.

Highlights

Load factor (percent of full speed load)

- Thirty-four percent of industrial sector motor system electricity consumption operates at variable load, with load factors between 40 percent and 75 percent (see Table 24).
- Forty-three percent of industrial sector motor system units operate at constant loads greater than 75 percent of full load (see Table 25).
- Forty percent of commercial sector motor system electricity consumption operates at variable load, with load factors between 40 percent and 75 percent (see Table 26).
- Thirty-six percent of commercial sector motor system units operate at variable loads, with load factors between 40 percent and 75 percent (see Table 27).
- Very little of industrial or commercial motor system electricity consumption operates at load factors under 40 percent load. Only 6 percent of industrial sector motor system electricity consumption (1 percent from constant load systems and 5 percent from variable load systems) and 9 percent of the industrial motor systems (1 percent from constant load systems and 8 percent from variable load systems) operate under 40 percent load factor. Only 3 percent of the commercial sector motor system electricity consumption (0 percent from constant load systems and 3 percent from variable load systems) and units (0 percent from constant load units and 3 percent from variable load units) operate under 40 percent of load factor (see Table 24, Table 25, Table 26, and Table 27).

Load control

- On average, 16 percent of motor system capacity at an industrial facility use VFDs and 74 percent has no load control technology/equipment (see Figure 59).
- The rate of installation of VFDs and other load control technologies in the industrial and commercial sectors increases with motor system size (see Figure 62 and Figure 68).
- On average, 4 percent of motor system capacity at a commercial facility uses VFDs, and 91 percent has no load control technology/equipment (see Figure 66).
- The share of motor system capacity with a VFD increases with increasing facility size for both the industrial and commercial sectors. In the industrial sector, 17 percent of motor system capacity in large facilities is on a VFD, compared to 8 percent in small facilities. Similarly, 10 percent of the motor system capacity in large commercial facilities is on a VFD, compared to 2 percent in small commercial facilities (see Figure 60 and Figure 67).
- The uptake of VFDs by driven equipment type in the industrial sector is nearly uniform, at about 23 percent of electricity consumption for each equipment type, with most operating using temperature or pressure setpoints as the control mechanism (see Figure 63 and Figure 64).

- The uptake of VFDs by driven equipment type in the commercial sector varies but is highest for fan and blower systems (37 percent). The most common metric for VFD control on commercial sector fans/blowers and pumping systems is pressure setpoint (see Figure 72).

Transmission type

- Thirty-four percent of industrial sector motor systems and 44 percent of commercial sector motor systems use direct drive transmission to convey motor shaft power to the end-use equipment. Direct shaft drive is the most common transmission type observed across both sectors (see Figure 73 and Figure 75).

Motor system energy management

- Forty-nine percent of industrial facilities consider energy efficiency in the procurement of motor system components, and 58 percent consider energy efficiency in the design of new motor systems (see Figure 77 and Figure 78).
- Large industrial facilities are more likely to consider energy efficiency in the procurement and design of motor systems and related components compared to small facilities. It was also observed that facilities of any size are more likely to make motor system-related decisions at the facility level (as opposed to the corporate level) (see Figure 77, Figure 78, and Table 29).
- Fifty-nine percent of commercial facilities consider energy efficiency in the procurement of motor system components, and 67 percent consider energy efficiency in the design of new motor systems (see Figure 79 and Figure 80).
- Large commercial facilities are less likely to consider energy efficiency in the procurement and/or design of motor systems and related components compared to small facilities. It was also observed that facilities of any size are more likely to make motor system-related decisions at the facility level (as opposed to a corporate office) (see Figure 79, Figure 80, and Table 29).
- Across all industrial facilities, external energy assessments were the most common method for identifying energy efficiency measures, with 59 percent utilizing external assessors (see Table 30).
- Across all commercial facilities, peer-to-peer knowledge sharing is the most common method for identifying energy efficiency measures, with 13 percent of facilities utilizing this method (see Table 30).
- Thirteen percent of industrial facilities and 18 percent of commercial facilities had an inventory of all their motors, spare and connected (see Table 31).

Motor system maintenance

- It is estimated that commercial and industrial facilities experience more than 8 million and 6 million hours annually of unplanned motor system downtime, respectively, due to failure (see Table 32).
- On average, a commercial facility experiences three hours of unplanned motor system downtime due to failure per year, and an industrial facility experiences 47 hours per year (see Figure 82).

- In the industrial sector, 54 percent of all facilities have a repair/replace policy, with the leading criteria guiding the policy being lowest first cost, which is used by 36 percent of facilities (see Figure 83).
- The most common maintenance procedure for industrial motor systems (over the previous two years) is belt tightening, which was performed for 28 percent of industrial motor systems. Four percent of industrial motors were rewound over the previous two years (see Table 33).
- In the commercial sector, 16 percent of all facilities have a repair/replace policy. Most facilities were unaware of the criteria underpinning the policy. The most commonly cited criteria guiding the policy are lowest first cost (11 percent) and quickest option (10 percent) (see Figure 85).
- The most common maintenance procedure for commercial motor systems (over the previous two years) is belt tightening (18 percent). Less than 1 percent of commercial motors were rewound over the previous two years (see Table 36).

References

Arthur D. Little (1999) *Opportunities for Energy Savings in the Residential and Commercial Sectors with High-Efficiency Electric Motors*.

International Energy Agency (2007) *Tracking Industrial Energy Efficiency and CO₂ Emissions, Tracking Industrial Energy Efficiency and CO₂ Emissions*. doi: 10.1787/9789264030404-en.

McKane, A., and A. Hasanbeigi (2011) “Motor systems energy efficiency supply curves: A methodology for assessing the energy efficiency potential of industrial motor systems.” *Energy Policy*. doi: 10.1016/j.enpol.2011.08.004.

NAICS Association. No date. 2213 - Water, Sewage and Other Systems.
<https://www.naics.com/naics-code-description/?code=2213>.

Rao, P. et al. (2016) *Assessing Energy Efficiency Opportunities in US Industrial and Commercial Building Motor Systems*. Berkeley, California.

Rao, P., Sheaffer, P. and Scheihing, P. (2017) “Methodology for Assessing the US Industrial and Commercial Motor System Market Assessment.” In *Energy Efficiency in Motor Driven Systems*. Rome, Italy.

UNIDO (2010) “Motor Systems Efficiency Supply Curves.” *United Nations Industrial Development Organisation (UNIDO)*.

U.S. Bureau of Labor Statistics. (No date) Industries by Supersector and NAICS Code.
https://www.bls.gov/iag/tgs/iag_index_naics.htm.

U.S. Department of Energy. (1989) *Improving Fan System Performance: A sourcebook for industry*. Energy Efficiency and Renewable Energy.
<https://www.nrel.gov/docs/fy03osti/29166.pdf>.

U.S. Department of Energy (2002) *United States Industrial Electric Motor Systems Market Opportunities Assessment*. <https://www.energy.gov/sites/prod/files/2014/04/f15/mtrmkt.pdf>.

U.S. Department of Energy (2012) *Replace V-Belts with Notched or Synchronous Belt Drives*. EERE. Advanced Manufacturing Office.
https://www.energy.gov/sites/prod/files/2014/04/f15/replace_vbelts_motor_systemts5.pdf.

U.S. Department of Energy (2015) *Energy Conservation Program: Energy Conservation Standards for Pumps*. 10 CFR Parts 429 and 431. Docket Number EERE–2011–BT–STD–0031. RIN 1904-AC54.
<https://www.energy.gov/sites/prod/files/2015/12/f28/Pumps%20ECS%20Final%20Rule.pdf>.

U.S. Department of Energy (2017) *10 CFR Parts 429 and 431. Docket Number EERE-2013-BT-STD-0040. RIN 1904-AC83. Energy Conservation Program: Energy Conservation Standards for Air Compressors*.
https://www.energy.gov/sites/prod/files/2016/12/f34/Compressors_Standards_Final_Rule.pdf.

U.S. Energy Information Administration (1999, 2003, 2012) CBECS Terminology. Commercial Buildings Energy Consumption Survey (CBECS).
https://www.bls.gov/iag/tgs/iag_index_naics.htm.

U.S. Energy Information Administration (2012) Commercial Building Energy Consumption Survey. <https://www.eia.gov/consumption/commercial/>

U.S. Energy Information Administration (2014) Manufacturing Energy Consumption Survey. <https://www.eia.gov/consumption/manufacturing/>

Waide, P., and C. U. Brunner (2011) “Energy-Efficiency Policy Opportunities for Electric Motor-Driven Systems.” *Internationale energy agency*. doi: 10.1787/5kgg52gb9gjd-en.

Glossary

Air (or gas) compressor - a machine or apparatus that converts different types of energy into the potential energy of gas (air or other, such as nitrogen) pressure for displacement and compression of gaseous media to any higher pressure values above atmospheric pressure and has a pressure ratio at full-load operating pressure greater than 1.3. Generally in this report, these will be air compressors. (U.S. Department of Energy, 2017)

Air handling - a system of components, including fan and ducting, used to move conditioned air from location to location.

Apparel - industries in the Apparel Manufacturing subsector group establishments with two distinct manufacturing processes: (1) cut and sew (i.e., purchasing fabric and cutting and sewing to make a garment), and (2) the manufacture of garments in establishments that first knit fabric and then cut and sew the fabric into a garment. The Apparel Manufacturing subsector includes a diverse range of establishments manufacturing full lines of ready-to-wear apparel and custom apparel: apparel contractors, performing cutting or sewing operations on materials owned by others; jobbers performing entrepreneurial functions involved in apparel manufacture; and tailors, manufacturing custom garments for individual clients are all included. Knitting, when done alone, is classified in the Textile Mills subsector, but when knitting is combined with the production of complete garments, the activity is classified in Apparel Manufacturing. (U.S. Bureau of Labor Statistics, No date)

Belt - a transmission type whereby the motor shaft is connected to the driven equipment through use of a band of flexible material.

Beverage and Tobacco Products - industries in the Beverage and Tobacco Product Manufacturing subsector manufacture beverages and tobacco products. The industry group, Beverage Manufacturing, includes three types of establishments: (1) those that manufacture nonalcoholic beverages; (2) those that manufacture alcoholic beverages through the fermentation process; and (3) those that produce distilled alcoholic beverages. Ice manufacturing, while not a beverage, is included with nonalcoholic beverage manufacturing because it uses the same production process as water purification. The industry group, Tobacco Manufacturing, includes two types of establishments: (1) those engaged in redrying and stemming tobacco and, (2) those that manufacture tobacco products, such as cigarettes and cigars. (U.S. Bureau of Labor Statistics, No date)

Chemicals - The Chemical Manufacturing subsector is based on the transformation of organic and inorganic raw materials by a chemical process and the formulation of products. This subsector distinguishes the production of basic chemicals that comprise the first industry group from the production of intermediate and end products produced by further processing of basic chemicals that make up the remaining industry groups. (U.S. Bureau of Labor Statistics, No date)

Cog belt - a belt type that is toothed and requires the installation of mating grooved sprockets. These are also called synchronous belts. (U.S. Department of Energy, 2012)

Compressed air plant - the air compressor(s) and all ancillary equipment supporting the air compressor(s), such as dryers, receiving/storage tanks, valves, etc.

Computer and Electronic Products - industries in the Computer and Electronic Product Manufacturing subsector group establishments that manufacture computers, computer peripherals, communications equipment, and similar electronic products, and establishments that manufacture components for such products. The design and use of integrated circuits and the application of highly specialized miniaturization technologies are common elements in the production technologies of the computer and electronic subsector.

Conveying - transfer of materials and unfinished goods from one location to another within the manufacturing process.

DC motor - direct current motor. Note that advanced motor designs, like permanent magnet and synchronous motors are categorized as AC motors.

Direct shaft - transmission type whereby the motor shaft is directly coupled to the driven equipment and thereby on the same axis of rotation without any change in speed or translation of motion.

Education - buildings used for academic or technical classroom instruction, such as elementary, middle, or high schools, and classroom buildings on college or university campuses. Buildings on education campuses for which the main use is not classroom are included in the category relating to their use. For example, administration buildings are part of "Office," dormitories are "Lodging," and libraries are "Public Assembly." This includes, but is not limited to: elementary or middle school, high school, college or university, preschool or daycare, adult education, career or vocational training, and religious education. (U.S. Energy Information Administration, 1999, 2003, 2012)

Electrical Equipment and Appliances - Industries in the Electrical Equipment, Appliance, and Component Manufacturing subsector manufacture products that generate, distribute, and use electrical power. Electric Lighting Equipment Manufacturing establishments produce electric lamp bulbs, lighting fixtures, and parts. Household Appliance Manufacturing establishments make both small and major electrical appliances and parts. Electrical Equipment Manufacturing establishments make goods, such as electric motors, generators, transformers, and switchgear apparatus. Other Electrical Equipment and Component Manufacturing establishments make devices for storing electrical power (e.g., batteries), for transmitting electricity (e.g., insulated wire), and wiring devices (e.g., electrical outlets, fuse boxes, and light switches). (U.S. Bureau of Labor Statistics, No date)

Exhausting/scrubbing - emissions control through ventilation of polluted, contaminated, or otherwise undesirable air.

Extrusion - a manufacturing process by which material is formed by forcing it through a mold or die.

Fabricated Metal Products - Industries in the Fabricated Metal Product Manufacturing subsector transform metal into intermediate or end products, other than machinery, computers and electronics, and metal furniture, or treat metals and metal formed products fabricated elsewhere. Important fabricated metal processes are forging, stamping, bending, forming, and machining, used to shape individual pieces of metal; and other processes, such as welding and assembling, used to join separate parts together. Establishments in this subsector may use one of these processes or a combination of these processes. (U.S. Bureau of Labor Statistics, No date)

Fan/blower - a power-driven machine that moves a continuous volume of air by converting rotational/mechanical energy to an increase in the total pressure of the moving air below a pressure ratio at full load of 1.3. (U.S. Department of Energy, 1989)

Food Products - Industries in the Food Manufacturing subsector transform livestock and agricultural products into products for intermediate or final consumption. The industry groups are distinguished by the raw materials (generally of animal or vegetable origin) processed into food products. The food products manufactured in these establishments are typically sold to wholesalers or retailers for distribution to consumers, but establishments primarily engaged in retailing bakery and candy products made on the premises not for immediate consumption are included. (U.S. Bureau of Labor Statistics, No date)

Food Sales - buildings used for retail or wholesale of food. This includes, but is not limited to: grocery store or food market, gas station with a convenience store, and convenience store. (U.S. Energy Information Administration, 1999, 2003, 2012)

Food Services - buildings used for preparation and sale of food and beverages for consumption. This includes, but is not limited to: fast food, restaurant or cafeteria, bar, catering service or reception hall, coffee/bagel/doughnut shop, and ice cream/frozen yogurt shop. (U.S. Energy Information Administration, 1999, 2003, 2012)

Furniture and Related Products - Industries in the Furniture and Related Product Manufacturing subsector make furniture and related articles, such as mattresses, window blinds, cabinets, and fixtures. The processes used in the manufacture of furniture include the cutting, bending, molding, laminating, and assembly of such materials as wood, metal, glass, plastics, and rattan. However, the production process for furniture is not solely bending metal, cutting and shaping wood, or extruding and molding plastics. Design and fashion trends play an important part in the production of furniture. The integrated design of the article for both esthetic and functional qualities is also a major part of the process of manufacturing furniture. Design services may be performed by the furniture establishment's work force or may be purchased from industrial designers. (U.S. Bureau of Labor Statistics, No date)

Gearbox - a gear assembly/system and its housing used to transmit power.

Health Care: Inpatient - buildings used as diagnostic and treatment facilities for inpatient care. This includes, but is not limited to: hospitals and inpatient rehabilitation. (U.S. Energy Information Administration, 1999, 2003, 2012)

Health Care: Outpatient - buildings used as diagnostic and treatment facilities for outpatient care. Medical offices are included here if they use any type of diagnostic medical equipment (if they do not, they are categorized as an office building). This includes, but is not limited to: medical office, clinic or other outpatient health care, outpatient rehabilitation, and veterinarian. (U.S. Energy Information Administration, 1999, 2003, 2012)

Hot water/steam plant - equipment, including boilers, pumps, condensate return tanks, and other, used to generate steam or hot water.

Hydraulic system - a system that relies on pressurized fluids, such as water, to transmit power generated by a motor.

Leather and Allied Products - Establishments in the Leather and Allied Product Manufacturing subsector transform hides into leather by tanning or curing and fabricating the leather into products for final consumption. It also includes the manufacture of similar products from other materials, including products (except apparel) made from “leather substitutes,” such as rubber, plastics, or textiles. Rubber footwear, textile luggage, and plastics purses or wallets are examples of “leather substitute” products included in this group. The products made from leather substitutes are included in this subsector because they are made in similar ways leather products are made (e.g., luggage). They are made in the same establishments, so it is not practical to separate them. (U.S. Bureau of Labor Statistics, No date)

Load factor - the ratio of average motor output power to the motor’s rated power. For example, a motor rated at 100 hp but only operating at 40 hp would have a load factor of 0.4.

Lodging (includes Nursing) - buildings used to offer multiple accommodations for short-term or long-term residents, including skilled nursing and other residential care buildings. This includes, but is not limited to: motel or inn, hotel, dormitory, fraternity or sorority, retirement home, nursing home, assisted living or other residential care, convent or monastery, shelter, orphanage or children’s home, and halfway house. (U.S. Energy Information Administration, 1999, 2003, 2012)

Machinery - Industries in the Machinery Manufacturing subsector create end products that apply mechanical force, for example, the application of gears and levers, to perform work. Some important processes for the manufacture of machinery are forging, stamping, bending, forming, and machining that are used to shape individual pieces of metal. Processes, such as welding and assembling are used to join separate parts together. Although these processes are similar to those used in metal fabricating establishments, machinery manufacturing is different because it typically employs multiple metal forming processes in manufacturing the various parts of the machine. Moreover, complex assembly operations are an inherent part of the production process. (U.S. Bureau of Labor Statistics, No date)

Material(s) handling - Materials handling includes motor systems that transport materials, such as conveyor motors.

Material(s) processing - Materials processing includes motor systems that use mechanical means to process materials. Examples include grinders, hydraulics, and extruder motors.

Material(s) shaping - physical deformation of materials into a desired shape. Examples include stamping, bending, machining, and forging.

Mercantile: Retail (other than mall) - buildings used for the sale and display of goods other than food. This includes, but is not limited to: retail store, beer/wine/liquor store, rental center, dealership or showroom for vehicles or boats, and studio/gallery. (U.S. Energy Information Administration, 1999, 2003, 2012)

Mercantile: Enclosed and Strip Malls - Shopping malls comprised of multiple connected establishments. This includes, but is not limited to enclosed malls and strip shopping centers. (U.S. Energy Information Administration, 1999, 2003, 2012)

Miscellaneous - Industries in the Miscellaneous Manufacturing subsector make a wide range of products that cannot readily be classified in specific NAICS subsectors in manufacturing. Processes used by these establishments vary significantly, both among and within industries. For example, a variety of manufacturing processes are used in manufacturing sporting and athletic goods that include products such as tennis racquets and golf balls. The processes for these products differ from each other, and the processes differ significantly from the fabrication processes used in making dolls or toys, the melting and shaping of precious metals to make jewelry, and the bending, forming, and assembly used in making medical products. (U.S. Bureau of Labor Statistics, No date)

Municipal Wastewater Treatment - This industry group comprises establishments primarily engaged in operating sewer systems or sewage treatment facilities. This does not include transfer to and away from the wastewater facility. (NAICS Association, No date)

Nonmetallic Mineral Products - The Nonmetallic Mineral Product Manufacturing subsector transforms mined or quarried nonmetallic minerals, such as sand, gravel, stone, clay, and refractory materials into products for intermediate or final consumption, such as glass and cement. Processes used include grinding, mixing, cutting, shaping, and honing. Heat often is used in the process and chemicals are frequently mixed to change the composition, purity, and chemical properties for the intended product. For example, glass is produced by heating silica sand to the melting point (sometimes combined with cullet or recycled glass) and then drawn, floated, or blow molded to the desired shape or thickness. Refractory materials are heated and then formed into bricks or other shapes for use in industrial applications.

Office - Buildings used for general office space, professional office, or administrative offices. Medical offices are included here if they do not use any type of diagnostic medical equipment (if they do, they are categorized as an outpatient health care building). This includes, but is not limited to: administrative or professional office, government office, mixed-use office, bank or other financial institution, medical office, sales office, contractor's office (e.g., construction, plumbing, HVAC), nonprofit or social services, city hall or city center, religious office, and call center. (U.S. Energy Information Administration, 1999, 2003, 2012)

Other and Vacant - buildings that are industrial or agricultural with some retail space; buildings having several different commercial activities that, together, comprise 50 percent or more of the floorspace, but whose largest single activity is agricultural, industrial/manufacturing, or residential; buildings in which more floorspace was vacant than was used for any single commercial activity at the time of interview. Therefore, a vacant building may have some occupied floorspace; and all other miscellaneous buildings that do not fit into any other category. This includes, but is not limited to: airplane hangar, crematorium, laboratory, telephone switching, agricultural with some retail space, manufacturing or industrial with some retail space, data center, or server farm. (U.S. Energy Information Administration, 1999, 2003, 2012)

Other processing - processing other than conveying, extruding, materials handling, materials processing, materials shaping, process heating, product transfer, screening/filtration/separation, and wastewater management.

Paper and Allied Products - Industries in the Paper Manufacturing subsector make pulp, paper, or converted paper products. The manufacturing of these products is grouped together because they constitute a series of vertically connected processes. More than one is often carried out in a single establishment. There are essentially three activities. The manufacturing of pulp involves separating the cellulose fibers from other impurities in wood or used paper. The manufacturing of paper involves matting these fibers into a sheet. Converted paper products are made from paper and other materials by various cutting and shaping techniques and include coating and laminating activities. (U.S. Bureau of Labor Statistics, No date)

Petroleum and Coal Products - The Petroleum and Coal Products Manufacturing subsector is based on the transformation of crude petroleum and coal into usable products. The dominant process is petroleum refining that involves the separation of crude petroleum into component products through such techniques as cracking and distillation. In addition, this subsector includes establishments that primarily further process refined petroleum and coal products and produce products, such as asphalt coatings and petroleum lubricating oils. (U.S. Bureau of Labor Statistics, No date)

Plastic and Rubber Products - Industries in the Plastics and Rubber Products Manufacturing subsector make goods by processing plastics materials and raw rubber. The core technology employed by establishments in this subsector is that of plastics or rubber product production. Plastics and rubber are combined in the same subsector because plastics are increasingly being used as a substitute for rubber; however, the subsector is generally restricted to the production of products made of just one material, either solely plastics or rubber. (U.S. Bureau of Labor Statistics, No date)

Primary Metals - Industries in the Primary Metal Manufacturing subsector smelt and/or refine ferrous and nonferrous metals from ore, pig, or scrap, using electrometallurgical and other process metallurgical techniques. Establishments in this subsector also manufacture metal alloys and superalloys by introducing other chemical elements to pure metals. The output of smelting and refining, usually in ingot form, is used in rolling, drawing, and extruding operations to make

sheet, strip, bar, rod, or wire, and in molten form to make castings and other basic metal products. (U.S. Bureau of Labor Statistics, No date)

Printing and Related Support - Industries in the Printing and Related Support Activities subsector print products, such as newspapers, books, labels, business cards, stationery, business forms, and other materials, and perform support activities, such as data imaging, platemaking services, and bookbinding. The support activities included here are an integral part of the printing industry, and a product (a printing plate, a bound book, or a computer disk or file) that is an integral part of the printing industry is almost always provided by these operations. (U.S. Bureau of Labor Statistics, No date)

Process/equipment cooling - cooling equipment, materials, process lines, and auxiliary equipment.

Process heating - heating materials and/or process lines to a desired temperature as part of the manufacturing process.

Product transfer - moving a final product from one location to another (e.g., stocking in a warehouse).

Public Assembly - buildings in which people gather for social or recreational activities, whether in private or non-private meeting halls. This includes, but is not limited to: social or meeting (e.g., community center, lodge, meeting hall, convention center, senior center), recreation (e.g., gymnasium, health club, bowling alley, ice rink, field house, indoor racquet sports), entertainment or culture (e.g., museum, theater, cinema, sports arena, casino, nightclub), library, funeral home, student activities center, armory, exhibition hall, broadcasting studio, and transportation terminal. (U.S. Energy Information Administration, 1999, 2003, 2012)

Public Order and Safety - buildings used for the preservation of law and order or public safety. This includes, but is not limited to: police station, fire station, jail/reformatory/penitentiary, and courthouse or probation office. (U.S. Energy Information Administration, 1999, 2003, 2012)

Pump - equipment designed to move liquids (which may include entrained gases, free solids, and totally dissolved solids) by physical or mechanical action. (U.S. Department of Energy, 2015)

Refrigeration compressors - a mechanical device that employs the vapor-compression cycle to move heat from a higher reservoir to a lower one for the effect of cooling the higher reservoir. A chiller is a common example of a refrigeration compressor.

Religious worship - buildings in which people gather for religious activities, (such as chapels, churches, mosques, synagogues, and temples).

Screening/Filtration/Separation - physical separation of one material from another based on physical size.

Service - buildings in which some type of service is provided, other than food service or retail sales of goods. This includes, but is not limited to: vehicle service or vehicle repair shop, vehicle storage/ maintenance (car barn), repair shop, dry cleaner or laundromat, post office or postal center, car wash, gas station, photo processing shop, beauty parlor or barber shop, tanning salon, copy center or printing shop, and kennel. (U.S. Energy Information Administration, 1999, 2003, 2012)

Space cooling - cooling of a physical space for the purposes of maintaining desired ambient temperature and humidity, often for the purposes of human comfort.

Space heating - heating of a physical space for the purposes of maintaining desired ambient temperature, often for the purposes of human comfort.

Synchronous belt - a belt type that is toothed and requires the installation of mating grooved sprockets. These are also called cog belts. (U.S. Department of Energy, 2012)

Textile Mills - industries in the Textile Mills subsector group establishments that transform a basic fiber (natural or synthetic) into a product, such as yarn or fabric that is further manufactured into usable items, such as apparel, sheets, towels, and textile bags for individual or industrial consumption. The further manufacturing may be performed in the same establishment and classified in this subsector, or it may be performed at a separate establishment and be classified elsewhere in manufacturing. (U.S. Bureau of Labor Statistics, No date)

Textile Product Mills - industries in the Textile Product Mills subsector group establishments that make textile products (except apparel). With a few exceptions, processes used in these industries are generally cut and sew (i.e., purchasing fabric and cutting and sewing it to make non-apparel textile products, such as sheets and towels). (U.S. Bureau of Labor Statistics, No date)

Transportation Equipment - Industries in the Transportation Equipment Manufacturing subsector produce equipment for transporting people and goods. Transportation equipment is a type of machinery. An entire subsector is devoted to this activity because of the significance of its economic size in all three North American countries. Establishments in this subsector utilize production processes similar to those of other machinery manufacturing establishments — bending, forming, welding, machining, and assembling metal or plastic parts into components and finished products. However, the assembly of components and subassemblies and their further assembly into finished vehicles tends to be a more common production process in this subsector than in the Machinery Manufacturing subsector. (U.S. Bureau of Labor Statistics, No date)

Unable to collect - The assessment team was unable to collect or request this information. This is different from “do not know” or “no,” where the team was able to request the information.

V-belt - a belt type that uses a trapezoidal cross section to create a wedging action on the pulleys to increase friction and improve the belt’s power transfer capability. (U.S. Department of Energy, 2012)

Warehouse and Storage - buildings used to store goods, manufactured products, merchandise, raw materials, or personal belongings (such as self-storage). This includes, but is not limited to: refrigerated warehouse, non-refrigerated warehouse, and distribution or shipping center. (U.S. Energy Information Administration, 1999, 2003, 2012)

Wastewater management - any process or equipment associated with the treatment of wastewater for safe disposal or transfer offsite. This does not include distribution of wastewater outside of the facility.

Wood Products - Industries in the Wood Product Manufacturing subsector manufacture wood products, such as lumber, plywood, veneers, wood containers, wood flooring, wood trusses, manufactured homes (i.e., mobile homes), and prefabricated wood buildings. The production processes of the Wood Product Manufacturing subsector include sawing, planing, shaping, laminating, and assembling of wood products starting from logs that are cut into bolts, or lumber that then may be further cut, or shaped by lathes or other shaping tools. The lumber or other transformed wood shapes may also be subsequently planed or smoothed, and assembled into finished products, such as wood containers. The Wood Product Manufacturing subsector includes establishments that make wood products from logs and bolts that are sawed and shaped, and establishments that purchase sawed lumber and make wood products. With the exception of sawmills and wood preservation establishments, the establishments are grouped into industries mainly based on the specific products manufactured. (U.S. Bureau of Labor Statistics, No date)

Appendix A: Sampling Allocation

Units of analysis

The MSMA was designed to obtain data on motor use from industrial and commercial sites. The overall sample size for each sector was set at 300 industrial and 150 commercial sites.

For the industrial sector, a site was an “establishment,” meaning a particular business at a physical location. Thus, for example, if a manufacturing complex is renting out space to two different businesses, it counts as two establishments. Conversely, if an industrial business has several buildings at a particular location (e.g., a campus), all its buildings belong to the site that might be selected for an MSMA onsite inventory.

Non-vacant, operational industrial establishments with six or more employees are eligible for the study. The MSMA excludes establishments with zero to five employees. This restriction is consistent with the target population for the Energy Information Administration’s (EIA) Manufacturing Energy Consumption Survey (MECS).

For the commercial sector, a site was a commercial building. If a single commercial building includes multiple businesses, all these businesses are included in the commercial site for purposes of the MSMA inventory. A strip mall is counted as a single building.

Only buildings greater than 1,000 square feet are eligible for the MSMA. This is consistent with the target population for the EIA’s Commercial Buildings Energy Consumption Survey (CBECS).

Data sources for the population characteristics and sampling frame

To determine the sample allocation to industrial and commercial subsectors overall, and by finer subdivisions within subsectors, the sample design relied on the 2010 MECS and 2012 CBECS data to represent the national populations of manufacturing facilities and commercial buildings, respectively. These are nationally representative samples of thousands of sites each. The datasets include estimates of energy use by various decompositions and in relation to site characteristics. In particular, they provide estimates of electricity use by functional end use. These estimates provide a foundation for designing a study of motor energy use.

The MECS and CBECS provide aggregate estimates at the subsector level that are used to determine the target sample sizes. However, these survey samples are confidential. To fulfill the targeted sample sizes, a list frame was used for each sector, the MNI U.S. Manufacturing Industry Database for the industrial sector and the SMR Enhanced Commercial Property Database for the commercial sector.

Sample stratification

The sample allocation was designed to provide some coverage for each manufacturing and commercial subsector, with acceptable overall precision at the sector level, subject to the overall

sample size constraints. To meet these objectives, the sample was stratified by commercial or industrial subsector, and by size. Each subsector was divided into three size bins, where the size cut points for each subsector were defined by an employment level. The subsector cut points were set such that the small-, medium-, and large-size bins accounted for roughly 25 percent, 50 percent, and 25 percent, respectively, of the subsector's total employment. These proportions were not exact because the cut points had to align with the available data categories in the sources. For the commercial subsectors, the establishment cut points were mapped to floorspace cut points based on the subsector's employees per square foot.

Setting cut points at roughly these proportions was a subjective decision. Creating roughly equal measures of size in each size bin is generally a fairly efficient strategy. Using a 25/50/25 split instead of 33/33/33 makes a more targeted definition of high, with potentially somewhat lower variability, and reduces the number of very small sites that will be included.

The employment data by cut point came from the 2012 CBECS for commercial subsectors and from the 2013 County Business Patterns (CBP) for industrial sectors. Table 39 shows the size bin cut points for each subsector.

Table 39: Size cut points by subsector

Industrial Subsector	Small Upper Bound Employment	Medium Upper Bound Employment
Food Products	99	999
Beverage and Tobacco Products	49	499
Textile Mills	49	249
Textile Product Mills	49	249
Apparel	19	249
Leather and Allied Products	49	499
Wood Products	49	249
Paper and Allied Products	99	499
Printing and Related Support	19	249
Petroleum and Coal Products	99	999
Chemicals	99	499
Plastic and Rubber Products	49	499
Nonmetallic Mineral Products	19	249
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	99	999
Primary Metals: Other	99	499
Fabricated Metal Products	49	249
Machinery	49	499
Computer and Electronic Products	99	999
Electrical Equipment and Appliances	99	499
Transportation Equipment	249	999
Furniture and Related Products	49	499
Miscellaneous	49	499

Table 39: Size cut points by subsector (cont'd)

Commercial Subsector	Small Upper Bound Square Feet	Medium Upper Bound Square Feet
Education	17,500	128,000
Food Sales	3,500	34,000
Food Services	3,000	9,500
Health Care: Inpatient	240,000	900,000
Health Care: Outpatient	9,000	69,000
Lodging (Includes Nursing)	20,000	215,000
Mercantile: Retail (other than mall)	7,000	110,000
Mercantile: Enclosed and Strip Malls	22,500	150,000
Office	18,000	250,000
Public Assembly	9,000	360,000
Public Order and Safety	9,500	160,000
Religious Worship	5,000	29,500
Service	5,000	26,000
Warehouse and Storage	12,000	136,000
Other (Includes CBECS = Other, Laboratory) and Vacant	15,000	114,000

Metrics used for sample allocation

To allocate the sample to subsector-size bins, two key metrics used were (1) the magnitude of estimated motor system electricity consumption and (2) its variability (standard deviation) across establishments within the subsector. Motor system electricity consumption and standard deviation were estimated as follows.

For industrial subsectors, motor electricity consumption for each subsector was calculated as the sum of net electricity use for process cooling and refrigeration, motor drive, and facility HVAC, from EIA's 2010 MECS (Table 5.2). For commercial subsectors, the motor electricity consumption was calculated as the sum of the subsector's 2012 CBECS cooling, ventilation, refrigeration, and miscellaneous uses (Table E3). The ratio of this estimated motor electricity consumption to the corresponding subsector establishments or buildings from the MECS or CBECS was then calculated.

The standard deviation of motor system electricity consumption across establishments or buildings was estimated for each subsector based on the standard errors and sample sizes from the MECS and CBECS. The standard deviation was calculated as the product of the standard error and the square root of the sample size.

Sample sizes by commercial and industrial subsector

Each sector's total sample was allocated to subsectors using a few different methods (1-4 below), and these different results were considered in the final allocation (5), which balanced these.

1. Optimal allocation to produce best possible precision for the sector in total. This is the standard Neyman-Pearson allocation formula, where the sample size for each subsector is proportional to the product of population size (in this case, number of establishments) and standard deviation (in this case, estimated standard deviation of motor electricity consumption).
2. Allocation proportional to estimated motor electricity consumption.
3. Allocation proportional to number of establishments.
4. A judgmental allocation of a minimum of seven per subsector.
5. After reviewing the other allocations, a final allocation that balanced the objectives was selected: (a) ensure some minimal representation for each subsector, (b) ensure sectors contributing more to total sector motor energy use have higher allocations, and (c) ensure acceptable precision for the sector motor energy use estimate in total.

Based on the estimated standard deviations and the target sample sizes, overall precision at 90 percent confidence was projected at 8.0 percent for the industrial sector ($n = 300$) and 26.3 percent for the commercial sector ($n = 150$).

Allocation to size bins within a subsector

After the subsector-level allocations were determined, these were allocated to size bins within each subsector. The allocation to size bins within a subsector was proportional to the product of the number of establishments and a sector-wide size bin scaling factor. The effect of this allocation was to put a little under 20 percent of the sample in the small bin and a little over 40 percent each in the medium and large bins, with some variation across subsectors.

Table 40 and Table 41 provide the targeted and achieved sample allocations by subsector and size bin, for the industrial and commercial sectors, respectively. These tables also indicate the projected precision (prior to actual data collection and analysis) for each subsector. For a few of the subsectors, the projected precision was quite wide. These are subsectors that contribute relatively little to total sector motor consumption. For this reason, they received lower sample allocations, and the projected sector-level precision is reasonable despite these poorly determined subsectors.

The precision projections assume the same sample efficiency for total motor energy use in each subsector as was obtained for the MECS and CBECS samples. The achieved precision of subsector motor electricity consumption estimates, presented Appendix B: Weighting Description, was generally much better than these projections from the sample design stage. This improvement was due to using the MECS and CBECS estimates of total electric use, together with the ratio of motor kilowatt-hour to total kilowatt-hour determined from the MSMA sample. This ratio turned out to have very good precision for most subsectors. The corresponding ratio is not reported directly in the MECS and CBECS public tables, so a precision estimate is not available for comparison from those sources and was not available as an input to the sample design.

Table 40: Targeted and achieved sample allocations by subsector and size bin, for the industrial subsector

Industrial Subsector	Estimated Motor Consumption Based on MECS 2010 (Trillion Btu)	Projected Precision for 90% Confidence Interval (CI) (%)	Target Sample Size				Achieved Sample Size			
			Sub-sector Total	Small	Medium	Large	Sub-sector Total	Small	Medium	Large
Food Products	219	21.0	20	4	9	7	18	3	11	4
Beverage and Tobacco Products	21	35.8	7	1	3	3	7	3	2	2
Textile Mills	35	71.5	7	1	2	4	7	1	1	5
Textile Product Mills	5	175.6	7	1	2	4	7	4	1	2
Apparel	2	521.5	7	1	4	2	7	1	4	2
Leather and Allied Products	0	248.7	7	2	4	1	4	4	0	0
Wood Products	45	42.7	7	1	3	3	8	1	4	3
Paper and Allied Products	282	6.4	20	2	8	10	13	1	5	7
Printing and Related Support	35	156.1	10	1	6	3	7	0	3	4
Petroleum and Coal Products	199	1.5	20	5	8	7	13	7	4	2
Chemicals	434	18.9	25	4	7	14	19	2	9	8
Plastic and Rubber Products	102	65.3	15	2	9	4	19	4	12	3
Nonmetallic Mineral Products	71	28.7	15	1	9	5	8	1	5	2
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	85	1.2	7	2	3	2	7	2	3	2
Primary Metals: Other	60	55.2	17	2	5	10	14	1	7	6
Fabricated Metal Products	68	70.0	20	4	7	9	21	4	10	7
Machinery	44	65.2	12	2	6	4	8	1	3	4
Computer and Electronic Products	62	56.7	18	3	8	7	8	1	4	3
Electrical Equipment and Appliances	22	95.3	7	1	2	4	7	0	3	4
Transportation Equipment	80	41.1	16	3	4	9	14	3	3	8
Furniture and Related Products	11	186.7	7	2	3	2	7	0	5	2
Miscellaneous	16	167.3	11	3	5	3	13	0	10	3

Municipal Water	-		9	3	3	3	0	0	0	0
Municipal Wastewater	74	43.7	9	3	3	3	10	-	-	-
Total	1,973	8.0	300	54	123	123	246	44	109	83

Table 41: Targeted and achieved sample allocations by subsector and size bin, for the commercial subsector

Commercial Subsector	Estimated Motor Consumption Based on CBECS 2012 (Trillion Btu)	Projected Precision for 90% CI (%)	Sample Size				Achieved Sample Size			
			Sub-sector Total	Small	Medium	Large	Sub-sector Total	Small	Medium	Large
Education	264	86.7	13	1	4	8	11	1	2	8
Food Sales	177	72.0	7	1	3	3	7	0	5	2
Food Services	195	77.1	7	1	2	4	7	1	4	2
Health Care: Inpatient	169	5.3	7	1	2	4	7	2	2	3
Health Care: Outpatient	72	124.7	7	1	3	3	7	2	4	1
Lodging (Includes Nursing)	195	75.7	7	1	3	3	7	1	3	3
Mercantile: Retail (other than mall)	184	112.7	11	1	6	4	8	2	5	1
Mercantile: Enclosed and Strip Malls	315	48.6	7	1	3	3	5	3	1	1
Office	490	83.2	20	6	9	5	16	4	7	5
Public Assembly	204	102.1	10	2	7	1	9	1	7	1
Public Order and Safety	43	114.8	7	1	3	3	7	2	3	2
Religious Worship	61	168.6	7	1	2	4	7	0	4	3
Service	76	201.4	7	1	3	3	7	2	4	1
Warehouse and Storage	203	130.6	17	2	7	8	11	1	4	6
Other (Includes CBECS = Other, Laboratory) and Vacant	223	116.4	16	3	6	7	7	1	2	4
Total	2,870	26.3	150	24	63	63	123	23	57	43

Sample selection within a sampling cell

The list frames used for sample recruitment were sorted by subsector, size, and census region. Within a subsector and size category, all site listings had an equal chance of being included in the study.

In the event that a selected industrial listing turned out to include multiple industrial establishments, or a selected commercial listing turned out to include multiple commercial buildings, a single establishment or building was selected at random.

Sample by census region

Explicit sample allocations were not set by geography. Sample allocations to cells defined by combinations of subsector, size, and geography would have been very small, making sample fulfillment challenging. However, overall targets by census region were set as “soft” targets for each subsector. These overall subsector targets by census region were roughly proportional to subsector employment within each region.

Table 42 and Table 43 show the achieved sample distribution by subsector and census region, for the industrial and commercial sectors. Also shown in each table is the distribution by census region that would have corresponded to distributing each subsector’s achieved sample over census regions in proportion to employment. On the whole, the samples are well distributed over census regions, though there is some disproportionate allocation for some subsectors.

Table 42: Industrial sample achieved by census region

NAICS	Achieved Sample					Allocation if Proportional to Employment within NAICS*				
	NE	M	S	W	Total	NE	M	S	W	Total
Wastewater	0	4	4	2	10	N/A	N/A	N/A	N/A	10
Food Products	0	6	7	5	18	2	6	6	4	18
Beverage and Tobacco Products	0	2	1	4	7	1	1	2	3	7
Textile Mills	0	0	7	0	7	1	0	5	1	7
Textile Product Mills	1	2	2	2	7	1	1	4	1	7
Apparel	1	0	1	5	7	1	1	2	3	7
Leather and Allied Products	3	0	0	1	4	1	1	1	1	4
Wood Products	1	1	2	4	8	1	2	3	2	8
Paper and Allied Products	2	3	6	2	13	2	4	5	2	13
Printing and Related Support	2	4	0	1	7	1	3	2	1	7
Petroleum and Coal Products	2	1	4	6	13	1	3	6	3	13
Chemicals	0	3	14	2	19	4	5	7	3	19
Plastic and Rubber Products	4	8	5	2	19	3	7	7	2	19
Nonmetallic Mineral Products	0	2	0	6	8	1	2	3	2	8
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	1	5	0	0	6	0	4	1	1	6
Primary Metals: Other	0	9	3	2	14	2	6	4	2	14
Fabricated Metal Products	1	10	8	3	22	4	8	7	3	22
Machinery	1	4	2	1	8	1	3	3	1	8
Computer and Electronic Products	2	2	1	3	8	2	1	2	3	8
Electrical Equipment and Appliances	0	1	5	1	7	1	2	3	1	7
Transportation Equipment	1	8	4	1	14	1	6	5	2	14
Furniture and Related Products	1	3	3	0	7	1	2	3	1	7
Miscellaneous	3	1	8	1	13	3	4	3	3	13
TOTAL Industrial	26	79	87	54	246	35	72	84	45	246

Notes: NE = Northeast, M = Midwest, S = South, W = West. *proportional allocation rounded and in a few cases adjusted by ± 1 to reconcile to the total achieved.

Table 43: Commercial sample achieved by census region

	Achieved Sample					Allocation if Proportional to Employment within Building Type*				
Commercial Building Type	NE	M	S	W	Total	NE	M	S	W	Total
Education	5	2	2	2	11	2	2	4	3	11
Food Sales	4	2	1	0	7	2	1	2	2	7
Food Services	1	1	0	5	7	1	1	3	2	7
Health Care: Inpatient	1	1	3	2	7	2	1	3	1	7
Health Care: Outpatient	2	0	1	4	7	2	2	2	1	7
Lodging (Includes Nursing)	2	1	2	2	7	1	1	3	2	7
Mercantile: Retail (other than mall)	0	1	0	7	8	2	1	3	2	8
Mercantile: Enclosed and Strip Malls	1	0	1	5	7	1	1	3	2	7
Office	2	2	9	3	16	4	3	6	3	16
Other (Includes CBECS = Other, Laboratory) and Vacant	5	2	0	1	8	2	1	2	3	8
Public Assembly	2	3	0	3	8	2	2	3	1	8
Public Order and Safety	0	2	2	3	7	2	1	3	1	7
Religious Worship	1	1	1	4	7	1	1	3	2	7
Service	2	0	0	4	6	1	2	2	1	6
Warehouse and Storage	1	2	2	5	10	1	2	4	3	10
TOTAL Commercial	29	20	24	50	123	26	22	46	29	123

Notes: NE = Northeast, M = Midwest, S = South, W = West. *proportional allocation rounded and in a few cases adjusted by ± 1 to reconcile to the total achieved.

Sample improvements compared to the prior study

Avoiding Clustering: The 2002 study was clustered into 20 geographic primary sampling units (PSU), selected with probability proportional to estimate motor electricity consumption. The clustering was to limit field costs in a first-of-its kind study. The current MSMA sample was drawn from across the United States, without clustering. This improves its representativeness.

Simpler Sample Allocation and Sample Management: Both studies had similar overall sample sizes for the manufacturing sector. For both, it was desirable to ensure coverage and distribution of the sample across subsectors, sizes, and geography; but it was not practical to allocate the sample to cells defined by the intersection of those. The prior study addressed this by randomly selecting the subsector and size bins that would be sampled from within each PSU, then selecting sites within those cells. This approach was complex to implement, both at the design and fulfillment stage. The current study established targets by sector-size combination and set soft targets by census region. This approach was more straightforward to implement and achieved good distribution of the sample across the country.

Use of sector variability in sample allocation: The prior study allocated the sample in proportion to estimated motor electricity consumption, after setting a minimum of four per subsector. The current study used within-sector variability estimates from the MECS and CBECS to estimate the sample allocations that would estimate sector-level motor system electricity consumption with the best precision for the overall sample size.

Ensuring minimum sample size for each subsector: The prior study set a minimum target of four per subsector, and for a few subsectors achieved only one or two. The final sample design for the MSMA allocated a minimum of seven to each subsector, and achieved at least that number, with the exception of Leather and Allied Products. This approach ensured some information for even the low-consuming subsectors. Most of these subsectors had relative precision better than 10 percent at 90 percent confidence, even with these small sample sizes. Leather and Allied Products had only four completed sites.

Better targeted recruitment lists: The prior study used Dun and Bradstreet records to identify establishments in manufacturing SIC codes. This may have resulted in some sites being included in the study that were not primarily manufacturing. Also, the range and completeness of data fields available at that time in such databases was more limited than what is currently available.

The current study used directories specialized for the industrial sectors from MNI, which identifies itself as the nation's oldest and largest compiler and publisher of industrial information. The MNI data include primary and secondary SIC codes, employment, floorspace, and business descriptions, as well as contact information. For commercial lists, the study used SMR's Enhanced Commercial Property Database, which combines public records databases such as those of tax assessors with additional sources. The database includes floorspace and building use, as well as location and contact information.

Overall results: The estimates of motor system electricity consumption based on the current study have much better precision than those from the prior study. In part, this improvement likely reflects the closer relationship between motor system electricity consumption and total site electricity consumption used as the basis for ratio estimation in this study versus the

relationship between motor system electricity consumption and employment used in the prior study. The better precision may also reflect use of better targeted recruitment lists.

Limitations of separating recruitment lists from the sample allocation population

In most studies with sampling for primary data collection, the same list of units defines both the population that will be represented by the study and the list of units from which the sample will be selected. For the MSMA, the CBP and CBECS aggregate data were used to determine the counts of establishments and employees by size group, while individual sites were recruited from separate lists.

The recruited sample was selected from the lists according to the allocations based on the separate population data. To the extent the recruitment list coverage is not fully aligned with the population data, some bias may result.

Further, with this approach, calculation of population totals requires scaling motor-to-whole-site consumption ratios determined from the sample by population total whole-site consumption. That consumption is known only from energy consumption surveys, which are conducted only periodically and have a lag between data collection and results publication. Thus, for example, the subsector motor system electricity consumption estimates from this study combine:

1. the subsector ratio of motor system electricity to whole-site electric consumption, determined from the sample, and
2. total subsector electric use, from the 2014 MECS or 2012 CBECS.

Thus, bias may result both from coverage discrepancies in the lists used for recruiting and in the lag from the most recent population energy survey.

Data sources

Table 44 provides the data sources used, how they were used in the study, and links to the data themselves.

Table 44: Data sources used

Data	Use	Website
2013 State-Level Census Data By NAICS and Size	Establishments and employment by industrial NAICS	https://www.census.gov/programs-surveys/cbp.html
MECS 2010	Motor energy use per employee	https://www.eia.gov/consumption/manufacturing/data/2010/index.cfm?view=data
MECS 2014	Total electric use by manufacturing sector, for sample expansion	https://www.eia.gov/consumption/manufacturing/data/2014
CBECS 2012	Proxy motor energy use per employee, employment by size bin	https://www.eia.gov/consumption/commercial/data/2012/index.cfm?view=microdata
	Total electric use by commercial subsector	
2013 EPRI Study	Municipal water and wastewater data	http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=000000003002001433&Mode=download
MNI U.S. Manufacturing Industry Database	Recruitment lists for manufacturing subsectors	https://mni.net
SMR Enhanced Commercial Property Database	Recruitment lists for commercial subsectors	http://commbuildings.com

Appendix B: Weighting Description

Construction of weights

Basic weights

Three weights were developed to expand the survey assessment data at the motor level to the national level. The expansion is conducted separately by subsector (manufacturing NAICS code or commercial building type), with each subsector stratified into three size categories (based on the number of employees for manufacturing sites and the square footage for commercial sites).

Each site belongs to a unique subsector-size combination. Each motor within each surveyed site belongs to one of eight horsepower size ranges, which range from 1 hp to larger than 1,000 hp.⁸

The three weights developed are:

1. Quantity
2. Preliminary Motor to Site Weight
3. Site to National Weight

These weights and their combinations are described below.

Quantity

This weight is recorded with the assessed data. The quantity associated with a motor record is the number of motors at the site that are identified by the assessor as being the same as the recorded motor, meaning they are identical motors with identical usage patterns, only differing on their unique nameplate serial number.

Preliminary Motor to Site Weight

This weight is the number of motors at the site represented by each observed motor, where all motors included in a quantity count are treated as observed. Using this weight, the weighted total of the data on the observed motors provides the estimated total for the site as a whole, for each variable of interest.

If all motors treated as observed were recorded individually, rather than being accounted for in the quantity variable, this preliminary motor to site weight would be used directly to weight each motor package record. To produce a weight that is the number of motors represented by an observed motor consisting of multiple identical motors, an additional factor is applied to the preliminary motor to site weight, to produce the final motor to site weight described below.

The preliminary motor to site weight is calculated separately for each horsepower size category present at the site. For each horsepower size category at a site, the motor to site

⁸ For weighting purposes, all motors larger than 1,000 hp were considered to be part of a single bin. A separate field in the dataset ("motor size bin") was used in the analyses. This process field-categorized sampled motor packages larger than 1,000 hp into three separate bins (1001-2001 hp, 2001-5001 hp, and 5001+ hp).

weight is the ratio of the number of motors observed at the site in a given horsepower size range to the estimated total motor count for that site and horsepower size.

The numerator for the weight came from the total number of surveyed motors by horsepower size category. The denominator of the weight was based on the motor count for the size bin at the site.

Preliminary Motor to Site Weight Calculation Formula

For site j and hp size h , the preliminary motor to site weight is calculated as:

$$WMS_{jh} = Q_{jh} / \sum_r q_{jhr}$$

Where:

WMS_{jh} = motor to site weight for hp size h at site j

Q_{jh} = estimated total motor count for hp size h at site j

q_{jhr} = quantity for motor package record r in hp size h at site j

The summation is over all motor package records r at site j .

The total motor count Q_{jh} for the site and horsepower size was calculated as the sum of the counts for that horsepower size over all departments at the site. The total observed in the denominator was calculated as the sum of the quantities for that horsepower size, over all the motor package records for the site.

Table 45 shows an example of this calculation for multiple horsepower sizes at a site. The example site had 72 estimated motors and 71 observed motors across five horsepower size bins. All motors were observed during the assessment for four of the five horsepower size bins. The remaining horsepower size bin (6-21 hp) had 26 estimated motors and 25 observed motors. The resulting weight for that horsepower size bin for the site was $26/25 = 1.04$.

Table 45: Example preliminary motor to site weight

Motor hp Size Bin	Estimated Total Motors at Site (Q)	Total Observed Motors (q)	Preliminary Motor to Site Weight (WMS)
1-5	29	29	1.00
6-20	26	25	1.04
21-50	13	13	1.00
51-101	3	3	1.00
501-1,001	1	1	1.00

Site to National Weight

This weight is the number of sites/facilities in the full national population represented by each observed site. Using this weight, the weighted total of the site-level observations or estimates provides the estimated total for the subsector as a whole. The site to national weight is calculated for each combination of subsector and site size.

Subsector population totals were taken from the 2012 CBECS for commercial subsectors and from the 2014 MECS for manufacturing subsectors. The subsector-size total population count

was estimated as part of the sample design process.

Site to National Weight Calculation Formula

For subsector g and site size z , the site to national weight is calculated as:

$$WSN_{gz} = N_{gz}/n_{gz}$$

Where:

WSN_{gz} = site to national weight in subsector g , site size z
 N_{gz} = population count of sites in subsector g , site size z , from MECS or CBECs
 n_{gz} = sample count of sites in subsector g , site size z

Our example site in Table 45 was in the commercial office subsector. Table 46 shows the site to national weight calculations for commercial offices. Our example site was a large office, so the site to national weight was calculated as the number of estimated large offices in the population (6,976) divided by the number of sampled sites (5), which is $6,976/5 = 1,395.2$

Table 46: Example site to national weight calculation (commercial office subsector)

Size Category	Estimated Population of Sites (N)	Number of Sampled Sites (N)	Site to National Weight (WSN)
Large	6,976	5	1,395.2
Medium	143,560	7	20,508.6
Small	861,836	4	215,459.1

Combined weights

The **final motor to site weight** for a given motor package record r and horsepower size h at site j is the product of the quantity q_{jhr} and the preliminary motor to site weight.

Final Motor to Site Weight Calculation Formula

For motor record r of hp size h at site j , the final motor to site weight is calculated as:

$$WCMS_{jhr} = q_{jhr} WMS_{jh}$$

Where:

$WCMS_{jhr}$ = final motor to site weight
 q_{jhr} and WMS_{jh} are calculated as indicated above.

For our example site, we show the calculation of the combined motor to site weight for each of the motors horsepower size bin 6-21 hp in Table 47. The weight is the product of the preliminary motor to site weight and the quantity of motors observed for each motor package record.

Table 47: Example combined motor to site weight calculation

Motor	Preliminary Motor to Site Weight (WMS)	Quantity	Final Motor to Site Weight (WFMS)
1	1.04	1	1.04
2	1.04	1	1.04
3	1.04	2	2.08
4	1.04	2	2.08
5	1.04	2	2.08
6	1.04	1	1.04
7	1.04	1	1.04
8	1.04	1	1.04
9	1.04	1	1.04
10	1.04	6	6.24
11	1.04	1	1.04
12	1.04	1	1.04
13	1.04	1	1.04
14	1.04	1	1.04
15	1.04	1	1.04
16	1.04	1	1.04
17	1.04	1	1.04

The **combined motor to national weight** is the number of motors in the population represented by a given motor record in the survey data. Using this weight, the weighted total of a given variable over the observed motors provides the estimated total of that variable for the nation as a whole. This weight is obtained by multiplying the motor to site weight and the site to national weight.

Combined Motor to National Weight Calculation Formula

For motor record r of HP size h at site j in subsector g and site size z , the final motor to national weight is calculated as:

$$WCMN_{gzjhr} = WCMS_{jhr} WSN_{gz}$$

Where:

$WCMN_{gzjhr}$ = combined motor to national weight
 $WCMS_{jhr}$ and WSN_{gz} are calculated as indicated above.

Table 48 shows the calculation of the combined motor to national weight for the same motor package records as were shown in Table 47. The combined motor to national weight is the product of the final motor to site weight and the site to national weight.

Table 48: Example combined motor to national weight calculations

Motor	Motor Size Bin	Final Motor to Site Weight (WFMS)	Site to National Weight (WSN)	Final Motor to National Weight (WFMN)
1	6-21	1.04	1,395.3	1451.1
2	6-21	1.04	1,395.3	1451.1
3	6-21	2.08	1,395.3	2902.2
4	6-21	2.08	1,395.3	2902.2
5	6-21	2.08	1,395.3	2902.2
6	6-21	1.04	1,395.3	1451.1
7	6-21	1.04	1,395.3	1451.1
8	6-21	1.04	1,395.3	1451.1
9	6-21	1.04	1,395.3	1451.1
10	6-21	6.24	1,395.3	8706.6
11	6-21	1.04	1,395.3	1451.1
12	6-21	1.04	1,395.3	1451.1
13	6-21	1.04	1,395.3	1451.1
14	6-21	1.04	1,395.3	1451.1
15	6-21	1.04	1,395.3	1451.1
16	6-21	1.04	1,395.3	1451.1
17	6-21	1.04	1,395.3	1451.1

Ratio estimation expansion

The weighted estimates shown thus far are a direct application of the weights, known as mean-per-unit (MPU) estimates. For quantities that are correlated with a metric of facility size (such as megawatt-hour consumption, floorspace, employment) in the same subsector, the same dataset can typically produce estimates with better precision by using ratio estimation. The ratio estimators have better precision because they utilize additional information, namely, a size variable known for the population, together with the relationship between the quantity of interest and the size variable. This property is described further below.

This section describes basic ratio estimation, the development of ratio-based weights to simplify the calculation of ratio estimates, and stratified ratio estimation.

Basic ratio estimator

Calculation

A ratio estimator for the subsector total Y_{TOT} of any variable y of interest that is known at the site level is defined as follows:

$$R_y = \sum_j WSN_j y_j / \sum_j WSN_j x_j$$

$$Y_{TOTR} = R_y X_{TOT}$$

In these equations:

R_y = ratio estimator for the variable of interest y . In the MSMA context, R_y is the average ratio of motor system electricity consumption to total site electricity consumption in a given subsector.

WSN_j = site-to-national weight for site j

y_j = value of variable of interest, the total motor system electricity use for site j

x_j = site total electricity consumption

X_{TOT} = known subsector total of x , site total electricity consumption, from MECS or CBECS

Y_{TOTR} = estimated subsector total motor electricity consumption

The summation is over all sites in the sample for a particular subsector.

Note that the ratio R_y is the ratio of the site-level mean-per-unit estimate of Y_{TOT} to the mean-per-unit estimate of X_{TOT} , both based on the same sample points. That is,

$$R_y = Y_{TOTMPU} / X_{TOTMPU}$$

where

Y_{TOTMPU} = mean-per-unit estimate of total of y , based on the sample

X_{TOTMPU} = mean-per-unit estimate of total of x , based on the sample

Why use the ratio estimator

The ratio R_y tends to have good precision if y and x are well correlated, which they tend to be for any size-related variables x and y . X_{TOT} is typically a fixed known quantity. Thus, the relative precision of the ratio estimator Y_{TOTR} depends only on the precision of R_y , which depends on how well correlated y is with the size measure x .

X_{TOT} may not be directly known, but rather be an independent estimate measured with error. This is the case for the MSMA, where X_{TOT} is electricity consumption from the EIA Energy Consumption Surveys. For such cases, the uncertainty of X_{TOT} also can be considered in assessing the accuracy of the estimated total for y .

Expanding the formula for Y_{TOTR} , we have

$$\begin{aligned} Y_{TOTR} &= R_y X_{TOT} \\ &= (\sum_j WSN_j y_j / \sum_j WSN_j x_j) X_{TOT} \\ &= (\sum_j WSN_j y_j) (X_{TOT} / \sum_j WSN_j x_j) \\ &= Y_{TOTMPU} (X_{TOT} / X_{TOTMPU}) \end{aligned}$$

That is, the ratio estimator of Y_{TOT} is the direct mean-per-unit estimator Y_{TOTMPU} , rescaled by the ratio of the known total X_{TOT} to the corresponding mean-per-unit estimator X_{TOTMPU} . If the sample randomly tends to have somewhat lower or somewhat higher than average units, the ratio estimator Y_{TOTR} adjusts for this, based on the ratio of the known X_{TOT} to the mean-per-unit estimate X_{TOTMPU} .

For the MSMA, the ratio estimator used is the ratio of each y variable of interest to whole-site electricity consumption. Ratio estimation was also attempted using employment as the denominator x for manufacturing subsectors, and floorspace for commercial subsectors. However, ratios using these denominators were less well determined than those using site electricity consumption.

The section below provides key estimates and confidence intervals using the ratio estimator. These tables demonstrate the precision provided by leveraging the site electric consumption data.

Ratio-based weights

Ratio weight calculation

To simplify calculations that would have improved precision if performed using ratio estimation, a set of ratio weights is provided that can be used directly to calculate weighted totals equivalent to ratio estimators. An adjustment factor (adj_elec) is calculated for each subsector as the ratio of subsector level electric consumption in the most current MECS and CBECS studies (2014 and 2012, respectively, in the dataset) to the sample weighted total site electric consumption in each subsector, using the direct site to national weight. That is, for a given subsector:

$$Adj_elec = X_{TOT} / \sum_i WSN_i x_i$$

Where X_{TOT} is the total of x for the subsector and the summation in the denominator is over all sites in the sample for the subsector.

Substituting for the ratio R_y in the ratio estimator for the total of Y , we have:

$$\begin{aligned} Y_{TOTR} &= (\sum_j WSN_j y_j / \sum_j WSN_j x_j) X_{TOT} \\ &= \sum_j WSN_j (X_{TOT} / \sum_i WSN_i x_i) y_j \\ &= \sum_j RWSN_j y_j \end{aligned}$$

where the ratio site to national weight, $RWSN_j$, for site j is:

$$RWSN_j = WSN_j (X_{TOT} / \sum_i WSN_i x_i) = WSN_j Adj_elec.$$

Thus, if the ratio weight is used in place of the direct weight, the sample weighted sum produces the ratio estimator rather than the mean-per-unit estimator.

To calculate ratio estimates directly from the motor level to the national level, the ratio-adjusted final motor to national weight $RWFMN$ should be used.

$$RWFMN_{gzjhr} = WFMN_{gzjhr} x (X_{TOTg} / \sum_{i \in g} WSN_i x_i)$$

When to use the ratio weight

The ratio-based weight is used for calculating any totals from the MSMA, as well as for calculating proportions across different subsectors. For calculation of ratios or proportions within a subsector, the basic weights will yield the same results as the ratio-based weights.

Stratified Ratio Estimation

When the sample for x and y is stratified, there are two general variations available for the

ratio estimator.

The **combined ratio estimator** calculates the ratio of the population-level mean-per-unit Y_{TOTMPU} to the corresponding mean-per-unit X_{TOTMPU} . Thus, if the sample is stratified, the combined ratio is calculated the same as for the unstratified case above:

$$R_y = Y_{TOTMPU}/X_{TOTMPU}$$

The **separate ratio estimator** calculates a separate ratio for each stratification cell k .

$$\begin{aligned} R_{yk} &= Y_{TOTMPUK}/X_{TOTMPUK} \\ Y_{TOTk} &= R_{yk}X_{TOTk} \\ Y_{TOT} &= \sum_k Y_{TOTk} \\ &= \sum_k R_{yk}X_{TOTk} \end{aligned}$$

The separate ratio estimator is more intuitive in some ways, particularly if there is reason to believe the ratios vary across strata. Also, if stratum-level and higher level ratios are to be calculated, separate ratio estimation ensures arithmetic consistency across the sets of estimators. However, if there is no strong reason to expect a lot of variation in the true underlying ratios across strata, and the sample sizes within cell are small, the combined ratio estimator is typically more reliable.

For the MSMA study, our primary interest is in estimates at the subsector level, and sample sizes within a subsector-size cell are often quite small. We therefore used combined ratio estimators across size strata, separately for each subsector. That is, within each subsector we calculated the combined ratio estimator across the three size sampling cells. A separate combined ratio estimator was calculated for each subsector.

Applying the weights: Direct expansion

Direct expansion for non-count variables

This expansion process is appropriate for estimating the total horsepower, kilowatt-hours, and other non-count totals where the total for all motors on a motor record would be appropriately calculated as quantity times the value shown for the variable on the motor package record.

Site-level totals

To estimate the total over motors within a site j of a variable X known for each motor r , apply the final motor to site weights to the values x_r observed for each motor record as follows:

$$\begin{aligned} X_j &= \sum_{r \text{ in } j} x_r W_{CMSjhr} \\ &= \sum_h (\sum_{r \text{ in } jh} x_r) W_{CMSjhr} \end{aligned}$$

In this formula, the summation of x_r is over all motor records r at site j .

Totals across sites

When site-level total X_j have been obtained, to estimate the national total, apply the site-to-national weights and the ratio weight (R_y).

$$X_{TOT} = \sum_j X_j W_{SNj} R_{yj}$$

$$= \sum_{gz} (\sum_{j \text{ in } gz} X_j) WSN_{gz} Ry_{gz}$$

The first line indicates that each site's value X_j is multiplied by its corresponding site-to-national weight. The second line indicates that this summation can be considered as summing the values of X_j for each subsector g and site size z , then applying the site-to-national weight and ratio weight for that subsector and site size.

National totals directly from the motor-record data

Using the final motor to national weights and the ratio weight, the national totals are calculated directly from the motor-record data as:

$$\begin{aligned} X_{TOT} &= \sum_r x_r WCMN_r Ry_r \\ &= \sum_{gzjh} x_{jhr} WCMN_{gzjhr} Ry_{gzjhr} \\ &= \sum_{gzjh} x_{jhr} EMW_{gzjhr}, \\ \text{Note: } EMW_{gzjhr} &= WCMN_{gzjhr} Ry_{gzjhr} = \text{Electric Master Weight} \end{aligned}$$

The first line indicates that the summation is over motor package records, each multiplied by its corresponding motor to national weight. The second line shows explicitly that each motor record r belongs to a particular site j , which belongs to a particular subsector g and site size bin z , and is for a motor of a particular horsepower size h . The third line simplifies the motor national weight and ratio weight into a single term: the electric master weight (EMW).

Counts

These direct expansion approaches are appropriate for estimating counts of motors with a characteristic.

Site-level totals

To estimate the total count over motors within a site j of variable quantity known for each package r , apply the preliminary motor to site weights to the values q_r observed for each motor record as follows:

$$\begin{aligned} Q_j &= \sum_{r \text{ in } j} q_r WMS_{jhr} \\ &= \sum_h (\sum_{r \text{ in } jh} q_r) WMS_{jhr} \end{aligned}$$

In this formula, the summation of q_r is over all motor records r at site j .

Totals across sites

When site-level quantities Q_j have been obtained, to estimate the national total, apply the site to the national weights and the ratio weight (adj_elec).

$$\begin{aligned} Q_{TOT} &= \sum_j Q_j WSN_j Ry_j \\ &= \sum_{gz} (\sum_{j \text{ in } gz} Q_j) WSN_{gz} Ry_{gz} \end{aligned}$$

The first line indicates that each site's value Q_j is multiplied by its corresponding site-to-national weight. The second line indicates that this summation can be considered as summing the values of Q_j for each subsector g and site size z , then applying the site-to-national weight and ratio weight for that subsector and site size.

National totals directly from the motor-record data

Using the motor to national weights and the ratio weight (when multiplied together these are the **elec_master_wt** field), the national total counts are calculated directly from the motor-record data as:

$$\begin{aligned} Q_{TOT} &= \sum_r q_r WMN_r R_{y_r} \\ &= \sum_{gzjh} q_{jhr} WMN_{gzjhr} R_{y_{gzjhr}} \\ &= \sum_{gzjh} q_{jhr} EMW_{gzjhr} \end{aligned}$$

The first line indicates that the summation is over motor records, each multiplied by its corresponding motor to national weight. The second line shows explicitly that each motor record r belongs to a particular site j , which belongs to a particular subsector g and site size bin z , and is for a motor of a particular horsepower size h . The third line simplifies the motor national weight and ratio weight into a single term: the EMW.

Uncertainty

Components of uncertainty

The MSMA estimates are based on a statistical sample of industrial and commercial facilities. These estimates have uncertainty due to the random sampling. The difference between the estimate based on the sample and the results that would be obtained if the entire population could be observed is the sampling error.

The estimates also have non-sampling sources of error or uncertainty. To the extent these errors are equally likely to be in either direction, and do not systematically overstate or understate variables of interest, these are random errors. Non-sampling errors that lead to systematic overestimates or underestimates contribute to bias. Bias ordinarily cannot be quantified. Efforts were made to minimize opportunities for bias in the study design and data collection process.

The magnitude of random error, including both sampling and non-sampling random error, is measured by the standard error and confidence intervals. The standard error is a measure of the “typical” difference between the estimate and the true population value. The confidence interval is a window that brackets the point estimate, and has a given likelihood of including the true value. Tables provided for this study give 90 percent confidence intervals.

Basic confidence intervals capture the uncertainty due to the MSMA sampling only. For totals calculated as the product of an MSMA ratio and an EIA Energy Consumption Survey electricity total, the combined confidence interval reflects the random error in both the MSMA and the Energy Consumption Survey samples.

Basic confidence intervals

Ratio estimates and their standard errors and related statistics were calculated using the SAS procedure “proc surveymeans.”⁹ This SAS procedure is used to calculate ratio estimation by domains while providing the correct standard error of the estimate for each domain and overall. The procedure takes into account defined clusters of observations (sites) and stratification and (as used in this analysis) calculates Taylor series errors.

Combined uncertainty including the Energy Consumption Survey estimates

⁹ SAS. 2016. SAS/STAT®14.2 User’s Guide: The SURVEYMEANS Procedure
<https://support.sas.com/documentation/onlinedoc/stat/142/surveymeans.pdf>.

The basic confidence intervals reflect the full sampling uncertainty for ratios. For MSMA totals calculated by multiplying the ratio by the EIA Energy Consumption Survey total electric consumption,¹⁰ the uncertainty in the electric consumption totals also contributes to the uncertainty of the MSMA estimate.

The combined standard error calculation uses the relative standard error (RSE) of the estimates; that is, the ratio of the standard error to the estimate. When two estimates are independent, the RSE of their product is approximated by the square root of the sum of squared RSE's. The MSMA ratio and the EIA Energy Consumption Survey total are

Combined SE Calculation Formula

When the subsector total for a quantity y is calculated as the product of an electricity ratio Ry_g from the MSMA data and the electricity total X_{TOTg} from the corresponding EIA Energy Consumption Survey,

$$Y_{TOTrg} = Ry_g X_{TOTg},$$

the combined RSE for the estimated total is approximated by:

$$RSE(Y_{TOTrg}) \simeq [RSE(Ry_g)^2 + RSE(X_{TOTg})^2]^{1/2}$$

The standard error is then calculated as:

$$SE(Y_{TOTrg}) = RSE(Y_{TOTrg}) Y_{TOTrg}$$

independent estimates, so this formula applies.

For most subsectors, the uncertainty in the EIA Energy Consumption Survey electric total increases the confidence interval widths by 20 percent or less; in many cases by much less than 1 percent. The exceptions are Printing and Rubber, with a 32 percent increase, and Textile Mills, with a 72 percent increase. Both of these subsectors have low motor electricity consumption.

Non-sampling error and bias

Non-sampling sources of error in the MSMA estimates include the following sources:

Non-response. Recruitment for studies of this type is challenging. How similar the sites agreeing to an assessment are to those that decline, within the same sampling cell, is unknown. The sample expansion and standard error estimation assumes that within each sampling cell the chance of being included in the study is the same for all sites in the population.

Frame coverage and alignment. The sample allocation was based on CBP data on industrial establishment and employment by NAICS group and employment size, and on CBECS data on commercial buildings employment totals by building type and size bin. The CBP data are the standard, comprehensive dataset on U.S. establishments. There is no authoritative list of

¹⁰ 2012 CBECS data Table C13.

<http://www.eia.gov/consumption/commercial/data/2012/index.cfm?view=microdata>.

2014 MECS data Table 11.1.

<https://www.eia.gov/consumption/manufacturing/data/2014/#r13>.

commercial buildings; the CBECS is the most comprehensive, systematic set of estimates on commercial floorspace and activity.

Recruitment was conducted from the MNI U.S. Manufacturing Industry Database and the SMR Enhanced Commercial Property Database establishment lists. These lists were used because they had good contact information, but they are not an authoritative comprehensive source. They are likely to have some missed sites and inaccuracies.

Assumptions for derived values. Some of the data reported in the MSMA are calculated or imputed, rather than directly observed. Errors in assumptions for these derived values would tend to affect all derived elements similarly. This is detailed below.

Measurement/observational errors. Individual data values may be misrecorded during the field assessment. Other errors may arise during data entry and processing. To the extent such errors are equally likely to occur in either direction, they can be regarded as a form of random error that is captured by the variance estimation. Errors that tend to be more in one direction than another — such as an order of magnitude error, which results in overestimates more often than underestimates, contribute to bias. The quality control processes implemented for the MSMA were designed to identify and correct such errors.

Imputation approach

Total site consumption (kWh) was not collected at five sites, and several sites had inventoried motors of a certain size (horsepower bin) with no sampled motors observed. Omitting these records would result in underestimates of motor consumption, necessitating imputation to fill values. The imputations used three calculation methods with clear decision rules to determine which method would be used for each missing value.

For each imputation the following approaches and decision rules were used:

1. The default approach was to take the average within the subsector and size group used in the sample design.
2. When approach #1 was based on fewer than two sites, approach #2 was used. This approach used the average taken within the subsector and the combined sample in the small- and medium-size categories (no large sites required imputation).
3. When approach #2 also had fewer than two observations, approach #3 was used. Approach #3 used the average across sampled sites for the whole subsector.

Site consumption (MWh) imputation

Total site megawatt-hour consumption was imputed for 5 of the 369 sampled sites, all in the commercial sector.

The imputation method used was to impute based on the ratio of observed site electricity consumption to observed alternate measure of size averaged across the known sample most similar to the site with missing information (based on the decision rules above). “Site size” was the number of employees for industrial sites and square footage for commercial sites. The imputation multiplied the average ratio of site megawatt-hours to site size by the known site size for the site to estimate the site megawatt-hours. Table 49 and Table 50 provide details on the amount of imputation. The tables show the number of sites and millions of

weighted site megawatt-hours for each subsector, both imputed and total, along with the percent of each subsector that required imputation.

Table 49: Imputation for unobserved industrial site consumption

Subsector	Sites			Weighted Site Million MWh		
	Total in Sample	Imputed Site MWh	Percent of Subsector Sampled Sites Imputed (%)	Total	Imputed	Percent of Subsector Imputed (%)
Food Products	18	0	0.0	72	0.0	0.0
Beverage and Tobacco Products	7	0	0.0	10	0.0	0.0
Textile Mills	7	0	0.0	13	0.0	0.0
Textile Product Mills	7	0	0.0	3	0.0	0.0
Apparel	7	0	0.0	1	0.0	0.0
Leather and Allied Products	4	0	0.0	0	0.0	0.0
Wood Products	8	0	0.0	21	0.0	0.0
Paper and Allied Products	13	0	0.0	56	0.0	0.0
Printing and Related Support	7	0	0.0	14	0.0	0.0
Petroleum and Coal Products	13	0	0.0	49	0.0	0.0
Chemicals	19	0	0.0	134	0.0	0.0
Plastic and Rubber Products	19	0	0.0	56	0.0	0.0
Nonmetallic Mineral Products	8	0	0.0	38	0.0	0.0
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	0	0.0	60	0.0	0.0
Primary Metals: Other	14	0	0.0	67	0.0	0.0
Fabricated Metal Products	21	0	0.0	42	0.0	0.0
Machinery	8	0	0.0	23	0.0	0.0
Computer and Electronic Products	8	0	0.0	33	0.0	0.0
Electrical Equipment and Appliances	7	0	0.0	12	0.0	0.0
Transportation Equipment	14	0	0.0	45	0.0	0.0
Furniture and Related Products	7	0	0.0	5	0.0	0.0
Miscellaneous	13	0	0.0	8	0.0	0.0
Municipal Wastewater	10	0	0.0	31	0.0	0.0

Table 50: Imputation for unobserved commercial site consumption

Subsector	Sites			Weighted Site Million MWh		
	Total in Sample	Imputed Site MWh	Percent of Subsector Sampled Sites Imputed (%)	Total	Imputed	Percent of Subsector Imputed (%)
Education	11	0	0.0	134	0.0	0.0
Food Sales	7	0	0.0	61	0.0	0.0
Food Services	7	0	0.0	82	0.0	0.0
Health Care: Inpatient	7	0	0.0	74	0.0	0.0
Health Care: Outpatient	7	0	0.0	33	0.0	0.0
Lodging (Includes Nursing)	7	0	0.0	89	0.0	0.0
Mercantile: Retail (other than mall)	8	0	0.0	82	0.0	0.0
Mercantile: Enclosed and Strip Malls	5	2	40.0	117	19.0	16.3
Office	16	1	6.3	264	21.7	8.2
Public Assembly	9	0	0.0	81	0.0	0.0
Public Order and Safety	7	1	14.3	22	3.4	15.5
Religious Worship	7	0	0.0	24	0.0	0.0
Service	7	0	0.0	37	0.0	0.0
Warehouse and Storage	11	1	9.1	100	22.2	22.3
Other (Includes CBECS = Other, Laboratory) and Vacant	7	0	0.0	64	0.0	0.0

Unobserved motor consumption imputation

Individual motor consumption was imputed using the weighted average of motor consumption within motors of the same horsepower size bin. The decision rules above were used to determine the sites included in the average used for imputation. Table 51 and Table 52 provide details on the amount of imputation. The tables show the number of sites, motors, and millions of weighted motor megawatt-hours in each subsector, both those that required imputation and the total, along with the percent of each subsector that required imputation.

Table 51: Imputation for unobserved industrial motors

Subsector	Sites			Motors			Weighted Motor Million MWh		
	Total in Sample	With Any Imputed Motors	Percent of Sample With Any Imputed Motors (%)	Total in Sample	Imputed	Percent of Sample Imputed (%)	Total	Imputed	Percent of Subsector Imputed (%)
Food Products	18	2	11.1	4,121	3	0.1	48	0.2	0.4
Beverage and Tobacco Products	7	1	14.3	1,059	2	0.2	7	0.3	3.6
Textile Mills	7	0	0.0	2,500	0	0.0	10	0.0	0.0
Textile Product Mills	7	0	0.0	734	0	0.0	2	0.0	0.0
Apparel	7	1	14.3	304	1	0.3	0	0.0	0.7
Leather and Allied Products	4	0	0.0	140	0	0.0	0	0.0	0.0
Wood Products	8	0	0.0	1,068	0	0.0	20	0.0	0.0
Paper and Allied Products	13	1	7.7	4,205	1	0.0	45	0.0	0.0
Printing and Related Support	7	0	0.0	1,004	0	0.0	10	0.0	0.0
Petroleum and Coal Products	13	2	15.4	1,995	4	0.2	39	0.8	2.1
Chemicals	19	2	10.5	5,716	3	0.1	106	0.1	0.1
Plastic and Rubber Products	19	2	10.5	3,045	2	0.1	40	0.2	0.5
Nonmetallic Mineral Products	8	0	0.0	579	0	0.0	26	0.0	0.0
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	0	0.0	1,571	0	0.0	24	0.0	0.0
Primary Metals: Other	14	2	14.3	1,725	2	0.1	40	0.1	0.3
Fabricated Metal Products	21	2	9.5	2,787	2	0.1	26	0.1	0.3
Machinery	8	0	0.0	1,129	0	0.0	16	0.0	0.0
Computer and Electronic Products	8	2	25.0	1,796	2	0.1	12	0.4	3.4
Electrical Equipment and Appliances	7	2	28.6	1,518	2	0.1	8	0.1	1.9
Transportation Equipment	14	1	7.1	3,448	1	0.0	32	0.1	0.2
Furniture and Related Products	7	1	14.3	892	1	0.1	3	0.0	0.1
Miscellaneous	13	5	38.5	2,379	8	0.3	6	0.3	4.5
Municipal Wastewater	10	2	20.0	499	3	0.6	28	0.3	0.9

Table 52: Imputation for unobserved commercial motors

Subsector	Sites			Motors			Weighted Motor Million MWh		
	Total in Sample	With Any Imputed Motors	Percent of Sample With Any Imputed Motors (%)	Total in Sample	Imputed	Percent of Subsector Imputed (%)	Total	Imputed	Percent of Subsector Imputed (%)
Education	11	0	0.0	818	0	0.0	76	0.0	0.0
Food Sales	7	0	0.0	228	0	0.0	24	0.0	0.0
Food Services	7	0	0.0	109	0	0.0	35	0.0	0.0
Health Care: Inpatient	7	2	28.6	842	3	0.4	35	3.4	9.8
Health Care: Outpatient	7	0	0.0	215	0	0.0	20	0.0	0.0
Lodging (Includes Nursing)	7	0	0.0	453	0	0.0	59	0.0	0.0
Mercantile: Retail (other than mall)	8	0	0.0	175	0	0.0	31	0.0	0.0
Mercantile: Enclosed and Strip Malls	5	0	0.0	260	0	0.0	34	0.0	0.0
Office	16	0	0.0	479	0	0.0	93	0.0	0.0
Public Assembly	9	0	0.0	232	0	0.0	28	0.0	0.0
Public Order and Safety	7	0	0.0	189	0	0.0	12	0.0	0.0
Religious Worship	7	0	0.0	97	0	0.0	10	0.0	0.0
Service	7	0	0.0	29	0	0.0	7	0.0	0.0
Warehouse and Storage	11	0	0.0	654	0	0.0	40	0.0	0.0
Other (Includes CBECS = Other, Laboratory) and Vacant	7	0	0.0	1,101	0	0.0	29	0.0	0.0

Calculating motor consumption and motor counts results

Ratios for the variables of interest were calculated and applied to the associated ratio to estimate the total number of motors and total motor megawatt-hour consumption per subsector. The ratio estimation results were weighted by the site to nation weight and MECS/CBECS adjustment factor, equaling 1, and calculated 90 percent confidence intervals.

The **ratio estimator calculation for the number of motors** per subsector is as follows. The numerator (total_motors) represents the total number of motors per subsector. The denominator (SI_MWh) is the total site level electricity consumption in MWh per subsector.

$$R_{yk} = Y_{TOTMPUK}/X_{TOTMPUK}$$
$$R_{MOTORSk} = \text{total_motors}/SI_MWh$$

The resulting ratio is the number of motors per site-level MWh.

The **magnitude calculation for the number of motors** per subsector is as follows:

$$Y_{TOTk} = R_{yk}X_{TOTk}$$
$$Y_{TOT} = \sum_k Y_{TOTk}$$
$$= \sum_k R_{yk}X_{TOTk}$$
$$Y_{TOTMOTORS} = \sum_k R_{MOTORSk} SI_MWh$$

The **ratio estimator calculation for the total motor MWh consumption** per subsector is as follows. The numerator (wt_sum_mtr_MWh) represents the weighted site level sum of motor MWh consumption per subsector. The denominator (SI_MWh) is the total site level electricity consumption in MWh per subsector.

$$R_{yk} = Y_{TOTMPUK}/X_{TOTMPUK}$$
$$R_{MWHk} = \text{wt_sum_mtr_MWh}/SI_MWh$$

The resulting ratio is the motor MWh per site-level MWh.

The **magnitude calculation for the total motor MWh consumption** per subsector is as follows:

$$Y_{TOTk} = R_{yk}X_{TOTk}$$
$$Y_{TOT} = \sum_k Y_{TOTk}$$
$$= \sum_k R_{yk}X_{TOTk}$$
$$Y_{TOTMWH} = \sum_k R_{MWHk} SI_MWh$$

MSMA confidence limits

The tables in this section (Table 53 through Table 64) and the next (Table 65 through Table 68) show the same results, but with different confidence limits. The difference in the confidence limits is that confidence intervals in this section includes only the errors associated with this MSMA study, while the next section shows the errors on which the confidence limits are based

and incorporates both this study's error and the error associated with consumption estimates from MECS and CBECS. CI stands for confidence interval, LCL stands for lower confidence limit, and UCL stands for upper confidence limit.

Table 53: Number of motors relative to the site level electricity consumption in MWh ratio results and 90% confidence interval (CI) by sector

Sector	N	Ratio	Ratio 90% CI LCL	Ratio 90% CI UCL
Industrial	246	0.01	0.01	0.01
Commercial	123	0.03	0.03	0.04
All	369	0.03	0.02	0.03

Table 54: Magnitude of the number of motors and 90% confidence interval (CI) by sector

Sector	N	Number of Motors	Number of Motors 90% CI LCL	Number of Motors 90% CI UCL
Industrial	246	10,832,523	9,775,140	11,889,907
Commercial	123	41,683,816	37,283,498	46,084,135
All	369	52,516,340	47,990,761	57,041,919

Table 55: Cumulative motor MWh consumption relative to site level electricity consumption in MWh ratio results and 90% confidence interval (CI) by sector

Sector	N	Ratio	Ratio 90% CI LCL	Ratio 90% CI UCL
Industrial	246	0.66	0.71	0.69
Commercial	123	0.40	0.45	0.43
All	369	0.51	0.55	0.53

Table 56: Cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by sector

Sector	N	Motor Consumption (MWh)	Motor Consumption (MWh) 90% CI LCL	Motor Consumption (MWh) 90% CI UCL
Industrial	246	546,962,888	527,131,806	566,793,970
Commercial	123	532,023,857	502,305,490	561,742,225
All	369	1,078,986,746	1,043,259,260*	1,114,714,231*

*calculated as square root of the sum of squares for each sector

Industrial subsectors

Table 57: Industrial number of motors relative to site level electricity consumption in MWh ratio results and 90% confidence interval (CI) by subsector

Subsector	N	Ratio	Ratio 90% CI LCL	Ratio 90% CI UCL
Food Products	18	0.01	0.01	0.01
Beverage and Tobacco Products	7	0.04	0.03	0.05
Textile Mills	7	0.02	0.02	0.03
Textile Product Mills	7	0.03	0.01	0.06
Apparel	7	0.03	0.01	0.05
Leather and Allied Products	4	0.20	0.15	0.25
Wood Products	8	0.01	0.00	0.01
Paper and Allied Products	13	0.01	0.00	0.01
Printing and Related Support	7	0.03	0.02	0.05
Petroleum and Coal Products	13	0.01	0.00	0.01
Chemicals	19	0.01	0.01	0.01
Plastic and Rubber Products	19	0.02	0.02	0.03
Nonmetallic Mineral Products	8	0.01	0.01	0.01
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	0.00	0.00	0.01
Primary Metals: Other	14	0.01	0.01	0.01
Fabricated Metal Products	21	0.02	0.01	0.02
Machinery	8	0.08	0.06	0.11
Computer and Electronic Products	8	0.01	0.01	0.02
Electrical Equipment and Appliances	7	0.01	0.00	0.01
Transportation Equipment	14	0.01	0.01	0.01
Furniture and Related Products	7	0.02	0.01	0.02
Miscellaneous	13	0.02	0.01	0.04
Municipal Wastewater	10	0.00	0.00	0.01

**Table 58: Industrial magnitude of the number of motors and 90% confidence interval (CI)
by subsector**

Subsector	N	Number of Motors	Number of Motors 90% CI LCL	Number of Motors 90% CI UCL
Food Products	18	743,691	439,573	1,047,809
Beverage and Tobacco Products	7	381,723	288,733	474,713
Textile Mills	7	297,785	250,701	344,868
Textile Product Mills	7	84,182	18,391	149,973
Apparel	7	28,242	9,298	47,186
Leather and Allied Products	4	59,139	43,967	74,312
Wood Products	8	191,363	72,456	310,270
Paper and Allied Products	13	308,165	157,108	459,223
Printing and Related Support	7	497,586	330,329	664,842
Petroleum and Coal Products	13	299,199	165,363	433,036
Chemicals	19	1,287,307	699,851	1,874,763
Plastic and Rubber Products	19	1,142,320	860,478	1,424,161
Nonmetallic Mineral Products	8	357,484	275,407	439,562
Primary Metals: Iron and steel Mills and Ferroalloy Manufacturing	7	253,409	121,139	385,680
Primary Metals: Other	14	777,699	672,795	882,604
Fabricated Metal Products	21	713,947	474,927	952,966
Machinery	8	1,971,632	1,397,889	2,545,376
Computer and Electronic Products	8	489,368	302,141	676,595
Electrical Equipment and Appliances	7	103,339	36,041	170,637
Transportation Equipment	14	468,066	344,151	591,980
Furniture and Related Products	7	81,503	46,867	116,138
Miscellaneous	13	194,775	71,006	318,544
Municipal Wastewater	10	100,599	3,637	197,561

Table 59: Industrial cumulative motor MWh consumption relative to site level electricity consumption in MWh ratio results and 90% confidence interval (CI) by subsector

Subsector	N	Ratio	Ratio 90% CI LCL	Ratio 90% CI UCL
Food Products	18	0.66	0.55	0.77
Beverage and Tobacco Products	7	0.73	0.52	0.95
Textile Mills	7	0.79	0.77	0.82
Textile Product Mills	7	0.69	0.66	0.72
Apparel	7	0.48	0.17	0.78
Leather and Allied Products	4	0.77	0.71	0.83
Wood Products	8	0.92	0.86	0.97
Paper and Allied Products	13	0.80	0.73	0.88
Printing and Related Support	7	0.67	0.52	0.83
Petroleum and Coal Products	13	0.80	0.65	0.95
Chemicals	19	0.79	0.71	0.87
Plastic and Rubber Products	19	0.72	0.64	0.79
Nonmetallic Mineral Products	8	0.70	0.61	0.79
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	0.40	0.33	0.47
Primary Metals: Other	14	0.60	0.54	0.65
Fabricated Metal Products	21	0.61	0.47	0.75
Machinery	8	0.68	0.64	0.73
Computer and Electronic Products	8	0.38	0.26	0.49
Electrical Equipment and Appliances	7	0.67	0.63	0.70
Transportation Equipment	14	0.71	0.65	0.77
Furniture and Related Products	7	0.62	0.50	0.74
Miscellaneous	13	0.66	0.56	0.77
Municipal Wastewater	10	0.90	0.77	1.02

Table 60: Industrial cumulative motor MWh consumption magnitude and 90% confidence interval (CI) by subsector

Subsector	N	Motor Consumption (MWh)	Motor Consumption (MWh) 90% CI LCL	Motor Consumption (MWh) 90% CI UCL
Food Products	18	47,585,342	39,731,627	55,439,057
Beverage and Tobacco Products	7	7,108,466	5,074,065	9,142,866
Textile Mills	7	10,000,460	9,664,512	10,336,408
Textile Product Mills	7	1,819,467	1,738,614	1,900,320
Apparel	7	419,002	149,546	688,458
Leather and Allied Products	4	226,490	209,476	243,504
Wood Products	8	19,592,433	18,392,684	20,792,182
Paper and Allied Products	13	45,026,429	40,938,101	49,114,758
Printing and Related Support	7	9,669,040	7,450,112	11,887,969
Petroleum and Coal Products	13	39,269,425	31,971,643	46,567,207
Chemicals	19	105,699,422	94,807,470	116,591,375
Plastic and Rubber Products	19	39,898,215	35,778,433	44,017,997
Nonmetallic Mineral Products	8	26,322,488	22,930,311	29,714,665
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	24,136,804	19,892,037	28,381,571
Primary Metals: Other	14	39,780,066	36,182,384	43,377,747
Fabricated Metal Products	21	25,639,097	19,874,124	31,404,070
Machinery	8	16,039,772	14,961,108	17,118,436
Computer and Electronic Products	8	12,437,837	8,633,536	16,242,139
Electrical Equipment and Appliances	7	7,800,134	7,355,616	8,244,651
Transportation Equipment	14	31,846,584	29,135,442	34,557,726
Furniture and Related Products	7	3,104,566	2,499,704	3,709,428
Miscellaneous	13	5,643,485	4,774,083	6,512,887
Municipal Wastewater	10	27,897,864	23,985,241	31,810,488

Commercial subsectors

Table 61: Commercial number of motors relative to site level electricity consumption in MWh ratio results and 90% confidence interval (CI) by subsector

Subsector	N	Ratio	Ratio 90% CI LCL	Ratio 90% CI UCL
Education	11	0.02	0.02	0.03
Food Sales	7	0.03	0.02	0.04
Food Services	7	0.05	0.04	0.06
Health Care: Inpatient	7	0.01	0.01	0.01
Health Care: Outpatient	7	0.03	0.02	0.04
Lodging (Includes Nursing)	7	0.06	0.03	0.09
Mercantile: Retail (other than mall)	8	0.04	0.03	0.05
Mercantile: Enclosed and Strip Malls	5	0.05	0.05	0.05
Office	16	0.02	0.01	0.02
Public Assembly	9	0.03	0.01	0.05
Public Order and Safety	7	0.04	0.02	0.05
Religious Worship	7	0.08	0.04	0.13
Service	7	0.05	0.02	0.08
Warehouse and Storage	11	0.04	0.03	0.06
Other (Includes CBECS = Other, Laboratory) and Vacant	7	0.01	0.00	0.01

Table 62: Commercial number of motors magnitude and 90% confidence interval (CI) by subsector

Subsector	N	Number of Motors	Number of Motors 90% CI LCL	Number of Motors 90% CI UCL
Education	11	3,303,261	2,227,712	4,378,809
Food Sales	7	1,686,742	1,161,210	2,212,274
Food Services	7	4,082,172	3,341,414	4,822,930
Health Care: Inpatient	7	612,586	394,924	830,249
Health Care: Outpatient	7	914,332	640,435	1,188,228
Lodging (Includes Nursing)	7	5,340,744	2,580,484	8,101,004
Mercantile: Retail (other than mall)	8	3,401,350	2,337,755	4,464,945
Mercantile: Enclosed and Strip Malls	5	6,307,752	5,880,181	6,735,324
Office	16	4,762,177	3,370,638	6,153,716
Public Assembly	9	2,525,907	1,050,487	4,001,327
Public Order and Safety	7	759,636	408,554	1,110,717
Religious Worship	7	1,941,057	906,899	2,975,216
Service	7	1,892,272	710,413	3,074,131
Warehouse and Storage	11	3,611,794	2,389,933	4,833,656
Other (Includes CBECS = Other, Laboratory) and Vacant	7	542,034	181,633	902,436

Table 63: Commercial cumulative motor MWh consumption relative to site level electricity consumption in MWh ratio results and 90% confidence interval (CI) by subsector

Subsector	N	Ratio	Ratio 90% CI LCL	Ratio 90% CI UCL
Education	11	0.57	0.52	0.62
Food Sales	7	0.39	0.33	0.44
Food Services	7	0.43	0.38	0.47
Health Care: Inpatient	7	0.47	0.41	0.54
Health Care: Outpatient	7	0.60	0.47	0.73
Lodging (Includes Nursing)	7	0.66	0.56	0.77
Mercantile: Retail (other than mall)	8	0.37	0.32	0.42
Mercantile: Enclosed and Strip Malls	5	0.27	0.25	0.29
Office	16	0.37	0.28	0.46
Public Assembly	9	0.34	0.28	0.40
Public Order and Safety	7	0.55	0.51	0.60
Religious Worship	7	0.44	0.33	0.55
Service	7	0.19	0.16	0.21
Warehouse and Storage	11	0.48	0.37	0.59
Other (Includes CBECS = Other, Laboratory) and Vacant	7	0.45	0.40	0.50

Table 64: Commercial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector

Subsector	N	Motor Consumption (MWh)	Motor Consumption (MWh) 90% CI LCL	Motor Consumption (MWh) 90% CI UCL
Education	11	76,338,893	69,891,707	82,786,078
Food Sales	7	23,642,670	20,267,234	27,018,105
Food Services	7	34,776,262	30,995,975	38,556,548
Health Care: Inpatient	7	34,759,383	29,958,510	39,560,256
Health Care: Outpatient	7	20,085,177	15,680,051	24,490,303
Lodging (Includes Nursing)	7	59,189,118	50,121,356	68,256,880
Mercantile: Retail (other than mall)	8	30,649,528	26,352,717	34,946,338
Mercantile: Enclosed and Strip Malls	5	33,771,833	30,991,649	36,552,017
Office	16	93,334,776	70,226,615	116,442,937
Public Assembly	9	27,552,463	22,480,846	32,624,081
Public Order and Safety	7	11,816,966	10,853,069	12,780,864
Religious Worship	7	10,487,390	7,883,156	13,091,625
Service	7	6,892,861	5,937,479	7,848,242
Warehouse and Storage	11	40,054,011	30,716,217	49,391,806
Other (Includes CBECS = Other, Laboratory) and Vacant	7	28,672,527	25,584,725	31,760,329

MSMA and MECS/CBECS combined confidence limits

Industrial Subsectors

Table 65: Industrial magnitude number of motors and 90% confidence interval (CI) by subsector

Subsector	N	Number of Motors	Number of Motors 90% CI LCL	Number of Motors 90% CI UCL
Food Products	18	743,691	421,382	1,066,000
Beverage and Tobacco Products	7	381,723	259,013	504,433
Textile Mills	7	297,785	200,854	394,715
Textile Product Mills	7	84,182	4,546	163,818
Apparel	7	28,242	5,317	51,167
Leather and Allied Products	4	59,139	35,073	83,206
Wood Products	8	191,363	48,566	334,160
Paper and Allied Products	13	308,165	142,517	473,813
Printing and Related Support	7	497,586	237,804	757,367
Petroleum and Coal Products	13	299,199	153,833	444,565
Chemicals	19	1,287,307	667,301	1,907,313
Plastic and Rubber Products	19	1,142,320	785,814	1,498,826
Nonmetallic Mineral Products	8	357,484	260,071	454,898
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	253,409	91,746	415,072
Primary Metals: Other	14	777,699	664,238	891,160
Fabricated Metal Products	21	713,947	441,444	986,450
Machinery	8	1,971,632	1,238,447	2,704,817
Computer and Electronic Products	8	489,368	268,114	710,623
Electrical Equipment and Appliances	7	103,339	22,101	184,578
Transportation Equipment	14	468,066	328,414	607,717
Furniture and Related Products	7	81,503	38,533	124,472
Miscellaneous	13	194,775	56,924	332,627
Municipal Wastewater	10	100,599	(7,123)	208,322

Table 66: Industrial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector

Subsector	N	Motor Consumption (MWh)	Motor Consumption (MWh) 90% CI LCL	Motor Consumption (MWh) 90% CI UCL
Food Products	18	47,585,342	39,081,812	56,088,873
Beverage and Tobacco Products	7	7,108,466	4,500,764	9,716,168
Textile Mills	7	10,000,460	7,345,284	12,655,636
Textile Product Mills	7	1,819,467	1,487,161	2,151,773
Apparel	7	419,002	90,631	747,374
Leather and Allied Products	4	226,490	180,114	272,866
Wood Products	8	19,592,433	15,141,700	24,043,166
Paper and Allied Products	13	45,026,429	40,406,616	49,646,243
Printing and Related Support	7	9,669,040	5,462,756	13,875,325
Petroleum and Coal Products	13	39,269,425	31,288,225	47,250,625
Chemicals	19	105,699,422	93,912,061	117,486,784
Plastic and Rubber Products	19	39,898,215	31,790,377	48,006,053
Nonmetallic Mineral Products	8	26,322,488	22,038,334	30,606,642
Primary Metals: Iron and Steel Mills and Ferroalloy Manufacturing	7	24,136,804	18,984,937	29,288,671
Primary Metals: Other	14	39,780,066	35,883,872	43,676,260
Fabricated Metal Products	21	25,639,097	18,465,742	32,812,452
Machinery	8	16,039,772	13,147,705	18,931,838
Computer and Electronic Products	8	12,437,837	7,948,146	16,927,528
Electrical Equipment and Appliances	7	7,800,134	6,408,862	9,191,406
Transportation Equipment	14	31,846,584	27,745,785	35,947,384
Furniture and Related Products	7	3,104,566	2,229,131	3,980,000
Miscellaneous	13	5,643,485	4,316,423	6,970,547
Municipal Wastewater	10	27,897,864	23,551,022	32,244,707

Commercial subsectors

Table 67: Commercial number of motors magnitude and 90% confidence interval (CI) by subsector

Subsector	N	Number of Motors	Number of Motors 90% CI LCL	Number of Motors 90% CI UCL
Education	11	3,303,261	2,049,314	4,557,207
Food Sales	7	1,686,742	964,483	2,409,000
Food Services	7	4,082,172	2,900,654	5,263,690
Health Care: Inpatient	7	612,586	331,370	893,803
Health Care: Outpatient	7	914,332	494,189	1,334,474
Lodging (Includes Nursing)	7	5,340,744	1,940,623	8,740,865
Mercantile: Retail (other than mall)	8	3,401,350	2,017,912	4,784,788
Mercantile: Enclosed and Strip Malls	5	6,307,752	4,428,257	8,187,248
Office	16	4,762,177	3,177,812	6,346,542
Public Assembly	9	2,525,907	799,534	4,252,279
Public Order and Safety	7	759,636	273,044	1,246,227
Religious Worship	7	1,941,057	665,158	3,216,957
Service	7	1,892,272	463,339	3,321,205
Warehouse and Storage	11	3,611,794	2,009,122	5,214,466
Other (Includes CBECS = Other, Laboratory) and Vacant	7	542,034	71,102	1,012,966

Table 68: Commercial cumulative motor MWh consumption magnitude results and 90% confidence interval (CI) by subsector

Subsector	N	Motor Consumption (MWh)	Motor Consumption (MWh) 90% CI LCL	Motor Consumption (MWh) 90% CI UCL
Education	11	76,338,893	64,297,426	88,380,360
Food Sales	7	23,642,670	17,079,399	30,205,940
Food Services	7	34,776,262	26,656,611	42,895,912
Health Care: Inpatient	7	34,759,383	26,104,639	43,414,127
Health Care: Outpatient	7	20,085,177	12,217,297	27,953,057
Lodging (Includes Nursing)	7	59,189,118	43,797,998	74,580,237
Mercantile: Retail (other than mall)	8	30,649,528	22,986,693	38,312,363
Mercantile: Enclosed and Strip Malls	5	33,771,833	23,504,768	44,038,898
Office	16	93,334,776	66,360,897	120,308,654
Public Assembly	9	27,552,463	19,902,041	35,202,885
Public Order and Safety	7	11,816,966	7,665,664	15,968,269
Religious Worship	7	10,487,390	6,792,420	14,182,361
Service	7	6,892,861	5,257,861	8,527,861
Warehouse and Storage	11	40,054,011	25,924,270	54,183,752
Other (Includes CBECS = Other, Laboratory) and Vacant	7	28,672,527	17,278,958	40,066,095

Appendix C: Field Assessment Questions

This appendix documents the questions used by the engineering team (“assessor[s]”) at each site during the on-site motor system field assessment.

Six sets of questions were used and are documented here:

- Basic motor inventory questions were used to gather motor inventory and operating characteristics for all motors across all systems observed at the facility (Table 69).
- Pump checklist questions were for pump systems greater than 20 hp and operating more than 2,000 hours. These were asked to provide more detailed information on the pump system and its operating characteristics (Table 70).
- Fan/blower questions were for fan/blower systems greater than 20 hp and operating more than 2,000 hours. These were asked to provide more detailed information on the fan/blower system and its operating characteristics (Table 71).
- Compressed air checklist questions were for compressed air systems greater than 20 hp and operating more than 2,000 hours. These were asked to provide more detailed information on the compressed air system and its operating characteristics (Table 72).
- Refrigeration checklist questions were for refrigeration systems greater than 20 hp and operating more than 2,000 hours. These were asked to provide more detailed information on the refrigeration system and its operating characteristics (Table 73).
- Facility general motor questions were used to gather information on general motor system energy management and maintenance protocols (Table 74).

The questions are documented in the form of six tables corresponding to each of the above. The first column (Field #) provides the question number, the second (Field Label) provides the question, the third (Field Type) provides the format for answering the question, the fourth (Field Description) provides further details on the Field Label, the fifth (Field Options) provides the answer choices when applicable, and the sixth (Other Notes) provides additional guidance on how the question should be answered.

Basic motor inventory questions

Table 69: Basic motor inventory

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.01	Department	Dropdown	Various Departments previously entered in by assessor	List of assessor entered departments	
1.02	Sub Department Description	Open Ended	An optional description of the area that the system is in. Intended to assist in identifying motor. Not intended for LBNL use.		
1.03	Package Name	Open Ended	A required name		
1.04	Quantity	Numerical	The number of identical systems that this entry encompasses. (All systems encompassed in the quantity have the same or nearly the same characteristics.)		
1.05	Black Box	Check Box	If data regarding individual motors and motor-driven components within the package are inaccessible, then "Black Box" is selected. If "Black Box" is selected, the assessor collects operation and nameplate data for the complete package.	Single Checkbox (Black box or not)	If selected, the following fields are hidden from collection: "Mechanical Transmission Type," "Component Size" 1 and 2, "Load Control Type," "Control Setting," "Motor Load Vary," "Motor Load Feedback," "Load varying output controls," and "System run unnecessarily," as well as all nameplate fields that hide when nameplate is "illegible."
1.06	Rated Power	Numerical Open Ended	Nameplate rated nominal output power		
1.07	Rated Power Unit	Dropdown	Unit of nameplate rated power	HP, kW	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.08	Rated Power Source (unlabeled)	Radio Button	Source of rated power information	Observed, From Contact, Visually, Estimated, Other	
1.09	End Use Component	Fixed Dropdown	Type of driven equipment. This category/type will be used to aggregate motor data by application and to associate motor end uses to other parameters such as NAICS	Pump, Centrifugal; Pump, Positive Displacement; Pump, Other; Fan, Centrifugal / Blower; Fan, Axial; Fan, Other; Blower, Positive Displacement; Vacuum Pump; Air Compressor, Rotary Screw; Air Compressor, Centrifugal; Air Compressor, Recip; Air Compressor, Other; Refrig Compressor, Screw; Refrig Compressor, Recip; Refrig Compressor, Hermetic; Refrig Compressor, Centrifugal; Material Handling; Material Processing; None of the Above	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.10	Process Type	Fixed Dropdown	A description of the application of the package in general terms	Refrigeration/Chiller Plant (including condensers/towers and primary pumps); Process/Equipment Cooling (including secondary pumps); Space Cooling (including secondary pumps); Cleaning In Place (CIP); Other Cleaning; Gas Compression (other than air or refrigerant); Compacting; Extrusion; Molding; Machining/Forming; Other Material Shaping; Grinding/Crushing/Shredding; Screening/Filtration/Separation; Mixing/Agitating; Other Processing; Compressed Air Plant; Hydraulic System; Conveying; Packaging; Product Transfer; Dry Waste Management (not including dust); Dust Collection; Wastewater Management; Hot Water/Steam Plant; Process Heating; Space Heating; Heatless Blowoff Drying (e.g., Air Knife); Aeration; Supply/Return Air Handling; Exhausting; None of the Above; Do Not Know	
1.11	Schedule	Fixed Dropdown	The name of the general schedule that the package operates with	List of assessor entered schedules	Defaults to the schedule associated with the previously selected department
1.12	Annual Hours	Numerical	Annual hours that the equipment operation is based on	From 1 to 8,736	The "Annual Hours" is not necessarily the actual annual run time of the equipment. The "Annual Hours" multiplied by the "Cycling Factor" equate to the estimated actual run hours of the equipment.

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.13	Cycling Factor	Percent	The percent of the "Annual Hours" that the equipment is energized and operating	1% to 100%	
1.14	Facility Motor/Equipment Tag	Open Ended	Any facility produced code used to identify the equipment and/or motor.		Is used only for adding clarity to the inventory and report produced for the facility for their participation
1.15	Mechanical Transmission Type	Fixed Dropdown	The applicable mechanical drive type	Direct Shaft; Belt (Unknown Type); V belt; Cog Belt; Synchronous Belts; Gearbox; None of the Above; Do Not Know	Field is hidden if field number 1.05 ≠ "Yes"
1.16	Package Notes	Open Ended	For the assessor to write down any notes on the motor that can be used later to better clarify the performance and operation of the system		Field is hidden if field number 1.05 ≠ "Yes" and/or field number 1.06 < 20 hp
1.17	Component Size 1 (Flow)	Numerical	The rated nominal output of the driven equipment (flow only)		
1.18	Component Size 1 Unit (Flow)	Editable Dropdown	The unit of the "Component Size 1"	GPM; CFM; ft/sec; Tons (Refrig)	Other units can be added to the list by the assessor, if necessary. Field is hidden if field number 1.05 ≠ "Yes" and/or if field number 1.06 < 20 hp
1.19	Component Size 2 (Press.)		The rated nominal output of the driven equipment (Pressure only). Typically, only used for equipment where both flow and pressure are critical points, e.g., Pumps and Air Compressors.		Field is hidden if field number 1.05 ≠ "Yes" and/or field number 1.06 < 20 hp

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.20	Component Size 2 Unit (Press.)			Ft-Head-PSIG; Bar; In-Wg; In-Hg;	Other units can be added to the list by the assessor if necessary. Field is hidden if field number 1.05 ≠ "Yes" and/or f field number 1.06 < 20 hp

1.21	What is the Load Control Type?	Fixed Dropdown	The system, if any, used to control the output from the motor-driven component	<p>Variable Frequency Drive; Throttle Valve; Inlet Vane; Inlet Damper; Outlet Damper; On/Off Cycling; Load/Unload; Multispeed Motor; Slide Valve; Hydraulic Drive; Eddy Current Drive; Adjustable Speed Gearbox; Mechanical Drive; Multiple Methods w/ VFD; Multiple Methods w/o VFD; None (bypass loop); None (constant load); None of the Above; Do Not Know</p>	<p>Field is hidden if field number 1.05 ≠ "Yes" and/or if field number 1.06 < 20 hp. Special instructions given to assessors: Even if the motor load does not fluctuate, indicate any output controls being utilized in the system. For example, a throttle valve set to 50% flow all the time.</p> <p>Equipment with "No Control": For equipment that always run at full speed and have a constant load, select "None (constant load)." These systems are not likely candidates for control improvement. For example, a process chilled-water pump supplying a constant cooling load.</p> <p>For equipment that always run at full speed but have potential to fluctuate their output, select "None (bypass loop)." These systems may be candidates for control improvements. For example, a chilled water loop with a varying cooling load and 3-way bypass valves.</p> <p>On/Off Cycling: For fixed output equipment that cycle frequently</p>
------	--------------------------------	----------------	--	--	--

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
					<p>and are possible candidates for VFD. .control select "ON/Off Cycling". For example, evaporative condenser fans.</p> <p>For fixed output equipment that are automatically cycled, but infrequently, select "None (constant load)" or "None (bypass loop)", depending on the system design. For example, a constant load wastewater pump that only comes on-line during wet-weather flows.</p>

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.22	What is the control setting?	Radio Button	If the input to the system operation is automatic or manual	Manual Automatic Do Not Know	<p>Field is hidden if field number 1.05 ≠ "Yes" and/or field number 1.06 < 20 hp. This is to indicate if the output of the equipment is being controlled based on an automatic feedback system, or is manually adjusted by an operator.</p> <p>An example of manual adjustment is when operators manually adjust the speed of VFD-controlled conveyor motors based on product loading.</p> <p>This is also to check for possible cases of incomplete commissioning of VFD or other control installations, where output should be automatically controlled, but for some reason is not.</p>

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.23	Does the motor load vary over time?	Radio Button	This is to indicate if the motor brake horsepower ever fluctuates to different values during its typical operation. See "Other Notes" for further clarification and special circumstances of selection.	Yes; No; Do Not Know	<p>Field is hidden if field number 1.05 ≠ "Yes" and/or if field number 1.06 < 20 hp. This is to indicate if the motor load changes significantly based on demand.</p> <p>Just because a piece of equipment is utilizing a control device, does not necessarily mean its output fluctuates. For example, a VFD-equipped fan that is set to constant speed.</p> <p>A note on "On/Off Cycling": Equipment that cycles frequently based on loading and are possible candidates for VFD control, for example condenser fans, should answer "Yes."</p>
1.24	Percent Time Equipment (Not Motor) is below 40% Output:	Percent	<p>This is to indicate the amount of time that the equipment is on, but operating at below 40% of its designed output.</p> <p>This is <u>not</u> referring to the motor load factor.</p>	1% to 100%	An example of this is a fan designed to output 1,000 CFM at full power, but is controlled down to 250 CFM for 30% of its operating time.
1.25	Percent Time Equipment (Not Motor) is at 100% Output:	Percent	<p>This is to indicate the amount of time that the equipment is on, and operating at 100% of its designed output.</p> <p>This is <u>not</u> referring to the motor load factor.</p>	1% to 100%	An example of this is a fan designed to output 1,000 CFM at full power, and operates at design output (1,000 CFM) for 50% of its operating time.

1.26	Average Motor Load Factor	Percent	Average percent (over the total annual run hours of the equipment) of the motor output brake power vs. its rated power.	1% to 125%	<p>This is the average MOTOR power output (brake power) divided by its rated output.</p> <p>The assessor should ask the contact for this data first. If the contact's answer seems plausible to the assessor, considering the answers to the previous several questions, then the assessor should use this value. However, if the contact's answer does not fit with answers to the previous control and profile answers, then the engineer should use his or her judgment.</p> <p>This field defaults to 75% because most motors are oversized for their typical operation. This default is typically only valid for motors that are known to only operate at full load whenever they are on. If any controls are being utilized on the equipment, whether these controls vary the load, then it is likely this value will likely be less. For controlled equipment that is difficult to assess, a good estimate will be 50%-60%.</p> <p>Certain types of equipment (for example, air compressors), commonly operate well above the "rated" motor power (Full-load load factor >120%)</p>
------	---------------------------	---------	---	------------	---

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.27	Is this system a candidate for improved load-varying output controls?	Radio Button	This question is to indicate if a system is currently being run at a constant output, all the time, but has the potential to vary its output based on varying demand downstream.	Yes; No; Do Not Know	Field is hidden if field number 1.23 = "Yes," and/or field is hidden if field number 1.05 ≠ "Yes" and/or if field number 1.06 < 20 hp
1.28	Motor Load Feedback Parameter (What is the input to the control logic?)	Editable Dropdown	This is the parameter that the equipment is being controlled to.	Air Pressure; Automatic Sequencer; Conveyer Load; Differential Pressure; Dissolved Gas Level; Production Loading (e.g., sawmill saw); Gas Concentration Level; Hydraulic Load; Liquid Level Setpoint; Outdoor Ambient Conditions; HVAC Factors (Indoor and Outdoor Conditions); Process Pressure; Process Temperature; None (Manual Control); Do Not Know	Field is hidden if field number 1.23 ≠ "Yes," and/or field is hidden if field number 1.05 ≠ "Yes" and/or if field number 1.06 < 20 hp
1.29	Does the equipment ever run unnecessarily? (i.e., Is this system a candidate for improved runtime controls?)	Radio Button	This is to indicate if a piece of equipment can be controlled to turn off, based on the operation of other equipment, by using interlocking controls or timers.	Yes; No; Do Not Know	Field is hidden if field number 1.05 ≠ "Yes," and/or field is hidden if field number 1.05 ≠ "Yes" and/or field number 1.06 < 20 hp
1.30	Is this a DC Motor?		Indicates if the motor is a DC motor	Yes; No; Do Not Know	
1.31	Is Motor Nameplate Legible?		This is to indicate if the motor nameplate information is mostly illegible for any reason.	Yes; No	Field is hidden if field number 1.05 ≠ "Yes"
1.32	Motor Manufacturer	Open Ended	Manufacturer of the motor		Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes"
1.33	Motor Manufacture Country	Editable Dropdown	Country of motor manufacture	U.S.A.; Japan; China; Mexico; Germany	Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes"

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.34	Motor Efficiency Label		Manufacturer produced label indicating relative level of motor efficiency	Premium; Energy Efficient; Standard; No Label	Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes." This is any labeling that is not necessarily attributed to NEMA official labeling. If you see the official "NEMA Premium" stamp, select "Premium" in this field and select "Yes" in the next field. If the motor label says "Premium Efficient" or something similar, but does not display the official "NEMA Premium" stamp, select "Premium" and select "No" in the next field (1.35).
1.35	Does the motor have the official NEMA Premium Stamp?	Radio Button	To indicate if the motor nameplate includes the official NEMA "Premium" stamp indicating that the motor has been certified by NEMA to be of premium energy performance.	Yes; No	Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes."
1.36	NEMA Nominal Motor Efficiency %	Percent	The NEMA rated nominal efficiency of the motor	1% to 100%	
	NEMA Nominal Motor Efficiency % Source	Radio Button	Source of nominal efficiency information	Observed; From Contact; Visually Estimated; Other	
1.37	Number of Poles (Sync Speed)	Fixed Dropdown	The number of poles in the motor (or the corresponding synchronous speed)	2 (3,600 RPM); 4 (1,800 RPM); 6 (1,200 RPM); 8 (900 RPM); 10 (720 RPM); 12 (600 RPM); Other	Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes"

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.38	Enclosure Type	Fixed Dropdown	The type of motor enclosure.	TEFC (Totally Enclosed, Fan Cooled); ODP (Open, Drip Proof); EXPL (Explosion proof); TENV (Totally Enclosed, Not Ventilated); TEAO (Totally Enclosed, Air Over); TEBC (Totally Enclosed, Blower Cooled); TEWD (Totally Enclosed, Washdown. i.e., "Waterproof"); Other; Can't Observe	Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes"
1.39	Motor Design	Fixed Dropdown	The relevant NEMA code if it is a synchronous motor.	A; B; C; D; E; Synchronous; Special Purpose	Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes"
1.40	Frame Size	Editable Dropdown		42; 48; 56; 56h; 143T; 145T; 182; 182T; 184T; 213	Field is hidden if field number 1.05 and/or 1.31 ≠ "Yes"
1.41	Was the motor operating under typical conditions when observed?	Radio Button		Yes; No; Do Not Know	
1.42	Motor Repairs within 2 years: (Check all that apply)	Checkbox		Rewind; Bearing Replacement; Other; Do Not Know	
1.43	Estimate of motor installation year	Numerical			
1.44	Uptime for this motor over last 12 months (%)	Percent		1% to 100%	Field is hidden if field number 1.06 < 20 hp
1.45	Has this motor ever been rewound?	Radio Button		Yes; No; Do Not Know	Field is hidden if field number 1.06 < 20 hp

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
1.46	How many times has the motor been rewound?	Fixed Dropdown		1; 2; 3; 4; 5+	Field is hidden if field number 1.06 < 20 hp

Pump checklist

Table 70: Pump checklist

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
2.01	Pump Type	Fixed Dropdown	Specific pump technology	Positive Displacement; Positive Displacement – Piston; Positive Displacement – Screw; Positive Displacement - Sliding Vane; Positive Displacement - Rotary Lobe Types; Centrifugal; Centrifugal – Axial; Centrifugal - Mixed Flow; Centrifugal – Radial; None of the Above	
2.02	What is the working fluid?	Fixed Dropdown	Type of fluid being pumped	Clean Water; Glycol Solution; Other Water; Process Chemicals; Slurries; Refrigerant; Oil; Provide Hydraulic Force	
2.03	Pump Manufacturer	Editable Dropdown	Pump Manufacturer	American-Marsh; Grundfos; Gorman-Rupp Co.; PACO Pumps; Taco Pumps, Inc.; Weiman; Börger; Bell and Gossett; Fristam; Ollgear	Assessor can add to the available options
2.04	Pump Manufacture Year	Numerical Open Ended	Nameplate year of manufacture		
2.05	Approximate pump age in years (if year is unavailable)	Radio Buttons	Estimated age of pump if exact year is unknown	0-5; 6-10; 11-20; 21+	
2.06	Pump Capacity (GPM)	Numerical Open Ended	Rated flow capacity of the pump at design conditions		
2.07	Pump Head (ft)	Numerical Open Ended	Rated head pressure capacity of the pump at design conditions		
2.08	Pump Full Load Speed (RPM, not motor)	Numerical Open Ended	Rated speed of the pump at design conditions		

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
2.09	Country of Manufacture	Editable Dropdown	Country of Manufacture	U.S.A.; Japan; China; Mexico	Assessor can add to the available options
2.10	Is the pump on a flow meter?	Radio Buttons	If there is a flow meter installed on the output of this specific pump?	Yes; No; Do Not Know	
2.11	What does the flow meter read?	Numerical Open Ended	What is the reading of the pump specific flow meter?		Hidden if 2.10 ≠ "Yes"
2.12	What is the observed discharge pressure of the pump?	Numerical Open Ended	What is the reading of the output pressure of the pump?		
2.13	From staff, was the pump operating under typical conditions?	Radio Buttons		Yes; No; Do Not Know	
2.14	Is this pump primarily for flow or pressurization?	Fixed Dropdown	What does most of the pumps energy go to, flow or pressure?	Flow (friction dominated system); Pressurization (static dominated system) Combination (mixed friction-static systems); Do Not Know	
2.15	Flow output controls:	Fixed Dropdown	What is the primary control method for this specific pump?	VFD; Motor Controlled Valve Throttling; Manual Valve Throttling; Bypass; Mix of Throttles and Bypass; Multiple Pump Staging; Multispeed Pump; Multiple Methods w/ VFD; Multiple Methods w/o VFD; None (Constant Load); None (Bypass Loop); Do Not Know	
2.16	What was the observed throttle valve position?	Fixed Dropdown	If the flow is controlled by throttle vales, what was the observed position?	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Can't Observe	Hidden if 2.15 ≠ "Motor Controlled Valve Throttling" OR "Manual Valve Throttling" OR "Mix of Throttles and Bypass"

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
2.17	What is the observed speed?	Percent	Observed speed of the pump relative to the rated speed		Hidden if 2.15 ≠ "VFD" OR "Multiple Methods w/ VFD"
2.18	What is the throttle valve type?	Fixed Dropdown	What is the valve technology of the throttle valve?	Ball ; Butterfly; Gate; Other; Do Not Know	Hidden if 2.15 ≠ "Motor Controlled Valve Throttling" OR "Manual Valve Throttling" OR "Mix of Throttles and Bypass"
2.19	Is the VFD appropriate? (or is the pump at full speed all the time?)	Radio Buttons	Attempts to clarify if this pump is appropriately utilizing the VFD (for permanent or temporary part loading of the pump) or if the pump operates at full speed all the time.	Yes; No; Do Not Know	Hidden if 2.15 ≠ "VFD" OR "Multiple Methods w/ VFD"
2.20	Is the throttling valve ever adjusted?	Radio Buttons	Clarifies if the throttle valves are ever adjusted or remain at a fixed position, year-round.	Yes; No; Do Not Know	Hidden if 2.15 ≠ "Motor Controlled Valve Throttling" OR "Manual Valve Throttling" OR "Mix of Throttles and Bypass"
2.21	Is the current pump system size appropriate for the load?	Radio Buttons	Asks the contact if the pump is appropriately sized for its current duty.	Yes; No; Do Not Know	
2.22	Is this pump part of a lead/lag system?	Radio Buttons	Does the pump operate in conjunction with other pumps discharging to the same header and cycle on and off based on system loading?	Yes; No; Do Not Know	
2.23	Does your facility keep a pump curve for this pump on file?	Radio Buttons		Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
2.24	Which of these were done in the last 2 years? (check all that apply):	Checkbox		Bearings lubricated or replaced; Mechanical seal replaced; Packing tightened or replaced; Wear ring adjusted or replaced; Impeller replaced; Another repair; Do Not Know	
2.25	Which of the following were considered when selecting this pump? (select all that apply)	Checkbox		To ensure all pressure and flow requirements would be met; Best Efficiency Point; Lowest Implementation Cost; Lowest Running Cost; Corporate Requirement; Meeting Specs of Replaced Pump; Preference for Vendor; Preference for Manufacturer; Utility or Other Rebate; Overall System Energy Efficiency; Included in Package; Do Not Know	
2.26	Assessor estimate of system efficiency compared to best available technology and best maintenance practices:	Fixed Dropdown	Assessors on the spot assessment of the efficiency if the system	Very Poor; Poor; Fair; Good; Excellent	
2.27	Feasible energy savings potential?	Fixed Dropdown	Assessors on the spot assessment of the energy savings potential of the system	0-10%; 10-20%; 20-30%; 30-40%; More than 40%; Cannot reasonably estimate	

Fan/blower checklist

Table 71: Fan/blower checklist

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
3.01	Fan Type	Fixed Dropdown	Specific Fan technology	Positive displacement - Roots (Rotary Lobe); Positive displacement – Other; Axial; Axial – Vain; Axial – Tube; Axial – Propeller; Centrifugal; Centrifugal - Air Foil; Centrifugal - Backward Curved; Centrifugal - Forward Curved	
3.02	What is the fan used for?	Fixed Dropdown	Primary function of the fan/blower	Exhaust Gases; Ventilation – Supply; Ventilation – Return; Air Handling; Process Heating; Process Cooling; Process Ventilation; Materials Conveying; Refrigeration (Evaporator); Cooling Tower/Condenser; High Pressure Blower; Combustion Blower; Aeration; Mixing/Agitation; None of the Above; Do Not Know	
3.03	Fan Manufacturer	Editable Dropdown	Fan Manufacturer	Greenheck; New Your Blower; Twin City Blower	Assessor can add to the available options.
3.04	Country of Manufacture	Editable Dropdown	Country of Manufacture	U.S.A.; Japan; China; Mexico	Assessor can add to the available options.
3.05	Fan Manufacture Year	Numerical Open Ended	Nameplate year of manufacture		

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
3.06	Approximate fan age in years (if year is unavailable)	Radio Buttons	Estimated age of fan if exact year is unknown	0-5; 6-10; 11-20; 21+	
3.07	Rated flow rate (CFM)	Numerical Open Ended	Rated flow capacity of the fan at design conditions		
3.08	Rated Static Pressure (in-WG)	Numerical Open Ended	Rated head pressure capacity of the fan at design conditions		
3.09	Fan Diameter (in)	Numerical Open Ended	Diameter of fan impeller		
3.10	Fan Full Load Speed (RPM, not motor)	Numerical Open Ended	Rated speed of the fan at design conditions		
3.11	Is the fan on a flow meter?	Radio Buttons	If there is a flow meter installed on the output of this specific fan	Yes; No; Do Not Know	
3.12	What does the flow meter read?	Numerical Open Ended	What is the reading of the fan specific flow meter?		Hidden if 3.11 ≠ "Yes"
3.13	From staff, was the fan operating under typical conditions?	Radio Buttons		Yes; No; Do Not Know	
3.14	Flow output controls:	Fixed Dropdown	What is the primary control method for this specific fan?	VFD; Dampers; Inlet Vain; Disc Throttle; Variable Pitch; Multispeed Motor; Multiple Fans; Multiple Methods w/ VFD; Multiple Methods w/o VFD; None (Constant Load); None (Bypass or Open Flow); Other; Do Not Know	
3.15	Does the fan flow vary over time?	Radio Buttons	Clarifies if flow output of the fan varies over time.	Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
3.16	Is this fan part of a lead/lag system?	Radio Buttons	Does the fan operate in conjunction with other fans discharging to the same distribution system and cycle on and off based on system loading?	Yes; No; Do Not Know	
3.17	What was the observed damper position?	Fixed Dropdown	If the flow is controlled by a damper or veins, what was the observed position?	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Can't Observe	Hidden if 3.14 ≠ "Inlet Vain" OR "Disc Throttle" OR "Variable Pitch" OR "Dampers"
3.18	What is the observed speed?	Percent	Observed speed of the fan relative to the rated speed		Hidden if 3.14 ≠ "VFD" OR "Multiple Methods w/ VFD"
3.19	Is the VFD appropriate? (or is the fan at full speed all the time?)	Radio Buttons	Attempts to clarify if this fan is appropriately utilizing the VFD (for permanent or temporary part load operation of the fan) or if the fan operates at full speed all the time.	Yes; No; Do Not Know	Hidden if 3.14 ≠ "VFD" OR "Multiple Methods w/ VFD"
3.20	Is the current fan system size appropriate for the load?	Radio Buttons	Ask the contact if the fan is appropriately sized for its current duty.	Yes; No; Do Not Know	
3.21	Is the throttling damper ever adjusted?	Radio Buttons	Clarify if the throttle dampers or veins are ever adjusted or remain at a fixed position, year-round.	Yes; No; Do Not Know	Hidden if 3.14 ≠ "Inlet Vain" OR "Disc Throttle" OR "Variable Pitch" OR "Dampers"
3.22	Does your facility keep a fan curve for this fan on file?	Radio Buttons		Yes; No; Do Not Know	
3.23	Which of these were done in the last 2 years? (check all that apply):	Checkbox		Bearings lubricated or replaced; Cleaned; Blades replaced; Other repair; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
3.24	Which of the following were considered when selecting this fan (select all that apply)?	Checkbox		To ensure all pressure and flow requirements would be met; Based on air conditions (e.g., contaminant, moisture, etc.); Minimize noise; Best Efficiency Point; Lowest Implementation Cost; Lowest Running Cost; Corporate Requirement; Meeting Specs of Replaced Fan; Preference for Vendor; Preference for Manufacturer; Utility or Other Rebate; Overall System Energy Efficiency; Included in Package; Do Not Know	
3.25	Assessor estimate of system efficiency compared to best available technology and best maintenance practices:	Fixed Dropdown	Assessors on the spot assessment of the energy efficiency of the system	Very Poor; Poor; Fair; Good; Excellent	
3.26	Feasible energy savings potential?	Fixed Dropdown	Assessors on the spot assessment of the energy savings potential of the system	0-10%; 10-20%; 20-30%; 30-40%; More than 40%; Cannot reasonably estimate	

Compressed air checklist

Table 72: Compressed air checklist

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.01	Manufacturer	Editable Dropdown	Compressor manufacturer	Atlas Copco; Boge; Chicago Pneumatic; compare; FS Curtis; Gardner Denver; Ingersoll Rand; Kaeser; Mattei; Quincy; Sullair; Sullivan-Palatek; Do Not Know	Assessor can add to the available options.
4.02	Model Number	Open Ended	Compressor model number		
4.03	Type	Fixed Dropdown	Type of air compressor technology	Rotary Screw; Reciprocating – Single Acting; Reciprocating – Double Acting; Centrifugal; Do Not Know	
4.04	CFM Rating	Numerical Open Ended	Nameplate CFM rating of this specific compressor		
4.05	PSI Rating	Numerical Open Ended	Nameplate PSI rating of this specific compressor		
4.06	Year of Manufacture	Numerical Open Ended			
4.07	Lubrication	Radio Button	Type of air cooling/lubrication technology	Oil Injected; Oil-free; Do Not Know	
4.08	Cooling	Radio Button	Type of air compressor unit heat rejection	Air-cooled; Water-cooled; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.09	Capacity Control	Fixed Dropdown	Type of compressor output capacity control technology	Start/Stop; Load/Unload w/Shutdown Timer; Load/Unload w/o Shutdown Timer; Modulating; Variable Displacement; VFD; None of the Above; Do Not Know	
4.10	Pressure Setpoint	Numerical Open Ended	Setpoint pressure for this specific pressure		
4.11	Cut-in pressure	Numerical Open Ended	Lower end of the control band for the compressor at which the compressor will start discharging air to the system.		
4.12	Cut-out pressure	Numerical Open Ended	Upper end of the control band for the compressor at which the compressor will stop discharging air to the system.		
4.13	Observed compressor output pressure	Numerical Open Ended	Observed discharge pressure of the compressor at the time of observation		
4.14	Sequencing stage	Radio Button	Role of this specific compressor in the system level control strategy	Baseload; Trim; Unsequenced; Do Not Know	
4.15	Is the compressor using outdoor air when colder than ambient?	Radio Button	Is the compressor located outside, in a well-ventilated compressor room, or have an intake duct from the outside?	Yes; No; Do Not Know; N/A	
4.16	Is it feasible to duct outside air to the compressor?	Radio Button	If the compressor is not currently utilizing cooler outside air when available, is it feasible to duct or otherwise provide cooler air for intake when available?	Yes; No; Do Not Know; N/A	
4.17	Is the intake located away from contaminants like dust?	Radio Button		Yes; No; Do Not Know; N/A	
4.18	Is there an air filter on the incoming air?	Radio Button		Yes; No; Do Not Know; N/A	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.19	Is the air filter replaced per manufacturer's specifications?	Radio Button	Ask a knowledgeable contact.	Yes; No; Do Not Know; N/A	
4.20	Any compressors arranged in series for multi-stage compression?	Radio Button	Is the system designed in a way where the output of one compressor is the input of another to raise the pressure of the air in multiple stages using multiple compressors? This is not asking if any of the compressor units are multistage themselves.	Yes; No; N/A; Do Not Know	
4.21	What system level controls are in place?	Fixed Dropdown	What, if any, system level control technology is utilized to stage multiple compressors as compressed air load varies?	N/A (Single Compressor); Cascading Set Points; System Master Sequencing Controls; Network (Multi-Master) Controls; Automatic System Sequencing (Unknown Type); None (Manual Sequencing); None of the Above	
4.22	Is there a main air receiver?	Radio Button	Is there a main air receiver at or near the compressed air plant?	Yes; No; N/A; Do Not Know	
4.23	Main receiver height/length (ft):	Numerical Open Ended			Hides if 4.22 = no
4.24	Main receiver diameter (ft):	Numerical Open Ended			Hides if 4.22 = no
4.25	Main receiver volume (gal):	Numerical Open Ended			Will automatically calculate based on height and diameter. Can also be overwritten if the capacity is known. Hide if 4.22 = no.

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.26	Does the system have a pressure/flow controller?	Radio Button	Does the system have an arrangement of control equipment consisting of: a large air storage receiver, precision motor driven control valve, pressure transducer or pneumatic servo pilot device, and control panel used to maintain a tight balance point pressure in the main compressed air header.	Yes; No; Do Not Know	
4.27	What is the observed system pressure (preferably downstream of the compressed air plant)?	Numerical Open Ended	What is the pressure in the compressed air header near the main compressed air plant?		
4.28	Type of dryer(s)	Fixed Dropdown		Refrigerant Cycling; Refrigerant Non- Cycling; Regenerative Desiccant; Deliquescent; Heat-of- Compression; Membrane; Combination of Different Types; No Dryer; None of the Above; Do Not Know	
4.29	Total CFM capacity of dryer(s) (CFM)	Numerical Open Ended			
4.30	Are there controls installed that modulate dryer energy consumption based on compressed air demand?	Radio Button		Yes; No; N/A; Do Not Know	Hide if 4.28 = Regenerative Desiccant
4.31	Are desiccant dryer(s) controlled with dew point switching (DDS) controls?	Radio Button		Yes; No; N/A; Do Not Know	Hide if 4.28 ≠ Regenerative Desiccant
4.32	Total rated power of dryer(s) (HP or kW)	Numerical Open Ended			

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.33	Have you developed a pressure profile of your system to determine peak demand and dynamics of demand?	Radio Button		Yes; No; Do Not Know	
4.34	When (with respect to question 4.33)?				Hides if 4.33 ≠ Yes
4.35	Does compressed air demand vary significantly over time?	Checkbox	Does the compressed air load vary over time or does it stay consistent, whenever the system is being utilized?	Shift-wise; Seasonally	
4.36	Does the system stay pressurized for relatively small loads during non-production hours? (e.g., pneumatic controls, specialized equipment, etc.)	Radio Button	Is the main compressed air system being utilized to supply relatively small amounts of air for a few small loads when the main facility is not in production?	Yes; No; Do Not Know	
4.37	What percentage of the typical non-production CFM goes to the loads in question 4.36?	Percent			Hides if 4.36 ≠ Yes
4.38	Have you adjusted your compressor controls in the last year?	Radio Button	Have any setpoints or control logic been changed in the last year?	Yes; No; Do Not Know	
4.39	How capable is your current control strategy at meeting the facility's load?	Fixed Dropdown		All the time able to meet load; Most of the time able to meet load; Frequently struggles to meet load	
4.40	What is the highest pressure is required at the end-use points? (PSIG)	Numerical Open Ended	Of all the loads that the compressed air system serves, what is the highest required pressure at the point of use?		
4.41	What fraction of the average plant demand requires this pressure?	Percent			

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.42	Do the end uses require significantly different pressures?	Radio Button	Is there a significant difference in the required point of use pressures for all the loads served by the compressed air system?	Yes; No; Do Not Know	
4.43	Do you have a few high-pressure applications that determine the operating pressure for your entire plant?	Radio Button	Are the loads that dictate the supplied air pressure relatively small compared to the total load on the system (<10% CFM)	Yes; No; Do Not Know	
4.44	Have you investigated ways to serve high pressure applications at a lower pressure?	Radio Button	Has the facility studied the feasibility of utilizing lower pressure for these loads?	Yes; No; Do Not Know	
4.45	Are you using any of the following to supply intermittent, high volume applications?	Checkbox	Secondary Storage Receivers; Separate Compressor, Booster, or Amplifier		
4.46	Does the system use production, or schedule-based pressure setbacks? (PSI or PSI range setback)	Radio Button	Does the facility set back the pressure set points based on varying production requirements	Yes; No; Do Not Know	
4.47	Have you attempted to lower the system pressure any time in the last year?	Radio Button	Has the facility attempted to, and studied the effects of, lowering the compressed air plant discharge pressure in the last year?	Yes; No; Do Not Know	
4.48	Was it successful?	Radio Button		Yes; No; Do Not Know	
4.49	Do you have end-use applications that require a significantly different level of air quality?	Radio Button	Is there a significant difference in the required point of use air quality for all the loads served by the compressed air system?	Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.50	Do you have a few end use applications requiring high air quality that determine the air quality for the entire plant?	Radio Button	Are the loads that dictate the supplied air quality relatively small compared to the total load on the system (<10% CFM)	Yes; No; Do Not Know	
4.51	Have you investigated ways to serve these high air quality applications with point-of-use solutions?	Radio Button		Yes; No; Do Not Know	
4.52	Is oil-free air being used on end uses that do not require it?	Radio Button		Yes; No; N/A; Do Not Know	
4.53	Do you use compressed air for any of the following?	Checkbox		Open Blowing; Drying; Agitating; Stirring; Mixing; Aspirating; Atomizing; Padding; Dilute Phase Transport; Dense Phase Transport; Vacuum Generation; Personnel Cooling; Open Hand-held Blowguns; Cabinet Cooling; Vacuum Ventures; Diaphragm Pumps; Timer/Open Drains; Air Motors	
4.54	Can you estimate how much compressed air these end uses consume compared to total production?	Percent			

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.55	Have you analyzed your end uses to make sure they could not be more efficiently served using alternative energy sources (blower air, mechanical drive)?	Radio Button		Yes; No; Do Not Know	
4.56	Have you estimated the amount of leakage in your system?	Radio Button		Yes; No; Do Not Know	
4.57	Do you have the equipment to detect leaks (e.g., ultrasonic leak detector) or do you outsource leak detection?	Checkbox		Detection Equip.; Outsource; Other; None; Do Not Know	
4.58	Do you have an ongoing leak management program?	Radio Button		Yes; No; N/A; Do Not Know	
4.59	How often does your leak management program call for finding and repairing air leaks?	Fixed Dropdown		Daily; Weekly; Monthly; Annually; Other	
4.60	Do you adjust compressor controls after repairing leaks?	Radio Button		Yes; No; Do Not Know	
4.61	Do you (the assessor) hear a significant number of leaks?	Radio Button		Yes; No; Do Not Know	
4.62	What percent of your condensate drains are manual drain?	Percent			
4.63	What percent of your condensate drains are disc drain?	Percent			
4.64	What percent of your condensate drains are timed drain?	Percent			

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.65	What percent of your condensate drains are float traps?	Percent			
4.66	What percent of your condensate drains are solenoid valves?	Percent			
4.67	What percent of your condensate drains are zero loss traps?	Percent			
4.68	Have you measured pressure at various points in the system to determine pressure drop?	Radio Button		Yes; No; Do Not Know	
4.69	When?	Fixed Dropdown		Continuously; Within Last Month; Within Last Quarter; Within Last 6 Months; Within Last Year; Within Last 2 Years; Within Last 5 Years; More Than 5 Years	
4.70	Have you altered the system to reduce pressure drops? (For example: removing extra bends, increasing pipe diameter, looping main headers)	Radio Button	Has the facility recently modified the compressed air distribution piping to reduce pressure drops and allow the compressor plant to operate at a lower pressure?	Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.71	When (with respect to 4.70)?	Fixed Dropdown		Continuously; Within Last Month; Within Last Quarter; Within Last 6 Months; Within Last Year; Within Last 2 Years; Within Last 5 Years; More Than 5 Years	
4.72	Do you meet or exceed compressor and dryer manufacturer's requirements for maintenance?	Radio Button		Yes; No; Do Not Know	
4.73	Do you have a preventive maintenance program?	Radio Button		Yes; No; Do Not Know	
4.74	How often do you inspect the condensate drains?	Fixed Dropdown		Daily; Weekly; Monthly; Annually; Other	
4.75	Do you periodically inspect and replace end-use filters, check regulators, and lubricators to maintain functionality?	Radio Button		Yes; No; Do Not Know	
4.76	In the past 5 years, has there been an energy efficiency assessment performed on the compressed air system?	Radio Button		Yes; No; Do Not Know	
4.77	What percentage of the recommendations were implemented? (estimate, in terms of energy savings potential)	Percent			

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
4.78	Assessor's estimate of efficiency of system compared to Best Available Technology and best maintenance practices:	Fixed Dropdown	Assessors on the spot assessment of the efficiency of the system	Very Poor; Poor; Fair; Good; Excellent	
4.79	Feasible energy savings potential?	Fixed Dropdown	Assessors on the spot assessment of the energy savings potential of the system	0-10%; 10-20%; 20-30%; 30-40%; More than 40%; Cannot reasonably estimate	

Refrigeration checklist

Table 73: Refrigeration checklist

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.01	Manufacturer	Editable Dropdown	Compressor/Chiller manufacturer	Frick; Vilter; GEA; Trane; Copeland; York; Carrier; McQuay; Do Not Know	Assessor can add to the available options
5.02	Model Number	Open Ended	Compressor/Chiller model number		
5.03	Year of Manufacture	Numerical Open Ended			
5.04	Type	Fixed Dropdown	Type of air compressor/chiller technology	Recip; Screw; Rotary Vane; Centrifugal; None of the Above; Do Not Know	
5.05	Primary Application	Single Stage; High Stage; Low (Booster) Stage; Swing			
5.06	Design COP	Numerical Open Ended	Nameplate COP rating of this specific compressor/chiller at design		
5.07	Cooling Output Rating	Numerical Open Ended	Nameplate cooling capacity rating of this specific compressor/chiller		
5.08	Type of Oil Cooling	Radio Button	Type of oil cooling technology	Direct Oil Injection; External Heat Exchanger; Thermosiphon; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.09	Capacity Control	Fixed Dropdown	Type of compressor/chiller output capacity control technology	Cylinder Unloading (Recip Only); Slide Valve (Screw Only); Inlet Vane (Centrifugal Only); VFD Only; VFD w/ Slide Valve; VFD w/ Inlet Vane; On/Off; Other	
5.10	Sequencing stage	Radio Button	Role of this specific compressor/chiller in the system level control strategy	Baseload; Trim; Unsequenced; Do Not Know	
5.11	Observed suction pressure? (see compressor digital display or analog gauge)	Numerical Open Ended			
5.12	Observed discharge pressure? (see compressor digital display or analog gauge)	Numerical Open Ended			
5.13	Cooling load end use (select all that apply):	Checkbox	What are the primary cooling end uses that this system serves?	Process Cooling; Refrigerated Warehouse; HVAC; Equipment Cooling; Do Not Know	
5.14	Type of evaporator systems (select all that apply):	Checkbox	Primary evaporator technologies that exchange heat to the refrigeration cycle?	Liquid Chiller (Chilled Water / Chilled Glycol); Direct Air Cooling (unknown evaporator type); Direct Expansion; Liquid Overfeed; Flooded; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.15	Type of defrost	Fixed Dropdown		Hot Gas; Electric; Water; N/A; Do Not Know	Hide if 5.14 only = "Liquid Chiller (Chilled water / Chilled Glycol)"
5.16	System Refrigerant	Fixed Dropdown		Ammonia; R22; Other; Do Not Know	
5.17	System Stages	Fixed Dropdown	Primary design of the system, in regard to compression and expansion stages.	1-Stg. Compression and Liquid Expansion; 1-Stg. Compression and 2-Stg. Liquid Exp.; 2-Stg. Compression and Liquid Expansion; 2-Stg. Compression; Other; Do Not Know	
5.18	(Low Stage) Suction pressure setpoint	Numerical Open Ended			
5.19	(Low stage) Suction temperature setpoint (only if pressure is unavailable)	Numerical Open Ended			Hide if 5.18 = "unable to collect"
5.20	High stage suction pressure	Numerical Open Ended	If the system is a two-stage system, what is the high stage suction pressure?		Hide if 5.17 = "1-Stg. Compression and Liquid Expansion"
5.21	High stage suction Temperature	Numerical Open Ended	If the system is a two-stage system, what is the high stage suction temperature?		Hide if 5.20 = "unable to collect"
5.22	Constant or variable chiller flow	Radio Button	If the system produces chilled water, glycol, or other liquid media, does the flow through the refrigerant to liquid heat exchanger vary, or stay constant?	Constant Flow; Variable Flow; Do Not Know	Hide if 5.14 ≠ "Liquid Chiller (Chilled water / Chilled Glycol)"

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.23	Average or observed chilled water supply temperature	Numerical Open Ended			Hide if 5.14 ≠ "Liquid Chiller (Chilled water / Chilled Glycol)"
5.24	Average or observed chilled water return temperature	Numerical Open Ended			Hide if 5.14 ≠ "Liquid Chiller (Chilled water / Chilled Glycol)"
5.25	What is the setpoint temperature of the coldest load?	Numerical Open Ended	What is the temperature that dictates the suction temperature of the system?		
5.26	What is the setpoint temperature of the largest higher-temperature load?	Numerical Open Ended	What is the temperature of the most significant load that does not require the lowest temperature set point?		
5.27	Heat rejection method	Fixed Dropdown		Evaporative Condenser; Air Cooled Condenser; Water Cooled (Cooling Tower); Water Cooled (Dry Cooler); Do Not Know	
5.28	Total condenser/cooling tower fan capacity (hp)	Numerical Open Ended	What is the total hp capacity of the heat rejection fans?		
5.29	What is the current approach temperature? (at design conditions, if fixed head)	Numerical Open Ended	If the system has a fixed head, this is the approach temperature at design conditions. If this is a floating head system, this is the setpoint approach temperature.		

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.30	Does the current sequencing strategy ensure that no screw compressor operates below 50% capacity?	Radio Button	Is the current sequencing technology and logic capable of ensuring that no screw compressor runs below 50% capacity?	Yes; No; N/A; Do Not Know	
5.31	Does the system utilize floating head (discharge) pressure (or condenser water temperature reset)?	Radio Button		Yes; No; Do Not Know	
5.32	What is your current minimum discharge pressure?	Numerical Open Ended	What is the lowest discharge pressure that the system can handle without causing issues?		
5.33	What is likely the cause of discharge pressure lower limit?	Editable Dropdown	What parameter currently dictates the lowest that the discharge pressure can go?	Hot Gas Defrost; Injected Oil Cooling; Condenser Capacity; Oil Separator Performance; Heated Zones or Underfloor Heating; Do Not Know Other	
5.34	Does the system utilize floating suction pressure?	Radio Button	Does the system vary its suction pressure over time based on varying production requirements?	Yes; No; Do Not Know	
5.35	Highest achievable suction pressure	Numerical Open Ended			
5.36	Percent of evaporator (or Air Handler) fan motor controls that are on/off cycling?	Percent		Shift-wise; Seasonally;	Hide if 5.14 only = "Liquid Chiller (Chilled water / Chilled Glycol)"
5.37	Percent of evaporator (or air handler) fan motor controls that are 2 speed motors	Percent		Yes; No; Do Not Know	Hide if 5.14 only = "Liquid Chiller (Chilled water / Chilled Glycol)"

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.38	Percent of evaporator (or air handler) fan motor controls that are VFD control	Percent			Hide if 5.14 only = "Liquid Chiller (Chilled water / Chilled Glycol)"
5.39	Percent of evaporator (or Air Handler) fan motor controls that have no fan control	Percent		Yes; No; Do Not Know	Hide if 5.14 only = "Liquid Chiller (Chilled water / Chilled Glycol)"
5.40	Do you use active defrost management?	Radio Button		Yes; No; Do Not Know	Hide if 5.14 only = "Liquid Chiller (Chilled water / Chilled Glycol)"
5.41	Do you use liquid subcooling?	Radio Button		Yes; No; Do Not Know	
5.42	Do you use a desuperheater?	Radio Button		Yes; No; Do Not Know	
5.43	Do you use an autopurger?	Radio Button		Yes; No; Do Not Know	
5.44	Do you use electronic expansion valves on any evaporators?	Radio Button	Are the loads that dictate the supplied air pressure relatively small compared to the total load on the system (<10% CFM)?	All; Most; Some; None; N/A; Do Not Know	
5.45	Does the load on the system vary significantly over time?	Radio Button		Yes; No; Do Not Know	
5.46	Have any controls been adjusted in the last year?	Radio Button		Yes; No; Do Not Know	
5.47	Do suction setpoint(s) get adjusted based on production schedules?	Radio Button		Yes; No; Do Not Know	
5.48	Do any refrigeration setpoints get adjusted seasonally?	Radio Button		Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.49	Have the cooling loads of each shift been recently estimated?	Radio Button		Yes; No; Do Not Know	
5.50	Has the feasibility of raising the suction temperature of the system been recently explored?	Radio Button		Yes; No; Do Not Know	
5.51	Has the feasibility of lowering the discharge temperature of the system been recently explored?	Fixed Dropdown		No; Seasonally; Shift-Wise; Permanently	
5.52	Are the compressor manufacturer's requirements for maintenance met or exceeded?	Fixed Dropdown		Increase Condenser Capacity Float Head Pressure Other	
5.53	Do you have a preventive maintenance program?	Radio Button		Yes; No; N/A; Do Not Know	
5.54	How often are heat exchangers (condensers/evaporators) inspected?	Fixed Dropdown		Weekly; Monthly; Yearly; >One Year; N/A; Do Not Know	
5.55	How often is the system recharged?	Fixed Dropdown		Weekly; Monthly; Yearly; Every 2 Years; Every 5 Years; Do Not Know	
5.56	In the past 5 years, has there been an energy efficiency assessment performed on the system?	Radio Button		Yes; No; Do Not Know	
5.78	What percentage of the recommendations were implemented? (estimate, in terms of energy savings potential)	Percent			
5.79	Assessor estimate of energy efficiency of the system compared to Best Available Technology and Best Maintenance Practices:	Fixed Dropdown	Assessors on the spot assessment of the efficiency if the system	Very Poor; Poor; Fair; Good; Excellent	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
5.80	Feasible energy savings potential?	Fixed Dropdown	Assessors on the spot assessment of the energy savings potential of the system	0-10%; 10-20%; 20-30%; 30-40%; More than 40%; Cannot reasonably estimate	

Facility general motor practices questions

Table 74: Facility general motor practices questions

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.01	Are motor system related decisions made at the facility or outside of the facility?	Dropdown	Primary decision hierarchy for motor system decisions	At facility; By corporate; Mix	
6.02	Title of the person responsible for managing motor system energy	Dropdown	Self-explanatory	Plant/facility Manager; Maintenance Manager; Purchasing Manager; Plant Engineer; Energy Manager; Chief Electrician; President or General Manager	
6.03	Is this person located at the facility?	Radio Button	Self-explanatory	Yes; No; Do Not Know	
6.04	Is this person also in charge of motor and related equipment purchases?	Radio Button	Self-explanatory	Yes; No; Do Not Know	
6.05	Percent of this person's time dedicated to energy related issues	Dropdown	Self-explanatory	1-25%; 26-50%; 51-75%; 76-99%; 100%	
6.06	Does this facility have an energy savings goal?	Radio Button	Are there any goals or targets of reducing the energy usage or intensity at the facility level?	Yes; No; Do Not Know	
6.07	Is energy efficiency a consideration in the design of new capital projects?	Radio Button	When designing or changing an energy system, is energy efficiency or the energy implications of the system a consideration?	Yes; No; Do Not Know	
6.08	Is energy efficiency considered in procurement of motor and related system components?	Radio Button	When purchasing new equipment, is the energy efficiency or energy implication of the purchase a consideration?	Yes; No; Do Not Know	
6.09	Are metrics in use to track energy performance of the facility motor systems?	Radio Button	Does the facility track its per unit production energy use or other metric to track the energy intensity?	Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.10	Minimum simple payback required for energy efficiency projects	Fixed Dropdown	Self-explanatory	< 1 year; 1 year; 2 years; 3 years; > 3 years	
6.11	Does the facility use external energy assessors to identify energy efficiency improvements?	Radio Button	Does the facility utilize outside consulting to help manage energy and identify energy efficiency improvement opportunities?	Yes; No; Do Not Know	
6.12	Does the facility use Kaizen events to identify energy efficiency improvements?	Radio Button	Self-explanatory	Yes; No; Do Not Know	
6.13	Does the facility use equipment manufacturer resources to identify energy efficiency improvements?	Radio Button	For example: a compressed air audit by a compressed air manufacturer or vender.	Yes; No; Do Not Know	
6.14	Does the facility use utility resources to identify energy efficiency improvements?	Radio Button	For example: an energy audit performed or funded by the energy utility.	Yes; No; Do Not Know	
6.15	Does the facility use state government resources to identify energy efficiency improvements?	Radio Button	For example: an energy audit performed or funded by the State government.	Yes; No; Do Not Know	
6.16	Does the facility use federal government resources to identify energy efficiency improvements?	Radio Button	For example: an energy audit performed or funded by the Advance Manufacturing Office of the DOE.	Yes; No; Do Not Know	
6.17	Does the facility use peer to peer knowledge sharing to identify energy efficiency improvements?	Radio Button	For example: gaining knowledge through industry groups and trainings.	Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.18	Does the facility use an energy efficiency service provider to identify energy efficiency improvements?	Radio Button	Does the facility use contracted efficiency service providers to perform periodic energy related maintenance or retrocommissioning?	Yes; No; Do Not Know	
6.19	Are motor system operators trained on motor system energy efficiency practices?	Radio Button	Do any of the system operators receive training specific to the energy efficiency of the systems that they manage?	Yes; No; Do Not Know	
6.20	Is the facility certified or participating in any of the following (select all that apply)?	Checkbox	Is the facility currently certified to any of the following standards?	ISO 50001 certified; ISO 9001 certified; ISO 14001 certified; Better Plants Partner; Superior Energy Performance certified; ENERGY STAR Partner; LEED certified;	
6.21	Estimated percent of motors that failed over the past year	Fixed Dropdown	Estimated percentage of total motors that failed in the last year, by count.	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.22	Estimated total hours of unplanned downtime due to all motor system failures over the past year	Percentage	Self-explanatory		
6.23	Does your company use written specifications when purchasing motors?	Radio Button	This indicates if the facility has specific, written specs that guide the purchasing of motors. See 3.24 for all the options.	Yes; No; Sometimes	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.24	Which of the following concerns are addressed in those specifications? (check all that apply)	Checkbox	Which of the provided specifications does the facility use to guide the purchase of new motors?	Temperature rise/insulation class; Maximum starting current; Minimum stall time; Power factor range; Efficiency and test standard; Load inertia; Expected number of starts; Suitability to your facility's operating environment; Ease of repair (including availability and access to repair specs); Other	Field is hidden if field number 3.23 = "No"
6.25	Is there a policy guiding motor repair or replacement?	Radio Button	Self-explanatory. See 6.26.	Yes; No; Do Not Know	
6.26	Reasons guiding repair/replace policy	Fixed Dropdown	Primary driver of the facility's decision to repair or replace a burnt-out motor.	Lowest first cost; Lowest lifetime running costs (i.e., electricity, maintenance costs); Quickest option	Field is hidden if field number 3.25 ≠ "Yes"
6.27	Does facility use an EASA accredited or Green Motor Practices Group Member motor service center?	Fixed Dropdown	Self-Explanatory	Always; Mostly; Sometimes; Never; Do Not Know	
6.28	How is the size of the new motor determined?	Editable Dropdown	What is the typical guiding principal when deciding on the size of a replacement motor?	Replace with previous size; Nearest motor size from spares inventory; Select per end use specification; Estimate of required load	
6.29	Does the facility have a list of:	Checkbox	Self-explanatory	All motors (connected or otherwise); All connected motors; Pumps; Air compressors; Fans	
6.30	Does the facility have a spare motor inventory?	Radio Button	Indicates if the facility maintains a list of the current spare motors available on site.	Yes; No; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.31	In past 2 yrs., percent of motors repaired or maintained for motor rewind	Fixed Dropdown	Percent by count of connected motors that were rewound in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.32	In past 2 yrs., percent of motors repaired or maintained for motor bearing replacement	Fixed Dropdown	Percent by count of connected motors that were maintained for motor bearing replacement in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.33	In past 2 yrs., percent of motors repaired or maintained for motor shaft alignment	Fixed Dropdown	Percent by count of connected motors that were maintained for motor shaft alignment in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.34	In past 2 yrs., percent of motors repaired or maintained for motor belt maintenance	Fixed Dropdown	Percent by count of connected motors that were maintained for motor belt maintenance in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.35	In past 2 yrs., percent of motors repaired or maintained for other motor repair	Fixed Dropdown	Percent by count of connected motors that had any other motor maintenance performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.36	In past 2 yrs., percent of pumps repaired or maintained for pump bearing lube and replacement	Fixed Dropdown	Percent by count of connected pumps that had pump bearings lubed and/or replaced performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.37	In past 2 yrs., percent of pumps repaired or maintained for pump mechanical seal replacement	Fixed Dropdown	Percent by count of connected pumps that had a pump mechanical seal replacement performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.38	In past 2 yrs., percent of pumps repaired or maintained for pump packing tightening or replacement	Fixed Dropdown	Percent by count of connected pumps that had a pump packing tightened or replaced in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.39	In past 2 yrs., percent of pumps repaired or maintained for pump wear ring adjustment or replacement	Fixed Dropdown	Percent by count of connected pumps that had a pump wear ring adjusted or replaced in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.40	In past 2 yrs., percent of pumps repaired or maintained for pump impeller replacement	Fixed Dropdown	Percent by count of connected pumps that had pump impeller replacement performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.41	In past 2 yrs., percent of pumps repaired or maintained for other pump repair	Fixed Dropdown	Percent by count of connected pumps that had any other pump repair performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.42	In past 2 yrs., percent of air compressors repaired or maintained for lube and filter replacement	Fixed Dropdown	Percent by count of connected air compressors that had a lube and filter replacement performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.43	In past 2 yrs., percent of air compressors repaired or maintained for compressed air trap inspection	Fixed Dropdown	Percent by count of connected air compressors that had a compressed air trap inspection performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.44	In past 2 yrs., percent of air compressors repaired or maintained for air filter replacement	Fixed Dropdown	Percent by count of connected air compressors that had an air filter replaced in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.45	In past 2 yrs., percent of fans repaired or maintained for fan bearing lubrication and replacement	Fixed Dropdown	Percent by count of connected fans that had a fan bearings lubricated and/or replaced in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	
6.46	In past 2 yrs., percent of fans repaired or maintained for fan cleaning	Fixed Dropdown	Percent by count of connected fans that had a fan cleaning performed in the last 2 years	0%; 1-10%; 11-20%; 21-30%; 31-40%; 41-50%; 51-60%; 61-70%; 71-80%; 81-90%; 91-99%; 100%; N/A; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.47	How often is there a systematic visual inspection of the general condition of motors?	Fixed Dropdown	Self-explanatory	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	
6.48	How often is there a systematic inspection of motor vibration noise?	Fixed Dropdown	Self-explanatory	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	
6.49	How often is there a systematic inspection of motor temperature?	Fixed Dropdown	Self-explanatory	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	
6.50	How often is there a systematic inspection of pump system valves including throttles?	Fixed Dropdown	Self-explanatory	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	
6.51	How often is there a systematic inspection of fan damper functionality?	Fixed Dropdown	Self-explanatory	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.52	Are dead ends in the compressed air distribution system isolated?	Fixed Dropdown	Self-explanatory	Yes, all have been isolated (100%); generally (50%-99%); some, but not the majority (1%-49%); no (0%)	
6.53	For the pump system distribution system, are flow paths to non-operating equipment isolated?	Fixed Dropdown	Self-explanatory	Yes, all have been isolated (100%); generally (50%-99%); some, but not the majority (1%-49%); no (0%)	
6.54	Are booster pumps used for loads with requirements well above balance of plant requirements?	Radio Button	Indicates if the facility uses any mechanical pumping to raise a pumped systems pressure above what is provided to the facility	Yes; No; Do Not Know	
6.55	What fraction of the facility's water load is boosted?	Fixed Dropdown	Indicates what fraction of the facility's pumped systems are mechanically boosted.	All instances; 51%-99% instances; 1%-50% of the instances; Do Not Know; None	
6.56	How are leaks in pumping systems identified?	Fixed Dropdown	Self-explanatory	Periodic Inspection Program; Employees/Operators identify; Multiple Methods; None; N/A; Do Not Know	
6.57	How are leaks in the compressed air systems identified?	Fixed Dropdown	Self-explanatory	Periodic Inspection Program; Employees/Operators identify; Multiple Methods; None; N/A; Do Not Know	
6.58	How are leaks in the ductwork identified?	Fixed Dropdown	Self-explanatory	Periodic Inspection Program; Employees/Operators identify; Multiple Methods; None; N/A; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.59	How often are pump system distributions inspected for efficiency of layout?	Fixed Dropdown	Indicates how often pump systems are typically reviewed for the energy efficiency of their design and layout	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	
6.60	How often is the compressed air system distribution inspected for efficiency of layout?	Fixed Dropdown	Indicates how often compressed air distribution systems are typically reviewed for the energy efficiency of their design and layout	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	
6.61	How often is the air duct distribution inspected for efficiency of layout?	Fixed Dropdown	Indicates how often blower driven duct distribution systems are typically reviewed for the energy efficiency of their design and layout	Weekly; Bi-Weekly; Monthly; Quarterly; Every 6 months; Annually; Every 2 years; More than every 2 years; Never; N/A; Do Not Know	

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.62	Rate the condition of the pump system distribution	Fixed Dropdown	Indicates the assessor's rating of the typical pumped system's condition	Best practice; Good; Fair; Poor; N/A	Best practice - no leakage observed; where installed, insulation in excellent condition Good - minimal leakage observed; where installed, insulation has been maintained; current maintenance practices appear to be sufficient Fair - leakage observed but not throughout the plant; where installed, insulation often found in need of repair; current maintenance practices could be improved Poor - many instances of leakage observed; where installed, insulation in need of repair; no evidence of existing maintenance practices
6.63	Rate the condition of the compressed air distribution system	Fixed Dropdown	Indicates the assessor's rating of the typical compressed air distribution system's condition	Best practice; Good; Fair; Poor; N/A	Best Practice - no leaks observed; air is free from moisture Good - minimal leaks observed; air is mostly dry Fair - leaks observed but not throughout the plant; moisture is found in the air, but evidence that air has been dried Poor - many instances of leaks observed; no evidence that air has been dried was observed; where installed, insulation in need of repair; no evidence of existing maintenance practices

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.64	Rate the condition of the air ducts	Fixed Dropdown	Indicates the assessor's rating of the typical ducted system's condition	Best practice; Good; Fair; Poor; N/A	<p>Best practice - no leakage observed; where installed, insulation in excellent condition</p> <p>Good - minimal leakage observed; where installed, insulation has been maintained; current maintenance practices appear to be sufficient</p> <p>Fair - leakage observed but not throughout the plant; where installed, insulation often found in need of repair; current maintenance practices could be improved</p> <p>Poor - many instances of leakage observed; where installed, insulation in need of repair; no evidence of existing maintenance practices</p>

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.65	Rate the design of the pump system distribution	Fixed Dropdown	Indicates the assessor's rating of the typical pumped system distribution system's design	Best practice; Good; Fair; Poor; N/A	Best practice - minimal elbows or sufficient distance between elbow and pump inlets and outlets; minimal dead ends; pipe sizing appropriate for flow conditions; where required, insulation exists Good - some elbows but flow into and out of pump generally unaffected; some dead ends; pipe sizing generally appropriate; where required, insulation mostly exists Fair - elbows throughout and flow into and out of pump is affected; dead ends throughout; varying pipe sizing found throughout the plant; where required, insulation may be observed Poor - excessive elbows with many impacting pump inlet and outlet; excessive dead ends; multiple pipe sizes along the same flow path; where required, insulation does not exist

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.66	Rate the design of the compressed air distribution system	Fixed Dropdown	Indicates the assessor's rating of the typical compressed air distribution system's design	Best practice; Good; Fair; Poor; N/A	Best practice - minimal elbows; minimal dead ends; receiver tanks used where beneficial; dryers used throughout Good - some elbows; some dead ends; receiver tanks used, but could be used more frequently; dryers installed but capacity could be increased Fair - elbows throughout; dead ends throughout; receiver tanks used but sporadically; dryers used sporadically Poor - excessive elbows; excessive dead ends; receiver tanks generally not used or inadequate; dryers generally not used or inadequate

Field #	Field Label	Field Type	Field Description	Field Options	Other Notes
6.67	Rate the design of the air ducts	Fixed Dropdown	Indicates the assessor's rating of the typical ducted system's design	Best practice; Good; Fair; Poor; N/A	<p>Best practice - minimal elbows or sufficient distance between elbow and fan inlets and outlets; minimal dead ends; duct sizing appropriate for flow conditions; where required, insulation exists</p> <p>Good - some elbows but flow into and out of fan generally unaffected; some dead ends; duct sizing generally appropriate; where required, insulation mostly exists</p> <p>Fair - elbows throughout and flow into and out of fan is affected; dead ends throughout; varying duct sizing found throughout the plant; where required, insulation may be observed</p> <p>Poor - excessive elbows with many impacting fan inlet and outlet; excessive dead ends; multiple duct sizes along the same flow path; where required, insulation does not exist</p>