

Lawrence Berkeley National Laboratory

LBL Publications

Title

Simulation driven design approach and prototype development for low-cost high-efficiency room air conditioners using next generation refrigerants

Permalink

<https://escholarship.org/uc/item/4m6823hn>

Journal

Science and Technology for the Built Environment, ahead-of-print(ahead-of-print)

ISSN

2374-4731

Authors

Ding, Chao
Shah, Nihar
Park, Won Young
[et al.](#)

Publication Date

2026-06-15


DOI

10.1080/23744731.2026.2688048

Copyright Information

This work is made available under the terms of a Creative Commons Attribution-NoDerivatives License, available at <https://creativecommons.org/licenses/by-nd/4.0/>

Peer reviewed



Simulation driven design approach and prototype development for low-cost high-efficiency room air conditioners using next generation refrigerants

Chao Ding, Nihar Shah, Won Young Park, Thomas Burke & Nihan Karali

To cite this article: Chao Ding, Nihar Shah, Won Young Park, Thomas Burke & Nihan Karali (02 Jul 2026): Simulation driven design approach and prototype development for low-cost high-efficiency room air conditioners using next generation refrigerants, Science and Technology for the Built Environment, DOI: [10.1080/23744731.2026.2688048](https://doi.org/10.1080/23744731.2026.2688048)

To link to this article: <https://doi.org/10.1080/23744731.2026.2688048>



Copyright © 2026 The Author(s). Published with license by Taylor & Francis Group, LLC



Published online: 02 Jul 2026.



Submit your article to this journal [↗](#)



Article views: 413



View related articles [↗](#)



View Crossmark data [↗](#)

Simulation driven design approach and prototype development for low-cost high-efficiency room air conditioners using next generation refrigerants

CHAO DING* , NIHAR SHAH*, WON YOUNG PARK , THOMAS BURKE and NIHAN KARALI

Lawrence Berkeley National Laboratory, 1 Cyclotron Rd., Berkeley, CA 94720, USA

The global refrigerant transition requires the redesign of heating, ventilation and air-conditioning (HVAC) systems. Higher efficiency systems also reduce peak loads and allow better integration of secure, affordable, reliable base-load generation technologies. However, many small and medium-sized air conditioner (AC) manufacturers, particularly in developing and emerging economies, lack the technical capacity to design affordable, energy-efficient systems using next generation refrigerants. This study presents a simulation-driven design approach for developing cost-effective, high-efficiency mini-split AC prototypes using R32, R454B, and R290. Physics-based system models were developed in VapCyc[®] and CoilDesigner[®] to conduct component-level simulations and system optimization. Cost analysis was performed to minimize material costs, and optimal designs were validated under ISO 5151 conditions in a psychrometric chamber. All prototypes achieved 33% higher EER and nearly doubled cooling seasonal efficiency compared to reference units, with only a 2–16% increase in material cost. These results indicate an approximately twofold reduction in peak load and emissions at comparable cost. The proposed simulation-driven methodology shortens the product development cycle and enables reliable, high-performance, next generation AC designs, offering a practical pathway for manufacturers in emerging markets to accelerate the transition to sustainable cooling technologies, meeting grid reliability constraints, environmental regulations and market demands for affordability.

1. Introduction

The global demand for space cooling is experiencing rapid growth, driven by electrification, increasing incomes, and higher temperatures in China, India & ASEAN countries (IEA 2018). As global temperatures rise, air conditioning is transitioning from a luxury to a necessity for health, comfort, and productivity (International Labour Organization 2019; Obringer et al. 2022; Smallcombe et al. 2022).

However, this surge in cooling demand presents a challenge for grid reliability and energy security. Further, the environmental impact of conventional air conditioning is twofold, comprising both direct and indirect emissions. Direct emissions occur through the leakage and improper disposal of synthetic refrigerants, which are potent greenhouse gases with Global Warming Potentials (GWPs) thousands of times greater than that of carbon dioxide (CO₂) (O'Neill et al. 2020; Homma et al. 2025). Indirect emissions, which constitute the larger portion of the environmental footprint, result from the substantial electricity consumption of cooling equipment, a significant fraction of which is generated by burning fossil fuels.

The International Energy Agency (IEA) has highlighted that the number of air conditioning units in buildings worldwide is set to increase from ~1.6 billion today to ~5.6 billion by 2050, an expansion that would require new electricity capacity equivalent to the combined capacity of the United States, European Union, and Japan (IEA 2018; Falchetta et al. 2024). This trajectory poses a critical threat to grid and energy security objectives, underscoring the urgency for a paradigm shift toward sustainable cooling technologies. The development of next-generation room air

Received October 17, 2025; accepted June 2, 2026

Chao Ding, PhD, Associate Member ASHRAE, is a Technology Researcher. **Nihar Shah, PhD, PE**, Full Member ASHRAE, is a Policy Researcher. **Won Young Park, MS**, is a Policy Researcher. **Thomas Burke, MS**, is a Policy Researcher. **Nihan Karali, PhD**, is a Policy Researcher.

*Corresponding authors e-mail: nkshah@lbl.gov, chaoding@lbl.gov

This is an Open Access article distributed under the terms of the Creative Commons Attribution License (<http://creativecommons.org/licenses/by/4.0/>), which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited. The terms on which this article has been published allow the posting of the Accepted Manuscript in a repository by the author(s) or with their consent.

conditioners (RACs) that are both highly efficient and utilize next generation working fluids is therefore not merely incremental but a critical imperative (Andersen et al. 2020; Purohit et al. 2020).

The international policy landscape, shaped by the landmark Montreal Protocol on Substances that Deplete the Ozone Layer, has been remarkably successful in orchestrating the global phaseout of ozone-depleting substances (ODS) like chlorofluorocarbons (CFCs) and hydrochlorofluorocarbons (HCFCs). They are scheduled to be completely phased out (with the exception of process agents and feedstocks) by 2030 in non-A5 Parties and A5 parties¹ (with a small service tail of only 2.5% allowed for the 2030–2040 period) (United Nations Environment Programme (UNEP) 2010). However, their primary replacements, hydrofluorocarbons (HFCs), while being benign to the ozone layer, were later identified as potent GHGs. HFCs such as R410A, is a zeotropic, albeit a near-azeotropic mixture of difluoromethane (CH₂F₂, known as R32) and pentafluoroethane (CHF₂CF₃, known as R125). It does not contain bromine or chlorine, which are known to contribute to ozone depletion. However, R410A has a high global warming potential (GWP) similar to that of R22. The GWP and ozone depletion potential (ODP) values of R22 and R410A are listed in Table 1. R410A has a 100-year GWP of 2100, meaning one kilogram released has the same climate impact as over two thousand times of CO₂. With atmospheric concentrations of HFCs growing at 10–15% per year, they became the fastest-growing category of GHGs (Velders et al. 2012, 2014). Air conditioners (ACs) dominate the HFC market with a 56% share of GWP-weighted tons of carbon dioxide (CO₂) equivalent (UNEP Ozone Secretariat 2015).

Recognizing this impending threat, the global community adopted the Kigali Amendment to the Montreal Protocol in 2016. This agreement established a legally binding global framework for the phasedown of HFC production and consumption by more than 80% over the next 30 years. The amendment sets differentiated timelines for developed (non-Article 5) and developing (Article 5) countries, a move projected to avoid up to 0.4 °C of global warming by the end of the century. Research has shown that coupling the HFC phasedown with simultaneous improvements in the energy efficiency of AC units could more than double the climate benefits of the Kigali Amendment alone. Achieving the efficiency levels of the best-available technologies could prevent up to 100 billion tons of CO₂-equivalent emissions by 2050 and avoid significant peaker power plant and grid impacts (Shah et al. 2017).

This understanding catalyzed extensive research into sustainable cooling technologies. Numerous studies have investigated the performance of next generation low-GWP refrigerant alternatives. Mildly flammable (A2L) refrigerants like R32 have been widely studied as a replacement for R410A, offering a lower GWP and favorable thermodynamic

Table 1. R22 And R410A GWP and ODP values.

Type	Refrigerant	GWP 100 years ^a		ODP
		IPCC5 ^b	RTOC ^c	
HCFC	R22	1760	1780	0.034
HFC	R410A	1900	2100	None

Notes.

^aGWP over a 100-year period.

^bIPCC5: Intergovernmental Panel on Climate Change (IPCC) Fifth Assessment Report.

^cRTOC: Refrigeration, Air Conditioning and Heat Pumps Technical Options Committee.

properties, though requiring careful system optimization (Alabdulkarem et al. 2015; Panato et al. 2022; Lee et al. 2024). Hydrocarbon (HC) refrigerants like R290 (propane) offer a near-zero GWP and excellent efficiency but face stricter safety standards due to their high flammability (A3), limiting charge sizes in residential systems (Park et al. 2019; Colbourne and Suen 2021; Li et al. 2023; Wei et al. 2024; Zou et al. 2025). Newer hydrofluoro-olefin (HFO) blends, such as R454B, have also emerged, providing a balance of low GWP, non-flammability, and performance comparable to legacy refrigerants (Shen et al. 2022; Suerdem et al. 2023; Wu et al. 2024). The consensus is that there is no “one-size-fits-all” solution; optimal refrigerant choice depends on the application, safety constraints, and system design (Calm 2008).

Parallel to refrigerant research, advancements in component design and system modeling have become central to achieving higher efficiency. Simulation-driven design has been shown to dramatically shorten the product development cycle and reduce costs compared to traditional build-and-test methodologies (Zhao et al. 2023; Hwang and Park 2024). Physics-based simulation tools are essential for this process. For instance, detailed heat exchanger models, often employing a segment-by-segment approach, are critical for optimizing geometry, circuitry, and airflow to enhance heat transfer and minimize refrigerant charge (Jiang 2003; Jiang et al. 2006). Similarly, accurate compressor models, frequently based on the 10-coefficient AHRI standard polynomials, are fundamental for predicting system performance across various operating conditions (AHRI Standard 540 540, 2015; Aute et al. 2015). System-level simulation platforms, such as the equation-based language Modelica (Fritzson and Engelson 1998; Tiller 2001; Wetter et al. 2014), and component-based tools like VapCyc (Richardson et al. 2002; Winkler et al. 2006), allow for the virtual integration and optimization of these components. These tools are often coupled with optimization algorithms, such as genetic algorithms, to explore various design space and identify configurations that maximize performance metrics like the Energy Efficiency Ratio (EER) or Cooling Seasonal Performance Factor (CSPF) (Bau et al. 2015; Li et al. 2018).

Despite these significant technological advancements in both refrigerants and design tools, a critical barrier persists: many small and medium-sized manufacturers (SMEs),

¹A5 and non-A5 parties are defined here: <https://ozone.unep.org/classification-parties>.

particularly in the rapidly growing markets of developing and emerging economies, lack the specialized technical capacity, R&D budgets, and testing facilities to effectively integrate these innovations into cost-effective products (UNEP 2019). While high-efficiency ACs (UNEP 2019) with next generation refrigerants, such as R32, R454B and R290, are commercially available at prices comparable to similar ACs using high-GWP refrigerants, high efficiency is often associated with premium products selling at substantially higher prices than less efficient low-end products (Park et al. 2017). Consequently, high-efficiency, low-GWP systems are often positioned as premium products, priced out of reach for the majority of consumers who then default to cheaper, less efficient models that lock in high energy consumption peak load and environmental impacts for years. This creates a significant gap between what is technically possible in a research lab and what is commercially accessible in the mass market, thereby slowing the global transition to sustainable cooling. Price-sensitive consumers, particularly those from emerging economies in the tropics and subtropics, wherein an approximately 70% of the projected growth in cooling demand is expected to occur, prefer to buy low first cost product which is often the least efficient and contains ozone depleting or obsolete refrigerant products. In general, SMEs worldwide lack the technical capabilities to design affordable, energy-efficient ACs in tandem with refrigerant transitions under the Montreal Protocol.

This study addresses this critical gap by developing, demonstrating, and validating a practical, simulation-driven design methodology tailored to the needs of these manufacturers. It moves beyond pure theory by presenting a holistic workflow that integrates performance simulation with detailed cost analysis to ensure commercial viability. Using the commercially available simulation tools VapCyc[®] and CoilDesigner[®], we present a systematic approach to optimize component design and system configuration for three distinct next generation low-GWP refrigerants: R32, R454B, and R290. The optimized virtual designs are then translated into physical prototypes, and their performance is experimentally validated in a psychrometric chamber under the ISO 5151 test standard. The outcome is a tangible, repeatable pathway for SMEs to leapfrog traditional development cycles, mitigate R&D risk, and accelerate the adoption of next-generation, energy secure cooling technologies.

2. Methodology

2.1. Energy performance modeling approach

To better understand the energy performance of AC equipment and identify optimal system designs, this research developed a physics-based, component-level modeling approach using a suite of validated, industry-standard simulation tools, VapCyc[®] and CoilDesigner[®] (Richardson et al. 2002; Jiang et al. 2006; Winkler et al. 2006). The core of the methodology involved developing calibrated energy performance models to characterize the vapor compression




Fig. 1. Air conditioner system diagram in VapCyc.

cycle, conduct extensive sensitivity analyses of key design parameters to identify opportunities for energy performance improvement, and determine optimal configurations prior to any physical prototype construction.

The system-level vapor compression cycle simulation and optimization were modeled using VapCyc[®], a flexible, component-based simulation tool that uses a successive substitution solver to converge on the system's steady-state operating point by balancing mass and energy across components. It is among the most popular AC/heat pump (HP) modeling software in the industry. The tool can be populated with product data to characterize the system performance. Figure 1 shows a typical vapor compression cycle with four key components: compressor, evaporator, expansion device, and condenser. For the most critical components, detailed physics-based models were developed and integrated.

2.1.1. Compressor model

Compressors are the most important components of refrigeration systems. They function as the heart of the system by compressing the refrigerant from the low-pressure part to the high-pressure part. The VapCyc provides several compressor models. In this study, compressor performance maps were collected in the form of 10-coefficient polynomial equations defined by AHRI Standards 540 (2015). Manufacturer-provided coefficient sets for both power consumption and refrigerant mass flow rate at different compressor frequencies, valid for each specific refrigerant and compressor model, were used as inputs. These polynomials correlate compressor performance as a function of suction and discharge dew point temperatures as follows in Equation 1.

$$X = C_1 + C_2 t_s + C_3 t_D + C_4 t_s^2 + C_5 t_s t_D + C_6 t_D^2 + C_7 t_s^3 + C_8 t_s^2 t_D + C_9 t_s t_D^2 + C_{10} t_D^3 \quad (1)$$




Fig. 2. A Screenshot of CoilDesigner's Main GUI.

where

$C_1 - C_{10}$ = regression coefficients provided by the manufacturer

t_s = suction dew point temperature [$^{\circ}\text{C}$, $^{\circ}\text{F}$],

t_D = discharge dew point temperature, [$^{\circ}\text{C}$, $^{\circ}\text{F}$]

X = individual published rating, such as capacity [W, Btu/h], input power [W], and refrigerant mass flow rate [kg/s, lbm/h].

The employment of this model assumes that the AHRI 10-coefficient polynomials, derived from standard calorimeter testing, accurately interpolate performance across the evaluated design space and that the effects of compressor oil circulation on refrigerant thermophysical properties are negligible.

2.1.2. Heat exchanger model

The evaporator and condenser were modeled using CoilDesigner[®]. This tool employs a segment-by-segment modeling approach. The refrigerant path is discretized into a series of small, interconnected control volumes. For each segment, the governing equations for mass, momentum, and energy conservation are solved. Appropriate and validated heat transfer and pressure drop correlations are applied for different flow regimes (e.g., single-phase liquid, two-phase boiling/condensation, single-phase vapor). This detailed approach allows for the accurate prediction of energy performance based on specific geometric parameters. Key geometries, including inner and outer tube diameters, tube lengths, fin density (FPI), fin type, and complex refrigerant circuitry paths, were measured from reference product and implemented in the software to ensure the highest possible fidelity for the simulations. After defining the basic heat exchanger configuration, the circuit design, tube connection,

and airflow properties were set up using the main graphic user interface (GUI) window (Figure 2). The resulting validated heat exchanger models were then imported and used as component within the VapCyc[®] system model for system design and optimization.

It is noted that the CoilDesigner[®] segment-by-segment model relies on several key assumptions: it assumes steady-state, one-dimensional homogeneous flow within the tubes, uniform airflow distribution across the coil face (prior to calibration corrections), and negligible longitudinal heat conduction along the tube walls.

Other components. Fan performance was modeled based on manufacturer data and measurements, correlating airflow rate with power consumption. Pressure drops in connecting lines were also included to account for their impact on the system. The expansion device was modeled as an isenthalpic process.

2.2. Reference system and model calibration

To validate the accuracy and predictive power of the simulation approach, reference models were developed and calibrated against experimental data. The reference systems were commercially available ductless mini-split² AC units. They use a fixed-speed compressor with a rated system energy efficiency ratio (EER) of 3.0 W/W, representing a typical energy efficiency level available in developing economies, based on UNEP (2019). Table 2 summarizes the

²This study focuses on ductless split ACs, because the global room AC market is dominated by this type of unit, known in the United States as mini-split ACs. In the United States, Canada, and Mexico, room ACs are typically understood to be window-type units.

Table 2. Reference mini-split AC models.

Model	Market	Compressor type	Rate EER (W/W)	Rate cooling capacity (kW)	Refrigerant
A	India	FSD	3.0	3.5	R22
B	China	FSD	3.0	3.5	R410A

Note: FSD: fixed speed drive; VSD: variable speed drive.

Table 3. Model B (R410A) calibration results under standard full capacity cooling condition.³

	Cooling capacity [W]	Power [W]	EER [W/W]
Test	3543	1208	2.93
Simulation	3506	1151	3.05
% difference	-1.0%	-4.7%	3.9%

high-level energy performance information of the selected reference units.

The physical unit was installed and tested under the standard T1 full-capacity cooling conditions as specified in the ISO 5151 standard in a psychrometric test chamber. Detailed performance data, including cooling capacity, power consumption, temperatures, and pressures, were recorded. The VapCyc[®] and CoilDesigner[®] simulation models were then developed at the identical boundary conditions. To ensure the high fidelity of the reference model, a systematic calibration process was performed to match the simulated results with the experimental baseline data. First, the heat exchanger models were developed based on the measured geometric details of the physical reference model, incorporating the actual tube dimensions, tube spacing, fin types, fin parameters, circuitry designs, and measured fan powers. Second, the compressor was modeled using the actual 10-coefficient compressor performance maps for mass flow rate and power consumption provided by the compressor manufacturer. Finally, the compressor curves were calibrated by adjusting the associated correction factors within the model to match the actual measured system cooling capacity and power consumption at the rated test condition. Table 3 presents the test and simulation results for the R410A model, which was the only unit tested, as the R22 unit is no longer commonly available in the market and obtaining reliable cost details for it is extremely challenging. The simulation results of Model B were consistent with the test data. The differences between the test and simulation results were within $\pm 5\%$. This successful single-point calibration confirmed the model's fidelity and established a reliable and trustworthy foundation for conducting the subsequent design optimization studies.

It is noted that, while multi-point calibration is beneficial for seasonal mapping, a single-point calibration at the standard T1 full-capacity condition is justified here as it serves as the critical anchor for heat exchanger sizing and MEPS compliance. Furthermore, because VapCyc[®] and CoilDesigner[®] are fundamental, physics-based solvers rather than simple empirical curve-fits, once the baseline physical parameters (e.g., thermal contact resistance, airflow maldistribution) are

anchored, the software's internal fluid property databases reliably predict the thermodynamic shifts associated with switching to alternative refrigerants like R32, R454B, and R290.

2.3. Multi-Objective design optimization

Following model calibration, a multi-objective design optimization was performed for three low-GWP refrigerant alternatives: R32 (GWP 675) and R454B (GWP 470) as near-term replacements for R410A, and R290 (GWP 3) as an ultra-low GWP replacement for R22. The primary objective was to maximize the system's EER under full-load conditions while simultaneously minimizing the increase in total material cost and the extent of modifications required from the reference design. The cost model used for this analysis was a bottom-up estimation developed through direct surveys and data collection with AC industry partners and component manufacturers. While heat exchanger pricing was heavily correlated with raw copper and aluminum weight, these assumptions and the final detailed cost numbers (presented in Section 3.1) were explicitly validated by our industry partners. This validation ensured that all actual manufacturing overhead, production volume economies, and fabrication costs for the selected materials and sizes were accurately embedded in the estimates.

A genetic algorithm (GA) was employed to systematically and efficiently search the large, multi-variable design space. GAs are well-suited for such engineering problems as they are robust in navigating complex, non-linear solution spaces to find near-globally optimal solutions. The GA was configured to explore a wide range of design parameters, treated as "genes" for the optimization. The key design variables included:

- Refrigerant Choice: R32, R454B, R290.
- Compressors: Higher efficiency variable-speed drive (VSD) compressors were selected for each refrigerant, replacing the reference fixed-speed drive (FSD) unit.
- Fans: High-efficiency, electronically commutated direct current (DC) fan motors were substituted for the reference alternating current (AC) motors to reduce auxiliary power consumption.
- Heat exchanger circuitry: The refrigerant flow path was reconfigured to ensure optimal fluid distribution and facilitate efficient phase change within the tubes.
- Tube diameter: The tube diameter was reduced from the traditional 7 mm to a smaller 5 mm to explore benefits from enhanced the rate of heat transfer.
- Overall heat exchanger geometry: Parameters including the number of tubes, tube length, and fin density (Fin

Table 4. Key component constraints for the system optimization formulation.

Component	Property	Model B	Lower bound	Upper bound
Indoor unit	Fan Air Flow Rate [m^3/h]	910	720	950
Outdoor unit	Tube length [m]	0.812	0.65	0.812
Outdoor unit	Fan Air Flow Rate [m^3/h]	1800	1440	2160

**Fig. 3.** Photographs of the R32 prototype AC unit.

Per Inch), were varied within manufacturing limits and optimized based on simulation results to maximize energy performance.

The optimization was run independently for each of the three refrigerants. To ensure the reproducibility of this methodology for industry practitioners, the optimization was not run via a custom-built script, but was instead driven by the built-in optimization module within the VapCyc[®] software suite. The GA was configured with a maximum number of 100 iterations, a population size of 50, and a population replacement value of 10. The GA generated and evaluated over 1,100 unique design combinations for each refrigerant, ensuring a rigorous search of the design space to identify the optimal Pareto front balancing material cost and system energy efficiency. The selection process for the final optimal design was a two-step process. First, the GA identified a set of Pareto-optimal solutions that represented the best possible tradeoffs between EER and cost. From this set, a final design was selected that offered the most substantial EER improvement for the lowest associated material cost increase, subject to practical manufacturing and component constraints as outlined in Table 4. The cost model used for this analysis was a bottom-up estimation based on manufacturer quotes for major components (compressor, motors, controls) and material-based pricing for heat exchangers (based on copper and aluminum weight).

2.4. Prototype development and experimental validation

Based on the final optimized designs identified through the simulation process, physical prototypes were fabricated in collaboration with component suppliers and AC equipment manufacturers. This step translated the virtual models into tangible hardware. The control logic for each prototype,

including the VSD compressor frequency, indoor and outdoor fan speeds, and electronic expansion valve (EEV) opening settings, was programmed and fine-tuned based on the optimal operating points identified in the simulations and subsequently verified during preliminary lab tests. Figure 3 shows the photos of one prototype AC system as an example. The detailed heat exchanger circuitry designs are included in Figures A1 and A2. The photographs of the key components are shown in Table A1.

The final, fully assembled prototype units were then sent to Lawrence Berkeley National Laboratory (LBNL) for comprehensive and independent energy performance test validation. All experimental tests were conducted in LBNL's HVAC&R testing facilities, specifically in the advanced psychrometric test chamber (Figure 4). This facility is used to evaluate the performance of central ACs and HPs with cooling capacities in the range of 1.76–26.37 kW (0.5–7.5 refrigeration tons), and with heating capacities in the range of 1.76–17.58 kW (0.5–5 refrigeration tons). It is comprised of side-by-side indoor and outdoor chambers with independently controlled temperature, humidity, and airflow. The indoor and outdoor room conditions, including the temperature and humidity, were controlled independently using proportional–integral–derivative (PID) controllers built into the data acquisition software. Each test room was equipped with an air enthalpy tunnel or a “code tester.” Code testers provided accurate control and measurements of the airflow volume and external static pressure of the test unit. In addition, the psychrometric test chamber included the necessary safety equipment for testing air conditioners utilizing A2L (R32) and A3 (R290) flammable refrigerants. Safety equipment included refrigerant detection sensors and control equipment to shut down the operation of the test chamber in the event of a flammable refrigerant leak.



Fig. 4. A Photograph of LBNL's psychrometric test chamber.

Four psychrometers were built and installed in the chamber according to ASHRAE 41.1 41.1 (2013) and ASHRAE 41.6 41.6 (2014). Psychrometers provide accurate measurements of air properties, which are essential for testing and rating HVAC equipment. Three units were installed to power the test units. Based on the specifications of the tested product, the input voltage to the test unit could be configured within 110–500 V, at 50 or 60 Hz. The configurable test unit power supply system facilitated testing of international equipment. A data acquisition system was built with measurements of the temperature, pressure, refrigerant flow, and fan speed.

System performance was rigorously evaluated in strict accordance with the international test standard ISO 5151:2017/Amd 1:2020: “Non-ducted air conditioners and heat pumps -Testing and rating for performance” (ISO 5151:2017/Amd 1:2020 1:2020, 2020). It also specifies the test methods for determining the capacity and efficiency ratings. The cooling capacity was determined using the primary indoor air enthalpy method, which measures the change in enthalpy of the air passing through the indoor unit. The outdoor air enthalpy method was used for the secondary-capacity heat balance. The power usage, including the current and voltage to the compressor, outdoor fan, and indoor fan, could be measured individually with Yokogawa power meters, which provided highly accurate and reliable capacity measurement results.

An uncertainty analysis was conducted to evaluate the reliability of the experimental measurements using the standard method of error propagation. The systematic uncertainties of the primary sensors were as follows: 0.1 °C for temperature sensors and 0.5% for the Yokogawa power meters. Propagating these instrument accuracies, the

Table 5. Summary of the key design parameters of the studied designs.

Key design parameters	Model B	optimal designs		
Refrigerant	R410A	R32	R454B	R290
Compressor rated COP ^a		4.55	4.5	4.74
Indoor Unit				
Tube diameter [mm]	7	5	5	5
Tube length [mm]	656	656	656	656
Number of tubes	14×2	17×2	17×2	17×2
Fan Power [W]	25	30	50	60
Fan Air Flow Rate [m ³ /h]	910	864	792	864
Outdoor Unit				
Tube diameter [mm]	7	5	5	5
Tube length [mm]	812	650	786	786
Number of tubes	24×2	26×2	26×2	26×2
Fan Power [W]	40	42	61	59
Fan Air Flow Rate [m ³ /h]	1800	2016	1872	1836
Cooling Capacity [W]	3506	3360	3425	3232
System Power [W]	1151	840	862	847
System EER [W/W]	3.0	4.0	3.97	3.82

^aThe rated compressor capacity and input are measured by the compressor manufacturer with inverter circuit based on the secondary refrigerant calorimeter methods defined by the standard JIS B8606. The compressors are used as is, without any modifications to the original designs.

maximum expanded uncertainty (at a 95% confidence level) for the calculated cooling capacity and the EER were determined to be 5%. These low uncertainty levels confirm the high reliability of the experimental data used to validate the simulation models.




Fig. 5. Energy efficiency performance for the optimized R32, R454B, and R290 mini-split units (full capacity cooling).

3. Results

3.1. Optimal designs

Table 5 lists certain key design parameters of the optimal designs and compares the corresponding values with those of the reference Model B.

Figure 5 illustrates the system energy performance of the optimized AC units. Compared with the reference Model B unit (R410A), the optimized R32 and R454B AC designs exhibited a 4.2% and 2.3% reduction in cooling capacity, respectively, accompanied by a substantial decrease in power consumption of 27.0% and 25.1%, respectively. This resulted in remarkable enhancements in the system's EER of 33.3% and 32.4%, respectively. Furthermore, compared to the reference Model A unit (R22), the optimized R290 AC design resulted in a 7.7% decrease in cooling capacity and a 27.4% reduction in power consumption. This translates into a significant 27.2% improvement in the system's EER. These findings demonstrate that the optimized R32, R454B, and R290 AC designs achieved a favorable balance between cooling capacity and power consumption, surpassing the energy efficiency of conventional units that use R410A and R22 refrigerants.

Table 6 illustrates the cost differentials among the optimal VSD models using R32, R454B, and R290 compared to the reference Model B (FSD design R410A refrigerant). The production of optimal prototype units required only marginal increases in cost. This observation underscores the cost-effectiveness of manufacturing these optimized units. Noted that FSD compressors generally entail lower costs compared to VSD compressors. The primary reason behind the higher

compressor cost for the R410A reference model stems from the scarcity of R410A FSD units in the China domestic market during our research phase because ~95% of new RACs transitioned to VSD units in 2021 (ChinaIOL 2022). Limited production volumes led to elevated component prices. Conversely, higher production volumes of other VSD components resulted in cost reductions due to economies of scale.

3.2. Experimental validation of optimized prototypes

The three optimized low-GWP prototypes (R32, R454B, and R290) were fabricated and experimentally tested under the ISO 5151 T1 standard cooling conditions. The test condition comprised indoor and outdoor temperatures of 27 °C (dry-bulb)/19 °C (wet-bulb), and 35 °C (dry-bulb)/24 °C (wet-bulb), respectively. The full and half cooling capacities of the systems were tested. A primary goal of this phase was to validate the predictive accuracy of the entire simulation-driven design workflow. The refrigerant charge was optimized first and maintained constant while the openness of the expansion valve was adjusted to align with the simulations for subcooling and superheating. The experimental results demonstrated an excellent agreement with the performance predictions from the final simulation models.

As detailed in the comparative summary in Table 7 for full-capacity standard cooling conditions as an example, the measured cooling capacity and Energy Efficiency Ratio (EER) for all three prototypes were well within a 5% discrepancy of the simulated values. This close correlation between the simulated design performance and the measured physical performance provides strong validation for the predictive accuracy and reliability of the modeling approach used in this study.

3.3. System performance and efficiency improvements

This study analyzes the seasonal cooling energy performance of the prototype units according to the ISO cooling seasonal performance factor (CSPF) calculation. The ISO CSPF calculation refers to ISO 16358-1:2019 Clause 6.4 for fixed-speed units and Clause 6.7 for variable-speed units. The CSPF calculation for variable-speed units is based on two sets of test data—measurement of performance (capacity and power input) at full- and half-capacity operation at an outdoor dry bulb temperature of 35 °C—and then performance at 29 °C is calculated by ISO 16358-determined equations. The CSPF calculation for fixed-speed units is based on one set of test data—measurement of performance (capacity and power input) at full-capacity operation at an outdoor dry bulb temperature of 35 °C—and then performance at 29 °C is calculated by the predetermined equations.⁴

The corresponding system results are listed in Table 8. The optimized low-GWP prototypes demonstrated

⁴Given that predetermined equations are used to estimate the performance at 29 °C, CSPF for fixed-speed units results in a linear relationship with EER, i.e., $CSPF = 1.062 \times EER$ with the ISO reference temperature bin hours (Park et al. 2019).

Table 6. Cost comparisons between optimal R32, R454B, and R290 prototypes and R410 reference model based on manufacturer survey.

Cost [US\$]	R410A reference	R32 prototype	R454B prototype	R290 prototype
Refrigerant	5.36	3.00	3.00 ^a	2.73
Heat Exchanger	25.79	21.96	23.28	23.28
Compressor	47.65 ^b	36.08	36.08	59.16
Capillary Tube/Expansion Valve	0.50	4.36	4.36	4.36
Fans + Motors	16.47	20.42	20.42	20.42
Control Board	9.53	36.76	36.76	36.76
Others	50.00	50.00	50.00	50.00
Total Material Cost	155.31	172.58	173.90	196.71

^aOwing to low production volumes, the price of R454B is currently more than 9x higher than that of R32. It was assumed that the price would be similar to that of R32 when produced on an economic scale.

^bDue to the low production volumes of R410A fix-speed units in the research market, the prices of fixed speed compressor components were higher.

Table 7. Comparisons of the optimal simulation results and full capacity cooling test results.

	Test	Simulation	Δ%	Test	Simulation	Δ%	Test	Simulation	Δ%
Refrigerant	R32			R454B			R290		
Rated Cooling Capacity (W)	3383	3360	−0.68	3417	3425	0.23	3236	3232	−0.12
Power Consumption (W)	829	840	1.33	849	862	1.53	818	847	3.55
EER	4.10	4.00	−2.44	4.02	3.97	−1.28	3.96	3.82	−3.54

Note: R32 and R290 test results were validated at LBNL's test chamber within 5% tolerance.

Table 8. Comparisons of energy efficiency improvements and cost increases.

	Model B R410 (FSD)	Initial plan (VSD)	Actual performance (VSD)	Improvement from reference
Refrigerant	R22		R32 (GWP 675)	
Full cooling capacity [W]	3500	3500	3456	−1.3%
EER ¹ [W/W]	3.0	≥3.0	4.1	33%
ISO CSPF ² [Wh/Wh]	3.2	≥4.2	6.1	90%
UEC ³ [kWh/y]	805	–	413	49%
Estimated material cost [USD]	170 (±10)	<190(±10)	< 173(±10)	2%
Refrigerant	R22		R454B (GWP 470)	
Full cooling capacity [W]	3500	3500	3417	−2.4%
EER [W/W]	3.0	≥3.0	4.0	33%
ISO CSPF [Wh/Wh]	3.2	≥4.2	5.7	78%
UEC [kWh/y]	805	–	443	45%
Estimated material cost [USD]	170 (±10)	<190(±10)	174(±10) ⁴	2%
Refrigerant	R22		R290 (GWP 3)	
Full cooling capacity [W]	3500	3500	3236	−7.6%
EER [W/W]	3.0	≥3.0	4.0	33%
ISO CSPF [Wh/Wh]	3.2	≥4.2	5.9	83%
UEC [kWh/y]	805	–	405	50%
Estimated material cost [USD]	170 (±10)	As low as possible	197(±10)	16%

Notes: FSD: fixed speed drive; VSD: variable speed drive.

¹Energy efficiency ratio per ISO 5151: 2010.

²Cooling seasonal performance factor per ISO 16358-1: 2019.

³Cooling seasonal energy consumption per ISO 16358-1: 2019.

⁴Due to low production volumes, the price of R454B is currently more than 9x higher than that of R32. It was assumed that the price would be similar to that of R32 when produced on an economic scale.




Fig. 6. Seasonal energy performances of three prototype AC units.

substantial and compelling improvements in both nominal and seasonal energy efficiency when compared to the reference R410A fixed-speed unit. At the T1 full-capacity cooling condition, the optimized designs yielded major reductions in power consumption while maintaining similar cooling capacities. Notably, through system optimization, the prototype units achieved a 33% improvement in the EER compared with the reference FSD model.

The improvements in seasonal performance, which better reflect real-world annual energy consumption, were even more pronounced. The adoption of higher efficiency VSD compressors and optimized components resulted in a dramatic increase in the CSPF, calculated according to the ISO 16358 standard. The R32, R454B, and R290 prototypes achieved remarkable CSPF values that were 90%, 78%, and 83% higher than the reference fixed-speed unit, respectively. This is a direct result of the superior part-load performance of the VSD systems.

As shown in Figure 6, the seasonal energy performance of the R32 prototype complies with the leading international requirements (i.e., with China's MEPS and achieves the highest 5-Star rating in India). The R454B and R290 prototypes also performed strongly, closely approaching these stringent requirements. Crucially, this high level of efficiency was achieved with only a marginal 2%–16% increase in first cost. These results confirm both the commercial viability and technical feasibility of replacing conventional refrigerants with low-GWP alternatives in 1-ton mini-split units for competitive global markets.

3.4. Economic analysis of optimized designs

A central objective of the study was to ensure that the designed efficiency gains were achieved without rendering the final product unaffordable in cost-sensitive markets. The economic analysis, based on a bottom-up material and component cost model, confirms that high performance was accomplished with only a modest increase in total manufacturing cost.

As detailed in the cost breakdowns in Table 6 and summarized in Table 8, the final estimated material costs for the optimized, high-efficiency VSD prototypes were only marginally higher than the reference FSD unit. The total material costs for the R32, R454B, and R290 prototypes were 2%, 2%, and 16% higher, respectively, than the estimated cost of

the reference unit. The analysis noted that while the VSD compressor and control board are more expensive than their FSD counterparts, these costs were partially offset by savings in the optimized heat exchangers (due to smaller tube diameters and reduced material weight) and the economies of scale for VSD components in major manufacturing markets (as detailed in Section 3.1). This result is highly significant, as it demonstrates that a near doubling of seasonal energy efficiency can be achieved for a very small increment in first cost, breaking the paradigm that high efficiency must come at a high price premium.

4. Discussion

4.1. Interpretation and significance of findings

Our survey of the global market reveals that high-efficiency air-conditioners (ACs) with low-GWP refrigerants are already commercially available. However, the cost of these ACs is often over three times as high as the market average. Price-sensitive consumers, particularly from developing and emerging economies in the tropics and subtropics where nearly 70% of the projected growth in cooling demand is expected to occur, typically prefer to buy less-efficient, high-GWP refrigerant ACs due to their lower cost. Addressing this gap requires advanced R&D methodologies. However, even for some top-tier global OEMs, simulation-driven design is not the main R&D approach for new products. When utilized by large OEMs, their specific workflows and economic tradeoff models remain highly proprietary. Consequently, small and medium-sized enterprises (SMEs) around the world often rely on iterative, trial-and-error physical prototyping, which frequently leads to economically non-viable products when attempting refrigerant transitions. They generally lack the technical capabilities to design affordable, energy-efficient, next-generation refrigerant ACs.

The results of this study demonstrate that a systematic, simulation-driven design approach can effectively bridge the technical and economic gaps for manufacturers transitioning to sustainable cooling technologies. The key takeaway is that the dual climate goals of phasing down obsolete refrigerants and improving energy efficiency are not mutually exclusive; rather, they can be pursued in synergy to achieve compounded benefits. Furthermore, this can be accomplished

without incurring prohibitive costs that would otherwise hinder market adoption. The methodology presented and validated here provides a practical and reliable pathway for developing cost-effective, high-efficiency, next generation low-GWP room air conditioners using commercially available components. This is particularly significant for small and medium-sized manufacturers (SMEs) in developing and emerging economies. It provides them with a streamlined, de-risked product development cycle, enabling them to leapfrog legacy technologies and compete in markets with increasingly stringent energy performance standards and environmental regulations.

While extensive academic research has explored the thermodynamic potential of low-GWP refrigerants and the theoretical optimization of individual components, this work distinguishes itself by presenting a holistic and commercially-focused methodology. Many simulation studies in the literature remain purely theoretical or focus on maximizing performance without strict, realistic cost constraints. A primary novelty of this research is the democratization of this simulation driven process: providing a transparent, reproducible, step-by-step blueprint utilizing commercially available software and off-the-shelf components. By bridging the critical gap between academic modeling and real-world industrial product development, this study proves that any manufacturer can achieve a nearly twofold increase in seasonal efficiency for a marginal cost increase of only 2–16%. It provides a tangible, cost-effective blueprint that is directly applicable for the target audience of SMEs, an aspect often absent from purely theoretical research. The findings provide strong evidence to policymakers that ambitious MEPS are technically and economically feasible, and offer a clear business case for manufacturers to invest in cleaner, more efficient technologies.

4.2. Limitations and future work

This study was intentionally focused on a 3.5 kW (1 ton) capacity mini-split air conditioner, a common residential size in many global emerging markets. While the simulation-driven methodology is much more broadly applicable, further work would be needed to adapt and validate the specific design findings for other system types (e.g., window units, ducted systems) and cooling capacities.

Furthermore, to ensure the immediate relevance and accessibility of the designs for the target manufacturing audience, this work was deliberately constrained to using only currently commercially available, mass-produced components. This practical choice means that further performance gains could be realized with even higher efficiency or next-generation technology.

This points to several exciting avenues for future research. The next step is to apply this integrated design methodology to reversible heat pump (HP) systems to optimize for heating performance. Additionally, future work could focus on integrating and evaluating next-generation, innovative components, such as microchannel heat exchangers, advanced compressor designs (e.g., vapor injection), or novel materials to push system performance well beyond

what is achievable with current off-the-shelf parts. Finally, this study focused on component and system hardware optimization; a significant opportunity remains for improving real-world performance through advanced, dynamic control strategies. Optimizing the operation of the VSD compressor, EEV, and fans in response to changing environmental loads could unlock further significant gains in seasonal efficiency.

5. Conclusions

The global transition to sustainable cooling requires the simultaneous adoption of next generation refrigerants and high-efficiency equipment. This presents a technical and economic challenge, particularly for small and medium-sized manufacturers in emerging economies. This study successfully developed, implemented, and validated a simulation-driven design methodology that directly addresses this challenge. By systematically integrating component-level modeling in VapCyc® and CoilDesigner® with a cost analysis, optimized AC prototypes were designed and built that achieved a 33% improvement in EER and a nearly twofold increase in seasonal efficiency (CSPF) compared to the reference units.

Crucially, these substantial performance gains were realized with only a 2–16% increase in total material cost, proving that high-performance, low-climate-impact air conditioners can be commercially viable and accessible in cost-sensitive markets. The close agreement between simulation predictions and experimental validation in a psychrometric chamber confirms the reliability and predictive power of the approach. The methodology presented herein is highly reproducible. By intentionally utilizing commercially available simulation tools, explicitly defining optimization settings, and constraining physical designs to off-the-shelf components and standard manufacturing processes, this study provides a transparent blueprint. It allows independent design engineers and SMEs to successfully replicate this workflow and achieve similar cost-effective efficiency gains in their own product lines. This work provides a validated, practical pathway and a tangible business case for manufacturers to accelerate the development and deployment of next-generation cooling technologies. It offers a clear blueprint to meet the dual challenge of performance and affordability, thereby contributing meaningfully to achieving the global grid, peak load and energy security goals.

Abbreviations

AC	= air conditioner
AHRI	= Air-Conditioning, Heating, and Refrigeration Institute
ASHRAE	= American Society of Heating, Refrigerating and Air-Conditioning Engineers
CO ₂	= carbon dioxide
CSPF	= cooling seasonal performance factor
DC	= direct current

EER = energy efficiency ratio
 FPI = fin per inch
 FSD = fixed speed drive
 GCEP = Global Cooling Efficiency Program
 GWP = global warming potential
 GHGs = greenhouse gases
 HC = hydrocarbon
 HCFC = hydrochlorofluorocarbon
 HFC = hydrofluorocarbon
 HFO = hydrofluoro-olefins
 HP = heat pump
 HVAC&R = heating, ventilation, air conditioning, and refrigeration
 IPCC = Intergovernmental Panel on Climate Change
 IPCC5 = Intergovernmental Panel on Climate Change Fifth Assessment Report
 ISO = International Organization for Standardization
 ODP = ozone depletion potential
 RTOC = Refrigeration, Air Conditioning and Heat Pumps Technical Options Committee
 UNEP = United Nations Environment Programme
 VSD = variable speed drive

Acknowledgments

The authors gratefully acknowledge the valuable feedback and technical review provided by Omar Abdelaziz (American University in Cairo), Brian Holuj (United Nations Environment Programme), Ian McGavisk (Rocky Mountain Institute), Ankit Kalanki (Rocky Mountain Institute), Alexander Lekov (Lawrence Berkeley National Laboratory), and Greg Rosenquist (Lawrence Berkeley National Laboratory). Affiliations are provided for identification purposes only and do not imply endorsement of this work.

Disclosure statement

No potential conflict of interest was reported by the author(s).

Funding

This study was supported by the National Philanthropic Trust, United States through the US Department of Energy Prime Contract Number DE-AC02-05CH11231.

ORCID

Chao Ding  <http://orcid.org/0000-0003-0373-0167>

Won Young Park  <http://orcid.org/0000-0003-1974-3835>

References

AHRI Standard 540. 2015. Performance rating of positive displacement refrigerant compressors and compressor units.

- Alabdulkarem A, Eldeeb R, Hwang Y, Aute V, Radermacher R. 2015. Testing, simulation and soft-optimization of R410A low-GWP alternatives in heat pump system. *Int J Refrig*. 60:106–117. <https://doi.org/10.1016/j.jrefrig.2015.08.001>
- Andersen S et al. 2020. Cooling emissions and policy synthesis report: benefits of cooling efficiency and the Kigali Amendment.
- ASHRAE 41.1. 2013. Standard method for temperature measurement.
- ASHRAE 41.6. 2014. Standard method for humidity measurement.
- Aute V, Martin C, Radermacher R. 2015. AHRI project 8013: a study of methods to represent compressor performance data over an operating envelope based on a finite set of test data. Air-Conditioning, Heating, and Refrigeration Institute.
- Bau U, Neitzke D, Lanzerath F, Bardow A. 2015. Multi-objective optimization of dynamic systems combining genetic algorithms and Modelica: application to adsorption air-conditioning systems. In *Proceedings of the 11th International Modelica Conference*, Versailles, France (No. 118, pp. 777–784). <https://doi.org/10.3384/ecp15118777>
- Calm JM. 2008. The next generation of refrigerants – Historical review, considerations, and outlook. *Int J Refrig*. 31(7):1123–1133. <https://doi.org/10.1016/j.jrefrig.2008.01.013>
- ChinaOL. 2022. Energy efficiency study of China's exported room air conditioner (in Chinese).
- Colbourne D, Suen KO. 2021. Hydrocarbon refrigerant charge limits for quiescent rooms. *Int J Refrig*. 125:75–83. <https://doi.org/10.1016/j.jrefrig.2021.01.006>
- Falchetta G, Cian ED, Pavanetto F, Wing IS. 2024. Inequalities in global residential cooling energy use to 2050. *Nat Commun*. 15(1):7874. <https://doi.org/10.1038/s41467-024-52028-8>
- Fritzon P, Engelson V. 1998. Modelica—A unified object-oriented language for system modeling and simulation. In *European Conference on Object-Oriented Programming* (pp. 67–90). Berlin, Heidelberg: Springer Berlin Heidelberg.
- Homma T, Kuijpers LJM, Palandre L, Zaelke D, Xu Y. 2025. Combined effects of refrigerant substitutions and lifecycle refrigerant management in residential air conditioners from 2020 to 2070. *Sustainability*. 17(18):8429. <https://doi.org/10.3390/su17188429>
- Hwang YJ, Park N. 2024. Virtual design on the heat pump refrigeration cycle: challenges and approaches. *Int J Air-Cond Ref*. 32, 8. <https://doi.org/10.1007/s44189-024-00052-0>
- IEA. 2018. The future of cooling, IEA, Paris. Licence: CC BY 4.0. <https://www.iea.org/reports/the-future-of-cooling>
- International Labour Organization. 2019. Working on a warmer planet: the impact of heat stress on labour productivity and decent work. ILO.
- ISO 5151: 2017/Amd 1:2020. 2020. ISO 5151 non-ducted air conditioners and heat pumps – Testing and rating for performance.
- Jiang H, Aute V, Radermacher R. 2006. CoilDesigner: a general-purpose simulation and design tool for air-to-refrigerant heat exchangers. *Int J Refrig*. 29(4):601–610. <https://doi.org/10.1016/j.jrefrig.2005.09.019>
- Jiang H. 2003. Development of a simulation and optimization tool for heat exchanger design.
- Lee M, Lee S, Chung JY, Kwon S, Kim Y. 2024. Energy and environmental performances of heat pumps using R32 and R466A as alternatives to R410A. *Appl Therm Eng*. 256:124140. <https://doi.org/10.1016/j.applthermaleng.2024.124140>
- Li Y et al. 2023. Leakage, diffusion and distribution characteristics of refrigerant in a limited space: a comprehensive review. *Therm Sci Eng Prog*. 40:101731. <https://doi.org/10.1016/j.tsep.2023.101731>
- Li Z, Ling J, Aute VC. 2018. Tube-fin heat exchanger circuitry optimization for multiple airflow maldistribution profiles.
- O'Neill NF et al. 2020. A modified total equivalent warming impact analysis: addressing direct and indirect emissions due to corrosion.

- Sci Total Environ. 741:140312. <https://doi.org/10.1016/j.scitotenv.2020.140312>
- Obringer R et al. 2022. Implications of increasing household air conditioning use across the United States under a warming climate. *Earth's Fut.* 10(1):e2021EF002434. <https://doi.org/10.1029/2021EF002434>
- Panato VH, Pico DFM, Bandarra Filho EP. 2022. Experimental evaluation of R32, R452B and R454B as alternative refrigerants for R410A in a refrigeration system. *Int J Refrig.* 135:221–230. <https://doi.org/10.1016/j.ijrefrig.2021.12.003>
- Park W, Shah N, Ding C, Qu Y. 2019. Challenges and recommended policies for simultaneous global implementation of low-GWP refrigerants and high efficiency in room air conditioners. In *Challenges and Recommended Policies for Simultaneous Global Implementation of Low-GWP Refrigerants and High Efficiency in Room Air Conditioners*. <https://escholarship.org/uc/item/07j5f74s>
- Park WY, Shah N, Gerke B. 2017. Assessment of commercially available energy-efficient room air conditioners including models with low global warming potential (GWP) refrigerants. Lawrence Berkeley National Laboratory. <https://eta.lbl.gov/publications/assessment-commercially-available>
- Purohit et al. 2020. Electricity savings and greenhouse gas emission reductions from implementing technical measures for cooling in the G20. *Atm Chem Phys.* 20:11305–11328. <https://doi.org/10.5194/acp-20-11305-2020>
- Richardson DH, Jiang H, Lindsay D, Radermacher R. 2002. Optimization of vapor compression systems via simulation.
- Shah N et al. 2017. Opportunities and risks for simultaneous efficiency improvement and refrigerant transition in air conditioning. Lawrence Berkeley National Laboratory. <https://eta.lbl.gov/publications/opportunities-simultaneous-efficiency>
- Shen B, Li Z, Gluesenkamp KR. 2022. Experimental study of R452B and R454B as drop-in replacement for R410A in split heat pumps having tube-fin and microchannel heat exchangers. *Appl Therm Eng.* 204:117930. <https://doi.org/10.1016/j.applthermaleng.2021.117930>
- Smallcombe JW et al. 2022. Quantifying the impact of heat on human physical work capacity; part IV: interactions between work duration and heat stress severity. *Int J Biometeorol.* 66(12):2463–2476. <https://doi.org/10.1007/s00484-022-02370-7>
- Suerdem K, Taner T, Acikgoz O, Dalkilic AS, Panchal H. 2023. Performance of refrigerants employed in rooftop air-conditioners. *J Build Eng.* 70:106301. <https://doi.org/10.1016/j.jobbe.2023.106301>
- Tiller M. 2001. Introduction to physical modeling with Modelica. Springer Science & Business Media.
- UNEP Ozone Secretariat. 2015. Fact sheet 2. Overview of HFC market sectors. Background material on HFC management.
- UNEP. 2019. Model regulation guidelines for energy-efficient and climate-friendly air conditioners – supporting information. https://eta-publications.lbl.gov/sites/default/files/u4e_ac_model-reg-supporting-info_20190923.pdf
- United Nations Environment Programme (UNEP). 2010. Alternatives to HCFCs in the refrigeration and air conditioning sector. Practical guidelines and case studies for equipment retrofit and replacement. Swedish Environmental Protection Agency.
- Velders GJ et al. 2012. Preserving Montreal protocol climate benefits by limiting HFCs. *Science.* 335(6071):922–923. <https://doi.org/10.1126/science.1216414>
- Velders GJM, Solomon S, Daniel JS. 2014. Growth of climate change commitments from HFC banks and emissions. *Atmos Chem Phys.* 14(9):4563–4572. <https://doi.org/10.5194/acp-14-4563-2014>
- Wei M et al. 2024. Benefits and challenges in deployment of low global warming potential R290 refrigerant for room air conditioning equipment in California. *Sustainable Energy Technol Assess.* 70:103937. <https://doi.org/10.1016/j.seta.2024.103937>
- Wetter M, Zuo W, Nouidui TS, Pang X. 2014. Modelica buildings library. *J Build Perform Simul.* 7(4):253–270. <https://doi.org/10.1080/19401493.2013.765506>
- Winkler J, Aute V, Radermacher R. 2006. Component-based vapor compression simulation tool with integrated multi-objective optimization routines.
- Wu Z et al. 2024. Flow boiling heat transfer of R454B in a 24-port microchannel tube. *Appl Therm Eng.* 248:123150. <https://doi.org/10.1016/j.applthermaleng.2024.123150>
- Zhao D et al. 2023. Data-driven online energy management framework for HVAC systems: an experimental study. *Appl Energy.* 352:121921. <https://doi.org/10.1016/j.apenergy.2023.121921>
- Zou L, Liu Y, Yu J. 2025. Recent advances on performance enhancement of propane heat pump for heating applications. *Energy.* 314:134251. <https://doi.org/10.1016/j.energy.2024.134251>

Appendix




Fig. A1. Circuitry design of the evaporator.





Fig. A2. Circuitry design of the condenser.

Table A1. Key components of the prototype units.

Components	Photos
Evaporator 5 mm hairpin tubes	
Indoor DC motor	


(Continued)

Table A1. (Continued).

Components	Photos
Axial fan	
Indoor control board	
Connecting line	


(Continued)

Table A1. (Continued).

Components	Photos
Connecting Pipe	
Condenser 5 mm hairpin tubes	

(Continued)

Table A1. (Continued).

Components	Photos
Outdoor DC motor	
Fan blade	

(Continued)

Table A1. (Continued).

Components	Photos
Outdoor control board	
Compressor	