

Lawrence Berkeley National Laboratory

Recent Work

Title

A Survey of Air Flow Models for Multizone Structures

Permalink

<https://escholarship.org/uc/item/4th9b0dm>

Authors

Feustel, H.E.

Dieris, J.

Publication Date

1991-03-01



Lawrence Berkeley Laboratory


UNIVERSITY OF CALIFORNIA

APPLIED SCIENCE DIVISION

A Survey of Air Flow Models for Multizone Structures

H.E. Feustel and J. Dieris

March 1991



APPLIED SCIENCE
DIVISION

1 LOAN COPY |
1 Circulates |
1 for 4 weeks |
Bldg. 50 Library.

PUB-603
Copy 2

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

A Survey of Air Flow Models for Multizone Structures

Helmut E. Feustel and Juergen Dieris

Indoor Environment Program
Applied Science Division
Lawrence Berkeley Laboratory
Berkeley, CA 94720, USA

March 1991

This report has been reproduced directly from the best available copy

This work was jointly supported by Carl-Duisberg-Gesellschaft e.V., Koeln, FRG, and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

A Survey of Air Flow Models for Multizone Structures

Abstract

Air flow models are used to simulate the rates of incoming and outgoing air flows for a building with known leakage under given weather and shielding conditions. Additional information about the flow paths and air-mass flows inside the building can only be made by using multizone air flow models. In order to obtain more information on multizone air flow models, a literature review was performed in 1984 [1]. A second literature review and a questionnaire survey performed in 1989, revealed the existence of 50 multizone air flow models, all developed since 1966, two of which are still under development. All these programs use similar flow equations for crack flow, but differ in the versatility to describe the full range of flow phenomena and the algorithm provided for solving the set of nonlinear equations. This literature review has found that newer models are able to describe and simulate the ventilation systems and interrelation of mechanical and natural ventilation.

Introduction

Air flow models are used to simulate the rates of incoming and outgoing air flows for a building with known leakage under given weather and shielding conditions. Air flow models can be divided into two main categories, single zone models and multi-zone models. Single zone models assume that the structure can be described by a single, well mixed zone. The major application for this model type is the single-story, single-family house with no internal partitions (e.g., all internal doors are open). A large number of buildings, however, have structures that would characterize them more accurately as multizone structures, more detailed models have been developed, which also take internal partitions into account. Figure 1 shows a simple multizone network [2].




Figure 1: Simple Multizone Network

Multizone air flow network models deal with the complexity of flows in a building by recognizing the effects of internal flow restrictions. They require extensive information about flow characteristics and pressure distributions and, in many cases, are too complex to justify their use in predicting flow for simple structures such as single-family residences [3].

As for their single-zone counterparts, these models are based on the mass-balance equation. Unlike the single-zone approach, where there is only one internal pressure to be determined, the multizone models must determine one pressure for each of the zones. This adds considerably to the complexity of the numerical solving algorithm, but by the same token, the multizone approach offers great potential in analyzing infiltration and ventilation air flow distribution.

The advantage of multizone models, besides being able to simulate infiltration in larger buildings, is their ability to calculate mass flow interactions between the different zones. Understanding the air-mass flow in buildings is important for several reasons :

- exchange of outside air with inside air is necessary for building ventilation
- energy consumed to heat or cool the incoming air to inside comfort temperature
- air needed for combustion
- airborne particles and germs transported by air flow in buildings
- smoke distribution in case of fire.

The air-mass flow distribution for a given building is caused by pressure differences, whether evoked by wind, thermal buoyancy, mechanical ventilation systems or a combination of those. The distribution of openings in the building shell and the inner paths also influence the air flow. The openings can be varied by the inhabitants. This can lead to significant differences in the pressure distribution inside the building. Figure 2 shows in detail the influence of pressure distribution on the air-mass flow distribution.

In terms of air mass flow, buildings are complicated interlacing systems of flow paths. In this grid-system the joints are the rooms of the building and the connections between the joints simulate the flow paths including the flow resistances caused by open or closed doors and windows or background leakage of the partitions. The boundary conditions for the pressure can be described by the grid points outside the building. The wind pressure distribution depends on the velocity and the direction of the wind, the terrain surrounding of the building, and the shape of the building. If the physical interrelationship between the flow resistance and the air flow is known for all flow paths, the air flow distribution for the building can be calculated, as long as there is no density difference between outside and inside air. Differences in density of the air, due to differences between outside and inside air temperatures or moisture content, cause further pressures in the vertical direction, again influencing the air mass flow.

Mechanical ventilation can also be included in this network. The duct system can be treated like the other flow paths in the building. The advantage for calculating air flow distribution effects of mechanical ventilation systems is that the duct path ways, as well as their connections with the building, are known. In the case of mechanical ventilation systems the fan can be described as the source of pressure differences; lifting the pressure level between two joints according to the characteristic curve of the fan.

Because of the non-linear dependency of the volume flow rate on the pressure difference, the pressure distribution for a building can be calculated only by using a method of iterations. Large quantities of computer storage was necessary for the early models to describe buildings with arbitrary floor plans and to solve the set of non-linear equations.




Figure 2 : Influence of Pressure Distribution on the Air-Mass Flow in Buildings

Literature Review and Questionnaire Survey

A literature review undertaken in 1984 [1] revealed 26 papers describing 15 different multizone infiltration models which had been developed in eight countries. A recent questionnaire survey produced additional information about the status of network models. One of the first models we found was Jackman's model "LEAK" [4] which was published in 1970. In 1974 it was followed by the NRCC model [5], which was the first one available to interested parties. Indeed, this numerical tool is probably still the most widely used multizone infiltration model.

Several multizone models were developed in the aftermath of the oil price crises. Between 1975 and 1977 a series of steps were taken at Technische Universitaet Berlin to develop such a model. This resulted in the program STROM [6] which was later extended to handle HVAC-systems and has recently been rewritten to improve the solver and to be combined with a thermal building simulation model [7]. Concurrent with STROM, ELA 4 [8] was developed. The models VENT 1 and VENT 2 [9] as well as BREEZE [10] were developed in the late 1970's by researchers from British Gas and the Building Research Establishment. In the early 1980's, the first versions of Nantka's INFILTRATION & VENTILATION [11], Walton's AIRNET [12] and Herrlin's MOVECOMP [13] appeared. The latter two programs were the first to address the mathematical problem of solving the set of non-linear equations for zones with very different leakage characteristics. Open doorways in otherwise tight constructions are the main cause of significant problems in convergence. This has been solved by introducing under-relaxation factors to the well known Newton method.

KGVCVP from Hayakawa dates back to 1979 [14]. More recent work done in Japan has been published by Ishida and Udagowo [15] as well as Hayashi and Urano [16], Sasaki [17], Okuyama [18] and Matsumoto and Yoshino. [19].

France has also developed several multizone models; the recent survey unveiled models from CSTB, INSA [20] and EDF. From Brazil, Melo's model FLOW2 [21] has been discovered.

The latest development in infiltration modeling is the COMIS model [22]. In a twelve month period ten scientists from nine countries, working together at Lawrence Berkeley Laboratory, developed a multizone model on a modular base. Because of its modular structure COMIS is designed to expand its capability to simulate buildings. To accomplish a "user-friendly" program, special emphasis was given to input and output routines. Support of the international group by IEA's Air Infiltration and Ventilation Centre will help the wide distribution of this model to all interested parties. COMIS can be used as a stand-alone infiltration model with input and output features, or as an infiltration module for thermal building simulation programs. It also serves as a module library.

One of the major tasks for the program user is to find a method of determining the wind pressure distribution for a building. This can be done by measuring the wind pressure distribution on a scale model in a wind tunnel or by using measured data from available literature. Only few attempts have been made to

calculate the wind pressure distribution. In order to calculate the C_p -distribution for buildings, the COMIS group worked on a method based on a parametrical study, to determine the C_p -values [23].

Crack flow, large openings and mechanical ventilation systems can be simulated by some of the models. Furthermore, additional flows, i.e., simultaneous two way flow at large openings and wind turbulence effect at single-sided windows etc., were studied.

Airflow rates through doorways, windows and other common large openings are significant ways in which air, pollutants and thermal energy are transferred from one zone of a building to another.

In the previous survey of multizone infiltration models, however, none of the described codes were able to solve this problem in any other way than to divide the large opening into a series of small ones described by crack flow equations.

Therefore, COMIS's contribution to this fundamental problem was to describe the physical problem, review the various solutions developed in the literature and compare these solutions using both a numerical and a physical point of view.

In most cases the temperature of the air in a crack is quite different from the temperatures of the zones on either side of the crack. Furthermore, air leakage performance measurements are usually performed in a certain temperature condition, but results are used at different temperatures. The temperature variation, however, has a big influence on the air leakage flow due to changes in the air viscosity and air density. Unfortunately, almost all the models dealing with air leakage characteristics ignore this phenomenon.

HVAC-Systems (Heating, Ventilating and Air-Conditioning Systems) are composed of ducts, duct fittings, junctions, fans, air filters, heating and cooling coils, air-to-air heat exchangers, flow controllers, etc. Several modeling programs for ventilating systems were developed.

Calculating the infiltration and ventilation flow rates requires the solution of a non-linear system of equations. The main task is to find an efficient solving method. The starting point is the Newton-Raphson method, with derivatives, operating on a node-oriented network which, in most cases, quickly brings about the convergence of the system of equations.

Although network computer models are available, there is an obvious need for simplified multichamber infiltration models capable of providing the same accuracy as the established single-cell models. The extended crack model is the simplest multizone model. It is used to design conditioning loads and size the conditioning equipment [24]. The method is based on the single-zone crack model and has been refined to multizone applications by also taking into consideration the crack flow through internal partitions. Buildings are characterized according to their cross flow and stack flow capabilities. The stack pressures of the core zones for multistory structures are pre-calculated for design weather conditions and published in look-up tables. Together with pressures due to the effect of wind

and permeability distribution this enables a user to calculate the infiltration for each of the outside zones.

The simplified multizone infiltration model developed at LBL [25] is able to calculate the air flow distribution for arbitrary structures in any given weather condition. The basic idea is to determine the flow network and to calculate the resultant air permeability of a zone from the combination of flow paths arranged in series and/or parallel. The use of these equations assumes that all permeabilities have the same flow characteristics and, therefore, the same exponent, n .

Air flows caused by separate mechanisms (such as wind and thermal buoyancy) are not able to be added because the flow rates are not linearly proportional to the pressure differences. To superimpose the flows, it is necessary to add the pressures.

Several lumped parameters reflecting the different permeability distributions of the building's envelope and the flow resistances inside the building were introduced to describe the air flow distribution. To keep the model simple no mass-balance equation is used to predict the air flows. Because of the pre-calculation of the simplified network, the model gives a comprehensive understanding of the flow characteristics of the structure under investigation. The model is simple to use and requires only simple mathematical tools, e.g., pocket calculator.

In terms of the total number of returned questionnaires this survey represents the most comprehensive review of current research in developed multizone infiltration models. The questionnaires were mailed to addresses provided by the Air Infiltration and Ventilation Centre [26,27]. Fifty multizone infiltration models developed in 16 countries are represented in this survey. In addition to the general references more than 60 papers describing the programs in detail are listed in Appendix B together with the names and addresses of the authors. Of those models for which questionnaires were not returned, information was collected from the reviewed literature.

In cases where the reviewed paper did not give a reasonable answer to a certain problem or where information was missing from a returned questionnaire, a question mark was entered in the list of models.

The summarized list of multizone air flow models found in the literature are reproduced in Appendix A. The current addresses of the authors including their references are shown in Appendix B. Equations are reproduced separately in Appendix C.

Discussion

The survey of multizone network models is summarized in Table 1. It shows that 34 models have been written in FORTRAN (FORTRAN IV (F IV), FORTRAN V (F V), and FORTRAN 77 (F 77)). The programming language BASIC has been used four times; followed by HPL with three and "C" with two applications. PASCAL and dBaseIV have been used for the development of one model each.

Among the analyzed models it appeared that 14 were developed on main frame computers, 15 on PC's and 11 on workstations.

In the past large amounts of computer storage was necessary, when calculating the air flow distribution of more complicated buildings. Nowadays most programs use solvers which reduce the space requirement, e.g., band matrices or the skyline method. The Newton method is the most common tool used to solve the set of nonlinear equations. The majority of the programs use a technique based on Newton-Raphson. Other Algorithms are used less frequently.

The limits of zones and openings per zone a model can handle depends on computer storage. Due to the limited availability of computer storage most of the earlier models were not able to handle more than 100 zones. Models developed later are able to handle an unlimited number of zones.

Approximately 1/3 of the models do not have an interactive input option and the output features listed show that only few models use graphical output or statistical functions rather than files comparable to the arrays used by the model. These features are an indication of a user unfriendly model. CAD - Input and 3 - D building description are not necessary to run the program, but would increase the user-friendliness. Unfortunately, these input features belong to the "special design", and are rarely integrated in these kind of models.

Only 19 models take into consideration occupant schedules which can lead to significant differences in the pressure distribution.

The output features show that the graphical output and the statistical functions are less applied than files used by the model.

Twentyfour of the models use a separate input program and twenty models are based on a modular structure. A modular structure might be more advantageous for further development, because the model would be easier to expand. A combination with other models would also be easier to implement.

Fifteen of the models allow a combination with a thermal model and thirteen models are coupled with a pollution model.

Less than one third (15) of the models are available to third parties. Some models are not available before completing and testing. Fifteen models are not available to the public and are written as research tools, rather than for the use of professional engineers or architects.

Table 1 : Review of Multizone Air Flow Infiltration Network Models			
Program Language :			
FORTRAN	34		
BASIC	4		
PASCAL	1		
C	2		
HPL	3		
dBaseIV	1		
Computer Type :			
Main Frame Computer	14		
Work Station	11		
Personal Computer	15		
Solver :			
Hardy - Cross - Method	1		
Newton - Raphson Method	25		
Levenberg - Marquard - Method	1		
Brown - Conte - Method	1		
Secant - Method	3		
Rule "falsi"	1		
Gaussian - Elimination	1		
Beta - Method by Newmark	1		
Limits :	≤ 100	> 100	unlimited
max. number of zones	18	7	18
max. number of opening/zone	17	3	23
max. number of shafts/corridors/floors	17	2	23
max. number of mechanical ventilation system	18	2	20
Input Features :	yes	no	not specified
interactive input	15	21	14
CAD input	1	30	19
weather data from weather files	24	14	13
3 - D building description	10	26	14
schedules (e.g., occupants)	19	17	14
Output Features :	yes	no	not specified
file of arrays used by the model	29	6	15
graphical output	12	23	15
statistical functions	5	29	16
Structure :	yes	no	not specified
separate input program	24	14	12
modular structure	20	14	16
Combination with other models :	yes	no	not specified
combined with thermal model	15	24	11
combined with pollution model	13	26	11
Availability :	no	yes	yes, but
program available to third parties	15	15	12

Conclusion

This literature review and the questionnaire survey show that an extensive research effort has been made in the last five years to develop an air flow model for multizone structures. Especially the maximum number of zones the models can handle has been increased due to reduced computer storage requirements. Some of the models have been extended with special input and output features.

Fifteen of the models are available to third parties and fifteen models have been written as research tools, and are difficult to use. This might be the reason they are not available to third parties.

The development of multizone infiltration and ventilation models shows a relatively slow evolution. Lack of exchange of information, restricted distribution of models, poor documentation, and lack of a flexible structure are probably the reasons why models developed in the early seventies are not very different from those developed in the late eighties.

Although several of the models discovered during this survey serve a particular purpose, they could have been developed using existing models. The COMIS workshop was trying to overcome these problems by creating a multizone infiltration model with a modular structure which will allow modules to be changed easily. The availability of the program and its documentation together with the international authorship should help to establish COMIS as an infiltration standard on which specific applications can be built.

Future Outlook

Along with stand-alone infiltration models, network models will also find their way into thermal building simulation models. With the expected advances in the development of the next generation of building simulation programs, infiltration modules will be needed for implementation in the program libraries.

Future tasks include the development of methods to determine the required input parameters, especially the wind pressure distribution. Further work must be done through sensitivity studies to reduce the input requirement and to increase user-friendliness by using the output features of the PC's.

Validation of the models is another essential task. In order to understand physical phenomena related to transport mechanism in buildings and to develop numerical descriptions, measurements must first be performed under steady state conditions. It is necessary, in order to measure mass flow transport mechanism accurately, to be able to control the pressure level and its fluctuation for each of the outside walls. This is only possible if the test building itself is located in a building. Such a test facility would not only validate air flow models as a whole, but would also help to validate the tracer gas techniques used to validate infiltration models in field experiments.

Recent developments in measurement techniques open new possibilities to study physical phenomena and use the results for comparison with results from the model. Some data sets for evaluation purposes have been produced based on in-situ measurements of heavy instrumented buildings. Before these data sets can be used for model evaluation, however, internal model comparisons based on benchmark buildings have to be performed.

The Energy Conservation in Buildings and Community Systems Program of the International Energy Agency adopted a new working group (Annex 23) to study physical phenomena causing air flow and pollutant transport (e.g., moisture) in multizone buildings and to develop modules to be integrated in a multizone air flow modeling system. The system itself shall be user-friendly and structured to be incorporable in thermal building simulation models. Furthermore, special emphasis shall be given to provide data necessary to use the system (e.g., wind pressure distribution, default values for leakage of building components, material properties like absorption and desorption). The comparison between results from the model and from in-situ tests is an important part of this annex.

Close cooperation is envisaged, with regard to state-of-the art reviews, data collection, coordination of work, e.g., defining cases for evaluation purposes with other pertinent projects. The work to be carried out will be complementary with the above mentioned Annexes.

The Air Infiltration and Ventilation Centre will, as part of its on-going work plan, act as a vehicle for disseminating the results of this particular Annex. A data base for evaluation purposes is going to be prepared by AIVC. The Centre has already started to collect wind pressure data and leakage data.

Acknowledgements

We would like to acknowledge the program authors for their cooperation in responding to our questionnaires, for without this information the different programs could not have been summarized.

This work was jointly supported by the Carl-Duisberg-Gesellschaft, Koeln, Federal Republic of Germany, and the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems, Building Systems Division of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

References

1. Feustel, H.E. and V.M. Kendon: "Infiltration Models for Multicellular Structures - a Literature Review", Energy and Buildings, Vol 8, No. 2, 1985, Lawrence Berkeley Laboratory, LBL-Report No. 17588, April 1985
2. Liddament, M.: "Air Infiltration Calculation Techniques - An Applications Guide", Air Infiltration and Ventilation Centre, June 1986
3. ASHRAE 1985 Handbook of Fundamentals, Chapter 22, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta, GA, 1985
4. Jackman, P.J.: "A Study of Natural Ventilation of Tall Office Buildings", Journal of Institution of Heating and Ventilating Engineers, Vol 38, 1970
5. Sander, D.M. "FORTRAN IV Program to calculate Air Infiltration in Buildings", DBR Computer Program No. 37, National Research Council Canada, 1984
6. Feustel, H.E.: "Entwicklung eines FORTRAN Programms zur Bestimmung der Luftstromverteilung in Gebaeuden", Thesis, Technische Universitaet Berlin, 1977
7. Jianxiong Guo: "Weiterentwicklung des Programms mit dem Ergebnis einer Beruecksichtigung thermischer Druckdifferenzen auch innerhalb eines Geschosses und einer spuerbaren Verringerung der Rechenzeiten", Interner Institutsbericht, Technische Universitaet Berlin, 1988
8. de Gids, W.F.: "Calculation Method for the Natural Ventilation of Buildings", TNO Research Institute for Environmental Hygiene, Delft, 1977
9. Etheridge, D.W. and D.K. Alexander: "The British Gas Multi-Cell Model for Calculating Ventilation", ASHRAE Transactions, Vol. 86, Part II, 1980
10. Evers, E. and A. Waterhouse: "A Computer Model for Analysing Smoke Movement in Buildings", Building Research Establishment, 1978
11. Nantka, M.: "A Numerical Method for Air Change Rate of Buildings Calculated" in Proceedings, 5th International Conference on HVAC, Praha, 1981
12. Walton, G.N.: "Thermal Analysis Research Program Reference Manual", NBSIR 83-2655, U.S. Department of Commerce, 1983

13. Herrlin, M.K.: "MOVECOMP: A static Multicell Air Flow Model", ASHRAE Transactions, Vol 91, Part 2B, 1985
14. Hayakawa, S and S. Togari: "Flow Rate Variation of Air Conditioning Systems due to Stack Effect and opening a Window", Kajima Institute of Construction Technology, Japan, Report Nr. 30, 1979
15. Ishida, K. and M. Udagowo: "Validation of the Ventilation Net Work Model for the Estimation of Room Temperatures and Heat Load of Residential Buildings with Measured Data", Transactions of the Architectural Institute of Japan, 1988
16. Hayashi, T., Y. Urano, T. Watanabe and Y. Ryu: "Passive System Simulation Program PSSP and its Applications", in Proceedings, "Building Energy Simulation Conference 1985, Seattle, 1985
17. Sasaki, T.: "Der Lueftungszustand von der Luftschicht durch Wind-Unruhe", Transactions of the Architectural Institute of Japan, No. 372, 1987
18. Okuyama, H.: "Network Numerical Analysis Method for Heat Transfer and Air Flow in Buildings", in Proceedings, 17th Symposium by the Committee of Building Heat Transfer, Building Environment Committee of Architectural Institute of Japan, 1987
19. Matsumoto, M. and H. Yoshino: "A Calculation Method for Predicting Air Pollution in Multi-Celled Buildings", The Meeting of the Tohoku Branch of the Architectural Institute of Japan, 1988
20. Cacavelli, D., J.J. Roux; and F. Allard: "A simplified Approach of Air Infiltration in Multizone Buildings", in Proceedings, "9th AIVC Conference", Gent, 1988
21. Melo, C.: "FLOW - An Algorithm for Calculating Air Infiltration into Buildings", in Proceedings, ICBEM'87 International Congress on Building Energy Management, Lausanne, 1987
22. Feustel, H.E., F. Allard, V.B. Dorer, M. Grosso, M. Herrlin, M. Liu, J.C. Phaff, Y. Utsumi, and H. Yoshino: "The COMIS Infiltration Model", in Proceedings, "Building Simulation '89, The International Building Performance Simulation Association", Vancouver, 1989.
23. Feustel, H.E. and A. Raynor-Hoosen (Editors): "Fundamentals of the Multizone Air Flow Model - COMIS", Air Infiltration and Ventilation Centre,

Warwick, Technical Note 29, May 1990

24. German Standard DIN 4701: "Regeln fuer die Berechnung des Waermebedarfs von Gebaeuden", Teil 1: Grundlagen der Berechnung Teil 2: Tabellen, Bilder, Algorithmen Beuth Verlag Berlin, Berlin, 1983
25. Feustel, H.E. and M.H. Sherman: "A Simplified Model for Predicting Air Flow in Multizone Structures", Energy and Buildings, Vol 13, No. 3, 1989
26. Charlesworth, P.: "1986 Survey of Current Research into Air Infiltration and Related Air Quality Problems in Buildings", Air Infiltration and Ventilation Centre, Technical Note 19, December 1986
27. Blacknell, J.: "A Subject Analysis of the AIVC's Bibliographic Database - AIRBASE (6th edition)", Air Infiltration and Ventilation Centre, Technical Note 25, January 1989

APPENDICES

The following appendices describe the reviewed literature and the results of the questionnaire survey in a tabular form. Fifty different multizone air flow models are listed in Appendix A. A question mark was entered in the table of models where the reviewed paper did not give a reasonable answer to a certain problem or where information was missing from the returned questionnaire. The authors of the models can be found in Appendix B. Together with the authors of the computer models and their current addresses, more than 60 papers describing the models in detail are listed in Appendix B. Equations used by the models as well as a nomenclature are shown separately in Appendix C.

APPENDIX A - List of Multizone Air Flow Models

Number (for authors see Appendix B)	1	2	3	4	5	6	7	8	9	10	11
General											
-name	see ^{1.1}	see ^{2.1}	?	PSSP/MV ^{14.1}	ETIMCELL	VENT	see ^{7.1}	see ^{8.1}	NETS	S3PAS	GAINE
-program-language ^{0.1}	F + Basic	?	F77 + MS	F 77	Pascal	F 77	Basic	F	F	F 77	F IV
-written for computer type ^{0.2}	PC	?	M / PC	M / PC ^{4.2}	PC	M	PC	M	M	WS	WS
-written for operating system	MS-DOS/DOS	?	?	? ^{4.2}	MS-DOS 3.3	--	?	?	--	VMS	VMS
Equations^{0.3}											
-flow through cracks	1 G	1 D	1 E	1 E	1 E	1 B	1 E	1 E	1 K	1 E	1 A
-flow through large openings	2 D	1 D	2 D	2 D	2 D	2 D	2 D	2 G	2 I	2 D	--
-flow through duct work	3 B	1 D	--	--	3 C	?	3 E	3 E	3 G	--	3 E
-fan flow characteristics	4 E	--	4 A	constant	4 B	?	4 E	--	4 G	4 C	4 C
-wind pressure	5 C	-- ^{2.2}	5 D	5 C	5 B	5 E	5 D	5 C	5 C	5 B	5 C
-thermal buoyancy	6D	6D	6B	6D	6 B	--	6 B	6 D	6 J	6 B	6 B
-outside pressure fluctuation	constant	--	--	--	--	--	7 A	--	--	--	constant
-circulation flow on large openings	yes	?	?	yes	yes ^{5.2}	--	--	--	--	--	--
-single sided ventilation	yes	?	?	yes ^{4.3}	--	--	?	?	--	--	?
-cross ventilation	yes	?	?	8 D	--	--	?	?	--	--	?
-pressure coefficient (only if calculated)	--	?	?	yes	yes ^{5.3}	--	?	?	--	11 A	constant
-temperature gradient	yes	?	12 A	--	constant	--	?	?	constant	--	?
Algorithm To Solve Nonlinear Set Of Equation^{0.4}											
-name of algorithm ^{0.5}	N - R	Iteration	N - R	Newton ^{4.4}	see ^{5.4}	?	N - R	rule "falsi"	MNR	see ^{10.1}	Newton
-equation	13 C	13 D	13 C	13 F	?	13 A	13 B	13 D	see ^{9.1}	13 A	13 E
Limits											
-max. number of zones	100	2 or 3	20	unlimited	see ^{5.5}	8	?	?	300	10	unlimited
-max. number of openings/zone	20	2 or 3	20	unlimited	?	12	?	?	900	33	unlimited
-max. number of shafts/corridors/floors	20	--	?	unlimited	?	2	?	?	300	unlimited	unlimited
-max. number of mechanical ventilation systems	unlimited	--	20	unlimited	?	--	?	?	900	100	unlimited
Input											
-interactive input	?	no	no	no	yes	no	yes	no	no	yes	no
-CAD-input	no	no	no	no	no	no	yes	no	no	no	?
-weather data from weather files	no	no	yes	yes	yes/no ^{5.6}	yes	yes	yes	yes	no	yes
-3-D building description	no	no	no	no	yes	no	yes	no	yes	no	no
-schedules (e.g., occupants)	no	no	yes	yes	yes	yes	yes	yes	yes	yes	yes
Output											
-file of arrays used by the model	?	no	yes	yes	yes	no	yes	no	yes	yes	yes
-graphical output	no	no	no	no	no	no	no	no	yes	yes	yes
-statistical functions	no	no	no	no	no	no	no	no	no	no	yes
Structure											
-separate input program	?	no	yes	yes	yes	yes	no	no	yes	yes	yes
-modular structure	?	no	no	no	yes	no	yes	yes	yes	yes	yes
Combination With Other Models											
-combined with thermal model	yes	no	yes	yes	no	no	no	no	yes	yes	no
-combined with pollution model	yes	no	no	no	no	no	no	no	yes	no	yes
Program Availability											
-program available to third parties	no	yes, but ^{2.3}	no	yes ^{4.5}	yes, but ^{5.7}	yes	no	no	yes, but ^{9.2}	?	no

Number (for authors see Appendix B)	12	13	14	15	16	17	18	19	20	21	22
General											
-name	SIREN2	JKCIRCUS	see ^{14.1}	--	see ^{16.1}	see ^{17.1}	SSPV-7	AIRNET	MOVECOMP-PC	--	VENCON
-program-language ^{0.1}	F IV	F	F 77	F	F	F	F 77	C	F 77	F	HP Basic 4.0
-written for computer type ^{0.2}	WS	WS/PC	?	?	PC	WS	?	PC	M/PC	M/PC	series 200
-written for operating system	VMS	VMS/MS-DOS	?	?	MS-DOS	VAX	?	MS-DOS	MS-DOS	NCOS/DOS	HP Basic 4.0
Equations^{0.3}											
-flow through cracks	1 A	1 G	1 E	1 A	1 A	1 B	1 G	1 A + 1 J ^{10.1}	1 A	1 A	1 G + 2 F
-flow through large openings	2 A	2 K	2 D	2 A	2 D	?	2 D	2 A + 2 H ^{10.1}	2 A	2 A	1 G + 2 F
-flow through duct work	3 B	3 H	--	?	3 B	?	--	3 F	3 H	--	3 E
-fan flow characteristics	4 C	--	4 B	?	4 A	?	4 B	4 F	yes ^{20.1}	--	4 A
-wind pressure	5 C	5 B	5 C	5 B	5 A	?	5 B	5 C	5 D	5 B	5 B
-thermal buoyancy	6 B	constant	6 B	?	6 H	?	6 B	6 A	6 D	6 B	6 G
-outside pressure fluctuation	constant	--	?	?	?	?	--	--	--	--	7 B
-circulation flow on large openings	--	--	?	?	?	?	--	yes	--	1 A	yes
-single sided ventilation	?	--	?	?	?	?	--	--	--	--	yes
-cross ventilation	?	--	?	?	?	?	--	yes	--	1 A	yes
-pressure coefficient (only if calculated)	constant	--	?	?	?	?	11 B	--	constant	--	--
-temperature gradient	?	--	?	?	12 B	?	--	--	12 C	no	yes
Algorithm To Solve Nonlinear Set Of Equations^{0.4}											
-name of algorithm ^{0.5}	Lev - Mar	Gauss	Bro - Con	N - R	?	Beta	N - R	N - Steff	N-R ^{20.2}	N - R	Sec - Met
-equation	13 F	13 G	see ^{14.2}	?	?	?	13 B	13 E or 13 H	13 H	13 E	see ^{22.1}
Limits											
-max. number of zones	40	unlimited	unlimited	?	30	unlimited	unlimited	unlimited	unlimited	unlimited	unlimited
-max. number of openings/zone	unlimited	unlimited	unlimited	?	20	unlimited	unlimited	unlimited	unlimited	unlimited	unlimited
-max. number of shafts/corridors/floors	1	unlimited	unlimited	?	20	unlimited	unlimited	unlimited	unlimited	unlimited	unlimited
-max. number of mechanical ventilation systems	unlimited	unlimited	unlimited	?	10	unlimited	unlimited	unlimited	unlimited	--	400
Input											
-interactive input	no	no	yes	yes	no	?	no	yes	no	yes	no
-CAD-input	?	no	?	no	no	?	no	no	no	no	no
-weather data from weather files	yes	no	yes	no	yes	yes	yes	no	yes	no	no
-3-D building description	no	no	?	no	yes	?	yes	no	no	yes	no
-schedules (e.g., occupants)	yes	no	yes	no	no	no	?	yes	no	no	no
Output											
-file of arrays used by the model	yes	yes	yes	yes	?	yes	yes	no	yes	no	yes
-graphical output	no	no	yes	no	?	?	no	no	no	no	yes
-statistical functions	no	no	?	no	?	?	no	no	yes	no	yes
Structure											
-separate input program	yes	no	yes	yes	no	yes	no	yes	yes	no	no
-modular structure	yes	no	?	no	no	?	no	yes	yes	no	yes
Combination With Other Models											
-combined with thermal model	no	no	yes	no	no ^{16.2}	no	yes	no	no	no	yes
-combined with pollution model	yes	no	no	no	no	no	yes	no	no	no	no
Program Availability											
-program available to third parties	no	yes	no	?	no ^{16.3}	limited	no	yes	yes	no	no

Number (for authors see Appendix B)	23	24	25	26	27	28	29	30	31	32	33 ^{33.1}
General											
-name	INFILTR	ICARE	TONY	STROM-II	?	FLOW2	CP 37 ^{29.1}	PAFDPIM	CLIM	?	COMERL
-program-language ^{0.1}	F 77	Basic	F 77	F V	F	F 77	F	Basic	F 77	F 77	dBaseIV
-written for computer type ^{0.2}	PC	HP-series 200	M/PC	M	M	VAX/IBM	M/PC	PC	?	M/WS	PC
-written for operating system	MS-DOS	HP Basic 3.0	VMS-DOS	?	?	VMS	?	DOS	?	Ultrix	DOS
Equations^{0.3}											
-flow through cracks	1 L	1 G	1 G	1 E	1 C	1 B	1 F	1 B	1 M	1 H	1 A
-flow through large openings	2 J	--	2 D	2 D	2 C	2 D	2 E	2 D	2 K	2 D	2 L
-flow through duct work	3 I	3 C	--	3 B	--	--	--	3 J	?	3 D	3 J
-fan flow characteristics	--	4 E	4 E	4 B	--	--	--	4 H	?	4 D	4 E
-wind pressure	5 B	5 D	5 D	5 D	5 B	5 B	5 F	--	5 G	5 B	5 C
-thermal buoyancy	6 B	6 A	6 B	6 B	6 C	6 C	6 D	--	6 I	6 F	6 J
-outside pressure fluctuation	--	--	--	--	--	constant	--	--	--	--	constant
-circulation flow on large openings	--	--	--	--	--	8 A	--	--	8 B	--	8 C
-single sided ventilation	constant	--	--	?	?	--	--	--	--	?	yes ^{33.2}
-cross ventilation	constant	yes	yes	?	?	--	--	--	12 A	?	yes ^{33.2}
-pressure coefficient (only if calculated)	?	yes	--	--	?	yes ^{28.1}	--	--	--	?	yes ^{33.3}
-temperature gradient	?	--	--	--	?	12 D	--	--	--	?	constant
Algorithm To Solve Nonlinear Set Of Equation^{0.4}											
-name of algorithm ^{0.5}	?	Newton	Newton	Newton	HCR	SOLVP	Newton	Newton	Sec-Met	Newton	see ^{33.4}
-equation	13 B	13 D	13 D	13 B	13 C	13 D	13 D	?	13 I	-- ^{32.1}	--
Limits											
-max. number of zones	200	4	unlimited	150	unlimited	unlimited	25	4	25	60	unlimited
-max. number of opening/zone	3500	--	unlimited	unlimited	unlimited	unlimited	4	7	10	unlimited	unlimited
-max. number of shafts/corridors/floors	--	5	unlimited	unlimited	unlimited	unlimited	8	--	?	10	unlimited
-max. number of mechanical ventilation	--	5	unlimited	6	unlimited	unlimited	?	2	4	unlimited	unlimited
Input											
-interactive input	no	yes	no	yes	?	no	no	yes	?	?	yes
-CAD-input	no	no	no	no	?	no	no	no	?	?	no
-weather data from weather files	no	yes	yes	no	?	yes	no	no	yes	?	yes
-3-D building description	yes	no	no	yes	?	no	no	no	no	?	no
-schedules (e.g., occupants)	no	yes	yes	?	?	no	no	no	?	?	yes
Output											
-file of arrays used by the model	yes	yes	yes	yes	?	yes	yes	no	?	?	yes
-graphical output	no	yes	no	no	?	yes	no	no	yes	?	yes
-statistical functions	no	yes	no	no	?	no	no	no	yes	?	no
Structure											
-separate input program	yes	yes	yes	yes	?	yes	no	no	no	?	yes
-modular structure	yes	yes	yes	yes	?	yes	yes	no	no	?	yes
Combination With Ohter Models											
-combined with thermal model	no	yes	yes	yes	?	yes	no	no	yes	?	no
-combined with pollution model	no	no	no	no	?	yes	no ^{29.2}	no	no	?	yes
Program Availablilty											
-program available to third parties	?	yes	yes	no	yes	yes, but ^{28.2}	yes	yes, but ^{30.1}	no	?	unclear yet

Number (for authors see Appendix B)	34	35	36	37	38	39	40	41	42	43	44
General											
-name	?	?	TARP	?	Vent	?	?	SAFM ^{41.1}	?	?	?
-program-language ^{0.1}	F 77	F IV	F 77	F IV	F 77	HPL	HP-Special	--	?	?	F
-written for computer type ^{0.2}	VAX	M	?	M	IBM compatible	PC	PC	--	?	?	ICL 1907
-written for operating system	?	?	?	?	MS DOS	?	?	--	?	?	?
Equations^{0.3}											
-flow through cracks	1 G	1 F	1 A	1 B	1 M	1 E	1 E	1 B	1 E	1 E	1 E
-flow through large openings	--	2 E	2 A	2 B	2 B	2 F	--	--	--	?	?
-flow through duct work	3 A	constant	--	--	?	3 E	--	--	3 C	?	?
-fan flow characteristics	yes	--	--	4 A	see ^{38.1}	4 E	--	--	4 C	?	?
-wind pressure	5 E	yes	5 A	5 B	5 F	5 B	5 D	5 H	5 B	?	?
-thermal buoyancy	6 B	6 D	6 A	6 B	6B, 6C, 6J	6 G	6 B	6 K	6 E	?	?
-outside pressure fluctuation	yes	--	constant	--	?	7 B	--	--	--	?	?
-circulation flow on large openings	--	--	yes	--	?	--	--	--	--	?	?
-single sided ventilation	?	?	--	?	?	?	?	--	?	?	?
-cross ventilation	?	?	yes	?	?	?	?	--	?	?	?
-pressure coefficient	?	?	--	?	?	?	?	11 C	?	?	?
-temperature gradient	?	?	--	?	?	?	?	--	?	?	?
Algorithm To Solve Nonlinear Equation^{0.4}											
-name of algorithm ^{0.5}	--	?	N - Steff	N - R	N - R	Sec - Met	--	--	?	?	?
-equation	13 A	13 D	13 E	13 B	13C,13E,13H,13I	13 D	see ^{40.1}	--	?	?	?
Limits											
-max. number of zones	725	25	see ^{36.1}	300	100	50	see ^{40.2}	unlimited	?	?	211
-max. number of openings/zones	unlimited	4	see ^{36.1}	120	100	see ^{39.1}	see ^{40.3}	unlimited	4	?	4
-max. number of shafts/corridors/floors	5,720,720	1	see ^{38.1}	unlimited	?	see ^{39.1}	unlimited	unlimited	1, 0, ?	?	1, ?, 10
-max. number of mechanical ventilation	20	8	see ^{36.1}	unlimited	100	see ^{39.1}	--	--	?	?	?
Input											
-interactive input	?	?	--	?	yes	?	?	no	?	?	?
-CAD-input	?	?	--	?	no	?	?	no	?	?	?
-weather data from weather files	?	?	yes	?	?	?	?	no	?	?	?
-3-D building description	?	?	yes	?	?	?	?	no	?	?	?
-schedules (e.g., occupants)	?	?	yes	?	?	?	?	no	?	?	?
Output											
-file of arrays used by the model	?	?	--	?	yes	?	?	no	?	?	?
-graphical output	?	?	--	?	?	?	?	no	?	?	?
-statistical functions	?	?	--	?	?	?	?	no	?	?	?
Structure											
-separate input program	?	?	yes	?	yes	?	?	no	?	?	?
-modular structure	?	?	no	?	yes	?	?	no	?	?	?
Combination With Other Models											
-combined with thermal model	?	?	yes	?	no	?	?	no	?	?	?
-combined with pollution model	?	?	yes	?	yes	?	?	no	?	?	?
Program Availability											
-program available to third parties	limited	yes	limited	limited	yes, but ^{38.2}	no	no	yes	?	?	yes

Number (for authors see Appendix B)	45	46	47	48	49	50
General						
-name	?	VENT 1	VENT 2	COMIS	CONTAM88	DTFAM
-program-language ⁰¹	?	F 77	Basic	F 77	C	F77
-written for computer type ⁰²	?	M	PC	MicroVAX,PC	IBM comp	IBM com
-written for operating system	?	?	?	Unix, MS-DOS	MS-DOS	MS-DOS
Equations⁰³						
-flow through cracks	1 D	1 D	1 D	1 A	see ^{40.1}	see ^{50.1}
-flow through large openings	2 G	2 D	2 D	2 L	see ^{40.1}	see ^{50.1}
-flow through duct work	2 G	--	--	3 J	see ^{40.1}	see ^{50.1}
-fan flow characteristics	?	constant	constant	4 E	see ^{40.1}	see ^{50.1}
-wind pressure	?	5 C	5 C	5 C	?	?
-thermal buoyancy	?	6 B	6 B	6 J	?	?
-outside pressure fluctuation	?	7 A	7 A	constant	--	--
-circulation flow on large openings	?	--	--	8 C	yes	yes
-single sided ventilation	?	--	--	yes ^{48.1}	--	--
-cross ventilation	?	--	--	yes ^{48.1}	?	?
-pressure coefficient (only if calculated)	?	--	--	yes ^{48.2}	?	?
-temperature gradient	?	--	--	constant	uniform	uniform
Algorithm To Solve Nonlinear Set Of Equation⁰⁴						
-name of algorithm ⁰⁵	Newton	see ^{46.1}	see ^{47.1}	see ^{48.3}	N - R	N - R
-equation	?	?	?	13 B	?	?
Limits						
-max. number of zones	150	40	2	unlimited	unlimited	unlimited
-max. number of openings/zones	?	unlimited	40	unlimited	unlimited	unlimited
-max. number of shafts/corridors/floors	?	40, 40, 40	0	unlimited	unlimited	unlimited
-max. number of mechanical ventilation systems	?	1/opening	1	unlimited	unlimited	unlimited
Input						
-interactive input	?	yes	yes	yes	no	no
CAD-input	?	?	?	no	no	no
-weather data from weather files	?	yes	no	yes	yes	yes
-3-D building description	?	no	no	no	yes	yes
-schedules (e.g., occupants)	?	no	no	yes	yes	yes
Output						
-file of arrays used by the program	?	no	no	yes	yes	yes
-graphical output	?	yes	yes	yes	no	no
-statistical functions	?	no	no	no	no	no
Structure						
-separate input program	?	yes	no	yes	yes	no
-modular structure	?	?	?	yes	yes	yes
Combination With Other Models						
-combined with thermal model	?	yes	no	no	no	yes
-combined with pollution model	?	yes	no	yes	yes	no
Program Availability						
-program available to third parties	?	limited	limited	yes ^{48.4}	yes ^{49.2}	yes ^{50.2}

Notes used in Appendix A

0.1) Abbreviations used for the Computer Language:

F	Fortran
F 77	Fortran 77
MS	MicroSoft
F IV	Fortran IV
C	program language "C"
HP Basic 4.0	Hewlett Packard Basic 4.0
F V	Fortran V
dBaseIV	Data Base Language
HPL	Hewlett Packard Language
HP-Special	Hewlett Packard Special

0.2) Abbreviations used for the Computer Type:

PC	Personal Computer
M	Mainframe
WS	Workstation
VAX	Vertual Address Extension
IBM	International Business Machine

0.3) for Equations see Table 1 - 12, Appendix C

0.4) for Algorithm to Solve Nonlinear Set of Equation see Table 13, Appendix C

0.5) Abbreviations used for the Name of Algorithm to Solve Nonlinear Set of Equation:

N - R	Newton - Raphson - Method
MNR	Modified Newton - Raphson Method
Lev - Mar	Levenberg - Marquardt Method
Gauss	Gaussian Elimination
Bro - Con	Brown - Conte Method
Beta	Beta Method by Newmark
N - Steff	Newton Method with Steffensen Acceleration
Sec - Met	Secant Method

1.1) Kajima General Ventilation Calculation Program

2.1) Calculation of Infiltration

2.2) under consideration

2.3) not so useful

4.1) Passive System Simulation Program / Multiroom Version 1

4.2) not in particular

4.3) integration of 1 E or 2 D

4.4) Transformed Newton Method for the System of Nonlinear Equations using Jacobian Matrix

4.5) under the revise for new version

5.1) still under development

5.2) by Dividing Them to Horizontal Equidistant Strips

5.3) Lineare Interpolation from CPBANK

- 5.4) Internal Reference Pressure Adjusted until Flow Errors Negligible
- 5.5) Not Fully Tested
- 5.6) Optional
- 5.7) after completing and testing
- 7.1) Infiltration and Ventilation
- 8.1) AIR-Calculation
- 9.1) Numerically Derived Jacobian-Matrix is inversed and Calculated Pressure Correction Vector is multiplied by 0.5 for Avoiding Oscillation
- 9.2) only in Japanese
- 10.1) Reference Pressures adjusted until Flow Errors Negligible
- 14.1) Simultaneous Heat, Moisture And Ventilation Predicting Program Multi Rooms
- 14.2) revised Newton - Raphson Method
- 16.1) Modified - Walton (NBS) Algorithm
- 16.2) not yet
- 16.3) not yet (used at users risk)
- 17.1) Model For Fluctuating Wind Pressure
- 19.1) alternate
- 20.1) Lineare interpolation between given points
- 20.2) Method with optimized Acceleration
- 22.1) Secant and u/L - Decomposition
- 28.1) Harmonic Analysis (Reference 1) and Lagrange Interpolation (Reference 2)
- 28.2) with some restrictions
- 29.1) Fortran Program to Calculate Air Infiltration in Buildings - May 1974
- 29.2) but a second program, named CP 46, is combined with pollution model (smoke concentration)
- 30.1) its applicability is very limited
- 32.1) Iterative technique using linear approximation to set of nonlinear equations including Q and P.
- 33.1) still under development
- 33.2) treated like large openings
- 33.3) calculated by CPCALC, calculation program, see "Fundamentals of the Multizone", Air Infiltration and Ventilation Centre, Technical Note 29, May 1990
- 33.4) optimized Newton, Newton with given relaxation, Newton-Steffensen
- 36.1) It is intended that the program be compiled with the appropriate values of a few parameter statements to match the program to the problem.
- 38.1) still under development
- 38.2) still under development
- 39.1) total number of connections smaller than 200
- 40.1) The exact nonlinear equations were solved to determine the volume flow rate . The balance of in- and outflowing air was determined by iteration (variation of the neutral pressure level NPL).

- 40.2) In horizontal direction (per floor): 3 groups of rooms; outside group divided in windward and leeward flats, inner group (shafts), middle group (corridors) combine the different groups. In vertical direction: 30
- 40.3) one to each attached region
- 41.1) Simplified Air Flow Model
- 46.1) Internal reference pressure adjusted until flow errors negligible
- 47.1) Internal references pressure adjusted until flow errors negligible
- 48.1) treated like large openings
- 48.2) calculated by CPCALC, calculation program, see "Fundamentals of the Multizone", Air Infiltration and Ventilation Centre, Technical Note 29, May 1990
- 48.3) optimized Newton, Newton with given relaxation, Newton-Steffenson
- 48.4) as soon as fully debugged
- 49.1) Equation to be specified by the user
- 49.2) available at the National Institute of Standards and Technology
- 50.1) Equation to be specified by the user
- 50.2) available at the National Institute of Standards and Technology

APPENDIX B

The authors and references of the computer programs

Model - Number :	1
Author :	Shin Hayakawa Building Environmental Engineering Department Kajima Institute of Construction Technology Kajima Corporation 2-19-21 Chofu-City, Tokyo Japan
References :	1. Hayakawa, S.; Togari, S.; Hioki, M.: "Air Flow Rate Variation of HVAC caused by Stack Effect and Opening a Window"; Third International Symposium on the Use of Computers for Environmental Engineering related to Building, pp 627-636, Banff, Canada, Mai 1978
Model - Number :	2
Author :	Hitoshi Yamazaki Department of Architecture Faculty of Engineering Oita University 700, Dan-no-haru Oita-shi, 870-11 Japan
References :	--
Model - Number :	3
Author :	Mitsuhiro Udagawa Department of Architecture Kogakuin University 1-24-2, Nishi-Shinjyuku Shinjyuku-ku, Tokyo Japan, 160
References :	1. Ishida, K.-I.; Udagawa, M.: "A Practical Method for Calculation of Room Temperature Variation Considering Natural Ventilation and Radiant Heat Exchange among Room Surfaces in Multi - Room Buildings"; Transactions of the Architectural Institute of Japan, Nov. 1987 2. Ishida, K.-I.; Udagawa, M.: "Validation of the Ventilation Net Work Model for the Estimation of Room Temperatures and Heat Load of Residential Buildings with Measured Data"; Transaction of the Architectural Institute of Japan, Oct. 1988 3. Ishida, K.-I.; Udagawa, M.: "Ventilation of Simulation Program for the Estimation of Thermal Performance of Residential Houses using the Data from the Year Round Monitoring"; CLIMA 2000, 1985

Model - Number :	4
Author :	Tetsuo Hayashi Department of Thermal Energy System Interdisciplinary Graduate School of Engineering Sciences, Kyushu University 6 - 1 Kasuga-Kouen Kasuga-Shi, Fukuoka-Ken, 816 Japan
References :	1. Hayashi, T.; Urano, Y.; Watanabe, T.; Ryu, Y.: "Passive System Simulation Program "PSSP" and its Applications", Proceedings of Building Energy Simulation Conference 1985, Seattle, USA 2. Hayashi, T.; Urano, Y.; Katayama, T.; Sugai, T.; Watanabe, T.; Shiotsuki, Y.; Ryu, Y.: "Prediction of Air Distribution in Multiroom Buildings"; Proceedings of the Roomvent-87 (Air Distribution in Ventilated Space), 1987, Stockholm, Sweden
Model - Number :	5
Author :	Karoly Balazs Hungarian Institute for Building Science (eti) P.O.B. 71 XI. David F. u. 6. Budapest 1113, Hungary
References :	--
Model - Number :	6
Author :	Ian C. Ward University of Sheffield Dept. of Bldg. Science Sheffield S10 2TN United Kingdom
References :	--

Model - Number :	7,8
Author :	Marian .B. Nantka Institute of Heating, Ventilating and Air Protection Silesian Technical University Pstrowski 5, Room 23 44 100 Gliwice, Poland
References :	<ol style="list-style-type: none"> 1. "Effectiveness of Ventilation Functioning in Multi-Story Residential Houses"; (in polish; District Heating, Heating & Ventilation) No.6, pp 154, 1981 2. "A Numerical Method for Air - Change Rate of Buildings Calculated"; Recordings of the 5 th International Conference on HVAC, Czechoslovakia, Nov. 24-26, 1981 3. "Mathematical Method for Natural and Mechanical Air Flows Calculated" (in polish)
Model - Number :	9
Author :	Hiroyasu Okuyama Division of Environmental Technique Shimizu Corporation Institute of Technology 4-17-, Etchujima 3-chome, Koto-ku Tokyo, Japan
References :	<ol style="list-style-type: none"> 1. Okuyama, H. : "Theoretical Study on the Thermal Network Model in Buildings"; (Doctorate) Waseda University, Tokyo, Dec. 1987 2. Okuyama, H. : "Network Numerical Analysis Method for Heat Transfer and Airflow in Buildings"; Proceedings of 17 th Symposium by the Committee of Building Heat Transfer in Building Environment, Comitees of Architectural Institute of Japan, Aug. 1987 3. Okuyama, H. : "A Computer Modelling Method of Building Airflow Network and The Solution of Non-linear Simultaneous Equations"; Annual Meeting Proceedings of Society of Heating Air-Conditioning and Sanitary Engineers of Japan, Oct. 1989, p 729, (Japanese)
Model - Number :	10
Author :	Servando Alvarez Dominguez Dpto. de Ingenieria Energetica y Fluidomecanica Escuela Tecnica Superior de Ingenieros Industriales Avda. Reina Mercedes E-4101 Sevilla Spain
References :	--

Model - Number : 11,12

Author : Redwan Mounajer
Centre Scientifique et Technique du Batiment
Station de Recherche
84, Avenue Jean Jaures
F-77420 Marne la Vallee Decex 2
France

References : --

Model - Number : 13

Author : Johnny Kronvall
Dep. of Building Science
Lund University
P.O. Box 118
S-221 00 Lund, Sweden

References : 1. Kronvall, J.: "Air flow in Building Components"; Div of Building Technology, Lund Institute of Technology, Report TVBH - 1002, Lund, Sweden 1980

Model - Number : 14

Author : Takao Tsuchiya
Department of Architecture
Faculty of Engineering
Toyo University
2100 Kujirai
Kawagoe-Shi, Saitama
Japan

References : --

Model - Number : 15

Author : Katsumichi Nitta
Department of Architecture
Faculty of Technical Art
Kyoto Kogei Sen-i University
Kaido-machi, Gosho, Matsugasaki,
Sakyo-ku, Kyoto-shi, 606
Japan

References : --

Model - Number : 16

Author : Martin Liddament
Air Infiltration and Ventilation Centre
University of Warwick Science Park
Barclays Venture Centre
Sir William Lyons Road
Coventry CV4 7EZ
Great Britain

References : --

Model - Number : 17

Author : Takashi Sasaki
Department of Architecture
Hokkaido University
Nishi 8-chome, Kita 13-jou, Kitaku
Sapporo, 006
Japan

References :

1. Sasaki, T; Hayashi, M.; Aratani, N.: "On the Ventilating Characteristics of the Space under the fluctuating Wind Pressure" Int. Conf. Roomvent 1987, Stockholm, Session 4a, pp 1-12
2. Sasaki, T; Aratani, N.: "Study on Change from Summer - Oriented Houses to Winter - Oriented Ones and their Ventilation" Bulletin of Faculty of Engineering, Hokkaido University No. 145, pp 125-151, Dec.1988
3. Sasaki, T; et al: "Der Lueftungszustand von der Luftschicht durch die Wind-Unruhe" Trans. AIJ (Architectural Institute of Japan) No. 372, Feb. 1987

Model - Number : 18

Author : Hiroshi Matsumoto
Toyohashi University of Technology
Department of Regional Planning
Tempakucho
Toyohashi-shi, 440
Japan

References :

1. Matsumoto, H.; Nagatomo, M.; Yoshino, H.: " A Calculating Method for Predicting Air Pollution in Multi-celled Buildings"; Meeting of Tohoku branch of AIJ, 33-36, 1988 (in japanese)

Model - Number : 19

Author : George Walton
National Institute of Standards and Technology
BR/A 313
Washington D.C. 20234
United States of Amerika

References : 1. "AIRNET - a Computer-Program for Building Airflow Network Modeling";
National Institute of Standards Interagency Report NISIR 89-4072
2. Walton, G.N.: "Airflow Network Models for Element - Based Building Airflow
Modeling"; ASHRAE Transactions, 1989.

Model - Number : 20

Author : Magnus Herrlin
Lawrence Berkeley Lab
Bldg. 90, Rm. 3074
Berkeley, CA 94720
USA

References : 1. Herrlin, M.K.: "MOVECOMP : A Multizone Infiltration and Ventilation Simu-
lation Program"; Air Infiltration Review, Volume 9, No. 3, May 1988

Model - Number : 21

Author : Yasuo Utsumi
Miyagi National College of Technology
48 Nodayama, Shiote, Medeshima
Natori 981-12
Japan

References : --

Model - Number : 22

Author : W. de Gids
TNO Division of Technology for Society

P.O. Box 217
2600 AE Delft
Netherlands

References : --

Model - Number : 23

Author : B. Spruit
ISSO - Netherlands
Institute for Study and Promotion of Research in the Field of Building Services
Postbus 20740
3001 JA Rotterdam
Netherlands

References : 1. "ISSO - 4" (to be published)
2. Liddament, M.: "Air Infiltration Calculation Techniques - An Application Guide"; Air Infiltration and Ventilation Centre, June 1986

Model - Number : 24

Author : F. Allard; J.J. Roux; D. Caccavelli
Laboratoire Equipement de l'Habitat
Centre de Thermique - URA CNRS 1372
INSA de Lyon
Batiment 307
F-69621 Villeurbanne Cedex
France

- References :
1. Caccavelli, D.; Roux, J.J.; Roldan, A.: "Infiltration, Air Flow Distribution and Micro - Computation Roomvent 87, "Air Distribution in Ventilated Spaces"; Session 4a, Stockholm 10/12 1987
 2. Caccavelli, D.; Roux, J.J.; Allard, F.: "Transferts aerauliques dans les batiments"; presentation de deux niveaux d'approche ; Journee d'Etude de la Societe Francaise des Thermiciens, Etat des connaissances sur la ventilation, Paris 26 Nov. 87
 3. Caccavelli, D.; Roux, J.J.; Allard, F.: "A Simplified Approach of Air Infiltration in Multizone Buildings"; 9th Air Infiltration and Ventilation Centre - Conference, Gent, Belgium, Vol 2 Sept. 1988
 4. Caccavelli, D.; Roux, J.J.; Allard, F. : "Modelisation du comportement thermique des batiments multizones"; Adaptation a un processus de conception, These de Doctorat INSA de Lyon Nov. 88, 473 p

Model - Number : 25

Author : F. Allard; G. Achard; A. Roldan
Laboratoire Equipement de l'Habitat
Centre de Thermique - URA CNRS 1372
INSA de Lyon
Batiment 307
F-69621 Villeurbanne Cedex
France

- References :
1. Roldan, A.; Achard, G.; Allard, F.: "Influence des infiltrations et des transferts aeraulique entre pieces sur la charge thermique d'un batiment multizone"; Third International Congress on Building Energy Management, ICBEM 87, Lausanne Sept. 87, pp 178-185
 2. Roldan, A.: "Etude thermique et aeraulique des envelopps de batiment". Influence des couplages interieurs et du multizonage; These de Doctorat INSA de Lyon, Dec. 1985, 310 p

Model- Number : 26

Author : H. Esdorn; H.E. Feustel; J. Guo
Hermann-Rietschel-Institut
Technische Universitaet Berlin
Marchstrasse 4
D-1000 Berlin 10
Federal Republic of Germany

References : 1. Feustel, H.: "Beitrag zur theoretischen Beschreibung der Druck- und Luftmassenstromverteilung in natuerlichen und maschinell geluefteten Gebaeuden"; Dissertation Technische Universitaet Berlin, 1983, VDI-Fortschrittsberichte, Reihe 6, Nr. 151, VDI-Verlag, Duesseldorf

2. Guo, J. : "Weiterentwicklung des Programms gemaess 1) und 2) mit dem Ergebnis einer Beruecksichtigung thermischer Druckdifferenzen auch innerhalb eines Geschosses und einer spuerbaren Verringerung der Rechenzeiten"; Interner Institutsbericht

Model - Number : 27

Author : P. J. Jackman
Building Services Research
and Information Association
Old Bracknell Lane West
Bracknell, Berkshire RG12 4AH
United Kingdom

References : 1. Jackman, P.J.: "Heat Loss in Buildings as a Result of Infiltration"; BSE; Vol 42 (1974), pp 6-15

2. Jackman, P.J.: "A Study of the Natural Ventilation of tall Office Buildings"; JIHVE, Vol 38 (1970), pp 103-118

Model - Number : 28

Author : Claudio Melo
Departamento de Engenharia Mecanica
Universidade Federal de Santa Catarina
CX. Postal 476
88.049 Florianopolis - SC
Brazil

References : 1. Allen, C.: "Wind Pressure Data Requirements for Air Infiltration Calculation"
Air Infiltration and Ventilation Centre, Technical Note 13, Bracknell, UK, 1984
2. Bowen, A.J.: "A Wind Tunnel Investigation using Simple Building Models to
Obtain Mean Surface Wind Pressure Coefficient for Air Infiltration Estimates";
National Aeronautical Establishment Report LTR LA 209, NRCC, Canada, 1976

Model - Number : 29

Author : Daniel M. Sander
National Research Council Canada
Institute for Research in Construction
Building M 24, Montral Road
Ottawa, Ontario
Canada K1A0R6

References : --

Model - Number : 30

Author : Krzysztof Klobut
Helsinki University of Technology
Faculty of Mechanical Engineering
Otakaari 4
SF - 02150 ESPOO
Finland

References : --

Model - Number : 31

Author : P. Dalicieux
Departement Applications de l'Electricite
77250 Moret sur Loing
France

References : --

Model - Number : 32

Author : Peter Warren
Building Research Establishment
Bucknalls Lane
Garston, Watford WD2 7JR
United Kingdom

References : 1. Evers, E.; Waterhouse, A.: "A Computer Model for Analysing Smoke Movement in Buildings"; Building Research Establishment CP 69/78 (1978)

Model - Number : 33

Author : Viktor Dorer
EMPA ABT 176
CH-8600 Duebendorf
Switzerland

References : --

Model - Number : 34

Author : J. Gabrielsson
Ekono Association for Power and Fuel Economy
P.O. Box 27
00131 Helsinki 13
Finland

References : 1. Gabrielsson, J.; Porra, P.: "Calculation of Infiltration and Transmission Heat Loss in Residential Buildings by Digital Computers" JIHVE, Vol 35 (1968), pp 357-368

Model - Number : 35

Author : C. Y. Shaw
Institute for Research in Construction
National Research Council
Bldg. M-24, IRC, NRC, Montreal Road
Ottawa, Canada K1A OR6

- References :
1. Sander, D.M.; Tamura, G.T.: "FORTRAN IV Program to Simulate Air Movements in Multi-Storey Buildings"; DBR Computer Program No. 35, National Research Council of Canada, (1974).
 2. Sander, D.M.: "FORTRAN IV Program to Calculate Air Infiltration in Buildings"; DBR Computer Program No. 37, National Research Council of Canada (1974).
 3. Shaw, C.Y.; Sander, D.M.; Tamura, G.T.: "A FORTRAN IV Program to Simulate Stair-Shaft Pressurization Systems in Multi-Storey Buildings"; DBR Computer Program No. 38, National Research Council of Canada (1974)

Model - Number : 36

Author : George Walton
National Bureau of Standards
BR/B 114
Washington D.C. 20234
United States of Amerika

- References :
1. Walton, G.N.: "Thermal Analysis Research Program" Reference Manual NBSIR 83-2655, U.S. Department of Commerce, (1983)

Model - Number : 37

Author : Stephen Irving
Oscar Faber Consulting Engineers
Marlborough House
Upper Marlborough Road
St. Albans
Herts, AL1 3UT, Great Britain

- References :
1. Irving, S.J.; Wilson, A.P.: "Validation of a Smoke Movement Program"; Building Engineering Research & Technology, Vol 2 (1984), No. 4, pp 151-159
 2. Irving, S.J.: "The Computer Simulation of Smoke Movement during Building Fires"; Fire Prevention Science and Technology, No. 22, (1979), pp 3-8

<p>Model Number : 38</p> <p>Author : Mike Holmes Arup Research & Development 13 Fitzroy Street London W1P 6BO England</p> <p>References : 1. Holmes, M. J.: "Design for Ventilation", 6th Air Infiltration and Ventilation Centre - Conference, September 16-19, 1985, Netherlands</p> <p>2. Holmes, M. J.; Salusbury, T.: "Ventilation Design for a Bus Station", 9th Air Infiltration and Ventilation Centre - Conference held at Novotel Hotel, Gent, Belgium, 12-15 September 1988</p>
<p>Model - Number : 39</p> <p>Author : W. de Gids TNO Division of Technology for Society P.O. Box 217 2600 AE Delft Netherlands</p> <p>References : 1. deGids, W.F.: "Calculation Method for the Natural Ventilation of Buildings"; Publication No. 632 of the TNO Research Institut for Environmental Hygiene, Delft, (1977)</p>
<p>Model - Number : 40</p> <p>Author : W. Brinkmann Bundesbaudirektion Berlin Fasanenstrasse 87 D - 1000 Berlin 12 Federal Republic of Germany</p> <p>References : 1. Brinkmann, W.: "Zur Bestimmung des Lueftungswaermebedarfs hoher Gebaeude"; Dissertation, Technische Universitaet Berlin, 1980</p>

Model - Number : 41

Author : Helmut E. Feustel
Lawrence Berkeley Laboratory
Building 90, Room 3074
1 Cyclotron Rd
Berkeley, California 94720
USA

References : 1. Feustel, H.E.; Sherman, M.: "A Simplified Model for Predicting Air Flow in Multizone Structures" Energy and Buildings, Vol. 13, 1989, pp 217-230

Model - Number : 42

Author : G. Hausladen
Schiedel GmbH & Co
Lerchenstr. 9
Postfach 50 05 65
D - Munich 50
Federal Republik of Germany

References : 1. Hausladen, G.: "Wohnungslueftung, Untersuchung der verschiedenen Lueftung-arten bzw. Lueftungspraktiken unter hygienischen, bauphysikalischen und energetischen Gesichtspunkten"; Dissertation Technische Universitaet Muenchen, 1980, Fortschrittsberichte der VDI Zeitschriften, Reihe 6, Nr. 73

2. Hausladen, G.: "Luftwechsel in Wohnungen"; Heizung, Lueftung Haustechnik, 1978, Nr.1, pp 21-28

3. Krueger, W.; Hausladen, G.: "Einfluss von Wind- und thermischen Kraefte auf das Betriebsverhalten von mechanisch betriebenen Entlueftungsanlagen in mehrgeschossigen Wohngebaeuden"; Forschungsbericht fuer Haustechnik, Technische Universitaet Muenchen, 1979

Model - Number : 43

Author : J. P. Cockroft
Building Services Research Unit
University of Glasgow
3 Lillybank Gardens
Glasgow G12 8RZ
United Kingdom

References : 1. Cockroft, J.P.: "Air Flows in Buildings"; Proceedings of the Environment Inside Buildings Symposium, Southend on Sea, 1979
2. Cockroft, J.P.: "Validation of Buildings and Systems Energy Prediction using Real Measurements"; Computer Aided Design, Vol 14, 1982, No. 1, pp 39-43

Model - Number : 44

Author : R. E. Billsborrow
Department of Building Science
Faculty of the Architectural Studies
University of Sheffield
Sheffield S10 2TN
United Kingdom

References : 1. Billsborrow, R.E.: "Digital Analogue for Natural Ventilation Calculations"; Report No 6, Department of Buildings Science, University of Sheffield, 1973
2. Pitts, A.C.; Wards, I.C.: "A Review of the Prediction and Investigation of Air Movement in Buildings"; Report No BS 69, Department of Buildings Science, University of Sheffield, 1983

Model - Number :	45
Author :	S. Swetlov Soviet Union
References :	1. Swetlov, K.S.: "Calculations of Air Infiltration in Multi-Story Buildings using Electronic Computers"; Vodosnabize i Sanitarna Tekhnika, Vol 11, 1966, HVRA-Translation 122
Model - Number :	46, 47
Author :	D. W. Etheridge British Gas plc Watson House Peterborough Road London SW6 3HN United Kingdom
References :	1. Etheridge, D.W.; Alexander, D.K.: "The British Gas Multi Cell Model for Calculating Ventilation"; ASHRAE-Transactions, Vol 86, 1980, Part II, pp 808-821 2. Etheridge, D.W.: "Crack Flow Equations and Scale Effect"; Building and Environment, Vol 12, 1977, pp 181-189 3. Etheridge, D.W.; Nolan, J.A.: "Ventilation Measurements at Model Scale in a Turbulent Flow"; Building and Environment, Vol 14, 1979, pp 53-64
Reference for VENT 2 :	1. Etheridge, D.W.; Gale, R.: "Theoretical and Experimental Techniques for Ventilation Research in Buildings"; International Gas Conference, Paper C 18-33, London, June 1983.

Model - Number : 48

Authors :

Francis Allard
Laboratoire Equipment de'l Habitat
Centre de Thermique
INSA de Lyon
Batiment 307
F-69621 Villeurbanne Cedex,
France

Victor Dorer
EMPA ABT 175
CH-8600 Duebendorf
Switzerland

Helmut E. Feustel
Lawrence Berkeley Laboratory
Building 90, Room 3074
Berkeley, CA 94720, USA

Liu Mingsheng
Mechanical Engineering Department
Texas A&M University
College Station, TX 77840, USA

Eduardo Rodrigues Garcia
Dpt. Ingenieria Energetica y
Fluido Mecanica
Escuela Superior de Ingenieros
Industriales
Avda. Reina Mercedes S/N
E-Sevilla, Spain

Hiroshi Yoshino
Dept. of Architecture
Faculty of Engineering
Tohoku University
Sendai, 980
Japan

Mario Grosso
Dipartimento di Scienze e Tecniche
Per i Processi di Insediamento
Politecnico Di Torino
Viale Mattioli 39
I-10125 Torino, Italy

Hans C. Phaff
MT-TNO
POB 217
2600 AE Delft
Netherlands

Magnus Herrlin
Division for Building Services Engineering
Royal Institute of Technology
S-10044 Stockholm
Sweden

Yasuo Utsumi
Department of Architecture
Miyagi National College of Technology
Medeshima, Natori, Miyagi
Japan

References :

1. Feustel, H. E.; Raynor-Hoosen, A. (Editors): "Fundamentals of the Multizone Air Flow Model - COMIS", Air Infiltration and Ventilation Centre, Tech. Note TN 29, May 1990, Coventry, UK

Model - Number : 49, 50

Author : James Axley
Bldg. Technical Program
3 - 437
Mass. Institute of Technology
77 Mass. Ave
Cambridge, MA 02139
USA

- References :
1. Axley, J.; Grot, R.: "The Coupled Air Flow and Thermal Analysis Problem in Building Airflow System Simulation", ASHRAE Symposium on Calculation of Interzonal Heat and Mass Transport in Buildings, Vol. 95, Pt. 2: 1989.
 2. Axley, J.; Grot, R.: "Coupled Airflow and Thermal Analysis for Building System Simulation by Element Assembly Techniques", Room Vent '90: Engineering Aero- and Thermodynamics of Ventilated Rooms (Submitted for publication 1/29/90): 1990.
 3. Grot, R.: "Users Manual - -NBSAVIS - CONTAM88", National Institute of Standards and Technology, 1990.
 4. Walton, G.: "AIRNET - A Computer Programm for Building Airflow Network Modeling", NISTR 89-4072, National Institute of Standards and Technology, 1988.

APPENDIX C

Equations used in the computer programs

Nomenclature see Table 14

TABLE 1: Equations used for flow through cracks

1 A) $F = D \Delta P^n$

1 B) $Q = D \Delta P^n$

1 C) $\frac{Q}{3600} = \frac{D}{3600} \Delta P^{1/n}$

1 D) $\Delta P = a Q^2 + b Q$

1 E) $Q = C L \Delta P^n$

1 F) $F = K \Delta P^x$

1 G) $Q = C A \Delta P^n$

1 H) $\Delta P = \left(\frac{Q}{K L} \right)^n$

1 I) $\Delta P = 0.5 L \rho Q^2$

1 J) $\Delta p = a F + b F^2$

1 K) $\Delta p = \zeta \frac{\rho}{2} \left(\frac{Q}{A} \right)^n$

1 L) $F = \rho D \Delta p^n$ with $n = \frac{2}{3}$

1 M) $Q = K \Delta p^n$

TABLE 2: Equations used for flow through large openings

2 A) $F = D \Delta P^n$

2 B) $Q = D \Delta P^n$

2 C) $\frac{Q}{3600} = \frac{D}{3600} \Delta P^{1/n}$

2 D) $Q = A C \left(\frac{2 \Delta P}{\rho} \right)^{1/2}$

2 E) $F = K \Delta P^x$

2 F) $Q = A (2 \Delta P)^{1/n} \sqrt{(1/\rho)}$

2 G) $\Delta P = S Q^2$

2 H) $\Delta p = a F + b F^2$

2 I) $\Delta p = \zeta \frac{\rho}{2} \left(\frac{Q}{A} \right)^n$

2 J) $F = \rho D \Delta p^n$; with $n = \frac{2}{3}$

2 K) $Q = K \Delta p^n$

2 L) $F = \frac{2}{3} w C_d \Theta \sqrt{\rho [2 g (\rho_1 - \rho_2) - b_t]} \left| H - Z_n \right|^{\frac{3}{2}}$

TABLE 3: Equations used for flow through duct work

$$3 A) \quad Q = C A \left[P_r - \rho_f g \left(H_r - H_f + \frac{H_i}{2} - H_s \right) - P_i + \rho_i g \left(H_s - \frac{H_i}{2} \right) \right]^n$$

$$3 B) \quad Q = A \left(\frac{2}{\rho} \right)^{1/2} \sum_{i=1}^m \left(\frac{1}{k} \right)_i^{1/2} \Delta p^{1/2}$$

$$3 C) \quad P - \frac{\rho}{2} v^2 (1 + \Sigma \zeta) + \Delta P_{vE} - P_D = 0$$

$$3 D) \quad \Delta P = \left[K + \frac{f_L}{D} \right] \frac{g}{H^2 D^4 \rho} Q^2$$

$$3 E) \quad Q = A_{NET} (2 \Delta P)^{1/n} \left(\frac{1}{\rho} \right)^{1/2} \left(\frac{\lambda L}{d} + \Sigma \zeta \right)$$

$$3 F) \quad F = \frac{\left(\frac{2 \rho A^2}{f L/D + \Sigma C_0^2} \right)^{1/2}}{\Delta p}$$

$$3 G) \quad Q = A \left(\frac{2 \Delta p}{\rho \zeta} \right)^{(1/n)}$$

$$3 H) \quad \Delta p = \zeta \frac{1}{2} \rho v^2$$

$$\text{and : } \Delta p = \frac{\lambda L}{d} \frac{1}{2} \rho v^2$$

$$3 I) \quad F = A \left(\frac{2 \rho \Delta p_K}{\left(\frac{\lambda L}{d} \right) + \Sigma \zeta} \right)^{(1/2)}$$

$$3 J) \quad \Delta p = C Q^2$$

TABLE 4: Equations used for fan flow characteristics

- 4 A) $Q = K_1 + K_2 \Delta P + K_3 \Delta P^2$
 4 B) $\Delta P = K_1 + K_2 Q + K_3 Q^2$
 4 C) $\Delta P = \Delta P_o - K_1 Q - K_2 Q^2$
 4 D) $\Delta P = B n^2 D^2 + \frac{Q^2}{A^2 D^4}$
 4 E) $\Delta P = f(Q_v)$
 4 F) $\Delta p = K_0 + K_1 F + K_2 F^2 + K_3 F^3$
 4 G) $\Delta p_t = K_1 + K_2 Q + K_3 Q^2 + K_4 Q^3$
 4 H) $\Delta p = C_1 - (C_2 Q^2)$

TABLE 5: Equations used for wind pressure

- 5 A) $\Delta P = \frac{\rho}{2} v^2$
 5 B) $\Delta P = C \frac{\rho_o}{2} v^2$
 5 C) $\Delta P = C \frac{\rho}{2} v_o^2$
 5 D) $\Delta P = C \frac{\rho}{2} v H^2$
 5 E) $\Delta P = \frac{\rho}{2} v^2$
 with: $v = v_o 2334 [1 + 2.8 \log (H + 4.75)]$
 5 F) $\Delta p = K v^2 c_p$; with : c_p are input
 5 G) $p_{wind} = c_p \frac{1}{2} \rho v^2$
 5 H) $\Delta p = c_p \Delta p_{dyn}$

TABLE 6: Equations used for thermal buoyancy

- 6 A) $\Delta P = \rho g \Delta H$
- 6 B) $\Delta P = (\rho_o - \rho_i) g (H - H_o)$
- 6 C) $\Delta P = 3462 (H - H_o) \left(\frac{1}{T_o} - \frac{1}{T_i} \right)$
- 6 D) $\Delta P = (\rho_o - \rho_i) g H$
- 6 E) $\Delta P = (\rho_o - \rho_i) g H (X - 0.5 - N/2) b + c$
- 6 F) $Q = (C_D A/n) \left(\Delta \Theta g \frac{H}{\Theta} \right)^{1/2}$
- 6 G) $\Delta P = \rho_o \left(\frac{T_i - T_o}{T_i T_o} \right) T_o g H$
- 6 H) $\Delta p = \rho g 273 (h - h_o) \left(\frac{1}{T_o} - \frac{1}{T_i} \right)$
- 6 I) $\Delta p_z = \Delta \rho g z$
- 6 J) $\Delta p = (p_i - \rho_i g h_i) - (p_j - \rho_j g h_j)$
- 6 K) $\Delta p = \Delta \rho g \Delta H$

TABLE 7: Equations used for outside pressure fluctuations

- 7 A) $(\Delta \bar{P}^2)^{0.5} = 0.5 (\bar{P}_o^2)^{0.5}$
- 7 B) $Q_v = 1/2 A_{NET} (0.001 v^2 + 0.0035 H \Delta T + 0.01)^{1/2}$

TABLE 8: Equations used for circulation flow on large openings

- 8 A) $Q_x = C_d A_x \left(\frac{2}{\rho} \Delta p \right)^{0.5}$
- 8 B) $Q = K \Delta p^{0.5}$; with : $\Delta p = \Delta \rho g h$
- 8 C) $\Delta F = F_{O,ZN} - F_{ZN,H}$

TABLE 9: Equations used for single sided ventilation

no equations were specified

TABLE 10: Equations used for cross ventilation

10 A) $Q = K \Delta p^{0.67}$

TABLE 11: Equations used for pressure coefficient

11 A) $c_p = 0.75 - 1.05 \frac{Q}{90}$ if $Q \leq 90^\circ$

$c_p = -0.45 + 0.15 \frac{Q}{90}$ if $Q > 90^\circ$

$\implies \Delta p_{wind} = \frac{1}{2} \rho c_p v^2$

11 B) $c_w = 0.75$ if $b = 0 - 30^\circ$

$c_w = -0.01667 b + 1.25$ if $b = 30 - 75^\circ$

$c_w = -0.02667 b + 2.0$ if $b = 75 - 90^\circ$

$c_w = -0.4$ if $b = 90 - 180^\circ$

11 C) $c_{p_{wind}} = 1$ $c_{p_{lee}} = -0.3$

TABLE 12: Equations used for temperature gradient

12 A) $Q = \int_{H_1}^{H_2} D \Delta p \left| \Delta p \right|^{\frac{1}{n} - 1}$

12 B) $\frac{dp}{dz} = - \frac{g p_0 273}{w_z + T_{z0}}$

12 C) $p = \frac{p_{ref}}{R (T_{ref} - \lambda_t H)}$

and: $dp = - \rho g dH$

12 D) $T_z = a z + T_{z0}$

and: $p_z = g \int_0^h p(z) dz$

LAWRENCE BERKELEY LABORATORY
UNIVERSITY OF CALIFORNIA
INFORMATION RESOURCES DEPARTMENT
BERKELEY, CALIFORNIA 94720