

UC Davis

UC Davis Previously Published Works

Title

Performance Evaluation of Phenol-Resin-Based Adsorbents for Heat Transformation Applications.

Permalink

<https://escholarship.org/uc/item/5vn4z7p0>

Journal

Materials, 16(15)

ISSN

1996-1944

Authors

Asfahan, Hafiz
Sultan, Muhammad
Farooq, Muhammad
et al.

Publication Date

2023-07-26






DOI

10.3390/ma16155262

Peer reviewed

Article

Performance Evaluation of Phenol-Resin-Based Adsorbents for Heat Transformation Applications

Hafiz M. Asfahan ^{1,†}, Muhammad Sultan ^{1,*,†}, Muhammad Farooq ², Fahid Riaz ^{3,*}, Sobhy M. Ibrahim ⁴, Md Shamim Ahamed ⁵ and Muhammad Imran ⁶

¹ Department of Agricultural Engineering, Bahauddin Zakariya University, Multan 60800, Pakistan; hmasfahan@gmail.com

² Department of Mechanical Engineering, University of Engineering and Technology, Lahore 39161, Pakistan; engr.farooq@uet.edu.pk

³ Mechanical Engineering Department, Abu Dhabi University, Abu Dhabi P.O. Box 59911, United Arab Emirates

⁴ Department of Biochemistry, College of Science, King Saud University, P.O. Box 2455, Riyadh 11451, Saudi Arabia; syakout@ksu.edu.sa

⁵ Department of Biological and Agricultural Engineering, University of California, Davis, CA 95616, USA; mahamed@ucdavis.edu

⁶ Department of Mechanical, Biomedical and Design Engineering, College of Engineering and Physical Sciences, Aston University, Birmingham B4 7ET, UK; m.imran12@aston.ac.uk

* Correspondence: muhammadsultan@bzu.edu.pk (M.S.); fahid.riaz@adu.ac.ae (F.R.)

† These authors contributed equally to this work.

Abstract: Phenol resins (PRs) are considered as relatively inexpensive adsorbents synthesized from agricultural biomass via employing a variety of synthesized procedures. The performance of PR for heat transformation application is not widely investigated. In this regard, the present study aims to evaluate the four PR derivative/refrigerant pairs, namely (i) KOH6-PR/CO₂, (ii) SAC-2/HFC, (iii) KOH4-PR/ethanol, and (iv) KOH6-PR/ethanol, for adsorption cooling and adsorption heating applications. Ideal cycle analyses and/or thermodynamic modelling approaches were utilized comprising governing heat and mass balance equations and adsorption equilibrium models. The performance of the AHP system is explored by means of specific cooling energy (SCE), specific heating energy (SHE), and coefficient of performance (COP), both for cooling and heating applications, respectively. It has been realized that KOH6-PR/ethanol could produce a maximum SCE of 1080 kJ/kg/cycle and SHE of 2141 kJ/kg/cycle at a regeneration temperature (T_{reg}) and condenser temperature (T_{cond}) of 80 °C, and 10 °C, respectively, followed by KOH4-PR/ethanol, SAC-2/HFC-32, and KOH6-PR/CO₂. The maximum COP values were estimated to be 1.78 for heating and 0.80 for cooling applications, respectively, at $T_{reg} = 80$ °C and $T_{cond} = 10$ °C. In addition, the study reveals that, corresponding to increase/decrease in condenser/evaporator pressure, both SCE and SHE decrease/increase, respectively; however, this varies in magnitude due to adsorption equilibrium of the studied PR derivative/refrigerant pairs.

Keywords: phenol resins; ideal cycle; specific cooling energy; specific heating energy



Citation: Asfahan, H.M.; Sultan, M.; Farooq, M.; Riaz, F.; Ibrahim, S.M.; Ahamed, M.S.; Imran, M. Performance Evaluation of Phenol-Resin-Based Adsorbents for Heat Transformation Applications. *Materials* **2023**, *16*, 5262. <https://doi.org/10.3390/ma16155262>

Academic Editor: Georgios C. Psarras

Received: 15 May 2023

Revised: 17 July 2023

Accepted: 21 July 2023

Published: 26 July 2023



Copyright: © 2023 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

Research activities are shifting toward the development of energy-efficient solid sorption, namely adsorption heat pump (AHP) systems, which are acknowledged as a credible route for minimizing the exponential growth in energy demand in the air conditioning (AC) sector. Mechanical vapor compression (MVC) AC systems have a high coefficient of performance (COP) ranging between 3.0 and 5.0, consequently indicating their wide implementation as a convenient commercialized cooling/heating system [1,2]. However, environmental consequences aligned with the MVC-AC system include high global warming potential, emission of harmful greenhouse gasses, destruction of the ozone layer, and prominently alleviating the paucity of natural fossil fuel reserves [3]. On the other hand,

radiative cooling technology that utilizes the principles of thermal radiation to achieve cooling without the need for mechanical compression holds great promise [4]. However, radiative cooling requires clear sky conditions and the need for direct exposure to the sky for effective heat dissipation [4]. The AHP system scavenges discarded low-grade waste heat, abundantly available in the surrounding environment, as a prime mover, thereby contributing its share to mitigating the environmental pollution [1,5].

At the very core of an AHP system, the adsorbent is considered as the vital driving entity that directly influences the performance of the AHP system [6,7]. The adsorbent material captures the refrigerant vapors based on their active free sites, surface area, pore volume, and even on the refrigerant flow patterns [8]. The possible choice for the AHP system is an adsorbent material having hygroscopic characteristics [9,10]. In this regard, various adsorbents belonging to different classes were investigated in the past [11,12]. For instance, silica gels (SGs) are a commonly employed adsorbent class in the AHP system. Typically, the surface area of SG ranges between 586.0 and 863.6 m²/g, having a pore volume of 0.41–0.489 cm³/g [13,14]. The studies relevant to SG/water pair are presented here for completeness. The potential of an SG/water pair for adsorption cooling (AC) was explored and it was found that specific cooling energy (SCE) of 176 W/kg was measured at 80 °C regeneration temperature (T_{reg}) with the COP of 0.45 [15]. Similarly, an experimental facility of adsorption chiller is developed in the literature comprising an SG/water pair [16]. The SCE and COP were recorded to be 104.60 W/kg and 0.39, respectively, at 80 °C of T_{reg} . Peter et al. [17] mathematically investigated the performance of an SG/water pair by configuring four adsorption beds. It was reported that an SCE of 15.0 R-ton/ton could be produced. Wang et al., [18] developed a lumped numerical model, which reported that an SCE of 5.0 R-ton/ton at 85 °C T_{reg} can be obtained from an SG/water pair. In the same manner, for adsorption heating (AH), J. Pinheiro et al. [19] realized a specific heating energy (SHE) of 802 J/kg with a COP of 1.02 by employing an SG/water pair.

Activated carbons (AC) are another adsorbent class highly investigated in communication with different refrigerants [20]. Zhao et al. [21] studied the AC/methanol combination and observed a COP of 0.11 at 110 °C T_{reg} . Another study reveals that the AC/methanol pair produced an SCE of 16 W/kg and entailed a COP of 0.125 when T_{reg} was set at 120 °C [22]. El-Sharkawy et al. [23] experimented with methanol adsorption on Maxsorb III and performed isotherm modeling using the Dubinin–Raduskevich (D–R) model. Additionally, a thermodynamic model was utilized to explore the cooling potentials obtained from Maxsorb III/methanol pairs. The results showed that an SCE of 448.0 W/kg with a COP of 0.77 could be obtained; however, if compared with the activated charcoal/methanol pair, the SCE recorded 731 W/kg at $T_{reg} = 90$ °C and $T_{evap} = 7$ °C. If T_{evap} reduces to -5 °C, the SCE and COP are significantly decreased. Similarly, the performance of AC/ethanol is also reported for the AC system. For instance, it has been reported that Maxsorb-III/ethanol can produce 420 kJ/kg SCE at an T_{evap} of 7 °C and T_{reg} 80 °C [24]. One can refer to the cited articles for exploring the performance of activated carbon/ethanol pairs [25–27]. The AC/ammonia pair was also investigated for the AC system. For instance, a laboratory-scale refrigerator was developed, operating at T_{evap} of -1 °C. Similarly, a simple test rig was developed, driving with hot and cold airstreams for desorption and adsorption of ammonia from the AC [28]. It was identified that the system is capable of producing an SCE of 400 W/kg with COP 0.85.

Metal–organic frameworks (MOFs) are the emerging adsorbent class highly investigated for AHP systems due to their tremendous tunable porous structure, high surface area, and adsorption uptake. For instance, CPO-27(Ni) has a surface area of 1113–1337 m²/g with a pore volume of 0.39–0.54 cm³/g [29,30] when investigated for the AC system, and the SCE of 216 R-ton/ton was recorded [31]. MIL-101 has a surface area of 4000 m²/g [32] with a pore volume of 1.51 cm³/g [33] and can produce an SCE of 89.7 R-ton/ton [34]. Similarly, aluminum fumarate can produce an SCE of 185 W/kg at $T_{reg} = 80$ °C [35]. Adsorption of other refrigerants, such as CO₂ adsorption on MOFs, is also investigated in the literature [36,37]. However, the MOFs are expensive, have complex synthesis procedures,

deterioration over time, and low hydro-thermal stability, hindering their wider implementation. Significant research efforts are directed towards the advancement of MOFs, with a particular focus on enhancing their adsorption capabilities and optimizing their thermophysical properties [38,39]. A low-cost sustainable adsorbent is principally required to develop an energy-efficient AHP system.

Phenol resin (PR) is another adsorbent class manufactured from agriculture biomass for various heat transformation applications. El-Sharkawy et al. [40] developed two PR derivatives activated with potassium hydroxide (KOH), namely KOH4-PR and KOH6-PR, in communication with ethanol as a refrigerant from the perspective of developing a next-generation AC system. In this regard, the isothermal characterization was performed using thermogravimetric analysis. In addition, adsorption isotherm modeling was performed using a Dubinin–Astakhov (D–A) model. The results indicated that the KOH6-PR is capable of uptake of 2 kg of ethanol per kg of KOH6-PR and 1.43 kg of ethanol per kg of KOH4-PR. Uddin et al. [41] investigated CO₂ adsorption on KOH6-PR. The results reveal that the KOH6-PR ethanol can uptake 1.69 kg of CO₂ per kg of KOH6-PR. Sultan et al. [42] investigated the adsorption of HFC-32 on spherical activated carbon (SAC-2) and reported uptake of 2.34 kg/kg. These PR derivative/refrigerant pairs could outperform if employed in the AHP system due to their porosity and adsorption potentials.

In this realm, the present study aims to investigate the performance of four kinds of phenol resin (PR) derivative/refrigerant pairs abbreviated as (i) KOH6-PR/CO₂, (ii) SAC-2/HFC-32, (iii) KOH4-PR/ethanol, and KOH6-PR/ethanol for an AHP system that mutually exhibited adsorption cooling and adsorption heating applications. To the best of the author's knowledge, the selected PR derivative/refrigerant pairs have not been investigated for twin applications. The thermophysical properties and fitting constants of the adsorption isotherm model for the selected PR derivative/refrigerant pairs are available via [40–42] and utilized accordingly in the present research. A steady-state thermodynamic modeling scheme is utilized comprising the Dubinin–Astakhov model, and the system's governing heat and mass balance equations are widely accessible and often employed in the literature [43,44]. The key performance indicators of the AHP system, including specific cooling energy (SCE), specific heating energy (SHE), and COP, are evaluated at steady-state conditions. Furthermore, the study also performs a sensitivity analysis in order to explore the effect of regeneration temperature (T_{reg}), adsorption temperature (T_{ads}), condenser pressure (P_{cond}), and evaporator pressures (P_{evap}) on the studied key performance indicators of the AHP system. Overall, the study contributes positively regarding the selection of the potential PR derivative/refrigerant pair for the AHP system.

2. Adsorption Heat Pump (AHP)

The working of AHP follows a close cyclic configuration, employing well-known thermodynamic processes, i.e., adsorption, isosteric heating, regeneration, and isosteric cooling, respectively. Generally, the AHP system contains an expansion valve, heating/cooling water baths, and four cylinders retrofitted with heat exchangers. Two cylinders within the AHP device are packed with porous adsorbent material, while the remaining two cylinders serve as an evaporator and condenser, respectively. Indeed, the performance of the AHP system relies heavily on the type of adsorbent material, associated adsorption equilibrium, as well as thermophysical properties. The working schematic and ideal cycle of the AHP system are showcased in Figure 1 (left) and (right), respectively. The thermodynamic processes are accomplished in the cylinders packed with the porous adsorbent material; however, they have been controlled/regulated with the externally connected heating/cooling water baths in order to maintain the required thermal fronts. For instance, to facilitate the adsorption process, a cooling bath is connected from the perspective of harnessing adsorption heat released during the process, thereby augmenting the overall adsorption capacity. During the adsorption process, the refrigerant undergoes a transition from liquid to vapor within the evaporator via utilizing surrounding heat. Subsequently, the vapor is effectively trapped within the pore spaces of the adsorbent material, facilitated

by the establishment of Van der Waals forces of interaction and driven by significant affinity between the refrigerant and the adsorbent. As the adsorption process is performed at constant evaporator pressure, it is thereby termed as isobaric adsorption. Similarly, for enabling the desorption process, an external heating source is required (i.e., heating bath), causing the breakdown of the Van der Waals force of attraction. As a result, the refrigerant molecules are liberated from the adsorbent pore spaces under conditions of high temperature and pressure and subsequently proceed towards the condenser. The coolant circulating inside the condenser heat exchanger captures the latent heat of the refrigerant and supports the refrigerant phase transition. A high-pressure liquid with relatively low-temperature refrigerant is produced, which is then directed to the expansion valve. The expansion valve undergoes the refrigerant to experience a sudden drop in pressure, leading to a corresponding decrease in temperature. As a result, a low-pressure liquid–vapor mixture is generated, which is then directed to the evaporator to initiate the subsequent cycle. Prior to the adsorption and desorption processes, isosteric cooling and isosteric heating processes are conducted with the aim of adjusting the cylinder pressure to match the pressure of the condenser and evaporator, respectively. Both processes, also known as switching times, allow the cylinder to prepare itself for the subsequent adsorption and desorption processes by increasing or decreasing the pressure accordingly. The isosteric heating temperature ($T_{\text{iso_heating}}$) and isosteric cooling temperature ($T_{\text{iso_cooling}}$) are the intermediate temperatures values beyond which the desorption and adsorption processes are executed, respectively. The extended details relevant to the determination of these temperature points are provided in Section 4.




Figure 1. Working schematic of the AHP system (left) and ideal cycle pressure–temperature–uptake diagram (right).

The AHP device can potentially be used both for both cooling and heating applications. The cooling potential (Q_{evap}) is realized in the AHP cycle during the evaporation of refrigerant in the evaporator, whereas the heating potential is realized during condensation (Q_{cond}) and adsorption (Q_{ads}) processes. The steady-state operating conditions of the AHP system used for the present study are summarized in Table 1.

Table 1. Steady-state operating conditions of AHP system.

Parameter/Symbol	Value	Units
Adsorption temperature (T_{ads})	30	$^{\circ}\text{C}$
Regeneration temperature (T_{reg})	80	$^{\circ}\text{C}$
Evaporator temperature (T_{evap})	10	$^{\circ}\text{C}$
Condenser temperature (T_{cond})	30	$^{\circ}\text{C}$
Cooling bath temperature (T_{cool})	$T_{ads} - T_{iso_cooling}$	$^{\circ}\text{C}$
Hot bath temperature (T_{hw})	$T_{iso_heating} - T_{reg}$	$^{\circ}\text{C}$

3. Materials

In this study, four kinds of PR derivative/refrigerant pairs, i.e., (i) KOH6-PR/ CO_2 [41], (ii) SAC-2/HFC-32 [42], (iii) KOH4-PR/ethanol [40], and (iv) KOH6-PR/ethanol [40], are studied from the viewpoint of thermodynamically analyzing their performances for AHP system exhibiting both adsorption cooling and heating applications. The comprehensive discussion and procedure regarding the manufacturing as well as thermophysical features and structures of the PR derivatives can be found from the cited literature [40–42].

A quick overview regarding the synthesizing of the studied PR derivatives in order to encompass all facets is as follows [44–46]: PR derivatives were prepared via carbonization of the raw PR occurring at $600\text{ }^{\circ}\text{C}$ for an hour at a heating rate of $5\text{ }^{\circ}\text{C}/\text{min}$ in the presence of nitrogen (N_2) flow. For activation, KOH was utilized as activating agent. Two weight ratios (KOH/carbonized PR) of 4 and 6 were subjected to heat treatment process at a heating rate of $5\text{ }^{\circ}\text{C}/\text{min}$ and maintained at $900\text{ }^{\circ}\text{C}$ for one hour under N_2 flow. To eliminate the salts generated during the heat treatment and residual KOH, the samples underwent a rigorous washing procedure. This involved subjecting them to multiple rinses with a HCl solution and a subsequent rinse with deionized water for a pH of 7. The collected sample was subjected to two-step drying process. Primary drying takes place at $100\text{ }^{\circ}\text{C}$ for three hours while secondary drying takes place at $150\text{ }^{\circ}\text{C}$ for 12 h. Figure 2 shows the pictorial of raw PR, entailing SEM images of raw PR and associated derivatives. The porous properties, elemental composition, and thermal properties of the PR derivatives are presented in Table 2 [40–42].




Figure 2. Pictorial and SEM images of studied raw PR and associated investigated for the AHP system, reproduced with permission from [40–42].

Table 2. Porous, elemental composition, and thermal properties of the studied PR derivatives, reproduced with permission from [40–42].

Parameters	KOH4-PR	KOH6-PR	SAC-2
Porous Properties			
Total surface area (m ² /g)	3060	2910	2992
Total pore volume (cm ³ /g)	1.90	2.53	2.52
Micropore volume (cm ³ /g)	1.85	2.37	2.29
Pore width (nm)	1.25	1.78	1.62
Elemental Composition			
C (-)	0.9537	0.9272	0.9518
H (-)	0.0005	0.0010	0.0022
N (-)	0.0018	0.0022	0.0026
O _{diff} (-)	0.0440	0.0543	0.0434
O/C (-)	0.035	0.044	N/A
Ash (-)	N/A	0.0153	N/A
Thermal Property			
Specific heat capacity (kJ/kg.K)	N/A	0.751–0.924 (@ 30–150 °C) [45]	N/A

A thermodynamic model based on the adsorption equilibrium model and governing heat and mass balance equations are utilized and/or programmed in Python from the perspective of investigating the PR derivative/refrigerant pairs for the AHP system. The developed Python program is capable of estimating the heating and cooling potentials of AHP corresponding to different operating conditions (i.e., regeneration and adsorption temperature). In addition, the effect of evaporator and condenser pressure is analyzed for each PR derivative/refrigerant pair. The subsequent subsections entail the specifics of the adsorption equilibrium model as well as a comprehensive discussion regarding the thermodynamic equations and Python libraries used in this study.

3.1. Adsorption Equilibrium

Dubinin–Astakhov (D–A) isotherm model is used for simulation of the adsorption isotherms. The well-optimized fitting constants for the D–A model corresponding to each PR derivative/refrigerant pair are provided in Table 3 and available via [40–42]. The D–A isotherm model is presented in Equation (1) as provided by [46]:

$$w = w_o \exp \left[- \left(\frac{R_o T}{E} \ln \frac{P_s}{P} \right)^n \right] \quad (1)$$

where w (kg_{ref}/kg_{PR} or cm³/g_{ref}) and w_o (kg_{ref}/kg_{PR}) are the adsorption equilibrium and maximum adsorption uptake possessed by the PR derivatives corresponding to the different refrigerants, T (K) is adsorption temperature, E (kJ/kg) is the characteristic energy, and n is the structural heterogeneity parameter commonly named as D–A fitting constant. P and P_s are the partial and saturation pressures (kPa), respectively. The P_s of the refrigerants corresponding to T are obtained from the Coolprop, an open-source Python library for fluid properties. However, beyond the critical temperature ($T > T_{cr}$) of the refrigerants, the P_s values are calculated from the pseudo-saturation pressure provided by Equation (2) [41]. In addition, q is evaluated on volumetric bases (cm³_{ref}/g_{PR}) to convert into equilibrium adsorption amount (kg_{ref}/kg_{PR}) using Equation (3) as provided by [41,42]:

$$P_s = \left(\frac{T}{T_{cr}} \right)^k P_c \quad (2)$$

$$q = \frac{w_o}{V_t \exp(\alpha(T - T_t))} \exp\left(-\left\{\frac{R_o T}{E} \ln\left(\frac{P_s}{P}\right)\right\}^n\right) \quad (3)$$

Table 3. The D–A constants for the studied PR derivative/refrigerant pairs, reproduced with permission from [40–42].

PR Derivative/Refrigerant Pairs	w_o ($\text{kg}_{\text{ref}}/\text{kg}_{\text{PR}}$)	E (kJ/kg)	n (-)	k (-)	Ref.
KOH6-PR/ CO_2	2.36 *	86.74	1.064	4.799	[41]
SAC-2/HFC-32	3.13 *	67.25	1.0217	3.65	[42]
KOH4-PR/ethanol	1.43	128	2	-	[40]
KOH6-PR/ethanol	1.98	90	1.5	-	

Note: measures of volumetric bases ($\text{cm}^3_{\text{ref}}/\text{g}_{\text{PR}}$).

In Equation (2), P_c is the critical pressure and k is a fitting constant. The k values for HFC-32 and CO_2 are provided in Table 3 [41,42]. However, V_t is the molar volume of the refrigerant determined by Equation (3) using the Refprop software at triple point temperature (T_t). The α is the thermal expansion coefficient taken as 0.0025 K^{-1} . The V_t value of HFC-32 and CO_2 refrigerants are computed as $0.69966 \text{ cm}^3/\text{g}_{\text{ref}}$ and $0.84858 \text{ cm}^3/\text{g}_{\text{ref}}$, respectively.

3.2. System Governing Equations

In this section, steady-state governing heat and mass balance equations used in ongoing research are presented and discussed accordingly in order to develop a Python program that is employed to evaluate the performance of the AHP system. A generalized programming code is written in Python for thermodynamic modeling of the AHP system, which is capable of investigating different adsorbent/refrigerant pairs. The scope of the work in this case, however, is confined to analyzing the PR derivative/refrigerant pairs. Clausius–Clapeyron model is utilized for determining the heat of adsorption/desorption (Q_{st}), provided by Equation (4) [41]. Accordingly, isosteric heating temperature ($T_{\text{iso_heating}}$) and isosteric cooling temperature ($T_{\text{iso_cooling}}$) were estimated.

$$\frac{Q_{st}}{R_o} = - \left[\frac{\partial \ln(P)}{\partial \left(\frac{1}{T}\right)} \right]_{w=\text{constant}} \quad (4)$$

Once isosteric temperature points are identified, the Python program developed pressure–temperature–uptake (P–T–U) diagram. Four thermodynamic processes, namely (i) isobaric adsorption, (ii) isosteric heating, (iii) isobaric desorption, and (iv) isosteric cooling processes, perform in sequence to complete a single AHP cycle. The time required to complete a single AHP cycle depends upon the adsorption kinetics. However, the primary objective of the present study is to undertake a comprehensive investigation into steady-state phenomena. It is noteworthy that, within the scope of this research, the kinetics pertaining to PR derivative/refrigerant pairs have deliberately been excluded from consideration. Thermodynamic processes involved in the AHP cycle are provided by Equations (5)–(8) [43,47].

Isobaric adsorption (process 1-2);

$$-Q_{1-2} = \int_{T_1}^{T_2} (m_{\text{PR}} c_{\text{PRd}} + w m_{\text{PR}} c_{\text{ref@T}}) dT + m_{\text{PRd}} \int_{w_{\text{min}}}^{w_{\text{max}}} Q_{st_w} dw \quad (5)$$

Isosteric heating (process 2-3);

$$+Q_{2-3} = \int_{T_2}^{T_3} m_{PR} c_{pPRd} dT + w_{max} c_{p_{ref@T}} \int_{T_2}^{T_3} dT \quad (6)$$

Isobaric desorption (process 3-4);

$$+Q_{3-4} = \int_{T_3}^{T_4} (m_{PR} c_{pPRd} + w m_{PR} c_{p_{ref@T}}) dT + m_{PRd} \int_{w_{max}}^{w_{min}} Q_{st_w} dw \quad (7)$$

Isosteric cooling (process 4-1);

$$-Q_{1-4} = \int_{T_4}^{T_1} m_{PR} c_{pPRd} dT + w_{min} c_{p_{ref@T}} \int_{T_4}^{T_1} dT (T_1 - T_4) \quad (8)$$

The first term in Equation (5) computes the sensible heat release during the cooling of PR derivative, whereas the second term computes the latent heat release during the adsorption of refrigerant vapors. The total energy release during isobaric adsorption (Q_{1-2}) is indicated with a negative sign. The total isosteric heat (Q_{2-3}) supplied for increasing the temperature from T_2 to T_3 is computed by Equation (6), which is the summation of the sensible heat gained by the PR derivative adsorbent and heat gained by the refrigerant vapors under equilibrium conditions. The desorption heat is supplied from the external low-grade heat source. The heat supplied during isobaric desorption (Q_{3-4}) can be computed from Equation (7). The first term calculates the sensible heat supplied to the PR derivative adsorbent for reaching regeneration temperature (T_4), whereas the second term is the latent heat gained by refrigerant vapors for desorbing from the adsorbent surface. Again, the heat is released during the isosteric cooling process (Q_{1-4}) estimated by Equation (8) that is the summation of the two sensible heats for lowering the temperature of PR derivative as well as the refrigerant vapors that still adsorb on the surface. The key performance indicators for both adsorption cooling and adsorption heating are estimated using Equations (9)–(13) as provided by [43,47]:

Evaporator/specific cooling energy (SCE):

$$Q_{evap} \text{ or } SCE = m_{PRd} (w_{max} - w_{min@T,P}) LH_{vap@T_e} - m_{PRd} (w_{max} - w_{min}) c_{p_{ref@T}} \int_{T_{evap}}^{T_{cond}} dT \quad (9)$$

Condenser;

$$Q_{cond} = (w_{max} - w_{min}) m_{PRd} LH_{vap@T_{cond}} \quad (10)$$

Specific heating energy (SHE);

$$SHE = Q_{cond} + Q_{1-2} + Q_{1-4} \quad (11)$$

Coefficient of performance for cooling application ($COP_{cooling}$);

$$COP_{cooling} = \frac{SCE}{Q_{2-3} + Q_{3-4}} \quad (12)$$

Coefficient of performance for heating application ($COP_{heating}$);

$$COP_{heating} = \frac{SHE}{Q_{2-3} + Q_{3-4}} \quad (13)$$

The specific cooling energy (SCE) or Q_{evap} is obtained during the isobaric adsorption process when the refrigerant in the evaporator changes from liquid to vapors by gaining the surrounding heat. In order to compute the refrigeration effect, Equation (9) is utilized, which consists of latent heat of evaporation of the refrigerant minus the sensible heat of refrigerant, which enters into the evaporator at condenser temperature. Similarly, the specific heating

energy (SHE) obtained from the single AHP cycle is the function of heat released during condensation plus the heat released during the isosteric cooling and isobaric adsorption. The condenser (Q_{cond}) is computed by the latent heat of vaporization at condenser temperature, as provided in Equation (10). The total SHE is calculated from Equation (11). The COP for both cooling and heating is provided by Equations (12) and (13), respectively.

4. Results and Discussion

Figure 3 shows the isosteric heat of adsorption of PR derivative/refrigerant pairs and the isosteric heat of adsorption (Q_{st}) profiles computed for all PR derivative/refrigerant pairs corresponding to the percentage coverage of refrigerants on the adsorbent surface. The Q_{st} values are determined using the Clausius–Clapeyron equation in conjunction with the adsorption equilibrium model. It has been realized that KOH4-PR/ethanol and KOH6-PR/ethanol pairs possess high Q_{st} if compared with KOH6-PR/ CO_2 and SAC-2/HFC-32 pairs. The Q_{st} values in the case of the KOH4-PR/ethanol pair and KOH6-PR/ethanol pair are measured at 1198.0 kJ/kg and 1120.0 kJ/kg at 1% coverage, which declined to 915.71 kJ/kg and 912.93 kJ/kg at 100% coverage (saturation), respectively. For KOH6-PR/ CO_2 and SAC-2/HFC-32, the Q_{st} values vary from 713.70 to 304.85 kJ/kg and 757.49 to 385.09 kJ/kg, respectively. The computed Q_{st} values for each PR derivative/refrigerant pair have been utilized for determining the $T_{\text{iso_heating}}$ and $T_{\text{iso_cooling}}$ that are later utilized for the development of P–T–U diagrams.




Figure 3. Isosteric heat of adsorption of PR derivative/refrigerant pairs.

4.1. KOH6-PR/ CO_2

The ideal cycle and/or P–T–U for KOH6-PR/ CO_2 is presented in Figure 4a, determined at operating conditions provided in Table 1. The $T_{\text{iso_heating}}$ and $T_{\text{iso_cooling}}$ were computed at 54.90 °C and 52.95 °C, respectively. The net adsorption uptake of ethanol on KOH6-PR is estimated to be 0.525 kg/kg at the operational states provided in Table 1. Figure 4b presents the simulated adsorption equilibrium profiles of KOH6-PR/ CO_2 at the temperature range from 10 °C to 100 °C regarding superimposing the AHP cycle. The reference study [41] experimentally investigated the adsorption equilibrium profiles at temperatures of 20 to 70 °C with an interval of 5 °C, and 10 °C, and estimated the fitting constants for the DA model. However, in the present study, the same fitting constants were utilized to simulate the adsorption isotherms at temperatures less than and greater than 20 °C and 70 °C, respectively. The P_{evap} and P_{cond} are assumed to be 4629.83 kPa and 6941.10 kPa, respectively, based on the saturation pressure of CO_2 . Figure 4c shows the effect of T_{reg} from 50 °C to 80 °C on specific energies and COPs that can be obtained from

the KOH6-PR/CO₂ pair. It has been observed that, corresponding to an increase in T_{reg} , the SCE and SHE linearly increase. At T_{reg} of 80 °C, the SCE and SHE approach to a maximum potential with a magnitude of 77.44 and 314.58 kJ/kg/cycle. In accordance with increasing the T_{reg} from 51 to 80 °C, the COP for AHP for heating application varies from 0.95 to 1.07, which depicts an increasing trend. However, regarding AHP for cooling application, it has been identified that the COP drops from 0.28 to 0.26. On the other hand, corresponding to an increase in T_{ads} , specific energy and COP both for heating and cooling applications are linearly decreased, as shown in Figure 4d. The SCE and SHE were estimated at 88 and 320 kJ/kg/cycle, respectively. Similarly, at T_{ads} of 30 °C, the $COP_{heating}$ was estimated at 4.0-fold higher as compared to the $COP_{cooling}$. Figure 4e shows the effect of P_{cond} on both SCE and SHE at T_{reg} of 52 °C, 63 °C, and 80 °C, differentiated with markers. In the case of the SCE, the P_{cond} was observed to be sensitive to both P_{cond} and T_{reg} . However, for SHE, relatively small variation is observed corresponding to an increase in the P_{cond} , while there was significant improvement with respect to the step-based increment in T_{reg} . This implies that the influence of the P_{cond} is unremarkable on SHE for the KOH6-PR/CO₂ pair. The maximum SCE of 175 kJ/kg/cycle and SHE of 340 kJ/kg/cycle are observed at P_{cond} and T_{reg} of 4525 kPa and 80 °C, respectively. Similarly, the SCE and SHE are observed to be sensitive and insensitive to P_{evap} , respectively, as shown in Figure 4f. However, T_{cool} significantly enhances the magnitude of both SCE and SHE. The maximum SCE of 165.40 kJ/kg/cycle and SHE of 340 kJ/kg/cycle were observed at $P_{evap} = 6360$ kPa and T_{cool} of 30 °C. Figure 4g,h show the detailed impact of T_{cond} , varying from 10 to 25 °C, and T_{reg} from 51 to 80 °C at $T_{evap} = 10$ °C on both SCE and SHE for developing better understanding as well as visualization of the trends. It can be concluded that the impact of T_{cond} is highly sensitive for SCE, whilst T_{cond} does not significantly impact the SHE at $T_{reg} > 75$ °C. The extended results regarding the influence of operating parameters on the SCE, SHE, $COP_{cooling}$, and $COP_{heating}$ are provided in Appendix A accordingly.

4.2. SAC-2/HFC-32

Figure 5a presents the P–T–U diagram of AHP-packed SAC-2/HFC-32 pairs with the operating conditions mentioned in Table 1. The $T_{iso_heating}$ and $T_{iso_cooling}$ were computed to be 54.90 °C and 52.95 °C, respectively. The net absorption uptake of HFC-32 on SAC-2 adsorbent was estimated to be 0.669 kg/kg. Figure 5b presents the simulated adsorption equilibrium profiles corresponding to variations in adsorption/desorption temperature, superimposed with the ideal AHP cycle. The isobaric adsorption and isobaric desorption processes are taking place at 1030.44 kPa and 1979.49 kPa for P_{evap} and P_{cond} , respectively. Figure 5c presents the SCE and SHE obtained from SAC-2/HFC-32. The SCE found 175.20 kJ/kg/cycle, whereas SHE was 561.14 kJ/kg/cycle. Similarly, the $COP_{cooling}$ varied from 0.50 to 0.45, whereas the $COP_{heating}$ was estimated at 1.24 to 1.46, corresponding to the increase in the T_{reg} from 50 to 80 °C. On the other hand, corresponding to the increment in T_{ads} from 30 to 55 °C, the SCE and SHE decrease from 200 to 0 kJ/kg/cycle and from 590 to 0 kJ/kg/cycle, thereby recommending the 30 °C optimum T_{ads} for the AHP system.

Figure 5e presents the impact of P_{cond} on SCE and SHE while maintaining $P_{evap} = 1030.44$ kPa. It has been observed that the P_{cond} responds to a linear decrease in SCE and SHE; however, the higher P_{evap} responds to a linear increase in both SCE and SHE, as shown in Figure 5f. It is noteworthy that both P_{evap} and P_{cond} have a significant influence on the performance of the AHP system packed with SAC-2/HFC-32 pair. Figure 5g and (h) show the detailed impact of T_{cond} varying from 10 to 25 °C and T_{reg} from 51 to 80 °C at $T_{evap} = 10$ °C on both SCE and SHE for developing better understanding as well as visualization of the trends. It can be concluded that the impact of T_{cond} as well as T_{reg} is highly sensitive for both SCE and SHE. The extended results regarding the influence of operating parameters on the SCE, SHE, $COP_{cooling}$, and $COP_{heating}$ are provided in Appendix A accordingly.




Figure 4. (a) P–T–U diagram of KOH6-PR/CO₂ pair at $T_{\text{evap}} = 10^\circ\text{C}$ and $T_{\text{cond}} = 30^\circ\text{C}$, (b) simulated adsorption equilibrium profiles entailing ideal AHP cycle, (c) effect of T_{reg} on SCE and COP, (d) effect of T_{ads} on SCE and COP, (e) effect of condenser pressure on SCE and SHE, (f) effect of evaporator pressure on SCE and SHE, (g) SCE production corresponding to variation in T_{reg} and T_{cond} at $T_{\text{evap}} = 10^\circ\text{C}$, and (h) SHE production corresponding to varying T_{reg} and T_{cond} at $T_{\text{evap}} = 10^\circ\text{C}$.




Figure 5. (a) P–T–U diagram of SAC/HFC-32 pair at $T_{\text{evap}} = 10\text{ }^{\circ}\text{C}$ and $T_{\text{cond}} = 30\text{ }^{\circ}\text{C}$, (b) simulated adsorption equilibrium profiles entailing ideal AHP cycle, (c) effect of T_{reg} on SCE and COP, (d) effect of T_{cool} on SCE and COP, (e) effect of condenser pressure on SCE and SHE, (f) effect of evaporator pressure on SCE and SHE, (g) SCE production corresponding to variation in T_{reg} and T_{cond} at $T_{\text{evap}} = 10\text{ }^{\circ}\text{C}$, and (h) SHE production corresponding to varying T_{reg} and T_{cond} at $T_{\text{evap}} = 10\text{ }^{\circ}\text{C}$.

4.3. KOH4-PR/Ethanol

The ideal cycle and/or P–T–U for KOH4-PR/ethanol is presented in Figure 6a, determined at operating conditions provided in Table 1. The $T_{\text{iso_heating}}$ and $T_{\text{iso_cooling}}$ were computed to be $51.95\text{ }^{\circ}\text{C}$ and $56.12\text{ }^{\circ}\text{C}$, respectively. The net adsorption uptake of ethanol on KOH4-PR is estimated to be 0.727 kg/kg at the operational states provided in Table 1. Figure 6b presents the simulated adsorption equilibrium profiles of KOH4-PR/ethanol at a temperature range from $10\text{ }^{\circ}\text{C}$ to $100\text{ }^{\circ}\text{C}$ regarding superimposing the AHP cycle. It is noteworthy that the fitting constants of the adsorption equilibrium were computed for the temperature range between 30 and $70\text{ }^{\circ}\text{C}$ [40]. However, for higher temperatures ($>70\text{ }^{\circ}\text{C}$) and lower temperatures ($<30\text{ }^{\circ}\text{C}$), the adsorption uptakes are simulated using the D–A model varying the temperature parameter. Based on the saturation properties

of the ethanol, the P_{evap} and P_{cond} are assumed to be 3.11 kPa and 10.41 kPa, respectively. Figure 6c shows the effect of T_{reg} from 50 °C to 80 °C on specific energies and COPs that can be obtained from the KOH4-PR/ethanol pair. It has been observed that, corresponding to increase in T_{reg} , the SCE and SHE linearly increase. At T_{reg} of 80 °C, the SCE and SHE approach maximum potential, with values of 643.85 and 1474.12 KJ/kg/cycle, entailing maximum COP of 1.78 and 0.79, respectively. On the other hand, it corresponds to an increase in T_{ads} , with both specific energy and COP both for heating and cooling applications linearly decreasing, as shown in Figure 6d. This implies that the $T_{\text{reg}} = 80$ °C and $T_{\text{ads}} = 30$ °C are supportive in order to obtain the maximum potential (either cooling or heating) from the KOH4-PR/ethanol. Figure 6e shows the effect of P_{cond} on both SCE and SHE at T_{reg} of 52 °C, 63 °C, and 80 °C, differentiated with markers. The study reveals that P_{cond} of 3.11 kPa and T_{reg} of 80 °C is promising in terms of producing high SCE (980 kJ/kg/cycle) and SHE (1790 KJ/kg/cycle). The increment in the T_{reg} reflects the step-based improvement in both SCE and SHE, whilst the degraded corresponds to an increase in P_{cond} . Figure 6f shows the effect of P_{evap} and T_{cool} on SCE and SHE. The results depict that nearly linear increments of SCE and SHE correspond to an increase in P_{evap} . Also, the step-based increment reflects the significant improvement in the overall SCE and SHE. The maximum SCE of 960 kJ/kg/cycle and SHE of 1750 kJ/kg/cycle were computed at P_{evap} of 7.85 kPa and T_{cool} of 30 °C. Figure 6g,h show the detailed impact of T_{cond} , varying from 10 to 25 °C and T_{reg} from 51 to 80 °C at $T_{\text{evap}} = 10$ °C on both SCE and SHE for developing better understanding as well as visualization of the trends. It can be concluded that the impact of T_{cond} on both SCE and SHE is ignorable at $T_{\text{reg}} > 70$ °C. The extended results regarding the influence of operating parameters on the SCE, SHE, $\text{COP}_{\text{cooling}}$, and $\text{COP}_{\text{heating}}$ are provided in Appendix A accordingly.

4.4. KOH6-PR/Ethanol

The ideal cycle and/or P–T–U for KOH6-PR/ethanol is presented in Figure 7a, determined at operating conditions provided in Table 1. The $T_{\text{iso_heating}}$ and $T_{\text{iso_cooling}}$ were computed to be 51.97 °C and 56.10 °C, respectively. The net adsorption uptake of ethanol on KOH6-PR is estimated at 1.0265 kg/kg at the operational states provided in Table 1. Figure 7b presents the simulated adsorption equilibrium profiles of KOH6-PR/ethanol at a temperature range from 10 °C to 100 °C entailing superimposing the AHP cycle. The cited study determined the fitting constants for KOH6-PR/ethanol at a temperature range between 30 and 70 °C [40]; however, in the present study, the adsorption isotherms for higher temperatures (>70 °C) and lower temperatures (<30 °C) are estimated using the D–A model varying the temperature parameter. The P_{evap} and P_{cond} assume 3.11 kPa and 10.41 kPa, respectively. Figure 7c shows the effect of T_{reg} from 50 °C to 80 °C on specific energies and COPs that can be obtained from the KOH6-PR/ethanol pair. It has been observed that, corresponding to an increase in T_{reg} , the SCE and SHE linearly increase. At T_{reg} of 80 °C, the SCE and SHE approach to a maximum potential with a magnitude of 907.77 and 2024.34 KJ/kg/cycle, with maximum COP of 0.79 and 1.78, respectively. In the case of AHP for cooling application, the COP followed a declining trend (0.84 to 0.78) due to the mounting of externally supplied heat that leads to a slight drop in the COP. On the other hand, it corresponds to an increase in T_{ads} -specific energy and COP both for heating and cooling applications, which follow a relatively curved shape declining trend, as shown in Figure 7d. The SCE and SHE were estimated at 915.00 and 2032.72 kJ/kg/cycle, respectively. Similarly, at T_{ads} of 30 °C, the COP for heating application was estimated 2.34-fold higher as compared to the COP for cooling application. Figure 7e shows the effect of P_{cond} on both SCE and SHE at T_{reg} of 52 °C, 63 °C, and 80 °C, differentiated with markers. The study reveals that P_{cond} of 3.11 kPa and T_{reg} of 80 °C are promising in terms of producing high SCE (1033.78 kJ/kg/cycle) and SHE (2235 KJ/kg/cycle). However, it has been identified that, at $T_{\text{reg}} = 80$ °C, the P_{cond} seems unresponsive to producing SHE for KOH6-PR/ethanol. Similarly, the slope of the SCE profiles corresponds to an increase in the T_{reg} from 52 °C to 80 °C. Figure 7f shows the effect of P_{evap} and T_{cool} on SCE and SHE.

The maximum SCE of 1664.21 kJ/kg/cycle and SHE of 2736 kJ/kg/cycle were estimated at P_{evap} of 7.85 kPa and T_{cool} of 30 °C. Figure 7g,h show the detailed impact of T_{cond} , varying from 10 to 25 °C and T_{reg} from 51 to 80 °C at $T_{evap} = 10$ °C on both SCE and SHE for developing better understanding as well as visualization of the trends. It can be concluded that the impact of T_{cond} on both SCE and SHE is ignorable at $T_{reg} > 75$ °C. The extended results regarding the influence of operating parameters on the SCE, SHE, $COP_{cooling}$, and $COP_{heating}$ are provided in Appendix A accordingly.




Figure 6. (a) P–T–U diagram of KOH4-PR/ethanol pair at $T_{evap} = 10$ °C and $T_{cond} = 30$ °C, (b) simulated adsorption equilibrium profiles entailing ideal AHP cycle, (c) effect of T_{reg} on SCE and COP, (d) effect of T_{cool} on SCE and COP, (e) effect of condenser pressure on SCE and SHE, (f) effect of evaporator pressure on SCE and SHE, (g) SCE production corresponding to variation in T_{reg} and T_{cond} at $T_{evap} = 10$ °C, and (h) SHE production corresponding to varying T_{reg} and T_{cond} at $T_{evap} = 10$ °C.




Figure 7. (a) P–T–U diagram of KOH6-PR/ethanol pair at $T_{evap} = 10\text{ }^{\circ}\text{C}$ and $T_{cond} = 30\text{ }^{\circ}\text{C}$, (b) simulated adsorption equilibrium profiles entailing ideal AHP cycle, (c) effect of T_{reg} on SCE and COP, (d) effect of T_{ads} on SCE and COP, (e) effect of condenser pressure on SCE and SHE, (f) effect of evaporator pressure on SCE and SHE, (g) SCE production corresponding to variation in T_{reg} and T_{cond} at $T_{evap} = 10\text{ }^{\circ}\text{C}$, and (h) SHE production corresponding to varying T_{reg} and T_{50} at $T_{evap} = 10\text{ }^{\circ}\text{C}$.

5. Conclusions

The global transition towards the development of energy-efficient air conditioning systems encourages field researchers to explore the potential of an adsorption heat pump (AHP) system for heat transformation applications. Adsorbent/refrigerant pairs play an important role in the success of the AHP system. In this realm, the study aims to evaluate four kinds of phenol resin (PR) derivative/refrigerant pairs, i.e., (i) KOH6-PR/CO₂, (ii) SAC-2/HFC, (iii) KOH4-PR/ethanol, and (iv) KOH6-PR/ethanol, for adsorption cooling and adsorption heating applications. A steady-state thermodynamic modeling strategy is utilized containing a Dubinin–Astokhov (D–A) model and governing heat and mass balance equations to explore the performance of the AHP system for the selected PR derivative/refrigerant pairs. Specific cooling energy (SCE), specific heating energy (SHE), and associated coefficient of performances (COP) are estimated in response to influential operating parameters, i.e., regeneration temperature (T_{reg}), adsorption temperature (T_{ads}), condenser pressure (P_{cond}), and evaporator pressure (P_{evap}). The analysis reveals that KOH6-PR/ethanol outperforms for the AHP system due to producing the highest SCE of 907.77 kJ/kg/cycle, with SHE of 2024.34 kJ/kg/cycle at T_{reg} of 80 °C, P_{cond} of 10.41 kPa, and P_{evap} of 3.106 kPa, followed by KOH4-PR/ethanol, SAC-2/HFC-32, and KOH6-PR/CO₂. Accordingly, the COP_{cooling} and COP_{heating} were estimated to be 0.79, and 1.78, respectively. In addition, for KOH6-PR/ethanol, it was observed that condenser temperature (T_{cond}) and evaporator temperature (T_{evap}) have no and/or relatively less sensitive for higher T_{reg} (>75 °C) and lower T_{ads} (<32 °C), respectively. However, prior to implementation, meticulous consideration of the adsorption kinetics is highly imperative. Therefore, the performance of the KOH6-PR/ethanol pair may exhibit considerable variability, necessitating in-depth exploration and comprehensive analysis of the underlying adsorption kinetics. Conducting further investigations in this domain is crucial to attain a thorough understanding and optimize the overall efficiency of this intricate system.

Author Contributions: Conceptualization, H.M.A. and M.S.; Data curation, H.M.A. and M.S.A.; Formal analysis, H.M.A.; Funding acquisition, M.S., F.R. and S.M.I.; Investigation, M.S., F.R., M.S.A. and M.I.; Methodology, H.M.A., M.S. and M.F.; Project administration, M.S., F.R. and S.M.I.; Resources, M.S.; Software, H.M.A.; Supervision, M.S.; Validation, M.S., M.F. and M.I.; Visualization, H.M.A., M.S., M.F., F.R., S.M.I., M.S.A. and M.I.; Writing—original draft, H.M.A. and M.S.; Writing—review and editing, M.S., M.F., F.R., S.M.I., M.S.A. and M.I. All authors have read and agreed to the published version of the manuscript.

Funding: This work was supported by Researchers Supporting Project number (RSP2023R100), King Saud University, Riyadh, Saudi Arabia.

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: The data are available within the article.

Acknowledgments: This work was supported by Researchers Supporting Project number (RSP2023R100), King Saud University, Riyadh, Saudi Arabia. Authors acknowledge financial support from Abu Dhabi University's Office of Research and Sponsored Programs. This research work has been carried out in the Department of Agricultural Engineering, Bahauddin Zakariya University, Multan-Pakistan with the support of the BZU-ORIC Project (2020-21).

Conflicts of Interest: The authors declare no conflict of interest.

Appendix A

Appendix A.1. AHP for Cooling

Figure A1 presents the effect of T_{reg} and T_{cond} on SCE for the selected PR derivative/refrigerant pairs while maintaining the $T_{evap} = 10\text{ }^{\circ}\text{C}$. It has been observed that KOH6-PR/ethanol pair possesses the highest SCE among the selected PR derivative/refrigerant pairs. The SCE value ranges between 276 and 1080 kJ/kg/cycle, followed by KOH4-PR/ethanol pair (139.5–969.5 kJ/kg/cycle), SAC-2/HFC-32 pair (55.60–369.6 kJ/kg/cycle), and KOH6-PR/ CO_2 (19.80–173.56 kJ/kg/cycle), respectively, while varying the T_{reg} from $51\text{ }^{\circ}\text{C}$ to $80\text{ }^{\circ}\text{C}$ and T_{cond} from $10\text{ }^{\circ}\text{C}$ to $25\text{ }^{\circ}\text{C}$. In Figure A2, the effect of T_{cool} and T_{evap} on SCE is depicted considering $T_{cond} = 30\text{ }^{\circ}\text{C}$. The SCE of KOH6-PR/ethanol estimated $>513.0\text{ kJ/kg/cycle}$ at $T_{evap} = 25\text{ }^{\circ}\text{C}$ and $T_{cool} = 30\text{ }^{\circ}\text{C}$, followed by KOH4-PR/ethanol ($>890\text{ kJ/kg cycle}$), SAC-2/HFC-32 ($>425.0\text{ kJ/kg cycle}$), and KOH6-PR/ CO_2 ($>158.0\text{ kJ/kg cycle}$). It can be concluded that KOH6-PR/ethanol is superior from the perspective of producing SCE. Figure A3 shows the variation in the $\text{COP}_{cooling}$ corresponding to T_{reg} and T_{cond} while maintaining $T_{evap} = 10\text{ }^{\circ}\text{C}$. The $\text{COP}_{cooling}$ observed sensitive for both KOH6-PR/ CO_2 and SAC-2/HFC-32 whilst not sensitive for KOH4-PR/ethanol and KOH6-PR/ethanol. Figure A4 presents the $\text{COP}_{cooling}$. Similarly, higher T_{cool} placed an adverse impact on the $\text{COP}_{cooling}$, as presented in Figure A4. It has been observed that, for KOH4-PR/ethanol, $\text{COP}_{cooling}$ value of >2.59 is estimated followed by KOH6-PR/ethanol (>1.485), SAC-2/HFC-32 (>2.03), and KOH6-PR/ CO_2 pairs, respectively.




Figure A1. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{reg} and T_{cond} on SCE at $T_{evap} = 10\text{ }^{\circ}\text{C}$.




Figure A2. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{cool} and T_{evap} on SCE at $T_{cond} = 30$ °C.




Figure A3. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{reg} and T_{cond} on $COP_{cooling}$ at $T_{evap} = 10$ °C.




Figure A4. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{cool} and T_{evap} on $COP_{cooling}$ at $T_{cond} = 30\text{ }^{\circ}\text{C}$.

Appendix A.2. AHP for Heating

Figure A5 presents the SHE that might be obtained from an AHP system packed with PR derivative/refrigerant pairs. According to the obtained results, KOH6-PR/ethanol possesses the highest SHE potential, having a value of $> 1955\text{ kJ/kg/cycle}$ at $T_{reg} = 80\text{ }^{\circ}\text{C}$ while irrespective of the T_{cond} . Figure A6 shows the effect of T_{cool} and T_{evap} on SHE. It has been realized that a maximum of 2744 kJ/kg/cycle of SHE can be harnessed with the AHP system packed with KOH6-PR/ethanol. Figure A7 shows the variation in the COP corresponding to T_{reg} and T_{cond} while maintaining $T_{evap} = 10\text{ }^{\circ}\text{C}$. The $COP_{heating}$ observed is sensitive for both KOH6-PR/ CO_2 and SAC-2/HFC-32 whilst not sensitive for KOH4-PR/ethanol and KOH6-PR/ethanol. Beyond the $65\text{ }^{\circ}\text{C}$ of T_{reg} , the highest $COP_{heating}$ values are observed for both KOH4-PR/ethanol and KOH6-PR/ethanol. Figure A8 presents the $COP_{heating}$ of the AHP system corresponding to varying the T_{cool} and T_{evap} . It can be observed that, at low T_{cool} ($30\text{--}35\text{ }^{\circ}\text{C}$), maximum SHE is produced, entailing high $COP_{heating}$. The $COP_{heating}$ values for KOH4-PR/ethanol and KOH6-PR/ethanol are observed to be greater than 2.0, reflecting high heating potential.




Figure A5. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{reg} and T_{cond} on SHE at $T_{evap} = 10$ °C.




Figure A6. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{cool} and T_{evap} on SHE at $T_{cond} = 30$ °C.




Figure A7. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{reg} and T_{cond} on $COP_{heating}$ at $T_{evap} = 10\text{ }^{\circ}\text{C}$.




Figure A8. Comparison of PR derivative/refrigerant pairs focusing on determining the effect of T_{cool} and T_{evap} on $COP_{heating}$ at $T_{cond} = 30\text{ }^{\circ}\text{C}$.

References

1. Demir, H.; Mobedi, M.; Ülkü, S. A review on adsorption heat pump: Problems and solutions. *Renew. Sustain. Energy Rev.* **2008**, *12*, 2381–2403. [[CrossRef](#)]
2. Wang, R.; Xu, Z.; Ge, T. Introduction to solar heating and cooling systems. *Adv. Sol. Heat. Cool.* **2016**, 3–12. [[CrossRef](#)]
3. Sarbu, I. A review on substitution strategy of non-ecological refrigerants from vapour compression-based refrigeration, air-conditioning and heat pump systems. *Int. J. Refrig.* **2014**, *46*, 123–141. [[CrossRef](#)]
4. Lv, S.; Zhang, B.; Ji, Y.; Ren, J.; Yang, J.; Lai, Y.; Chang, Z. Comprehensive research on a high performance solar and radiative cooling driving thermoelectric generator system with concentration for passive power generation. *Energy* **2023**, *275*, 127390. [[CrossRef](#)]
5. Dias, J.M.; Costa, V.A. Adsorption heat pumps for heating applications: A review of current state, literature gaps and development challenges. *Renew. Sustain. Energy Rev.* **2018**, *98*, 317–327. [[CrossRef](#)]
6. Aristov, Y.I. Challenging offers of material science for adsorption heat transformation: A review. *Appl. Therm. Eng.* **2013**, *50*, 1610–1618. [[CrossRef](#)]
7. Scherle, M.; Nowak, T.A.; Welzel, S.; Etzold, B.J.; Nieken, U. Experimental study of 3D—Structured adsorbent composites with improved heat and mass transfer for adsorption heat pumps. *Chem. Eng. J.* **2022**, *431*, 133365. [[CrossRef](#)]
8. Liu, F.; Sun, Z.; Bian, H.; Ding, M.; Meng, X. Identification and classification of the flow pattern of hydrogen-air-steam mixture gas under steam condensation. *Int. J. Therm. Sci.* **2023**, *183*, 107854. [[CrossRef](#)]
9. Jiang, G.; Liu, X.; Jian, H.; Lu, P.; Bai, J.; Zhang, G.; Yun, W.; Li, S.; He, Y. Cu-clusters nodes of 2D metal-organic frameworks as a cost-effective noble-metal-free cocatalyst with high atom-utilization efficiency for efficient photocatalytic hydrogen evolution. *Chin. Chem. Lett.* **2022**, *33*, 3049–3052. [[CrossRef](#)]
10. Zhao, M.; Li, S.; Wang, M.; Guan, X.; Zhao, R. Adsorption of water and formic acid molecules on the (104) surface of calcite: A theoretical study by DFT-D3. *New J. Chem.* **2023**, *47*, 8737–8743. [[CrossRef](#)]
11. Sultan, M.; El-Sharkawy, I.I.; Miyazaki, T.; Saha, B.B.; Koyama, S. An overview of solid desiccant dehumidification and air conditioning systems. *Renew. Sustain. Energy Rev.* **2015**, *46*, 16–29. [[CrossRef](#)]
12. Mohammed, R.H.; Rezk, A.; Askalany, A.; Ali, E.S.; Zohir, A.; Sultan, M.; Ghazy, M.; Abdelkareem, M.A.; Olabi, A. Metal-organic frameworks in cooling and water desalination: Synthesis and application. *Renew. Sustain. Energy Rev.* **2021**, *149*, 111362. [[CrossRef](#)]
13. Ng, K.C.; Thu, K.; Kim, Y.; Chakraborty, A.; Amy, G. Adsorption desalination: An emerging low-cost thermal desalination method. *Desalination* **2013**, *308*, 161–179. [[CrossRef](#)]
14. Aristov, Y.I.; Tokarev, M.M.; Freni, A.; Glaznev, I.S.; Restuccia, G. Kinetics of water adsorption on silica Fuji Davison RD. *Microporous Mesoporous Mater.* **2006**, *96*, 65–71. [[CrossRef](#)]
15. Chang, W.-S.; Wang, C.-C.; Shieh, C.-C. Experimental study of a solid adsorption cooling system using flat-tube heat exchangers as adsorption bed. *Appl. Therm. Eng.* **2007**, *27*, 2195–2199. [[CrossRef](#)]
16. Xia, Z.; Wang, D.; Zhang, J. Experimental study on improved two-bed silica gel–water adsorption chiller. *Energy Convers. Manag.* **2008**, *49*, 1469–1479. [[CrossRef](#)]
17. Youssef, P.G.; Mahmoud, S.M.; Al-Dadah, R.K. Performance analysis of four bed adsorption water desalination/refrigeration system, comparison of AQSOA-Z02 to silica-gel. *Desalination* **2015**, *375*, 100–107. [[CrossRef](#)]
18. Wang, X.; He, Z.; Chua, H.T. Performance simulation of multi-bed silica gel-water adsorption chillers. *Int. J. Refrig.* **2015**, *52*, 32–41. [[CrossRef](#)]
19. Pinheiro, J.M.; Salústio, S.; Rocha, J.; Valente, A.A.; Silva, C.M. Analysis of equilibrium and kinetic parameters of water adsorption heating systems for different porous metal/metalloid oxide adsorbents. *Appl. Therm. Eng.* **2016**, *100*, 215–226. [[CrossRef](#)]
20. Shabir, F.; Sultan, M.; Miyazaki, T.; Saha, B.B.; Askalany, A.; Ali, I.; Zhou, Y.; Ahmad, R.; Shamshiri, R.R. Recent updates on the adsorption capacities of adsorbent-adsorbate pairs for heat transformation applications. *Renew. Sustain. Energy Rev.* **2020**, *119*, 109630. [[CrossRef](#)]
21. Zhao, H.; Zhang, M.; Zhenyan, L.; Yanling, L.; Xiaodong, M. Mechanical and experimental study on freeze proof solar powered adsorption cooling tube using active carbon/methanol working pair. *Energy Convers. Manag.* **2008**, *49*, 2434–2438. [[CrossRef](#)]
22. Wang, L.; Wu, J.; Wang, R.; Xu, Y.; Wang, S.; Li, X. Study of the performance of activated carbon–methanol adsorption systems concerning heat and mass transfer. *Appl. Therm. Eng.* **2003**, *23*, 1605–1617. [[CrossRef](#)]
23. El-Sharkawy, I.; Hassan, M.; Saha, B.; Koyama, S.; Nasr, M. Study on adsorption of methanol onto carbon based adsorbents. *Int. J. Refrig.* **2009**, *32*, 1579–1586. [[CrossRef](#)]
24. El-Sharkawy, I.; Saha, B.; Koyama, S.; He, J.; Ng, K.; Yap, C. Experimental investigation on activated carbon–ethanol pair for solar powered adsorption cooling applications. *Int. J. Refrig.* **2008**, *31*, 1407–1413. [[CrossRef](#)]
25. El-Sharkawy, I.; Kuwahara, K.; Saha, B.; Koyama, S.; Ng, K. Experimental investigation of activated carbon fibers/ethanol pairs for adsorption cooling system application. *Appl. Therm. Eng.* **2006**, *26*, 859–865. [[CrossRef](#)]
26. Saha, B.; El-Sharkawy, I.; Chakraborty, A.; Koyama, S. Study on an activated carbon fiber–ethanol adsorption chiller: Part II—Performance evaluation. *Int. J. Refrig.* **2007**, *30*, 96–102. [[CrossRef](#)]
27. Saha, B.; El-Sharkawy, I.; Chakraborty, A.; Koyama, S. Study on an activated carbon fiber–ethanol adsorption chiller: Part I—System description and modelling. *Int. J. Refrig.* **2007**, *30*, 86–95. [[CrossRef](#)]

28. Critoph, R. Multiple bed regenerative adsorption cycle using the monolithic carbon–ammonia pair. *Appl. Therm. Eng.* **2002**, *22*, 667–677. [[CrossRef](#)]
29. Elsayed, E.; Al-Dadah, R.; Mahmoud, S.; Elsayed, A.; Anderson, P.A. Aluminium fumarate and CPO-27(Ni) MOFs: Characterization and thermodynamic analysis for adsorption heat pump applications. *Appl. Therm. Eng.* **2016**, *99*, 802–812. [[CrossRef](#)]
30. Haque, E.; Jhung, S.H. Synthesis of isostructural metal–organic frameworks, CPO-27s, with ultrasound, microwave, and conventional heating: Effect of synthesis methods and metal ions. *Chem. Eng. J.* **2011**, *173*, 866–872. [[CrossRef](#)]
31. Youssef, P.G.; Dakkama, H.J.; Mahmoud, S.M.; Al-Dadah, R.K. Experimental investigation of adsorption water desalination/cooling system using CPO-27Ni MOF. *Desalination* **2017**, *404*, 192–199. [[CrossRef](#)]
32. Khutia, A.; Rammelberg, H.U.; Schmidt, T.; Henninger, S.; Janiak, C. Water Sorption Cycle Measurements on Functionalized MIL-101Cr for Heat Transformation Application. *Chem. Mater.* **2013**, *25*, 790–798. [[CrossRef](#)]
33. D’ans, P.; Courbon, E.; Permyakova, A.; Nouar, F.; Simonnet-Jégat, C.; Bourdreux, F.; Malet, L.; Serre, C.; Frère, M.; Steunou, N. A new strontium bromide MOF composite with improved performance for solar energy storage application. *J. Energy Storage* **2019**, *25*, 100881. [[CrossRef](#)]
34. Elsayed, E.; Al-Dadah, R.K.; Mahmoud, S.; Anderson, P.A.; Elsayed, A.; Youssef, P.G. CPO-27(Ni), aluminium fumarate and MIL-101(Cr) MOF materials for adsorption water desalination. *Desalination* **2017**, *406*, 25–36. [[CrossRef](#)]
35. Elsheniti, M.B.; Rezk, A.; Shaaban, M.; Roshdy, M.; Nagib, Y.M.; Elsamni, O.A.; Saha, B.B. Performance of a solar adsorption cooling and desalination system using aluminum fumarate and silica gel. *Appl. Therm. Eng.* **2021**, *194*, 117116. [[CrossRef](#)]
36. Zhao, G.; Li, Z.; Cheng, B.; Zhuang, X.; Lin, T. Hierarchical porous metal organic framework aerogel for highly efficient CO₂ adsorption. *Sep. Purif. Technol.* **2023**, *315*, 123754. [[CrossRef](#)]
37. Zhang, J.; Wang, Y.; Wang, H.; Zhong, D.; Lu, T. Enhancing photocatalytic performance of metal-organic frameworks for CO₂ reduction by a bimetallic strategy. *Chin. Chem. Lett.* **2022**, *33*, 2065–2068. [[CrossRef](#)]
38. Ma, X.; Wu, Q.; Tan, L.; Fu, C.; Ren, X.; Du, Q.; Chen, L.; Meng, X. Chemical chaperone delivered nanoscale metal–organic frameworks as inhibitor of endoplasmic reticulum for enhanced sensitization of thermo-chemo therapy. *Chin. Chem. Lett.* **2022**, *33*, 1604–1608. [[CrossRef](#)]
39. Han, L.; Xu, J.; Huang, Y.; Dong, W.; Jia, X. High-performance electrocatalyst of vanadium-iron bimetal organic framework arrays on nickel foam for overall water splitting. *Chin. Chem. Lett.* **2021**, *32*, 2263–2268. [[CrossRef](#)]
40. El-Sharkawy, I.I.; Uddin, K.; Miyazaki, T.; Saha, B.B.; Koyama, S.; Kil, H.-S.; Yoon, S.-H.; Miyawaki, J. Adsorption of ethanol onto phenol resin based adsorbents for developing next generation cooling systems. *Int. J. Heat Mass Transf.* **2015**, *81*, 171–178. [[CrossRef](#)]
41. Uddin, K.; Pal, A.; Saha, B.B. Improved CO₂ adsorption onto chemically activated spherical phenol resin. *J. CO₂ Util.* **2020**, *41*, 101255. [[CrossRef](#)]
42. Sultan, M.; Miyazaki, T.; Saha, B.B.; Koyama, S.; Kil, H.-S.; Nakabayashi, K.; Miyawaki, J.; Yoon, S.-H. Adsorption of Difluoromethane (HFC-32) onto phenol resin based adsorbent: Theory and experiments. *Int. J. Heat Mass Transf.* **2018**, *127*, 348–356. [[CrossRef](#)]
43. Sharafianardakani, A.; Bahrami, M. A Quasi Steady State Model for Adsorption Cooling Systems: Automotive Applications. In Proceedings of the ASME 2012 6th International Conference on Energy Sustainability, ES 2012, Collocated with the ASME 2012 10th International Conference on Fuel Cell Science, Engineering and Technology, San Diego, CA, USA, 23–26 July 2013; pp. 1263–1272. [[CrossRef](#)]
44. Asfahan, H.M.; Sultan, M.; Farooq, M.; Ibrahim, S.M.; Imran, M.; Askalany, A.A.; Shahzad, M.W.; Zhou, Y.; Sajjad, U.; Feng, Y.-Q. Evaluating the emerging adsorbents for performance improvement of adsorption desalination cum cooling system. *Int. Commun. Heat Mass Transf.* **2023**, *142*, 106661. [[CrossRef](#)]
45. Uddin, K.; Islam, A.; Mitra, S.; Lee, J.-B.; Thu, K.; Saha, B.B.; Koyama, S. Specific heat capacities of carbon-based adsorbents for adsorption heat pump application. *Appl. Therm. Eng.* **2018**, *129*, 117–126. [[CrossRef](#)]
46. Aleem, M.; Sultan, M.; Farooq, M.; Riaz, F.; Yakout, S.M.; Ahamed, S.; Asfahan, H.M.; Sajjad, U.; Imran, M.; Shahzad, M.W. Evaluating the emerging adsorbents for water production potential and thermodynamic limits of adsorption-based atmospheric water harvesting systems. *Int. Commun. Heat Mass Transf.* **2023**, *145*, 106863. [[CrossRef](#)]
47. Shabir, F.; Sultan, M.; Niaz, Y.; Usman, M.; Ibrahim, S.M.; Feng, Y.; Naik, B.K.; Nasir, A.; Ali, I. Steady-State Investigation of Carbon-Based Adsorbent–Adsorbate Pairs for Heat Transformation Application. *Sustainability* **2020**, *12*, 7040. [[CrossRef](#)]

Disclaimer/Publisher’s Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.