Lawrence Berkeley National Laboratory

Recent Work

Title

A method to estimate the costs and benefits of undergrounding electricity transmission and distribution lines

Permalink

<https://escholarship.org/uc/item/693823hn>

Author

Larsen, PH

Publication Date

2016-11-01

DOI

10.1016/j.eneco.2016.09.011

Copyright Information

This work is made available under the terms of a Creative Commons Attribution-NonCommercial-NoDerivatives License, available at <https://creativecommons.org/licenses/by-nc-nd/4.0/>

Peer reviewed

A method to estimate the costs and benefits of undergrounding electricity transmission and distribution lines

Peter H. Larsen *

Energy Analysis and Environmental Impacts Division, Lawrence Berkeley National Laboratory, Berkeley, CA, USA
Management Science and Engineering Department, Stanford University, Stanford, CA, USA

ARTICLE INFO

Article history:

Received 19 July 2014
Received in revised form 6 September 2016
Accepted 9 September 2016
Available online 16 September 2016

JEL classification:

Q4 Energy
Q5 Environmental Economics
R00 General
O2 Development Planning and Policy

Keywords:

Electric system reliability
Grid resilience
Power outages
Undergrounding
Cost–benefit analysis

ABSTRACT

There has been a general shortfall of peer-reviewed literature identifying methods to estimate the costs and benefits of strategies employed by electric utilities to improve grid resilience. This paper introduces—for the first time—a comprehensive analysis framework to estimate the societal costs and benefits of implementing one strategy to improve power system reliability: undergrounding power transmission and distribution lines. It is shown that undergrounding transmission and distribution lines can be a cost-effective strategy to improve reliability, but only if certain criteria are met before the decision to underground is made.

© 2016 Elsevier B.V. All rights reserved.

1. Introduction

Despite the high costs attributed to power outages, there has been little or no research to quantify *both* the benefits and costs of improving electric utility reliability—especially within the context of decisions to underground transmission and distribution (T&D) lines (e.g., [EEL, 2013](#); [Nooij, 2011](#); [Brown, 2009](#); [Navrud et al., 2008](#)). One study found that the costs—in general—of undergrounding Texas electric utility T&D infrastructure were “far in excess of the quantifiable storm benefits” ([Brown, 2009](#)). However, this same study also noted that targeted storm-hardening activities may be cost-effective. Despite the importance of considering indirect (external) costs and benefits, policymakers have not always recognized their use within the economic evaluation of proposed policies ([Arrow et al., 1996](#)). It is possible that grid resiliency initiatives could pass a societal benefit–cost test, yet fail a private benefit–cost test and, ultimately, not be mandated by a public utility commission. Transparent assessments of the costs and benefits of undergrounding and other grid-hardening activities are useful to policymakers interested in enabling the long-term resilience of critical electricity system infrastructure ([Executive Office of the President, 2013a](#)).

[Larsen et al. \(2015\)](#) found that U.S. power system reliability is generally getting worse over time (i.e., average annual interruption durations are increasing), due in large part to impacts associated with increasingly severe weather. This study also found that customers of utilities with a relatively larger share of underground line miles typically experienced less frequent and total minutes of power interruptions when compared to utility customers in places that had a lower share of undergrounded line miles.

The purpose of this study is to expand on research by [Larsen et al. \(2015\)](#) by systematically evaluating a policy that requires investor-owned utilities (IOUs) to bury all existing and future transmission and distribution lines underground. More specifically, this analysis will attempt to address the following questions:

- What are the life cycle costs of undergrounding all existing and new transmission and distribution lines at the end of their useful life span?
- Could increasing the share of underground T&D lines lead to fewer power interruptions—and are there corresponding monetary benefits from this reduction?
- Are there aesthetic benefits from reducing the number of overhead T&D lines?
- How much might health and safety costs change if there is an extensive conversion of overhead-to-underground lines?

* 1 Cyclotron Road, 90-4000, Berkeley, CA 94720, USA.
E-mail address: PHLarsen@lbl.gov.

- How much might undergrounding transmission and distribution lines affect ecosystem restoration costs?
- How important are assumptions, including value of lost load estimates, relative to one another within a decision to underground power lines?
- What are the minimum conditions necessary for a targeted undergrounding initiative to have net social benefits?

This article is organized as follows. Section 2 provides background on the causes of power outages, how electric system reliability is measured, and undergrounding. Section 3 contains a discussion of the over-arching analysis framework including study perspective, standing, and methods. Results and a sensitivity analysis are presented in Section 4. Section 5 concludes with a policy recommendation, discussion of the analysis shortcomings, and highlights potential areas for future research.

2. Background

The IEEE guide 1366-2012 formally defines a number of metrics to track electric utility reliability (IEEE, 2012). The System Average Interruption Frequency Index (SAIFI) is one of the most commonly used metrics to assess electric utility reliability (Eto et al., 2012).¹ Eq. (1) shows that annual SAIFI for a utility is calculated by summing all annual customer interruptions and dividing this number by the total number of customers served. In this equation, the number of customers affected by all events in year t is $Affected_t$ and the total number of customers served by the utility in a given year is $Customers_t$:

$$SAIFI_t = \frac{\sum Affected_t}{Customers_t} \quad (1)$$

An IEEE survey of 106 utilities found that the median 2012 SAIFI value is 1.5 interruption events for a typical customer (IEEE, 2014).

It follows that burying power lines (i.e., “undergrounding”) would mitigate some of the risk associated with weather-related events (EEI, 2013). In 2012, the Department of Energy reported that “calls for undergrounding are common from customers, elected officials, and sometimes state utility commissions. However, undergrounding is costly and the decisions are complex” (USDOE, 2012). According to a U.S. Department of Energy press release, widespread power outages, which are often caused by severe storms, “inevitably lead to discussions about burying electric utility T&D infrastructure” (USDOE, 2012). Coincidentally, just 3 months after this press release, “Superstorm Sandy”—a large hurricane affecting the U.S. Eastern Seaboard—caused power outages for tens of millions of people with damages estimated in excess of \$50 billion dollars (NOAA, 2013). For nearly 60 years, researchers have acknowledged that reliable electric service (or lack thereof) has economic benefits (costs) to society (Larsen, 2016). As the electric industry evolved over this time period, so have the methods used by researchers to value lost load (VLL). For example, Sullivan et al. (2009) collected and organized information from nearly thirty value-of-service reliability studies undertaken by ten U.S. electric utilities, noting that

“...because these studies used nearly identical interruption cost estimation or willingness-to-pay/accept methods it was possible to integrate their results into a single meta-database describing the value of electric service reliability observed in all of them. Once the datasets from the various studies were combined, a two-part regression model was used to estimate customer damage functions that can be generally applied to calculate customer interruption costs per event by season, time of day, day of week, and geographical regions within the U.S. for industrial, commercial, and residential customers.”

¹ Although not the focus of this analysis, other popular reliability metrics include the System Average Interruption Duration Index (SAIDI) and Customer Average Interruption Duration Index.

Earlier studies can provide a basis for estimating the avoided damages from strategies to improve grid resilience (e.g., Sullivan et al., 2009, 2010; Leahy and Tol, 2011). Brown (2009) conducted a narrow cost–benefit analysis of storm-hardening strategies on behalf of the Public Utility Commission of Texas. This study indicated that undergrounding T&D lines is significantly more expensive when compared to traditional overhead installations. Brown (2009) assumed that converting existing overhead transmission lines to underground lines would cost approximately \$5 million per mile.² For comparison, Brown (2009) indicates that it costs ~\$180,000/mile to replace single wood pole transmission lines and ~\$459,000/mile to replace state-of-the-art overhead transmission lines that meet current National Electric Safety Code (NESC) standards.³ Brown (2009) estimated that undergrounding local overhead distribution lines would cost ~\$1 million per mile. For comparison, the minimum replacement costs for existing overhead distribution lines ranged from \$86,700 to \$126,900/mile with maximum replacement costs ranging from \$903,000 to \$1,000,000 (EEI, 2013).

It is unfortunate, but likely, that replacing a large amount of overhead infrastructure with underground infrastructure will lead to relative increases in risk to utility operational staff working in the field. EEI (2013) indicates that undergrounding infrastructure has “created a significant safety hazard for crews attempting to locate and repair failed equipment.” For this reason, it was assumed that worker health and safety costs will increase—above levels observed with the status quo—as the share of underground lines increases.

Reducing risk of power outages from severe storms is not the only reason given by stakeholders during discussions about burying T&D lines. Aesthetic improvements are a commonly listed benefit of undergrounding electric utility infrastructure (Brown, 2009; EEI, 2013; Navrud et al., 2008; Headwaters Economics, 2012). EEI (2013) notes that utility customers “prefer underground construction” with “customer satisfaction” and “community relations” being the primary benefit of undergrounding. For example, the community of Easthampton, New York issued a stop-work order and threatened to sue the local utility, PSEG Long Island, over their plan to build new high-voltage transmission lines (Gralla, 2014). This community and others are advocating for the undergrounding of future high-voltage transmission lines.

Des Rosiers (2002) found that a direct view of a transmission system pylon or conductors had a significantly negative impact on property prices with lost values ranging from –5% to –20% depending on the distance from the overhead infrastructure to the residence. Sims and Dent (2005) also evaluated how property prices changed based on proximity to high-voltage overhead transmission lines. Sims and Dent studied four different types of property and found that the relationship is not linear, but that there was a ~10%–18% reduction in value for semi-detached properties and a ~6%–13% reduction for detached properties. Furthermore, properties having a rear view of a pylon were found to have their value reduced by ~7%. By comparison, the negative impact on value for property having a frontal view was found to be greater (14.4% loss).

² EEI (2013) reported a minimum overhead-to-underground transmission line conversion cost of \$536,760–\$1,100,000/mile and a maximum conversion cost of \$6,000,000–\$12,000,000. EEI (2013) reported a minimum overhead-to-underground distribution line conversion cost range of \$158,100–\$1,000,000/mile and a maximum conversion cost range of \$1,960,000–\$5,000,000. The Edison Electric Institute (EEI) estimates that the minimum replacement costs for overhead transmission lines range from \$174,000 per mile (rural) to \$377,000 (urban). The maximum replacement costs for existing overhead transmission lines ranges from \$4.5 million/mile (suburban) to \$11 million/mile for urban customers (EEI, 2013). EEI (2013) also reported that installing new underground distribution lines costs from \$297,200–\$1,141,300/mile (minimum) to \$1,840,000–\$4,500,000/mile (maximum). EEI noted that installing new underground transmission lines costs from \$1,400,000–\$3,500,000/mile (minimum) to \$27,000,000–\$30,000,000/mile (maximum).

³ Brown (2009) assumes that future costs and benefits are discounted 10% annually. In addition, underground and overhead T&D infrastructure have forty- and sixty-year life spans, respectively.

Fig. 1. System average interruption frequency index over time—annual average of all Texas utilities.

Both overhead and underground electric utility infrastructures affect the natural environment and the services that these ecosystems provide. As discussed earlier, wildlife (e.g., squirrels, birds) die prematurely because of the presence of overhead electric utility infrastructure and, in doing so, cause reliability problems. The U.S. Fish and Wildlife Service estimates that collisions with power transmission and distribution lines “may kill anywhere from hundreds of thousands to 175 million birds annually, and power lines electrocute tens to hundreds of thousands more birds annually” (Manville, 2005). Undergrounding lines may reduce mortality rates of birds, rodents, and squirrels, but the process of installing underground power delivery infrastructure could significantly disturb sensitive wetlands (Jones and Pejchar, 2013), forests (Most and Weissman, 2012), or other valuable ecosystems within the T&D corridor. It is likely that undergrounding infrastructure will increase the area of environmental disturbance—when compared to traditional overhead line replacement (Public Service Commission of Wisconsin, 2013). Measurement of the total economic value of an ecosystem is a controversial and difficult undertaking

(e.g., Loomis et al., 2000). Goulder and Kennedy (2009) discuss the value of ecosystem services within a benefit–cost analysis framework. It is noted that

“...when a portion of the ecosystem is threatened with conversion, it may be more important to know the change or loss of ecosystem value associated with such conversion than to know the total value of the entire original ecosystem....willingness to pay offers a measure of the change in well-being to humans generated by a given policy change to protect nature or environmental quality. No comparable measure is currently available for assessing changes in satisfaction to other species or communities of them” (Goulder and Kennedy, 2009, p. 18).

The purchase of conservation easements is one way that developers are able to mitigate some or all of the lost value of an ecosystem affected by specific development projects (The Nature Conservancy, 2014). Developers often purchase conservation easements in locations with similar habitats to the corridor that was affected by the development activity. For example, if new power lines were installed across a prairie habitat in Texas, a developer would be allowed to purchase a conservation easement for comparable land somewhere else.

2.1. Texas (U.S.) as case study

Although the model described in this article has universal applicability, it was initially configured for Texas investor-owned utilities. Texas was selected for a number of reasons, including the following: (1) the Brown (2009) study of Texas contained a number of important assumptions about the cost and life span of T&D infrastructure; (2) Texas has a mix of urban and rural areas, which extends the applicability of this model to other regions; (3) Texas policymakers have expressed interest in the financial viability of an undergrounding mandate; and (4) these service territories are consistently exposed to severe weather.

Fig. 1 shows the average SAIFI values for all Texas utilities used in the Larsen et al. (2015) study without and with major events (i.e., severe storms) included. The pronounced effect of major events on the frequency of outages can be seen in this figure. The figures show a fairly flat time trend for the reliability data without major events, but a slightly increasing trend for the frequency of outages with the inclusion of major events.

3. Analysis framework and method

This analysis is conducted from the perspective of any individual who cares about maximizing net social benefits. There are a number of stakeholders in this type of analysis including the state government, electric utility ratepayers, electric utilities, developers of T&D infrastructure, and society (i.e., all state residents). Given resource constraints, this preliminary analysis assumes that all additional costs to utilities associated with undergrounding will be passed along to ratepayers—including additional administrative, permitting, and siting expenses. Given this key assumption, the stakeholders with standing in this analysis are IOUs, utility ratepayers, and all residents within the service territory.

This analysis evaluates impacts of a policy (“require undergrounding”) against a baseline (“status quo”). In the following sections, the benefits and costs were evaluated for a policy that requires investor-owned Texas electric utilities to underground (1) existing T&D lines at the end of their useful life and (2) when new infrastructure is needed to meet projected growth.

Table 1 describes a range of possible impacts (costs and benefits) for each alternative and group with standing (see above). It is expected that utility ratepayers will bear the cost burden as utilities pass-through all of the costs to install and maintain underground power lines. The largest beneficiaries of policies to encourage undergrounding of power lines would be the state’s residents.

In general, this analysis involved predicting and monetizing impacts for five distinct categories: (1) life cycle infrastructure costs, including administrative, permitting, and siting costs; (2) avoided costs from less frequent power interruptions; (3) reduced aesthetic costs; (4) increased health and safety costs; and (5) increased ecosystem restoration costs. The stream of benefits and costs were evaluated from 2013 through 2050—the approximate life span of an underground T&D line installed in 2012. All future benefits and costs were discounted back to the present using a typical utility weighted average cost of capital (Brown, 2009; Public Utilities Fortnightly, 2013).

3.1. Life cycle infrastructure costs

In this section, an empirical method is introduced to estimate the “status quo” and undergrounding-related costs associated with replacing and maintaining existing overhead T&D infrastructure, installing new overhead (underground) T&D infrastructure, and converting existing overhead

Table 1
Potential impacts from a policy requiring the undergrounding of T&D lines.

Key stakeholders	Undergrounding mandate	
	Selected costs	Selected benefits ^a
IOUs Utility ratepayers	<ul style="list-style-type: none"> Increased worker fatalities and accidents Higher installation cost of underground lines Additional administrative, siting, and permitting costs associated with undergrounding^b Increased ecosystem restoration/right-of-way costs 	<ul style="list-style-type: none"> Lower operations and maintenance costs for undergrounding^c
All residents within service area		<ul style="list-style-type: none"> Avoided costs due to less frequent power outages^d Avoided aesthetic costs

^a Other potential impacts not evaluated in this study include societal benefits from improved local/regional/national security and changes to the likelihood of electrocution to the general public.

^b It is assumed that an administrative, permitting, and siting fee (% share of the total circuit replacement cost) is levied by the government against the utilities in the year before the first conversion decision. For example, if a utility converts an overhead transmission line to an underground transmission line in 2020, a proportional fee (e.g., 2%) is assessed in 2019 and discounted back to the present. In this analysis, this government fee (i.e., tax) is considered a deadweight loss to society because this form of government revenue is not recycled back into the economy (Boardman et al., 2011). It is assumed that utilities will include this fee in the cost of line replacement or conversion.

^c Anecdotal evidence suggests that O&M expenses are lower for undergrounded systems (e.g., significant savings accrue from reduced vegetation management expenditures). However, there is little or no published information describing annual O&M cost differences between underground and overhead T&D systems. For the Texas case, it is assumed that the percentage share of replacement costs that represent operations and maintenance costs are the same between overhead and underground systems.

^d Evaluation of the avoided costs due to shorter duration outages is beyond the scope of this initial analysis.

infrastructure to underground lines. Determining the life cycle costs of infrastructure involved a number of important steps, including (1) collecting basic information on the total line mileage and replacement (i.e., conversion) and operations and maintenance (O&M) costs of T&D infrastructure that is currently overhead and underground for IOUs operating in Texas (Brown, 2009; EEI, 2013); (2) randomly determining the age and length of each segment (i.e., circuit) of existing overhead and underground infrastructure; (3) and calculating the net present replacement and O&M costs of T&D infrastructure through 2050 for a status quo and undergrounding mandate.

As discussed earlier, Brown (2009) and EEI (2013) report the costs of replacing and converting both overhead and underground T&D infrastructure. In addition, Brown (2009) provides useful summary statistics that describe the total number of T&D miles currently overhead and underground for the following Texas IOUs: TNMP, Oncor, Entergy Texas, Centerpoint, SWEPCO, AEP TX North, and AEP TX Central. Table A-1 in the Technical Appendix shows the existing number of T&D miles assumed for this study, the assumed costs for the T&D lines, and a number of other key assumptions.

Unfortunately, there are no publicly available sources of information identifying the current age, location, or length of overhead and underground T&D line segments across Texas.⁴ The timing of when these T&D costs materialize and any associated benefits accrue will determine how much future costs and benefits will need to be discounted back to the present. Therefore, the next step in estimating the life cycle costs of infrastructure involved randomly generating the current age and length of each line circuit up to the total mileage for all IOUs operating in Texas.⁵ Eqs. (2)–(4) describe how each segment, i , of existing infrastructure was randomly assigned an age using a statistical technique to approximate an observed statistical distribution that appears lognormal (StackExchange, 2015). Unfortunately, the average age of overhead and underground transmission and distribution lines located in Texas could not be easily determined. For this reason, publicly accessible information was used to describe average ages ($\overline{Age}_x$) for underground and overhead T&D systems located in other Western states (Northwestern Energy, 2011; Southern California Edison, 2013). Northwestern Energy recently filed a report with the Montana Public Service Commission that contained an overhead distribution system “age profile” (i.e., histogram of electricity infrastructure ages) (Northwestern Energy, 2011). The shape of this distribution was approximately normal with a slight skew to the right. Accordingly, the shape of this 2012 age profile was estimated—for Texas—using the average age for underground and overhead T&D line circuits and repeatedly drawing from a gamma distribution (SAS Institute, 2015) that is scaled (Eq. (2)), shaped (Eq. (3)), and lower-bounded at zero (StackExchange, 2015). Throughout this article, the subscript x refers to overhead transmission ($x = 1$) and distribution ($x = 2$) lines and underground transmission ($x = 3$) and distribution ($x = 4$) lines:

$$Scale_x^{Age} = \frac{\left(\frac{\overline{Age}_x}{2}\right)^2}{\overline{Age}_x} \quad (2)$$

$$Shape_x^{Age} = \frac{\overline{Age}_x}{\left(\frac{\overline{Age}_x}{2}\right)^2} \quad (3)$$

Eq. (4) denotes the randomly determined circuit age (in 2012), where z is a positive observation generated from the gamma probability distribution (SAS Institute, 2015).

$$Age_{2012,i} \sim Scale_x^{Age} \left(\frac{1}{\Gamma(Shape_x^{Age})} \right) z^{Shape_x^{Age}-1} e^{-z}, z > 0 \quad (4)$$

For example, Fig. 2 is a histogram of existing overhead distribution line circuit ages that were simulated using this technique.

⁴ In this analysis, it is assumed that a line segment is analogous to a “circuit”. However, it is likely that what is referred to as a segment may be much longer than a typical T&D line circuit. For this preliminary analysis, it is assumed that electric utilities will replace or convert each circuit (segment) independently.

⁵ It is assumed that the total T&D line mileage grows at 2% per year.

Fig. 2. Simulated age profile of Texas IOU overhead distribution lines.

Individual circuit length was determined following a similar process to what is described above for generating circuit ages (see Eqs. (5)–(7)). In this case, an assumption was made about the average circuit length ($\overline{\text{Length}}_x$), in miles, for underground and overhead T&D systems:

$$\text{Scale}_x^{\text{Length}} = \frac{\left(\frac{\overline{\text{Length}}_x}{2}\right)^2}{\overline{\text{Length}}_x} \quad (5)$$

$$\text{Shape}_x^{\text{Length}} = \frac{\overline{\text{Length}}_x}{\left(\frac{\overline{\text{Length}}_x}{2}\right)^2} \quad (6)$$

$$\text{Length}_i \sim \text{Scale}_x^{\text{Length}} \left(\frac{1}{\Gamma(\text{Shape}_x^{\text{Length}})} \right) z^{\text{Shape}_x^{\text{Length}}-1} e^{-z}, z > 0 \quad (7)$$

Fig. 3 is a histogram of existing overhead distribution line circuit lengths that were simulated using this technique. Note that the integral of this distribution is an estimate of the total mileage of overhead distribution lines operated by Texas IOUs in 2012 (i.e., 165,141 miles simulated versus 165,158 actual overhead distribution lines).

A life cycle analysis of T&D line costs through 2050 can be conducted with information on the circuit age in 2012, the length, expected useful life span, and replacement and O&M costs for all underground and overhead infrastructure. Eqs. (8)–(15) describe a technique to calculate the “true economic depreciation” of infrastructure (Samuelson, 1964; Larsen et al., 2008; Heal, 2012).⁶ Under the status quo, it is assumed that overhead (underground) infrastructure is replaced at the end of its useful life span with the same type of infrastructure (overhead is replaced with overhead, underground is replaced with underground). Eq. (8) denotes how the age of each circuit into the future was determined given the age of the circuit in the base year ($\text{Age}_{2012,i}$), its expected life span (Life span_x), and whether or not it was replaced in any given future year.

$$\text{Age}_{it} = \begin{cases} \text{Age}_{2012,i} + (t-2012), & \text{if } \text{Age}_{it} \leq \text{Life span}_x \\ 1, & \text{if } \text{Age}_{it} - \text{Life span}_x = 1 \\ \text{Age}_{it-1} + 1, & \text{if } \text{Age}_{it} - \text{Life span}_x > 1 \end{cases} : \forall i, t, x \quad (8)$$

It is possible that overhead and underground T&D line replacement costs may increase (decrease) from the initial replacement cost assumption for the base year (i.e., 2012). Eq. (9) depicts how line (x) replacement costs (ReplCost) could increase (decrease) linearly in time, t , at an annual growth (decay) rate expressed as Ψ_x :

$$\text{ReplCost}_{xt} = \begin{cases} \text{ReplCost}_x, & \text{if } t = 2012 \\ \text{ReplCost}_x + \Psi_x(t-2012)(\text{ReplCost}_x), & \text{if } t > 2012 \end{cases} : \forall i, t, x \quad (9)$$

⁶ A variation of this method was used to estimate the additional costs to Alaska's infrastructure from the impacts of rapid climate change (Larsen et al., 2008):

Fig. 3. Simulated mileage profile of Texas IOU overhead distribution lines.

Eq. (10) denotes status quo capital expenses (CAPEX) occurring in future years (t) when the age (Age_{it}) of the circuit exceeds the expected useful life span. All capital expenses incurred for each circuit ($Length_i$) are then discounted t -2012 years back to the present—every time a replacement occurs—using discount rate, r , and summed over the entire analysis period (2013–2050):

$$CAPEX_i^{StatusQuo} = \begin{cases} \sum_{t=2013}^{2050} \frac{ReplCost_{xt}(Length_i)}{(1+r)^{t-2012}}, & \text{if } Age_{it} = 1 \\ 0, & \text{if } Age_{it} \neq 1 \end{cases} : \forall i, t, x \quad (10)$$

Eq. (11) describes how annual O&M expenses (OPEX) for each type of T&D line are assumed to be a fraction (Θ_x) of the overall replacement costs ($ReplCost$)—and that these O&M expenses increase at a constant amount each year as the circuit approaches its expected useful life span⁷:

$$OPEX_{xt} = \begin{cases} \Theta_x(ReplCost_{xt}), & \text{if } Age_{it} = 1 \text{ and } x = [1, 2] \\ OPEX_{xt-1} + \Theta_x(ReplCost_{xt}), & \text{if } Age_{it} > 1 \text{ and } x = [1, 2] \\ \Theta_x(ReplCost_{xt}), & \text{if } Age_{it} = 1 \text{ and } x = [3, 4] \\ OPEX_{xt-1} + \Theta_x(ReplCost_{xt}), & \text{if } Age_{it} > 1 \text{ and } x = [3, 4] \end{cases} : \forall i, t \quad (11)$$

Annual O&M expenses incurred for each circuit ($Length_i$) are then discounted back to the present using discount rate, r , and then summed for all future years in the analysis (see Eq. (12)):

$$OPEX_i^{StatusQuo} = \sum_{t=2013}^{2050} \frac{OPEX_{xt}(Length_i)}{(1+r)^{t-2012}} : \forall i, t \quad (12)$$

Total life cycle costs, under the status quo, can then be estimated by summing both recurring capital and ongoing O&M expenditures for all circuits (see Eq. (13)):

$$LifecyleCost^{StatusQuo} = \sum_i CAPEX_i^{StatusQuo} + \sum_i OPEX_i^{StatusQuo} : \forall i \quad (13)$$

Under the undergrounding alternative, however, the model replaces existing overhead infrastructure with underground infrastructure in the first retirement year. Eq. (14) describes how the first retirement year is determined using the expected useful life span and age of circuit in 2012.

$$FirstRetire_i = Life\ span_x - Age_{2012_i} + 2012 : \forall i, x \quad (14)$$

⁷ It is likely that actual infrastructure O&M expenses increase (decrease) over time in a non-linear fashion. Future research should be undertaken to determine a more appropriate functional form. For the purposes of this initial analysis, however, a linear increase is more accurate than the assumption that O&M expenditures are constant regardless of circuit age.

Eq. (15) describe how at a specific point in time (FirstRetire_i) and in all future retirement years, the overhead lines are replaced with underground lines that have a relatively shorter technical life span and higher capital costs (CAPEX).

$$CAPEX_i^{Under} = \begin{cases} \sum_{t=2013}^{2050} \frac{ReplCost_{(x+2)t}(Length_i)}{(1+r)^{t-2012}}, & \text{if Age}_{it} = 1 \text{ and } x = [1, 2] \\ \sum_{t=2013}^{2050} \frac{ReplCost_{xt}(Length_i)}{(1+r)^{t-2012}}, & \text{if Age}_{it} = 1 \text{ and } x = [3, 4] \\ 0, & \text{if Age}_{it} \neq 1 \end{cases} : \forall i, t \quad (15)$$

For the undergrounding scenario and prior to the first retirement, annual overhead O&M expenses are estimated in the same fashion as described in Eq. (11). However, after an overhead circuit is first converted to an underground circuit, then annual O&M expenses are re-estimated for the new underground line and these costs increase each year according to the amount specified in Eq. (11). Eq. (16), below, describes how circuit O&M costs reset as overhead lines are converted to underground lines:

$$OPEX_i^{Under} = \begin{cases} \sum_{t=2013}^{2050} \frac{(OPEX_{xt})(Length_i)}{(1+r)^{t-2012}}, & \text{if } x = [3, 4] \\ \sum_{t=2013}^{2050} \frac{(OPEX_{xt})(Length_i)}{(1+r)^{t-2012}}, & \text{if } t < \text{FirstRetire}_i \text{ and } x = [1, 2] \\ \sum_{t=2013}^{2050} \frac{(OPEX_{(x+2)t})(Length_i)}{(1+r)^{t-2012}}, & \text{if } t \geq \text{FirstRetire}_i \text{ and } x = [1, 2] \end{cases} : \forall i, t \quad (16)$$

Total life cycle costs, under the undergrounding scenario, can then be estimated by summing both the recurring capital and ongoing O&M expenditures for all circuits (see Eq. (17)).

$$LifecycleCost^{Under} = \sum_i CAPEX_i^{Under} + \sum_i OPEX_i^{Under} : \forall i \quad (17)$$

Eq. (18) shows that future annual underground line mileage (Underground_t) can be determined based on the existing amount of underground line miles in 2012 (Underground₂₀₁₂) and the ongoing conversion from overhead to underground T&D lines described above:

$$Underground_t = \begin{cases} (Underground_{2012}) + \sum_i Length_i, & \text{if } t \geq \text{FirstRetire}_i \\ (Underground_{2012}), & \text{if } t < \text{FirstRetire}_i \end{cases} : \forall i, t, x \quad (18)$$

Finally, the net present value of costs (LifecycleCost) associated with the status quo case are subtracted from the undergrounding alternative to estimate the additional life cycle costs due to undergrounding (see Eq. (19)).

$$LifecycleCost^{Net} = LifecycleCost^{Under} - LifecycleCost^{StatusQuo} \quad (19)$$

3.2. Avoided costs from less frequent outages

All residents and businesses living and operating, respectively, within the IOU service territories will avoid costs if undergrounding leads to less frequent power outages. The avoided costs from a more reliable electrical grid were derived by (1) applying an econometric model developed by Larsen et al. (2015) to estimate the total number of outages—under the status quo—from now until 2050; (2) estimating the total number of outages—for the undergrounding alternative—by gradually removing the effect of weather on this same econometric model as the share of undergrounded line miles increases each year; (3) assigning a dollar value for the total number of annual customer-outages for both alternatives; and (4) subtracting the outage-related costs for the undergrounding alternative from the outage costs for the status quo to determine the dollar value of reduced outages.

Larsen et al. (2015) develop an electric utility reliability model that correlates annual measures of weather (heating degree-days, cooling degree-days, lightning strikes, wind speed, and precipitation), utility T&D expenditures, delivered electricity, presence of outage management systems, number of customers per line mile, and share of underground miles to the frequency of power outages (Outages_t^{StatusQuo}) across the United States (see Eq. (20))⁸:

$$Outages_t^{StatusQuo} = \exp \left(\frac{\beta_1 + \beta_2 Sales + \beta_3 Expenditures + \beta_4 PostOMS + \beta_5 OMS + \beta_6 Cold + \beta_7 Warm}{+ \beta_8 Lightning + \beta_9 Windy + \beta_{10} Windy^2 + \beta_{11} Wet + \beta_{12} Dry + \beta_{13} Year} \right) \quad (20)$$

The model coefficients (and intercept) from Larsen et al. (2015) were used along with average values of historical weather and other model inputs that are relevant for Texas (see Technical Appendix) to estimate the future number of outages for Texas IOUs for the status quo.

Next, the total number of outages were estimated—for the undergrounding alternative—by gradually removing the effect of weather on this same econometric model as the share of undergrounded line miles increases each year. Again, the coefficients and intercept were used from Larsen et al. (2015). However, instead of using a fixed ~20% value for the share of T&D miles underground, the share of underground miles was increased based on

⁸ Electric utility and reporting year are represented by subscript *i* and *t*, respectively. Please see the Technical Appendix for the values of the coefficients used in this analysis.

annual overhead-to-underground conversion decisions from the life cycle replacement analysis. In addition, a weather impact mitigation factor, ϕ , was used to decrease the impact of the weather on utility reliability—as the share of underground miles (Underground) increased. Eq. (21) represents the weather impact mitigation factor:

$$\phi_t = 1 - (\text{Underground}_t - \text{Underground}_{2012}) \quad (21)$$

Eq. (22) depicts how the frequency of power outages was re-estimated ($\text{Outages}_t^{\text{Under}}$) using both the weather impact mitigation factor and the increasing share of underground miles:

$$\text{Outages}_t^{\text{Under}} = \exp \left(\begin{aligned} &\beta_1 + \beta_2 \text{Sales} + \beta_3 \text{Expenditures} + \beta_4 \text{PostOMS} + \beta_5 \text{OMS} \\ &+ \phi_t (\beta_6 \text{Cold} + \beta_7 \text{Warm} + \beta_8 \text{Lightning} + \beta_9 \text{Windy} + \beta_{10} \text{Windy}^2 + \beta_{11} \text{Wet} + \beta_{12} \text{Dry}) \\ &+ \beta_{13} \text{Year} + \beta_{14} \text{Customers} + \beta_{15} \text{Underground} \end{aligned} \right) \quad (22)$$

The total value of lost load under the status quo (Eq. (23)) and undergrounding (Eq. (24)) alternative can be estimated using (1) the number of outages from Eqs. (20) and (22), respectively; (2) the number of customers (Customers) for each class of service (i.e., commercial and industrial, residential, other), c ; and (3) and assumptions about the lost economic value, by customer class, for each power outage (VLL):

$$\text{VLL}^{\text{StatusQuo}} = \sum_{t=2013}^{2050} \frac{\left(\sum_{c=1}^3 \text{Outages}_t^{\text{StatusQuo}} (\text{Customers}_c) (\text{VLL}_c) \right)}{(1+r)^{t-2012}} \quad (23)$$

Sullivan et al. (2010) report a range of values of lost load per outage—by duration—for residential, commercial, and industrial customers. For the base case analysis, it is assumed that the value of lost load per customer is based on a 30-min power outage and that other and small commercial and industrial customers have equivalent VLLs:

$$\text{VLL}^{\text{Under}} = \sum_{t=2013}^{2050} \frac{\left(\sum_{c=1}^3 \text{Outages}_t^{\text{Under}} (\text{Customers}_c) (\text{VLL}_c) \right)}{(1+r)^{t-2012}} \quad (24)$$

Finally, the benefits of avoided outages were calculated by subtracting the status quo total value of lost load ($\text{VLL}^{\text{StatusQuo}}$) from the total value of lost load from the undergrounding alternative ($\text{VLL}^{\text{Under}}$) (Eq. (25)):

$$\text{VLL}^{\text{Avoided}} = \text{VLL}^{\text{StatusQuo}} - \text{VLL}^{\text{Under}} \quad (25)$$

3.3. Avoided aesthetic costs as a proxy for property value improvements

For this analysis, it is assumed that property owners will receive no aesthetic benefit from undergrounding *distribution* lines because it is likely that poles with television cable and internet cables will continue to stay in place for the foreseeable future (Most and Weissman, 2012). However, as discussed earlier, hedonic studies (Des Rosiers, 2002; Sims and Dent, 2005; Headwaters Economics, 2012; Navrud et al., 2008) have shown that the presence of overhead high-voltage transmission lines negatively affect the value of real estate (e.g., ~ –5% to –20%). It is assumed that avoided aesthetic costs serve as a proxy for improved property values. Calculating the net aesthetic benefit of undergrounding these transmission lines involves the following: (1) estimating the number of residential, commercial, and industrial, and other properties within an “overhead transmission corridor” (e.g., 300 ft on either side of overhead transmission line or 600 ft wide); (2) multiplying the number of affected properties against the median real estate value (PropertyValue) for each property class and lost property value (PricelImpact) associated with overhead high-voltage transmission lines (e.g., 12.5%, which is the average of the high and low values found in Des Rosiers (2002) is used for the base case); and (3) discounting the stream of avoided aesthetic costs back to the present using a 10% discount rate (see Eq. (26)):

$$\text{Aesthetic}^{\text{Under}} = \sum_{t=2013}^{2050} \frac{\left(\frac{(\text{Corridor})}{5280} (\text{Underground}_t - \text{Underground}_{t-1}) \right)}{\text{ServiceArea}} (\text{Customer}_c) (\text{PropertyValue}_c) (\text{PricelImpact}) \quad (26)$$

3.4. Ecosystem-related restoration costs

It is assumed that habitat restoration activities took place when the existing overhead and underground lines were sited, but that fewer restoration activities will need to take place as new lines are added and/or converted to underground infrastructure. It is also assumed that undergrounding T&D lines will affect a larger surface area than overhead lines (Public Service Commission of Wisconsin, 2013). The monetization of ecosystem restoration costs involved (1) estimating the number of acres affected by T&D line growth in the future (using development corridor width and total line miles); (2) multiplying total T&D line corridor acreage against a conservation easement price; and (3) discounting this cost back to the present.

Eq. (27) describes initial assumptions about the width, in feet, of the T&D line corridor for the overhead transmission ($x = 1$) and distribution ($x = 2$) lines and underground transmission ($x = 3$) and distribution ($x = 4$) lines:

$$\text{Corridor}^{\text{Eco}} = \begin{cases} 60 : x = [1, 2] \\ 120 : x = [3, 4] \end{cases} \quad (27)$$

The total ecosystem restoration cost of the status quo alternative was calculated by multiplying the additional overhead line miles (built after 2012) against the relevant corridor width ($\text{Corridor}^{\text{Eco}}$), converting square miles to acres, and multiplying the impacted ecosystem acreage against the per-acre price of a conservation easement (EasementValue) in year t (see Eq. (28)):

$$\text{Restoration}^{\text{StatusQuo}} = \sum_{t=2013}^{2050} \frac{\left(\sum_{x=1}^2 \sum_i \text{Length}_{it} - \sum_{x=1}^2 \sum_i \text{Length}_{it-1} \right) \left(\frac{\text{Corridor}^{\text{Eco}}(640)}{5280} \right) (\text{EasementValue})}{(1+r)^{t-2012}} \quad (28)$$

The total ecosystem restoration cost of the undergrounding alternative was calculated by multiplying the additional underground line miles (built after 2012) against the relevant corridor width ($\text{Corridor}^{\text{Eco}}$), converting square miles to acres, and multiplying the impacted ecosystem acreage against the per-acre price of a conservation easement in year t (see Eq. (29)):

$$\text{Restoration}^{\text{Under}} = \sum_{t=2013}^{2050} \frac{(\text{Underground}_t - \text{Underground}_{t-1}) \left(\frac{\text{Corridor}^{\text{Eco}}(640)}{5280} \right) (\text{EasementValue})}{(1+r)^{t-2012}} \quad (29)$$

It is assumed in this case study that an unlimited amount of Texas conservation easements can be purchased for \$3000/acre in any year (The Nature Conservancy, 2014) and that future easement purchases were discounted back to the present using a 10% discount rate. It follows that the additional (net) restoration costs—due to undergrounding—can be calculated by subtracting the status quo restoration costs from the undergrounding alternative restoration costs (see Eq. (30)):

$$\text{Restoration}^{\text{Net}} = \text{Restoration}^{\text{Under}} - \text{Restoration}^{\text{StatusQuo}} \quad (30)$$

3.5. Construction-related morbidity and mortality costs

It is unfortunate, but likely, that replacing a large amount of overhead infrastructure with underground infrastructure will lead to relative increases in risk to utility operational staff working in the field. For that reason, it is assumed that health and safety costs will increase—above levels observed with the status quo—as the share of underground lines increases. Quantifying the additional costs associated with increases in worker morbidity and mortality involved a number of steps.

First, publicly accessible information was used from the utilities to estimate the total number of employees working for the utilities represented in this study. Next, information was collected on the existing incidence rates and costs of relevant injuries (e.g., electrocution, broken bones, burns, sprains, mass trauma) for electric utility workers from the U.S. Occupational Safety and Health Administration (U.S. Department of Labor, 2014). In addition, information is collected on existing fatality rates for the electric utility sector from U.S. Bureau of Labor Statistics (2014) and the value of a statistical life (\$6.9 million) from a recent document published by the Executive Office of the President (2013b). The following equations describe how non-fatal costs (Eq. (31)) and fatality-related economic losses (Eq. (32)) were calculated by multiplying the corresponding incidence rates by the number of IOU employees (Employees), a randomly determined annual injury cost (InjuryCost), and the value of statistical life; and discounting the future annual morbidity and mortality costs back to the present using an appropriate discount rate:

$$\text{NonFatal}^{\text{StatusQuo}} = \sum_{t=2013}^{2050} \frac{\left((\text{NFIR}) \left(\frac{\text{Employees}}{100000} \right) (\text{InjuryCost}) \right)}{(1+r)^{t-2012}} \quad (31)$$

where NFIR and FIR represents non-fatality and fatality incidence rates, respectively; Employees are the total number of employees working for the Texas IOUs; InjuryCost is the total direct and indirect cost of an injury that is likely to occur for workers in the electric utility sector; and VSL is the value of a statistical life:

$$\text{Fatal}^{\text{StatusQuo}} = \sum_{t=2013}^{2050} \frac{\left((\text{FIR}) \left(\frac{\text{Employees}}{100000} \right) (\text{VSL}) \right)}{(1+r)^{t-2012}} \quad (32)$$

The fatal and non-fatal incidence rates were increased proportionally as the share of underground line miles increases each year (see Eq. (33)):

$$\psi_t = \left(\frac{\text{Underground}_t}{\text{Underground}_{t-1}} \right) \quad (33)$$

Table 2
Sensitivity analyses and impact categories.

No.	Sensitivity/scenario analysis	Range			Impact category				
		Minimum value (10th %)	Base case value (50th %)	Maximum value (90th %)	Life cycle assessment (cost)	Avoided outages (benefit)	Aesthetics (benefit)	Health and safety (cost)	Ecosystem restoration (cost)
1	Alternative replacement cost of undergrounding T&D lines (\$ per mile)	\$71,400 (dist.) \$336,000 (trans.)	\$357,000 (dist.) \$1,680,000 (trans.)	\$642,600 (dist.) \$3,024,000 (trans.)	*	*			
2	Alternative values of lost load for each customer class (\$ per event)	\$0.5 (residential) \$87 (other) \$1843.4 (C&I)	\$2.7 (residential) \$435 (other) \$9217 (C&I)	\$4.9 (residential) \$783 (other) \$16,590.6 (C&I)		*			
3	Alternative discount rates (%)	2%	10%	18%	*	*	*	*	*
4	Alternative aesthetic-related property loss factors (% of property value)	2.5%	12.5%	22.5%			*		
5	Alternative incidence rates for accidents and fatalities (per 100,000 employees)	420 (non-fatal) 3 (fatal)	2100 (non-fatal) 15 (fatal)	3780 (non-fatal) 27 (fatal)				*	
6	Alternative accident costs and VSL (\$ per accident/\$ per life)	\$26,131.6 \$1,380,000 (VSL)	\$130,658 \$6,900,000 (VSL)	\$235,184.4 \$12,420,000 (VSL)				*	
7	Alternative conservation easement prices (\$/acre)	\$600	\$3000	\$5400					*
8	Alternative life span assumptions for overhead T&D infrastructure (years)	45	60	75	*	*	*	*	*
9	Share of underground line miles impact on reliability	−0.0002	−0.001	−0.0018		*			
10	Number of customers per line mile	15	75.0	135		*			
11	Annual O&M cost expressed as % of replacement cost: underground T&D lines	1% (trans.) 0.1% (dist.)	5% (trans.) 0.5% (dist.)	9% (trans.) 0.9% (dist.)	*				

Next, the increased incidence rates by the number of employees, injury costs, and value of statistical life for the undergrounding alternative; and discounted the future annual morbidity and mortality costs back to the present using an appropriate discount rate (see Eqs. (34) and (35)):

$$\text{NonFatal}^{\text{Under}} = \sum_{t=2013}^{2050} \frac{(\psi_t)(\text{NFIR})\left(\frac{\text{Employees}}{100000}\right)(\text{InjuryCost})}{(1+r)^{t-2012}} \quad (34)$$

$$\text{Fatal}^{\text{Under}} = \sum_{t=2013}^{2050} \frac{(\psi_t)(\text{FIR})\left(\frac{\text{Employees}}{100000}\right)(\text{VSL})}{(1+r)^{t-2012}} \quad (35)$$

Finally, the NPV of status quo fatal and non-fatal costs is subtracted from the NPV of fatal and non-fatal costs (undergrounding alternative) to determine the NPV of morbidity and mortality costs (HealthSafety) due to undergrounding (see Eq. (36)):

$$\text{HealthSafety}^{\text{Net}} = (\text{NonFatal}^{\text{Under}} + \text{Fatal}^{\text{Under}}) - (\text{NonFatal}^{\text{StatusQuo}} + \text{Fatal}^{\text{StatusQuo}}) \quad (36)$$

3.6. Sensitivity analysis

A sensitivity analysis was conducted by varying several of the key inputs to this cost–benefit analysis—independently and together—including (1) the replacement cost of undergrounding lines; (2) the impact of undergrounding on reliability; (3) the purchase price of conservation easements; (4) the increased chance of construction-related accidents and fatalities; (5) the discount rate; (6) the alternative lost real estate value assumptions; (7) the alternative life span assumptions for overhead infrastructure; (8) the assumptions related to the value of mortality and morbidity; (9) the alternative value of lost load assumptions; (10) the number of customers per line mile; and (11) the O&M costs of undergrounding lines. Table 2 shows which sensitivity analyses apply to each of the selected impact categories.

4. Results and discussion

4.1. Estimated costs

Fig. 4 shows the impact of varying the assumed life span of overhead T&D lines. Not surprisingly, as the assumed life span of overhead lines is decreased from 75 to 60 to 45 years, the life cycle algorithm replaces those overhead lines with underground lines earlier in time—leading to a larger share of underground line miles by 2050. For example, the entire Texas IOU T&D system could be 50% underground by 2028 if the life span of existing overhead lines is assumed to be 45 years instead of 60 years. The share of underground line miles has important

economic implications throughout this analysis. Accordingly, a sensitivity analysis is conducted on the assumed life span of existing overhead T&D infrastructure.

Fig. 5 shows that the life cycle replacement costs ranged from ~\$26.0 billion (status quo) to \$52.3 billion (undergrounding). Net increased NPV replacement costs were ~\$26.3 billion. The net present value of ecosystem restoration costs were ~\$1.0 billion for the status quo and ~\$2.8 billion for the undergrounding alternative. Additional ecosystem restoration costs due to undergrounding were ~\$1.8 billion. Base case health and safety costs were ~\$313 million and \$560 million for the status quo and undergrounding alternative, respectively. It follows that additional health and safety costs due to undergrounding are ~\$245 million.

Fig. 4. Share of underground line miles using alternative useful life spans of overhead T&D lines.

Fig. 6. Typical number of interruptions per customer for status quo and alternative assumptions about useful life span of overhead T&D lines.

4.2. Estimated benefits

In the previous section, it was demonstrated that as the share of underground line miles increases, customers will experience less frequent power outages over time—relative to the status quo (see Fig. 6). It is important to note that outages continue to increase under both the status quo and undergrounding scenarios—as shown in Fig. 6. This finding is a result of the positive coefficient for the YEAR coefficient (i.e., a positive time trend indicates that the frequency of outages is increasing over time) as reported by Larsen et al. (2015) and in Table A-7 of the Technical Appendix.

Fig. 7 shows the interruption costs for the status quo (~\$188 billion) and undergrounding alternative (~\$183 billion). Accordingly, the avoided interruption costs due to undergrounding is estimated at approximately \$5.8 billion. Fig. 7 also shows that the total avoided aesthetic costs for the status quo is estimated at \$10.5 billion with the avoided aesthetic costs increasing to \$12.0 billion for the undergrounding alternative. Net increased avoided aesthetic costs, which is a proxy for the property value benefits of undergrounding, is estimated at ~\$2 billion.

Fig. 8 shows a breakdown of the net benefits of avoided outage costs by the three customer classes. Commercial/industrial customers are projected to receive the largest share of net benefits (\$5.7 billion) primarily due to the relatively higher value of lost load assumption for this customer class when compared to the other customer classes.

Fig. 7. Net present value of benefits for status quo and undergrounding alternative.

Fig. 5. Net present value of costs for status quo and undergrounding alternative.

Fig. 8. Net present value of net avoided interruption costs by customer type.

Fig. 9. Net present value of net avoided aesthetic costs by customer type.

Fig. 9 shows a breakdown of the net increase in avoided aesthetic costs by the three customer classes. Commercial/industrial and residential customers are projected to benefit from an approximately equal share of the avoided aesthetic cost gains.

4.3. Net social benefit and sensitivity analysis

Under the base case, the net costs from undergrounding are estimated at ~\$28.3 billion with net benefits of ~\$7.3 billion (see Table 3). It follows that the base case net social loss from undergrounding all Texas IOU T&D lines is ~\$21 billion, which is equivalent to a 0.3 benefit–cost ratio.

Fig. 10 is a tornado diagram created by varying each of the eleven key input assumptions, separately, to evaluate the overall effect on the total net benefit calculation.⁹ This type of sensitivity analysis shows that the net benefit (loss) calculation is most sensitive to the choice of (1) discount rates; (2) replacement cost of undergrounding lines; (3) overhead T&D line life span; (4) value of lost load; and (5) customers per line mile. For example, the minimum costs for replacing underground T&D lines leads to net benefits of ~\$5 billion whereas assuming the maximum replacement cost yields net losses of ~\$47 billion—all else being equal.

A Monte Carlo simulation was conducted by sampling all of the key input assumptions from uniform distributions—bounded by the minimum and maximum values reported in Table 2—simultaneously. The resulting distributions, which are based on repeated sampling ($n = 500$), show the full range of net benefits possible if all key parameters vary simultaneously and independently of one another. Fig. 11 shows the likelihood of total net losses for an assumed overhead T&D line life span of 45 years (red), 60 years (dark blue), and 75 years (green). As discussed earlier, if overhead life spans are assumed to be shorter, a larger share of lines are undergrounded—with corresponding relative increases in net losses. The results of the Monte Carlo simulations show average net losses of ~\$21.6 billion. Interestingly, varying all of the key parameters simultaneously leads to consistently negative average net losses. In addition, net losses may be the highest in places where the typical life span of overhead lines is the shortest. In this case, the net present value (NPV) life cycle costs of replacing the shorter life span overhead lines with underground lines—in the near term—far exceed the NPV life cycle costs of replacing longer life span overhead lines many decades into the future. For this reason, the net losses are lower under the 75-year life span sensitivity assumptions.

⁹ The results were generated by running the individual parameter minimum and maximum values as shown in Table 2.

Table 3
Summary of base case costs and benefits.

Impact category	Undergrounding	Status quo	Net cost (\$billions)
Environmental restoration	\$2.8	\$1.0	\$1.8
Health and safety	\$0.56	\$0.31	\$0.2
Life cycle costs	\$52.3	\$26.1	\$26.3
Total net costs (undergrounding)			\$28.3
Impact category	Undergrounding	Status quo	Net benefit (\$billions)
Interruption cost	\$182.7	\$188.4	\$5.8
Avoided aesthetic costs	\$12.1	\$10.6	\$1.5
Total net benefits (undergrounding)			\$7.3
Net social benefit (undergrounding)			
Net social benefit (billions of \$2012)			-\$21.0
Benefit–cost ratio			0.3

4.4. Minimum conditions necessary for positive net social benefits

To date, widespread undergrounding initiatives have been most prevalent in urban areas, including Washington D.C., San Diego, New York City, and London (Washington D.C. Power Line Undergrounding Task Force, 2014; City Council of San Diego, 2002; New York City Office of Long-Term Planning and Sustainability, 2013; National Grid-UK, 2016). It is possible that there may be localized net benefits in places

Fig. 10. Sensitivity analysis of net social benefit (loss) using alternative model parameters.

Fig. 11. Monte Carlo simulation of net social loss for 45/60/75-year life span for overhead T&D lines (billions of \$2012).

Table 4
Summary of Texas IOU line mileage and number of customers.

Overhead or underground	Type	Urban + rural line miles (Brown, 2009)	Urban line miles
Overhead	Distribution	165,158	75,250 ^a
Overhead	Transmission	33,060	15,063 ^b
Underground	Distribution	46,669	2881 ^a
Underground	Transmission	81	5 ^b
Total line mileage:		244,968	93,199
Number of customers:		6,983,069	5,914,659 ^c
Customers per line mile:		28.5	63.5

Notes:

^a Author estimates based on extrapolation using Brown (2009) and ABB-Ventyx (2015) sources.

^b ABB-Ventyx (2015).

^c Author estimated by multiplying Census (2015) share of Texas residents living in urban areas (84.7%) against estimate of all Texas IOU customers from Brown (2009).

where (1) there are a large number of customers per line mile (i.e., urban areas)—thus allowing IOUs to achieve economies of scale during the installation of underground lines, and (2) undergrounding is expected to lead to substantial reliability improvements in urban areas vulnerable to frequent and intense storms.

This subsection evaluates the possibility that strategically focusing undergrounding efforts on urban areas within service territories could lead to net benefits.

4.4.1. Method and key assumptions

The goal of this analysis is to identify the minimum conditions that would need to be met in order for a targeted undergrounding initiative to have a near-zero net benefit (i.e., benefit–cost ratio equal to one). To achieve this, the undergrounding model was solved through a backward induction technique where:

- only T&D lines passing within one mile of an urban area are considered in the analysis
- the reliability impact from undergrounding falls within the range of the base case and maximum values reported in Table 2
- the right of way (i.e., easement area) is assumed to be larger for overhead lines than underground lines
- the initial underground T&D line capital costs vary within the range of the minimum and base case values (see Table 2) and in subsequent years are decreased until the resulting benefit–cost ratio is approximately equal to one.

These conditions and the assumptions used in this analysis are described in greater detail below.

4.4.2. Target urban areas within service territories

First, the extent of overhead and underground T&D line miles was reduced to reflect the subset of lines located near urban areas. Table 4 shows the assumed line miles and number of customers from the original, unrestricted analysis (rural and urban) and the restricted analysis (urban only) described in this subsection. As shown in Table 4, the customers per line mile more than doubles when only urban areas are considered. In addition to justifying undergrounding cost economies of scale (see below), customers per line is an explanatory variable in the model component used to project future outages (see section 3.4.2)—and the associated benefits from reductions in outages due to undergrounding. It is assumed that the number of customers per line mile randomly varies from 63.5 (see Table 2) to 135 (the maximum value reported in Table 2).¹⁰

¹⁰ Figure A-1 in the technical appendix contains a map depicting the location of all overhead transmission lines that pass within one mile of a designated urban area (ABB-Ventyx, 2015). It is also shown that there have been a significant number of major storms impacting urban areas across the Texas IOU service territories, including hurricanes (see Figure A-2).

Fig. 12. Share of underground line miles using alternative useful life spans of overhead T&D lines.

Fig. 12 shows that—depending on the assumed life span of overhead lines—the total Texas IOU line mileage converted to underground ranges from 40% to 55% by 2050. For comparison, undergrounding all rural and urban lines at the end of their useful life span resulted in 65–98% of the combined service territories being underground by 2050 (see Fig. 4).

4.4.3. Power system reliability improvements

Next, it was shown in previous sections that power systems with a larger share of underground lines miles typically have higher levels of reliability. For this reason, the reliability impact from undergrounding is assumed to randomly vary within the range of the base case (−0.001) and maximum values (−0.0018) as reported in Table 2.

4.4.4. Higher ecosystem restoration costs for new overhead lines

The Chief Executive Officer of the Cordova (Alaska) Electric Cooperative stated that the right of way for underground lines is smaller relative to overhead distribution corridors (Larsen, 2016). Accordingly, the model was reconfigured by assuming that the typical widths of an underground and overhead right of way are 60 ft and 180 ft, respectively. This change implies that newly sited overhead lines will have higher ecosystem restoration costs when compared to new underground lines. The overall effect is an avoided ecosystem restoration cost due to a larger share of underground lines.

4.4.5. Decreasing capital costs for underground lines

Finally, it is assumed that a strategic initiative to underground all urban, overhead T&D lines at the end of their existing useful life span can be achieved at a lower installation cost when compared to the unrestricted analysis assumptions introduced earlier. Urban areas, which have high customer population densities, will allow IOUs to achieve economies of scale. In many cities, there are existing and extensive underground rights-of-way, because of the placement of fiber optic lines and other telecommunications and public utility infrastructure (e.g., water/sewer corridors). This cost advantage—along with the ability of IOU workers to underground large expanses of lines within a small geographic area—is the reason why underground–overhead installation cost parity could be achieved in the not-so-distant future. For this analysis, it is assumed that the initial underground T&D line capital costs randomly vary within the range of the minimum and base case values (see Table 2) and are decreased linearly by 1.75% per year in each subsequent year.

Table 5
Comparison of unrestricted (urban and rural) and restricted Monte Carlo analyses.

Results	Unrestricted analysis (rural + urban)	Restricted analysis (urban)
Average net social benefit for 45/60/75 year overhead life spans	–\$21.6 billion	\$0.05 billion
Average benefit–cost ratio for 45/60/75 year overhead life spans	0.3	1.0
Average % share of line miles underground by 2050 for 45/60/75 year overhead life spans	79%	47%

Compared to the unrestricted analysis (i.e., entire IOU service territories undergrounded), the restricted analysis (i.e., only urban areas within IOU service territories) assumes that there are (1) larger improvements in reliability due to undergrounding near storm pathways, (2) capital cost reductions for underground T&D lines initially and in subsequent years, (3) larger ecosystem restoration costs (i.e., wider right of way) for overhead T&D lines, and (4) a higher number of customers per square mile. This model configuration represents the minimum conditions necessary to achieve average net social benefits (see Table 5 and Fig. 13).

If only urban areas are considered, then the percentage share of Texas IOU T&D line miles underground by 2050 drops from 79% to 47% (see Table 5). In other words, Texas IOUs could satisfy a social benefit–cost test if about half of their T&D line miles were underground by the middle of this century.

5. Conclusion

A general policy that mandates electric utilities to underground line infrastructure had a base case net social loss of ~\$21 billion through 2050 (or a 0.3 benefit–cost ratio). Varying all of the key parameters simultaneously leads to aggregate net social losses of ~\$21.6 billion—on average. The model results are most sensitive to the choice of (1) discount rates, (2) replacement cost of undergrounding lines, (3) overhead T&D line life span, (4) value of lost load, and (5) customers per line mile. Based on the initial configuration of this model, the Texas public utility commission should *not* consider broadly mandating undergrounding when overhead T&D lines have reached the end of their useful life. However, a subsequent configuration of the model found that a policy specifically targeting urban areas could be cost-effective if a number of key criteria are met. Policymakers should consider requiring that T&D

lines be undergrounded in places where most of the following conditions are present:

- There are a large number of customers per line mile (e.g., greater than forty customers per T&D line mile)
- There is an expected vulnerability to frequent and intense storms
- There is the potential for underground T&D line installation economies of scale (e.g., ~2% decrease in annual installation costs expected per year)
- Overhead T&D line utility easements (i.e., rights-of-way) are larger than underground T&D utility easements

However, there are limitations to this analysis—and a number of possibilities for improvement in the future. First, it is assumed that the number of utility employees, real estate prices, and conservation easement prices are fixed at current levels. It is likely that these specific assumptions will increase over time, which could affect the benefit–cost ratio. It is also possible that a national model of electric utility reliability (Eto et al., 2012; Larsen et al., 2015) may not be appropriate for regional or local analyses. More research is needed to explore the factors that affect local utility reliability. This analysis assumed that the only stakeholders who have standing in this analysis include utilities, ratepayers, governments, and residents who live within the boundary of the Texas independent operating utilities. It is possible that there are other stakeholders who will be impacted if the share of underground line miles increases. It is assumed that future weather through 2050 (e.g., number of lightning strikes, annual temperature, precipitation, and average wind speed) will be similar to weather observed during the 2000–2012 time period. However, it is highly likely that future weather (climate) will not be similar to what has been recently observed (IPCC, 2014). Future research could entail mapping state-of-the-art projections of local storm activity and temperature to each utility and recalibrating the analysis. Increased annual temperatures and storm activity will increase the estimated benefits of undergrounding T&D lines. It is also possible that the estimates of increased injury costs due to undergrounding may be less than the economic value of quality life to injured electric utility workers—or that undergrounding may, in fact, reduce health and safety risks to the general population. There is also emerging research indicating that underground lines are less efficient than overhead lines, which would increase the costs of undergrounding relative to the overhead status quo. Furthermore, this analysis did not consider the possibility that customers—especially commercial and industrial customers—may have installed backup generators or other technologies to reduce the risk of power interruptions. Another key assumption is that electric utilities in Texas are able to pass along all of their additional costs (due to undergrounding) to ratepayers. Despite these shortcomings, this section introduces a modeling framework that could be improved upon and extended to other regions who are interested in the economics of electric utility reliability.

Acknowledgments

I gratefully acknowledge the overall guidance and encouragement given throughout this project by Jim Sweeney of Stanford University. I would also like to thank Christine Pal Chee, Kate Bundorf, John Weyant, and Larry Goulder (Stanford University) for providing constructive feedback as I developed and implemented the analysis framework. A number of other individuals provided advice at various points during this project including, but not limited to Joe Eto, Juan Pablo Carvallo, and Kristina Hamachi LaCommare of Lawrence Berkeley National Laboratory. All errors and omissions are my own.

Appendix A. Supplementary data

Supplementary data to this article can be found online at <http://dx.doi.org/10.1016/j.eneco.2016.09.011>.

Fig. 13. Monte Carlo simulation of net social benefit/loss for 45/60/75-year life span for overhead T&D lines (billions of \$2012).

References

- ABB-Ventyx, 2015. Ventyx Velocity Suite Energy Mapping Software (Boulder, December 12).
- Arrow, K., et al., 1996. Is there a role for benefit–cost analysis in environmental, health, and safety regulation? *Science* 272, 221–222.
- Boardman, A., Greenberg, D., Vining, A., Weimer, D., 2011. *Cost-benefit Analysis: Concepts and Practice*. Fourth. Pearson Education.
- Brown, R., 2009. Cost–benefit analysis of the deployment of utility infrastructure upgrades. Final report prepared for the Public Utility Commission of Texas, Quanta Technology.
- City Council of San Diego, 2002. City Council Policy 600-08: Underground Conversion of Utility Lines by Utility Company (San Diego, May 28).
- Des Rosiers, F., 2002. Power lines, visual encumbrance, and house values. *J. Real Estate Res.* 23 (3).
- Edison Electric Institute. Out of sight, out of mind. Prepared by Kenneth Hall for EEI, Edison Electric Institute, 2013.
- Eto, J.E., LaCommare, K.H., Larsen, P., Todd, A., Fisher, E., 2012. An examination of temporal trends in electricity reliability based on reports from U.S. electric utilities. LBNL Report-5268E. Lawrence Berkeley National Laboratory, Berkeley.
- Executive Office of the President, 2013a. Economic Benefits of Increasing Electric and Grid Resilience to Weather Outages. The White House, Washington D.C.
- Executive Office of the President, 2013b. Draft Report to Congress on the Benefits and Costs of Federal Regulations. Draft report. Executive Office of the President, Washington D.C.
- Goulder, L., Kennedy, D., 2009. Interpreting and estimating the value of ecosystem services. Working Paper. Stanford University Department of Economics, Stanford.
- Gralla, J., 2014. East Hampton residents protest PSEG LI plan to install taller power lines. *Newsday* (April 5).
- Headwaters Economics, 2012. Transmission Lines and Property Value Impacts. Prepared for the MSTI Review Project. Headwaters Economics, Bozeman.
- Heal, G., 2012. Reflections-defining and measuring sustainability. *Rev. Environ. Econ. Policy* 28, 1–21.
- IEEE, 2012. IEEE 1366-2012: IEEE guide for electric power distribution reliability indices. Guides and Standards. IEEE Power and Energy Society.
- IEEE, 2014. *IEEE Benchmark Year 2013: Results for 2012 Data*. 2013. Intergovernmental Panel on Climate Change. *Fifth Assessment Report Summary for Policymakers: Impacts, Adaptation, and Vulnerability*. Intergovernmental Panel on Climate Change.
- Intergovernmental Panel on Climate Change, 2013. *Fifth Assessment Report Summary for Policymakers: Impacts, Adaptation, and Vulnerability*. Intergovernmental Panel on Climate Change.
- Jones, N., Pejchar, L., 2013. Comparing the ecological impacts of wind and oil & gas development: a landscape scale assessment. *PLoS One* 8 (11).
- Larsen, P., 2016. Severe Weather, Power Outages, and a Decision to Improve Electric Utility Reliability (Dissertation) Stanford University (Accessed at: <http://purl.stanford.edu/sc466vy9575>).
- Larsen, P., et al., 2008. Estimating future costs for Alaska public infrastructure at risk from climate change. *Glob. Environ. Chang.* 18, 442–457.
- Larsen, P., Hamachi-LaCommare, K., Eto, J., Sweeney, J., 2015. *Assessing Changes in the Reliability of the U.S. Electric Power System*. LBNL-188741. Lawrence Berkeley National Laboratory, Berkeley.
- Leahy, E., Tol, R., 2011. An estimate of the value of lost load for Ireland. *Energy Policy* 39, 1514–1520.
- Loomis, J., Kent, P., Strange, L., Fausch, K., Kovich, A., 2000. Measuring the total economic value of restoring ecosystem services in an impaired river basin: results from a contingent valuation survey. *Ecol. Econ.* 33.
- Manville, A., 2005. Bird Strikes and Electrocutations at Power Lines, Communication Towers, and Wind Turbines: State of the Art and State of the Science—Next Steps Toward Mitigation. Technical Report PSW-GTR-191. U.S. Department of Agriculture-Forest Service.
- Most, W., Weissman, S., 2012. Trees and power lines: minimizing conflicts between electric power infrastructure and the urban forest. Report. University of California Center for Law, Energy, and the Environment, Berkeley.
- National Grid-UK, 2016. UK Electricity Network: Underground Cables January 15 <http://www2.nationalgrid.com/uk/services/land-and-development/planning-authority/electricity-network-underground-cables/>.
- National Oceanic and Atmospheric Administration, 2013. National Weather Service Assessment: Hurricane/Post-Tropical Cyclone Sandy. Technical Assessment, National Weather Service.
- Navrud, S., Ready, R., Magnussen, K., Bergland, O., 2008. Valuing the social benefits of avoiding landscape degradation from overhead power transmission lines: do underground cables pass the benefit–cost test? *Landsc. Res.* 33 (3), 281–296.
- New York City Office of Long-Term Planning and Sustainability, 2013i. Utilization of Underground and Overhead Power Lines in the City of New York. Office of the Mayor, New York City.
- Nooij, M., 2011. Social cost–benefit analysis of electricity interconnector investment: a critical appraisal. *Energy Policy* 39.
- Northwestern Energy, 2011. Response to Montana Public Service Commission Data Requests: 001-007." Vol. Docket D2011.1.7. Montana Public Service Commission, Helena (February 11).
- Public Service Commission of Wisconsin, 2013. Environmental Impacts of Transmission Lines. Electric 10 (07/13). State of Wisconsin, Madison.
- Public Utilities Fortnightly, 2013. 2013 Rate Case Study. Public Utilities Fortnightly (November).
- Samuelson, P., 1964. Tax deductibility of economic depreciation to insure invariant valuations. *J. Polit. Econ.* 72 (4), 604–606.
- SAS Institute, 2015. Documentation for SAS 9.3 Functions and CALL Routines: RAND Function. <http://support.sas.com/documentation/cdl/en/lefuctionsref/63354/HTML/default/viewer.htm#p0fpeei0opypg8n1b06qe4r040lv.htm>.
- Sims, S., Dent, P., 2005. High-voltage overhead power lines and property values: a residential study in the UK. *Urban Stud.* 42 (4).
- Southern California Edison, 2013. 2015 general rate case: transmission and distribution volume 4–infrastructure replacement programs. U 338-E. California Public Utilities Commission.
- StackExchange. How to Get Only Positive Values when Imputing Data, July 2015n. <http://stats.stackexchange.com/questions/107679/how-to-get-only-positive-values-when-imputing-data>.
- Sullivan, M., Mercurio, M., Schellenberg, J., 2009. *Estimated Value of Service Reliability for Electric Utility Customers in the United States*. LBNL-2132E. Lawrence Berkeley National Laboratory, Berkeley.
- Sullivan, M., Mercurio, M., Schellenberg, J., Eto, J., 2010. How to estimate the value of service reliability improvements. Proceedings from the 2010 IEEE Power and Energy Society General Meeting. IEEE.
- The Nature Conservancy. Conservation Buyer Program, 2014. <http://www.nature.org/about-us/private-lands-conservation/conservation-buyer/properties/index.htm>.
- U.S. Bureau of Labor Statistics, 2014. Census of fatal occupational injuries and survey of occupational injuries and illnesses (April) <http://www.bls.gov>.
- U.S. Census Bureau, 2015. American Community Survey (Washington D.C., November 4).
- U.S. Department of Energy, 2012. DOE/EIA Today in Energy: Power Outages Often Spur Questions around Burying Power Lines (July 25) <http://www.eia.gov/todayinenergy/detail.cfm?id=7250>.
- U.S. Department of Labor, 2014. Safety Pays Program: Statistics on Direct and Indirect Costs of Accidents. Occupational Safety and Health Administration, Washington D.C.
- Washington D.C., 2014. Power Line Undergrounding Task Force. Findings and Recommendations Report. Office of City Administrator, Washington D.C.