Lawrence Berkeley National Laboratory

Recent Work

Title

Siting Samplers to Minimize Expected Time to Detection

Permalink

<https://escholarship.org/uc/item/6n6253sq>

Journal

Risk Analysis, 32

Authors

Walter, Travis
Lorenzetti, David M.
Sohn, Michael D.

Publication Date

2012-12-12

ERNEST ORLANDO LAWRENCE BERKELEY NATIONAL LABORATORY

Siting Samplers to Minimize Expected Time to Detection

Travis Walter, David M. Lorenzetti, Michael D. Sohn

Environmental Energy Technologies Division

December 2012

This work was supported by the Office of Energy Efficiency and Renewable Energy (Solar Technologies Office) of the U.S. Department of Energy under Lawrence Berkeley National Laboratory Contract No. DE-AC02-05CH1131

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Ernest Orlando Lawrence Berkeley National Laboratory is an equal opportunity employer.

Abstract

We present a probabilistic approach to designing an indoor sampler network for detecting an accidental or intentional chemical or biological release, and demonstrate it for a real building. In an earlier paper, Sohn and Lorenzetti⁽¹⁾ developed a proof of concept algorithm that assumed samplers could return measurements only slowly (on the order of hours). This led to optimal “detect to treat” architectures, which maximize the probability of detecting a release. This paper develops a more general approach, and applies it to samplers that can return measurements relatively quickly (in minutes). This leads to optimal “detect to warn” architectures, which minimize the expected time to detection. Using a model of a real, large, commercial building, we demonstrate the approach by optimizing networks against uncertain release locations, source terms, and sampler characteristics. Finally, we speculate on rules of thumb for general sampler placement.

Keywords: sampler networks, indoor airflow, optimization, CONTAM

1 INTRODUCTION

Many private and public agencies are developing hardware to detect the presence of airborne chemical or biological agents in or near buildings. Detecting a contaminant would allow acting to minimize adverse health effects, for example by evacuating the building, manipulating air supplies, and mobilizing medical response. However, this range of possible responses—plus practical constraints imposed by the hardware, and uncertainty about the operating conditions under which it must function—complicate the design and operation of a monitoring network that balances risk appropriately.

The designer must decide, for example, on the number of samplers to deploy, their operating characteristics (e.g., sampling frequency and detection limit), where to place them, and what release scenarios to try to detect. To address these questions, Sohn and Lorenzetti⁽¹⁾ proposed a probabilistic approach to network design, and demonstrated its application in a synthetic building. Many other approaches have been taken^(2,3,4) that advance the state of this research, but none account for the relative likelihoods of uncertain conditions. This paper extends the work in ⁽¹⁾ by: 1) developing a more complete analysis framework, 2) adding a new metric for evaluating network performance, and 3) applying the resulting algorithms to a real building.

The approach taken here, while developed to protect against airborne plumes of chemical or biological material (see also ^(5,6)), is relevant to wider problems of monitoring indoor air quality⁽⁷⁾, building energy⁽⁸⁾, occupancy⁽⁹⁾, thermal comfort⁽¹⁰⁾, lighting⁽¹¹⁾, and more^(12,13). Whenever samplers are too expensive to deploy widely throughout a building, a probabilistic optimization approach may help balance the competing design constraints and goals of the sampler network. Furthermore, whenever the network must operate under uncertain or variable conditions, a probabilistic approach, such as the one described here, may be needed.

2 PROBABILISTIC ALGORITHM FOR SAMPLER DEPLOYMENT

Consider designing an air-monitoring network in order to maximize some measure, ϕ , of the network quality. Whatever the metric, uncertainty and variability in the operating conditions mean that the network quality cannot be defined deterministically.

Stochastic effects arise in the source (for example, the release location, rate, and time, and the material degradation and deposition rates); in sampler characteristics (probability of detecting a given concentration, or the time needed to process samples); in environmental conditions (outside temperature and wind

direction); and in the building operation (status of the ventilation system, condition of filters, position of doors and windows, leakiness of the ductwork). Uncertainty also arises from the models used to assess the contaminant dispersion (for example, due to simplifications in the model physics, and the extent to which model parameters have been tuned to match the actual building operation).

2.1 Expected Performance

In the face of such probabilistic effects, the quality metric should reflect the statistically *expected* performance of the network. The Probabilistic Approach to Sampler Siting (PASS)⁽¹⁾ finds the expected network performance by aggregating the outcomes of many deterministic model runs, each drawing its input parameters from distributions of likely values.

In this approach, the key sources of uncertainty and variability that might affect the performance of the sampler network—the source and sampler characteristics, environmental conditions, building operation, model structure, and so on—are first identified and characterized. Assigning probability distributions to these uncertain conditions can be done using past measurements or engineering judgement. While specifying these distributions is not trivial, a key feature of probabilistic algorithms is that they allow testing for the effect the distributions have on sampler placement and network performance. Sampling from these distributions yields a suite of *scenarios*, or test cases, against which to evaluate candidate networks. A pollutant fate and transport model is then used to simulate each scenario. Finally, PASS finds the expected performance of each candidate sampler network, taking into account the relative likelihood of each scenario.

Let ϕ_i give the value of some quality metric, as applied to scenario i . Because each scenario is defined deterministically, ϕ_i also is a deterministic measure of how well a particular sampler network performs given a specific scenario. Combining across all I scenarios in the suite yields the expected performance, as

$$E[\phi] = \sum_{i \in I} \phi_i \cdot P[i] \quad (1)$$

where $P[i]$ gives the relative likelihood of scenario i .

2.2 Performance Metrics

The algorithm reported in ⁽¹⁾ maximized the expected probability of detecting a release. This goal implicitly acknowledged the fact that first-generation samplers required many hours to collect and analyze

samples before returning results. The resulting networks were optimal *detect-to-treat* architectures, which sought mainly to identify the fact that a release took place.

A new generation of samplers, able to provide data on the order of minutes, offers the promise of *detect-to-warn* architectures. Such systems, by focusing mainly on fast detection, will enable actions intended to minimize exposures, for example by evacuating the building, or manipulating fresh air supplies. However, this greater capability further complicates the network design: while higher sampling rates may let the network detect a release earlier, they also can lead to noisier data, to lower detection probabilities (since shorter sampling windows present the sampler with less airborne mass to detect), or to more false positives.

Suppose a sampler returns a new result at intervals of length τ . Each such interval constitutes a *sampling window*. Let $P[S_{i,z,w}]$ give the probability, for release scenario i , that sampler z will alarm during a particular window, w . Then a network comprising a set Z of samplers will alarm during window w if one or more of those samplers alarms:

$$P[N_{i,w}] = 1 - \prod_{z \in Z} (1 - P[S_{i,z,w}]) \quad (2)$$

Note that Equation 2 uses $P[\text{at least one occurs}] = 1 - P[\text{none occurs}]$. If the network concept of operation demands multiple samplers to alarm, for example in order to guard against false positives, a more complicated expression results.

Looking across all sampling windows, the cumulative probability that a network will alarm for scenario i after sampling across W windows is

$$P[N_i] = 1 - \prod_{w=1}^W (1 - P[N_{i,w}]) \quad (3)$$

Combining Equations 2 and 3,

$$P[N_i] = 1 - \prod_{w=1}^W \prod_{z \in Z} (1 - P[S_{i,z,w}]) \quad (4)$$

Since the order of multiplication is immaterial, one may precompute the products $1 - P[S_{i,z,w}]$ across the windows W of interest, then combine them according to the sampler selections in Z .

For detect-to-treat architectures, we define the performance metric in scenario i as the probability that

the network in question will detect the release:

$$\phi_i = P[N_i] \quad (5)$$

with W chosen sufficiently large. Note that the optimal network will *maximize* the expected value of this performance metric over all scenarios.

We now turn to the goal of fast detection. As described above, many of the distributions that define the scenarios affect the probability of detecting a release. Therefore detection is, itself, a stochastic phenomenon. Accordingly, we let the network designer specify a desired level of confidence, β , that the network will alarm. Then

$$T_i = \tau \cdot \min\{W : P[N_i] > \beta\} \quad (6)$$

gives the time at which a particular network can detect scenario i with at least β probability.

If a network does not detect the release in scenario i , Equation 6 leaves T_i undefined. In this case, the designer must specify some appropriate value, for example, by estimating the time it would take to detect the release by some other means (e.g., when a large number of occupants experience health effects).

For detect-to-warn architectures, we define the performance metric in scenario i as the time required to detect the release:

$$\phi_i = T_i \quad (7)$$

and note that the optimal network will *minimize* the expected value of this performance metric over all scenarios.

In this paper, we consider only two performance metrics, probability of detection and time to detection. However the algorithm presented here can use any performance metric, including occupant exposure^(5,6), health consequences, or total cost of operation.

3 APPLICATION TO A CONVENTION CENTER

To demonstrate the sampler network design approach, we apply the algorithm to a realistic model of a large building. Figure 1 shows a modified schematic of a real convention center in which Lawrence Berkeley National Laboratory (LBNL) performed tracer gas experiments⁽¹⁴⁾. In addition to the main convention space floor, the building has two floors of offices. The building is served by sixty-seven HVAC (heating, ventilation and air conditioning) units.

Figure 1: Plan of occupied floors of the convention center, with approximate floor areas.

3.1 Model

In each of six experiments, one or more inert tracer gases were released, and concentrations measured every one to 30 minutes, in approximately 40 locations. The data were used to calibrate a multizone airflow and pollutant transport model of the building using CONTAM⁽¹⁵⁾. The model consists of 337 well-mixed zones. Figure 2 shows typical post-calibration model-to-data comparisons. For this particular building, high ventilation rates mean the well-mixed assumption is valid, but our algorithm allows any type of pollutant transport model (e.g., CFD) to be used.

Because the model does not perfectly represent the building, the model introduces uncertainty into the network design process. A key feature of the approach described here is that the network designer can hedge against this uncertainty by using multiple pollutant transport models of the building. For example, one model could be tuned to match the integrated concentration in each zone (which might be most appropriate when maximizing the probability of detection), while another model could be tuned to match the estimated timing of the peaks (which might be most appropriate when minimizing the time to detection). Using multiple models would mean adding scenarios to the analysis, with the relative

confidence in each model reflected in the scenario likelihoods, $P[i]$. In the present study, we used only the convention center CONTAM model described in ⁽¹⁴⁾, since it is available for others to use in comparative sampler network design studies.

(a) Release in a reception area on the 2nd floor. From left to right, concentration profiles are shown for: 1) an adjacent atrium on the 2nd floor, 2) an atrium on the 3rd floor, 3) a reception area on the 3rd floor, and 4) a zone in Hall A. For visual clarity, the three leftmost plots are on a different vertical scale than the rightmost plot.

(b) Release in zone in Hall C. From left to right, concentration profiles are shown for: 1) an adjacent zone in Hall C, 2) another adjacent zone in Hall C, 3) a nearby zone in Hall C, and 4) a farther zone in Hall C. For visual clarity, the two leftmost plots are on a different vertical scale than the two rightmost plots.

Figure 2: Concentration profiles as predicted by the model (lines), and as measured in experiments (points). Results are for two of three experiments shown in ⁽¹⁴⁾.

3.2 Release Scenarios

The most important sources of uncertainty in designing a sampler network are the variables that affect the transport and dispersion of the chemical or biological agent: the source characteristics, environmental

conditions, and building operation. As demonstrated here, the designer can enumerate the scenarios of interest, and assign each a relative likelihood of occurrence. Alternately, the designer can define continuous distributions of parameters such as the release mass and wind speed, then sample from those distributions in order to generate probability-weighted scenarios. For clarity, in this study we consider only 60 scenarios, each consisting of one of 20 possible release locations (Table I) and one of three possible release rates (Table II). In this study, we vary only release locations and release rates, but our algorithm allows specification of scenarios that vary any uncertain parameters, such as those mentioned in Section 2.

Table I: Release location probabilities. Release locations were selected to encompass a variety of zone types and ventilation rates. Note that releases on the main floor are assumed more likely than ones on the upper floors.

Location	Count	Probability (each)
Ground Floor	16	0.0575
2nd Floor	2	0.02
3rd Floor	2	0.02

Table II: Release rate probabilities. All releases are assumed to last for 10 minutes.

Rate (g/min)	Probability
0.1	0.1
1	0.6
10	0.3

3.3 Sampler Performance

The real performance of a sampler may have a probabilistic component. Given a large amount of contaminant in the air, there is a higher chance that the sampler will detect the agent. However, due to miscalibration, fouling, noise, imperfect mixing, and so on, the presence of an agent in the room air does not guarantee detection—even above the sampler’s nominal detection threshold.

Figure 3 shows the assumed sampler performance for this study, based on simplified performance curves of actual hardware (mass units are withheld for security reasons). The probability of detection during any given sampling window depends on both the agent mass that passed through the sampler during that time, and the sensitivity of the detection equipment. We assumed ambient air is pumped through a sampler at 100 liters/minute. For this building, with large rooms and high ventilation rates, we assumed that the presence of a sampler will not affect the airflow between rooms, and will not significantly change

the well-mixed assumption within rooms.

In the analysis that follows, all samplers in a given network have the same operating curve and sampling window. However, a network could include samplers with different detection characteristics—for example, incorporating fast, sensitive samplers to detect a release quickly, along with slower, but less error-prone, samplers to confirm a release. Similarly, a network consisting of samplers with different window lengths, or with windows staggered in relation to one another, might yield a more robust network. The PASS approach can be applied to any of these options, at the cost of having to evaluate more networks in order to find the optimal one.

Figure 3: Probability of detecting an agent during a single sampling window, for high (solid), medium (dashed), and low (dotted) sensitivity of the detection equipment.

3.4 Detection Confidence

The sampler network design includes decision points for signaling an alarm, which is a part of the network *concept of operation* (ConOps). As suggested above, this may include the number and type of samplers that must alarm before taking action. The decision criterion used in this analysis is for a network to alarm as soon as at least one sampler alarms. Alternately, a network could be chosen to alarm when at

least two samplers alarm, or when at least two samplers alarm within a given time period. In cases where false alarms can be exceedingly expensive (e.g., whole-building evacuation, deployment of emergency personnel, etc.), a very high confidence criteria might be chosen, but this in turn may result in delayed detection.

It is important to distinguish between the ConOps (which determine the operation of the network after deployment) and the calculations of expected network performance during the design phase (which will determine sampler locations, but not network operation). Network designers must define a performance metric that takes the ConOps into account. For this example, we set $\beta = 0.5$ in Equation 6. In other words, for each scenario, we take T_i as the average time at which each network detects a release with at least 50% confidence.

3.5 Candidate Locations

We allow PASS to choose from among 35 possible sampler locations in the convention center, including several types of occupied zones and ventilation return ducts. In principle, any zone of the multizone model defines a possible sampler location. However, in practice the number of possible sampler networks increases sharply with the number of sampler locations the algorithm is allowed to consider. When PASS optimizes n samplers among r possible locations, it must evaluate

$$\frac{(r + n - 1)!}{(r - 1)! n!} \quad (8)$$

networks. For example, placing $n = 5$ samplers among the 35 locations we allow, defines 575,757 networks. Doubling the number of possible locations would increase the number of networks by a factor of almost 28. In the examples that follow, computing an optimal two-sampler network with 5-minute sampling windows takes less than one minute on a 2.4GHz processor with 2GB of RAM, running Mac OS X 10.5. Finding an optimal 4-sampler network takes approximately 18 minutes.

3.6 Calculations

Simulating the contaminant transport for any given scenario gives the mass that a hypothetical sampler would accumulate in each candidate location, during each sampling window. The mass is then used to determine the detection probabilities, $P[S_{i,z,w}]$, using the curves in Figure 3. Aggregating across samplers and sampling windows, Equation 3 gives the probability a network will detect the scenario, while

Equation 6 gives the time to detect at the specified confidence level (for convenience in calculating these performance metrics, the first sampling window, $w = 1$, is taken as the window in effect at the time the release begins). Finally, Equation 1 gives the network’s expected performance across all 60 scenarios. All possible networks are compared, in order to find the one with the best expected performance.

4 RESULTS

Figures 4–7 summarize the performance of the optimal networks that PASS identifies. For example, Figure 4 shows the maximum expected probability of detection, across all the networks tested, as a function of the number of samplers in the network. Similarly, Figure 5 shows the probability of detection for the best network as a function of the sampling window duration, and Figures 6 and 7 show similar plots for the networks with the fastest time to detection.

Figure 4: Expected probability of detection of best network, for varying network size, sampler sensitivity and sampling window.

4.1 Optimal Locations

Comparing the optimal networks, we saw no consistently-favored sampler locations. This contradicts ⁽¹⁾, in which maximizing the probability of detection, across networks of different sizes, tended to place more-sensitive samplers in bathrooms (to take advantage of exhaust airflows), and less-sensitive samplers in ventilation system return ducts (which effectively sample air from throughout the building).

Figure 5: Expected probability of detection of best network, for varying network size and sampling window. Results are for low sensitivity samplers. Each curve is labeled with the number of samplers in the network.

We attribute the lack of favored sampler locations in the convention center to the large airflows between zones. With no partitions between many zones, and relatively high recirculation rates, the convention center mixes quickly compared to the office-dominated building from the original study. The high mixing rate also explains why, in the convention center, many of the best networks have nearly the same expected performance: if no particular zone has a unique concentration profile, then no particular zone is critical to the sampler network’s performance.

Because many networks have similar quality, the optimal sampler locations are often non-intuitive. For example, the best two-sampler network will not necessarily place a sampler in the same zone as the best one-sampler network. Thus, a “greedy” optimization approach, in which samplers are added one by one to the previous best network, is not ideal for the sampler placement problem.

In a real design exercise, we would treat the relatively small variation in performance among many networks as an invitation to expand the scope of the investigation. Improving the scenarios considered—for example, by including new building operating conditions, better characterizing the distributions of uncertain parameters, or adding new release locations and amounts—might allow PASS to better discriminate between the expected performance of the networks. Admitting more possible sampler locations might improve the final network quality. Tightening the confidence limit for estimating T_i might reveal some networks to be more robust than others. Finally, if none of these changes affected the results

Figure 6: Expected time to detection of fastest network, for varying network size, sampler sensitivity and sampling window.

appreciably, then we would accept that many networks are near-optimal, and pick the final sampler locations based on other operational criteria (such as ease of service, or aesthetics).

4.2 Network Size

In Figures 4-7, the expected network performance improves with network size. The marginal improvement in network performance when adding a sampler is largest for small networks, and, in this application, is virtually negligible for networks with 5 or more samplers. Intuitively, allowing PASS to place more samplers improves its ability to cover all parts of the building; however, mixing by the ventilation system means that effective coverage does not demand placing a sampler in every zone.

4.3 Sampler Sensitivity

Figures 4 and 6 show that improving the sampler sensitivity improves the expected network performance (giving higher detection probability, or faster detection). This effect is more pronounced for smaller networks. However, among the smaller networks, adding a single sampler generally improves the network quality more than does increasing the sampler sensitivity by a factor of ten. This suggests using PASS to explore an interesting practical tradeoff, between cost and sensitivity, in real sampler design.

Figure 7: Expected time to detection of fastest network, for varying network size and sampling window. Results are for low sensitivity samplers. Each curve is labeled with the number of samplers in the network. The dotted line represents the maximum possible performance for a given sampling window duration (i.e., the network detects at the end of the first sampling window).

4.4 Sampling Frequency

Figures 5 and 7 show that network performance is highest for very short sampling windows and improves as the sampling windows get very long. They also show lower overall network performance for intermediate sampling window sizes. For example, in Figure 5, the detection probability for the optimal network that samples with 15-minute windows is lower than that of networks having one-minute or 30-minute windows. In Figure 7, note that this effect is relative to maximum performance—overall, shorter sampling windows yield lower absolute time to detection. This effect is more pronounced for smaller networks.

One explanation for this result may be competing attributes of an optimal network. With very short sampling windows, many samples, each of which individually may have low probability of detection, can result in a high cumulative probability of detection (see Equation 3). Conversely, with a long duration window, such as two hours, a large amount of mass is collected and that single sample results in a high probability of detection (see Figure 3). With intermediate sampling windows, the network benefits from neither many samples nor long samples, and the performance of the networks decreases.

Other possible reasons for the dip include the duration of the release, the residence time of the contaminant in the building, or when samples are taken relative to the beginning of the release. To explore

these possibilities, we conducted numerical experiments in which we varied these parameters. While none of these factors individually explained the shape of the curves in Figure 5, each had some contribution. Network designers would benefit from a rule of thumb on selecting the ideal sampling window, but further research is needed on this topic.

4.5 Air Exchange Rates

We also explored methods for choosing optimal networks in cases where a contaminant transport model of the building is not available, and would be prohibitively expensive or time-consuming to produce. Building operators may wish to estimate network performance using easily-identifiable building characteristics, either in lieu of building a model, or as a feasibility test to determine whether it is worthwhile to construct a building model.

Airborne transport is the most important mechanism for mixing chemical and biological agents through a building, and is essential to the operation of the types of samplers considered here. Furthermore, all else being equal, increasing the amount of airflow through a zone increases the chances it will receive air from a zone that contains the agent release. Therefore a natural choice for a performance predictor is the air exchange rate in each zone, information which may be easily estimated by building operators (for example, using as-built drawings of the ventilation system).

In Figures 8 and 9, the performance of a one-sampler network improves somewhat with higher air exchange rates in the zone of interest. However, there is a great deal of variability, particularly for zones with low air exchange rates. Clearly the air exchange rate for a zone is not a good proxy, at least in this building, for overall mixing of air from other parts of the building through that particular zone.

While we acknowledge that the relationship between network performance and air exchange rates is tenuous, and that the accuracy of performance predictions depends on the accuracy of air exchange rate estimates, we believe there is merit in further investigating methods to predict network performance using easily evaluated building characteristics, and plan to explore this further in future work.

5 CONCLUSION

We presented a probabilistic approach to designing an indoor sampler network for the purpose of detecting a chemical or biological agent. The design of such a network is complicated by uncertainty and variability in all aspects of the problem, including building operation modes, agent release conditions, meteorology, contaminant transport modeling, and sampler hardware behavior. These probabilistic effects

(a) Medium sensitivity samplers, 5-minute sampling window. (b) High sensitivity samplers, one-minute sampling window.

Figure 8: Probability of detection for one-sampler networks, plotted against air changes per hour in that zone, for varying sampler sensitivity and sampling window. Each circle represents one of the candidate sampler locations, and the line represents a linear fit to the data.

motivated a statistical approach that optimizes the network’s expected performance, according to the likelihood of a range of possible scenarios.

Past work on this approach maximized the probability of detecting a release. However, advances in sampler hardware have made results available more rapidly. Therefore in this work we also minimize the time to detect a release, at a prescribed level of confidence. We demonstrated our approach by designing sampler networks for a large commercial building, using a pollutant dispersion model that was tuned to experimental data from a real building.

Our approach allows comparisons between competing network design parameters and network performance. Therefore network designers can minimize the hardware, deployment, and maintenance cost of fielding a network with a given level of performance (for example, by trading one high-sensitivity sampler for several lower-cost samplers of lesser sensitivity). Similarly, the PASS methodology also could be used by sampler hardware manufacturers, to guide their designs (for example, in deciding whether to build faster or more sensitive samplers).

(a) Medium sensitivity samplers, 5-minute sampling window. (b) High sensitivity samplers, one-minute sampling window.

Figure 9: Expected time to detection for one-sampler networks, plotted against air changes per hour in that zone, for varying sampler sensitivity and sampling window. Each circle represents one of the candidate sampler locations, and the line represents a linear fit to the data.

ACKNOWLEDGMENT

This work was supported by the Office of Energy Efficiency and Renewable Energy (Solar Technologies Office) of the U.S. Department of Energy under Lawrence Berkeley National Laboratory Contract No. DE-AC02-05CH1131

REFERENCES

1. Sohn MD, Lorenzetti DM. Siting bio-samplers in buildings. *Risk Analysis*, 2007; 27(4):877-886.
2. Berry JW, Fleischer L, Hart WE, Phillips CA, Watson JP. Sensor placement in municipal water networks. *Journal of Water Resources Planning and Management*, 2005; 131(3):237-243.
3. Lohner R, Camelli F. Optimal placement of sensors for contaminant detection based on detailed 3D CFD simulations. *Engineering Computations*, 2005; 22(3-4):260-273.
4. Whicker JJ, Rodgers JC, Moxley JS. A quantitative method for optimized placement of continuous air monitors. *Health Physics*, 2003; 85(5):599-609.
5. Chen YL, Wen J. Sensor system design for building indoor air protection. *Building and Environment*, 2008; 43(7):1278-1285.
6. Chen YL, Wen J. Comparison of sensor systems designed using multizone, zonal, and CFD data for protection of indoor environments. *Building and Environment*, 2010; 45(4):1061-1071.

7. Kim J, Jung SK, Kim JT. Wireless monitoring of indoor air quality by a sensor network. *Indoor and Built Environment*, 2010; 19(1):145-150.
8. Chen Q. Ventilation performance prediction for buildings: A method overview and recent applications. *Building and Environment*, 2009; 44(4):848-858.
9. Liao C, Barooah P. An integrated approach to occupancy modeling and estimation in commercial buildings. In 2010 American Control Conference Proceedings, pages 3130-3135, Baltimore, Maryland, USA, July 2010.
10. Tennakoon M, Mayorga RV, Shirif E. A fuzzy interface system prototype for indoor air and temperature quality monitoring and hazard detection. *Journal of Environmental Informatics*, 2010; 16(2):70-79.
11. Martirano L, Aliberti M, Massarella F. Metering of energy used for lighting: A practical indirect method. In 2010 IEEE Electrical Power and Energy Conference Proceedings, pages 1-8, Halifax, Nova Scotia, Canada, August 2010.
12. Dorini G, Jonkergouw P, Kapelan Z, Savic D. SLOTS: Effective algorithm for sensor placement in water distribution systems. *Journal of Water Resources Planning and Management*, 2010; 136(6):620-628.
13. Deleawe S, Kusznir J, Lamb B, Cook DJ. Predicting air quality in smart environments. *Journal of Ambient Intelligence and Smart Environments*, 2010; 2(2):145-154.
14. Black DR, Price PN. Contam airflow models of three large buildings: Model descriptions and validation. Lawrence Berkeley National Laboratory, Technical Report, LBNL-3593E, September 2009.
15. Walton GN, Dols WS. Contam 3.0 user guide and program documentation. National Institute of Standards and Technology Technical Report, NISTIR 7251, December 2010.