## **UC** Irvine

**SSOE** Research Symposium Dean's Awards

## Title

Water Conveyance System

## Permalink

https://escholarship.org/uc/item/7xc2x5dj

## **Authors**

Cabrera, Mayra Avila, Eloy Jimenez, Matthew <u>et al.</u>

### **Publication Date**

2015-03-30

Peer reviewed





## **PROJECT DESCRIPTION**

San Diego currently imports about 90% of its total water consumption. To improve water reliability in an environment influenced by climate change the region is embarking on a program to diversify its water portfolio. This strategy includes the proposed \$2b Indirect Potable Reuse (IPR) project called Pure Water.

The Anteater Hydro-Tech Project is for the \$150m Water Conveyance System for Pure Water. The conveyance system is being optimized considering Triple Bottom Line principles: Economic, Environmental, Social

## **PIPELINE ALIGNMENT** North City Water Reclamation Plant to San Vicente Reservoir – 26 miles





Recommended Alternative: Optimizing Energy and Capital Costs, avoids energy loss at Fortuna Mountain at low flows, achieves reasonably low pressures below San Diego City's Requirement of 250 psi.

# **SENSITIVITY ANALYSIS OF PRESENT WORTH**

	Capital	Annual Power	Present Worth in \$ Million					
Pipe Size	Cost in		Discount	Pipe	Energy Escalation Rate			
Size	φινιιιιοη	φινιπιση	Rate	Size	2%	3%	4%	5%
24"	\$106.26	\$4.71		24"	\$237.32	\$258.71	\$284.58	\$315.96
30"	\$110.64	\$2.96		30"	\$193.01	\$206.46	\$222.72	\$242.45
32"	\$115.51	\$2.42	25	33" 34"	\$182.87 \$181.32	\$193.86 \$191.79	\$207.16 \$204 45	\$223.29 \$219.80
33"	\$117,19	\$2.30	2.0	36"	\$179.58	\$189.20	\$200.83	\$214.94
20"	• / • • • • •	+=		39"	\$181.61	\$190.37	\$200.96	\$213.81
30	\$120.64	\$2.12		42"	\$185.20`	\$193.41	\$203.35	\$215.40
39"	\$127.96	\$1.93		24"	\$228.12	\$247.51	\$270.90	\$299.21
42"	¢134 87	¢1 Q1		30"	\$187.23	\$199.42	\$214.12	\$231.92
12	φ134.07	φ1.01		33"	\$178.14	\$188.11	\$200.13	\$214.68
			3	34"	\$176.82	\$186.31	\$197.75	\$211.60
				36"	\$175.44	\$184.16	\$194.68	\$207.41
				39"	\$177.85	\$185.79	\$195.36	\$206.95
				42"	\$181.67	\$189.11	\$198.10	\$208.97
				24"	\$219.94	\$237.41	\$258.60	\$284.17
				30"	\$182.09	\$193.07	\$206.39	\$222.46
				33"	\$173.94	\$182.92	\$193.81	\$206.95
			3.5	34"	\$172.82	\$181.36	\$191.73	\$204.25
				36"	\$171.76	\$179.62	\$189.15	\$200.65
				39"	\$172.94	\$179.85	\$188.23	\$198.35
				42"	\$178.53	\$185.23	\$193.37	\$203.19

# **DESIGN APPROACH**

- Triple Bottom Line Optimization: Economic, Environmental, Social
- Conveyance system route elevation change minimized
- Design guiding criteria: M11 Steel Pipe Design & Installation • Pump station integration in order to eliminate tunneling needs and to fulfill flow demands.
- Minimized altering existing terrain wherever possible
- Cost analysis (Present Worth) conducted on pipeline, pump station, and energy costs in a low discount rate and variable energy escalation environment
  - Powering water infrastructure in California amounts to a concerning 20% **STEEL & PUMP STATION COST** of all electricity produced in the state. **Pipe Cost Per Foot HYDRAULIC GRADE LINE PROFILE** 800.00 -Pipeline Profile Alignment 700.00 -Optimal Design: 2 Pump Stations Alternative 1: One Pump Station **5**600.00 1200 ----Alternative 2: Three Pump Stations \$ 500.00 and the second second 400.00 300.00 Diameter (in) 200 ➡120 psi ➡180 psi ➡240 psi ➡300 psi 100000 50000 **DISTANCE** [feet] **Pump Station Cost Curve** Alternatives are at hypothetical loss of 5'/1000' 1800000.00 Alternative 1: One Pump Station alternative eliminated because of excessive head Alternative 2: Three Pump Station alternative eliminated because of free water surface with associated energy loss at Fortuna Mountain 15000000.00 Two Pump Station alternative adopted € 12000000.00 **O** 9000000.00 TIMIZING TRIPLE BOTTOM LINE 600000.00 ONOMIC Jsing multiple energy escalation and discount rate combinations for sensitivity analysis 3000000.00 Using the sensitivity analysis we can determine the optimal present worth value 1000 2000 3000 4000 5000 6000 7000 VIRONMENTAL • As the pipe diameter increases, the cost/ft increases. With increasing pressure, the curve Flat areas chosen to build pump stations in order to minimize altering mountainside shifts upwards, meaning that the cost/ft also increases. Route alignment parallel to existing roads in order to minimize altering undeveloped areas • The pump station cost curve was using 3000 (hp) pump station as a base. As the (hp) Construction methods that minimize dust emission implemented increases, the cost also increases. Energy usage optimized CIAL Provide safe, reliable water **NEXT PHASE** Minimizing community Impact Alignment designed to stay out of site whenever possible • AutoCAD drawings of horizontal & vertical alignments for pipeline design Construction time only during normal working hours • Open channel dimensions and cost Safe construction methods implemented to minimize risk to public Optimal pipeline diameter using energy escalation and discount rate model •

# Water Conveyance System

Anteater Hydro-Tech (A.H.T.) Project Manager: Mayra Cabrera, cabrerm1@uci.edu Project Engineers: Eloy Avila, Matthew Jimenez, Christian Portillo Jens Solvkjar, Chosita Sribhibhadh Faculty Mentor: Professor Stanley Grant, Ph.D

# **ASSUMPTIONS AND DESIGN CRITERIA**

# **FLOW**

- Uniform Flow
- Tri Annual Flow Magnitude Changes: 10, 15, 20 MGD every 4 months
- Additional 53 MGD flow introduced 10 years after project completion 6 miles to outlet
- 30 year planning period

# PIPELINE

- Uniform Diameter
- Uniform Diameter of 66" for common pipe • 50' surge pressure
- Free water surface at each pump station
- Hazen–Williams C factor: 120
- 250 Working Pressure–City's Preference
- Minimum wall thickness for low pressures adopted for pipeline handling stability





In Collaboration With Client Consultant: Richard Trembath



ENGINEERING

TREMBATH CONSULTING, INC.

## **COST ANALYSIS**

- ENRALA10051.3–Cost Index
- Discount Rate: 4%,5%,6%
- Wire to water efficiency range 69%, 75% and 69% for 10, 15, and 20 MGD, respectively
- Construction Cost Contingency 30%

• Specific type of pump selection and location of pump stations

- Energy Cost \$0.15 / kWhr