

Lawrence Berkeley National Laboratory

Lawrence Berkeley National Laboratory

Title

Development of procedures for refurbishing x-ray optics at the Advanced Light Source

Permalink

<https://escholarship.org/uc/item/8157s2zc>

Author

Yashchuk, Valeriy V.

Publication Date

2012-07-16

Development of procedures for refurbishing x-ray optics at the Advanced Light Source

Valeriy V. Yashchuk, Nikolay A. Artemiev, Frank Zucca,
Richard Celestre, Wayne R. McKinney, Daniel J. Merthe,
Dmitry L. Voronov, and Howard A. Padmore

Lawrence Berkeley National Laboratory, One Cyclotron Road, Berkeley, CA 94720, U.S.A.

ABSTRACT

At the Advanced Light Source (ALS), plans for re-manufacture of many of the original beamlines, some of which are now almost 20 years old, are developing. Replacement of a beamline is a costly enterprise, and hence it takes considerable time to raise the necessary funds.

In parallel with this long term program, we are developing ideas for a short term program to improve the performance of the ALS beamlines with modest improvements of the optical systems, leaving the basic beamline structure and design intact. The cost of this program that we call Light Source Upgrade of X-ray Optics for Research (LUXOR) is estimated to be on average 10% of the cost of a new beamline, and in some cases, performance increases of several orders of magnitude can be gained [1].

In the scope the LUXOR initiative, we have started at the ALS an experimental program to develop practical and robust procedures for refurbishing x-ray optics.

First, we work to optimize regimes for Ultraviolet Ozone (UVO) cleaning [2] of carbon contaminated x-ray optics. Based on comprehensive surface metrology data, we provide details of the UVO cleaning process that has allowed us to refurbish highly contaminated super polished mirror substrates. With Kirkpatrick-Baez mirrors using the refurbished substrates, we are able to reach two dimensional diffraction limited focusing [3].

Second, we investigate the possibility of in situ cleaning of contaminated x-ray optics using a cold low pressure plasma [4,5]. Recent progress in development of a test set-up based on an Evactron® De-Contaminator [6] is reported.

This work was supported by the U.S. Department of Energy under contract number DE-AC02-05CH11231.

REFERENCES

1. S. Kanel, H. Ade, D. Delongchamp, M. Chabiny, C. Wang, J. Guo, G. Snell and C. Ralston, "2011 ALS User Meeting and Workshops," *Synchrotron Radiation News* **25**(1), 4-8 (2012).
2. Jelight Company, Inc., "UVO-Cleaner studies using Jelight Company Inc. Products" (<http://www.jelight.com/applications.php>).
3. D. J. Merthe, V. V. Yashchuk, K. A. Goldberg, M. Kunz, N. Tamura, W. R. McKinney, R. S. Celestre, G. Y. Morrison, E. Anderson, B. V. Smith, E. E. Domning, H. A. Padmore, "Methodology for Optimal In Situ Alignment and Setting of Bendable Optics for Diffraction-Limited Focusing of Soft X-Rays," Abstract to SPIE Optics and Photonics 2012, Conference OP320: *Advances in Metrology for X-Ray and EUV Optics IV* (San Diego, August 12-16, 2012).
4. W. R. McKinney and P. Z. Takacs, "Plasma discharge cleaning of replica grating contaminated by synchrotron radiation." *Nucl. Instrum. and Meth.* **195**, 371-374 (1982).
5. T. O. Mueller, J. Cowan, and E. Swanson, "The Use of Oxygen in SEM Plasma Cleaning Equipment," *Proc.M&M*, 210CD (2007).
6. XEI Scientific, Inc., "The Evactron® De-Contaminator: Fast, Safe, and Reliable Remote Plasma Cleaning" (www.evactron.com).

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.