## Lawrence Berkeley National Laboratory

Lawrence Berkeley National Laboratory

## Title

Development of a detector for bunch by bunch measurement and optimization of luminosity in the LHC  $\,$ 

Permalink https://escholarship.org/uc/item/9c28p0nr

### Author

Turner, W.C.

Publication Date 2000-05-19

LBNL-45774



## ERNEST ORLANDO LAWRENCE BERKELEY NATIONAL LABORATORY

# Development of a Detector for Bunch by Bunch Measurement and Optimization of Luminosity in the LHC

W.C. Turner, M.T. Burks, P.S. Datte, P.F. Manfredi, J.E. Millaud, N.V. Mokhov, M. Placidi, L. Ratti, V. Re, H. Schmickler, and V. Speziali

## Accelerator and Fusion Research Division

May 2000

Presented at the 8th Pisa Meeting on Advanced Detectors, Isola d'Elba, Italy, May 21–27, 2000, and to be published in the Proceedings

#### DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Ernest Orlando Lawrence Berkeley National Laboratory is an equal opportunity employer.

### Development of a Detector for Bunch by Bunch Measurement and Optimization of Luminosity in the LHC\*

W.C. Turner<sup>1</sup>, M.T. Burks<sup>1</sup>, P.S. Datte<sup>1</sup>, P.F. Manfredi<sup>1,6</sup>, J.E. Millaud<sup>1</sup>, N.V. Mokhov<sup>2</sup>, M. Placidi<sup>3</sup>, L. Ratti<sup>5,6</sup>, V. Re<sup>4,6</sup>, H. Schmickler<sup>3</sup>, V. Speziali<sup>5,6</sup>

<sup>1</sup>Lawrence Berkeley National Laboratory, Berkeley, CA 94720 <sup>2</sup>Fermi National Accelerator Laboratory, Batavia, IL 60510 <sup>3</sup>CERN, Geneva, Switzerland <sup>4</sup>University of Bergamo, Bergamo, Italy <sup>5</sup>University of Pavia, Pavia, Italy <sup>6</sup>INFN, Pavia, Italy

Presented at the 8th Pisa Meeting on Advanced Detectors, Isola d'Elba, Italy May 21 - 27, 2000

\*This work was supported by the Director, Office of Science, Office of High Energy & Nuclear Physics, High Energy Physics Division, of the U.S. Department of Energy, under Contract No. DE-AC03-76SF00098.

# Development of a detector for bunch by bunch measurement and optimization of luminosity in the LHC\*

W.C. Turner<sup>1</sup>, M.T. Burks<sup>1</sup>, P.S. Datte<sup>1</sup>, P.F. Manfredi<sup>1.6</sup>, J.E. Millaud<sup>1</sup>, N.V. Mokhov<sup>2</sup>,

M. Placidi<sup>3</sup>, L. Ratti<sup>5,6</sup>, V. Re<sup>4,6</sup>, H. Schmickler<sup>3</sup>, V. Speziali<sup>5,6</sup>

<sup>1</sup>Lawrence Berkeley National Laboratory, Berkeley, CA 94720

<sup>2</sup>Fermi National Accelerator Laboratory, Batavia, IL 60510

<sup>3</sup>CERN, Geneva, Switzerland

<sup>4</sup>University of Bergamo, Bergamo, Italy

<sup>5</sup>University of Pavia, Pavia, Italy

<sup>6</sup>INFN, Pavia, Italy

(19 May 2000)

Abstract

The front IR quadrupole absorbers (TAS) and the IR neutral particle absorbers (TAN) in the high luminosity insertions of the LHC each absorb approximately 1.8TeV of forward collision products on average per pp interaction (~235W at design luminosity 10<sup>34</sup> cm<sup>-2</sup>s<sup>-1</sup>). This secondary particle flux can be exploited to provide a useful storage ring operations tool for optimization of luminosity. Novel segmented, multi-gap, pressurized gas ionization chambers are proposed for sampling the energy deposited near the maxima of the hadronic/ electromagnetic showers in these absorbers. The system design choices have been strongly influenced by optimization of signal to noise ratio and by the very high radiation environment. The ionization chambers are instrumented with state of the art low noise, fast, pulse shaping electronics capable of resolving individual bunch crossings at 40 MHz. Data on each bunch are separately accumulated over multiple bunch crossings until the desired statistical accuracy is obtained. At design luminosity approximately 2x10<sup>3</sup> bunch crossings suffice for a 1% luminosity measurement.

### **1 INTRODUCTION - REQUIREMENTS**

The IR absorbers in the LHC and the concept of instrumenting them to provide a machine operations tool for optimization of luminosity are described in previous reports.<sup>1,2</sup> The requirements of an LHC luminosity monitor for machine operations purposes were established at a mini workshop held at CERN on 15-16 Apr. 1999.<sup>3</sup> The requirements that are relevant for this report are:

- Dynamic luminosity range 10<sup>28</sup> to 10<sup>34</sup> cm<sup>-2</sup> s<sup>-1</sup> with "reasonable" integration time
- Bandwidth 40 MHz to resolve luminosity of individual bunches.

The practical consequence of these two requirements is that the luminosity instrumentation must be designed to have a dynamic range capable of measuring the signal from one to  $\sim 100$  pp interactions per bunch crossing at 40 MHz. The signal to noise ratio should be large enough to clearly separate the signal from one pp interaction from noise.

Aside from bandwidth and sensitivity requirements, an IR absorber luminosity monitor must be able to withstand very high radiation doses. The peak flux of particles of various types at the shower maximum in the TAN is given in Table 1 for design luminosity  $10^{34}$  cm<sup>2</sup>s<sup>-1</sup>. Fluxes in the TAS are similar. The cutoff energy for neutrons is .002 eV so the neutron flux includes thermal neutrons. For all other particles the cutoff energy in 0.1 MeV. The flux of neutrons with energy above 0.1 MeV is approximately 2.1x10<sup>9</sup> cm<sup>-2</sup>s<sup>-1</sup>.

Table 1: The peak flux of particles of various types at the shower maximum in the TAN at design luminosity  $10^{34}$  cm<sup>-2</sup>s<sup>-1</sup>.

| Particle type     | Flux(cm <sup>-2</sup> s <sup>-1</sup> ) |  |
|-------------------|---|--|
| Charged hadrons   | 4.7x10 <sup>8</sup>                     |  |
| Electron/positron | 7.5x10 <sup>10</sup>                    |  |
| Photons           | 1.1x10 <sup>12</sup>                    |  |
| Neutrons          | 4.6x10 <sup>9</sup>                     |  |

Additional requirements dealing with backgrounds and correlation of the apparent luminosity signal with

<sup>\*</sup> Work supported by the US Dept of Energy under contract no. DE-AC03-76SF00098.

crossing angle transverse position of the IP have been discussed in previous reports.<sup>1,4,5</sup> The device described in this report is intended to provide a relative luminosity measurement, calibrated against a particle detector (ATLAS, CMS or TOTEM) or by use of simultaneous measurements of bunch intensity and rms beam radius.

### **2 CHOICE OF DETECTOR**

The following detectors have been considered for the application described in this paper: CVD diamond, water Cerenkov, transition radiation, liquid Ar ionization and gas ionization.<sup>6</sup> CVD diamond begins to degrade at 2-5x10<sup>15</sup> hadrons/cm<sup>2</sup> which, for the fluxes given in Table 1. leads to impractically short operation times.<sup>7</sup> Water Cerenkov and transition radiation detectors are very fast but awkward to implement because of the requirement of transporting photons out of the IR absorbers to a region where photomultipliers could withstand the radiation. A liquid Ar detector could perhaps meet the radiation tolerance requirement but the 85K cryogenics required is difficult to deal with in the IR absorbers and low ion mobility leads to space charge problems at high luminosity. We have therefore chosen a gas ionization chamber filled with a mizture of Ar and N, as the simplest detector that can meet the requirements.

### **3 OPTIMIZATION**

The design of the ionization chamber and front end electronics have been optimized for meeting the noise, bandwidth and radiation requirements. A 3-m radiation hard cable between the ionization chamber and front end electronics is needed in order to locate the solid state devices in a low radiation zone (< 100 Gy/yr). The bipolar transistor was chosen as the device for the front end amplifier on the basis of low noise and the possibility of utilizing a cold cable termination.<sup>8</sup> The front end amplifier is followed by a pulse shaper to restore the signal to the baseline before the arrival of the next bunch. Neglecting the presence of a cable connecting the ionization chamber to the front end amplifier, the maximum signal to noise ratio for such devices may be expressed as

$$\left(\frac{S}{N}\right)^{2} = \frac{N_{gap}Q_{gap}^{2}}{2kTC_{gap}\left(\frac{a_{1}a_{3}}{\beta}\right)^{1/2} * \sigma^{2}}.$$
 (1)

where  $N_{gsp}$  is the number of gaps in the ionization chamber,  $Q_{gsp}$  is the charge collected in a single gap,  $C_{gsp}$ is the capacitance of a single gap.<sup>9</sup> The transistor current gain is  $\beta$  (~100);  $a_1$  and  $a_3$  are additional dimensionless transistor parameters with values near unity. The ballistic deficit  $\sigma \sim 2.8$  describes the loss of signal due to the ratio of the transit time of electrons (~ 20ns) to the shaping time ( $\tau \sim 2ns$ ). One notes from Eqn. 1 that the most sensitive parameter for controlling the signal to noise ratio is  $Q_{gsp}$ . Since the area, width and therefore the capacitance and volume of a gap are fixed by transit time and geometrical constraints the primary means for changing  $Q_{ssp}$  is the pressure of the gas.

The signal to noise ratio in the presence of a cable connecting the detector and electronics is controlled by two parameters, the cable delay time  $\theta$  and the shaping time  $\tau$ , each normalized to the rise time of the chamber capacitance  $C_d$  connected to the cable impedance  $R_0$ .

$$\gamma = \frac{\theta}{R_0 C_d}$$

$$\delta = \frac{\tau}{R_0 C_d}$$
(2)

The detector capacitance  $C_d = (N_p/N_s)C_{gap}$  is the capacitance of a single gap multiplied by the number of gaps in parallel  $(N_p)$  and divided by the number in series  $(N_s)$ . The total number of gaps  $N_{gap} = N_p * N_s$ . In order that the ratio of signal to noise not be degraded by the cable with  $\gamma > 1$ , we must choose  $\delta \sim 1$ .

### 4 IONIZATION CHAMBER PARAMETERS

The parameters of the ionization chamber have been determined by specifying S/N ~ 6 for 1 pp interaction,  $\delta$ ~ 1 and a equivalent noise charge ~  $4.4 \times 10^3$  e for 1 pp interaction. Parameters of the ionization chamber are given in Table 2. An illustration of the ionization chamber is given in Fig. 1. The total area of the detector is constrained to 80mmx80mm by the distance between the beams in the TAN and further divided into quadrants to allow measurement of the beam crossing angle at the IP. The parameters in Table 2 refer to a single quadrant 40mmx40mm. The chamber operating pressure is 4 atmospheres with gap voltage 150V to achieve saturation electron drift velocity 2.3cm/µs in Ar+1%N<sub>2</sub>. The plate gap is chosen to be 0.5mm so the electron transit time 21.7ns plus 2ns shaping time is less than the 25ns between bunches. The total number of gaps is 60 with six series groups of ten in parallel. The MARS code has been used to simulate hadronic/electromagnetic shower production at the position of the detectors.<sup>10</sup> To good approximation a single pp interaction produces 268 minimum ionizing particles which in ten gaps produce 5.2x10<sup>4</sup> ionization pairs. The corresponding induced electron charge collected is 2.6x10<sup>4</sup>e. At design luminosity 10<sup>34</sup> cm<sup>-2</sup>s<sup>-1</sup> the average number of pp interactions is 20 per bunch crossing and the average signal is twenty times larger.

| Property   | Value                                   |                                |  |
|--|---|--------------------------------|--|
| Active Area (1 quadrant)   | 40mm x 40mm                             |                                |  |
| Plate gap  | 0.5mm                                   |                                |  |
| No. of gaps  | 60(electrically 10 parallel x 6 series) |                                |  |
| Capacitance per gap  | 28.3pF                                  |                                |  |
| Gas  | Ar+1%N <sub>2</sub> , 4x760 Torr        |                                |  |
| Gap voltage  | 150V                                    |                                |  |
| Electron gap transit time  | 21.7ns                                  |                                |  |
| Bunch freq/Rev freq  | 40.079MHz/11.2455kHz                    |                                |  |
| Bunch structure  | 12x(3x81+2x8+38)=3564                   |                                |  |
| Inel pp int/bunch xing @ 10 <sup>34</sup> cm <sup>-2</sup> s <sup>-1</sup> | 20                                      |                                |  |
| mip per pp int   | 268                                     |                                |  |
| mip per bunch xing @ $10^{34}$ cm <sup>-2</sup> s <sup>-1</sup>            | 5.35x10 <sup>3</sup>                    |                                |  |
| Electron-ion pairs/cm-mip  | 388                                     |                                |  |
| Ioniz e'/pp int  | 5.2x10 <sup>3</sup> (1 gap)             | 5.2x10 <sup>4</sup> (10 gaps)  |  |
| Ioniz e-/bunch xing @ 10 <sup>34</sup> cm <sup>-2</sup> s <sup>-1</sup>    | 1.04x10 <sup>5</sup> (1 gap)            | 1.04x10 <sup>6</sup> (10 gaps) |  |

Table 2: Properties of the ionization chamber.



Fig. 1: Illustration of the multi-plate ionization chamber.

A prototype ionization chamber and front end electronics package have been fabricated. The equivalent

noise charge has been measured to be ~  $4.4 \times 10^3$ e per pulse thus achieving the desired S/N ~ 6 for a signal corresponding to 1pp interation. The prototype will be tested in the Summer of 2000 in showers produced by 450 GeV protons extracted from the SPS and incident on a SS absorber. Provisions have been made for collecting the ion charge as well as electrons.

### **AKNOWLEDGEMENT**

The authors would like to thank David Nygren and Jozsef Ludwig for their very helpful participation in the early stages of defining the hardware for this project.

### REFERENCES

- W. Turner, E.H. Hoyer and N.V. Mokhov, "Absorbers for the High Luminosity Insertions of the LHC", Proc. of EPAC 98, Stockholm, 1998, pg. 368.
- [2] W.C. Turner, "Instrumentation for the Absorbers in the Low Beta Insertions of LHC", LBNL-42180, (13 Aug. 1998).
- [3] See H. Schmickler, "Summary Comments" in Proc. Of Tools for Luminosity Optimisation in the LHC, 15-16 Apr. 1999, CERN, Geneva. The proceedings can be found on the web site:

http://www.cern.ch/CERN/Divisions/SL/groups/bi/c onferences/Lworksho/Lworkshop.html

- [4] W.C. Turner, "The effect of TAN z location on the relative luminosity signal and the correlations of apparent luminosity with crossing angle and IP position", LBNL CBP Tech. Note 203, 27 Mar. 2000.
- [5] W. Turner, P. Datte, P.F. Manfredi, J. Millaud, N. Mokhov, M. Placidi, V. Re and H. Schmickler, "Status report on the development of instrumentation for bunch by bunch measurement and optimization of luminosity in the LHC", LBNL-45549. Proc. Of US-LHC Meeting on Accelerator Physics for Future Hadron Colliders, BNL, 22-23 Feb. 2000. http:///www.rhichome.bnl.gov/LHC/org/Beam2000/i ndex.html
- [6] P. Datte, J. Ludwig, P.F. Manfredi, J.E. Millaud, D.R. Nygren and W.C. Turner, "Preliminary Design Considerations on the LHC Beam Monitor", LBNL internal report dated 13 Dec. 1999.
- [7] D. Meier et al, Nucl. Inst. And Methods, 426, 173. (1999)

- [8] E. Gatti and P.F. Manfredi, IEEE Trans. Nucl. Sci., Vol. NS-25, 66. (1978)
- [9] P.F. Manfredi, V. Speziali and F. Svelto, Rev. Sci. Inst., 65, 3848. (1994)
- [10] N. Mokhov, "MARS Code Developments, Benchmarking and Applications", Proc. ICRS-9 Intl. Conf. on Radiation Shielding", Tsukuba, Japan, Oct. 1999, and references therein. <u>http://www-ap.fnal.gov/~mokhov/papers/2000/</u> Fermilab-Conf-00-066.ps