

# Lawrence Berkeley National Laboratory

## Recent Work

### Title

Integrated Estimation of Commercial Sector End-Use Load Shapes and Energy Use Intensities, Phase II (Appendices)

### Permalink

<https://escholarship.org/uc/item/9wv1771z>

### Authors

Akbari, H.

Rainer, L.

Eto, J.

### Publication Date

1991



# Lawrence Berkeley Laboratory

UNIVERSITY OF CALIFORNIA

## APPLIED SCIENCE DIVISION


### Integrated Estimation of Commercial Sector End-Use Load Shapes and Energy Use Intensities, Phase II

Final Report

Appendices

H. Akbari, L. Rainer, and J. Eto

January 1991



APPLIED SCIENCE  
DIVISION

### DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. Neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or The Regents of the University of California and shall not be used for advertising or product endorsement purposes.

This report has been reproduced directly  
from the best available copy.

Available to DOE and DOE Contractors  
from the Office of Scientific and Technical Information  
P.O. Box 62, Oak Ridge, TN 37831  
Prices available from (615) 576-8401, FTS 626-8401

Available to the public from the  
National Technical Information Service  
U.S. Department of Commerce  
5285 Port Royal Road, Springfield, VA 22161

Lawrence Berkeley Laboratory is an equal opportunity employer.

LBL-30401  
UC-350  
Part 2 of 2

## **Integrated Estimation of Commercial Sector End-Use Load Shapes and Energy Use Intensities, Phase II**

*Final Report  
Appendices*

January 1991

Prepared for  
California Energy Commission  
and  
California Institute for Energy Efficiency

Prepared by  
Hashem Akbari, Leo Rainer, and Joseph Eto  
Energy Analysis Program  
Applied Science Division  
Lawrence Berkeley Laboratory  
University of California  
Berkeley, CA 94720

This report has been reproduced directly from the best available copy.

This research was sponsored by the California Energy Commission through the California Institute for Energy Efficiency (CEC Contract No. 300-88-004), and by the Assistant Secretary for Conservation and Renewable Energy, Office of Building and Community Systems of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.



## Table of Contents

Title	Description	Page
	Abstract .....	i
	Executive Summary .....	ii
	List of Tables .....	viii
	List of Figures .....	x
Chapter I	Introduction .....	1
Chapter II	Methodology and Data .....	4
Chapter III	Prototype Building Descriptions and DOE-2 Building Simulations .....	14
Chapter IV	Whole-Building Load Shapes .....	34
Chapter V	Reconciling End-Use EUIs and Load Shapes .....	54
Chapter VI	Developing EUIs for the CEC Forecasting Model ...	97
Chapter VII	References .....	118
 <b>Appendices (under separate cover)</b> 		
Appendix A	Memo on Re-examination of Phase I EUIs for Large Office, Large Retail, and Small Retail and Replacement Tables for LBL-27512.....	1
Appendix B	DOE-2 BDL Prototype Input Files .....	22
Appendix C	Summaries of LRD.....	60
Appendix D	Results from Load-Temperature Regressions.....	79
Appendix E	THI Matrices for Cooling .....	96



**Appendix A. Memo on Re-examination of Phase I EUIs for Large Office, Large Retail, and Small Retail and Replacement Tables for LBL-27512**



## CEC EUI/LS Phase II Project

Revised End Use EUIs and Load Shapes for:  
Large Office, Large Retail, and Small Retail

Discussion Notes Prepared for CEC Review  
(May 8, 1990)

One of the outstanding issues from the Phase I project was the validity of the resultant end-use EUIs and load shapes for small office, large office, large retail, and small retail buildings. Phase I resultant EUIs for these building categories were considered at variance compared to other utility data. The EUIs of the Phase I project was obtained from utility bills of a sample of 375 buildings in Southern California. The average whole-building electric EUIs calculated from the sample utility bills were different for these building types. A reanalysis of the end-use EUIs and LSs for these three buildings was postponed to Phase II (the current Phase) of the project.

As we have discussed in the Phase I Final Report, whole-building EUIs are "control" figures for the reconciliation process; they are used to estimate end-use EUIs and LSs subject to the condition that the total of all end-use EUIs for a building type would be the same as the controlling whole-building EUIs. The whole-building EUIs were calculated by weighting and averaging the electric bills for the on-site survey premises. Small sample sizes and uncertain weights may have led to whole-building EUIs for these building types that were different from other utility data sources.

In collaboration with CEC project staff, we have reviewed the available whole-buildings EUIs for these building categories in order to arrive at a set of acceptable whole-building EUIs for

the reconciliation process. These notes summarize our conclusions. We have also carried out the process of reconciliation for these buildings and obtained a new set of end-use EUIs and LSs.

### **Whole-Building EUIs**

As we have stated in our February 23, 1990 memo to CEC, several sources for whole-building EUIs were considered including: LBL analysis of the SCE 1985 mail survey, CEC analysis of the SCE 1988 mail survey, CEC analysis of SCE 1987 and 1988 QFER data, and SCE analysis of its 1988 accounts by SIC code (provided by Tim Tutt on February 22, 1990). The following whole-building EUIs were adopted:

Small Retail	12.2 kWh/sf
Large Retail	18.2 kWh/sf

Although, initially, it was planned to reanalyze the small office buildings, at the February 23 meeting, it was decided not to proceed with the reanalysis. This decision was based on additional data supporting the Phase I whole-building EUI for small offices.

For large offices, LBL was charged to review the available data and prepare a memo proposing whole-building EUIs. This note is intended to replace that memo.

Available Data. SCE analysis of 1988 accounts (S1) estimates a whole-building EUI for large offices of 19.8 kWh/sf. (S1 also estimates a whole-building EUI for small offices of 12.6 kWh/sf; we will use this data later on to justify our conclusions.) CEC estimates whole-building EUIs for all offices from 1986 (S2) and 1987 (S3) data of 16.2 and 16.5 kWh/sf, respectively. CEC

preliminary analysis of 1988 SCE mail data (S4) has resulted in a whole-building EUI for large offices of 11.0 kWh/sf. (S4 also estimates a whole-building EUI for small offices of 15.9 kWh/sf; we will use this data later on to justify our conclusions.) The following table summarizes these data sources

Code	Description	Large Offices	Small Offices	All Offices
----	-----	-----	-----	-----
S1	SCE 1988 accounts	19.8	12.6	
S2	CEC 1986 analysis			16.2
S3	CEC 1987 analysis			16.5
S4	CEC 1988 analysis	11.0	15.9	

Review and Recommendation. If we calculate the whole-building EUIs for all office buildings from S1 and S4, using the estimates of floor areas for large offices (241 Msf) and small offices (125 Msf) in the SCE service area, the resulting EUIs will be 17.4 and 12.7 kWh/sf. A quick comparison of all-office EUIs from these sources indicate that difference between S1, S2, and S3 are less than 7%. However, the difference between S4 and all other sources is 20% - 27%. (S1 is used as the basis for estimating percent differences.)

To understand these differences better, we reviewed the S4 data in further details. Cumulative frequency plot of the floor areas for large offices in this data set indicated that close to 35% of records are buildings with less than 10,000 sf; 25% are less than 6,500 sf; and 50% less than 23,000 sf (See **Figure 1**). There appears to be some errors in the data base which need to be filtered. Cumulative frequency plots for the EUIs also indicated that about 25% of large offices have EUIs less than 6 kWh/sf and about 10% have unusually large EUIs (> 50 kWh/sf).

To preliminary check the impact of these possible data errors on EUIs, we **arbitrarily** dropped the lower and upper 25% of the data points and noticed that the average EUI increased to 14.6 kWh/sf. A step in the right direction!

In summary, it is obvious that data source S4 needs to be cleaned up and cannot be considered as reliable. Also, the differences between S1, S2, and S3 are fairly minimal. Therefore, to be consistent with sources for small and large retail whole-building EUIs, **we propose using S1, EUI = 19.8 kWh/sf, as the controlling whole-building EUI for reconciliation process.**

### Results

We applied the EDA, discussed in detail in Phase I final report, to obtain individual end use EUIs and LSs. Since, the whole building EUIs reflect the energy intensity of the entire SCE service area, we needed to adjust these EUIs to estimate EUIs for each climate zones. We used adjustment factors derived from DOE-2 simulations as discussed in Phase I final report. The adjustment factors by climate zones are:

Building Type	LAX	BUR	NOR
-----	-----	-----	-----
Large Office	0.95	1.00	1.06
Large Retail	0.97	0.99	1.06
Small Retail	0.96	0.99	1.06

The adjusted whole-building EUIs are then used to estimate end-use EUIs and load shapes. **Table 1** summarizes the 'new' end-use EUIs and compares them with those report in Phase I report ('old'). The annual average daily load shapes for standard and non-standard days for these building types are **estimated and**

plotted on **Figures 2(a&b)** for large offices, **Figures 3(a&b)** for large retails, and **Figures 4(a&b)** for small retails.

Upon CEC's review and approval of the 'new' EUIs and load shapes, we will calculate THI matrixes for these building types and transfer the data electronically to CEC.

**Table 1. Reconciled Electricity EUIs (kWh/ft<sup>2</sup>-yr) for Large Offices, Large Retails, and Small Retails for Climate Zone 1 (LAX), Zone 2 (BUR) and Zone 3 (NOR). A comparison of 'new' and 'old' EUIs.**

	Indoor Lighting	Outdoor Lighting	Misc. Equip.	Refrig.	Cooking	Water Heating	Ventilation <sup>1</sup>	Cooling <sup>1</sup>	Total	
Large Office (old)	11.93	2.11	4.28	0.10	0.00	0.16	3.09	3.93	24.54	LAX
							3.30	3.91	25.94	BUR
							3.45	5.11	27.58	NOR
(new)	9.05	1.61	3.21	0.10	0.00	0.12	2.45	3.01	18.75	LAX
							2.60	3.00	19.82	BUR
							2.72	3.91	21.07	NOR
Small Retail (old)	7.49	1.59	1.48	0.95	0.01	0.04	1.67	5.45	17.21	LAX
							1.82	6.54	17.40	BUR
							2.04	11.15	18.81	NOR
(new)	4.71	1.36	0.91	0.94	0.01	0.03	1.17	3.68	11.84	LAX
							1.26	4.40	11.97	BUR
							1.43	7.57	12.94	NOR
Large Retail (old)	12.21	1.47	1.12	0.61	0.19	0.02	3.41	5.79	22.50	LAX
							3.71	4.94	22.76	BUR
							3.61	7.65	24.48	NOR
(new)	9.44	1.14	0.87	0.61	0.17	0.02	2.65	4.52	17.64	LAX
							2.88	3.86	17.84	BUR
							2.81	5.97	19.19	NOR

1. Cooling and ventilation EUIs were estimated separately for the Coastal region (represented by Los Angeles Airport weather), the Inland region (represented by Hollywood-Burbank Airport weather), and the Desert region (represented by Norton Air Force Base weather), in descending order.


**Table 1. Reconciled Electricity EUIs (kWh/ft<sup>2</sup>-yr) for Large Offices, Large Retail, and Small Retail for Climate Zone 1 (LAX), Zone 2 (BUR) and Zone 3 (NOR). A comparison of 'new' and 'old' EUIs.**

	Indoor Lighting	Outdoor Lighting	Misc. Equip.	Refrig.	Cooking	Water Heating	Ventilation <sup>1</sup>	Cooling <sup>1</sup>	Total							
Large Office (old)	11.93	2.11	4.28	0.10	0.00	0.16	3.09	3.93	24.54	LAX						
							3.30	3.91	25.94	BUR						
							3.45	5.11	27.58	NOR						
(new)	8.67	1.44	3.06	0.10	0.00	0.12	2.45	3.01	18.75	LAX						
							9.18	1.66	3.26	0.09	0.00	0.12	2.60	3.00	19.82	BUR
							9.29	1.72	3.32	0.10	0.00	0.13	2.72	3.91	21.07	NOR
Avg.	9.05	1.61	3.21	0.10	0.00	0.12										
Small Retail (old)	7.49	1.59	1.48	0.95	0.01	0.04	1.67	5.45	17.21	LAX						
							1.82	6.54	17.40	BUR						
							2.04	11.15	18.81	NOR						
(new)	5.12	1.52	1.01	0.95	0.01	0.03	1.17	3.68	11.84	LAX						
							4.88	1.43	0.95	0.94	0.01	0.03	1.26	4.40	11.97	BUR
							4.12	1.14	0.78	0.93	0.01	0.02	1.43	7.57	12.94	NOR
Avg.	4.71	1.36	0.91	0.94	0.01	0.03										
Large Retail (old)	12.21	1.47	1.12	0.61	0.19	0.02	3.41	5.79	22.50	LAX						
							3.71	4.94	22.76	BUR						
							3.61	7.65	24.48	NOR						
(new)	9.25	1.08	0.85	0.61	0.17	0.02	2.65	4.52	17.64	LAX						
							9.70	1.12	0.89	0.61	0.17	0.02	2.88	3.86	17.84	BUR
							9.37	1.21	0.87	0.61	0.18	0.02	2.81	5.97	19.19	NOR
Avg.	9.44	1.14	0.87	0.61	0.17	0.02										

1. Cooling and ventilation EUIs were estimated separately for the Coastal region (represented by Los Angeles Airport weather), the Inland region (represented by Hollywood-Burbank Airport weather), and the Desert region (represented by Norton Air Force Base weather), in descending order.

# 'Igoff'

## 'StandardDayLoadShapes'





# 'Igoff'

## 'NonstandardDayLoadShapes'





Fig 3a

# 'Igret'

## 'StandardDayLoadShapes'



# 'Igret'

## 'NonstandardDayLoadShapes'





Fig 4a


# 'smret'

## 'StandardDayLoadShapes'



# 'smret'

## 'NonstandardDayLoadShapes'



## **Guide to the Replacement Tables for LBL-27512 rev.**

The following pages contain revised tables for the Phase I report, LBL-27512 rev. These tables are intended to be wholly substituted for those in the Phase I report. That is the table numbering corresponds exactly to that used in the Phase I report.

There are four replacement tables:

1. Table VIII-30 contains new reconciled cooling EUIs for large office, small retail, and large retail (based on the re-analysis reported in this Appendix). In addition, all U75 values have been re-expressed in kBtu/sqft.
2. Table VIII-31 contains new values for non-electric heating U75s for food store, non-refrigerated warehouse, and restaurant. This corrects a calculation error in the Pcontainsse I report.
3. Table VIII-32 contains new reconciled ventilation EUIs for large office, small retail, and large retail (based on the re-analysis reported in this Appendix).
4. Table VIII-33 contains new reconciled indoor lighting, outdoor lighting, miscellaneous equipment, refrigeration, cooking, and water heating EUIs for large office, small retail, and large retail (based on the re-analysis reported in this Appendix).

**Table VIII-30. Cooling EUIs for 1975 and 1980 Vintages**  
(changes from original in boldface)

	Recon EUI	Load <sub>Proto</sub> <sup>1</sup> EUI <sub>Proto</sub>	Load <sub>1975</sub> <sup>2</sup> Load <sub>Proto</sub>	Fuel Type	1975 EUI <sup>3,4</sup>	Load <sub>1980</sub> <sup>5</sup> Load <sub>1975</sub>
Sm Off LAX	2.77	2.48	0.94	Elec.	<b>6.76</b>	0.91
				Gas	<b>57.01</b>	
				Other	<b>37.40</b>	
Sm Off BUR	5.80	2.36	0.98	Elec.	<b>14.02</b>	0.84
				Gas	<b>118.16</b>	
				Other	<b>77.49</b>	
Sm Off NOR	8.92	2.19	0.97	Elec.	<b>19.86</b>	0.92
				Gas	<b>167.36</b>	
				Other	<b>109.76</b>	
Lg Off LAX	<b>3.01</b>	3.48	1.98	Elec.	<b>21.71</b>	0.38
				Gas	<b>182.86</b>	
				Other	<b>119.94</b>	
Lg Off BUR	<b>3.00</b>	3.41	1.82	Elec.	<b>19.49</b>	0.40
				Gas	<b>164.15</b>	
				Other	<b>107.67</b>	
Lg Off NOR	<b>3.91</b>	3.22	1.72	Elec.	<b>22.66</b>	0.47
				Gas	<b>190.92</b>	
				Other	<b>125.23</b>	
Sm Ret LAX	<b>3.68</b>	2.51	0.92	Elec.	<b>8.97</b>	0.97
				Gas	<b>62.62</b>	
				Other	<b>49.14</b>	
Sm Ret BUR	<b>4.40</b>	2.38	0.94	Elec.	<b>10.39</b>	0.87
				Gas	<b>72.54</b>	
				Other	<b>56.93</b>	
Sm Ret NOR	<b>7.57</b>	2.21	0.95	Elec.	<b>16.77</b>	0.90
				Gas	<b>117.12</b>	
				Other	<b>91.91</b>	
Lg Ret LAX	<b>4.52</b>	2.80	1.17	Elec.	<b>15.63</b>	0.75
				Gas	<b>109.12</b>	
				Other	<b>85.63</b>	
Lg Ret BUR	<b>3.86</b>	2.72	1.18	Elec.	<b>13.07</b>	0.72
				Gas	<b>91.30</b>	
				Other	<b>71.65</b>	
Lg Ret NOR	<b>5.97</b>	2.59	1.13	Elec.	<b>18.44</b>	0.84
				Gas	<b>128.76</b>	
				Other	<b>101.04</b>	

**Table VIII-30. Cooling EUIs cont.<sup>6</sup>**  
 (changes from original in boldface)

	Recon EUI	Load <sub>Proto</sub> <sup>1</sup> EUI <sub>Proto</sub>	Load <sub>1975</sub> <sup>2</sup> Load <sub>Proto</sub>	Fuel Type	1975 EUI <sup>3,4</sup>	Load <sub>1980</sub> <sup>5</sup> Load <sub>1975</sub>
NonRef Ware LAX	1.16	2.56	0.85 0.96 <sup>5</sup>	Elec.	<b>2.87</b>	0.82
				Gas	<b>18.19</b>	
				Other	<b>13.96</b>	
BUR			1.01	Elec.	<b>3.04</b>	0.80
				Gas	<b>19.24</b>	
				Other	<b>14.77</b>	
NOR			1.04	Elec.	<b>3.07</b>	0.67
				Gas	<b>19.65</b>	
				Other	<b>15.08</b>	
Ref Ware LAX	2.82	2.27	0.97 0.79	Elec.	<b>5.77</b>	0.73
				Gas	<b>36.71</b>	
				Other	<b>28.18</b>	
BUR			0.85	Elec.	<b>6.24</b>	0.80
				Gas	<b>39.75</b>	
				Other	<b>30.50</b>	
NOR			1.19	Elec.	<b>8.73</b>	0.72
				Gas	<b>55.65</b>	
				Other	<b>42.72</b>	
Restaurant LAX	12.25	2.55	0.88 0.94	Elec.	<b>24.57</b>	0.96
				Gas	<b>177.01</b>	
				Other	<b>149.55</b>	
BUR			0.94	Elec.	<b>24.57</b>	0.93
				Gas	<b>177.01</b>	
				Other	<b>149.55</b>	
NOR			1.15	Elec.	<b>30.03</b>	1.04
				Gas	<b>216.32</b>	
				Other	<b>182.78</b>	



### Notes for Table VIII-30

1. Developed from DOE-2 simulations of the NELDIG prototype.
2. Developed using an additional simulation of the prototype modified for the 1975 vintage.
3. Calculated using CEC weighted average energy conversion efficiencies by fuel type: electricity, gas, and other.
4. **Converted to kBtu/ft<sup>2</sup>yr using a conversion factor of 3.412 kBtu/kWh.**
5. Because reconciliation was not performed separately for each climate region, climate variation is introduced by multiplying the 1975 EUI (one column to the right and above) by this ratio, which was developed using additional DOE-2 simulations of the prototype in each climate region.
6. Food stores showed no cooling load in the simulations of the NELDIG prototype; consequently, all temperature-sensitive load was assigned to refrigeration, and the cooling EUI was set to zero.

**Table VIII-31. Heating EUIs cont.<sup>5</sup>**  
 (changes to original in **boldface**)

	NELDIG EUI	Load <sub>Proto</sub> / EUI <sub>Proto</sub>	Load <sub>1975</sub> / Load <sub>Proto</sub> <sup>1</sup>	Fuel Type	1975 EUI	Load <sub>1980</sub> / Load <sub>1975</sub> <sup>3</sup>
Food Store LAX <sup>4</sup>	2.44	0.74	1.17	Elec.	3.90	1.00
			1.00	Gas	<b>10.93</b>	
				Other	<b>10.93</b>	
BUR			1.00	Elec.	3.90	1.00
				Gas	<b>10.93</b>	
				Other	<b>10.93</b>	
NOR			1.00	Elec.	3.90	1.00
				Gas	<b>10.93</b>	
				Other	<b>10.93</b>	
NonRef Ware LAX	1.48	0.74	0.91	Elec.	1.02	1.00
			1.00	Gas	<b>1.58</b>	
				Other	<b>1.58</b>	
BUR			1.00	Elec.	1.02	1.00
				Gas	<b>1.58</b>	
				Other	<b>1.58</b>	
NOR			1.00	Elec.	1.02	1.00
				Gas	<b>1.58</b>	
				Other	<b>1.58</b>	
Restaurant LAX	5.47	0.74	1.58	Elec.	6.92	1.02
			0.99	Gas	<b>11.36</b>	
				Other	<b>11.36</b>	
BUR			1.00	Elec.	6.94	1.08
				Gas	<b>11.39</b>	
				Other	<b>11.39</b>	
NOR			1.01	Elec.	6.98	1.05
				Gas	<b>11.45</b>	
				Other	<b>11.45</b>	

**Table VIII-32. Ventilation EUIs for 1975 and 1980 Vintages**  
(changes to original in boldface)

	Reconciled EUI	1975/ <sup>1</sup> Prototype	1975 EUI (kWh/ft <sup>2</sup> -yr)	1975 EUI (kBtu/ft <sup>2</sup> -yr)	1980/ <sup>2</sup> 1975
Small Office LAX	0.97	0.93	0.90	3.08	1.02
Small Office BUR	1.38	0.97	1.34	4.58	0.97
Small Office NOR	1.23	0.98	1.20	4.09	0.98
Large Office LAX	<b>2.45</b>	1.52	<b>3.72</b>	<b>12.71</b>	0.36
Large Office BUR	<b>2.60</b>	1.49	<b>3.87</b>	<b>13.22</b>	0.37
Large Office NOR	<b>2.72</b>	1.47	<b>4.00</b>	<b>13.64</b>	0.38
Small Retail LAX	<b>1.17</b>	0.92	<b>1.08</b>	<b>3.67</b>	1.04
Small Retail BUR	<b>1.26</b>	0.94	<b>1.18</b>	<b>4.04</b>	1.01
Small Retail NOR	<b>1.43</b>	0.95	<b>1.36</b>	<b>4.64</b>	1.02
Large Retail LAX	<b>2.65</b>	1.05	<b>2.78</b>	<b>9.49</b>	0.97
Large Retail BUR	<b>2.88</b>	1.05	<b>3.02</b>	<b>10.32</b>	0.96
Large Retail NOR	<b>2.81</b>	1.05	<b>2.95</b>	<b>10.07</b>	0.96

1. Based on DOE-2 simulations of the NELDIG prototype and a prototype modified for the 1975 vintage.
2. Based on DOE-2 simulations of the 1975 vintage prototype and a prototype modified for the 1980 vintage.

**Table VIII-33. Electric Non-HVAC EUIs for 1975 Vintage**  
(changes to original in **boldface**)

	In Light	Ex Light	Misc Eq	Refrig	Cook	Water Ht
Reconciled EUIs (kWh/ft <sup>2</sup> )						
Small Office	5.47	1.24	3.59	0.23	0.04	0.12
Large Office	<b>9.05</b>	<b>1.61</b>	<b>3.21</b>	<b>0.10</b>	<b>0.00</b>	<b>0.12</b>
Small Retail	<b>4.71</b>	<b>1.36</b>	<b>0.91</b>	<b>0.94</b>	<b>0.01</b>	<b>0.03</b>
Large Retail	<b>9.44</b>	<b>1.14</b>	<b>0.87</b>	<b>0.61</b>	<b>0.17</b>	<b>0.02</b>
Food Store	11.96	2.01	1.77	23.17	0.24	0.03
Ref Ware	3.02	0.55	6.24	11.34	0.01	0.17
NonRef Ware	3.38	0.17	0.70	0.41	0.00	0.03
Restaurant	7.94	4.09	4.89	10.78	4.46	0.03
Saturation from on-site survey and sampling weights (%) <sup>1</sup>						
Small Office	1.00	1.00	1.00	0.77	0.16	0.42
Large Office	1.00	1.00	1.00	0.81	0.43	0.28
Small Retail	1.00	1.00	1.00	0.79	0.10	0.26
Large Retail	1.00	1.00	1.00	0.99	0.56	0.14
Food Store	1.00	1.00	1.00	1.00	0.27	0.13
Ref Ware	1.00	1.00	1.00	1.00	0.66	0.73
NonRef Ware	1.00	1.00	1.00	0.83	0.00	0.76
Restaurant	1.00	1.00	1.00	1.00	0.90	0.02
1975 EUIs (kBtu/ft <sup>2</sup> ) <sup>2</sup>						
Small Office	19.95	4.51	7.84	1.10	1.03	1.05
Large Office	<b>33.04</b>	<b>5.88</b>	<b>7.01</b>	<b>0.45</b>	<b>0.00</b>	<b>1.56</b>
Small Retail	<b>17.20</b>	<b>4.97</b>	<b>2.51</b>	<b>4.34</b>	<b>0.37</b>	<b>0.42</b>
Large Retail	<b>34.46</b>	<b>4.16</b>	<b>2.40</b>	<b>2.25</b>	<b>1.11</b>	<b>0.52</b>
Food Store	43.66	7.34	4.86	84.59	3.27	0.84
Ref Ware	11.03	2.01	17.14	41.40	0.06	0.86
NonRef Ware	12.34	0.62	1.92	1.81	0.00	0.14
Restaurant	28.99	14.93	13.43	39.36	18.11	6.44

1. Developed on a total floor area basis using the on-site survey and the same weighting factors used for prototype development.
2. Developed using CEC short-run price elasticities and SCE historic prices and, for miscellaneous equipment only, a CEC technology growth adjustment factor. For all end uses but miscellaneous equipment, the price effect increases the reconciled EUIs by 7%. For office miscellaneous equipment, the combined effect reduces the miscellaneous equipment EUI by 36%; for all other building types, the combined effect reduces the miscellaneous equipment EUI by 19%.

## Appendix B. DOE-2 BDL Prototype Input Files

/user2/bed/lirsce/DOE2/Proto/college.inp

Tue Jan 29 01:55:39 1991

1

\$ DOE-2.1D BDL Input for College  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*College\*  
..

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-Z 8  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES  
..

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA FOR \$  
\$ COLLEGE \$

OCC-CLASS-WKD = DAY-SCHEDULE  
(1,8) (.0, .0, .0, .0, .1, .4, .6)  
(9,16) (.9, .9, .9, .6, .7, .8, .8)  
(17,24) (.6, .4, .2, .5, .5, .3, .1, .0)  
..

OCC-CLASS-WKE = DAY-SCHEDULE  
(1,8) (.0)  
(9,16) (.1, .3, .3, .3, .3, .1, .0)  
(17,24) (.0)  
..

OCC-CLASS = SCHEDULE THRU DEC 31  
(WD) OCC-CLASS-WKD  
(WEH) OCC-CLASS-WKE  
..

LIT-CLASS-WKD = DAY-SCHEDULE  
(1,8) (.2, .2, .2, .2, .2, .4, .9, .9)  
(9,16) (.9, .9, .9, .9, .9, .9, .9, .9)  
(17,24) (.9, .9, .8, .8, .8, .8, .4, .2)  
..

LIT-CLASS-WKE = DAY-SCHEDULE  
(1,8) (.2)  
(9,16) (.4, .4, .4, .4, .4, .2, .2)  
(17,24) (.2)  
..

LIGHT-CLASS = SCHEDULE THRU DEC 31  
(WD) LIT-CLASS-WKD  
(WEH) LIT-CLASS-WKE  
..

OCC-OFF-WKD = DAY-SCHEDULE  
(1,8) (.0, .0, .0, .0, .1, .3, .7)  
(9,16) (.8, .8, .8, .5, .5, .8, .8, .8)  
(17,24) (.7, .5, .4, .4, .4, .2, .0)  
..

OCC-OFF-WKE = DAY-SCHEDULE

(1,8) (.0)  
(9,16) (.2, .4, .4, .2, .2, .1, .1, .1)  
(17,24) (.0)  
..

OCC-OFF = SCHEDULE THRU DEC 31  
(WD) OCC-OFF-WKD  
(WEH) OCC-OFF-WKE  
..

LIGHT-OFF-WKD = DAY-SCHEDULE  
(1,8) (.1, .1, .1, .1, .1, .2, .4, .9)  
(9,16) (.9, .9, .9, .9, .9, .9, .9, .9)  
(17,24) (.8, .7, .7, .7, .6, .6, .6, .1)  
..

LIGHT-OFF-WKE = DAY-SCHEDULE  
(1,8) (.1)  
(9,16) (.2, .5, .5, .4, .4, .4, .4, .4)  
(17,24) (.1)  
..

LIGHT-OFF = SCHEDULE THRU DEC 31  
(WD) LIGHT-OFF-WKD  
(WEH) LIGHT-OFF-WKE  
..

DHW-OFF-WKD = DAY-SCHEDULE  
(1,8) (.21, .20, .20, .20, .22, .20, .51, .61)  
(9,16) (.59, .48, .42, .48, .45, .40, .35, .35)  
(17,24) (.33, .45, .60, .65, .55, .50, .48, .20)  
..

DHW-OFF-WKE = DAY-SCHEDULE  
(1,8) (.30, .25, .22, .22, .25, .31, .51, .55)  
(9,16) (.52, .57, .51, .51, .45, .42, .35, .32)  
(17,24) (.32, .42, .52, .52, .43, .52, .43, .25)  
..

DHW = SCHEDULE THRU DEC 31  
(WD) DHW-OFF-WKD  
(WEH) DHW-OFF-WKE  
..

ALLWAYSON = SCHEDULE THRU DEC 31  
(ALL) (1,24) (1) ..

\$ LOADS DATA \$

\$ Exterior Surfaces  
\$ Wall - poured concrete, insulation, air-space, gyp-board  
IN-W MATERIAL RES = 2.6 ..  
WALLR LAYERS MAT = (CC06, IN-W, AL21, GP02) ..  
WALLR-1 CONSTRUCTION LAYERS = WALLR ..

\$ Roof - built-up roofing, concrete, insulation, air-space, acoustic tile  
IN-R MATERIAL RES = 5.8 ..  
ROOFR LAYERS MAT = (BR01, CC25, IN-R, AL33, AC02) ..  
ROOFR-1 CONSTRUCTION LAYERS = ROOFR ..

\$ Floor - 4" light-weight conc., pad, carpet  
FLOORR LAYERS MAT = (CC24, CP01) ..  
FLOORR-1 CONSTRUCTION LAYERS = FLOORR ..

\$ Slab - 6" heavy-weight conc., 2' soil  
SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26  
CONDUCTIVITY = 1.0 DENSITY = 115 ..  
SLABL LAYERS MAT = (SOIL, CC15) ..  
SLABL-1 CONSTRUCTION LAYERS = SLABL ..

\$ Single Glass

SINGLE GLASS-TYPE PANES = 1  
SHADING-COEF = 0.4  
GLASS-CONDUCTANCE = 1.0278  
..

\$ DEFAULT CONSTRUCTIONS \$

SET-DEFAULT FOR EXTERIOR-WALL  
CONSTRUCTION = WALL-1  
HEIGHT = 10.  
..

SET-DEFAULT FOR WINDOW  
GLASS-TYPE = SINGLE  
..

\$ GENERAL SPACE CHARACTERISTICS \$

CLASS-ROOM SPACE-CONDITIONS

TEMPERATURE = (74)  
P-SCH = OCC-CLASS  
P-H-S = 230  
P-H-L = 190  
L-SCH = LIGHT-CLASS  
L-T = SUS-FLUOR L-W = 2.0  
FLOOR-WEIGHT = 70  
Z-TYPE = CONDITIONED ..

OFFICE SPACE-CONDITIONS

TEMPERATURE = (74)  
P-SCH = OCC-OFF  
N-O-P = 2  
P-H-S = 255  
P-H-L = 255  
E-SCH = LIGHT-OFF E-W = 0.6  
L-SCH = LIGHT-OFF  
L-T = REC-FLUOR-RV L-W = 1.0  
FLOOR-WEIGHT = 70  
Z-TYPE = CONDITIONED ..

BASE SPACE-CONDITIONS \$ Basement

ZONE-TYPE = UNCONDITIONED  
INF-METHOD = AIR-CHANGE  
AIR-CHANGES/HR = 2 \$ Combustion air  
SOURCE-TYPE = PROCESS  
SOURCE-BTU/HR = 140000 \$ 5% Jacket loss  
SOURCE-SCHEDULE = ALLWAYSON  
FLOOR-WEIGHT = 130  
..

\$ CLASS ROOMS \$

CLASSRM SPACE  
SPACE-CONDITIONS = CLASS-ROOM  
AREA = 32500  
VOLUME = 325000  
N-O-P = 400  
..

CEW-1 EXTERIOR-WALL  
WIDTH = 180  
AZIMUTH = 0  
..

CW-1 WINDOW  
HEIGHT = 2  
WIDTH = 180  
..  
EXTERIOR-WALL LIKE CEW-1 AZIMUTH = 90 ..  
WINDOW LIKE CW-1 ..  
EXTERIOR-WALL LIKE CEW-1 AZIMUTH = 180 ..  
WINDOW LIKE CW-1 ..  
EXTERIOR-WALL LIKE CEW-1 AZIMUTH = 270 ..  
WINDOW LIKE CW-1 ..

CF-1 INTERIOR-WALL \$ Floor to Basement  
CONSTRUCTION = FLOOR-1  
AREA = 32500  
NEXT-TO BASEMENT  
..

\$ OFFICES \$

OFF-1 SPACE  
MULTIPLIER = 32  
SPACE-CONDITIONS = OFFICE  
AREA = 500  
VOLUME = 5000  
..

EW1 EXTERIOR-WALL  
WIDTH = 25  
AZIMUTH = 0  
..

W1 WINDOW  
HEIGHT = 2  
WIDTH = 25  
..

OFF-2 SPACE LIKE OFF-1  
MULTIPLIER = 32  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..  
WINDOW LIKE W1 ..

OFF-3 SPACE LIKE OFF-1  
MULTIPLIER = 32  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
WINDOW LIKE W1 ..

OFF-4 SPACE LIKE OFF-1  
MULTIPLIER = 32  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
WINDOW LIKE W1 ..

OFF-1T SPACE LIKE OFF-1  
MULTIPLIER = 16  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 0 ..  
WINDOW LIKE W1 ..

R1 ROOF CONSTRUCTION = ROOF-1  
TILT = 0.0  
GND-REFLECTANCE = 0.0  
HEIGHT = 25  
WIDTH = 20  
..

OFF-2T SPACE LIKE OFF-1T  
MULTIPLIER = 16  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..  
WINDOW LIKE W1 ..  
ROOF LIKE R1 ..

OFF-3T SPACE LIKE OFF-1T  
MULTIPLIER = 16  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
WINDOW LIKE W1 ..  
ROOF LIKE R1 ..

OFF-4T SPACE LIKE OFF-1T  
MULTIPLIER = 16  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
WINDOW LIKE W1 ..  
ROOF LIKE R1 ..

\$ Basement

BASEMENT SPACE  
SPACE-CONDITIONS = BASE  
AREA = 32500  
VOLUME = 260000  
..

SLB-1 UNDERGROUND-FLOOR  
CONSTRUCTION = SLAB-1  
AREA = 32500  
U-EFFECTIVE = 0.0414  
..

\$ BUILDING RESOURCES \$

BUILDING-RESOURCE  
V-T-SCH = OCC-OFF  
VERT-TRANS-KW = 30  
HW-SCHEDULE = DHW  
HOT-WATER = 280000  
..

\$ LOADS REPORT DATA \$

\$ Space peak loads summary, Building peak load components  
LOADS-REPORT S (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

\$ fan schedules \$

ALWAYSON = SCH  
THRU DEC 31 (ALL) (1,24) (1) ..

5 Heat-Temp and Cool-Temp schedules\$

CLASSHT = SCH THRU DEC 31  
(ALL) (1,8) (65) (9,23) (72) (24) (65) ..

CLASSCL = SCH THRU DEC 31  
(ALL) (1,24) (76) ..

OFFHT = SCH THRU DEC 31  
(ALL) (1,24) (72) ..

OFFCL = SCH THRU DEC 31  
(ALL) (1,24) (76) ..

SYS-AIR = ZONE-AIR OA-CFM/PER = 15 ..

CNTRL-CLASS ZONE-CONTROL  
DESIGN-HEAT-T 72  
DESIGN-COOL-T 76  
HEAT-TEMP-SCH CLASSHT  
COOL-TEMP-SCH CLASSCL  
THERMOSTAT-TYPE PROPORTIONAL  
..

CNTRL-OFFICE ZONE-CONTROL  
DESIGN-HEAT-T 72  
DESIGN-COOL-T 76  
HEAT-TEMP-SCH OFFHT  
COOL-TEMP-SCH OFFCL  
THERMOSTAT-TYPE PROPORTIONAL  
..

CLASSRM ZONE  
ZONE-TYPE CONDITIONED  
ZONE-AIR SYS-AIR  
ZONE-CONTROL CNTRL-CLASS ..

OFF-1 ZONE LIKE CLASSRM  
\$ MULTIPLIER = 32  
ZONE-CONTROL CNTRL-OFFICE ..

OFF-2 ZONE LIKE OFF-1 ..

OFF-3 ZONE LIKE OFF-1 ..

OFF-4 ZONE LIKE OFF-1 ..

OFF-1T ZONE LIKE OFF-1 ..  
\$ MULTIPLIER = 16 ..

OFF-2T ZONE LIKE OFF-1T ..

OFF-3T ZONE LIKE OFF-1T ..

OFF-4T ZONE LIKE OFF-1T ..

BASEMENT ZONE ZONE-TYPE UNCONDITIONED ..

NORM-CONT SYSTEM-CONTROL  
MAX-S-T 110 MIN-S-T 52  
H-SCH ALWAYSON  
C-SCH ALWAYSON  
..

SYS1 SYSTEM \$ class rooms  
SYSTEM-TYPE SZRH  
OA-CONTROL TEMP  
REHEAT-DELTA-T 50  
S-C NORM-CONT  
F-SCH ALWAYSON  
ZONE-NAMES (CLASSRM,BASEMENT) ..



```
SYS2 SYSTEM 5 offices
SYSTEM-TYPE      RHFS
REHEAT-DELTA-T  50
MIN-CFM-RATIO    1
ECONO-LIMIT-T    68
S-C              NORM-CONT
ZONE-NAMES       (OFF-1,OFF-2,OFF-3,OFF-4
                  OFF-1T,OFF-2T,OFF-3T,OFF-4T) ..
```

```
PLT-1  PLANT-ASSIGNMENT
        SYSTEM-NAMES (SYS1,SYS2) ..
```

```
##defl sys_rep[] 2
```

```
      $ SYSTEM REPORT DATA $
```

```
##include /user2/bed/lirsce/DOE2/Proto/system_rep.inc
```

```
      $ PLANT DATA $
```

```
INPUT PLANT ..
```

```
PLT-1  PLANT-ASSIGNMENT ..
```

```
DHW      P-E TYPE DHW-HEATER  SIZE -999  ..
HWG      P-E TYPE HW-BOILER  SIZE -999  I-N 2  ..
CLG      P-E TYPE HERM-CENT-CHLR SIZE -999  I-N 2  ..
CTW      P-E TYPE COOLING-TWR  SIZE -999  I-N 2  ..
```

```
PLANT-PARAMETERS
```

```
      BOILER-FUEL NATURAL-GAS ..
```

```
      $ PLANT REPORT DATA $
```

```
##include /user2/bed/lirsce/DOE2/Proto/plant_rep.inc
```

```
STOP ..
```

/user2/bed/lirsce/DOE2/Proto/dorm.inp

Tue Jan 29 01:56:17 1991

1

\$ DOE-2.1D BDL Input for College Dorm.  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*College Dorm\*  
..

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-2 8  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES  
..

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA FOR \$  
\$ COLLEGE DORM \$

OCC-COR-ALL = DAY-SCHEDULE  
(1,8) (.1, .1, .1, .1, .1, .2, .4, .6)  
(9,16) (.6, .4, .2, .2, .2, .2, .2, .3)  
(17,24) (.3, .4, .8, .8, .7, .6, .3, .1)  
..

OCC-COR = SCHEDULE THRU DEC 31  
(ALL) OCC-COR-ALL  
..

LIGHT-COR = SCHEDULE THRU DEC 31  
(ALL) (1,24) (1) ..

OCC-KIT-ALL = DAY-SCHEDULE  
(1,8) (.0, .0, .0, .0, .2, .2, .4, .8)  
(9,16) (.8, .4, .6, .8, .8, .4, .4, .4)  
(17,24) (.8, .9, .9, .4, .2, .1, .1, .0)  
..

OCC-KIT = SCHEDULE THRU DEC 31  
(ALL) OCC-KIT-ALL  
..

LIGHT-KIT = SCHEDULE THRU DEC 31  
(ALL) (1,5) (.2) (6,23) (.9) (24) (.2)  
..

EQUIP-KIT = SCHEDULE THRU DEC 31  
(ALL) (1,6) (0.0) (7,10) (0.5) (11,17) (0.7) (18,24) (0.2) ..

OCC-DIN-ALL = DAY-SCHEDULE  
(1,8) (.0, .0, .0, .0, .0, .0, .2, .4)  
(9,16) (.4, .0, .2, .6, .5, .1, .1, .1)  
(17,24) (.4, .8, .5, .1, .1, .0, .0, .0)  
..

OCC-DIN = SCHEDULE THRU DEC 31  
(ALL) OCC-KIT-ALL  
..

LIGHT-DIN = SCHEDULE THRU DEC 31  
(ALL) (1,6) (.1) (7,23) (.9) (24) (.1)  
..

OCC-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.9, .9, .9, .9, .9, .8, .6, .4)  
(9,16) (.4, .2, .2, .2, .2, .2, .4, .4)  
(17,24) (.5, .5, .5, .6, .6, .8, .9, .9)  
..

OCC-ROOM = SCHEDULE THRU DEC 31  
(ALL) OCC-ROOM-ALL  
..

LIGHT-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.0, .0, .0, .0, .0, .2, .4, .4)  
(9,16) (.2, .0, .0, .0, .0, .0, .0, .2)  
(17,24) (.2, .2, .4, .4, .7, .8, .8, .4)  
..

LIGHT-ROOM = SCHEDULE THRU DEC 31  
(ALL) LIGHT-ROOM-ALL  
..

DHW-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.21, .20, .20, .20, .22, .20, .51, .61)  
(9,16) (.59, .48, .42, .48, .45, .40, .35, .35)  
(17,24) (.33, .45, .60, .65, .55, .50, .48, .20)  
..

DHW-ROOM = SCHEDULE THRU DEC 31  
(ALL) DHW-ROOM-ALL  
..

ALLWAYSON = SCHEDULE THRU DEC 31  
(ALL) (1,24) (1) ..

\$ LOADS DATA \$

\$ Exterior Surfaces  
\$ Wall - poured concrete,insulation,air-space,gyp-board  
IN-W MATERIAL RES = 2.6 ..  
WALLR LAYERS MAT = (CC06,IN-W,AL21,GP02) ..  
WALL-1 CONSTRUCTION LAYERS = WALLR ..

\$ Roof - built-up roofing,concrete,insulation  
IN-R MATERIAL RES = 5.8 ..  
ROOFR LAYERS MAT = (BR01,CC25,IN-R) ..  
ROOF-1 CONSTRUCTION LAYERS = ROOFR ..

\$ Floor - 6" heavy-weight conc., pad, carpet  
FLOORR LAYERS MAT = (CC15,CP01) ..  
FLOOR-1 CONSTRUCTION LAYERS = FLOORR ..

\$ Single Glass  
SINGLE GLASS-TYPE PANES = 1  
SHADING-COEF = 0.6  
GLASS-CONDUCTANCE = 1.0278  
..

\$ Zone Calculations  
\$ Base area = 9,600 sqft, 5 floors  
\$ 4 floors of rooms, 50 rooms per floor, 200 sqft per room  
\$ 1st floor = 2,600 sqft kitchen, 7,000 sqft dining

\$ DEFAULT CONSTRUCTIONS \$

SET-DEFAULT FOR EXTERIOR-WALL  
CONSTRUCTION = WALL-1  
HEIGHT = 8.  
..

SET-DEFAULT FOR WINDOW

GLASS-TYPE = SINGLE  
..

\$ GENERAL SPACE CHARACTERISTICS \$

CORRIDOR SPACE-CONDITIONS

TEMPERATURE = (74)  
P-SCH = OCC-COR  
P-H-S = 315  
P-H-L = 325  
L-SCH = LIGHT-COR  
L-T = REC-FLUOR-RV L-W = 1.5  
FLOOR-WEIGHT = 70  
Z-TYPE = CONDITIONED

KITCHEN SPACE-CONDITIONS

TEMPERATURE = (74)  
P-SCH = OCC-KIT  
P-H-S = 345  
P-H-L = 435  
E-SCH = EQUIP-KIT E-W = 3.0  
L-SCH = LIGHT-KIT  
L-T = SUS-FLUOR L-W = 2.0  
SOURCE-TYPE HOT-WATER  
SOURCE-SCHEDULE EQUIP-KIT  
SOURCE-BTU/HR = 165400  
S-L 0.1 S-S 0.1  
FLOOR-WEIGHT = 70  
Z-TYPE = CONDITIONED

DINNING

SPACE-CONDITIONS

TEMPERATURE = (74)  
P-SCH = OCC-ROOM  
P-H-S = 255  
P-H-L = 325  
L-SCH = LIGHT-DIN  
L-T = INCAND L-W = 1.5  
FLOOR-WEIGHT = 70  
Z-TYPE = CONDITIONED

ROOM

SPACE-CONDITIONS

TEMPERATURE = (74)  
P-SCH = OCC-ROOM  
P-H-S = 230  
P-H-L = 190  
E-SCH = LIGHT-ROOM E-W = 0.6  
L-SCH = LIGHT-ROOM  
L-T = INCAND L-W = 1.0  
FLOOR-WEIGHT = 70  
Z-TYPE = CONDITIONED

\$ CORRIDOR \$

CORR SPACE

SPACE-CONDITIONS = CORRIDOR  
AREA = 2400  
VOLUME = 19200  
N-O-P = 10

CEW-1

EXTERIOR-WALL  
WIDTH = 4  
AZIMUTH = 0

CW-1

WINDOW  
HEIGHT = 2  
WIDTH = 2

..  
EXTERIOR-WALL LIKE CEW-1 AZIMUTH = 90 ..  
WINDOW LIKE CW-1 ..  
EXTERIOR-WALL LIKE CEW-1 AZIMUTH = 180 ..  
WINDOW LIKE CW-1 ..  
EXTERIOR-WALL LIKE CEW-1 AZIMUTH = 270 ..  
WINDOW LIKE CW-1 ..

\$ KITCHEN \$

KIT

SPACE  
SPACE-CONDITIONS = KITCHEN  
AREA = 2600  
VOLUME = 20800  
N-O-P = 10

KEW-1

EXTERIOR-WALL  
WIDTH = 48  
AZIMUTH = 0

KW-1

WINDOW  
HEIGHT = 0.5  
WIDTH = 48

..  
EXTERIOR-WALL LIKE KEW-1 AZIMUTH = 90 ..  
WINDOW LIKE KW-1 ..  
EXTERIOR-WALL LIKE KEW-1 AZIMUTH = 180 ..  
WINDOW LIKE KW-1 ..  
EXTERIOR-WALL LIKE KEW-1 AZIMUTH = 270 ..  
WINDOW LIKE KW-1 ..

SLB-1

UNDERGROUND-FLOOR  
CONSTRUCTION = FLOOR-1  
AREA = 2600  
U-EFFECTIVE = 0.0414 ..

\$ DINNING ROOM \$

DIN

SPACE  
SPACE-CONDITIONS = DINNING  
AREA = 7000  
VOLUME = 56000  
N-O-P = 40

DEW-1

EXTERIOR-WALL  
WIDTH = 118  
AZIMUTH = 0

DW-1

WINDOW  
HEIGHT = 2  
WIDTH = 118

..  
EXTERIOR-WALL LIKE DEW-1 AZIMUTH = 90 ..  
WINDOW LIKE DW-1 ..  
EXTERIOR-WALL LIKE DEW-1 AZIMUTH = 180 ..  
WINDOW LIKE DW-1 ..  
EXTERIOR-WALL LIKE DEW-1 AZIMUTH = 270 ..  
WINDOW LIKE DW-1 ..

SLB-2

UNDERGROUND-FLOOR

CONSTRUCTION = FLOOR-1  
AREA = 7000  
U-EFFECTIVE = 0.0414 ..

\$ ROOMS \$

ROOM-1 SPACE  
MULTIPLIER = 40  
SPACE-CONDITIONS = ROOM  
AREA = 200  
VOLUME = 1600  
N-O-P = 2  
..  
EW1 EXTERIOR-WALL  
WIDTH = 3  
AZIMUTH = 0  
..  
W1 WINDOW  
HEIGHT = 1.6  
WIDTH = 3  
..  
ROOM-2 SPACE LIKE ROOM-1  
MULTIPLIER = 40  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..  
WINDOW LIKE W1 ..  
ROOM-3 SPACE LIKE ROOM-1  
MULTIPLIER = 40  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
WINDOW LIKE W1 ..  
ROOM-4 SPACE LIKE ROOM-1  
MULTIPLIER = 40  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
WINDOW LIKE W1 ..  
ROOM-1T SPACE LIKE ROOM-1  
MULTIPLIER = 10  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 0 ..  
WINDOW LIKE W1 ..  
R1 ROOF CONSTRUCTION = ROOF-1  
TILT = 0.0  
GND-REFLECTANCE = 0.0  
HEIGHT = 12  
WIDTH = 16  
..  
ROOM-2T SPACE LIKE ROOM-1T  
MULTIPLIER = 10  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..  
WINDOW LIKE W1 ..  
ROOF LIKE R1 ..  
ROOM-3T SPACE LIKE ROOM-1T  
MULTIPLIER = 10  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
WINDOW LIKE W1 ..

ROOF LIKE R1 ..

ROOM-4T SPACE LIKE ROOM-1T  
MULTIPLIER = 10  
..  
EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
WINDOW LIKE W1 ..  
ROOF LIKE R1 ..

\$ BUILDING RESOURCES \$

BUILDING-RESOURCE  
V-T-SCH = OCC-KIT  
VERT-TRANS-KW = 54  
HW-SCHEDULE = DHW-ROOM  
HOT-WATER = 280000  
GAS-SCHEDULE = EQUIP-KIT  
GAS-THERMS = 2.6  
..

\$ LOADS REPORT DATA \$

\$ Space peak loads summary, Building peak load components  
LOADS-REPORT \$ (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

\$ fan schedules \$

FAN-KIT = SCH \$ fan schedule for kitchen  
THRU DEC 31 (ALL) (1,5) (0) (6,24) (1)

..  
ALWAYSON = SCH  
THRU DEC 31 (ALL) (1,24) (1) ..

\$ Heat-Temp and Cool-Temp schedules\$

ROOMHT = SCH THRU DEC 31  
(ALL) (1,8) (72) (9,18) (65) (19,24) (72) ..

ROOMCL = SCH THRU DEC 31  
(ALL) (1,24) (85) ..

KITHT = SCH THRU DEC 31  
(ALL) (1,6) (65) (7,23) (70) (24) (65) ..

KITCL = SCH THRU DEC 31  
(ALL) (1,6) (85) (7,23) (78) (24) (85) ..

CORHT = SCH THRU DEC 31  
(ALL) (1,24) (72) ..

CORCL = SCH THRU DEC 31  
(ALL) (1,24) (85) ..

KIT-AIR = ZONE-AIR OA-CHANGES = 3.0 ..

COR-AIR = ZONE-AIR OA-CFM/PER = 15 ..

CNTRL-COR ZONE-CONTROL
DESIGN-HEAT-T 72
DESIGN-COOL-T 76
HEAT-TEMP-SCH CORHT
COOL-TEMP-SCH CORCL
THERMOSTAT-TYPE PROPORTIONAL
..

CNTRL-KIT ZONE-CONTROL
DESIGN-HEAT-T 70
DESIGN-COOL-T 78
HEAT-TEMP-SCH KITHT
COOL-TEMP-SCH KITCL
THERMOSTAT-TYPE PROPORTIONAL
..

CNTRL-ROOM ZONE-CONTROL
DESIGN-HEAT-T 72
DESIGN-COOL-T 76
HEAT-TEMP-SCH ROOMHT
COOL-TEMP-SCH ROOMCL
THERMOSTAT-TYPE PROPORTIONAL
..

KIT ZONE
ZONE-TYPE CONDITIONED
ZONE-AIR KIT-AIR
ZONE-CONTROL CNTRL-KIT
..

DIN ZONE LIKE KIT
ZONE-AIR COR-AIR ..

CORR ZONE LIKE KIT
ZONE-AIR COR-AIR
ZONE-CONTROL CNTRL-COR ..

ROOM-1 ZONE LIKE CORR
MULTIPLIER = 40
ZONE-CONTROL CNTRL-ROOM ..

ROOM-2 ZONE LIKE ROOM-1 ..

ROOM-3 ZONE LIKE ROOM-1 ..

ROOM-4 ZONE LIKE ROOM-1 ..

ROOM-1T ZONE LIKE ROOM-1

MULTIPLIER = 10 ..

ROOM-2T ZONE LIKE ROOM-1T ..

ROOM-3T ZONE LIKE ROOM-1T ..

ROOM-4T ZONE LIKE ROOM-1T ..

NORM-CONT SYSTEM-CONTROL
MAX-S-T 110 MIN-S-T 52
H-SCH ALWAYSON
C-SCH ALWAYSON
..

SYS1 SYSTEM \$ kitchen
SYSTEM-TYPE SZRH
S-C NORM-CONT
REHEAT-DELTA-T 50
F-SCH FAN-KIT
ZONE-NAMES (KIT,DIN) ..

SYS2 SYSTEM \$ rooms
SYSTEM-TYPE TFC

S-C NORM-CONT
ZONE-NAMES (CORR, ROOM-1, ROOM-2, ROOM-3, ROOM-4
ROOM-1T, ROOM-2T, ROOM-3T, ROOM-4T) ..

PLT-1 PLANT-ASSIGNMENT
SYSTEM-NAMES (SYS1,SYS2) ..

##defl sys\_rep[] 2

\$ SYSTEM REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/system\_rep.inc

\$ PLANT DATA \$

INPUT PLANT ..

PLT-1 PLANT-ASSIGNMENT ..

DHW P-E TYPE DHW-HEATER SIZE -999 ..

HWG P-E TYPE HW-BOILER SIZE -999 I-N 2 ..

PLANT-PARAMETERS

BOILER-FUEL NATURAL-GAS ..

\$ PLANT REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/plant\_rep.inc

STOP ..

\$ DOE-2.1D BDL Input for Hospital  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*Hospital\*  
..

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-Z 8  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES  
..

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULES \$

\$ OCC \$

OCC-SCHED-1=SCHEDULE THRU DEC 31  
(WD) (1,7) (0.50) (8,17) (1.00) (18,24) (0.50)  
(WEH) (1,24) (0.50) ..  
OCC-SCHED-2=SCHEDULE THRU DEC 31  
(WD) (1,5) (0.26) (6,7) (0.48) (8) (0.86) (9,11) (0.75)  
(12) (1.00) (13) (0.96) (14) (0.93) (15,17) (0.75)  
(18) (0.62) (19) (0.59) (20) (0.55) (21,24) (0.26)  
(WEH) (1,5) (0.26) (6,8) (0.48) (9,11) (0.37) (12) (0.62)  
(13) (0.59) (14) (0.55) (15,17) (0.37)  
(18) (0.62) (19) (0.59) (20) (0.55) (21,24) (0.26) ..  
OCC-SCHED-3=SCHEDULE THRU DEC 31  
(WD) (1,5) (0.18) (6,7) (0.84) (8,17) (1.00) (18,19) (0.84)  
(20,24) (0.18)  
(WEH) (1,5) (0.18) (6,19) (0.84) (20,24) (0.18) ..  
OCC-SCHED-4=SCHEDULE THRU DEC 31  
(ALL) (1,24) (1.00) ..  
OCC-SCHED-5=SCHEDULE THRU DEC 31  
(WD) (1,5) (0.50) (6,7) (0.67) (8,17) (1.00) (18,19) (0.84)  
(20,22) (0.52) (23,24) (0.50)  
(WEH) (1,5) (0.50) (6,7) (0.67) (8,19) (0.84) (20,22) (0.52)  
(23,24) (0.50) ..

\$ LIT \$

LIT-SCHED-1=SCHEDULE THRU DEC 31  
(ALL) (1,7) (0.30) (8,19) (1.00) (20,22) (0.50) (23,24) (0.30) ..  
LIT-SCHED-2=SCHEDULE THRU DEC 31  
(ALL) (1,5) (0.33) (6,7) (0.35) (8,19) (1.00) (20,22) (0.41)  
(23,24) (0.33) ..  
LIT-SCHED-3=SCHEDULE THRU DEC 31  
(ALL) (1,5) (0.20) (6,7) (0.66) (8,19) (1.00) (20,22) (0.24)  
(23,24) (0.20) ..  
LIT-SCHED-4=SCHEDULE THRU DEC 31  
(ALL) (1,7) (0.20) (8,19) (1.00) (20,22) (0.30) (23,24) (0.20) ..  
LIT-SCHED-5=SCHEDULE THRU DEC 31  
(ALL) (1,5) (0.61) (6,7) (0.73) (8,19) (1.00) (20,22) (0.64)  
(23,24) (0.61) ..

\$ EQP \$

EQP-SCHED-1=SCHEDULE THRU DEC 31  
(ALL) (1,7) (0.30) (8,19) (1.00) (20,22) (0.50) (23,24) (0.30) ..  
EQP-SCHED-2=SCHEDULE THRU DEC 31  
(ALL) (1,5) (0.31) (6,7) (0.35) (8) (0.97) (9,11) (0.95)  
(12) (1.00) (13,14) (0.99) (15,17) (0.95)  
(18) (1.00) (19) (0.99) (20) (0.44) (21,22) (0.39)  
(23,24) (0.31) ..  
EQP-SCHED-3=SCHEDULE THRU DEC 31  
(ALL) (1,5) (0.25) (6,7) (0.93) (8,12) (1.00) (13,14) (0.66)  
(15,17) (1.00) (18,19) (0.66) (20) (0.60) (21,24) (0.25) ..  
EQP-SCHED-4=SCHEDULE THRU DEC 31  
(ALL) (1,7) (0.20) (8,19) (1.00) (20,22) (0.30) (23,24) (0.20) ..  
EQP-SCHED-5=SCHEDULE THRU DEC 31  
(ALL) (1,5) (0.69) (6,7) (0.90) (8,19) (1.00) (20,22) (0.70)  
(23,24) (0.69) ..

\$ ELEC KITCHEN \$

EKITCH=SCHEDULE THRU DEC 31  
(ALL) (1,5) (0.2) (6,12) (0.8) (13,14) (0.5) (15,17) (0.8)  
(18,20) (0.5) (21,24) (0.2) ..

\$ HOT WATER \$

WAT-SCHED=SCHEDULE THRU DEC 31  
(ALL) (1,24) (0.18,0.18,0.18,0.25,0.25,0.65,1.0,0.86,  
0.8,0.69,0.69,0.73,0.73,0.57,0.69,0.84,0.73,0.66,  
0.5,0.48,0.46,0.42,0.43,0.33) ..

\$ EQUIPMENT \$

ELL-SCHED=SCHEDULE THRU DEC 31  
(ALL) (1,7) (1.0) (8,17) (0) (18,24) (1.0) ..

\$ ELEVATOR \$

ELEV-SCHED=SCHEDULE THRU DEC 31  
(ALL) (1,7) (0.1) (8,22) (1.0) (23,24) (0.1) ..

\$ BASEMENT PROCESS LOAD \$

ALLWAYSON=SCHEDULE THRU DEC 31  
(ALL) (1,24) (1) ..

\$ LOADS DATA \$

\$ Exterior Surfaces

\$ Wall - 12" cmu,insulation,air-space,gyp-board  
IN-W MATERIAL RES = 1.0 ..  
WALLR LAYERS MAT = (CB17,IN-W,AL21,GPO2) ..  
WALL-1 CONSTRUCTION LAYERS = WALLR ..

\$ Roof - built-up roofing,6" conc., insulation,air-space,accoustic tile

IN-R MATERIAL RES = 7.3 ..  
ROOFR LAYERS MAT = (BR01,CC25,IN-R,AL33,AC02) ..  
ROOF-1 CONSTRUCTION LAYERS = ROOFR ..

\$ Floor - 4" light-weight conc., pad, carpet

FLOORR LAYERS MAT = (CC24,CP01) ..  
FLOOR-1 CONSTRUCTION LAYERS = FLOORR ..  
\$ Slab - 6" heavy-weight conc., 2' soil  
SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26  
CONDUCTIVITY = 1.0 DENSITY = 115 ..  
SLABL LAYERS MAT = (SOIL,CC15) ..  
SLAB-1 CONSTRUCTION LAYERS = SLABL ..

\$ Single Glass
GT-1 GLASS-TYPE PANES = 1
SHADING-COEF = 0.4
GLASS-CONDUCTANCE = 1.0278

\$ GENERAL SPACE CHARACTERISTICS \$

\$ E-W and L-W based on lumped 5 zone input file
\$ infiltration not included

SPACE-1 SPACE-CONDITIONS \$ Perimeter spaces
ZONE-TYPE = CONDITIONED
PEOPLE-SCHEDULE = OCC-SCHED-1 P-H-G = 400
LIGHTING-SCHEDULE = LIT-SCHED-1 L-W = 2.00
EQUIP-SCHEDULE = EQP-SCHED-1 E-W = 0.50
FLOOR-WEIGHT = 60
SPACE-2 SPACE-CONDITIONS \$ Core and public spaces
LIKE SPACE-1
PEOPLE-SCHEDULE = OCC-SCHED-2 P-H-G = 400
LIGHTING-SCHEDULE = LIT-SCHED-2 L-W = 2.00
EQUIP-SCHEDULE = EQP-SCHED-2 E-W = 0.50
SPACE-3 SPACE-CONDITIONS \$ Kitchen
LIKE SPACE-1
PEOPLE-SCHEDULE = OCC-SCHED-3 P-H-G = 550
LIGHTING-SCHEDULE = LIT-SCHED-3 L-W = 2.50
EQUIP-SCHEDULE = EQP-SCHED-3 E-W = 3.40
SPACE-4 SPACE-CONDITIONS \$ Hallways
LIKE SPACE-1
PEOPLE-SCHEDULE = OCC-SCHED-4 P-H-G = 400
LIGHTING-SCHEDULE = LIT-SCHED-4 L-W = 1.00
EQUIP-SCHEDULE = EQP-SCHED-4 E-W = 0.00
SPACE-5 SPACE-CONDITIONS \$ Clinic
LIKE SPACE-1
PEOPLE-SCHEDULE = OCC-SCHED-5 P-H-G = 443
LIGHTING-SCHEDULE = LIT-SCHED-5 L-W = 2.50
EQUIP-SCHEDULE = EQP-SCHED-5 E-W = 1.47
SPACE-6 SPACE-CONDITIONS \$ Basement
ZONE-TYPE = UNCONDITIONED
INF-METHOD = AIR-CHANGE
AIR-CHANGES/HR = 2 \$ Combustion air
SOURCE-TYPE = PROCESS
SOURCE-BTU/HR = 320000 \$ 5% Jacket loss
SOURCE-SCHEDULE = ALLWAYSON
FLOOR-WEIGHT = 130

\$ Perimeter Zone (assume patient rooms 12' wide, 25' deep)\$

ZONE-1 SPACE
SPACE-CONDITIONS = SPACE-1
AREA = 300
VOLUME = 3000
N-O-P = 2 \$ based on average of 26-zone BDL
MULTIPLIER = 18

EW1-Z1 EXTERIOR-WALL CONSTRUCTION = WALL-1
HEIGHT = 10.
WIDTH = 12.
AZIMUTH = 0

W1-Z1 WINDOW GLASS-TYPE = GT-1
HEIGHT = 3.5
WIDTH = 12.

EXTERIOR-WALL LIKE EW1-Z1 AZIMUTH = 90 ..
WINDOW LIKE W1-Z1 ..

EXTERIOR-WALL LIKE EW1-Z1 AZIMUTH = 180 ..
WINDOW LIKE W1-Z1 ..

EXTERIOR-WALL LIKE EW1-Z1 AZIMUTH = 270 ..
WINDOW LIKE W1-Z1 ..

RF1-Z1 ROOF CONSTRUCTION = ROOF-1
TILT = 0.0
GND-REFLECTANCE = 0.0
HEIGHT = 12.
WIDTH = 25.

ZONE-1I SPACE \$ Interior
LIKE ZONE-1
FLOOR-MULTIPLIER = 6

EXTERIOR-WALL LIKE EW1-Z1 ..
WINDOW LIKE W1-Z1 ..
EXTERIOR-WALL LIKE EW1-Z1 AZIMUTH = 90 ..
WINDOW LIKE W1-Z1 ..
EXTERIOR-WALL LIKE EW1-Z1 AZIMUTH = 180 ..
WINDOW LIKE W1-Z1 ..
EXTERIOR-WALL LIKE EW1-Z1 AZIMUTH = 270 ..
WINDOW LIKE W1-Z1 ..

F-Z1 INTERIOR-WALL \$ Floor to Basement
CONSTRUCTION = FLOOR-1
AREA = 300
NEXT-TO ZONE-6

\$ Core/Public Zone \$

ZONE-2 SPACE
SPACE-CONDITIONS = SPACE-2
AREA = 12425
VOLUME = 124250
N-O-P = 34

EW2-Z1 EXTERIOR-WALL LIKE EW1-Z1
WIDTH = 64

W2-Z1 WINDOW LIKE W1-Z1
HEIGHT = 2
WIDTH = 64

EXTERIOR-WALL LIKE EW2-Z1 AZIMUTH = 90 ..  
 WINDOW LIKE W2-Z1 ..  
  
 EXTERIOR-WALL LIKE EW2-Z1 AZIMUTH = 180 ..  
 WINDOW LIKE W2-Z1 ..  
  
 EXTERIOR-WALL LIKE EW2-Z1 AZIMUTH = 270 ..  
 WINDOW LIKE W2-Z1 ..  
 RF2-Z1 ROOF LIKE RF1-Z1  
 HEIGHT = 111  
 WIDTH = 111  
 ..  
 ZONE-21 SPACE \$ Interior  
 LIKE ZONE-2  
 FLOOR-MULTIPLIER = 6  
 ..  
 EXTERIOR-WALL LIKE EW2-Z1 ..  
 WINDOW LIKE W2-Z1 ..  
 EXTERIOR-WALL LIKE EW2-Z1 AZIMUTH = 90 ..  
 WINDOW LIKE W2-Z1 ..  
 EXTERIOR-WALL LIKE EW2-Z1 AZIMUTH = 180 ..  
 WINDOW LIKE W2-Z1 ..  
 EXTERIOR-WALL LIKE EW2-Z1 AZIMUTH = 270 ..  
 WINDOW LIKE W2-Z1 ..  
 F-22 INTERIOR-WALL \$ Floor to Basement  
 CONSTRUCTION = FLOOR-1  
 AREA = 12425  
 NEXT-TO ZONE-6  
 ..  
 \$ Kitchen  
 ZONE-3 SPACE  
 SPACE-CONDITIONS = SPACE-3  
 AREA = 1775  
 VOLUME = 17750  
 N-O-P = 4 \$avg from 26-Z bdl  
 FLOOR-MULTIPLIER = 7.  
 ..  
 EW3-Z1 EXTERIOR-WALL LIKE EW1-Z1  
 WIDTH = 10  
 ..  
 W3-Z1 WINDOW LIKE W1-Z1  
 HEIGHT = 1  
 WIDTH = 10  
 ..  
 EXTERIOR-WALL LIKE EW3-Z1 AZIMUTH = 90 ..  
 WINDOW LIKE W3-Z1 ..  
  
 EXTERIOR-WALL LIKE EW3-Z1 AZIMUTH = 180 ..  
 WINDOW LIKE W3-Z1 ..  
  
 EXTERIOR-WALL LIKE EW3-Z1 AZIMUTH = 270 ..  
 WINDOW LIKE W3-Z1 ..  
 F-23 INTERIOR-WALL \$ Floor to Basement  
 CONSTRUCTION = FLOOR-1  
 AREA = 1775

NEXT-TO ZONE-6  
 ..  
 \$ Hallway  
 ZONE-4 SPACE  
 SPACE-CONDITIONS = SPACE-4  
 AREA = 7100  
 VOLUME = 71000  
 N-O-P = 10  
 ..  
 EW4-Z1 EXTERIOR-WALL LIKE EW1-Z1  
 WIDTH = 20  
 ..  
 W4-Z1 WINDOW LIKE W1-Z1  
 HEIGHT = 3.5  
 WIDTH = 20  
 ..  
 EXTERIOR-WALL LIKE EW4-Z1 AZIMUTH = 90 ..  
 WINDOW LIKE W4-Z1 ..  
  
 EXTERIOR-WALL LIKE EW4-Z1 AZIMUTH = 180 ..  
 WINDOW LIKE W4-Z1 ..  
  
 EXTERIOR-WALL LIKE EW4-Z1 AZIMUTH = 270 ..  
 WINDOW LIKE W4-Z1 ..  
 RF4-Z1 ROOF LIKE RF1-Z1  
 HEIGHT = 84  
 WIDTH = 84  
 ..  
 ZONE-4I SPACE \$ Interior  
 LIKE ZONE-4  
 FLOOR-MULTIPLIER = 6  
 ..  
 EXTERIOR-WALL LIKE EW4-Z1 ..  
 WINDOW LIKE W4-Z1 ..  
 EXTERIOR-WALL LIKE EW4-Z1 AZIMUTH = 90 ..  
 WINDOW LIKE W4-Z1 ..  
 EXTERIOR-WALL LIKE EW4-Z1 AZIMUTH = 180 ..  
 WINDOW LIKE W4-Z1 ..  
 EXTERIOR-WALL LIKE EW4-Z1 AZIMUTH = 270 ..  
 WINDOW LIKE W4-Z1 ..  
 F-24 INTERIOR-WALL \$ Floor to Basement  
 CONSTRUCTION = FLOOR-1  
 AREA = 7100  
 NEXT-TO ZONE-6  
 ..  
 \$ Clinic  
 ZONE-5 SPACE  
 SPACE-CONDITIONS = SPACE-5  
 AREA = 8875  
 VOLUME = 88750  
 N-O-P = 25  
 ..  
 EW5-Z1 EXTERIOR-WALL LIKE EW1-Z1



WIDTH = 36  
 ..  
 W5-Z1 WINDOW LIKE W1-Z1  
 HEIGHT = 1  
 WIDTH = 36  
 ..  
 EXTERIOR-WALL LIKE EW5-Z1 AZIMUTH = 90 ..  
 WINDOW LIKE W5-Z1 ..  
 EXTERIOR-WALL LIKE EW5-Z1 AZIMUTH = 180 ..  
 WINDOW LIKE W5-Z1 ..  
 EXTERIOR-WALL LIKE EW5-Z1 AZIMUTH = 270 ..  
 WINDOW LIKE W5-Z1 ..  
 RF5-Z1 ROOF LIKE RF1-Z1  
 HEIGHT = 94  
 WIDTH = 94  
 ..  
 ZONE-5I SPACE \$ Interior  
 LIKE ZONE-5  
 FLOOR-MULTIPLIER = 6  
 ..  
 EXTERIOR-WALL LIKE EW5-Z1 ..  
 WINDOW LIKE W5-Z1 ..  
 EXTERIOR-WALL LIKE EW5-Z1 AZIMUTH = 90 ..  
 WINDOW LIKE W5-Z1 ..  
 EXTERIOR-WALL LIKE EW5-Z1 AZIMUTH = 180 ..  
 WINDOW LIKE W5-Z1 ..  
 EXTERIOR-WALL LIKE EW5-Z1 AZIMUTH = 270 ..  
 WINDOW LIKE W5-Z1 ..  
 F-25 INTERIOR-WALL \$ Floor to Basement  
 CONSTRUCTION = FLOOR-1  
 AREA = 8875  
 NEXT-TO ZONE-6  
 ..  
 \$ Basement  
 ZONE-6 SPACE  
 SPACE-CONDITIONS = SPACE-6  
 AREA = 35500  
 VOLUME = 284000  
 ..  
 SLB-1 UNDERGROUND-FLOOR  
 CONSTRUCTION = SLAB-1  
 AREA = 35500  
 U-EFFECTIVE = 0.0145  
 ..  
 \$ DOMESTIC HOT WATER AND MISCELLANEOUS \$  
 BUILDING-RESOURCE  
 \$ schedule and intensity/sq ft. above ground floor from LBL hosp BDL  
 V-T-SCH = ELEV-SCHED  
 VERT-TRANS-KW = 80  
 \$ schedule and intensity/sq ft. from LBL hospital BDL  
 HW-SCHEDULE = WAT-SCHED  
 HOT-WATER = 1600000

E-SCH = EL1-SCHED  
 ELEC-KW = 18  
 GAS-SCHEDULE = EKITCH  
 GAS-THERMS = 4.5  
 ..

\$ LOADS REPORT DATA \$

\$ Space peak loads summary, Building peak load components  
 LOADS-REPORT \$ (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

ALWAYSON SCHEDULE THRU DEC 31 (ALL) (1,24) (1) ..  
 HTG-STPT SCHEDULE THRU DEC 31 (ALL) (1,24) (72) ..  
 CLG-STPT SCHEDULE THRU DEC 31 (ALL) (1,24) (76) ..

CONTROL ZONE-CONTROL  
 DESIGN-HEAT-T 72  
 DESIGN-COOL-T 76  
 HEAT-TEMP-SCH HTG-STPT  
 COOL-TEMP-SCH CLG-STPT  
 THERMOSTAT-TYPE PROPORTIONAL  
 ..

ZONE-1 ZONE  
 ZONE-CONTROL CONTROL  
 A-C/HR 3  
 ..

ZONE-1I ZONE LIKE ZONE-1 ..  
 ZONE-2 ZONE LIKE ZONE-1 ..  
 ZONE-2I ZONE LIKE ZONE-2 ..  
 ZONE-3 ZONE LIKE ZONE-1 ..

..  
 ZONE-4 ZONE LIKE ZONE-1 ..  
 ZONE-4I ZONE LIKE ZONE-4 ..  
 ZONE-5 ZONE LIKE ZONE-1 ..

..

ZONE-5I ZONE LIKE ZONE-5 ..  
 ZONE-6 ZONE

ZONE-TYPE UNCONDITIONED ..

NORM-CONT SYSTEM-CONTROL

MAX-S-T 110 MIN-S-T 52  
 H-SCH ALWAYSON C-SCH ALWAYSON  
 HEAT-CONTROL CONSTANT COOL-CONTROL CONSTANT  
 HEAT-SET-T 110 COOL-SET-T 52  
 ECONO-LIMIT-T 68

SYS1 SYSTEM \$ Perimeter spaces

SYSTEM-TYPE FFPC  
 S-C NORM-CONT  
 M-O-A 0.20

```

SUPPLY-STATIC 0.25
SUPPLY-EFF 0.5
ZONE-NAMES (ZONE-1,ZONE-11,ZONE-6) ..

```

\$ PLANT REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/plant\_rep.inc

STOP ..

```

SYS3 SYSTEM $ Kitchen
SYSTEM-TYPE SZRH
S-C NORM-CONT
M-O-A 1
OA-CONTROL TEMP
F-SCH ALWAYS ON
COOLING-SCHEDULE ALWAYS ON
SUPPLY-STATIC 2.5
SUPPLY-EFF 0.7
REHEAT-DELTA-T 50
ZONE-NAMES (ZONE-3) ..

```

```

SYS4 SYSTEM $ Clinic
SYSTEM-TYPE DDS
S-C NORM-CONT
M-O-A 1
OA-CONTROL TEMP
FAN-SCHEDULE ALWAYS ON
SUPPLY-STATIC 4.25
SUPPLY-EFF 0.7
RETURN-STATIC 2
RETURN-EFF 0.65
MAX-HUMIDITY 50
ZONE-NAMES (ZONE-5,ZONE-51) ..

```

```

SYS2 SYSTEM $ Core and public spaces
SYSTEM-TYPE VAVS
S-C NORM-CONT
M-O-A 0.50
REHEAT-DELTA-T 52
OA-CONTROL TEMP
F-SCH ALWAYS ON
SUPPLY-STATIC 4
SUPPLY-EFF 0.7
ZONE-NAMES (ZONE-2,ZONE-21,ZONE-4,ZONE-41) ..

```

PLT-1 PLANT-ASSIGNMENT SYSTEM-NAMES (SYS1,SYS2,SYS3,SYS4) ..

##defl sys\_rep[] 4

\$ SYSTEM REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/system\_rep.inc

\$ PLANT DATA \$

INPUT PLANT ..

PLT-1 PLANT-ASSIGNMENT ..

```

DHW P-E TYPE DHW-HEATER SIZE -999 ..
HWG P-E TYPE HW-BOILER SIZE -999 I-N 2 ..
CLG P-E TYPE HERM-CENT-CHLR SIZE -999 I-N 2 ..
CTW P-E TYPE COOLING-TWR SIZE -999 I-N 2 ..

```

PLANT-PARAMETERS

BOILER-FUEL NATURAL-GAS ..

/user2/bed/lirsce/DOE2/Proto/lghotel.inp

Tue Jan 29 01:57:11 1991

1

\$ DOE-2.1D BDL Input for Large\_Hotel  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*Large Hotel\*

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-Z B  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA FOR \$  
\$ LARGE HOTEL \$

OCC-LOB-ALL = DAY-SCHEDULE  
(1,8) (.1, .1, .1, .1, .1, .2, .4, .6)  
(9,16) (.6, .4, .2, .2, .2, .2, .2, .3)  
(17,24) (.6, .8, .8, .7, .5, .3, .3, .1)

OCC-LOB = SCHEDULE THRU DEC 31  
(ALL) OCC-LOB-ALL

LIGHT-LOB = SCHEDULE THRU DEC 31  
(ALL) (1,24) (1) ..

OCC-KIT-ALL = DAY-SCHEDULE  
(1,8) (.0, .0, .0, .0, .0, .0, .2, .4)  
(9,16) (.4, .4, .4, .4, .8, .8, .8, .8)  
(17,24) (.8, .8, .4, .4, .2, .2, .2, .2)

OCC-KIT = SCHEDULE THRU DEC 31  
(ALL) OCC-KIT-ALL

LIGHT-KIT = SCHEDULE THRU DEC 31  
(ALL) (1,7) (.1) (8,24) (.9)

EQUIP-KIT = SCHEDULE THRU DEC 31  
(ALL) (1,7) (0.0) (8,12) (0.2) (13,17) (0.8) (18,24) (0.3) ..

OCC-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.8, .8, .8, .8, .8, .8, .6, .4)  
(9,16) (.4, .2, .2, .2, .2, .2, .2, .3)  
(17,24) (.5, .5, .5, .6, .6, .8, .8, .8)

OCC-ROOM = SCHEDULE THRU DEC 31  
(ALL) OCC-ROOM-ALL

LIGHT-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.3, .3, .3, .3, .3, .3, .4, .4)  
(9,16) (.5, .5, .5, .5, .5, .5, .5, .5)

(17,24) (.5, .6, .7, .7, .7, .7, .6, .6)

LIGHT-ROOM = SCHEDULE THRU DEC 31  
(ALL) LIGHT-ROOM-ALL

DHW-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.21, .20, .20, .20, .22, .20, .51, .61)  
(9,16) (.59, .48, .42, .48, .45, .40, .35, .35)  
(17,24) (.33, .45, .60, .65, .55, .50, .48, .20)

DHW-ROOM = SCHEDULE THRU DEC 31  
(ALL) DHW-ROOM-ALL

ALLWAYSON = SCHEDULE THRU DEC 31  
(ALL) (1,24) (1) ..

\$ LOADS DATA \$

\$ Exterior Surfaces  
\$ Wall - poured concrete, insulation, air-space, gyp-board  
IN-W MATERIAL RES = 2.6 ..  
WALLR LAYERS MAT = (CC06, IN-W, AL21, GP02) ..  
WALL-1 CONSTRUCTION LAYERS = WALLR ..

\$ Roof - built-up roofing, concrete, insulation, air-space, acoustic tile  
IN-R MATERIAL RES = 5.8 ..  
ROOFR LAYERS MAT = (BR01, CC25, IN-R, AL33, AC02) ..  
ROOF-1 CONSTRUCTION LAYERS = ROOFR ..

\$ Floor - 4" light-weight conc., pad, carpet  
FLOORR LAYERS MAT = (CC24, CP01) ..  
FLOOR-1 CONSTRUCTION LAYERS = FLOORR ..

\$ Slab - 6" heavy-weight conc., 2' soil  
SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26  
CONDUCTIVITY = 1.0 DENSITY = 115 ..  
SLABL LAYERS MAT = (SOIL, CC15) ..  
SLAB-1 CONSTRUCTION LAYERS = SLABL ..

\$ Single Glass  
SINGLE GLASS-TYPE PANES = 1  
SHADING-COEF = 0.4  
GLASS-CONDUCTANCE = 1.0278  
..

\$ Zone Calculations  
\$ 70% Room, 25% Lobby/Conf, 5% Kitchen/Laundry  
\$ Room calcs (1600 = 400 sqft per room \* 4 orientations)  
\$ Wall calcs (lobby has three exterior walls, kitchen has one)

\$ DEFAULT CONSTRUCTIONS \$

SET-DEFAULT FOR EXTERIOR-WALL  
CONSTRUCTION = WALL-1  
HEIGHT = 10.  
..

SET-DEFAULT FOR WINDOW  
GLASS-TYPE = SINGLE  
..

\$ GENERAL SPACE CHARACTERISTICS \$

LOBBY-CONF SPACE-CONDITIONS

TEMPERATURE = (74)
P-SCH = OCC-LOB
P-H-S = 255
P-H-L = 255
L-SCH = LIGHT-LOB
L-T = REC-FLUOR-RV L-W = 1.5
FLOOR-WEIGHT = 70
Z-TYPE = CONDITIONED

KITCH-LAUND SPACE-CONDITIONS

TEMPERATURE = (74)
P-SCH = OCC-KIT
P-H-S = 345
P-H-L = 435
E-SCH = EQUIP-KIT E-W = 3.0
L-SCH = LIGHT-KIT
L-T = SUS-FLUOR L-W = 2.0
SOURCE-TYPE HOT-WATER
SOURCE-SCHEDULE EQUIP-KIT
SOURCE-BTU/HR = 165400
S-L 0.1 S-S 0.1
FLOOR-WEIGHT = 70
Z-TYPE = CONDITIONED

ROOM SPACE-CONDITIONS

TEMPERATURE = (74)
P-SCH = OCC-ROOM
N-O-P = 2
P-H-S = 230
P-H-L = 190
E-SCH = LIGHT-ROOM E-W = 0.6
L-SCH = LIGHT-ROOM
L-T = INCAND L-W = 1.0
FLOOR-WEIGHT = 70
Z-TYPE = CONDITIONED

BASE SPACE-CONDITIONS \$ Basement

ZONE-TYPE = UNCONDITIONED
INF-METHOD = AIR-CHANGE
AIR-CHANGES/HR = 2 \$ Combustion air
SOURCE-TYPE = PROCESS
SOURCE-BTU/HR = 140000 \$ 5% Jacket loss
SOURCE-SCHEDULE = ALLWAYSON
FLOOR-WEIGHT = 130

\$ LOBBY / CONFERENCE \$

LOBBY-CONF SPACE
SPACE-CONDITIONS = LOBBY-CONF
AREA = 51688
VOLUME = 516880
N-O-P = 258

LCEW-1 EXTERIOR-WALL
WIDTH = 170
AZIMUTH = 0

LCW-1 WINDOW
HEIGHT = 2
WIDTH = 170

EXTERIOR-WALL LIKE LCEW-1 AZIMUTH = 90 ..
WINDOW LIKE LCW-1 ..
EXTERIOR-WALL LIKE LCEW-1 AZIMUTH = 180 ..
WINDOW LIKE LCW-1 ..
EXTERIOR-WALL LIKE LCEW-1 AZIMUTH = 270 ..
WINDOW LIKE LCW-1 ..

LCF-1 INTERIOR-WALL \$ Floor to Basement
CONSTRUCTION = FLOOR-1
AREA = 51688
NEXT-TO BASEMENT

\$ KITCHEN / LAUNDRY \$

KIT-LND SPACE
SPACE-CONDITIONS = KITCH-LAUND
AREA = 10338
VOLUME = 103380
N-O-P = 26

KLEW-1 EXTERIOR-WALL
WIDTH = 25
AZIMUTH = 0

KLW-1 WINDOW
HEIGHT = 0.5
WIDTH = 25

EXTERIOR-WALL LIKE KLEW-1 AZIMUTH = 90 ..
WINDOW LIKE KLW-1 ..
EXTERIOR-WALL LIKE KLEW-1 AZIMUTH = 180 ..
WINDOW LIKE KLW-1 ..
EXTERIOR-WALL LIKE KLEW-1 AZIMUTH = 270 ..
WINDOW LIKE KLW-1 ..

KLF-1 INTERIOR-WALL \$ Floor to Basement
LIKE LCF-1
AREA = 10338
NEXT-TO BASEMENT

\$ ROOMS \$

ROOM-1 SPACE
MULTIPLIER = 80
SPACE-CONDITIONS = ROOM
AREA = 400
VOLUME = 4000

EW1 EXTERIOR-WALL
WIDTH = 20
AZIMUTH = 0

W1 WINDOW
HEIGHT = 2.7
WIDTH = 20

ROOM-2 SPACE LIKE ROOM-1
MULTIPLIER = 80
EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..
WINDOW LIKE W1 ..

ROOM-3 SPACE LIKE ROOM-1  
 MULTIPLIER = 80  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
 WINDOW LIKE W1 ..

ROOM-4 SPACE LIKE ROOM-1  
 MULTIPLIER = 80  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
 WINDOW LIKE W1 ..

ROOM-1T SPACE LIKE ROOM-1  
 MULTIPLIER = 10  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 0 ..  
 WINDOW LIKE W1 ..

R1 ROOF CONSTRUCTION = ROOF-1  
 TILT = 0.0  
 GND-REFLECTANCE = 0.0  
 HEIGHT = 20  
 WIDTH = 20  
 ..

ROOM-2T SPACE LIKE ROOM-1T  
 MULTIPLIER = 10  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..  
 WINDOW LIKE W1 ..  
 ROOF LIKE R1 ..

ROOM-3T SPACE LIKE ROOM-1T  
 MULTIPLIER = 10  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
 WINDOW LIKE W1 ..  
 ROOF LIKE R1 ..

ROOM-4T SPACE LIKE ROOM-1T  
 MULTIPLIER = 10  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
 WINDOW LIKE W1 ..  
 ROOF LIKE R1 ..

\$ Basement

BASEMENT SPACE  
 SPACE-CONDITIONS = BASE  
 AREA = 62026  
 VOLUME = 496200  
 ..

SLB-1 UNDERGROUND-FLOOR  
 CONSTRUCTION = SLAB-1  
 AREA = 62026  
 U-EFFECTIVE = 0.0414  
 ..

\$ BUILDING RESOURCES \$

BUILDING-RESOURCE

V-T-SCH = OCC-KIT  
 VERT-TRANS-KW = 54  
 HW-SCHEDULE = DHW-ROOM  
 HOT-WATER = 280000  
 GAS-SCHEDULE = EQUIP-KIT  
 GAS-THERMS = 3.72  
 ..

\$ LOADS REPORT DATA \$

\$ Space peak loads summary, Building peak load components  
 LOADS-REPORT S (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

\$ fan schedules \$

FAN-KIT = SCH \$ fan schedule for kitchen  
 THRU DEC 31 (ALL) (1,7) (0) (8,24) (1)

ALWAYSON = SCH  
 THRU DEC 31 (ALL) (1,24) (1) ..

\$ Heat-Temp and Cool-Temp schedules\$

ROOMHT = SCH THRU DEC 31  
 (ALL) (1,8) (72) (9,23) (65) (24) (72) ..

ROOMCL = SCH THRU DEC 31  
 (ALL) (1,24) (76) ..

KITHT = SCH THRU DEC 31  
 (ALL) (1,7) (65) (8,24) (70) ..

KITCL = SCH THRU DEC 31  
 (ALL) (1,7) (85) (8,24) (78) ..

LOBHT = SCH THRU DEC 31  
 (ALL) (1,24) (72) ..

LOBCL = SCH THRU DEC 31  
 (ALL) (1,24) (76) ..

KIT-AIR = ZONE-AIR OA-CHANGES = 3.0 ..

LOB-AIR = ZONE-AIR OA-CFM/PER = 15 ..

CNTRL-LOB ZONE-CONTROL  
 DESIGN-HEAT-T 72  
 DESIGN-COOL-T 76  
 HEAT-TEMP-SCH LOBHT  
 COOL-TEMP-SCH LOBCL  
 THERMOSTAT-TYPE PROPORTIONAL  
 ..

CNTRL-KIT ZONE-CONTROL  
 DESIGN-HEAT-T 70

/user2/bed/lirsce/DOE2/Proto/lghotel.inp

Tue Jan 29 01:57:11 1991

4

```
DESIGN-COOL-T 78
HEAT-TEMP-SCH KITHT
COOL-TEMP-SCH KITCL
THERMOSTAT-TYPE PROPORTIONAL
..

CNTRL-ROOM ZONE-CONTROL
DESIGN-HEAT-T 72
DESIGN-COOL-T 76
HEAT-TEMP-SCH ROOMHT
COOL-TEMP-SCH ROOMCL
THERMOSTAT-TYPE PROPORTIONAL
..

KIT-LND ZONE
ZONE-TYPE CONDITIONED
ZONE-AIR KIT-AIR
ZONE-CONTROL CNTRL-KIT
..

LOB-CON ZONE LIKE KIT-LND
ZONE-AIR LOB-AIR
ZONE-CONTROL CNTRL-LOB ..

ROOM-1 ZONE LIKE LOB-CON
MULTIPLIER = 80
ZONE-CONTROL CNTRL-ROOM ..

ROOM-2 ZONE LIKE ROOM-1 ..
ROOM-3 ZONE LIKE ROOM-1 ..
ROOM-4 ZONE LIKE ROOM-1 ..
ROOM-1T ZONE LIKE ROOM-1
MULTIPLIER = 10 ..
ROOM-2T ZONE LIKE ROOM-1T ..
ROOM-3T ZONE LIKE ROOM-1T ..
ROOM-4T ZONE LIKE ROOM-1T ..
BASEMENT ZONE ZONE-TYPE UNCONDITIONED ..

NORM-CONT SYSTEM-CONTROL
MAX-S-T 110 MIN-S-T 52
H-SCH ALWAYSON
C-SCH ALWAYSON
..

SYS1 SYSTEM $ lobby
SYSTEM-TYPE VAVS
MIN-CFM-RATIO 0.1
OA-CONTROL TEMP
ECONO-LIMIT-T 68
REHEAT-DELTA-T 50
S-C NORM-CONT
F-SCH ALWAYSON
ZONE-NAMES (LOB-CON,BASEMENT) ..

SYS2 SYSTEM $ kitchen
SYSTEM-TYPE SZRH
S-C NORM-CONT
REHEAT-DELTA-T 50
F-SCH FAN-KIT
ZONE-NAMES (KIT-LND) ..

SYS3 SYSTEM $ rooms
SYSTEM-TYPE FPFC
S-C NORM-CONT
ZONE-NAMES (ROOM-1,ROOM-2,ROOM-3,ROOM-4
ROOM-1T,ROOM-2T,ROOM-3T,ROOM-4T) ..
```

```
PLT-1 PLANT-ASSIGNMENT
SYSTEM-NAMES (SYS1,SYS2,SYS3) ..

##defl sys_rep[] 3
$ SYSTEM REPORT DATA $

##include /user2/bed/lirsce/DOE2/Proto/system_rep.inc
$ PLANT DATA $

INPUT PLANT ..
PLT-1 PLANT-ASSIGNMENT ..

DHW P-E TYPE DHW-HEATER SIZE -999 ..
HWG P-E TYPE HW-BOILER SIZE -999 I-N 2 ..
CLG P-E TYPE HERM-CENT-CHLR SIZE -999 I-N 2 ..
CTW P-E TYPE COOLING-TWR SIZE -999 I-N 2 ..

PLANT-PARAMETERS
BOILER-FUEL NATURAL-GAS ..

$ PLANT REPORT DATA $

##include /user2/bed/lirsce/DOE2/Proto/plant_rep.inc

STOP ..
```

/user2/bed/lirsce/DOE2/Proto/library.inp

Mon Jan 28 19:17:01 1991

1

\$ DOE-2.1D BDL Input for College Library  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*College Library\*  
..

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-2 8  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES  
..

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA \$

OCC-1 = DAY-SCHEDULE  
 (1,6) (0)  
 (7) (.2)  
 (8,11) (.5)  
 (12) (.4)  
 (13,17) (.6)  
 (18,19) (.4)  
 (20,23) (.7)  
 (24) (.2) ..

OCC-2 = DAY-SCHEDULE  
 (1,9) (0)  
 (10) (.2)  
 (11,12) (.4)  
 (13,16) (.6)  
 (17,18) (.3)  
 (19,24) (0) ..

OCC = SCHEDULE THRU DEC 31 (WD) OCC-1 (WEH) OCC-2 ..

LTS-1 = DAY-SCHEDULE  
 (1,6) (.2)  
 (7) (.5)  
 (8,23) (.9)  
 (24) (.2) ..

LTS-2 = DAY-SCHEDULE  
 (1,9) (.2)  
 (10,18) (.9)  
 (19,24) (.2) ..

LTS = SCHEDULE THRU DEC 31 (WD) LTS-1 (WEH) LTS-2 ..

\$ LOADS DATA \$

\$ Exterior Surfaces  
 IN-W MATERIAL RES = 1 ..  
 WA1 LAYERS MATERIAL = (CB31,IN-W,GP02) ..  
 IN-R MATERIAL RES = 4.9 ..  
 RF1 LAYERS MATERIAL = (BR01,PW04,IN-R,AL33,GP02)  
 INSIDE-FIIM-RES=.61 ..

TYP-WALL = CONSTRUCTION LAYERS = WA1 ..  
 TYP-ROOF = CONSTRUCTION LAYERS = RF1 ..  
 SINGLE = GLASS-TYPE PANES = 1 ..  
 SHADING-COEF = 0.6 ..  
 GLASS-CONDUCTANCE = 1.03 ..

\$ Slab - 2' 11, 6" heavy-weight conc.  
 SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26  
 CONDUCTIVITY = 1.0 DENSITY = 115 ..  
 SLABL LAYERS MAT = (SOIL,CC15) ..  
 SLAB-1 CONSTRUCTION LAYERS = SLABL ..

ROOM SPACE-CONDITIONS  
 TEMPERATURE = (74)  
 PEOPLE-SCHEDULE = OCC  
 NUMBER-OF-PEOPLE = 30  
 PEOPLE-HEAT-GAIN = 420  
 LIGHTING-SCHEDULE = LTS  
 LIGHTING-TYPE = REC-FLUOR-NV  
 LIGHTING-W/SQFT = 1.7  
 FLOOR-WEIGHT = 70  
 ..

ROOM1 = SPACE  
 SPACE-CONDITIONS = ROOM  
 AREA = 10000  
 VOLUME = 100000  
 ..

EWALL = EXTERIOR-WALL  
 CONSTRUCTION = TYP-WALL  
 WIDTH = 250  
 HEIGHT = 10  
 AZIMUTH = 0  
 ..

WIND = WINDOW  
 GLASS-TYPE = SINGLE  
 WIDTH = 250  
 HEIGHT = 1  
 ..

EROOF = ROOF  
 CONSTRUCTION = TYP-ROOF  
 GND-REFLECTANCE = 0  
 TILT = 0  
 WIDTH = 200  
 HEIGHT = 200  
 ..

SLB = UNDERGROUND-FLOOR  
 CONSTRUCTION = SLAB-1  
 AREA = 40000  
 U-EFFECTIVE = 0.0346  
 ..

ROOM2 = SPACE LIKE ROOM1 ..  
 EXTERIOR-WALL LIKE EWALL AZIMUTH = 90 ..  
 WINDOW LIKE WIND ..  
 ROOF LIKE EROOF ..  
 UNDERGROUND-FLOOR LIKE SLB ..

/user2/bed/lirsce/DOE2/Proto/library.inp

Mon Jan 28 19:17:01 1991

2

ROOM3 = SPACE LIKE ROOM1 ..  
EXTERIOR-WALL LIKE EWALL AZIMUTH = 180 ..  
WINDOW LIKE WIND ..  
ROOF LIKE EROOF ..  
UNDERGROUND-FLOOR LIKE SLB ..

ROOM2 ZONE-CONTROL ROOMCON ..  
ZONE LIKE ROOM1 ..  
ROOM3 ZONE LIKE ROOM1 ..  
ROOM4 ZONE LIKE ROOM1 ..

ROOM4 = SPACE LIKE ROOM1 ..  
EXTERIOR-WALL LIKE EWALL AZIMUTH = 270 ..  
WINDOW LIKE WIND ..  
ROOF LIKE EROOF ..  
UNDERGROUND-FLOOR LIKE SLB ..

SYS1 SYSTEM  
SYSTEM-TYPE RHFS  
REHEAT-DELTA-T 50  
COOL-SET-T 55  
MAX-SUPPLY-T 105  
MIN-SUPPLY-T 55  
MIN-CFM-RATIO 0.1  
ECONO-LIMIT-T 68  
OA-CONTROL TEMP  
FAN-SCHEDULE FAN  
ZONE-NAMES (ROOM1,ROOM2,ROOM3,ROOM4)  
..

\$ LOADS REPORT DATA \$

\$ Space peak loads summary, Building peak load components  
LOADS-REPORT S (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

FAN = SCHEDULE THRU DEC 31 (ALL) (1,24) (1) ..

CLG1 = DAY-SCHEDULE  
(1,5) (85)  
(6,24) (78) ..  
CLG2 = DAY-SCHEDULE  
(1,8) (85)  
(9,18) (78)  
(19,24) (85) ..

COOLING = SCHEDULE THRU DEC 31 (WD) CLG1 (WEH) CLG2 ..

HTG1 = DAY-SCHEDULE  
(1,5) (65)  
(6,24) (72) ..  
HTG2 = DAY-SCHEDULE  
(1,8) (65)  
(9,18) (72)  
(19,24) (65) ..

HEATING = SCHEDULE THRU DEC 31 (WD) HTG1 (WEH) HTG2 ..

ZNAIR = ZONE-AIR OA-CFM/PER 15.0 ..

ROOMCON = ZONE-CONTROL  
DESIGN-HEAT-T 72  
DESIGN-COOL-T 78  
HEAT-TEMP-SCH HEATING  
COOL-TEMP-SCH COOLING  
THROTTLING-RANGE 3  
THERMOSTAT-TYPE PROPORTIONAL  
..

ROOM1 ZONE  
ZONE-TYPE CONDITIONED  
ZONE-AIR ZNAIR

PLT-1 PLANT-ASSIGNMENT SYSTEM-NAMES (SYS1) ..

##defl sys\_rep[] 1

\$ SYSTEM REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/system\_rep.inc

\$ PLANT DATA \$

INPUT PLANT ..

PLT-1 PLANT-ASSIGNMENT ..

HWG P-E TYPE HW-BOILER SIZE -999 I-N 2 ..  
CLG P-E TYPE HERM-CENT-CHLR SIZE -999 I-N 2 ..  
CTW P-E TYPE COOLING-TWR SIZE -999 I-N 2 ..

PLANT-PARAMETERS

BOILER-FUEL NATURAL-GAS ..

\$ PLANT REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/plant\_rep.inc

STOP ..



/user2/bed/lirsce/DOE2/Proto/nursing.inp

Tue Jan 29 19:55:57 1991

1

\$ DOE-2.1D BDL Input for Nursing Home  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*Nursing Home\*  
..

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-2 B  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES  
..

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA \$

OCC-MULT-ALL = DAY-SCHEDULE  
(1,8) ( 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.3, 0.4)  
(9,16) ( 0.6, 0.4, 0.3, 0.3, 0.4, 0.5, 0.6, 0.6)  
(17,24) ( 0.6, 0.5, 0.4, 0.2, 0.0, 0.0, 0.0, 0.0)  
..

OCC-MULT = SCHEDULE THRU DEC 31  
(ALL) OCC-MULT-ALL  
..

LIGHT-MULT = SCHEDULE THRU DEC 31  
(ALL) (1,6) (.3) (7,17) (.9) (18,20) (.6) (21,24) (.3) ..

OCC-KIT-ALL = DAY-SCHEDULE  
(1,8) ( 0.0, 0.0, 0.0, 0.0, 0.0, 0.5, 0.7, 0.9)  
(9,16) ( 0.9, 0.7, 0.4, 0.7, 0.7, 0.3, 0.3, 0.5)  
(17,24) ( 0.5, 0.2, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0)  
..

OCC-KIT = SCHEDULE THRU DEC 31  
(ALL) OCC-KIT-ALL  
..

LIGHT-KIT = SCHEDULE THRU DEC 31  
(ALL) (1,5) (.1) (6,18) (.9) (19,24) (.1)  
..

EQUIP-KIT = SCHEDULE THRU DEC 31 (ALL)  
(1,8) ( 0.0, 0.0, 0.0, 0.0, 0.0, 0.2, 0.2, 0.5)  
(9,16) ( 0.6, 0.5, 0.5, 0.8, 0.8, 0.4, 0.4, 0.4)  
(17,24) ( 0.2, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0)  
..

OCC-ROOM-ALL = DAY-SCHEDULE  
(1,8) ( .9, .9, .9, .9, .9, .9, .7, .4)  
(9,16) ( .4, .4, .4, .6, .5, .4, .4, .4)  
(17,24) ( .5, .5, .5, .7, .8, .9, .9, .9)  
..

OCC-ROOM = SCHEDULE THRU DEC 31  
(ALL) OCC-ROOM-ALL  
..

LIGHT-ROOM-ALL = DAY-SCHEDULE  
(1,8) ( .2, .2, .2, .2, .2, .2, .4, .5)

(9,16) ( .4, .4, .25, .25, .25, .25, .25, .25)  
(17,24) ( .25, .25, .6, .7, .5, .2, .2, .2)  
..

LIGHT-ROOM = SCHEDULE THRU DEC 31  
(ALL) LIGHT-ROOM-ALL  
..

DHW-ROOM-ALL = DAY-SCHEDULE  
(1,8) ( .21, .20, .20, .20, .22, .20, .51, .61)  
(9,16) ( .59, .48, .42, .48, .45, .40, .35, .35)  
(17,24) ( .33, .45, .60, .65, .55, .50, .48, .20)  
..

DHW-ROOM = SCHEDULE THRU DEC 31  
(ALL) DHW-ROOM-ALL  
..

\$ LOADS DATA \$

\$ Exterior Surfaces  
\$ Wall - plywood,insulation,gyp-board  
IN-W MATERIAL RES = 1.0 ..  
WALLR LAYERS MAT = (PW04,IN-W,GP02) ..  
WALL-1 CONSTRUCTION LAYERS = WALLR ..

\$ Roof - built-up roofing,plywood,insulation,air-space,accoustic tile  
IN-R MATERIAL RES = 8.0 ..  
ROOFR LAYERS MAT = (BR01,PW05,IN-R,AL33,AC02) ..  
ROOF-1 CONSTRUCTION LAYERS = ROOFR ..

\$ Slab - 2' soil, 6" heavy-weight conc., pad, carpet  
SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26  
CONDUCTIVITY = 1.0 DENSITY = 115 ..  
SLABL LAYERS MAT = (SOIL,CC15,CP01) ..  
SLAB-1 CONSTRUCTION LAYERS = SLABL ..

\$ Single Glass  
SINGLE GLASS-TYPE PANES = 1  
SHADING-COEF = 0.4  
GLASS-CONDUCTANCE = 1.0278  
..

\$ DEFAULT CONSTRUCTIONS \$

SET-DEFAULT FOR EXTERIOR-WALL  
CONSTRUCTION = WALL-1  
HEIGHT = 8.  
..

SET-DEFAULT FOR WINDOW  
GLASS-TYPE = SINGLE  
..

\$ GENERAL SPACE CHARACTERISTICS \$

MULT SPACE-CONDITIONS  
TEMPERATURE = (74)  
P-SCH = OCC-MULT  
P-H-S = 255  
P-H-L = 255  
L-SCH = LIGHT-MULT  
L-T = REC-FLUOR-RV L-W = 1.5  
FLOOR-WEIGHT = 70  
Z-TYPE = CONDITIONED  
..

KIT SPACE-CONDITIONS

TEMPERATURE = (74)  
 P-SCH = OCC-KIT  
 P-H-S = 345  
 P-H-L = 435  
 E-SCH = EQUIP-KIT E-W = 3.0  
 L-SCH = LIGHT-KIT  
 L-T = SUS-FLUOR I-W = 1.7  
 SOURCE-TYPE HOT-WATER  
 SOURCE-SCHEDULE EQUIP-KIT  
 SOURCE-BTU/HR = 21452  
 S-L 0.1 S-S 0.1  
 FLOOR-WEIGHT = 70  
 Z-TYPE = CONDITIONED

LDEW-1 EXTERIOR-WALL  
 WIDTH = 180  
 AZIMUTH = 0  
 ..  
 EXTERIOR-WALL LIKE LDEW-1 AZIMUTH = 90 ..  
 EXTERIOR-WALL LIKE LDEW-1 AZIMUTH = 180 ..  
 EXTERIOR-WALL LIKE LDEW-1 AZIMUTH = 270 ..  
 ..  
 UNDERGROUND-FLOOR  
 LIKE SLB-1  
 AREA = 2000  
 U-EFFECTIVE = 0.0284  
 ..

ROOM SPACE-CONDITIONS

TEMPERATURE = (74)  
 P-SCH = OCC-ROOM  
 N-O-P = 2  
 P-H-S = 230  
 P-H-L = 190  
 E-SCH = LIGHT-ROOM E-W = 0.6  
 L-SCH = LIGHT-ROOM  
 L-T = INCAND L-W = 1.0  
 FLOOR-WEIGHT = 70  
 Z-TYPE = CONDITIONED

\$ ROOMS \$

ROOM-1 SPACE  
 MULTIPLIER = 12  
 SPACE-CONDITIONS = ROOM  
 AREA = 400  
 VOLUME = 3200  
 ..  
 EW1 EXTERIOR-WALL  
 WIDTH = 20  
 AZIMUTH = 0  
 ..  
 W1 WINDOW  
 HEIGHT = 1.5  
 WIDTH = 20  
 ..  
 R1 ROOF CONSTRUCTION = ROOF-1  
 TILT = 0.0  
 GND-REFLECTANCE = 0.0  
 HEIGHT = 20  
 WIDTH = 20  
 ..  
 SL1 UNDERGROUND-FLOOR  
 LIKE SLB-1  
 AREA = 400  
 U-EFFECTIVE = 0.104  
 ..

\$ MULTIPURPOSE \$

MULTIP SPACE  
 SPACE-CONDITIONS = MULT  
 AREA = 8000  
 VOLUME = 64000  
 N-O-P = 150  
 ..

ROOM-2 SPACE LIKE ROOM-1  
 MULTIPLIER = 12  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..  
 WINDOW LIKE W1 ..  
 ROOF LIKE R1 ..  
 UNDERGROUND-FLOOR LIKE SL1 ..  
 ..  
 ROOM-3 SPACE LIKE ROOM-1  
 MULTIPLIER = 12  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
 WINDOW LIKE W1 ..  
 ROOF LIKE R1 ..  
 UNDERGROUND-FLOOR LIKE SL1 ..

LBEW-1 EXTERIOR-WALL  
 WIDTH = 120  
 AZIMUTH = 0  
 ..

LBW-1 WINDOW  
 HEIGHT = 1.5  
 WIDTH = 120  
 ..

EXTERIOR-WALL LIKE LBEW-1 AZIMUTH = 90 ..  
 WINDOW LIKE LBW-1 ..  
 EXTERIOR-WALL LIKE LBEW-1 AZIMUTH = 180 ..  
 WINDOW LIKE LBW-1 ..  
 EXTERIOR-WALL LIKE LBEW-1 AZIMUTH = 270 ..  
 WINDOW LIKE LBW-1 ..

SLB-1 UNDERGROUND-FLOOR  
 CONSTRUCTION = SLAB-1  
 AREA = 8000  
 U-EFFECTIVE = 0.0852  
 ..

\$ KITCHEN \$

KITCHEN SPACE  
 SPACE-CONDITIONS = KIT  
 AREA = 2000  
 VOLUME = 16000  
 N-O-P = 5  
 ..

ROOM-4 SPACE LIKE ROOM-1  
 MULTIPLIER = 12  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
 WINDOW LIKE W1 ..  
 ROOF LIKE R1 ..

UNDERGROUND-FLOOR LIKE SL1 ..

\$ BUILDING RESOURCES \$

BUILDING-RESOURCE
HW-SCHEDULE = DHW-ROOM
HOT-WATER = 85824
..

\$ LOADS REPORT DATA \$

\$ Space peak loads summary, Building peak load components
LOADS-REPORT \$ (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

\$ fan schedules \$

ALWAYSON = SCH
THRU DEC 31 (ALL) (1,24) (1) ..

\$ Heat-Temp and Cool-Temp schedules\$

ROOMHT = SCH THRU DEC 31
(ALL) (1,24) (70) ..
ROOMCL = SCH THRU DEC 31
(ALL) (1,24) (76) ..
KITHT = SCH THRU DEC 31
(ALL) (1,4) (65) (5,21) (70) (22,24) (65) ..
KITCL = SCH THRU DEC 31
(ALL) (1,4) (85) (5,21) (80) (22,24) (85) ..
MULHT = SCH THRU DEC 31
(ALL) (1,7) (65) (8,20) (70) (21,24) (65) ..
MULCL = SCH THRU DEC 31
(ALL) (1,7) (85) (8,20) (80) (21,24) (85) ..

KIT-AIR = ZONE-AIR OA-CHANGES = 3.0 ..

MUL-AIR = ZONE-AIR OA-CFM/PER = 15 ..

CNTRL-MUL ZONE-CONTROL
DESIGN-HEAT-T 70
DESIGN-COOL-T 78
HEAT-TEMP-SCH MULHT
COOL-TEMP-SCH MULCL
THERMOSTAT-TYPE PROPORTIONAL
..

CNTRL-KIT ZONE-CONTROL
DESIGN-HEAT-T 70
DESIGN-COOL-T 80
HEAT-TEMP-SCH KITHT

COOL-TEMP-SCH KITCL
THERMOSTAT-TYPE PROPORTIONAL
..

CNTRL-ROOM ZONE-CONTROL
DESIGN-HEAT-T 70
DESIGN-COOL-T 78
HEAT-TEMP-SCH ROOMHT
COOL-TEMP-SCH ROOMCL
THERMOSTAT-TYPE PROPORTIONAL
..

MULTIP ZONE
ZONE-TYPE CONDITIONED
ZONE-AIR MUL-AIR
ZONE-CONTROL CNTRL-MUL
..

KITCHEN ZONE LIKE MULTIP
ZONE-AIR KIT-AIR
ZONE-CONTROL CNTRL-KIT ..

ROOM-1 ZONE LIKE MULTIP
MULTIPLIER = 12
ZONE-CONTROL CNTRL-ROOM ..
ROOM-2 ZONE LIKE ROOM-1 ..
ROOM-3 ZONE LIKE ROOM-1 ..
ROOM-4 ZONE LIKE ROOM-1 ..

NORM-CONT SYSTEM-CONTROL
MAX-S-T 110 MIN-S-T 52
H-SCH ALWAYSON
C-SCH ALWAYSON
..

SYS1 SYSTEM \$ multipurpose
SYSTEM-TYPE PSZ
OA-CONTROL FIXED
S-C NORM-CONT
F-SCH ALWAYSON
ZONE-NAMES (MULTIP) ..

SYS2 SYSTEM \$ kitchen
LIKE SYS1
ZONE-NAMES (KITCHEN) ..

SYS3 SYSTEM \$ rooms
SYSTEM-TYPE PTAC
S-C NORM-CONT
HEAT-SOURCE GAS-FURNACE
ZONE-NAMES (ROOM-1,ROOM-2,ROOM-3,ROOM-4) ..

PLT-1 PLANT-ASSIGNMENT
SYSTEM-NAMES (SYS1,SYS2,SYS3) ..

##defl sys\_rep[] 3

\$ SYSTEM REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/system\_rep.inc

\$ PLANT DATA \$

INPUT PLANT ..
PLT-1 PLANT-ASSIGNMENT ..

/user2/bed/lirsce/DOE2/Proto/nursing.inp

Tue Jan 29 19:55:57 1991

4

DHW P-E TYPE DHW-HEATER SIZE -999 ..

\$ PLANT REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/plant\_rep.inc

STOP ..

/user2/bed/lirsce/DOE2/Proto/prischool.inp

Mon Jan 28 19:20:18 1991

1

\$ DOE-2.1D BDL Input for Primary School  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*Primary School\*

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-Z 8  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA \$

OCC-CLASS1 = DAY-SCHEDULE  
(1,6) (0)  
(7) (.1)  
(8,11) (.9)  
(12) (.2)  
(13,15) (.8)  
(16,18) (.2)  
(19,24) (0) ..  
OCC-CLASS2 = DAY-SCHEDULE  
(1,24) (0) ..  
OC-CLASS = WEEK-SCHEDULE (WD) OCC-CLASS1 (WEH) OCC-CLASS2 ..  
UNOC-CLASS = WEEK-SCHEDULE (ALL) OCC-CLASS2 ..  
OCC-CLASS = SCHEDULE THRU JUN 1 OC-CLASS  
THRU SEP 1 UNOC-CLASS  
THRU DEC 20 OC-CLASS  
THRU DEC 31 UNOC-CLASS ..

LTS-CLASS1 = DAY-SCHEDULE  
(1,6) (.1)  
(7) (.2)  
(8,15) (.9)  
(16,18) (.3)  
(19,24) (.1) ..  
LTS-CLASS2 = DAY-SCHEDULE  
(1,24) (.1) ..  
LT-CLASS = WEEK-SCHEDULE (WD) LTS-CLASS1 (WEH) LTS-CLASS2 ..  
UNLT-CLASS = WEEK-SCHEDULE (ALL) LTS-CLASS2 ..  
LTS-CLASS = SCHEDULE THRU JUN 1 LT-CLASS  
THRU SEP 1 UNLT-CLASS  
THRU DEC 20 LT-CLASS  
THRU DEC 31 UNLT-CLASS ..

OCC-KIT1 = DAY-SCHEDULE  
(1,9) (0)  
(10) (.7)  
(11,13) (1)

(14) (.7)  
(15,24) (0) ..  
OCC-KIT2 = DAY-SCHEDULE  
(1,24) (0) ..  
OC-KIT = WEEK-SCHEDULE (WD) OCC-KIT1 (WEH) OCC-KIT2 ..  
UNOC-KIT = WEEK-SCHEDULE (ALL) OCC-KIT2 ..  
OCC-KIT = SCHEDULE THRU JUN 1 OC-KIT  
THRU SEP 1 UNOC-KIT  
THRU DEC 20 OC-KIT  
THRU DEC 31 UNOC-KIT ..

LTS-KIT1 = DAY-SCHEDULE  
(1,9) (.1)  
(10) (.5)  
(11,13) (1)  
(14,24) (.1) ..  
LTS-KIT2 = DAY-SCHEDULE  
(1,24) (0) ..  
LT-KIT = WEEK-SCHEDULE (WD) LTS-KIT1 (WEH) LTS-KIT2 ..  
UNLT-KIT = WEEK-SCHEDULE (ALL) LTS-KIT2 ..  
LTS-KIT = SCHEDULE THRU JUN 1 LT-KIT  
THRU SEP 1 UNLT-KIT  
THRU DEC 20 LT-KIT  
THRU DEC 31 UNLT-KIT ..

EQP-KITCHEN1 = DAY-SCHEDULE  
(1,9) (0)  
(10) (.25)  
(11) (.3)  
(12) (.9)  
(13) (.8)  
(14,24) (0) ..  
EQP-KITCHEN2 = DAY-SCHEDULE  
(1,24) (0) ..  
EQ-KITCHEN = WEEK-SCHEDULE (WD) EQP-KITCHEN1 (WEH) EQP-KITCHEN2 ..  
UNEQ-KITCHEN = WEEK-SCHEDULE (ALL) EQP-KITCHEN2 ..  
EQP-KIT = SCHEDULE THRU JUN 1 EQ-KITCHEN  
THRU SEP 1 UNEQ-KITCHEN  
THRU DEC 20 EQ-KITCHEN  
THRU DEC 31 UNEQ-KITCHEN ..

INFIL1 = DAY-SCHEDULE  
(1,7) (1)  
(8,18) (0)  
(19,24) (1) ..  
INFIL2 = DAY-SCHEDULE  
(1,24) (1) ..  
INF = WEEK-SCHEDULE (WD) INFIL1 (WEH) INFIL2 ..  
UNINF = WEEK-SCHEDULE (ALL) INFIL2 ..  
INFIL = SCHEDULE THRU JUN 1 INF  
THRU SEP 1 UNINF  
THRU DEC 20 INF  
THRU DEC 31 UNINF ..

SERVICE-HW1 = DAY-SCHEDULE  
(1,7) (0)  
(8) (.05)  
(9) (.3)  
(10) (.55)  
(11) (.6)  
(12) (.7)  
(13) (.75)

```

(14) (.5)
(15,16) (.2)
(17,24) (0) ..
SERVICE-HW2 = DAY-SCHEDULE
(1,24) (0) ..
SRC-HW = WEEK-SCHEDULE (WD) SERVICE-HW1 (WEH) SERVICE-HW2 ..
UNSRC-HW = WEEK-SCHEDULE (ALL) SERVICE-HW2 ..
SERVICE-HW = SCHEDULE THRU JUN 1 SRC-HW
THRU SEP 1 UNSRC-HW
THRU DEC 20 SRC-HW
THRU DEC 31 UNSRC-HW ..
    
```

\$ LOADS DATA \$

\$ Exterior Surfaces

```

IN-W MATERIAL RES = 1 ..
WA1 LAYERS MATERIAL = (CB31,IN-W,GP02) ..
IN-R MATERIAL RES = 4.9 ..
RF1 LAYERS MATERIAL = (BR01,PW04,IN-R,AL33,GP02)
INSIDE-FILM-RES=.61 ..

TYP-WALL = CONSTRUCTION LAYERS = WA1 ..
TYP-ROOF = CONSTRUCTION LAYERS = RF1 ..
GLASS1 = GLASS-TYPE PANES = 1 ..
SHADING-COEF = 0.85
GLASS-CONDUCTANCE = 1.03 ..
    
```

```

$ Slab - 2' soil, 6" heavy-weight conc.
SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26
CONDUCTIVITY = 1.0 DENSITY = 115 ..
SLAB LAYERS MAT = (SOIL,CC15) ..
SLAB-1 CONSTRUCTION LAYERS = SLABL ..
    
```

```

SET-DEFAULT FOR WINDOW GLASS-TYPE = GLASS1 ..
    
```

```

SP-CLASS SPACE-CONDITIONS
TEMPERATURE = (75)
PEOPLE-SCHEDULE = OCC-CLASS
NUMBER-OF-PEOPLE = 20
PEOPLE-HEAT-GAIN = 450
EQUIP-SCHEDULE = LTS-CLASS
EQUIPMENT-W/SQFT = .5
LIGHTING-SCHEDULE = LTS-CLASS
LIGHTING-TYPE = REC-FLUOR-NV
LIGHTING-W/SQFT = 2.2
INF-SCHEDULE = INFIL
INF-METHOD = AIR-CHANGE
INF-CFM/SQFT = .083
FLOOR-WEIGHT = 70
..
    
```

```

SP-LIB SPACE-CONDITIONS
TEMPERATURE = (75)
PEOPLE-SCHEDULE = OCC-CLASS
NUMBER-OF-PEOPLE = 80
PEOPLE-HEAT-GAIN = 550
EQUIP-SCHEDULE = LTS-CLASS
EQUIPMENT-W/SQFT = .5
LIGHTING-SCHEDULE = LTS-CLASS
LIGHTING-TYPE = REC-FLUOR-NV
LIGHTING-W/SQFT = 1.5
    
```

```

INF-SCHEDULE = INFIL
INF-METHOD = AIR-CHANGE
INF-CFM/SQFT = .083
FLOOR-WEIGHT = 70
..
    
```

SP-KIT

```

SPACE-CONDITIONS
TEMPERATURE = (75)
PEOPLE-SCHEDULE = OCC-KIT
NUMBER-OF-PEOPLE = 10
PEOPLE-HEAT-GAIN = 640
EQUIP-SCHEDULE = EQP-KIT
EQUIPMENT-W/SQFT = 50
LIGHTING-SCHEDULE = LTS-KIT
LIGHTING-TYPE = REC-FLUOR-NV
LIGHTING-W/SQFT = 1.7
SOURCE-BTU/HR = 300000
SOURCE-SCHEDULE = EQP-KIT
SOURCE-TYPE = HOT-WATER
SOURCE-SENSIBLE = .3
SOURCE-LATENT = .7
INF-SCHEDULE = INFIL
INF-METHOD = AIR-CHANGE
INF-CFM/SQFT = .333
FLOOR-WEIGHT = 70
..
    
```

CLASS

```

SPACE
SPACE-CONDITIONS = SP-CLASS
AREA = 1800
VOLUME = 18000
MULTIPLIER = 15
..
    
```

EWALLC

```

EXTERIOR-WALL
CONSTRUCTION = TYP-WALL
WIDTH = 15 $ 60 ft 4 ways
HEIGHT = 10
AZIMUTH = 0
..
    
```

WINDC

```

WINDOW
WIDTH = 15
HEIGHT = 2.5
..
EXTERIOR-WALL LIKE EWALLC AZIMUTH = 90 ..
WINDOW LIKE WINDC ..
EXTERIOR-WALL LIKE EWALLC AZIMUTH = 180 ..
WINDOW LIKE WINDC ..
EXTERIOR-WALL LIKE EWALLC AZIMUTH = 270 ..
WINDOW LIKE WINDC ..
    
```

EROOFC

```

ROOF
CONSTRUCTION = TYP-ROOF
GND-REFLECTANCE = 0
TILT = 0
WIDTH = 60
HEIGHT = 30
..
    
```

SLBC

```

UNDERGROUND-FLOOR
CONSTRUCTION = SLAB-1
AREA = 1800
U-EFFECTIVE = 0.0346
..
    
```

```

LIBRARY=    SPACE
            SPACE-CONDITIONS = SP-LIB
            AREA              = 6000
            VOLUME            = 60000
            ..
EWALLL     EXTERIOR-WALL LIKE EWALLC  WIDTH = 80 ..
WINDL      WINDOW LIKE WINDC  WIDTH = 80 ..
            EXTERIOR-WALL LIKE EWALLL  AZIMUTH = 90 ..
            WINDOW LIKE WINDL ..
            EXTERIOR-WALL LIKE EWALLL  AZIMUTH = 180 ..
            WINDOW LIKE WINDL ..
            EXTERIOR-WALL LIKE EWALLL  AZIMUTH = 270 ..
            WINDOW LIKE WINDL ..
            ROOF LIKE EROOFC
            WIDTH = 60
            HEIGHT = 100
            ..
            UNDERGROUND-FLOOR LIKE SLBC
            AREA              = 6000
            U-EFFECTIVE      = 0.0586
            ..

KITCHEN    - SPACE
            SPACE-CONDITIONS = SP-KIT
            AREA              = 2000
            VOLUME            = 20000
            ..
EWALLK     EXTERIOR-WALL LIKE EWALLC  WIDTH = 60 ..
            EXTERIOR-WALL LIKE EWALLK  AZIMUTH = 90 ..
            EXTERIOR-WALL LIKE EWALLK  AZIMUTH = 180 ..
            EXTERIOR-WALL LIKE EWALLK  AZIMUTH = 270 ..
            ROOF LIKE EROOFC
            WIDTH = 20
            HEIGHT = 100
            ..
            UNDERGROUND-FLOOR LIKE SLBC
            AREA              = 2000
            U-EFFECTIVE      = 0.00586
            ..

BUILDING-RESOURCE  HOT-WATER          = 34000
                   HW-SCHEDULE       = SERVICE-HW ..

$ LOADS REPORT DATA $

$ Space peak loads summary, Building peak load components
LOADS-REPORT $ (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

$ SYSTEMS DATA $

INPUT SYSTEMS ..

$ SYSTEM SCHEDULES $

```

```

FANC = DAY-SCHEDULE
      (1,7) (0)
      (8,18) (1)
      (19,24) (0) ..
FAN2 = DAY-SCHEDULE
      (1,24) (0) ..
FANCLASS = WEEK-SCHEDULE (WD) FANC (WEH) FAN2 ..
FANOFF = WEEK-SCHEDULE (ALL) FAN2 ..
FAN-CLASS = SCHEDULE THRU JUN 1 FANCLASS
            THRU SEP 1 FANOFF
            THRU DEC 20 FANCLASS
            THRU DEC 31 FANOFF ..

CLGC = DAY-SCHEDULE
      (1,6) (85)
      (7,15) (78)
      (16,24) (85) ..
CLG2 = DAY-SCHEDULE
      (1,24) (90) ..
CLGCLASS = WEEK-SCHEDULE (WD) CLGC (WEH) CLG2 ..
CLGOFF = WEEK-SCHEDULE (ALL) CLG2 ..
CLG-CLASS = SCHEDULE THRU JUN 1 CLGCLASS
            THRU SEP 1 CLGOFF
            THRU DEC 20 CLGCLASS
            THRU DEC 31 CLGOFF ..

HTGC = DAY-SCHEDULE
      (1,6) (65)
      (7,15) (75)
      (16,24) (65) ..
HTG2 = DAY-SCHEDULE
      (1,24) (55) ..
HTGCLASS = WEEK-SCHEDULE (WD) HTGC (WEH) HTG2 ..
HTGOFF = WEEK-SCHEDULE (ALL) HTG2 ..
HTG-CLASS = SCHEDULE THRU JUN 1 HTGCLASS
            THRU SEP 1 HTGOFF
            THRU DEC 20 HTGCLASS
            THRU DEC 31 HTGOFF ..

ZNAIR = ZONE-AIR OA-CFM/PER 15.0 ..

CLASSCON = ZONE-CONTROL
           DESIGN-HEAT-T 75
           DESIGN-COOL-T 78
           HEAT-TEMP-SCH HTG-CLASS
           COOL-TEMP-SCH CLG-CLASS
           THROTTLING-RANGE 2
           THERMOSTAT-TYPE PROPORTIONAL
           ..

LIBRARY ZONE
           ZONE-TYPE CONDITIONED
           ZONE-AIR ZNAIR
           ZONE-CONTROL CLASSCON
           ..

KITCHEN ZONE LIKE LIBRARY ..
CLASS   ZONE LIKE LIBRARY
        ZONE-CONTROL CLASSCON
        MULTIPLIER 40 ..

```

```
SYS1  SYSTEM
      SYSTEM-TYPE  PMZS
      COOL-SET-T   55
      MAX-SUPPLY-T 105
      MIN-SUPPLY-T 55
      REHEAT-DELTA-T 50
      OA-CONTROL   TEMP
      MIN-CFM-RATIO 0.5
      ECONO-LIMIT-T 68
      FAN-SCHEDULE FAN-CLASS
      RETURN-STATIC 1.0
      RETURN-EFF    0.66
      HEAT-SOURCE   GAS-FURNACE
      RETURN-AIR-PATH DUCT
      ZONE-NAMES    (LIBRARY)
      ..

SYS2 SYSTEM LIKE SYS1 ZONE-NAMES (KITCHEN) ..
SYS3 SYSTEM LIKE SYS1 ZONE-NAMES (CLASS) ..

PLT-1  PLANT-ASSIGNMENT  SYSTEM-NAMES (SYS1,SYS2,SYS3) ..

##defl sys_rep[] 3.
      $ SYSTEM REPORT DATA $

##include /user2/bed/lirsce/DOE2/Proto/system_rep.inc
      $ PLANT DATA $

INPUT PLANT ..
PLT-1  PLANT-ASSIGNMENT ..

DHW    P-E TYPE DHW-HEATER  SIZE -999 ..
      $ PLANT REPORT DATA $

##include /user2/bed/lirsce/DOE2/Proto/plant_rep.inc

STOP ..
```



/user2/bed/lirsce/DOE2/Proto/secschool.inp

Mon Jan 28 19:22:51 1991

1

\$ DOE-2.1D BDL Input for Secondary\_School  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*Secondary School\*  
..

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-2 8  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES  
..

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA \$

OCC-CLASS1 = DAY-SCHEDULE  
(1,6) (0)  
(7) (.1)  
(8,11) (.9)  
(12,15) (.8)  
(16) (.45)  
(17,21) (.33)  
(22,24) (.1) ..  
OCC-CLASS2 = DAY-SCHEDULE  
(1,24) (0) ..  
OC-CLASS = WEEK-SCHEDULE (WD) OCC-CLASS1 (WEH) OCC-CLASS2 ..  
UNOC-CLASS = WEEK-SCHEDULE (ALL) OCC-CLASS2 ..  
OCC-CLASS = SCHEDULE THRU JUN 1 OC-CLASS  
THRU SEP 1 UNOC-CLASS  
THRU DEC 20 OC-CLASS  
THRU DEC 31 UNOC-CLASS ..

LTS-CLASS1 = DAY-SCHEDULE  
(1,6) (.1)  
(7) (.2)  
(8,12) (.9)  
(13,16) (.8)  
(17,23) (.6)  
(24) (.1) ..

LTS-CLASS2 = DAY-SCHEDULE  
(1,24) (.1) ..  
LT-CLASS = WEEK-SCHEDULE (WD) LTS-CLASS1 (WEH) LTS-CLASS2 ..  
UNLT-CLASS = WEEK-SCHEDULE (ALL) LTS-CLASS2 ..  
LTS-CLASS = SCHEDULE THRU JUN 1 LT-CLASS  
THRU SEP 1 UNLT-CLASS  
THRU DEC 20 LT-CLASS  
THRU DEC 31 UNLT-CLASS ..

OCC-GYM1 = DAY-SCHEDULE  
(1,7) (0)  
(8,15) (1)

(16,20) (.4)  
(21,24) (0) ..  
OCC-GYM2 = DAY-SCHEDULE  
(1,24) (0) ..  
OC-GYM = WEEK-SCHEDULE (WD) OCC-GYM1 (WEH) OCC-GYM2 ..  
UNOC-GYM = WEEK-SCHEDULE (ALL) OCC-GYM2 ..  
OCC-GYM = SCHEDULE THRU JUN 1 OC-GYM  
THRU SEP 1 UNOC-GYM  
THRU DEC 20 OC-GYM  
THRU DEC 31 UNOC-GYM ..

LTS-GYM1 = DAY-SCHEDULE  
(1,7) (0)  
(8,20) (0.9)  
(21,24) (0) ..  
LTS-GYM2 = DAY-SCHEDULE  
(1,24) (0) ..  
LT-GYM = WEEK-SCHEDULE (WD) LTS-GYM1 (WEH) LTS-GYM2 ..  
UNLT-GYM = WEEK-SCHEDULE (ALL) LTS-GYM2 ..  
LTS-GYM = SCHEDULE THRU JUN 1 LT-GYM  
THRU SEP 1 UNLT-GYM  
THRU DEC 20 LT-GYM  
THRU DEC 31 UNLT-GYM ..

OCC-AUD1 = DAY-SCHEDULE  
(1,9) (0)  
(10,11) (0.75)  
(12) (0.2)  
(13,14) (0.75)  
(15,24) (0) ..  
OCC-AUD2 = DAY-SCHEDULE  
(1,24) (0) ..  
OC-AUD = WEEK-SCHEDULE (WD) OCC-AUD1 (WEH) OCC-AUD2 ..  
UNOC-AUD = WEEK-SCHEDULE (ALL) OCC-AUD2 ..  
OCC-AUD = SCHEDULE THRU JUN 1 OC-AUD  
THRU SEP 1 UNOC-AUD  
THRU DEC 20 OC-AUD  
THRU DEC 31 UNOC-AUD ..

LTS-AUD1 = DAY-SCHEDULE  
(1,9) (0)  
(10,14) (0.9)  
(15,24) (0) ..  
LTS-AUD2 = DAY-SCHEDULE  
(1,24) (0) ..  
LT-AUD = WEEK-SCHEDULE (WD) LTS-AUD1 (WEH) LTS-AUD2 ..  
UNLT-AUD = WEEK-SCHEDULE (ALL) LTS-AUD2 ..  
LTS-AUD = SCHEDULE THRU JUN 1 LT-AUD  
THRU SEP 1 UNLT-AUD  
THRU DEC 20 LT-AUD  
THRU DEC 31 UNLT-AUD ..

OCC-KIT1 = DAY-SCHEDULE  
(1,8) (0)  
(9,10) (.7)  
(11,12) (1)  
(13,18) (.4)  
(19,24) (0) ..  
OCC-KIT2 = DAY-SCHEDULE  
(1,24) (0) ..  
OC-KIT = WEEK-SCHEDULE (WD) OCC-KIT1 (WEH) OCC-KIT2 ..  
UNOC-KIT = WEEK-SCHEDULE (ALL) OCC-KIT2 ..  
OCC-KIT = SCHEDULE THRU JUN 1 OC-KIT

```

                THRU SEP 1 UNOC-KIT
                THRU DEC 20 OC-KIT
                THRU DEC 31 UNOC-KIT ..

LTS-KIT1 = DAY-SCHEDULE
            (1,9) (.1)
            (10) (.7)
            (11,18) (1)
            (19,24) (.1) ..

LTS-KIT2 = DAY-SCHEDULE
            (1,24) (0) ..

LT-KIT = WEEK-SCHEDULE (WD) LTS-KIT1 (WEH) LTS-KIT2 ..
UNLT-KIT = WEEK-SCHEDULE (ALL) LTS-KIT2 ..
LTS-KIT = SCHEDULE THRU JUN 1 LT-KIT
                THRU SEP 1 UNLT-KIT
                THRU DEC 20 LT-KIT
                THRU DEC 31 UNLT-KIT ..

EQP-KITCHEN1 = DAY-SCHEDULE
              (1,9) (0)
              (10) (.1)
              (11) (.4)
              (12) (.3)
              (13) (.2)
              (14) (.1)
              (15) (.1)
              (16,24) (0) ..

EQP-KITCHEN2 = DAY-SCHEDULE
              (1,24) (0) ..

EQ-KITCHEN = WEEK-SCHEDULE (WD) EQP-KITCHEN1 (WEH) EQP-KITCHEN2 ..

UNEQ-KITCHEN = WEEK-SCHEDULE (ALL) EQP-KITCHEN2 ..
EQP-KIT = SCHEDULE THRU JUN 1 EQ-KITCHEN
                THRU SEP 1 UNEQ-KITCHEN
                THRU DEC 20 EQ-KITCHEN
                THRU DEC 31 UNEQ-KITCHEN ..

OCC-DIN1 = DAY-SCHEDULE
           (1,10) (0)
           (11,13) (1)
           (14,15) (.2)
           (16,24) (0) ..

OCC-DIN2 = DAY-SCHEDULE
           (1,24) (0) ..

OC-DIN = WEEK-SCHEDULE (WD) OCC-DIN1 (WEH) OCC-DIN2 ..
UNOC-DIN = WEEK-SCHEDULE (ALL) OCC-DIN2 ..
OCC-DIN = SCHEDULE THRU JUN 1 OC-DIN
                THRU SEP 1 UNOC-DIN
                THRU DEC 20 OC-DIN
                THRU DEC 31 UNOC-DIN ..

LTS-DIN1 = DAY-SCHEDULE
           (1,9) (0)
           (10) (.4)
           (11,13) (1)
           (14,15) (.4)
           (16,24) (0) ..

LTS-DIN2 = DAY-SCHEDULE
           (1,24) (0) ..

LT-DIN = WEEK-SCHEDULE (WD) LTS-DIN1 (WEH) LTS-DIN2 ..
UNLT-DIN = WEEK-SCHEDULE (ALL) LTS-DIN2 ..
LTS-DIN = SCHEDULE THRU JUN 1 LT-DIN
                THRU SEP 1 UNLT-DIN
                THRU DEC 20 LT-DIN

```

```

                THRU DEC 31 UNLT-DIN ..

INFIL1 = DAY-SCHEDULE
        (1,7) (1)
        (8,23) (0)
        (24) (1) ..

INFIL2 = DAY-SCHEDULE
        (1,24) (1) ..

INF = WEEK-SCHEDULE (WD) INFIL1 (WEH) INFIL2 ..
UNINF = WEEK-SCHEDULE (ALL) INFIL2 ..
INFIL = SCHEDULE THRU JUN 1 INF
                THRU SEP 1 UNINF
                THRU DEC 20 INF
                THRU DEC 31 UNINF ..

SERVICE-HW1 = DAY-SCHEDULE
              (1,7) (0)
              (8) (.05)
              (9) (.3)
              (10) (.55)
              (11) (.6)
              (12) (.7)
              (13) (.75)
              (14) (.8)
              (15,16) (.6)
              (17,18) (.5)
              (19) (.15)
              (20,22) (.2)
              (23,24) (0) ..

SERVICE-HW2 = DAY-SCHEDULE
              (1,24) (0) ..

SRC-HW = WEEK-SCHEDULE (WD) SERVICE-HW1 (WEH) SERVICE-HW2 ..
UNSRC-HW = WEEK-SCHEDULE (ALL) SERVICE-HW2 ..
SERVICE-HW = SCHEDULE THRU JUN 1 SRC-HW
                THRU SEP 1 UNSRC-HW
                THRU DEC 20 SRC-HW
                THRU DEC 31 UNSRC-HW ..

PULL-SHADE = SCHEDULE THRU DEC 31 (ALL) (1,24) (40) ..
SHADE-MULT = SCHEDULE THRU DEC 31 (ALL) (1,24) (.5) ..

$ LOADS DATA $

$ Exterior Surfaces
IN-W MATERIAL RES = 1 ..
WAL LAYERS MATERIAL = (CB31,IN-W,GP02) ..
IN-R MATERIAL RES = 4.9 ..
RF1 LAYERS MATERIAL = (BR01,PW04,IN-R,AL33,GP02)
                                INSIDE-FILM-RES=.61 ..

TYP-WALL = CONSTRUCTION LAYERS = WAL ..
TYP-ROOF = CONSTRUCTION LAYERS = RF1 ..
GLASS1 = GLASS-TYPE PANES = 1
                                SHADING-COEF = 0.85
                                GLASS-CONDUCTANCE = 1.03 ..

$ Slab - 2' soil, 6" heavy-weight conc.
SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26
                                CONDUCTIVITY = 1.0 DENSITY = 115 ..
SLABL LAYERS MAT = (SOIL,CC15) ..
SLAB-1 CONSTRUCTION LAYERS = SLABL ..

```

```

SET-DEFAULT FOR WINDOW      GLASS-TYPE      = GLASS1
                             WIN-SHADE-TYPE     = MOVABLE-INTERIOR
                             MAX-SOLAR-SCH     = PULL-SHADE
                             SHADING-SCHEDULE  = SHADE-MULT ..

LIGHTING-TYPE               = REC-FLUOR-NV
LIGHTING-W/SQFT             = 0.80
INF-SCHEDULE                 = INFIL
INF-METHOD                  = AIR-CHANGE
INF-CFM/SQFT                 = .083
FLOOR-WEIGHT                 = 70
..

SP-CLASS                    SPACE-CONDITIONS
                             TEMPERATURE       = (75)
                             PEOPLE-SCHEDULE   = OCC-CLASS
                             NUMBER-OF-PEOPLE  = 20
                             PEOPLE-HEAT-GAIN  = 450
                             EQUIP-SCHEDULE    = LTS-CLASS
                             EQUIPMENT-W/SQFT  = .5
                             LIGHTING-SCHEDULE = LTS-CLASS
                             LIGHTING-TYPE     = REC-FLUOR-NV
                             LIGHTING-W/SQFT   = 2.2
                             INF-SCHEDULE      = INFIL
                             INF-METHOD      = AIR-CHANGE
                             INF-CFM/SQFT     = .083
                             FLOOR-WEIGHT     = 70
                             ..

SP-LIB                       SPACE-CONDITIONS
                             TEMPERATURE       = (75)
                             PEOPLE-SCHEDULE   = OCC-CLASS
                             NUMBER-OF-PEOPLE  = 315
                             PEOPLE-HEAT-GAIN  = 550
                             EQUIP-SCHEDULE    = LTS-CLASS
                             EQUIPMENT-W/SQFT  = .5
                             LIGHTING-SCHEDULE = LTS-CLASS
                             LIGHTING-TYPE     = REC-FLUOR-NV
                             LIGHTING-W/SQFT   = 1.5
                             INF-SCHEDULE      = INFIL
                             INF-METHOD      = AIR-CHANGE
                             INF-CFM/SQFT     = .083
                             FLOOR-WEIGHT     = 70
                             ..

SP-LIB                       SP-DIN
                             SPACE-CONDITIONS
                             TEMPERATURE       = (75)
                             PEOPLE-SCHEDULE   = OCC-DIN
                             NUMBER-OF-PEOPLE  = 484
                             PEOPLE-HEAT-GAIN  = 580
                             EQUIP-SCHEDULE    = LTS-DIN
                             EQUIPMENT-W/SQFT  = 0.5
                             LIGHTING-SCHEDULE = LTS-DIN
                             LIGHTING-TYPE     = REC-FLUOR-NV
                             LIGHTING-W/SQFT   = 1.7
                             INF-SCHEDULE      = INFIL
                             INF-METHOD      = AIR-CHANGE
                             INF-CFM/SQFT     = .333
                             FLOOR-WEIGHT     = 70
                             ..

SP-GYM                       SPACE-CONDITIONS
                             TEMPERATURE       = (75)
                             PEOPLE-SCHEDULE   = OCC-GYM
                             NUMBER-OF-PEOPLE  = 175
                             PEOPLE-HEAT-GAIN  = 800
                             EQUIP-SCHEDULE    = LTS-GYM
                             EQUIPMENT-W/SQFT  = .5
                             LIGHTING-SCHEDULE = LTS-GYM
                             LIGHTING-TYPE     = SUS-FLUOR
                             LIGHTING-W/SQFT   = 0.65
                             INF-SCHEDULE      = INFIL
                             INF-METHOD      = AIR-CHANGE
                             INF-CFM/SQFT     = .333
                             FLOOR-WEIGHT     = 70
                             ..

SP-GYM                       CLASSB =
                             SPACE
                             SPACE-CONDITIONS = SP-CLASS
                             AREA              = 1800
                             VOLUME           = 18000
                             MULTIPLIER       = 40
                             ..

SP-GYM                       EWALLC =
                             EXTERIOR-WALL
                             CONSTRUCTION     = TYP-WALL
                             WIDTH            = 15      $ 60 ft 4 ways
                             HEIGHT           = 10
                             AZIMUTH          = 0
                             ..

SP-AUD                       WINDC =
                             WINDOW
                             WIDTH            = 15
                             HEIGHT           = 2.9
                             ..
                             EXTERIOR-WALL LIKE EWALLC AZIMUTH = 90 ..

```

WINDOW LIKE WINDC ..  
 EXTERIOR-WALL LIKE EWALLC AZIMUTH = 180 ..  
 WINDOW LIKE WINDC ..  
 EXTERIOR-WALL LIKE EWALLC AZIMUTH = 270 ..  
 WINDOW LIKE WINDC ..  
 UNDERGROUND-FLOOR  
 CONSTRUCTION = SLAB-1  
 AREA = 1800  
 U-EFFECTIVE = 0.0346  
 ..

SLBC

CLASST = SPACE LIKE CLASSB  
 MULTIPLIER = 40  
 ..  
 EXTERIOR-WALL LIKE EWALLC ..  
 WINDOW LIKE WINDC ..  
 EXTERIOR-WALL LIKE EWALLC AZIMUTH = 90 ..  
 WINDOW LIKE WINDC ..  
 EXTERIOR-WALL LIKE EWALLC AZIMUTH = 180 ..  
 WINDOW LIKE WINDC ..  
 EXTERIOR-WALL LIKE EWALLC AZIMUTH = 270 ..  
 WINDOW LIKE WINDC ..

EROOFC ROOF CONSTRUCTION = TYP-ROOF  
 GND-REFLECTANCE = 0  
 TILT = 0  
 WIDTH = 60  
 HEIGHT = 30  
 ..

LIBRARY= SPACE  
 SPACE-CONDITIONS = SP-L1B  
 AREA = 31495  
 VOLUME = 314950  
 ..

EWALLL EXTERIOR-WALL LIKE EWALLC WIDTH = 177 ..  
 WINDL WINDOW LIKE WINDC WIDTH = 177 ..  
 EXTERIOR-WALL LIKE EWALLL AZIMUTH = 90 ..  
 WINDOW LIKE WINDL ..  
 EXTERIOR-WALL LIKE EWALLL AZIMUTH = 180 ..  
 WINDOW LIKE WINDL ..  
 EXTERIOR-WALL LIKE EWALLL AZIMUTH = 270 ..  
 WINDOW LIKE WINDL ..  
 UNDERGROUND-FLOOR LIKE SLBC  
 AREA = 31495  
 U-EFFECTIVE = 0.00586  
 ..

GYM = SPACE  
 SPACE-CONDITIONS = SP-GYM  
 AREA = 31495  
 VOLUME = 1007850  
 ..

EWALLG EXTERIOR-WALL LIKE EWALLC  
 WIDTH = 177 HEIGHT = 32 ..  
 WINDG WINDOW LIKE WINDC  
 WIDTH = 177 HEIGHT = 4 ..  
 EXTERIOR-WALL LIKE EWALLG AZIMUTH = 90 ..  
 WINDOW LIKE WINDG ..  
 EXTERIOR-WALL LIKE EWALLG AZIMUTH = 180 ..  
 WINDOW LIKE WINDG ..  
 EXTERIOR-WALL LIKE EWALLG AZIMUTH = 270 ..  
 WINDOW LIKE WINDG ..  
 UNDERGROUND-FLOOR LIKE SLBC  
 AREA = 31495

U-EFFECTIVE = 0.00586  
 ..  
 ROOF LIKE EROOFC  
 WIDTH = 177  
 HEIGHT = 177  
 ..

AUDITORIUM = SPACE  
 SPACE-CONDITIONS = SP-AUD  
 AREA = 19380  
 VOLUME = 620210  
 ..

EWALLA EXTERIOR-WALL LIKE EWALLC  
 WIDTH = 139 HEIGHT = 32 ..  
 EXTERIOR-WALL LIKE EWALLA AZIMUTH = 90 ..  
 EXTERIOR-WALL LIKE EWALLA AZIMUTH = 180 ..  
 EXTERIOR-WALL LIKE EWALLA AZIMUTH = 270 ..  
 UNDERGROUND-FLOOR LIKE SLBC  
 AREA = 19380  
 U-EFFECTIVE = 0.00747  
 ..

ROOF LIKE EROOFC  
 WIDTH = 139  
 HEIGHT = 139  
 ..

KITCHEN = SPACE  
 SPACE-CONDITIONS = SP-KIT  
 AREA = 4845  
 VOLUME = 48450  
 ..

EWALLK EXTERIOR-WALL LIKE EWALLC  
 WIDTH = 52 ..  
 EXTERIOR-WALL LIKE EWALLK AZIMUTH = 90 ..  
 EXTERIOR-WALL LIKE EWALLK AZIMUTH = 180 ..  
 EXTERIOR-WALL LIKE EWALLK AZIMUTH = 270 ..  
 ROOF LIKE EROOFC  
 WIDTH = 52  
 HEIGHT = 52  
 ..

DINNING = SPACE  
 SPACE-CONDITIONS = SP-DIN  
 AREA = 9690  
 VOLUME = 96900  
 ..

EWALLD EXTERIOR-WALL LIKE EWALLC  
 WIDTH = 74 ..  
 WINDD WINDOW LIKE WINDC  
 WIDTH = 74 HEIGHT = 4 ..  
 EXTERIOR-WALL LIKE EWALLD AZIMUTH = 90 ..  
 WINDOW LIKE WINDD ..  
 EXTERIOR-WALL LIKE EWALLD AZIMUTH = 180 ..  
 WINDOW LIKE WINDD ..  
 EXTERIOR-WALL LIKE EWALLD AZIMUTH = 270 ..  
 WINDOW LIKE WINDD ..  
 ROOF LIKE EROOFC  
 WIDTH = 74  
 HEIGHT = 74  
 ..

BUILDING-RESOURCE HOT-WATER = 339180

HW-SCHEDULE = SERVICE-HW

\$ LOADS REPORT DATA \$

\$ Space peak loads summary, Building peak load components  
LOADS-REPORT \$ (LS-C,LS-F) ..

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

FANC = DAY-SCHEDULE  
 (1,7) (0)  
 (8,23) (1)  
 (24) (0) ..

FANO = DAY-SCHEDULE  
 (1,7) (0)  
 (8,15) (1)  
 (16,24) (0) ..

FAN2 = DAY-SCHEDULE  
 (1,24) (0) ..

FANCLASS = WEEK-SCHEDULE (WD) FANC (WEH) FAN2 ..  
 FANOTHER = WEEK-SCHEDULE (WD) FANO (WEH) FAN2 ..  
 FANOFF = WEEK-SCHEDULE (ALL) FAN2 ..  
 FAN-CLASS = SCHEDULE THRU JUN 1 FANCLASS  
 THRU SEP 1 FANOFF  
 THRU DEC 20 FANCLASS  
 THRU DEC 31 FANOFF ..

FAN-OTHER = SCHEDULE THRU JUN 1 FANOTHER  
 THRU SEP 1 FANOFF  
 THRU DEC 20 FANOTHER  
 THRU DEC 31 FANOFF ..

CLGC = DAY-SCHEDULE  
 (1,6) (85)  
 (7,21) (78)  
 (22,24) (85) ..

CLGO = DAY-SCHEDULE  
 (1,6) (85)  
 (7,15) (78)  
 (16,24) (85) ..

CLG2 = DAY-SCHEDULE  
 (1,24) (90) ..

CLGCLASS = WEEK-SCHEDULE (WD) CLGC (WEH) CLG2 ..  
 CLGOTHER = WEEK-SCHEDULE (WD) CLGO (WEH) CLG2 ..  
 CLGOFF = WEEK-SCHEDULE (ALL) CLG2 ..  
 CLG-CLASS = SCHEDULE THRU JUN 1 CLGCLASS  
 THRU SEP 1 CLGOFF  
 THRU DEC 20 CLGCLASS  
 THRU DEC 31 CLGOFF ..

CLG-OTHER = SCHEDULE THRU JUN 1 CLGOTHER  
 THRU SEP 1 CLGOFF  
 THRU DEC 20 CLGOTHER  
 THRU DEC 31 CLGOFF ..

HTGC = DAY-SCHEDULE  
 (1,6) (65)

(7,21) (75)  
 (22,24) (65) ..

HTGO = DAY-SCHEDULE  
 (1,6) (65)  
 (7,15) (75)  
 (16,24) (65) ..

HTG2 = DAY-SCHEDULE  
 (1,24) (55) ..

HTGCLASS = WEEK-SCHEDULE (WD) HTGC (WEH) HTG2 ..  
 HTGOTHER = WEEK-SCHEDULE (WD) HTGO (WEH) HTG2 ..  
 HTGOFF = WEEK-SCHEDULE (ALL) HTG2 ..  
 HTG-CLASS = SCHEDULE THRU JUN 1 HTGCLASS  
 THRU SEP 1 HTGOFF  
 THRU DEC 20 HTGCLASS  
 THRU DEC 31 HTGOFF ..

HTG-OTHER = SCHEDULE THRU JUN 1 HTGOTHER  
 THRU SEP 1 HTGOFF  
 THRU DEC 20 HTGOTHER  
 THRU DEC 31 HTGOFF ..

ZNAIR = ZONE-AIR OA-CFM/PER 15.0 ..

CLASSCON = ZONE-CONTROL  
 DESIGN-HEAT-T 75  
 DESIGN-COOL-T 78  
 HEAT-TEMP-SCH HTG-CLASS  
 COOL-TEMP-SCH CLG-CLASS  
 THROTTLING-RANGE 2  
 THERMOSTAT-TYPE PROPORTIONAL  
 ..

OTHERCON = ZONE-CONTROL  
 LIKE CLASSCON  
 HEAT-TEMP-SCH HTG-OTHER  
 COOL-TEMP-SCH CLG-OTHER  
 ..

LIBRARY ZONE  
 ZONE-TYPE CONDITIONED  
 ZONE-AIR ZNAIR  
 ZONE-CONTROL OTHERCON  
 ..

GYM ZONE LIKE LIBRARY ..  
 AUDITORIUM ZONE LIKE LIBRARY ..  
 KITCHEN ZONE LIKE LIBRARY ..  
 DINNING ZONE LIKE LIBRARY ..  
 CLASSB ZONE LIKE LIBRARY  
 ZONE-CONTROL CLASSCON  
 MULTIPLIER 40 ..

CLASST ZONE LIKE CLASSB  
 MULTIPLIER 40 ..

SYS1 SYSTEM  
 SYSTEM-TYPE PM2S  
 COOL-SET-T 55  
 MAX-SUPPLY-T 105  
 MIN-SUPPLY-T 55  
 REHEAT-DELTA-T 50  
 OA-CONTROL TEMP  
 MIN-CFM-RATIO 0.5  
 ECONO-LIMIT-T 68

```
FAN-SCHEDULE      FAN-OTHER
RETURN-STATIC     1.0
RETURN-EFF        0.66
HEAT-SOURCE       GAS-FURNACE
RETURN-AIR-PATH   DUCT
ZONE-NAMES        (LIBRARY)
..

SYS2 SYSTEM LIKE SYS1 ZONE-NAMES (GYM) ..
SYS3 SYSTEM LIKE SYS1 ZONE-NAMES (AUDITORIUM) ..
SYS4 SYSTEM LIKE SYS1 ZONE-NAMES (KITCHEN) ..
SYS5 SYSTEM LIKE SYS1 ZONE-NAMES (DINNING) ..
SYS6 SYSTEM LIKE SYS1
      FAN-SCHEDULE FAN-CLASS
      ZONE-NAMES (CLASSB) ..
SYS7 SYSTEM LIKE SYS6 ZONE-NAMES (CLASST) ..

PLT-1    PLANT-ASSIGNMENT  SYSTEM-NAMES (SYS1,SYS2,SYS3,
      SYS4,SYS5,SYS6,SYS7) ..

##defl sys_rep[] 7
      $ SYSTEM REPORT DATA $

##include /user2/bed/lirsce/DOE2/Proto/system_rep.inc
      $ PLANT DATA $

INPUT PLANT ..
PLT-1    PLANT-ASSIGNMENT ..

DHW      P-E TYPE DHW-HEATER  SIZE -999 ..
HWG      P-E TYPE HW-BOILER  SIZE -999 I-N 2 ..

PLANT-PARAMETERS
      BOILER-FUEL NATURAL-GAS ..

      $ PLANT REPORT DATA $

##include /user2/bed/lirsce/DOE2/Proto/plant_rep.inc

STOP ..
```

55

/user2/bed/lirsce/DOE2/Proto/smhotel.inp

Tue Jan 29 19:56:13 1991

1

\$ DOE-2.1D BDL Input for Small\_Hotel/Motel  
\$ 1990 CEC LS/EUI Study

POST-PROCESSOR PARTIAL ..  
INPUT LOADS ..

TITLE LINE-1 \*1990 CEC LS/EUI Study\*  
LINE-2 \*Small Hotel/Motel\*  
..

RUN-PERIOD JAN 1 1986 THRU DEC 31 1986 ..

BUILDING-LOCATION LAT 34.07 LON 118.25 ALT 50 T-Z 8  
AZIMUTH 0  
HOLIDAY YES  
DAYLIGHT-SAVINGS YES  
..

ABORT ERRORS ..  
LIST WARNINGS ..  
PARAMETER CREDIT-DAYLTG NO ..

\$ LOADS SCHEDULE DATA \$

OCC-LOB-ALL = DAY-SCHEDULE  
(1,8) (.1, .1, .1, .1, .1, .2, .4, .6)  
(9,16) (.6, .4, .2, .2, .2, .2, .2, .3)  
(17,24) (.6, .8, .8, .7, .5, .3, .3, .1)

OCC-LOB = SCHEDULE THRU DEC 31  
(ALL) OCC-LOB-ALL

LIGHT-LOB = SCHEDULE THRU DEC 31  
(ALL) (1,24) (1) ..

OCC-LND-ALL = DAY-SCHEDULE  
(1,8) (.0, .0, .0, .0, .0, .0, .0, .2)  
(9,16) (.9, .9, .9, .7, .9, .9, .9, .9)  
(17,24) (.2, .0, .0, .0, .0, .0, .0, .0)

OCC-LND = SCHEDULE THRU DEC 31  
(ALL) OCC-LND-ALL

LIGHT-LND = SCHEDULE THRU DEC 31  
(ALL) (1,7) (.1) (8,17) (.9) (18,24) (.1)

EQUIP-LND = SCHEDULE THRU DEC 31  
(ALL) (1,7) (0) (8,17) (.8) (18,24) (0)

OCC-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.8, .8, .8, .8, .8, .8, .6, .4)  
(9,16) (.4, .2, .2, .2, .2, .2, .2, .3)  
(17,24) (.5, .5, .5, .6, .6, .7, .8, .8)

OCC-ROOM = SCHEDULE THRU DEC 31  
(ALL) OCC-ROOM-ALL

LIGHT-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.2, .15, .1, .1, .1, .2, .4, .5)  
(9,16) (.4, .4, .25, .25, .25, .25, .25, .25)  
(17,24) (.25, .25, .6, .7, .8, .7, .6, .3)

LIGHT-ROOM = SCHEDULE THRU DEC 31  
(ALL) LIGHT-ROOM-ALL

DHW-ROOM-ALL = DAY-SCHEDULE  
(1,8) (.21, .20, .20, .20, .22, .20, .51, .61)  
(9,16) (.59, .48, .42, .48, .45, .40, .35, .35)  
(17,24) (.33, .45, .60, .65, .55, .50, .48, .20)

DHW-ROOM = SCHEDULE THRU DEC 31  
(ALL) DHW-ROOM-ALL

\$ LOADS DATA \$

\$ Exterior Surfaces

\$ Wall - plywood,insulation,gyp-board  
IN-W MATERIAL RES = 1.0 ..  
WALLR LAYERS MAT = (PW04,IN-W,GP02) ..  
WALL-1 CONSTRUCTION LAYERS = WALLR ..

\$ Roof - built-up roofing,plywood,insulation,air-space,accoustic tile  
IN-R MATERIAL RES = 8.0 ..  
ROOFR LAYERS MAT = (BR01,PW05,IN-R,AL33,AC02) ..  
ROOF-1 CONSTRUCTION LAYERS = ROOFR ..

\$ Slab - 2' soil, 6" heavy-weight conc., pad, carpet  
SOIL MATERIAL THICKNESS = 2.0 SPECIFIC-HEAT = 0.26  
CONDUCTIVITY = 1.0 DENSITY = 115 ..  
SLABL LAYERS MAT = (SOIL,CC15,CP01) ..  
SLAB-1 CONSTRUCTION LAYERS = SLABL ..

\$ Single Glass

SINGLE GLASS-TYPE PANES = 1  
SHADING-COEF = 0.4  
GLASS-CONDUCTANCE = 1.0278  
..

\$ Zone Calculations

\$ 90% Room, 5% Lobby, 5% Laundry  
\$ Room calcs (800 = 200 sqft per room \* 4 orientations)  
\$ Wall calcs (lobby has three exterior walls, laundry has one)

\$ DEFAULT CONSTRUCTIONS \$

SET-DEFAULT FOR EXTERIOR-WALL  
CONSTRUCTION = WALL-1  
HEIGHT = 8.  
..

SET-DEFAULT FOR WINDOW  
GLASS-TYPE = SINGLE  
..

\$ GENERAL SPACE CHARACTERISTICS \$

LOBB SPACE-CONDITIONS

TEMPERATURE = (73)  
P-SCH = OCC-LOB  
P-H-S = 255  
P-H-L = 255  
L-SCH = LIGHT-LOB  
L-T = REC-FLUOR-RV L-W = 1.5  
FLOOR-WEIGHT = 70

Z-TYPE = CONDITIONED

LAUND SPACE-CONDITIONS

TEMPERATURE = (73)  
 P-SCH = OCC-LND  
 P-H-S = 345  
 P-H-L = 435  
 E-SCH = EQUIP-LND E-W = 3.0  
 L-SCH = LIGHT-LND  
 L-T = SUS-FLUOR L-W = 1.7  
 SOURCE-TYPE HOT-WATER  
 SOURCE-SCHEDULE EQUIP-LND  
 SOURCE-BTU/HR = 21452  
 S-L 0.1 S-S 0.1  
 FLOOR-WEIGHT = 70  
 Z-TYPE = CONDITIONED

VOLUME = 10720  
 N-O-P = 3

LDEW-1 EXTERIOR-WALL  
 WIDTH = 9  
 AZIMUTH = 0  
 ..  
 EXTERIOR-WALL LIKE LDEW-1 AZIMUTH = 90 ..  
 EXTERIOR-WALL LIKE LDEW-1 AZIMUTH = 180 ..  
 EXTERIOR-WALL LIKE LDEW-1 AZIMUTH = 270 ..

UNDERGROUND-FLOOR  
 LIKE SLB-1  
 AREA = 1340  
 U-EFFECTIVE = 0.0284

ROOM SPACE-CONDITIONS

TEMPERATURE = (73)  
 P-SCH = OCC-ROOM  
 N-O-P = 2  
 P-H-S = 230  
 P-H-L = 190  
 E-SCH = LIGHT-ROOM E-W = 0.6  
 L-SCH = LIGHT-ROOM  
 L-T = INCAND L-W = 1.0  
 FLOOR-WEIGHT = 70  
 Z-TYPE = CONDITIONED

\$ ROOMS \$

ROOM-1 SPACE  
 MULTIPLIER = 15  
 SPACE-CONDITIONS = ROOM  
 AREA = 200  
 VOLUME = 1600

EW1 EXTERIOR-WALL  
 WIDTH = 20  
 AZIMUTH = 0

W1 WINDOW  
 HEIGHT = 2  
 WIDTH = 20

SL1 UNDERGROUND-FLOOR  
 LIKE SLB-1  
 AREA = 200  
 U-EFFECTIVE = 0.104

ROOM-2 SPACE LIKE ROOM-1  
 MULTIPLIER = 15  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..  
 WINDOW LIKE W1 ..  
 UNDERGROUND-FLOOR LIKE SL1 ..

ROOM-3 SPACE LIKE ROOM-1  
 MULTIPLIER = 15  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..  
 WINDOW LIKE W1 ..  
 UNDERGROUND-FLOOR LIKE SL1 ..

ROOM-4 SPACE LIKE ROOM-1  
 MULTIPLIER = 15  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..  
 WINDOW LIKE W1 ..  
 UNDERGROUND-FLOOR LIKE SL1 ..

ROOM-1T SPACE LIKE ROOM-1  
 MULTIPLIER = 15  
 ..  
 EXTERIOR-WALL LIKE EW1 AZIMUTH = 0 ..

\$ LOBBY \$

LOBBY

SPACE  
 SPACE-CONDITIONS = LOBB  
 AREA = 1340  
 VOLUME = 10720  
 N-O-P = 7

LBEW-1

EXTERIOR-WALL  
 WIDTH = 27  
 AZIMUTH = 0

LBW-1

WINDOW  
 HEIGHT = 0.8  
 WIDTH = 27

EXTERIOR-WALL LIKE LBEW-1 AZIMUTH = 90 ..  
 WINDOW LIKE LBW-1 ..  
 EXTERIOR-WALL LIKE LBEW-1 AZIMUTH = 180 ..  
 WINDOW LIKE LBW-1 ..  
 EXTERIOR-WALL LIKE LBEW-1 AZIMUTH = 270 ..  
 WINDOW LIKE LBW-1 ..

SLB-1

UNDERGROUND-FLOOR  
 CONSTRUCTION = SLAB-1  
 AREA = 1340  
 U-EFFECTIVE = 0.0852

\$ LAUNDRY \$

LAUNDRY

SPACE  
 SPACE-CONDITIONS = LAUND  
 AREA = 1340



```

WINDOW LIKE W1 ..
R1 ROOF CONSTRUCTION = ROOF-1
   TILT = 0.0
   GND-REFLECTANCE = 0.0
   HEIGHT = 10
   WIDTH = 20
   ..
ROOM-2T SPACE LIKE ROOM-1T
MULTIPLIER = 15
..
EXTERIOR-WALL LIKE EW1 AZIMUTH = 90 ..
WINDOW LIKE W1 ..
ROOF LIKE R1 ..
ROOM-3T SPACE LIKE ROOM-1T
MULTIPLIER = 15
..
EXTERIOR-WALL LIKE EW1 AZIMUTH = 180 ..
WINDOW LIKE W1 ..
ROOF LIKE R1 ..
ROOM-4T SPACE LIKE ROOM-1T
MULTIPLIER = 15
..
EXTERIOR-WALL LIKE EW1 AZIMUTH = 270 ..
WINDOW LIKE W1 ..
ROOF LIKE R1 ..

```

\$ BUILDING RESOURCES \$

```

BUILDING-RESOURCE
$ schedule and intensity/sq ft. above ground floor from LBL hosp BDL
HW-SCHEDULE = DHW-ROOM
HOT-WATER = 85824
GAS-SCHEDULE = EQUIP-LND
GAS-THERMS = 0.5
..

```

\$ LOADS REPORT DATA \$

```

$ Space peak loads summary, Building peak load components
LOADS-REPORT S (LS-C,LS-F) ..

```

END ..

COMPUTE LOADS ..

\$ SYSTEMS DATA \$

INPUT SYSTEMS ..

\$ SYSTEM SCHEDULES \$

```

$ fan schedules $
FAN-LND = SCH $ fan schedule for laundry
THRU DEC 31 (ALL) (1,4) (0) (5,23) (1) (24) (0)
..
ALWAYSON = SCH
THRU DEC 31 (ALL) (1,24) (1) ..

```

```

$ Heat-Temp and Cool-Temp schedules$
ROOMHT = SCH THRU DEC 31
(ALL) (1,8) (70) (9,20) (65) (21,24) (70) ..
ROOMCL = SCH THRU DEC 31
(ALL) (1,24) (75) ..
LNDHT = SCH THRU DEC 31
(ALL) (1,4) (65) (5,23) (70) (24) (65) ..
LNDCL = SCH THRU DEC 31
(ALL) (1,4) (85) (5,23) (80) (24) (85) ..
LOBHT = SCH THRU DEC 31
(ALL) (1,24) (70) ..
LOBCL = SCH THRU DEC 31
(ALL) (1,24) (75) ..
LND-AIR = ZONE-AIR OA-CHANGES = 3.0 ..
LOB-AIR = ZONE-AIR OA-CFM/PER = 15 ..
CNTRL-LOB ZONE-CONTROL
DESIGN-HEAT-T 70
DESIGN-COOL-T 75
HEAT-TEMP-SCH LOBHT
COOL-TEMP-SCH LOBCL
THERMOSTAT-TYPE PROPORTIONAL
..
CNTRL-LND ZONE-CONTROL
DESIGN-HEAT-T 70
DESIGN-COOL-T 80
HEAT-TEMP-SCH LNDHT
COOL-TEMP-SCH LNDCL
THERMOSTAT-TYPE PROPORTIONAL
..
CNTRL-ROOM ZONE-CONTROL
DESIGN-HEAT-T 70
DESIGN-COOL-T 75
HEAT-TEMP-SCH ROOMHT
COOL-TEMP-SCH ROOMCL
THERMOSTAT-TYPE PROPORTIONAL
..
LAUNDRY ZONE
ZONE-TYPE CONDITIONED
ZONE-AIR LND-AIR
ZONE-CONTROL CNTRL-LND
..
LOBBY ZONE LIKE LAUNDRY
ZONE-AIR LOB-AIR
ZONE-CONTROL CNTRL-LND
..
ROOM-1 ZONE LIKE LOBBY
MULTIPLIER = 15
ZONE-CONTROL CNTRL-ROOM ..
ROOM-2 ZONE LIKE ROOM-1 ..
ROOM-3 ZONE LIKE ROOM-1 ..
ROOM-4 ZONE LIKE ROOM-1 ..
ROOM-1T ZONE LIKE ROOM-1
MULTIPLIER = 15.083437920 ..
ROOM-2T ZONE LIKE ROOM-1T ..
ROOM-3T ZONE LIKE ROOM-1T ..

```

/user2/bed/lirsce/DOE2/Proto/smhotel.inp

Tue Jan 29 19:56:13 1991

4

ROOM-4T ZONE LIKE ROOM-1T ..

NORM-CONT SYSTEM-CONTROL

MAX-S-T 110 MIN-S-T 52

H-SCH ALWAYSON

C-SCH ALWAYSON

..

SYS1 SYSTEM \$ lobby

SYSTEM-TYPE PSZ

OA-CONTROL FIXED

S-C NORM-CONT

F-SCH ALWAYSON

ZONE-NAMES (LOBBY) ..

SYS2 SYSTEM \$ laundry

LIKE SYS1

F-SCH FAN-LND

ZONE-NAMES (LAUNDRY) ..

SYS3 SYSTEM \$ rooms

SYSTEM-TYPE PTAC

S-C NORM-CONT

HEAT-SOURCE GAS-FURNACE

ZONE-NAMES (ROOM-1, ROOM-2, ROOM-3, ROOM-4  
ROOM-1T, ROOM-2T, ROOM-3T, ROOM-4T) ..

PLT-1 PLANT-ASSIGNMENT

SYSTEM-NAMES (SYS1, SYS2, SYS3) ..

##defl sys\_rep[] 3

\$ SYSTEM REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/system\_rep.inc

\$ PLANT DATA \$

INPUT PLANT ..

PLT-1 PLANT-ASSIGNMENT ..

DHW P-E TYPE DHW-HEATER SIZE -999 ..

PLANT-PARAMETERS

BOILER-FUEL NATURAL-GAS ..


\$ PLANT REPORT DATA \$

##include /user2/bed/lirsce/DOE2/Proto/plant\_rep.inc


STOP ..

## Appendix C. Summaries of LRD


## Average Weekday Profiles for Schools




## Average Weekday Profiles for Schools




## Average Weekday Profiles for Schools



## Average Weekday Profiles for Schools




## Average Weekday Profiles for Schools







## Average Weekday Profiles for Schools




## Average Weekday Profiles for Schools




## Average Weekday Profiles for Colleges




## Average Weekday Profiles for Colleges




# Average Weekday Profiles for Colleges




## Average Weekday Profiles for Hospitals



## Average Weekday Profiles for Hospitals




## Average Weekday Profiles for Hospitals







## Average Weekday Profiles for Hospitals




## Average Weekday Profiles for Hospitals




# Average Weekday Profiles for Hospitals (and Health)



# Average Weekday Profiles for Hotels & Motels



## Average Weekday Profiles for Hotels & Motels



**Appendix D. Results from Load-Temperature Regressions**

**LRD Regression Coefficients for Coastal Health - Standard Day - Summer**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	2.233	0.009	0.043	0.79	0.000	102
2	2.214	0.009	0.041	0.79	0.000	102
3	2.215	0.008	0.042	0.77	0.000	98
4	2.199	0.011	0.040	0.75	0.000	96
5	2.287	0.009	0.040	0.73	0.000	93
6	2.429	0.009	0.040	0.66	0.000	93
7	2.590	0.012	0.046	0.67	0.000	96
8	2.758	0.015	0.043	0.87	0.000	114
9	2.842	0.023	0.035	0.85	0.000	124
10	2.913	0.025	0.031	0.83	0.000	125
11	2.940	0.025	0.033	0.84	0.000	126
12	2.931	0.023	0.037	0.81	0.000	126
13	2.958	0.022	0.037	0.76	0.000	126
14	3.022	0.017	0.034	0.75	0.000	126
15	3.004	0.016	0.031	0.73	0.000	126
16	2.854	0.021	0.031	0.76	0.000	126
17	2.712	0.020	0.034	0.78	0.000	126
18	2.575	0.026	0.038	0.81	0.000	125
19	2.554	0.024	0.040	0.83	0.000	124
20	2.468	0.024	0.044	0.86	0.000	124
21	2.407	0.024	0.044	0.80	0.000	119
22	2.358	0.020	0.042	0.80	0.000	118
23	2.271	0.019	0.040	0.81	0.000	118
24	2.208	0.017	0.041	0.82	0.000	115

**LRD Regression Coefficients for Coastal Health - Standard Day - Winter**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	2.135	0.020	0.046	0.70	0.001	14
2	2.156	0.016	0.032	0.50	0.086	9
3	2.049	0.032	0.051	0.84	0.010	7
4	2.174	0.000	0.070	0.97	0.033	4
5	2.320	-0.020	0.050	0.98	0.017	4
6	2.470	-0.021	0.008	0.71	0.155	5
7	2.555	-0.006	0.045	0.87	0.017	6
8	2.689	0.005	0.047	0.42	0.029	15
9	2.903	-0.000	0.024	0.22	0.013	37
10	3.032	0.002	0.025	0.44	0.000	65
11	3.039	0.002	0.026	0.60	0.000	96
12	3.017	0.006	0.032	0.71	0.000	112
13	2.995	0.008	0.033	0.71	0.000	116
14	3.034	0.009	0.032	0.68	0.000	115
15	2.980	0.008	0.032	0.66	0.000	115
16	2.945	0.007	0.030	0.59	0.000	116
17	2.816	0.007	0.031	0.64	0.000	117
18	2.734	0.005	0.030	0.58	0.000	105
19	2.696	0.005	0.031	0.50	0.000	79
20	2.603	0.004	0.038	0.60	0.000	63
21	2.552	0.004	0.032	0.53	0.000	43
22	2.484	0.003	0.034	0.49	0.000	29
23	2.370	0.005	0.037	0.53	0.001	21
24	2.250	0.007	0.061	0.69	0.000	16

**LRD Regression Coefficients for Coastal Health - Non-Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	2.182	0.008	0.051	0.77	0.000	47
2	2.183	0.005	0.053	0.78	0.000	44
3	2.229	0.003	0.043	0.64	0.000	41
4	2.184	0.010	0.043	0.69	0.000	39
5	2.243	0.011	0.038	0.62	0.000	36
6	2.255	0.016	0.038	0.68	0.000	37
7	2.328	0.015	0.037	0.63	0.000	40
8	2.384	0.008	0.043	0.66	0.000	47
9	2.439	0.015	0.030	0.66	0.000	55
10	2.500	0.019	0.026	0.57	0.000	55
11	2.421	0.022	0.032	0.62	0.000	55
12	2.528	0.019	0.029	0.52	0.000	55
13	2.496	0.017	0.034	0.55	0.000	55
14	2.548	0.018	0.034	0.53	0.000	55
15	2.540	0.015	0.031	0.58	0.000	55
16	2.521	0.020	0.028	0.65	0.000	55
17	2.523	0.019	0.028	0.67	0.000	55
18	2.422	0.020	0.035	0.77	0.000	55
19	2.429	0.021	0.037	0.82	0.000	55
20	2.306	0.024	0.044	0.83	0.000	55
21	2.246	0.025	0.047	0.80	0.000	53
22	2.221	0.020	0.046	0.64	0.000	52
23	2.230	0.010	0.048	0.66	0.000	52
24	2.136	0.013	0.051	0.78	0.000	50

**LRD Regression Coefficients for Coastal Health - Non-Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	2.199	0.010	0.024	0.95	0.010	5
2	15.835	0.006	0.259	1.00	2.000	0
3	0.000	0.000	0.000	0.00	1.000	0
4	0.000	0.000	0.000	0.00	1.000	0
5	0.000	0.000	0.000	0.00	1.000	0
6	0.000	0.000	0.000	0.00	1.000	0
7	0.000	0.000	0.000	0.00	1.000	0
8	2.370	0.003	0.027	0.66	0.342	4
9	2.579	-0.010	-0.008	0.54	0.045	10
10	2.556	-0.005	0.018	0.54	0.000	32
11	2.525	-0.003	0.021	0.64	0.000	42
12	2.470	0.003	0.028	0.72	0.000	51
13	2.462	0.003	0.027	0.75	0.000	52
14	2.493	0.005	0.028	0.76	0.000	52
15	2.446	0.005	0.030	0.80	0.000	54
16	2.432	0.006	0.030	0.75	0.000	51
17	2.410	0.004	0.030	0.73	0.000	49
18	2.449	0.001	0.026	0.73	0.000	47
19	2.482	0.004	0.031	0.72	0.000	39
20	2.468	0.002	0.023	0.66	0.000	31
21	2.402	0.000	0.022	0.68	0.000	25
22	2.342	0.001	0.020	0.45	0.002	23
23	2.319	0.001	0.012	0.41	0.053	13
24	2.262	0.002	0.006	0.23	0.352	10



**LRD Regression Coefficients for Non-Coastal Health - Standard Day - Summer**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	2.335	0.015	0.035	0.73	0.000	104
2	2.280	0.016	0.036	0.64	0.000	101
3	2.298	0.011	0.032	0.62	0.000	97
4	2.306	0.011	0.031	0.60	0.000	92
5	2.354	0.012	0.030	0.61	0.000	87
6	2.613	0.014	0.034	0.67	0.000	81
7	2.858	0.014	0.035	0.69	0.000	85
8	3.038	0.021	0.039	0.79	0.000	95
9	3.170	0.019	0.039	0.81	0.000	117
10	3.149	0.026	0.039	0.85	0.000	124
11	3.134	0.024	0.039	0.87	0.000	124
12	3.070	0.028	0.039	0.89	0.000	125
13	3.017	0.025	0.041	0.89	0.000	124
14	3.041	0.024	0.042	0.88	0.000	125
15	2.948	0.026	0.045	0.89	0.000	125
16	2.885	0.022	0.046	0.88	0.000	123
17	2.800	0.022	0.046	0.89	0.000	125
18	2.789	0.021	0.043	0.88	0.000	126
19	2.750	0.027	0.042	0.90	0.000	124
20	2.688	0.020	0.047	0.84	0.000	123
21	2.597	0.025	0.046	0.84	0.000	123
22	2.486	0.024	0.045	0.82	0.000	121
23	2.419	0.020	0.042	0.80	0.000	114
24	2.364	0.015	0.041	0.74	0.000	109

**LRD Regression Coefficients for Non-Coastal Health - Standard Day - Winter**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	2.213	0.002	0.007	0.20	0.190	17
2	2.281	0.006	-0.007	0.05	0.707	16
3	2.280	0.005	-0.008	0.03	0.829	13
4	2.335	0.000	-0.017	0.03	0.890	10
5	2.445	-0.002	-0.052	0.09	0.689	10
6	2.605	0.012	-0.024	0.13	0.506	12
7	2.986	0.008	-0.085	0.20	0.467	9
8	3.168	0.014	-0.010	0.11	0.639	10
9	3.127	0.009	0.022	0.09	0.186	36
10	3.146	0.007	0.027	0.20	0.001	62
11	3.128	0.008	0.024	0.33	0.000	93
12	3.087	0.007	0.025	0.41	0.000	111
13	3.026	0.009	0.029	0.47	0.000	112
14	2.972	0.012	0.033	0.54	0.000	116
15	2.932	0.010	0.032	0.75	0.000	113
16	2.875	0.010	0.033	0.73	0.000	112
17	2.819	0.009	0.030	0.71	0.000	111
18	2.750	0.007	0.027	0.72	0.000	110
19	2.729	0.007	0.024	0.72	0.000	91
20	2.650	0.005	0.020	0.56	0.000	77
21	2.551	0.005	0.019	0.50	0.000	57
22	2.453	0.005	0.014	0.44	0.000	42
23	2.373	0.005	0.008	0.45	0.000	34
24	2.255	0.004	0.010	0.29	0.016	26

**LRD Regression Coefficients for Non-Coastal Health - Non-Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	2.294	0.020	0.031	0.72	0.000	45
2	2.267	0.019	0.027	0.67	0.000	43
3	2.261	0.018	0.022	0.59	0.000	41
4	2.285	0.016	0.019	0.55	0.000	40
5	2.338	0.016	0.017	0.56	0.000	37
6	2.500	0.017	0.022	0.60	0.000	37
7	2.600	0.017	0.025	0.53	0.000	40
8	2.579	0.020	0.038	0.71	0.000	43
9	2.701	0.021	0.025	0.58	0.000	53
10	2.654	0.022	0.031	0.68	0.000	55
11	2.662	0.025	0.032	0.74	0.000	55
12	2.582	0.020	0.036	0.80	0.000	55
13	2.628	0.022	0.035	0.84	0.000	55
14	2.573	0.022	0.037	0.86	0.000	54
15	2.556	0.022	0.037	0.86	0.000	55
16	2.511	0.023	0.040	0.87	0.000	54
17	2.553	0.024	0.039	0.88	0.000	55
18	2.654	0.026	0.036	0.83	0.000	55
19	2.630	0.023	0.036	0.82	0.000	55
20	2.587	0.028	0.036	0.87	0.000	55
21	2.554	0.026	0.033	0.79	0.000	54
22	2.485	0.023	0.029	0.72	0.000	52
23	2.408	0.019	0.029	0.72	0.000	48
24	2.400	0.013	0.025	0.65	0.000	45

**LRD Regression Coefficients for Non-Coastal Health - Non-Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	2.193	0.002	0.006	0.07	0.746	10
2	2.033	-0.008	0.040	0.44	0.745	3
3	4.539	-0.000	0.040	0.00	0.952	4
4	4.410	-0.007	0.040	0.55	0.258	4
5	4.382	-0.009	0.040	0.69	0.171	4
6	2.018	-0.015	0.041	0.83	0.167	4
7	2.020	-0.017	-0.004	0.94	0.243	3
8	2.613	0.005	-0.005	0.20	0.647	6
9	2.597	-0.002	0.003	0.06	0.677	14
10	2.566	0.004	0.021	0.52	0.000	28
11	2.500	0.001	0.022	0.55	0.000	36
12	2.522	0.003	0.023	0.68	0.000	43
13	2.526	0.005	0.025	0.71	0.000	47
14	2.490	0.004	0.025	0.67	0.000	48
15	2.448	0.004	0.027	0.69	0.000	49
16	2.388	0.006	0.030	0.77	0.000	48
17	2.417	0.005	0.027	0.74	0.000	49
18	2.508	0.003	0.023	0.73	0.000	47
19	2.533	0.004	0.021	0.76	0.000	41
20	2.492	0.001	0.015	0.36	0.002	31
21	2.381	-0.001	0.012	0.30	0.013	26
22	2.322	-0.002	0.005	0.12	0.273	22
23	2.246	-0.002	0.004	0.17	0.170	21
24	2.172	-0.001	0.005	0.12	0.380	17

**LRD Regression Coefficients for Coastal Lodging - Standard Day - Summer**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.925	-0.000	0.013	0.34	0.000	150
2	0.870	0.000	0.013	0.42	0.000	147
3	0.855	0.000	0.012	0.44	0.000	140
4	0.854	0.001	0.012	0.46	0.000	136
5	0.892	0.002	0.012	0.40	0.000	130
6	0.970	0.004	0.013	0.32	0.000	131
7	1.052	0.005	0.013	0.25	0.000	137
8	1.095	0.006	0.012	0.47	0.000	162
9	1.097	0.007	0.011	0.62	0.000	180
10	1.092	0.007	0.011	0.67	0.000	181
11	1.092	0.008	0.010	0.66	0.000	182
12	1.082	0.007	0.010	0.64	0.000	182
13	1.078	0.006	0.011	0.61	0.000	182
14	1.084	0.005	0.010	0.57	0.000	182
15	1.076	0.005	0.009	0.58	0.000	182
16	1.074	0.005	0.009	0.54	0.000	182
17	1.078	0.005	0.010	0.51	0.000	182
18	1.098	0.006	0.010	0.40	0.000	181
19	1.143	0.006	0.009	0.30	0.000	180
20	1.153	0.006	0.012	0.43	0.000	180
21	1.162	0.005	0.014	0.40	0.000	173
22	1.128	0.004	0.014	0.40	0.000	171
23	1.060	0.002	0.014	0.38	0.000	171
24	0.991	0.001	0.013	0.34	0.000	166

**LRD Regression Coefficients for Coastal Lodging - Standard Day - Winter**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.906	0.003	0.006	0.07	0.516	20
2	0.803	0.006	0.019	0.51	0.041	11
3	0.765	0.011	0.010	0.52	0.113	8
4	0.895	-0.020	0.007	0.81	0.084	5
5	0.945	-0.023	-0.021	0.90	0.034	5
6	0.959	-0.014	-0.015	0.27	0.536	6
7	1.016	-0.009	0.015	0.33	0.366	7
8	1.023	0.005	0.010	0.09	0.418	20
9	1.083	-0.000	0.003	0.02	0.676	48
10	1.077	0.003	0.007	0.24	0.000	98
11	1.069	0.003	0.007	0.28	0.000	139
12	1.055	0.003	0.008	0.30	0.000	164
13	1.047	0.003	0.008	0.31	0.000	169
14	1.043	0.004	0.008	0.34	0.000	168
15	1.037	0.004	0.007	0.31	0.000	170
16	1.028	0.003	0.007	0.29	0.000	168
17	1.047	0.003	0.007	0.21	0.000	167
18	1.118	0.002	0.005	0.06	0.008	153
19	1.145	0.003	0.007	0.12	0.001	119
20	1.159	0.004	0.009	0.16	0.000	95
21	1.158	0.003	0.006	0.16	0.003	69
22	1.147	0.003	0.003	0.09	0.096	53
23	1.094	0.003	-0.000	0.11	0.142	35
24	1.011	0.001	-0.003	0.03	0.672	27

**LRD Regression Coefficients for Coastal Lodging - Non-Standard Day - Summer**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.000	0.000	0.000	0.00	1.000	0
2	0.000	0.000	0.000	0.00	1.000	0
3	0.000	0.000	0.000	0.00	1.000	0
4	0.000	0.000	0.000	0.00	1.000	0
5	0.000	0.000	0.000	0.00	1.000	0
6	0.000	0.000	0.000	0.00	1.000	0
7	0.000	0.000	0.000	0.00	1.000	0
8	0.000	0.000	0.000	0.00	1.000	0
9	0.000	0.000	0.000	0.00	1.000	0
10	0.000	0.000	0.000	0.00	1.000	0
11	0.000	0.000	0.000	0.00	1.000	0
12	0.000	0.000	0.000	0.00	1.000	0
13	0.000	0.000	0.000	0.00	1.000	0
14	0.000	0.000	0.000	0.00	1.000	0
15	0.000	0.000	0.000	0.00	1.000	0
16	0.000	0.000	0.000	0.00	1.000	0
17	0.000	0.000	0.000	0.00	1.000	0
18	0.000	0.000	0.000	0.00	1.000	0
19	0.000	0.000	0.000	0.00	1.000	0
20	0.000	0.000	0.000	0.00	1.000	0
21	0.000	0.000	0.000	0.00	1.000	0
22	0.000	0.000	0.000	0.00	1.000	0
23	0.000	0.000	0.000	0.00	1.000	0
24	0.000	0.000	0.000	0.00	1.000	0

**LRD Regression Coefficients for Coastal Lodging - Non-Standard Day - Winter**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.000	0.000	0.000	0.00	1.000	0
2	0.000	0.000	0.000	0.00	1.000	0
3	0.000	0.000	0.000	0.00	1.000	0
4	0.000	0.000	0.000	0.00	1.000	0
5	0.000	0.000	0.000	0.00	1.000	0
6	0.000	0.000	0.000	0.00	1.000	0
7	0.000	0.000	0.000	0.00	1.000	0
8	0.000	0.000	0.000	0.00	1.000	0
9	0.000	0.000	0.000	0.00	1.000	0
10	0.000	0.000	0.000	0.00	1.000	0
11	0.000	0.000	0.000	0.00	1.000	0
12	0.000	0.000	0.000	0.00	1.000	0
13	0.000	0.000	0.000	0.00	1.000	0
14	0.000	0.000	0.000	0.00	1.000	0
15	0.000	0.000	0.000	0.00	1.000	0
16	0.000	0.000	0.000	0.00	1.000	0
17	0.000	0.000	0.000	0.00	1.000	0
18	0.000	0.000	0.000	0.00	1.000	0
19	0.000	0.000	0.000	0.00	1.000	0
20	0.000	0.000	0.000	0.00	1.000	0
21	0.000	0.000	0.000	0.00	1.000	0
22	0.000	0.000	0.000	0.00	1.000	0
23	0.000	0.000	0.000	0.00	1.000	0
24	0.000	0.000	0.000	0.00	1.000	0

**LRD Regression Coefficients for Non-Coastal Lodging - Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficeint (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	1.179	0.006	0.014	0.45	0.000	150
2	1.154	0.005	0.013	0.38	0.000	145
3	1.133	0.005	0.013	0.49	0.000	139
4	1.127	0.006	0.012	0.42	0.000	133
5	1.136	0.006	0.011	0.38	0.000	125
6	1.215	0.004	0.011	0.39	0.000	119
7	1.316	0.003	0.008	0.22	0.000	126
8	1.343	0.007	0.007	0.34	0.000	139
9	1.383	0.008	0.009	0.58	0.000	171
10	1.338	0.011	0.011	0.47	0.000	180
11	1.321	0.011	0.012	0.62	0.000	180
12	1.321	0.010	0.012	0.75	0.000	181
13	1.329	0.011	0.013	0.77	0.000	180
14	1.318	0.011	0.014	0.75	0.000	180
15	1.272	0.012	0.015	0.76	0.000	181
16	1.249	0.010	0.016	0.73	0.000	178
17	1.321	0.010	0.016	0.74	0.000	181
18	1.375	0.013	0.016	0.76	0.000	182
19	1.417	0.014	0.016	0.77	0.000	180
20	1.410	0.009	0.015	0.66	0.000	179
21	1.385	0.009	0.015	0.62	0.000	178
22	1.297	0.010	0.016	0.51	0.000	174
23	1.248	0.008	0.015	0.49	0.000	163
24	1.219	0.005	0.014	0.44	0.000	155

**LRD Regression Coefficients for Non-Coastal Lodging - Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficeint (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	1.221	0.002	0.000	0.05	0.492	28
2	1.164	0.001	0.001	0.01	0.898	20
3	1.145	0.001	-0.003	0.04	0.763	17
4	1.126	-0.001	-0.004	0.08	0.602	14
5	1.137	-0.000	-0.004	0.04	0.776	14
6	1.215	0.001	0.005	0.08	0.527	17
7	1.332	0.002	0.001	0.39	0.065	13
8	1.355	0.004	0.005	0.28	0.085	17
9	1.459	0.005	0.002	0.30	0.000	51
10	1.443	0.006	0.007	0.31	0.000	91
11	1.411	0.006	0.008	0.31	0.000	130
12	1.386	0.006	0.009	0.38	0.000	155
13	1.398	0.006	0.009	0.39	0.000	160
14	1.397	0.006	0.008	0.37	0.000	165
15	1.353	0.005	0.008	0.36	0.000	163
16	1.343	0.006	0.009	0.36	0.000	161
17	1.428	0.004	0.006	0.26	0.000	161
18	1.533	0.002	0.004	0.12	0.000	158
19	1.555	0.003	0.007	0.18	0.000	133
20	1.463	0.004	0.011	0.29	0.000	109
21	1.409	0.004	0.012	0.30	0.000	84
22	1.342	0.004	0.011	0.25	0.000	65
23	1.298	0.003	0.007	0.14	0.015	56
24	1.236	0.003	0.008	0.14	0.047	44

**LRD Regression Coefficients for Non-Coastal Lodging - Non-Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficeint (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.000	0.000	0.000	0.00	1.000	0
2	0.000	0.000	0.000	0.00	1.000	0
3	0.000	0.000	0.000	0.00	1.000	0
4	0.000	0.000	0.000	0.00	1.000	0
5	0.000	0.000	0.000	0.00	1.000	0
6	0.000	0.000	0.000	0.00	1.000	0
7	0.000	0.000	0.000	0.00	1.000	0
8	0.000	0.000	0.000	0.00	1.000	0
9	0.000	0.000	0.000	0.00	1.000	0
10	0.000	0.000	0.000	0.00	1.000	0
11	0.000	0.000	0.000	0.00	1.000	0
12	0.000	0.000	0.000	0.00	1.000	0
13	0.000	0.000	0.000	0.00	1.000	0
14	0.000	0.000	0.000	0.00	1.000	0
15	0.000	0.000	0.000	0.00	1.000	0
16	0.000	0.000	0.000	0.00	1.000	0
17	0.000	0.000	0.000	0.00	1.000	0
18	0.000	0.000	0.000	0.00	1.000	0
19	0.000	0.000	0.000	0.00	1.000	0
20	0.000	0.000	0.000	0.00	1.000	0
21	0.000	0.000	0.000	0.00	1.000	0
22	0.000	0.000	0.000	0.00	1.000	0
23	0.000	0.000	0.000	0.00	1.000	0
24	0.000	0.000	0.000	0.00	1.000	0

**LRD Regression Coefficients for Non-Coastal Lodging - Non-Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficeint (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.000	0.000	0.000	0.00	1.000	0
2	0.000	0.000	0.000	0.00	1.000	0
3	0.000	0.000	0.000	0.00	1.000	0
4	0.000	0.000	0.000	0.00	1.000	0
5	0.000	0.000	0.000	0.00	1.000	0
6	0.000	0.000	0.000	0.00	1.000	0
7	0.000	0.000	0.000	0.00	1.000	0
8	0.000	0.000	0.000	0.00	1.000	0
9	0.000	0.000	0.000	0.00	1.000	0
10	0.000	0.000	0.000	0.00	1.000	0
11	0.000	0.000	0.000	0.00	1.000	0
12	0.000	0.000	0.000	0.00	1.000	0
13	0.000	0.000	0.000	0.00	1.000	0
14	0.000	0.000	0.000	0.00	1.000	0
15	0.000	0.000	0.000	0.00	1.000	0
16	0.000	0.000	0.000	0.00	1.000	0
17	0.000	0.000	0.000	0.00	1.000	0
18	0.000	0.000	0.000	0.00	1.000	0
19	0.000	0.000	0.000	0.00	1.000	0
20	0.000	0.000	0.000	0.00	1.000	0
21	0.000	0.000	0.000	0.00	1.000	0
22	0.000	0.000	0.000	0.00	1.000	0
23	0.000	0.000	0.000	0.00	1.000	0
24	0.000	0.000	0.000	0.00	1.000	0

**LRD Regression Coefficients for Coastal School - Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.422	0.003	0.001	0.05	0.377	38
2	0.412	0.004	0.001	0.08	0.235	38
3	0.421	0.002	0.002	0.04	0.520	34
4	0.425	0.003	-0.000	0.03	0.675	32
5	0.421	0.007	-0.006	0.20	0.043	30
6	0.482	0.005	-0.005	0.10	0.233	30
7	0.678	0.002	-0.009	0.06	0.422	32
8	1.257	0.004	-0.029	0.14	0.026	50
9	1.873	0.003	-0.038	0.22	0.001	60
10	1.869	-0.002	-0.012	0.06	0.178	61
11	1.839	0.001	-0.006	0.02	0.569	62
12	1.819	0.000	-0.000	0.00	0.997	62
13	1.629	0.001	0.002	0.00	0.933	62
14	1.782	0.000	-0.005	0.02	0.619	62
15	1.474	0.004	0.000	0.03	0.349	62
16	0.973	0.004	0.005	0.19	0.002	62
17	0.732	0.004	0.005	0.12	0.025	62
18	0.664	0.007	-0.003	0.10	0.046	61
19	0.683	0.013	-0.013	0.24	0.000	60
20	0.667	0.011	-0.003	0.11	0.036	60
21	0.684	0.005	-0.004	0.03	0.462	55
22	0.587	0.001	-0.000	0.00	0.900	54
23	0.468	0.003	0.001	0.06	0.184	54
24	0.423	0.006	-0.002	0.09	0.092	51

**LRD Regression Coefficients for Coastal School - Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.339	0.012	0.028	0.54	0.009	14
2	0.352	0.010	0.047	0.85	0.001	9
3	0.419	0.004	0.038	0.66	0.068	7
4	0.170	0.061	0.064	0.99	0.005	4
5	0.399	0.014	0.055	0.84	0.159	4
6	0.515	-0.002	0.020	0.42	0.444	5
7	0.648	-0.006	0.019	0.40	0.361	6
8	1.057	0.011	0.011	0.02	0.851	15
9	1.620	-0.003	-0.015	0.01	0.789	37
10	1.619	0.000	-0.001	0.00	0.996	65
11	1.669	0.004	-0.005	0.01	0.521	96
12	1.541	0.005	0.011	0.01	0.437	112
13	1.381	0.005	0.010	0.02	0.325	116
14	1.437	0.007	0.012	0.03	0.210	115
15	1.275	0.003	0.008	0.01	0.430	115
16	0.903	0.001	0.006	0.03	0.227	116
17	0.715	0.000	0.003	0.01	0.559	117
18	0.715	0.000	-0.002	0.01	0.733	105
19	0.720	0.000	-0.001	0.00	0.971	79
20	0.774	-0.001	-0.006	0.02	0.574	63
21	0.715	0.001	0.001	0.01	0.835	43
22	0.622	-0.000	0.001	0.00	0.993	29
23	0.499	0.001	0.003	0.02	0.787	21
24	0.441	0.002	-0.003	0.08	0.559	16

**LRD Regression Coefficients for Coastal School - Non-Standard Day - Summer**

Hour	Regression Parameters			Statistics		
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	N
1	0.445	-0.003	0.000	0.02	0.298	111
2	0.435	-0.002	0.001	0.01	0.527	108
3	0.444	-0.003	0.000	0.02	0.317	105
4	0.443	-0.002	-0.000	0.01	0.473	103
5	0.435	-0.001	-0.000	0.00	0.851	99
6	0.386	0.005	-0.000	0.04	0.121	100
7	0.341	0.011	0.003	0.09	0.010	104
8	0.406	0.021	0.001	0.06	0.030	111
9	0.588	0.023	-0.005	0.03	0.154	119
10	0.646	0.014	0.002	0.02	0.345	119
11	0.679	0.011	0.003	0.01	0.490	119
12	0.693	0.009	0.002	0.01	0.556	119
13	0.687	-0.000	0.003	0.00	0.926	119
14	0.664	0.000	0.002	0.00	0.943	119
15	0.647	-0.002	0.001	0.00	0.862	119
16	0.502	0.004	0.002	0.01	0.580	119
17	0.427	0.001	0.003	0.02	0.369	119
18	0.413	0.002	0.001	0.01	0.516	119
19	0.448	-0.001	-0.000	0.00	0.934	119
20	0.485	-0.002	-0.002	0.01	0.519	119
21	0.564	-0.007	-0.004	0.08	0.008	117
22	0.545	-0.005	-0.004	0.08	0.010	116
23	0.474	-0.003	-0.001	0.04	0.091	116
24	0.439	-0.002	0.001	0.01	0.450	114

**LRD Regression Coefficients for Coastal School - Non-Standard Day - Winter**

Hour	Regression Parameters			Statistics		
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	N
1	0.441	-0.004	-0.023	0.10	0.850	5
2	85.191	0.689	0.846	1.00	2.000	0
3	0.000	0.000	0.000	0.00	1.000	0
4	0.000	0.000	0.000	0.00	1.000	0
5	0.000	0.000	0.000	0.00	1.000	0
6	0.000	0.000	0.000	0.00	1.000	0
7	0.000	0.000	0.000	0.00	1.000	0
8	0.356	-0.004	0.018	0.81	0.190	4
9	0.702	-0.034	-0.065	0.61	0.024	10
10	0.398	-0.008	0.010	0.14	0.098	32
11	0.426	-0.008	0.001	0.12	0.079	42
12	0.398	-0.005	0.004	0.12	0.046	51
13	0.393	-0.004	0.003	0.12	0.044	52
14	0.384	-0.001	0.005	0.07	0.186	52
15	0.383	-0.001	0.005	0.07	0.138	54
16	0.388	-0.000	0.004	0.07	0.157	51
17	0.446	-0.003	-0.002	0.06	0.215	49
18	0.492	-0.005	-0.004	0.10	0.085	47
19	0.500	-0.003	-0.001	0.05	0.365	39
20	0.516	-0.002	0.001	0.02	0.739	31
21	0.518	-0.001	0.002	0.01	0.897	25
22	0.494	-0.001	0.003	0.01	0.886	23
23	0.389	0.004	0.014	0.16	0.396	13
24	0.404	-0.005	0.007	0.30	0.245	10



**LRD Regression Coefficients for Non-Coastal School - Standard Day - Summer**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.290	0.005	0.004	0.07	0.236	40
2	0.263	0.005	0.011	0.09	0.183	37
3	0.249	0.004	0.022	0.15	0.081	33
4	0.273	0.003	0.017	0.06	0.415	29
5	0.335	0.003	0.001	0.01	0.840	26
6	0.387	0.004	0.015	0.04	0.622	24
7	0.815	-0.008	0.033	0.10	0.336	22
8	1.624	0.001	0.042	0.22	0.027	31
9	2.103	0.003	0.020	0.12	0.041	53
10	2.144	0.007	0.028	0.30	0.000	61
11	2.053	0.012	0.037	0.48	0.000	61
12	1.991	0.019	0.042	0.57	0.000	61
13	1.915	0.016	0.042	0.61	0.000	60
14	2.010	0.012	0.044	0.60	0.000	61
15	1.736	0.021	0.048	0.71	0.000	61
16	1.449	0.016	0.037	0.50	0.000	59
17	0.907	0.010	0.013	0.17	0.005	61
18	0.747	0.009	0.005	0.09	0.060	62
19	0.694	0.006	0.001	0.04	0.335	61
20	0.620	-0.000	0.004	0.01	0.840	59
21	0.548	0.005	0.005	0.03	0.370	59
22	0.469	0.006	0.003	0.08	0.107	57
23	0.344	0.006	0.015	0.15	0.020	51
24	0.301	0.003	0.019	0.14	0.043	45

**LRD Regression Coefficients for Non-Coastal School - Standard Day - Winter**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.256	0.000	-0.003	0.02	0.851	17
2	0.270	-0.001	-0.008	0.11	0.438	16
3	0.252	-0.001	-0.005	0.20	0.295	13
4	0.234	0.002	0.001	0.14	0.539	10
5	0.228	0.002	0.006	0.29	0.260	10
6	0.310	-0.005	0.012	0.26	0.229	12
7	0.707	-0.012	0.013	0.49	0.097	9
8	1.501	-0.008	0.024	0.49	0.069	10
9	1.770	-0.009	0.027	0.08	0.256	36
10	2.005	-0.003	-0.003	0.00	0.866	62
11	2.006	0.003	0.006	0.01	0.652	93
12	1.873	0.012	0.025	0.11	0.001	111
13	1.719	0.012	0.028	0.15	0.000	112
14	1.836	0.014	0.028	0.14	0.000	116
15	1.598	0.012	0.031	0.20	0.000	113
16	1.264	0.009	0.023	0.17	0.000	112
17	0.727	0.002	0.008	0.09	0.007	111
18	0.632	0.000	0.002	0.01	0.734	110
19	0.615	0.000	-0.002	0.00	0.855	91
20	0.567	-0.001	0.000	0.00	0.942	77
21	0.496	-0.001	0.002	0.01	0.678	57
22	0.406	-0.001	0.004	0.02	0.629	42
23	0.315	-0.001	0.004	0.03	0.567	34
24	0.267	-0.001	0.003	0.03	0.706	26

**LRD Regression Coefficients for Non-Coastal School - Non-Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.250	0.003	0.006	0.07	0.021	109
2	0.240	0.002	0.007	0.07	0.023	107
3	0.246	0.002	0.006	0.06	0.039	105
4	0.249	0.002	0.005	0.05	0.063	103
5	0.250	0.002	0.007	0.09	0.009	98
6	0.252	0.004	0.015	0.22	0.000	94
7	0.288	0.017	0.021	0.22	0.000	103
8	0.404	0.040	0.017	0.12	0.002	107
9	0.561	0.037	0.013	0.08	0.007	117
10	0.549	0.036	0.017	0.10	0.003	118
11	0.530	0.035	0.017	0.10	0.002	118
12	0.565	0.036	0.014	0.09	0.004	119
13	0.668	0.044	0.007	0.11	0.001	119
14	0.655	0.048	0.007	0.10	0.002	118
15	0.503	0.040	0.014	0.09	0.004	119
16	0.352	0.030	0.017	0.10	0.003	118
17	0.282	0.012	0.010	0.09	0.003	119
18	0.322	0.005	0.004	0.04	0.091	119
19	0.341	0.003	0.002	0.01	0.416	118
20	0.333	0.004	0.002	0.03	0.205	119
21	0.334	0.004	0.002	0.03	0.225	118
22	0.336	0.003	0.000	0.02	0.390	116
23	0.299	0.003	0.002	0.02	0.358	111
24	0.262	0.002	0.005	0.06	0.039	109

**LRD Regression Coefficients for Non-Coastal School - Non-Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.225	-0.000	0.002	0.01	0.942	10
2	0.254	0.000	-0.004	0.28	0.848	3
3	0.001	0.000	-0.004	0.00	0.941	4
4	0.026	0.002	-0.004	0.11	0.672	4
5	0.043	0.002	-0.004	0.25	0.499	4
6	0.307	0.003	0.055	0.90	0.096	4
7	0.503	0.012	0.019	1.00	0.070	3
8	0.192	-0.001	0.005	0.32	0.458	6
9	0.338	-0.041	-0.084	0.46	0.024	14
10	0.220	-0.009	0.003	0.06	0.431	28
11	0.237	-0.010	-0.000	0.08	0.265	36
12	0.254	-0.009	-0.001	0.06	0.297	43
13	0.251	-0.006	0.001	0.04	0.395	47
14	0.229	-0.005	0.003	0.04	0.383	48
15	0.211	-0.003	0.006	0.04	0.355	49
16	0.236	-0.004	0.002	0.05	0.322	48
17	0.252	-0.003	-0.000	0.05	0.297	49
18	0.276	-0.003	-0.002	0.09	0.134	47
19	0.276	-0.003	-0.003	0.12	0.081	41
20	0.261	-0.003	-0.004	0.23	0.023	31
21	0.262	-0.003	-0.006	0.27	0.024	26
22	0.265	-0.002	-0.008	0.32	0.020	22
23	0.244	-0.001	-0.005	0.22	0.099	21
24	0.235	-0.001	-0.004	0.15	0.307	17

**LRD Regression Coefficients for Coastal College - Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.774	-0.003	0.001	0.02	0.458	102
2	0.757	-0.003	0.001	0.02	0.376	102
3	0.758	-0.003	0.001	0.02	0.318	98
4	0.782	-0.002	0.002	0.03	0.299	96
5	0.818	0.001	0.006	0.17	0.000	93
6	0.942	0.001	0.009	0.27	0.000	93
7	1.212	-0.001	0.013	0.19	0.000	96
8	1.558	-0.005	0.008	0.06	0.037	114
9	1.732	-0.006	0.002	0.04	0.088	124
10	1.803	-0.006	0.001	0.04	0.076	125
11	1.811	-0.005	0.003	0.04	0.061	126
12	1.792	-0.005	0.003	0.05	0.030	126
13	1.800	-0.006	0.003	0.07	0.011	126
14	1.790	-0.003	0.002	0.02	0.229	126
15	1.771	-0.003	0.000	0.02	0.310	126
16	1.684	-0.003	-0.001	0.02	0.391	126
17	1.538	-0.005	-0.002	0.02	0.275	126
18	1.535	-0.002	-0.008	0.03	0.117	125
19	1.523	0.001	-0.013	0.06	0.028	124
20	1.424	0.002	-0.009	0.03	0.195	124
21	1.208	0.004	-0.003	0.01	0.633	119
22	1.001	0.001	-0.004	0.01	0.486	118
23	0.865	0.003	-0.004	0.02	0.276	118
24	0.780	0.003	-0.003	0.03	0.218	115

**LRD Regression Coefficients for Coastal College - Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.760	0.015	-0.006	0.49	0.018	14
2	0.740	0.013	-0.007	0.40	0.164	9
3	0.700	0.017	-0.001	0.30	0.412	7
4	1.366	-0.133	-0.049	1.00	0.004	4
5	0.974	-0.031	-0.030	0.23	0.769	4
6	0.815	0.012	0.050	0.12	0.830	5
7	0.916	0.018	0.105	0.33	0.451	6
8	1.311	-0.001	0.071	0.35	0.061	15
9	1.607	-0.004	0.021	0.14	0.068	37
10	1.677	0.005	0.017	0.12	0.017	65
11	1.711	0.009	0.013	0.13	0.001	96
12	1.627	0.011	0.021	0.17	0.000	112
13	1.606	0.010	0.018	0.14	0.000	116
14	1.611	0.011	0.018	0.14	0.000	115
15	1.604	0.008	0.016	0.10	0.002	115
16	1.558	0.005	0.015	0.09	0.004	116
17	1.479	0.005	0.016	0.09	0.005	117
18	1.432	0.005	0.014	0.05	0.072	105
19	1.479	0.008	0.013	0.06	0.079	79
20	1.471	0.005	0.011	0.03	0.448	63
21	1.343	0.004	0.024	0.06	0.304	43
22	1.203	0.004	0.017	0.04	0.554	29
23	1.006	0.003	0.015	0.11	0.339	21
24	0.868	0.002	0.030	0.20	0.207	16

**LRD Regression Coefficients for Coastal College - Non-Standard Day - Summer**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.687	-0.000	-0.002	0.02	0.689	47
2	0.674	-0.002	0.001	0.02	0.608	44
3	0.666	-0.001	0.001	0.01	0.795	41
4	0.665	-0.001	0.000	0.01	0.874	39
5	0.660	-0.002	0.002	0.04	0.521	36
6	0.634	-0.001	0.004	0.08	0.253	37
7	0.660	0.003	0.001	0.03	0.593	40
8	0.803	-0.001	-0.005	0.02	0.601	47
9	0.956	-0.008	-0.008	0.07	0.159	55
10	0.993	-0.011	-0.002	0.08	0.120	55
11	0.969	-0.014	0.004	0.14	0.016	55
12	0.991	-0.015	0.003	0.22	0.001	55
13	0.945	-0.015	0.007	0.35	0.000	55
14	0.971	-0.016	0.006	0.30	0.000	55
15	0.955	-0.016	0.006	0.33	0.000	55
16	0.903	-0.010	0.005	0.15	0.014	55
17	0.874	-0.014	0.005	0.21	0.002	55
18	0.892	-0.007	-0.001	0.05	0.250	55
19	0.927	-0.009	-0.003	0.09	0.075	55
20	0.907	-0.005	-0.004	0.04	0.378	55
21	0.868	-0.004	-0.002	0.02	0.558	53
22	0.828	-0.002	-0.008	0.08	0.130	52
23	0.751	-0.001	-0.006	0.05	0.247	52
24	0.673	0.002	-0.002	0.02	0.688	50

**LRD Regression Coefficients for Coastal College - Non-Standard Day - Winter**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.718	-0.001	-0.033	0.11	0.842	5
2	83.998	0.907	0.644	1.00	2.000	0
3	0.000	0.000	0.000	0.00	1.000	0
4	0.000	0.000	0.000	0.00	1.000	0
5	0.000	0.000	0.000	0.00	1.000	0
6	0.000	0.000	0.000	0.00	1.000	0
7	0.000	0.000	0.000	0.00	1.000	0
8	0.780	-0.002	-0.050	0.94	0.057	4
9	1.026	-0.019	-0.039	0.49	0.066	10
10	0.846	-0.002	0.011	0.08	0.272	32
11	0.863	-0.003	0.007	0.08	0.181	42
12	0.837	-0.001	0.009	0.12	0.041	51
13	0.862	-0.001	0.006	0.09	0.083	52
14	0.862	0.001	0.007	0.08	0.111	52
15	0.876	0.001	0.006	0.07	0.168	54
16	0.845	0.001	0.007	0.10	0.084	51
17	0.869	-0.004	0.003	0.09	0.108	49
18	0.899	-0.007	-0.002	0.12	0.053	47
19	0.902	-0.003	0.002	0.04	0.455	39
20	0.883	-0.000	0.009	0.05	0.473	31
21	0.875	-0.000	0.010	0.04	0.602	25
22	0.890	-0.001	-0.002	0.01	0.929	23
23	0.802	-0.000	0.004	0.06	0.717	13
24	0.751	-0.002	0.001	0.09	0.681	10

**LRD Regression Coefficients for Non-Coastal College - Standard Day - Summer**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.770	0.000	0.004	0.17	0.000	104
2	0.735	0.000	0.006	0.29	0.000	101
3	0.723	0.001	0.006	0.35	0.000	97
4	0.732	0.001	0.007	0.41	0.000	92
5	0.842	0.002	0.010	0.41	0.000	87
6	1.045	0.005	0.017	0.50	0.000	81
7	1.309	0.004	0.020	0.54	0.000	85
8	1.598	0.001	0.016	0.35	0.000	95
9	1.730	0.000	0.012	0.32	0.000	117
10	1.796	0.001	0.010	0.32	0.000	124
11	1.830	0.001	0.009	0.28	0.000	124
12	1.820	0.001	0.008	0.25	0.000	125
13	1.829	0.000	0.009	0.25	0.000	124
14	1.812	0.002	0.009	0.26	0.000	125
15	1.750	0.004	0.010	0.30	0.000	125
16	1.662	0.003	0.009	0.19	0.000	123
17	1.524	0.003	0.006	0.07	0.012	125
18	1.560	0.003	0.002	0.01	0.421	126
19	1.594	0.001	-0.001	0.00	0.944	124
20	1.509	0.002	0.001	0.01	0.737	123
21	1.334	0.003	0.001	0.01	0.429	123
22	1.042	0.000	0.001	0.00	0.756	121
23	0.880	0.000	0.004	0.06	0.023	114
24	0.810	0.000	0.003	0.10	0.003	109

**LRD Regression Coefficients for Non-Coastal College - Standard Day - Winter**

Hour	Regression Parameters			R <sup>2</sup>	Statistics Significance of F-Statistic	N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)			
1	0.782	0.003	0.004	0.35	0.040	17
2	0.750	0.003	0.004	0.52	0.006	16
3	0.733	0.002	0.002	0.53	0.015	13
4	0.732	0.002	0.001	0.30	0.238	10
5	0.825	-0.000	-0.015	0.28	0.269	10
6	0.923	0.003	-0.002	0.17	0.383	12
7	1.193	0.004	-0.008	0.19	0.476	9
8	1.506	0.008	0.019	0.31	0.233	10
9	1.632	0.005	0.019	0.26	0.005	36
10	1.764	0.005	0.006	0.10	0.045	62
11	1.769	0.006	0.010	0.13	0.001	93
12	1.710	0.010	0.017	0.27	0.000	111
13	1.659	0.010	0.016	0.28	0.000	112
14	1.667	0.011	0.016	0.28	0.000	116
15	1.642	0.011	0.016	0.29	0.000	113
16	1.570	0.011	0.017	0.29	0.000	112
17	1.496	0.009	0.017	0.27	0.000	111
18	1.432	0.007	0.015	0.18	0.000	110
19	1.515	0.008	0.012	0.13	0.002	91
20	1.495	0.006	0.011	0.06	0.081	77
21	1.526	0.008	-0.007	0.09	0.067	57
22	1.335	0.007	-0.008	0.12	0.082	42
23	1.048	0.004	-0.009	0.23	0.016	34
24	0.868	0.004	-0.001	0.32	0.009	26

**LRD Regression Coefficients for Non-Coastal College - Non-Standard Day - Summer**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.717	0.001	0.003	0.09	0.126	45
2	0.695	0.001	0.003	0.09	0.149	43
3	0.684	0.001	0.004	0.11	0.094	41
4	0.678	0.001	0.004	0.12	0.080	40
5	0.679	0.003	0.004	0.20	0.019	37
6	0.681	0.005	0.008	0.30	0.002	37
7	0.730	0.004	0.010	0.24	0.006	40
8	0.790	0.005	0.009	0.17	0.022	43
9	0.962	-0.005	-0.000	0.04	0.395	53
10	0.989	-0.005	0.004	0.07	0.160	55
11	1.004	-0.007	0.005	0.15	0.012	55
12	0.999	-0.008	0.006	0.23	0.001	55
13	0.988	-0.009	0.007	0.24	0.001	55
14	0.996	-0.009	0.006	0.25	0.001	54
15	1.030	-0.007	0.004	0.19	0.004	55
16	0.999	-0.007	0.004	0.22	0.001	54
17	0.942	-0.006	0.004	0.22	0.002	55
18	0.975	-0.010	0.002	0.32	0.000	55
19	1.007	-0.010	0.000	0.32	0.000	55
20	0.987	-0.005	0.002	0.12	0.039	55
21	0.942	-0.004	0.002	0.13	0.027	54
22	0.857	-0.001	0.003	0.13	0.034	52
23	0.798	-0.001	0.003	0.10	0.092	48
24	0.748	-0.002	0.003	0.10	0.095	45

**LRD Regression Coefficients for Non-Coastal College - Non-Standard Day - Winter**

Hour	Regression Parameters			Statistics		N
	Base Load Intercept (W/ft <sup>2</sup> )	Dew Point Coefficient (W/ft <sup>2</sup> /°F)	Dry Bulb Coefficient (W/ft <sup>2</sup> /°F)	R <sup>2</sup>	Significance of F-Statistic	
1	0.707	-0.000	0.011	0.19	0.429	10
2	0.660	-0.003	0.015	0.74	0.507	3
3	1.569	-0.001	0.015	0.13	0.638	4
4	1.578	-0.000	0.015	0.00	0.984	4
5	1.568	-0.001	0.015	0.01	0.880	4
6	0.678	-0.001	0.005	0.06	0.938	4
7	0.752	0.002	0.003	0.70	0.546	3
8	0.775	-0.000	-0.003	0.09	0.827	6
9	0.876	-0.009	-0.020	0.27	0.147	14
10	0.915	0.002	0.005	0.03	0.633	28
11	0.872	0.000	0.009	0.10	0.176	36
12	0.863	0.001	0.010	0.16	0.031	43
13	0.868	0.002	0.010	0.21	0.005	47
14	0.874	0.002	0.009	0.18	0.010	48
15	0.872	0.002	0.010	0.21	0.004	49
16	0.870	0.003	0.010	0.22	0.003	48
17	0.876	0.002	0.008	0.17	0.012	49
18	0.907	-0.001	0.004	0.09	0.126	47
19	0.917	-0.000	0.006	0.10	0.142	41
20	0.940	-0.000	0.002	0.01	0.874	31
21	0.925	-0.001	-0.001	0.01	0.923	26
22	0.910	0.000	-0.004	0.01	0.894	22
23	0.824	0.001	0.003	0.02	0.828	21
24	0.748	0.002	0.013	0.34	0.043	17

## Appendix E. THI Matrices for Cooling

Coastal College

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
44	nd	nd	nd	nd	nd	0.01	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	
45	nd	nd	nd	0.01	0.01	nd	nd	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	
46	nd	nd	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	
47	nd	0.01	0.01	nd	nd	nd	0.01	0.01	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	
48	nd	0.01	nd	nd	0.01	0.01	0.01	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.01	
49	0.04	0.01	nd	0.01	0.01	0.01	0.01	0.02	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	
50	0.01	nd	0.01	0.04	0.01	0.01	0.03	0.03	0.05	0.10	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.08	nd	
51	0.06	0.11	0.06	0.11	0.11	0.07	0.05	0.05	0.06	0.12	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.12	nd	nd	0.01	0.04	
52	0.11	0.12	0.11	0.06	0.09	0.09	0.05	0.05	0.10	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.09	0.08	0.08	nd	
53	0.13	0.11	0.11	0.12	0.12	0.10	0.07	0.08	0.12	0.13	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.07	nd	0.09	0.08	0.12	
54	0.14	0.12	0.12	0.13	0.14	0.11	0.09	0.09	0.11	nd	0.16	nd	nd	nd	nd	nd	nd	nd	0.15	0.13	0.11	0.10	0.08	0.13	
55	0.14	0.14	0.15	0.14	0.14	0.13	0.10	0.09	0.12	0.12	0.15	nd	nd	nd	nd	nd	nd	nd	0.13	0.12	0.13	0.10	0.09	0.09	0.13
56	0.16	0.15	0.15	0.14	0.16	0.13	0.11	0.11	0.12	0.15	0.15	nd	nd	nd	nd	nd	0.13	0.16	0.14	0.11	0.11	0.11	0.09	0.15	
57	0.17	0.15	0.15	0.15	0.16	0.15	0.12	0.12	0.15	0.16	0.17	0.18	0.16	0.16	0.16	0.15	0.15	0.15	0.14	0.14	0.13	0.13	0.11	0.10	0.16
58	0.18	0.15	nd	0.16	nd	0.17	0.14	0.12	0.15	0.17	0.20	0.18	0.19	0.15	0.15	0.16	nd	0.14	0.15	0.14	0.15	0.11	0.11	0.16	
59	0.21	0.19	0.18	0.19	0.19	0.18	0.15	0.16	0.20	0.20	0.18	0.20	0.19	0.20	0.20	0.19	0.18	0.20	0.17	0.16	0.16	0.13	0.12	0.19	
60	0.24	0.23	0.20	0.24	0.24	0.21	0.17	0.17	0.20	0.24	0.23	0.19	0.20	0.21	0.21	0.23	0.24	0.18	0.18	0.20	0.18	0.17	0.14	0.21	
61	0.22	0.20	nd	nd	0.24	0.24	0.24	0.20	0.19	0.22	0.24	0.24	0.25	0.23	0.23	0.24	0.25	0.21	0.22	0.21	0.21	0.20	0.17	0.14	0.21
62	0.26	nd	nd	nd	nd	0.25	0.24	0.24	0.24	0.26	0.26	0.27	0.25	0.26	0.27	0.24	0.22	0.22	0.23	0.24	0.20	0.16	0.15	0.24	
63	0.30	nd	nd	nd	nd	0.29	0.28	0.26	0.29	0.27	0.31	0.29	0.30	0.29	0.29	0.29	0.26	0.28	0.28	0.25	0.23	0.19	0.17	0.26	
64	nd	nd	nd	nd	nd	0.30	0.30	0.30	0.32	0.36	0.32	0.33	0.33	0.32	0.31	0.32	0.29	0.28	0.25	0.25	0.25	0.21	0.18	0.25	
65	0.37	nd	nd	nd	nd	0.33	0.32	0.31	0.34	0.35	0.37	0.36	0.36	0.36	0.37	0.36	0.31	0.31	0.29	0.30	0.27	0.20	0.18	0.26	
66	nd	nd	nd	nd	nd	0.36	0.35	0.33	0.37	0.39	0.39	0.39	0.38	0.39	0.39	0.36	0.32	0.30	0.32	0.33	0.29	0.20	0.20	0.29	
67	0.33	nd	0.28	nd	nd	0.38	0.38	0.33	0.33	0.38	0.37	0.39	0.39	0.39	0.38	0.36	0.34	0.35	0.33	0.30	0.29	0.23	0.20	0.29	
68	nd	nd	nd	nd	nd	nd	0.37	0.35	0.33	0.36	0.38	0.38	0.38	0.40	0.39	0.36	0.33	0.33	0.32	0.27	0.26	0.21	0.18	0.29	
69	nd	nd	nd	nd	nd	0.36	0.36	0.34	0.35	0.37	0.38	0.39	0.40	0.41	0.41	0.38	0.33	0.32	0.28	0.33	0.27	0.21	0.20	0.30	
70	nd	nd	nd	nd	nd	nd	0.40	0.36	nd	0.37	0.38	0.39	0.41	0.40	0.41	0.39	0.34	0.35	0.28	0.31	nd	0.20	0.19	0.28	
71	nd	nd	nd	nd	nd	nd	0.37	0.41	0.41	0.41	0.41	0.42	0.42	0.41	0.38	0.35	0.30	0.32	0.34	0.28	nd	nd	0.30	nd	
72	nd	nd	nd	nd	nd	nd	0.36	0.41	0.43	0.41	0.41	0.41	0.42	0.43	0.39	0.37	0.34	0.39	0.35	0.31	nd	nd	nd	nd	
73	nd	nd	nd	nd	nd	nd	nd	nd	0.42	0.44	0.43	0.43	0.44	0.43	0.43	0.40	0.33	0.35	0.35	nd	nd	nd	nd	nd	
74	nd	nd	nd	nd	nd	nd	nd	nd	0.42	nd	nd	0.47	0.44	0.44	0.42	0.39	0.38	0.40	nd	nd	nd	nd	nd	nd	
75	nd	nd	nd	nd	nd	nd	nd	nd	0.41	0.45	0.47	0.46	0.48	0.44	0.45	0.42	0.38	0.38	nd	nd	nd	nd	nd	nd	
76	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.47	0.47	0.49	0.49	0.49	0.47	0.42	0.41	nd	nd	nd	nd	nd	nd	nd	
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.47	0.47	0.48	0.47	0.50	0.47	0.45	0.38	nd	nd	nd	nd	nd	nd	nd	
78	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.52	0.49	0.52	0.52	0.48	0.43	nd	nd	nd	nd	nd	nd	nd	nd	nd	
79	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.48	0.49	nd	0.50	0.51	0.48	nd	nd	nd	nd	nd	nd	nd	nd	nd	
80	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.42	nd	nd	nd	nd	nd	nd	nd	nd	nd	
81	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.50	0.51	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	
82	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.54	nd	nd	nd	nd	nd	nd	nd	nd	nd	



Non-Coastal College

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
43	nd	nd	nd	nd	nd	nd	nd	0.14	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
44	0.16	nd	nd	nd	nd	nd	0.15	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
45	nd	0.12	0.15	0.15	0.19	0.15	0.19	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
46	nd	nd	0.07	0.13	nd	0.02	0.05	0.09	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
47	nd	nd	0.13	0.10	0.09	0.22	0.13	0.19	0.17	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
48	nd	0.16	0.11	0.12	0.13	0.16	0.17	nd	0.15	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
49	0.02	0.08	0.09	0.12	0.20	0.16	0.19	0.17	0.02	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.15
50	0.16	0.15	0.23	0.14	0.16	0.19	0.18	0.17	0.13	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.09	0.02
51	0.10	0.17	0.15	0.17	0.17	0.14	0.15	0.16	0.24	0.16	nd	nd	nd	nd	0.15	nd	nd	nd	nd	nd	0.08	0.06	0.04	0.02
52	0.15	0.14	0.14	0.19	0.17	0.14	0.16	0.15	0.23	0.19	0.13	nd	nd	nd	nd	nd	nd	nd	nd	0.07	0.12	0.07	0.06	0.13
53	0.19	0.20	0.20	0.18	0.19	0.19	0.19	0.16	0.22	0.17	0.14	nd	nd	nd	nd	nd	nd	0.02	0.11	0.09	0.06	0.11	0.09	0.15
54	0.18	0.15	0.14	0.19	0.19	0.19	0.18	0.15	0.13	0.20	nd	0.11	nd	nd	nd	nd	nd	0.06	0.20	0.12	0.10	0.13	0.12	0.16
55	0.19	0.20	0.20	0.19	0.19	0.22	0.17	0.16	0.16	0.16	0.21	nd	0.15	nd	nd	0.02	0.09	0.14	0.14	0.12	0.14	0.16	0.13	0.17
56	0.21	0.21	0.18	0.20	0.23	0.21	0.19	0.22	0.18	0.20	0.14	nd	0.02	0.11	0.07	0.09	0.09	0.17	0.12	0.16	0.15	0.14	0.11	0.24
57	0.20	0.20	0.18	0.19	0.21	0.21	0.20	0.19	0.22	0.20	0.19	0.19	0.12	0.10	0.14	0.16	0.12	0.13	0.10	0.16	0.17	0.15	0.14	0.19
58	0.21	0.20	0.20	0.19	0.22	0.23	0.25	0.23	0.19	0.20	0.16	0.15	0.16	0.16	0.12	0.14	0.12	0.17	0.15	0.17	0.17	0.17	0.13	0.22
59	0.22	0.21	0.20	0.21	0.23	0.24	0.24	0.26	0.26	0.24	0.22	0.21	0.19	0.19	0.16	0.17	0.19	0.15	0.16	0.20	0.18	0.18	0.13	0.18
60	0.22	0.21	0.22	0.23	0.28	0.30	0.25	0.22	0.24	0.24	0.21	0.20	0.19	0.32	0.17	0.13	0.15	0.17	0.20	0.20	0.19	0.13	0.13	0.21
61	0.24	0.24	0.24	0.25	0.28	0.31	0.31	0.26	0.28	0.26	0.23	0.18	0.20	0.20	0.19	0.20	0.18	0.18	0.21	0.21	0.21	0.20	0.16	0.23
62	0.26	0.26	0.25	0.27	0.31	0.31	0.34	0.27	0.27	0.36	0.27	0.24	0.20	0.18	0.18	0.17	0.22	0.22	0.23	0.24	0.25	0.17	0.17	0.24
63	0.30	0.28	0.27	0.28	0.32	0.37	0.37	0.34	0.33	0.30	0.28	0.27	0.19	0.22	0.20	0.22	0.23	0.24	0.21	0.25	0.26	0.19	0.17	0.27
64	0.30	0.29	0.30	0.30	0.35	0.42	0.41	0.36	0.38	0.36	0.34	0.28	0.23	0.22	0.20	0.24	0.27	0.24	0.28	0.27	0.27	0.22	0.20	0.27
65	0.31	0.30	0.30	0.31	0.38	0.45	0.44	0.40	0.39	0.34	0.37	0.32	0.29	0.26	0.26	0.26	0.27	0.27	0.26	0.33	0.31	0.23	0.20	0.29
66	0.32	0.30	0.31	0.33	0.41	0.50	0.45	0.42	0.40	0.43	0.40	0.29	0.32	0.29	0.27	0.27	0.23	0.28	0.30	0.33	0.28	0.22	0.20	0.30
67	0.33	0.33	0.31	0.33	0.38	0.48	0.50	0.47	0.45	0.42	0.38	0.39	0.33	0.30	0.28	0.33	0.31	0.30	0.41	0.35	0.31	0.23	0.21	0.31
68	0.35	0.32	0.34	0.33	0.39	0.51	0.48	0.47	0.46	0.43	0.40	0.40	0.43	0.32	0.30	0.29	0.26	0.39	0.37	0.35	0.34	0.23	0.23	0.33
69	0.34	0.36	0.35	0.36	0.43	0.24	0.48	0.49	0.46	0.48	0.48	0.43	0.40	0.41	0.39	0.38	0.32	0.38	0.37	0.35	0.29	0.25	0.22	0.34
70	nd	nd	0.35	nd	nd	0.57	0.60	0.51	nd	0.50	0.42	0.45	0.37	0.39	0.38	0.41	0.33	0.41	0.37	0.36	0.35	0.25	0.23	0.29
71	0.36	0.35	nd	nd	nd	nd	nd	0.53	0.53	0.51	0.45	0.45	0.47	0.43	0.41	0.41	0.39	0.39	0.38	0.36	0.34	0.24	0.23	0.33
72	nd	nd	nd	nd	nd	nd	nd	0.50	0.52	0.43	0.47	0.44	0.49	0.47	0.49	0.41	0.41	0.39	0.34	0.37	0.30	nd	nd	nd
73	0.37	nd	0.36	0.37	0.45	0.53	0.57	0.57	0.51	0.54	0.52	0.46	0.48	0.52	0.52	0.50	0.40	0.40	0.40	0.36	nd	0.24	0.22	0.33
74	nd	nd	nd	nd	nd	nd	nd	nd	0.65	0.58	0.59	0.53	0.47	0.46	0.54	0.48	0.40	0.40	0.37	nd	nd	nd	nd	nd
75	nd	nd	nd	nd	nd	nd	nd	nd	0.58	0.57	0.53	0.54	0.52	0.54	0.53	0.51	0.40	0.40	0.36	0.40	0.37	0.24	nd	nd
76	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.67	0.55	0.49	0.50	0.47	0.51	0.50	0.44	0.45	0.38	0.41	0.32	nd	nd	nd
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.60	0.60	0.55	0.54	0.51	0.52	0.53	0.41	0.36	0.30	nd	nd	nd	nd	nd
78	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.57	0.56	0.54	0.49	0.58	0.55	0.54	0.41	0.46	0.43	nd	nd	nd	nd	nd
79	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.64	0.62	0.59	0.59	0.60	0.56	0.47	0.49	nd	nd	nd	nd	nd	nd
80	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.68	0.63	0.65	0.62	0.61	0.49	nd	nd	nd	nd	nd	nd	nd
81	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.65	nd	0.69	0.68	0.67	0.63	nd	0.45	nd	nd	nd	nd	nd	nd
82	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.59	nd	0.64	0.69	nd	nd	nd	nd	nd	nd	nd	nd	nd
83	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.67	0.64	0.66	0.68	nd	nd	nd	nd	nd	nd	nd	nd	nd

Coastal Health

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
44	nd	nd	nd	nd	nd	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
45	nd	nd	nd	0.00	0.00	nd	nd	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
46	nd	nd	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
47	nd	0.00	0.00	nd	nd	nd	nd	0.00	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
48	nd	0.00	nd	nd	0.00	0.00	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.00
49	0.00	0.00	nd	0.00	0.00	0.00	0.00	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
50	0.00	nd	0.00	0.00	0.00	0.00	0.03	0.04	0.04	0.12	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.15	nd
51	0.09	0.08	0.06	0.12	0.09	0.00	0.07	0.09	0.09	0.23	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.17	nd	nd	0.00	0.00
52	0.08	0.12	0.20	0.06	0.10	0.16	0.06	0.05	0.12	0.14	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.12	0.18	0.24	0.12
53	0.15	0.15	0.14	0.19	0.18	0.14	0.07	0.17	0.23	0.25	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.15	nd	0.21	0.15	0.14
54	0.15	0.21	0.16	0.18	0.18	0.21	0.18	0.21	0.22	nd	0.28	nd	nd	nd	nd	nd	nd	nd	0.30	0.24	0.23	0.20	0.19	0.18
55	0.22	0.22	0.22	0.22	0.22	0.25	0.23	0.25	0.26	0.27	0.28	nd	nd	nd	nd	nd	nd	0.25	0.26	0.25	0.26	0.22	0.23	0.22
56	0.22	0.23	0.22	0.22	0.24	0.23	0.25	0.26	0.27	0.28	0.27	nd	nd	nd	nd	nd	0.25	0.29	0.28	0.26	0.25	0.26	0.24	0.23
57	0.23	0.23	0.24	0.25	0.23	0.26	0.26	0.28	0.28	0.31	0.31	0.31	0.32	0.29	0.28	0.27	0.28	0.26	0.31	0.27	0.25	0.26	0.25	0.24
58	0.25	0.27	nd	0.26	0.26	0.28	0.29	0.29	0.30	0.31	0.30	0.30	0.31	0.30	0.29	0.31	nd	0.29	0.31	0.29	0.29	0.27	0.26	0.25
59	0.27	0.27	0.26	0.27	0.27	0.28	0.30	0.32	0.32	0.34	0.33	0.34	0.31	0.32	0.32	0.35	0.33	0.34	0.33	0.30	0.30	0.29	0.29	0.28
60	0.30	0.31	0.30	0.34	0.35	0.32	0.32	0.33	0.33	0.36	0.36	0.34	0.33	0.36	0.37	0.36	0.37	0.33	0.35	0.33	0.33	0.32	0.31	0.30
61	0.32	0.34	nd	nd	0.34	0.36	0.37	0.38	0.37	0.37	0.39	0.39	0.38	0.41	0.41	0.41	0.36	0.38	0.41	0.35	0.36	0.35	0.34	0.33
62	0.37	nd	nd	nd	nd	0.41	0.44	0.45	0.39	0.41	0.41	0.41	0.40	0.41	0.42	0.42	0.40	0.41	0.43	0.41	0.41	0.40	0.39	0.37
63	0.45	nd	nd	nd	nd	0.48	0.53	0.49	0.47	0.43	0.46	0.46	0.47	0.48	0.49	0.49	0.47	0.49	0.49	0.46	0.46	0.46	0.45	0.45
64	nd	nd	nd	nd	nd	0.52	0.59	0.60	0.52	0.56	0.51	0.50	0.50	0.52	0.51	0.51	0.53	0.52	0.53	0.50	0.53	0.52	0.52	0.50
65	0.59	nd	nd	nd	nd	0.58	0.66	0.65	0.62	0.61	0.59	0.56	0.56	0.58	0.60	0.62	0.60	0.59	0.60	0.59	0.63	0.60	0.57	0.57
66	nd	nd	nd	nd	nd	0.65	0.73	0.72	0.70	0.69	0.68	0.66	0.64	0.65	0.68	0.65	0.64	0.67	0.65	0.70	0.67	0.64	0.63	0.62
67	0.61	nd	0.70	nd	nd	0.72	0.82	0.77	0.75	0.71	0.70	0.73	0.71	0.73	0.72	0.73	0.72	0.75	0.77	0.74	0.72	0.72	0.70	0.71
68	nd	nd	nd	nd	nd	nd	0.89	0.91	0.79	0.78	0.78	0.74	0.77	0.78	0.81	0.79	0.79	0.81	0.81	0.77	0.78	0.76	0.72	0.75
69	nd	nd	nd	nd	nd	0.78	0.89	0.96	0.87	0.84	0.83	0.85	0.85	0.86	0.89	0.87	0.87	0.93	0.86	0.88	0.86	0.87	0.91	0.81
70	nd	nd	nd	nd	nd	nd	0.97	0.98	nd	0.88	0.91	0.94	0.92	0.94	0.93	0.91	0.98	0.97	0.93	0.97	nd	0.83	0.81	0.80
71	nd	nd	nd	nd	nd	nd	1.00	1.02	1.02	0.97	0.95	0.99	0.98	0.98	1.00	0.99	0.97	1.05	1.01	0.98	0.91	nd	nd	0.84
72	nd	nd	nd	nd	nd	nd	nd	0.98	1.03	1.08	1.02	1.07	1.11	1.10	1.07	1.06	1.08	1.10	1.10	0.99	nd	nd	nd	nd
73	nd	nd	nd	nd	nd	nd	nd	nd	1.11	1.13	1.16	1.18	1.11	1.13	1.13	1.10	1.13	1.21	1.12	nd	nd	nd	nd	nd
74	nd	nd	nd	nd	nd	nd	nd	nd	1.15	nd	nd	1.13	1.16	1.20	1.14	1.19	1.22	1.22	nd	nd	nd	nd	nd	nd
75	nd	nd	nd	nd	nd	nd	nd	nd	1.13	1.21	1.23	1.24	1.27	1.18	1.26	1.26	1.30	1.27	nd	nd	nd	nd	nd	nd
76	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.28	1.32	1.34	1.32	1.38	1.24	1.35	1.31	nd	nd	nd	nd	nd	nd	nd
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.30	1.33	1.28	1.40	1.37	1.41	1.43	1.44	nd	nd	nd	nd	nd	nd	nd
78	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.59	1.46	1.46	1.45	1.53	1.48	nd	nd	nd	nd	nd	nd	nd	nd
79	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.40	1.43	nd	1.52	1.59	1.58	nd	nd	nd	nd	nd	nd	nd	nd
80	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.53	nd	nd	nd	nd	nd	nd	nd	nd
81	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.52	1.58	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
82	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.76	nd	nd	nd	nd	nd	nd	nd	nd	nd

Non-Coastal Health

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
43	nd	nd	nd	nd	nd	nd	nd	0.39	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
44	0.30	nd	nd	nd	nd	nd	0.37	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
45	0.32	0.22	0.31	0.31	0.33	0.33	0.41	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
46	nd	nd	0.00	0.25	nd	0.00	0.12	0.27	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
47	nd	nd	0.16	0.16	0.13	0.46	0.31	0.30	0.37	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
48	nd	0.25	0.17	0.21	0.09	0.26	0.22	nd	0.38	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
49	0.00	0.11	0.16	0.17	0.32	0.26	0.36	0.41	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.29
50	0.27	0.21	0.38	0.30	0.26	0.38	0.37	0.42	0.38	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.20
51	0.13	0.18	0.23	0.25	0.30	0.29	0.36	0.37	0.45	0.34	nd	nd	nd	nd	0.35	nd	nd	nd	nd	nd	0.15	0.11	0.06	0.04
52	0.21	0.25	0.22	0.35	0.29	0.28	0.38	0.44	0.47	0.37	0.17	nd	nd	nd	nd	nd	nd	nd	nd	0.10	0.20	0.13	0.10	0.19
53	0.28	0.31	0.35	0.33	0.35	0.39	0.44	0.39	0.43	0.36	0.18	nd	nd	nd	nd	nd	nd	0.15	0.23	0.19	0.11	0.19	0.26	0.23
54	0.30	0.25	0.27	0.34	0.34	0.39	0.40	0.39	0.30	0.38	nd	0.17	nd	nd	nd	nd	0.14	0.23	0.31	0.30	0.27	0.31	0.29	0.31
55	0.31	0.34	0.34	0.35	0.34	0.39	0.39	0.43	0.37	0.31	0.37	nd	0.33	nd	nd	nd	0.14	0.23	0.31	0.30	0.27	0.31	0.35	0.31
56	0.35	0.35	0.33	0.37	0.39	0.38	0.42	0.50	0.40	0.40	0.34	nd	0.00	0.23	0.22	0.23	0.24	0.37	0.30	0.28	0.32	0.33	0.30	0.38
57	0.35	0.36	0.35	0.35	0.37	0.42	0.44	0.46	0.48	0.40	0.41	0.43	0.27	0.18	0.28	0.37	0.20	0.21	0.25	0.31	0.36	0.32	0.36	0.32
58	0.37	0.34	0.38	0.35	0.39	0.41	0.53	0.53	0.41	0.44	0.28	0.35	0.38	0.34	0.37	0.21	0.29	0.27	0.38	0.33	0.34	0.36	0.35	0.38
59	0.39	0.39	0.37	0.39	0.39	0.46	0.53	0.61	0.51	0.44	0.43	0.43	0.44	0.50	0.33	0.38	0.40	0.36	0.38	0.40	0.38	0.39	0.36	0.34
60	0.38	0.38	0.41	0.43	0.52	0.58	0.50	0.53	0.50	0.48	0.43	0.40	0.40	0.53	0.41	0.31	0.34	0.36	0.42	0.40	0.37	0.34	0.35	0.40
61	0.42	0.46	0.47	0.48	0.49	0.58	0.67	0.57	0.58	0.50	0.44	0.41	0.42	0.41	0.43	0.46	0.40	0.38	0.44	0.42	0.43	0.50	0.46	0.44
62	0.50	0.53	0.54	0.55	0.57	0.59	0.71	0.56	0.53	0.64	0.48	0.46	0.39	0.36	0.40	0.41	0.41	0.43	0.47	0.47	0.56	0.46	0.55	0.44
63	0.65	0.61	0.60	0.60	0.61	0.69	0.80	0.77	0.64	0.56	0.54	0.52	0.40	0.42	0.40	0.42	0.44	0.49	0.46	0.55	0.55	0.52	0.56	0.65
64	0.66	0.65	0.70	0.69	0.76	0.89	0.96	0.76	0.79	0.68	0.59	0.52	0.48	0.43	0.44	0.49	0.51	0.49	0.64	0.58	0.60	0.64	0.66	0.62
65	0.76	0.77	0.75	0.75	0.81	0.87	0.97	1.00	0.76	0.63	0.65	0.57	0.53	0.48	0.49	0.47	0.56	0.59	0.56	0.63	0.76	0.79	0.77	0.75
66	0.85	0.84	0.83	0.86	0.92	1.22	0.95	1.05	0.93	0.84	0.76	0.50	0.57	0.54	0.50	0.53	0.50	0.59	0.62	0.75	0.69	0.74	0.77	0.82
67	0.91	0.89	0.78	0.83	0.85	0.95	1.15	1.29	1.08	0.90	0.70	0.72	0.57	0.54	0.56	0.63	0.67	0.65	0.89	0.79	0.88	0.82	0.94	0.93
68	0.90	0.86	0.91	0.81	0.84	0.79	1.08	1.02	1.09	0.83	0.77	0.71	0.87	0.60	0.55	0.61	0.59	0.81	0.83	0.90	0.94	1.01	1.03	1.01
69	0.83	0.84	0.87	0.82	0.88	0.54	0.92	1.20	1.06	1.10	0.90	0.84	0.74	0.77	0.76	0.78	0.71	0.82	0.87	1.02	1.00	1.20	1.02	0.98
70	nd	nd	0.73	nd	nd	1.29	1.49	1.37	nd	1.11	0.89	0.88	0.70	0.74	0.77	0.84	0.74	0.96	0.94	1.03	1.25	1.12	1.02	0.64
71	0.79	0.76	nd	nd	nd	nd	1.33	1.29	1.08	0.92	0.91	0.92	0.83	0.84	0.86	0.88	0.88	0.97	1.04	1.05	1.14	0.97	1.06	0.94
72	nd	nd	nd	nd	nd	nd	0.89	1.06	0.87	1.05	0.96	0.92	0.94	0.95	0.87	1.11	1.06	1.01	1.34	1.04	nd	nd	nd	nd
73	0.83	nd	0.80	0.81	0.91	1.04	1.31	1.49	1.23	1.32	1.19	1.01	1.05	1.08	1.14	1.12	1.14	1.15	1.20	1.10	nd	1.06	0.95	0.91
74	nd	nd	nd	nd	nd	nd	nd	nd	1.83	1.32	1.65	1.25	1.07	0.99	1.20	1.19	1.12	1.10	1.11	nd	nd	nd	nd	nd
75	nd	nd	nd	nd	nd	nd	nd	nd	1.45	1.41	1.17	1.23	1.26	1.27	1.28	1.32	1.24	1.29	1.24	1.28	1.23	1.17	nd	nd
76	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.96	1.33	1.21	1.24	1.20	1.25	1.35	1.11	1.34	1.38	1.34	1.29	nd	nd	nd
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.56	1.52	1.41	1.43	1.40	1.45	1.33	1.50	1.36	1.34	nd	nd	nd	nd	nd
78	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.39	1.44	1.45	1.43	1.47	1.54	1.58	1.52	1.51	1.36	nd	nd	nd	nd	nd
79	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.74	1.63	1.56	1.57	1.63	1.60	1.56	1.52	nd	nd	nd	nd	nd	nd	nd
80	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.91	1.67	1.71	1.66	1.69	1.69	nd	nd	nd	nd	nd	nd	nd	nd
81	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.67	nd	1.82	1.74	1.75	1.78	nd	1.57	nd	nd	nd	nd	nd	nd
82	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.60	nd	1.68	1.74	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
83	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.77	1.78	1.76	1.86	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd

Coastal Hotel

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
44	nd	nd	nd	nd	nd	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
45	nd	nd	nd	0.00	0.00	nd	nd	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
46	nd	nd	0.00	nd	nd	nd	nd	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
47	nd	0.00	0.00	nd	nd	0.00	0.00	0.00	0.02	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
48	nd	0.08	nd	nd	0.00	0.04	0.04	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.06
49	0.05	0.00	0.00	0.04	0.07	0.05	0.03	0.03	0.02	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
50	0.00	0.08	0.04	0.06	0.07	0.08	0.06	0.08	0.03	0.08	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.08	0.06
51	0.09	0.08	0.08	0.08	0.08	0.08	0.10	0.08	0.06	0.08	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.08	nd	0.07	0.07	0.07
52	0.09	0.09	0.09	0.08	0.08	0.09	0.10	0.09	0.08	0.08	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.07	0.07	0.08	0.06
53	0.10	0.09	0.08	0.08	0.09	0.10	0.11	0.10	0.11	0.10	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.07	0.08	0.08	0.08	0.08
54	0.11	0.10	0.10	0.09	0.09	0.11	0.11	0.11	0.09	0.09	0.11	nd	nd	nd	nd	nd	nd	nd	0.11	0.08	0.08	0.09	0.09	0.09
55	0.12	0.11	0.10	0.09	0.10	0.12	0.13	0.12	0.11	0.10	0.10	nd	nd	nd	0.10	nd	nd	0.10	0.08	0.09	0.10	0.10	0.10	0.09
56	0.13	0.13	0.12	0.12	0.12	0.13	0.15	0.14	0.13	0.13	0.12	0.10	nd	nd	nd	nd	0.11	0.11	0.09	0.11	0.11	0.11	0.12	0.10
57	0.16	0.14	0.12	0.13	0.13	0.16	0.18	0.16	0.15	0.14	0.15	0.13	0.13	0.13	0.15	0.13	0.13	0.10	0.12	0.11	0.12	0.12	0.13	0.12
58	0.17	0.15	0.14	0.13	0.13	0.18	0.19	0.17	0.16	0.15	0.14	0.15	0.14	0.13	0.13	0.14	nd	0.13	0.12	0.13	0.13	0.13	0.14	0.13
59	0.17	0.15	0.14	0.14	0.13	0.17	0.18	0.17	0.16	0.15	0.15	0.16	0.14	0.14	0.15	0.15	0.15	0.16	0.13	0.12	0.13	0.13	0.14	0.13
60	0.18	0.19	0.14	0.16	0.16	0.18	0.18	0.17	0.17	0.16	0.16	0.15	0.15	0.15	0.16	0.15	0.14	0.15	0.13	0.13	0.13	0.13	0.14	0.13
61	0.18	0.16	0.16	nd	0.16	0.19	0.20	0.18	0.18	0.16	0.16	0.16	0.15	0.16	0.15	0.16	0.16	0.15	0.14	0.13	0.14	0.14	0.14	0.13
62	0.18	0.15	nd	nd	nd	0.20	0.22	0.20	0.18	0.16	0.16	0.16	0.16	0.16	0.17	0.17	0.17	0.16	0.14	0.15	0.15	0.15	0.15	0.14
63	0.20	nd	nd	nd	nd	0.21	0.24	0.21	0.21	0.18	0.19	0.18	0.19	0.20	0.19	0.19	0.19	0.20	0.17	0.18	0.18	0.18	0.17	0.16
64	nd	nd	nd	nd	nd	0.22	0.24	0.23	0.22	0.22	0.20	0.20	0.21	0.21	0.20	0.21	0.22	0.21	0.19	0.21	0.22	0.20	0.20	0.17
65	0.21	nd	nd	nd	nd	0.22	0.24	0.25	0.24	0.24	0.23	0.23	0.23	0.23	0.25	0.26	0.27	0.24	0.26	0.28	0.30	0.26	0.24	0.19
66	nd	nd	nd	nd	nd	0.23	0.27	0.28	0.27	0.28	0.28	0.28	0.28	0.29	0.30	0.32	0.32	0.28	0.33	0.36	0.36	0.34	0.28	0.21
67	0.20	nd	0.21	nd	nd	0.26	0.32	0.32	0.31	0.30	0.32	0.34	0.32	0.36	0.36	0.36	0.38	0.37	0.38	0.44	0.44	0.41	0.36	0.32
68	nd	nd	nd	nd	nd	nd	0.40	0.44	0.34	0.36	0.37	0.37	0.39	0.39	0.42	0.44	0.47	0.42	0.46	0.50	0.53	0.50	0.45	0.39
69	nd	nd	nd	nd	nd	0.56	0.58	0.49	0.42	0.39	0.43	0.45	0.46	0.47	0.48	0.50	0.52	0.52	0.53	0.56	0.61	0.61	0.60	0.47
70	nd	nd	nd	nd	nd	nd	0.78	0.60	nd	0.42	0.48	0.54	0.53	0.54	0.55	0.55	0.60	0.57	0.57	0.65	nd	0.67	0.65	0.57
71	nd	nd	nd	nd	nd	nd	nd	0.62	0.58	0.53	0.56	0.58	0.56	0.59	0.61	0.61	0.63	0.64	0.62	0.75	0.68	nd	nd	0.61
72	nd	nd	nd	nd	nd	nd	nd	0.81	0.64	0.68	0.64	0.63	0.69	0.66	0.65	0.69	0.71	0.70	0.73	0.73	nd	nd	nd	nd
73	nd	nd	nd	nd	nd	nd	nd	0.78	0.78	0.75	0.75	0.72	0.68	0.69	0.72	0.78	0.75	0.75	nd	nd	nd	nd	nd	nd
74	nd	nd	nd	nd	nd	nd	nd	0.92	nd	nd	0.73	0.71	0.78	0.74	0.75	0.81	0.85	nd	nd	nd	nd	nd	nd	nd
75	nd	nd	nd	nd	nd	nd	nd	0.91	0.89	0.86	0.83	0.83	0.74	0.79	0.83	0.88	0.82	nd	nd	nd	nd	nd	nd	nd
76	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.03	0.91	0.91	0.90	0.81	0.80	0.84	0.90	nd	nd	nd	nd	nd	nd	nd
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.00	0.93	0.91	0.87	0.91	0.92	0.93	0.97	nd	nd	nd	nd	nd	nd	nd
78	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.13	1.02	1.04	0.96	0.95	0.93	nd	nd	nd	nd	nd	nd	nd	nd
79	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.06	1.06	nd	0.96	1.11	1.11	nd	nd	nd	nd	nd	nd	nd	nd
80	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.00	nd	nd	nd	nd	nd	nd	nd	nd
81	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.11	1.12	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
82	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.18	nd	nd	nd	nd	nd	nd	nd	nd	nd

Non-Coastal Hotel

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
43	nd	nd	nd	nd	nd	nd	nd	0.23	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
44	0.15	0.14	nd	nd	nd	nd	0.22	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.10
45	0.20	0.14	0.16	0.15	0.19	0.20	0.27	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
46	nd	nd	0.12	0.13	nd	0.08	0.12	0.16	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
47	0.14	nd	0.14	0.10	0.15	0.23	0.24	0.21	0.16	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.10	0.10
48	nd	0.15	0.12	0.15	0.14	0.19	0.16	0.18	0.19	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
49	0.12	0.11	0.14	0.14	0.18	0.17	0.22	0.19	0.13	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.11
50	0.14	0.15	0.16	0.16	0.15	0.22	0.24	0.21	0.19	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.00	0.05	0.09
51	0.11	0.15	0.14	0.16	0.21	0.20	0.26	0.22	0.21	0.17	nd	nd	nd	nd	0.15	nd	nd	nd	nd	0.11	0.05	0.05	0.11	0.08
52	0.15	0.13	0.16	0.19	0.16	0.20	0.24	0.27	0.23	0.18	0.13	nd	nd	nd	nd	nd	nd	nd	nd	0.10	0.06	0.10	0.09	0.09
53	0.17	0.19	0.20	0.19	0.20	0.23	0.28	0.23	0.23	0.19	0.15	nd	0.12	nd	nd	nd	nd	0.03	0.12	0.09	0.11	0.12	0.11	0.11
54	0.18	0.18	0.20	0.21	0.21	0.24	0.25	0.21	0.16	0.20	0.15	0.15	nd	0.13	0.11	0.11	0.14	0.12	0.17	0.11	0.11	0.12	0.13	0.13
55	0.20	0.20	0.19	0.20	0.20	0.23	0.25	0.21	0.20	0.18	0.20	0.14	0.15	0.11	nd	0.00	0.12	0.13	0.11	0.15	0.12	0.13	0.15	0.14
56	0.22	0.22	0.21	0.22	0.24	0.23	0.27	0.28	0.23	0.22	0.18	0.13	0.12	0.13	0.08	0.09	0.09	0.15	0.14	0.13	0.14	0.14	0.14	0.17
57	0.22	0.22	0.22	0.22	0.21	0.24	0.27	0.26	0.26	0.19	0.19	0.22	0.15	0.14	0.14	0.41	0.14	0.13	0.12	0.14	0.16	0.15	0.17	0.16
58	0.23	0.22	0.24	0.22	0.23	0.25	0.33	0.25	0.23	0.22	0.18	0.19	0.22	0.17	0.17	0.13	0.20	0.18	0.14	0.16	0.16	0.17	0.18	0.17
59	0.25	0.26	0.24	0.24	0.25	0.28	0.33	0.33	0.27	0.22	0.23	0.20	0.24	0.25	0.15	0.16	0.20	0.16	0.17	0.17	0.18	0.18	0.18	0.17
60	0.25	0.24	0.25	0.29	0.32	0.38	0.36	0.29	0.29	0.27	0.21	0.21	0.21	0.23	0.23	0.16	0.19	0.20	0.18	0.18	0.18	0.19	0.23	0.22
61	0.28	0.31	0.31	0.32	0.35	0.40	0.40	0.32	0.33	0.28	0.23	0.21	0.22	0.21	0.21	0.23	0.23	0.16	0.19	0.20	0.18	0.18	0.16	0.17
62	0.33	0.35	0.36	0.34	0.33	0.33	0.45	0.34	0.30	0.30	0.26	0.23	0.21	0.20	0.21	0.21	0.27	0.21	0.20	0.19	0.27	0.24	0.30	0.24
63	0.40	0.38	0.37	0.35	0.34	0.40	0.46	0.41	0.35	0.29	0.31	0.26	0.21	0.23	0.20	0.21	0.23	0.25	0.18	0.26	0.30	0.29	0.32	0.36
64	0.44	0.44	0.43	0.41	0.45	0.60	0.58	0.38	0.39	0.41	0.28	0.28	0.28	0.22	0.22	0.23	0.27	0.21	0.29	0.26	0.32	0.30	0.30	0.30
65	0.50	0.48	0.48	0.49	0.54	0.55	0.63	0.57	0.41	0.30	0.33	0.30	0.28	0.24	0.21	0.23	0.27	0.27	0.27	0.22	0.34	0.39	0.42	0.40
66	0.56	0.59	0.55	0.54	0.51	0.62	0.48	0.62	0.51	0.41	0.36	0.26	0.29	0.29	0.27	0.27	0.26	0.30	0.27	0.39	0.39	0.41	0.45	0.48
67	0.62	0.59	0.49	0.51	0.52	0.61	0.73	0.67	0.63	0.49	0.34	0.36	0.31	0.29	0.28	0.33	0.36	0.27	0.46	0.40	0.51	0.47	0.60	0.51
68	0.58	0.55	0.56	0.39	0.46	0.29	0.64	0.62	0.65	0.48	0.42	0.31	0.41	0.29	0.32	0.28	0.30	0.44	0.50	0.51	0.58	0.60	0.65	0.62
69	0.52	0.60	0.61	0.49	0.49	0.16	0.32	0.74	0.62	0.58	0.49	0.45	0.36	0.37	0.34	0.40	0.36	0.44	0.48	0.55	0.55	0.71	0.68	0.55
70	nd	nd	0.25	nd	nd	0.86	1.00	0.88	0.64	0.59	0.53	0.49	0.38	0.38	0.34	0.39	0.37	0.50	0.52	0.54	0.74	0.75	0.65	0.43
71	0.55	0.52	nd	nd	nd	nd	nd	0.84	0.81	0.62	0.50	0.42	0.55	0.43	0.45	0.48	0.52	0.54	0.57	0.62	0.75	0.69	0.65	0.62
72	nd	nd	nd	nd	nd	nd	nd	0.57	0.71	0.61	0.64	0.53	0.49	0.52	0.51	0.43	0.60	0.54	0.53	0.78	0.73	0.62	nd	nd
73	0.66	nd	0.64	0.62	0.73	0.83	0.97	0.99	0.76	0.79	0.69	0.57	0.52	0.58	0.60	0.59	0.60	0.61	0.73	0.76	0.73	0.63	0.71	0.63
74	nd	nd	nd	nd	nd	nd	nd	nd	1.15	0.89	0.97	0.71	0.57	0.58	0.63	0.65	0.64	0.60	0.66	0.73	nd	nd	nd	nd
75	nd	nd	nd	nd	nd	nd	nd	nd	0.96	0.92	0.60	0.69	0.65	0.63	0.65	0.68	0.70	0.71	0.71	0.89	0.90	0.70	nd	nd
76	nd	nd	nd	nd	nd	nd	nd	nd	1.21	0.89	0.69	0.70	0.52	0.59	0.68	0.59	0.93	0.89	0.86	0.76	nd	nd	nd	nd
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.02	1.00	0.81	0.78	0.77	0.75	0.76	0.86	0.87	1.09	nd	nd	nd	nd	nd
78	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.97	1.02	0.99	0.59	0.75	0.69	0.86	0.86	1.01	0.92	nd	nd	nd	nd	nd
79	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.15	1.05	0.95	0.93	0.92	0.84	0.98	1.14	nd	nd	nd	nd	nd	nd	nd
80	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.25	1.15	1.05	0.91	1.17	1.06	nd	nd	nd	nd	nd	nd	nd	nd
81	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.11	nd	1.27	1.26	1.22	1.27	nd	1.06	nd	nd	nd	nd	nd	nd	nd
82	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.19	nd	1.23	1.24	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
83	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.27	1.25	1.36	1.33	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd

Coastal School

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
44	nd	nd	nd	nd	nd	0.01	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
45	nd	nd	nd	0.01	0.01	nd	nd	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
46	nd	nd	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
47	nd	0.01	0.01	nd	nd	nd	0.00	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
48	nd	0.01	nd	nd	0.01	0.01	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.01
49	0.01	0.01	nd	0.01	0.01	0.01	0.00	0.01	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
50	0.01	nd	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.00	nd
51	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.01	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.00	nd	nd	0.00	0.01
52	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.00	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.01	0.01	0.00	0.01
53	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.04	0.01	0.02	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.00	nd	0.00	0.00	0.01
54	0.01	0.01	0.01	0.01	0.01	0.01	0.04	0.05	0.00	nd	0.01	nd	nd	nd	nd	nd	nd	nd	0.06	0.01	0.00	0.00	0.00	0.01
55	0.01	0.01	0.01	0.01	0.01	0.01	0.03	0.05	0.02	0.01	0.03	nd	nd	nd	nd	nd	nd	0.02	0.02	0.02	0.02	0.01	0.01	0.01
56	0.01	0.01	0.01	0.01	0.01	0.01	0.03	0.05	0.03	0.04	0.01	nd	nd	nd	nd	nd	0.03	0.05	0.03	0.01	0.02	0.04	0.03	0.01
57	0.01	0.01	0.01	0.01	0.01	0.01	0.04	0.10	0.06	0.09	0.11	0.08	0.12	0.11	0.09	0.07	0.06	0.04	0.07	0.04	0.02	0.03	0.02	0.01
58	0.01	0.01	nd	0.01	0.01	0.01	0.04	0.08	0.09	0.09	0.09	0.10	0.09	0.14	0.08	0.06	nd	0.06	0.06	0.05	0.05	0.05	0.04	0.01
59	0.01	0.01	0.01	0.01	0.01	0.01	0.04	0.09	0.10	0.14	0.10	0.12	0.12	0.09	0.10	0.13	0.10	0.06	0.06	0.05	0.06	0.05	0.04	0.01
60	0.01	0.01	0.01	0.01	0.01	0.01	0.04	0.13	0.15	0.14	0.16	0.11	0.18	0.19	0.20	0.11	0.09	0.06	0.06	0.07	0.06	0.07	0.05	0.01
61	0.01	0.01	nd	nd	0.01	0.01	0.05	0.13	0.14	0.20	0.19	0.22	0.11	0.20	0.16	0.14	0.11	0.09	0.09	0.08	0.08	0.08	0.04	0.01
62	0.01	nd	nd	nd	nd	0.01	0.07	0.22	0.19	0.20	0.25	0.21	0.23	0.18	0.16	0.12	0.11	0.10	0.10	0.11	0.09	0.09	0.04	0.01
63	0.01	nd	nd	nd	nd	0.01	0.07	0.22	0.28	0.25	0.29	0.27	0.26	0.25	0.22	0.16	0.14	0.14	0.12	0.12	0.12	0.12	0.02	0.01
64	nd	nd	nd	nd	nd	0.01	0.09	0.27	0.31	0.37	0.35	0.33	0.32	0.34	0.28	0.18	0.16	0.13	0.13	0.14	0.14	0.14	0.07	0.01
65	0.01	nd	nd	nd	nd	0.01	0.09	0.31	0.38	0.39	0.41	0.41	0.33	0.36	0.32	0.21	0.18	0.15	0.15	0.16	0.15	0.14	0.00	0.01
66	nd	nd	nd	nd	nd	0.01	0.08	0.24	0.46	0.54	0.50	0.53	0.44	0.42	0.35	0.24	0.21	0.16	0.17	0.19	0.17	0.15	0.05	0.01
67	0.01	nd	nd	nd	nd	nd	0.07	0.23	0.36	0.54	0.58	0.59	0.50	0.52	0.40	0.27	0.23	0.20	0.20	0.20	0.19	0.17	0.00	0.01
68	nd	nd	nd	nd	nd	nd	nd	nd	0.59	0.53	0.57	0.58	0.55	0.58	0.42	0.29	0.24	0.19	0.19	0.21	nd	nd	nd	nd
69	nd	nd	nd	nd	nd	nd	nd	nd	0.41	0.57	0.63	0.63	0.55	0.61	0.47	0.30	0.26	0.22	0.19	0.26	nd	nd	nd	nd
70	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.45	0.68	0.62	0.56	0.50	0.31	0.28	0.22	nd	nd	nd	nd	nd	nd	nd
71	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.51	0.67	0.59	0.58	0.69	0.48	0.33	0.27	0.19	nd	nd	nd	nd	nd	nd
72	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.55	0.82	0.54	0.60	0.47	0.37	0.32	0.24	nd	nd	nd	nd	nd	nd	nd
73	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.54	0.81	0.41	0.29	nd	nd	nd	nd	nd	nd	nd	nd	nd
74	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.68	nd	0.59	0.52	0.38	0.32	nd	nd	nd	nd	nd	nd	nd	nd
75	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.63	0.59	0.41	0.46	0.39	nd	nd	nd	nd	nd	nd	nd	nd	nd
76	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.70	0.58	0.47	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.77	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd

Non-Coastal School

THI	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
43	nd	nd	nd	nd	nd	nd	nd	0.02	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
44	0.00	nd	nd	nd	nd	nd	0.02	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
45	0.00	0.00	0.01	0.01	0.01	0.01	0.14	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
46	nd	nd	0.01	0.01	nd	0.03	0.03	0.06	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
47	nd	nd	0.00	0.00	0.01	0.05	0.07	0.14	0.09	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
48	nd	0.00	0.00	0.00	0.00	0.02	0.07	nd	0.09	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd
49	0.00	0.00	0.01	0.01	0.01	0.02	0.08	0.11	0.00	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.00
50	0.00	0.01	0.01	0.01	0.00	0.01	0.04	0.19	0.01	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.00
51	0.01	0.00	0.01	0.01	0.00	0.02	0.08	0.11	0.21	0.09	nd	nd	nd	nd	0.04	nd	nd	nd	nd	nd	nd	0.00	0.00	0.01
52	0.00	0.00	0.00	0.00	0.01	0.02	0.07	0.18	0.09	0.10	0.00	nd	nd	nd	nd	nd	nd	nd	nd	0.00	0.03	0.01	0.00	0.00
53	0.00	0.00	0.00	0.00	0.00	0.02	0.11	0.16	0.24	0.07	0.07	nd	nd	nd	nd	nd	nd	0.00	0.02	0.03	0.00	0.00	0.01	0.00
54	0.00	0.00	0.00	0.00	0.00	0.02	0.08	0.11	0.02	0.18	nd	0.04	nd	nd	nd	nd	nd	0.00	0.07	0.00	0.00	0.02	0.03	0.00
55	0.00	0.00	0.00	0.00	0.00	0.02	0.09	0.15	0.10	0.14	0.14	nd	0.07	nd	nd	0.00	0.01	0.07	0.00	0.02	0.01	0.05	0.04	0.00
56	0.00	0.00	0.00	0.00	0.00	0.03	0.09	0.20	0.12	0.14	0.04	nd	0.00	0.01	0.00	0.01	0.02	0.05	0.01	0.01	0.03	0.04	0.03	0.00
57	0.00	0.00	0.00	0.00	0.00	0.02	0.09	0.16	0.18	0.14	0.10	0.14	0.04	0.05	0.03	0.09	0.00	0.00	0.00	0.03	0.04	0.05	0.04	0.00
58	0.00	0.00	0.00	0.00	0.00	0.02	0.12	0.20	0.16	0.14	0.11	0.08	0.11	0.05	0.12	0.00	0.00	0.00	0.04	0.04	0.04	0.06	0.03	0.00
59	0.00	0.00	0.00	0.00	0.00	0.02	0.08	0.28	0.20	0.18	0.14	0.17	0.09	0.07	0.10	0.07	0.05	0.03	0.06	0.05	0.05	0.03	0.03	0.00
60	0.00	0.00	0.00	0.00	0.00	0.03	0.09	0.19	0.23	0.22	0.16	0.13	0.08	0.45	0.11	0.04	0.06	0.07	0.05	0.05	0.03	0.04	0.01	0.00
61	0.00	0.00	0.00	0.00	0.00	0.03	0.15	0.27	0.32	0.27	0.18	0.10	0.14	0.14	0.10	0.15	0.05	0.06	0.06	0.06	0.06	0.08	0.02	0.00
62	0.00	0.00	0.00	0.00	0.00	0.03	0.15	0.29	0.26	0.52	0.25	0.18	0.15	0.13	0.16	0.12	0.07	0.09	0.07	0.06	0.10	0.06	0.02	0.00
63	0.00	0.00	0.00	0.00	0.00	0.05	0.17	0.35	0.41	0.37	0.33	0.34	0.18	0.21	0.18	0.14	0.08	0.11	0.06	0.10	0.08	0.07	0.02	0.00
64	0.00	0.01	0.01	0.01	0.01	0.05	0.20	0.37	0.53	0.43	0.46	0.36	0.23	0.19	0.18	0.23	0.13	0.10	0.13	0.11	0.10	0.09	0.03	0.00
65	0.00	0.00	0.01	0.00	0.00	0.09	0.27	0.56	0.54	0.50	0.54	0.49	0.43	0.29	0.30	0.24	0.15	0.14	0.09	0.13	0.12	0.12	0.01	0.00
66	0.00	nd	nd	nd	nd	nd	nd	0.75	nd	0.72	0.70	0.43	0.55	0.40	0.40	0.29	0.13	0.15	0.12	0.14	0.10	0.15	0.08	0.00
67	nd	nd	nd	nd	nd	nd	nd	0.68	0.78	0.66	0.63	0.62	0.51	0.47	0.44	0.44	0.21	0.15	0.19	0.12	0.12	0.07	0.00	0.00
68	nd	nd	nd	nd	nd	nd	nd	nd	0.77	0.58	0.71	0.80	0.78	0.55	0.58	0.48	0.13	0.20	0.15	0.15	0.14	nd	nd	nd
69	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.63	0.98	0.77	0.68	0.77	0.74	0.55	0.18	0.22	0.19	0.17	0.05	nd	nd	nd
70	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.17	0.74	0.99	0.85	0.87	0.76	0.60	0.19	0.26	0.12	0.08	nd	nd	nd	nd
71	nd	nd	nd	nd	nd	nd	nd	nd	0.92	1.14	0.63	1.01	1.06	0.89	0.83	0.70	0.28	0.22	0.13	0.03	nd	nd	nd	nd
72	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.69	0.89	0.98	0.98	1.05	0.75	0.39	0.27	0.06	nd	nd	nd	nd	nd
73	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.29	0.79	0.98	1.20	1.17	0.87	0.31	0.19	0.13	nd	nd	nd	nd	nd
74	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.24	nd	0.98	0.89	1.09	1.27	0.90	0.16	0.17	0.16	nd	nd	nd	nd	nd
75	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.40	1.37	1.10	1.35	1.25	0.90	0.08	0.07	nd	nd	nd	nd	nd	nd	nd
76	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	0.85	0.71	0.96	0.65	0.14	nd	nd	nd	nd	nd	nd	nd	nd
77	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.51	1.36	1.10	1.28	0.59	0.31	nd	nd	nd	nd	nd	nd	nd	nd
78	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.26	nd	1.14	0.50	nd	nd	nd	nd	nd	nd	nd	nd
79	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.28	1.34	1.59	1.19	nd	nd	nd	nd	nd	nd	nd	nd	nd
80	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd	1.55	nd	nd	nd	nd	nd	nd	nd	nd	nd	nd