

Lawrence Berkeley National Laboratory

Lawrence Berkeley National Laboratory

Title

Is CO2 an Indoor Pollutant? Higher Levels of CO2 May Diminish Decision Making Performance

Permalink

<https://escholarship.org/uc/item/6qm6t5zc>

Author

Fisk, William J.

Publication Date

2013-03-25

Peer reviewed



ERNEST ORLANDO LAWRENCE BERKELEY NATIONAL LABORATORY

Is CO₂ an Indoor Pollutant? Higher Levels of CO₂ May Diminish Decision Making Performance

William J. Fisk¹, Usha Satish,² Mark J. Mendell,¹
Toshifumi Hotchi,¹ Douglas Sullivan,¹

¹Indoor Environment Group
Lawrence Berkeley National Laboratory
Berkeley, CA

²State University of New York
Upstate Medical University
Syracuse, NY

March 2013

Funding to Lawrence Berkeley National Laboratory was from the State University of New York Upstate Medical University via contract 600305000 and by the Assistant Secretary for Energy Efficiency and Renewable Energy, Building Technologies Program of the U.S. Department of Energy under contract DE-AC02-05CH11231. Funding to the State University of New York was provided by Collaborative Activities for Research and Technology Innovation (CARTI), which supports research in the areas of air quality and water resource management. CARTI, part of the Syracuse Center of Excellence located in Syracuse, New York, is supported by the U.S. Environmental Protection Agency under award EM-83340401-0.

Disclaimer

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Ernest Orlando Lawrence Berkeley National Laboratory is an equal opportunity employer.

Is CO₂ an Indoor Pollutant? Higher Levels of CO₂ May Diminish Decision Making Performance

William J. Fisk¹, Usha Satish,² Mark J. Mendell,¹ Toshifumi Hotchi,¹ Douglas Sullivan,¹

¹Indoor Environment Group, Lawrence Berkeley National Laboratory, Berkeley, CA

²State University of New York Upstate Medical University, Syracuse, NY

Because humans produce and exhale carbon dioxide (CO₂), concentrations of CO₂ in occupied indoor spaces are higher than concentrations outdoors. As the outdoor air ventilation rate per person decreases, the magnitude of the indoor-outdoor difference in CO₂ concentration increases.

Prior research has found that with higher indoor levels of CO₂, indicating less outdoor air ventilation per person, people tend to be less satisfied with indoor air quality, report more acute health symptoms (e.g., headache, mucosal irritation), work slightly slower, and are more often absent from work or school. It has been widely believed that these associations exist only because the higher indoor CO₂ concentrations occur at lower outdoor air ventilation rates and are, therefore, correlated with higher levels of other indoor-generated pollutants that directly cause the adverse effects. Thus CO₂ in the range of concentrations found in buildings (i.e., up to 5,000 ppm, but more typically in the range of 1000 ppm) has been assumed to have no direct effect on occupants' perceptions, health, or work performance. A small study from Hungary¹ cast doubts about this assumption. The authors reported that controlled human exposures to CO₂ between 2,000 ppm and 5,000 ppm, with outdoor air ventilation rates unchanged, had subtle adverse impacts on proofreading of text in some trials, but the brief reports in conference proceedings provided limited details. These results from Hungary stimulated our effort to evaluate effects of variation in CO₂ alone on potentially more sensitive high-level cognitive functioning. We investigated a hypothesis that higher concentrations of CO₂, within the range found in buildings, and without changes in outdoor air ventilation rate, have detrimental effects on occupants' decision-making.

To test this hypothesis, 22 subjects completed tests of decision making performance when exposed to low, medium, and high CO₂ concentrations for 2.5 h periods in an exposure chamber. During sessions with low CO₂, subjects and outdoor air were the only sources of CO₂, and measured CO₂ concentrations were approximately 600 ppm. In sessions with CO₂ at the medium and high levels, 99.9999% pure CO₂ was added to the chamber supply air at the rate needed to increase the CO₂ concentration to either 1,000 or 2,500 ppm. All other conditions (e.g., ventilation rate, temperature) remained unchanged. Each subject experienced all three CO₂ conditions on the same day and the order of sessions (low, medium, high; medium, low, high; etc.) was varied, as needed, among the subjects to cancel out effects of order of exposure. Three different versions of the decision making test were employed in a manner such that findings were not affected by differences in test difficulty. Subjects were not informed of the CO₂ conditions.

Performance in decision making was evaluated using the Strategic Management Simulation (SMS) designed to assess complex cognitive functioning. The parameters of decision making determine day to day productivity and are important for overall functioning. SMS users are

exposed to diverse computer-generated real-world-equivalent scenarios that match real-world day-to-day challenges and convey their decisions through a computer interface. The validated measures of task performance vary from relatively simple competencies such as activity and task orientation, through intermediate level capabilities such as initiative and use of information, to highly complex thought and action processes such as breadth of approach to problems and strategy. SMS scores predict real-world success as judged by peers and as demonstrated by income, job level, promotions, level in organizations. In other words, the SMS assesses capacities required for day to day routine tasks as well as higher level decisions people make at home and work. The SMS, described in greater detail in the numerous documents cited in reference 2, is available for research through the State University of New York, Upstate Medical University.

The main results are depicted in Figure 1. The data indicate that at 1,000 ppm CO₂, relative to 600 ppm, there were moderate and statistically significant decrements in six of nine scales of decision-making performance. At 2,500 ppm, large and statistically significant reductions occurred in seven scales of decision-making performance, but a small increase in performance was seen in the focused activity scale. For some scales of performance, the reductions were dramatic. More details are provided in reference 2.




Figure 1. Impact of CO₂ on Human Decision-Making Performance. Error bars indicate one standard deviation

The real-world significance of our findings depend upon the extent to which CO₂ concentrations are at or above 1,000 and 2,500 ppm in current or future buildings. In surveys of elementary school classrooms in California³ and Texas⁴, average CO₂ concentrations were above 1,000 ppm, a substantial proportion exceeded 2,000 ppm, and in 21% of Texas classrooms peak CO₂ concentration exceeded 3,000 ppm. In a representative survey of 100 U.S. offices (Persily and Gorfain 2008), only 5% of the measured peak indoor CO₂ concentrations exceeded 1,000 ppm,

assuming an outdoor concentration of 400 ppm. A very small study suggests that meeting rooms in offices, where important decisions are sometimes made, can have elevated CO₂ concentrations.

The dramatic direct influence of CO₂ on decision making performance was unexpected and the study needs to be replicated. The findings of this study, if replicated, have implications for the standards that specify minimum ventilation rates in buildings, and indicate the need to adhere more consistently to the existing standards. Many of the elevated CO₂ concentrations observed in practice are a consequence of a failure to supply the amount of outdoor air specified in current standards; however, even the minimum ventilation rates in ASHRAE Standard 62.1⁶ correspond to CO₂ concentrations above 1000 ppm in densely occupied spaces. There is a current interest in reducing ventilation rates to save energy and reduce energy costs. Yet large reductions in ventilation rates could lead to increased CO₂ concentrations that adversely affect decision-making performance, even when indoor air concentrations of other air pollutants are maintained low through implementation of pollutant source control measures or application of gas-phase air cleaning systems.

References

1. Kajtar, L., Herczeg, L., Lang, E., Hrustinzky, T. and Banhidi, L. (2006) Influence of carbon dioxide pollutant on human well being and work intensity, *Healthy Buildings 2006*, Vol. 1, Lisbon, Portugal, 85-90.
2. Satish, U., M. J. Mendell, K. Shekhar, T. Hotchi, D. Sullivan, S. Streufert and W. B. Fisk Is CO₂ an Indoor Pollutant? Direct Effects of Low-to-Moderate CO₂ Concentrations on Human Decision-Making Performance. *Environ Health Perspect* **2012**, 20.
3. Whitmore, R., Clayton, A. and Akland, G. (2003) California portable classrooms study phase II: main study, final report, volume II, Sacramento, CA, California Air Resources Board.
4. Corsi, R.L., Torres, V.M., Sanders, M. and Kinney, K.A. (2002) Carbon dioxide levels and dynamics in elementary schools: :results of the TESIAS study, *Indoor Air 2002*, volume 2, pp. 74-79, Monterey, CA, Indoor Air 2002, Inc.
5. Persily, A.K. and Gorfain, J. (2008) Analysis of ventilation data from the U.S. Environmental Protection Agency Building Assessment Survey and Evaluation (BASE) Study, NISTIR-7145-Revised, Bethesda, MD, National Institute for Standards and Technology.
6. ASHRAE (2010). ANSI/ASHRAE Standard 62.1-2010. Ventilation for acceptable indoor air quality. Atlanta, GA, ASHRAE Inc.